

JACKSONVILLE ELECTRIC AUTHORITY

21 WEST CHURCH STREET • JACKSONVILLE, FL 32202-3139



September 11, 1996

RECEIVED
SEP 16 1996
BUREAU OF
AIR REGULATION

Mr. Jonathan Holtom

Title V Section
Mail Station 5505
Florida Dept. of Environmental Protection
2600 Blair Stone Road
Tallahassee, Florida 32399

Dear Mr. Holtom:

RE: Northside Generating Station
Kennedy Generating Station
Southside Generating Station
Title V Permit Applications -- Supplemental Information

Attached please find the permit revision dated May 1, 1995 removing the throughput limits on the fuel storage tanks at each of the above facilities.

Also enclosed is the permit revision dated July 16, 1996 removing the fuel sulfur limits at the Northside station and providing for using the CEMs to show continuous compliance with the SO₂ emission limit using a 24-hour midnight-to-midnight average.

Finally, please note that no information was provided for Unit 3 at the Southside station since that unit is no longer in service and the air operating permit has been allowed to expire. Southside Units 1 and 2 air operating permits were surrendered during the St. Johns River Power Park permitting process and the emissions were used as offsets for modeling PSD increment consumption.

was it extend by Rule? surrendered by letter 5-11-97 30-

Mr. Jonathan Holtom
September 11, 1996
Page Two

All of these conditions are reflected in the Title V permit application as previously submitted.

If you have any questions with regard to this matter, please contact Bert Gianazza of my staff at (904) 632-6247.

Sincerely,

A handwritten signature in black ink, consisting of several overlapping loops and a long horizontal line extending to the right.

Richard Breitmoser, P.E.
Vice-President
Environmental Health &
Safety Group

RB/NBG

TITLEV2

**REGULATORY & ENVIRONMENTAL
SERVICES DEPARTMENT**
Air Quality Division



May 1, 1995

Mr. Robert Leetch, P.E.
Department of Environmental Protection
Northeast District
7825 Baymeadows Way, Suite B200
Jacksonville, Florida 32256-7590

JACKSONVILLE ELECTRIC AUTHORITY

RECEIVED

MAY 03 1995

Environmental, Health
& Safety Department

**RE: Duval County - Air Pollution
JEA Generating Station Fuel Storage Tanks
Kennedy Permit No. AO16-225064
Northside Permit No. AO16-225069
Southside Permit No. AO16-225066**

Dear Mr. Leetch:

The City of Jacksonville, Regulatory and Environmental Services Department, Air Quality Division (AQD) received a request on March 31, 1995 from JEA to amend the above referenced permits (attachment). The request is to delete throughput limits and the associated record-keeping requirements. In accordance with the Standard Operating Agreement, AQD is referring this request to your office for processing and final agency action.

AQD has reviewed this request and provides the following recommendations.

1. Specific Condition 7. of each referenced permit limits the throughput of No. 6 and No. 2 fuel oil. AQD agrees with JEA that the throughput limits should be eliminated.
2. AQD recommends that the record-keeping requirements for fuel oil throughput be maintained. An estimate of emissions for the AOR and Title V inventories will require this data.




421 West Church Street - Suite 412
Jacksonville, Florida 32202-4111

Area Code 904/630-3484

Mr. Robert Leetch, P.E.
May 1, 1995
Page 2

Please contact me or Mr. Ronald L. Roberson at (904) 630-3484 for any additional information.

Very truly yours,



Richard L. Robinson, P.E.
Pollution Control Engineer

RLR/ecr

Attachment

c: ✓ Mr. Richard Breitmoser, P.E. - JEA
Mr. Wayne Tutt, AQD
AQD File 1700-A
AQD Permitting File