

**Mitchell, Bruce**

---

**To:** Zhu, Yi  
**Cc:** Fancy, Clair; Sheplak, Scott  
**Subject:** ARMS update for the JEA - Kennedy Generating Station's CT #7: 0310047-008-AV (Title V Revision permitting project)

7/11/2001

Dear Yi,

Please review the ARMS update for the above referenced permitting project (Title V Revision). Many thanks.

Bruce

## Mitchell, Bruce

---

**From:** Boutwell, Barbara  
**Sent:** Wednesday, July 11, 2001 9:05 AM  
**To:** Elizabeth Bartlett; Gracy Danois; Gregg Worley; Joel Huey; Walker, Elizabeth (AIR)  
**Cc:** Mitchell, Bruce  
**Subject:** New Posting #0310047

There is a new posting on Florida's website.

0310047008AV  
JEA - KENNEDY

Final Permit Revision

If you have any questions, feel free to contact me.

Thanks,  
Barbara

**Mitchell, Bruce**

---

**To:** Boutwell, Barbara  
**Cc:** Fancy, Clair; Sheplak, Scott  
**Subject:** Posting of FINAL T-5 permit revision package: JEA\_Kennedy Generating Station: 0310047-008-AV.

7/9/2001

Dear Barbara,

Please post the following FINAL T-5 permit revision package (0310047-008-AV), which can be found at:

o:Bar/Title V/Bruce/Permits/0310047.007AC.008AV

0310047.008AV.FD

0310047F.008AV

0310047.008AV.SOB

0310047G.008AV

0310047H.008AV

0310047U.008AV

Many thanks.

Bruce

**Mitchell, Bruce**

---

**To:** Gianazza, N. Bert  
**Cc:** Fancy, Clair; Sheplak, Scott  
**Subject:** RE: DRAFT LETTER

5/18/2001

Dear Bert,

The draft letter looks fine. I had not seen your e-mail, dated 5/17/01, until after we had talked this morning about including a request to include the incorporation of the permit change made to S.C. #40 in 0310047-002-AC on 5/22/2000. So, if you would add the blurb regarding that permit change, I will make an Admin. Permit Correction to the Title V Permit first and then add the changes in the FINAL Title V Permit, 0310047-008-AV. Take care.

Bruce

-----Original Message-----

From: Gianazza, N. Bert [mailto:GianNB@jea.com]  
Sent: Thursday, May 17, 2001 11:26 AM  
To: Mitchell, Bruce  
Subject: DRAFT LETTER

Bruce, for your review and comment prior to issuance.

Tx, Bert

<<Mitchell13.doc>>

## Mitchell, Bruce

---

**From:** Boutwell, Barbara  
**Sent:** Thursday, May 10, 2001 12:16 PM  
**To:** Elizabeth Bartlett; Fillingim, Mary; Gracy Danois; Gregg Worley; Joel Huey; Walker, Elizabeth (AIR)  
**Cc:** Mitchell, Bruce  
**Subject:** New Posting #0310047

There is a new posting on Florida's website.

0310047008AV  
JEA - KENNEDY

Proposed Permit Revision

If you have any questions, feel free to contact me.

Thanks,  
Barbara

**Mitchell, Bruce**

---

**To:** Boutwell, Barbara  
**Cc:** Fancy, Clair; Sheplak, Scott  
**Subject:** Posting of PROPOSED Title V Permit package: JEA \_ Kennedy Generating Station: 0310047-008-AV

5/9/2001

Dear Barbara,

Please post the above referenced permit package at:  
o:\Bar\Title V\Bruce\Permits.0310047.007AC.008AV  
Many thanks.

0310047P.008.FEDNO

Bruce T.doc

## Mitchell, Bruce

---

**From:** Richard Robinson [ROBINSON@coj.net]  
**Sent:** Monday, March 26, 2001 2:50 PM  
**To:** Mitchell, Bruce  
**Cc:** Ron Roberson; Wayne Tutt; Wayne Walker; Jerry Woosley; Chris.Kirts@dep.state.fl.us  
**Subject:** Draft JEA Kennedy AC & AV Permits

Bruce,

I took a quick look at the subject draft permit package and noticed that our agency address and phone number require updating. Please use the following mailing address and phone number:

City of Jacksonville  
Regulatory and Environmental Services Department  
Air and Water Quality Division  
117 West Duval Street, Suite 225  
Jacksonville, FL 32202  
904-630-4900

The following are the 3 places I noticed where our address and phone number need updating: 1. Page 3 of the Public Notice, 2. Permit Cover Page, 3. Page 5, Section II, Facility-wide Condition 11. Please update prior to final issuance.

Thanks,  
Richard

21 West Church Street  
Jacksonville, Florida 32202-3139

RECEIVED

FEB 15 2001

BUREAU OF AIR REGULATION

February 13, 2001



Clair H. Fancy, P.E.  
Chief, Bureau of Air Regulation  
Florida Department of Environmental Protection  
Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, FL 32399-2400

E L E C T R I C

W A T E R

S E W E R

RE: Kennedy Generating Station Combustion Turbine CT 7  
Air Construction Permit 0310047-002-AC  
Title V Operating Permit 0310047-006-AV  
Request for Permit Revision

Dear Mr. Fancy:

Per my conversation with Bruce Mitchell, please issue permit revisions to the above referenced permits changing Specific Condition 31 in the construction permit and Specific Condition D 24 in the Title V permit from requiring stack testing to be performed at 95-100% of capacity to requiring stack testing to be performed at 90-100% of capacity. It is my understanding that these revisions can be performed simultaneously to reduce processing time.

These revisions will make the specific conditions consistent with the new combustion turbine stack testing guidance DARM-OGG-07, "Guidance on Rate of Operation during Compliance Testing for Combustion Turbines" dated March 1, 2000.

If you have any questions with regard to this matter, please call me at (904) 665-6247.

Sincerely,

A handwritten signature in black ink, appearing to read "N. Bert Gianazza".

N. Bert Gianazza, P.E.  
Environmental Permitting  
& Compliance

cc: Bruce Mitchell, P.E., FDEP