

# Florida Department of Environmental Protection

## Memorandum

---

TO: Joseph Kahn, Division of Air Resource Management  
THROUGH: Trina Vielhauer, Bureau of Air Regulation  
Jon Holtom, Title V Section  
FROM: Tom Cascio  
DATE: March 3, 2010  
SUBJECT: Title V Air Operation Permit Revision No. 0310047-020-AV  
JEA  
Kennedy Generating Station  
Final Title V Air Operation Permit Revision

The final permit revision for this project is attached for your approval and signature.

The attached Final Determination identifies issuance of the draft/proposed Title V air operation permit revision, and summarizes the publication process. There were two minor comments received from the applicant, and none from the public or EPA in response to the draft/proposed permit revision during the review period.

I recommend your approval of the attached final permit revision for this project.

Attachments

**NOTICE OF FINAL PERMIT REVISION**

*In the Matter of an  
Application for Permit Revision by:*

JEA  
21 West Church Street  
Jacksonville, Florida 32202

Permit Revision No. 0310047-020-AV  
Kennedy Generating Station  
Title V Air Operation Permit Revision  
Duval County


*Responsible Official:*

Dr. James M. Chansler, P.E., D.P.A., Chief  
Operating Officer

Enclosed is the final permit package to revise the Title V air operation permit for the Kennedy Generating Station by incorporating appropriate specific conditions of air construction permit No. 0310047-015-AC for commercial operation of Combustion Turbine (CT) No. 8 into the permit. The existing facility is located in Duval County at 4215 Talleyrand Avenue, Jacksonville, Florida. This permit revision is issued pursuant to Chapter 403, Florida Statutes.

Any party to this order has the right to seek judicial review of it under Section 120.68 of the Florida Statutes by filing a notice of appeal under Rule 9.110 of the Florida Rules of Appellate Procedure with the clerk of the Department of Environmental Protection in the Office of General Counsel (Mail Station #35, 3900 Commonwealth Boulevard, Tallahassee, Florida, 32399-3000) and by filing a copy of the notice of appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal. The notice must be filed within 30 days after this order is filed with the clerk of the Department.

Executed in Tallahassee, Florida.



Trina L. Vielhauer, Chief  
Bureau of Air Regulation

TLV/jkh/tbc


**CERTIFICATE OF SERVICE**

The undersigned duly designated deputy agency clerk hereby certifies that this Notice of Final Permit Revision (including the Final Permit Revision and Final Determination), or a link to these documents available electronically on a publicly accessible server, was sent by electronic mail with received receipt requested to the persons listed below:

- Dr. James M. Chansler, P.E., D.P.A., JEA: [chanjm@jea.com](mailto:chanjm@jea.com)
- Mr. Bert Gianazza, JEA: [GianNB@jea.com](mailto:GianNB@jea.com)
- Ms. Katy Forney, US EPA Region 4: [forney.kathleen@epa.gov](mailto:forney.kathleen@epa.gov)
- Ms. Ana Oquendo, US EPA Region 4: [oquendo.ana@epa.gov](mailto:oquendo.ana@epa.gov)
- Mr. Richard L. Robinson, City of Jacksonville: [robinson@coj.net](mailto:robinson@coj.net)
- Mr. Chris Kirts, P.E., Northeast District Office: [christopher.kirts@dep.state.fl.us](mailto:christopher.kirts@dep.state.fl.us)
- Ms. Barbara Friday, DEP BAR: [barbara.friday@dep.state.fl.us](mailto:barbara.friday@dep.state.fl.us) (for posting with U.S. EPA, Region 4)
- Ms. Victoria Gibson, DEP BAR: [victoria.gibson@dep.state.fl.us](mailto:victoria.gibson@dep.state.fl.us) (for reading file)

Clerk Stamp

**FILING AND ACKNOWLEDGMENT FILED**, on this date, pursuant to Section 120.52(7), Florida Statutes, with the designated agency clerk, receipt of which is hereby acknowledged.

 3/9/10  
(Clerk) (Date)

## FINAL DETERMINATION

---

### PERMITTEE

JEA  
21 West Church Street  
Jacksonville, Florida 32202

### PERMITTING AUTHORITY

Florida Department of Environmental Protection (Department)  
Division of Air Resource Management  
Bureau of Air Regulation, Title V Section  
2600 Blair Stone Road, MS #5505  
Tallahassee, Florida 32399-2400

### PROJECT

Permit Revision No. 0310047-020-AV  
Kennedy Generating Station

The purpose of this project is to revise Title V air operation permit No. 0310047-016-AV by incorporating appropriate specific conditions of air construction permit No. 0310047-015-AC for commercial operation of Combustion Turbine (CT) No. 8 into the permit.

### NOTICE AND PUBLICATION

The Department distributed an Intent to Issue a Title V Air Operation Permit Revision (draft/proposed) package on December 9, 2009. The applicant published the Public Notice of Intent to Issue a Title V Air Operation Permit Revision in the Florida Times-Union on January 7, 2010. The Department received the proof of publication on January 22, 2010.

### COMMENTS

#### Applicant Comments

Two minor comments of an administrative nature were received from the applicant as described below.

#### **Comment 1:**

**DLN System.** Draft/Proposed Specific Condition C.5., regarding the "DLN" combustion system, requires that JEA operate and maintain a "DLN 2.6 system." The air construction permit, however, allowed JEA to operate and maintain a DLN 2.6 system "(or better)." JEA requests that Condition C.5. be revised to include the parenthetical phrase allowing a better DLN system to be used and not limiting the system to only a 2.6 system. Because this unit is expected to be operated for thirty or more years, JEA expects that better systems will be available in the future, and at some point the 2.6 system may become outdated. This change in the permit language would give JEA the flexibility to ensure that the system is appropriately maintained and allow updated equipment to be used.

#### **Response 1:**

This change is acceptable to the Department and the change to the specific condition will be made as noted below. Double underline indicates added text. However, the permittee is advised that any planned significant upgrades to the equipment may need an air construction permit to implement.

**C.5. DLN Combustion.** The permittee shall operate and maintain the General Electric DLN 2.6 combustion system (or better) to control NO<sub>x</sub> emissions from the combustion turbine when firing natural gas. The system shall be maintained and tuned in accordance with the manufacturer's recommendations, industry standards or determined best practices. [0310047-015-AC, Specific Condition 5; 0310047-019-AC]

## FINAL DETERMINATION

---

### **Comment 2:**

**NO<sub>x</sub> Limit.** Draft/Proposed Specific Condition C.12. includes the 3-hour pound-per-hour limits for nitrogen oxides, consistent with the construction permit, but omits the language that had been included in footnote “b” in the air construction permit specifying when and how compliance with the pound-per-hour limits is to be demonstrated. Footnote “b” in the air construction permit included the following sentence which should be repeated in the Title V permit: “Compliance with the NO<sub>x</sub> emissions limit (lb/hr) shall be demonstrated by converting the NO<sub>x</sub> CEMS data collected during the initial CO test by using the applicable F-Factor and EPA Method 19.” This provision from the construction permit makes it clear that compliance with the 3-hour limit was required only during the initial testing and not on a continuous or annual basis. This sentence should therefore be included in the Title V permit as well, as part of footnote b of Condition C.12.

### **Response 2:**

The Department agrees that annual testing for compliance with the NO<sub>x</sub> emissions limit expressed in pounds per hour (lb/hr) is not required. However, the deleted footnote was obsolete since it referred to the initial testing protocol and therefore was rightly removed from the specific condition. The limit was retained in the permit because it will be needed if special testing is warranted.

### **Public and EPA Comments**

No comments were received from the public at large or the EPA Region 4 Office on the draft/proposed permit revision.

### **CONCLUSION**

The final action of the Department is to issue the permit revision with the one administrative change indicated above.

## STATEMENT OF BASIS

### PROJECT DESCRIPTION

The applicant applied on September 21, 2009, to revise the Title V air operation permit 0310047-016-AV for the Kennedy Generating Station to incorporate specific conditions from construction permit No. 0310047-015-AC for commercial operation of the new Combustion Turbine (CT) No. 8 into the permit.

### FACILITY DESCRIPTION

The existing facility consists of the following emissions units: Two combustion turbines (CT Nos. 7 and 8) and a fuel oil storage tank farm. Both of the combustion turbines are authorized to fire distillate oil and natural gas.

### PRIMARY REGULATORY REQUIREMENTS

The existing facility is regulated under:

Title III: The facility is not identified as a potential major source of hazardous air pollutants (HAP).

Title IV: The facility operates units subject to the acid rain provisions of the Clean Air Act.

Title V: The facility is a Title V major source of air pollution in accordance with Chapter 213, Florida Administrative Code (F.A.C.).

PSD: The facility is a Prevention of Significant Deterioration (PSD)-major source of air pollution in accordance with Rule 62-212.400, F.A.C.

NSPS: The facility operates units subject to the New Source Performance Standards (NSPS) of 40 Code of Federal Regulations (CFR) 60.

CAIR: The facility is subject to the Clean Air Interstate Rule (CAIR) set forth in Rule 62-296.470, F.A.C.

### APPLICABLE REGULATIONS

In addition to federal rules above, this facility is subject to the following state rules:

APPLICABLE REGULATIONS	EU ID
Rule 62-4, F.A.C. (Permitting Requirements)	015, 016
Rule 62-204, F.A.C. (Ambient Air Quality Requirements, PSD Increments, and Federal Regulations Adopted by Reference)	
Rule 62-210, F.A.C. (Permits Required, Public Notice, Reports, Stack Height Policy, Circumvention, Excess Emissions, and Forms)	
Rule 62-212, F.A.C. (Preconstruction Review, PSD Review and BACT)	
Rule 62-213, F.A.C. (Title V Air Operation Permits for Major Sources of Air Pollution)	
Rule 62-296, F.A.C. (Emission Limiting Standards)	
Rule 62-297, F.A.C. (Test Methods and Procedures, Continuous Monitoring Specifications, and Alternate Sampling Procedures)	
NSPS - 40 CFR 60, Subpart GG, Standards of Performance for Stationary Combustion Turbines, adopted and incorporated by reference in Rule 62-204.800, F.A.C.	015
NSPS - 40 CFR 60, Subpart KKKK, Standards of Performance for Stationary Combustion Turbines, adopted and incorporated by reference in Rule 62-204.800, F.A.C.	016
Rule 62-214, F.A.C. (Requirements For Sources Subject To The Federal Acid Rain Program)	015, 016
Federal Acid Rain Program, Phase II	
0310047-002-AC	015
0310047-015-AC; 0310047-018; 0310047-019	016

## STATEMENT OF BASIS

---

### PROJECT REVIEW

This project removes CT Nos. 3, 4 and 5 (EU-003, 004 and 005) from the facility's Title V permit and adds CT No. 8 (EU-016). Changes to the permit are noted in ~~striketrough~~ for text deletion and double underline for text addition.

### CONCLUSION

This project revises Title V air operation permit No. 0310047-016-AV, which was issued on January 1, 2008. This Title V Air Operation Permit Revision is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and Chapters 62-4, 62-210, 62-213 and 62-214, F.A.C.

**TITLE V AIR OPERATION PERMIT**

Final Permit Revision No. 0310047-020-AV  
(Second Revision to Permit No. 0310047-016-AV)

**Permittee**

JEA  
Kennedy Generating Station  
Facility ID No. 0310047  
Duval County, Florida

**Permitting Authority**

Florida Department of Environmental Protection  
Division of Air Resource Management  
Bureau of Air Regulation  
Title V Section  
Mail Station #5505  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400  
Telephone: 850/488-0114  
Fax: 850/921-9533

**Compliance Authority**

City of Jacksonville  
Environmental and Compliance Department  
Environmental Quality Division  
407 North Laura Street, Third Floor  
Jacksonville, Florida 32202  
Telephone: 904/ 255-7100  
Fax: 904/ 588-0518

# TABLE OF CONTENTS

Final Permit Revision No. 0310047-020-AV

Section	Page Number
Placard Page.....	1
I. Facility Information.....	2
A. Facility Description	
B. Emissions Units Summary	
II. Facility-wide Conditions.....	3
III. Emissions Units and Conditions.	
A. [Reserved.].....	4
B. Emissions Unit -015: 170.0 MW Combustion Turbine No. 7.....	5
C. Emissions Unit -016: 172.0 MW Combustion Turbine No. 8.....	11
IV. Acid Rain Part.	
A. Acid Rain.....	17
V. CAIR Part. ....	31
VI. Appendices.	
Appendix A-1. Citation Formats.	
Appendix I-1. List of Insignificant Emissions Units and Activities.	
Appendix U-1. List of Unregulated Emissions Units and Activities.	
Appendix GC. General Conditions.	
Appendix CC. Common Conditions.	
Appendix STR. Stack Testing Requirements.	
Appendix CS. Table 297.310-1 Calibration Schedule.	
Appendix NA. NSPS Subpart A, General Provisions.	
Appendix NGG. NSPS Subpart GG, Stationary Gas Turbines.	
Appendix NKKKK, NSPS Subpart KKKK, Stationary Gas Turbines.	
Appendix TV-6. Title V Conditions.	
Appendix JEPB. Rule 2 Conditions.	
Appendix H. Permitting History.	





# Florida Department of Environmental Protection

Bob Martinez Center  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

Charlie Crist  
Governor

Jeff Kottkamp  
Lt. Governor

Michael W. Sole  
Secretary

**Permittee:**

JEA  
21 West Church Street  
Jacksonville, Florida 32202

**Final Permit No.** 0310047-020-AV

**Facility ID No.** 0310047

**SIC No.** 4911

**Project:** Title V Air Operation Permit  
Revision for CT No. 8

This permit revision authorizes JEA to commercially operate the new Combustion Turbine (CT) No. 8 at the Kennedy Generating Station. This facility is located in Duval County at 4215 Talleyrand Avenue, Jacksonville, Florida. The UTM coordinates are: Zone 17, 440.065 km East and 3359.150 km North.

This Title V air operation permit revision is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and Florida Administrative Code (F.A.C.) Chapters 62-4, 62-210, 62-213 and 62-214. The above named permittee is hereby authorized to perform the work or operate the facility shown on the application and approved drawings, plans, and other documents, attached hereto or on file with the permitting authority, in accordance with the terms and conditions of this permit.

**0310047-016-AV Renewal Effective Date:** January 1, 2008

**0310047-017-AV Revision Effective Date:** March 27, 2009

**0310047-020-AV Revision Effective Date:** March 3, 2010

**Renewal Application Due Date:** May 20, 2012

**Expiration Date:** December 31, 2012

Joseph Kahn, Director  
Division of Air Resource Management

JK/tlv/jkh/tbc

---

## SECTION I. FACILITY INFORMATION

---

### Subsection A. Facility Description.

This facility consists of two combustion turbines (CT Nos. 7 and 8) and a fuel oil storage tank farm. Both of the combustion turbines fire distillate oil and natural gas. Also included in this permit are miscellaneous unregulated and insignificant emissions units and activities.

Based on the Title V permit renewal application received May 30, 2007, this facility is not a major source of hazardous air pollutants.

For CT Nos. 7 and 8, there are specific nitrogen oxides (NO<sub>x</sub>) emissions limiting standards, a water injection system is used to reduce NO<sub>x</sub> emissions when firing distillate oil, and NO<sub>x</sub> emissions are greater than 100 tons per year. However, a CAM plan is not required because compliance with the NO<sub>x</sub> standards is continuously demonstrated by data collected with the continuous emissions monitoring system (CEMS).

### Subsection B. Emissions Units Summary

#### *Regulated Emissions Units and Activities*

<u>EU No.</u>	<u>Description</u>
-003	CT No. 3 (permanently shut down)
-004	CT No. 4 (permanently shut down)
-005	CT No. 5 (permanently shut down)
-007	Boiler No. 8 (currently deactivated – Acid Rain Unit)
-008	Boiler No. 9 (currently deactivated – Acid Rain Unit)
-009	Boiler No. 10 (currently deactivated – Acid Rain Unit)
-015	CT No. 7 (Acid Rain Unit)
-016	CT No. 8 (Acid Rain Unit)

#### *Unregulated Emissions Units and Activities*

<u>EU No.</u>	<u>Description</u>
-010	Storage Tanks (tanks 1 and 4)
-014	Storage Tank (tank 13)

Please reference the Permit No., Facility ID No., and appropriate Emissions Unit ID Nos. on all correspondence, test report submittals, applications, etc.

## SECTION II. FACILITY-WIDE CONDITIONS

---

1. **Not federally enforceable. Odor Nuisance.** Pursuant to Jacksonville Ordinance Code (JOC) Chapter 376, any facility that causes or contributes to the emission of objectionable odors, which results in the City of Jacksonville's Environmental Resource Management Department - Environmental Quality Division (EQD) receiving and validating complaints from five (5) or more different households within a 90 day period, can be cited for objectionable odors. [JOC Chapter 376]
2. **Prevention of Accidental Releases (Section 112(r) of CAA).**
  - a. The permittee shall submit its Risk Management Plan (RMP) to the Chemical Emergency Preparedness and Prevention Office (CEPPO) RMP Reporting Center when, and if, such requirement becomes applicable. Any Risk Management Plans, original submittals, revisions or updates to submittals, should be sent to: RMP Reporting Center, Post Office Box 10162, Fairfax, VA 22038. The telephone number is (703) 227-7650. [40 CFR 68]
  - b. The permittee shall submit to the permitting authority Title V certification forms or a compliance schedule in accordance with Rule 62-213.440(2), F.A.C. [40 CFR 68]
3. **Notifications and Reports.** The permittee shall submit all compliance related notifications and reports required of this permit to the EQD at the following address: City of Jacksonville, Environmental and Compliance Department, Environmental Quality Division, 407 North Laura Street, Third Floor, Jacksonville, Florida 32202. The EQD telephone number is 904/ 255-7100 and facsimile number is 904/ 588-0518. Copies of all such documents shall be submitted to: Department of Environmental Protection, Northeast District, Air Resources, 7825 Baymeadows Way, Suite 200B, Jacksonville, Florida 32256-7590. The District telephone number is 904/807-3300 and facsimile number is 904/448-4363.
4. **U.S. EPA Region 4.** Any reports, data, notifications, certifications, and requests required to be sent to the United States Environmental Protection Agency, Region 4, should be sent to: United States Environmental Protection Agency, Region 4, Air, Pesticides & Toxics Management Division, Air & EPCRA Enforcement Branch, Air Enforcement Section, 61 Forsyth Street, Atlanta, Georgia 30303-8960. The telephone number is 404/562-9155 and the facsimile number is 404/562-9163.
5. **Not federally enforceable. Local Program Regulations.** The facility is subject to the JOC, Title X, Chapter 360 [Environmental Regulation], Chapter 362 [Air and Water Pollution], Chapter 376 [Odor Control], and City of Jacksonville Environmental Protection Board (JEPB) Rule 85-1 [Final Rules with Respect to Organization, Procedures, and Practice]. Appendix JEPB provides the applicable rules of the JEPB contained in Rule 2, Air Pollution Control, and the corresponding rules of the Department that have been adopted by reference and within the SOA (Specific Operating Agreement) signed with the Department.
6. **Statement of Compliance.** The annual statement of compliance pursuant to Rule 62-213.440(3)(a)2., F.A.C., shall be submitted to the Department, or its designee, and the EPA within 60 (sixty) days after the end of the calendar year using DEP Form No. 62-213.900(7), F.A.C. This condition implements the requirements of Rules 62-213.440(3)(a)2. & 3., F.A.C. See Condition 51. of Appendix TV-6, Title V Conditions. [Rules 62-213.440(3) and 62-213.900, F.A.C.]
7. **Certification by Responsible Official (RO).** In addition to the professional engineering certification required for applications by Rule 62-4.050(3), F.A.C., any application form, report, compliance statement, compliance plan and compliance schedule submitted pursuant to Chapter 62-213, F.A.C., shall contain a certification signed by a responsible official that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete. Any responsible official who fails to submit any required information or who has submitted incorrect information shall, upon becoming aware of such failure or incorrect submittal, promptly submit such supplementary information or correct information. [Rule 62-213.420(4), F.A.C.]
8. **Appendices.** The Appendices attached to this permit are attached as an enforceable part of the permit unless otherwise indicated.

**SECTION III. EMISSIONS UNIT SPECIFIC CONDITIONS**  
**SUBSECTION A. [RESERVED.]**

---

**SECTION III. EMISSIONS UNIT SPECIFIC CONDITIONS**  
**SUBSECTION B. COMBUSTION TURBINE 7**

---

**EMISSIONS UNITS**

<u>EU No.</u>	<u>Description</u>
-015	CT No. 7

Emissions unit -015 is a CT manufactured by General Electric (Model PG 7241 FA) and is designated as CT No. 7. CT No. 7 began commercial operation on April 30, 2000, and replaced Boiler No. 10 (EU No. -009) identified by JEA as KE10. It is a simple cycle unit consisting of a nominal 170 MW (at 59° F) CT-electrical generator set equipped with Dry Low NO<sub>x</sub> (DLN-2.6) combustors. The maximum heat input from firing natural gas is 1623 MMBtu/hour based on a compressor inlet temperature 59° F, 60% relative humidity, and the LHV of gas. The maximum heat input from firing distillate oil is 1822 MMBtu based on a compressor inlet temperature of 59° F, 60% relative humidity, and the LHV of oil. CT No. 7 is a peaking unit used during peak demand times and emergencies. Exhaust gas exits a stack that is 24 feet in diameter and 90 feet tall.

This emissions unit is regulated under 40 CFR 60, Subpart GG, Standards of Performance for Stationary Gas Turbines, adopted by reference in Rule 62-204.800, F.A.C.; and 40 CFR 60, Subpart A, adopted by reference in Rule 62-204.800, F.A.C.

**ESSENTIAL PTE PARAMETERS**

**B.1. Permitted Capacity.** Based on 100% load, the LHV of each fuel, a compressor inlet temperature of 59° F and ambient conditions of 60% relative humidity and 14.7 psi, the maximum heat input rates for CT No. 7 are:

<u>EU No.</u>	<u>MMBtu/hour</u>	<u>Fuel Type</u>
7	1623.0	Natural Gas
	1822.0	Distillate Oil

The maximum heat input rate will vary depending upon the CT inlet conditions and the CT characteristics. Manufacturer's curves corrected for site conditions or equations for correction to other ambient conditions shall be provided to the Department and/or the EQD office(s) upon request. [Rules 62-4.160(2) and 62-210.200(PTE), F.A.C. and 0310047-002-AC]

**B.2. Emissions Unit Operating Rate Limitation After Testing.** See specific condition **B.21.** [Rule 62-297.310(2), F.A.C.]

**B.3. Methods of Operation, Fuels.** CT No. 7 shall fire only natural gas and new No. 2 distillate oil, or better. [Rule 62-213.410(1), F.A.C. and 0310047-002-AC]

**B.4. Hours of Operation.** The maximum allowable hours of operation in any 12-month period (MAXHROP) for CT No. 7 are 4050 hours on natural gas and 1260 hours on distillate oil or the hours calculated pursuant to the following formula:

$$\text{MAXHROP} = 4050 - (3.215 \times \text{ACTHROPFO})$$

Where: ACTHROPFO = actual hours of operation on fuel oil.

[Rules 62-4.160(2) and 62-210.200(PTE), F.A.C. and 0310047-002-AC]

**CONTROL TECHNOLOGY**

**B.5. DLN Combustion.** DLN combustors shall be installed and operated on CT No. 7 to control NO<sub>x</sub> emissions when firing natural gas. The DLN combustion system shall be tuned to optimize emissions reductions and shall be maintained to minimize NO<sub>x</sub> emissions and carbon monoxide (CO) emissions. [0310047-002-AC]

**SECTION III. EMISSIONS UNIT SPECIFIC CONDITIONS**  
**SUBSECTION B. COMBUSTION TURBINE 7**

---

**B.6. Water Injection System, Oil Firing.** A water injection system shall be installed and operated to control NO<sub>x</sub> emissions when firing distillate oil. [0310047-002-AC]

**EMISSION LIMITATIONS AND STANDARDS**

{Permitting Note: Unless otherwise specified, the averaging time is based on the specified averaging time of the applicable test method.}

**B.7. VE and Particulate Matter (PM) Emissions.** VE shall not exceed 10 percent opacity when firing natural gas or distillate oil. {Permitting Note: Permit No. 0310047-002-AC specified a PM emissions limit of 17 lbs/hour (non-condensable only) when firing distillate oil. As allowed by this permit, the permittee elected an opacity limit of 10 percent when firing oil in lieu of the PM emissions limit and testing requirement.} [0310047-002-AC and Application No. 0310047-016-AV]

**B.8. Sulfur Content, Distillate Oil.** The sulfur content of distillate oil shall not exceed 0.05 percent, by weight. [0310047-002-AC]

**B.9. NO<sub>x</sub> Emissions, Natural Gas.** While burning natural gas, the concentration of NO<sub>x</sub> in the exhaust gas shall not exceed 15 ppmvd at 15% oxygen (O<sub>2</sub>) based on 24-hour block average as measured by the CEMS maintained in accordance with 40 CFR 75. In addition, NO<sub>x</sub> emissions calculated as NO<sub>2</sub> shall exceed neither 15 ppmvd at 15% O<sub>2</sub> nor 99 lbs/hour to be demonstrated by stack test. Total annual NO<sub>x</sub> emissions shall not exceed 200 tons on a 12-month rolling total basis from firing any combination of permitted fuels. [0310047-002-AC; 0310047-013-AC; Rule 62-212.400(12)(b), F.A.C.; and 40 CFR 75]

**B.10. NO<sub>x</sub> Emissions, Distillate Oil.** While burning distillate oil, the concentration of NO<sub>x</sub> in the exhaust gas shall not exceed 42 ppmvd at 15% O<sub>2</sub> based on a 24-hour block average as measured by the CEMS maintained in accordance with 40 CFR 75. In addition, NO<sub>x</sub> emissions calculated as NO<sub>2</sub> shall exceed neither 42 ppmvd at 15% O<sub>2</sub> nor 318 lbs/hour to be demonstrated by stack test. Total annual NO<sub>x</sub> emissions shall not exceed 200 tons on a 12-month rolling total basis from firing any combination of permitted fuels. [0310047-002-AC; 0310047-013-AC; Rule 62-212.400(12)(b), F.A.C.; and 40 CFR 75]

**B.11. CO Emissions.** The concentration of CO in the exhaust gas shall not exceed 15 ppmvd (natural gas) and 20 ppmvd (fuel oil) as measured by EPA Method 10. CO emissions shall not exceed 48 lbs/hour (natural gas) and 97 lbs/hour (fuel oil) to be demonstrated by stack test. [0310047-002-AC and 0310047-013-AC]

**B.12. Volatile Organic Compounds (VOC) Emissions.** The concentration of VOC in the exhaust gas shall not exceed 1.4 ppmvd (natural gas) and 3.5 ppmvd (distillate oil) as determined by EPA Methods 18, 25 or 25A. VOC emissions shall not exceed 2.9 lbs/hour (natural gas) and 19 lbs/hour (distillate oil). [0310047-002-AC and 0310047-013-AC]

**B.13. Sulfur Dioxide (SO<sub>2</sub>) Emissions.** SO<sub>2</sub> emissions shall not exceed 9.7 lbs/hour when firing pipeline natural gas and 98 lbs/hour when firing distillate oil. Emissions of SO<sub>2</sub> shall not exceed 62 tons per year. Compliance with these limits shall be demonstrated by complying with the fuel sulfur monitoring and fuel consumption monitoring requirements of this subsection. [0310047-002-AC; 0310047-013-AC; and Rule 62-212.400(12)(b), F.A.C.]

**SECTION III. EMISSIONS UNIT SPECIFIC CONDITIONS**  
**SUBSECTION B. COMBUSTION TURBINE 7**

---

**EXCESS EMISSIONS**

{Permitting Note: The Excess Emissions Rule at Rule 62-210.700, F.A.C., cannot vary any requirement of an NSPS, NESHAP or Acid Rain program provision.}

**B.14. Excess Emissions, Allowed.** See Appendix CC of this permit. [Rule 62-210.700(1), F.A.C.]

**B.15. Excess Emissions, Prohibited.** See Appendix CC of this permit. [Rule 62-210.700(4), F.A.C.]

**PERFORMANCE TEST METHODS AND PROCEDURES**

**B.16. Testing Requirements.** See Appendix STR (Stack Testing Requirements) of this permit for notification, testing, recordkeeping and reporting requirements regarding a performance test. [Chapter 62-297, F.A.C.]

**B.17. Test Methods.** When conducting emissions tests, the following reference methods shall be used.

- a. EPA Method 5 or 17, "Determination of Particulate Emissions from Stationary Sources".
- b. EPA Method 9, "Visual Determination of the Opacity of Emissions from Stationary Sources".
- c. EPA Method 10, "Determination of Carbon Monoxide Emissions from Stationary Sources".
- d. EPA Method 20, "Determination of Nitrogen Oxides, Sulfur Dioxide and Diluent Emissions from Stationary Gas Turbines".
- e. EPA Reference Method 18 or 25 and/or 25A, "Determination of Volatile Organic Concentrations".

No other test methods may be used for compliance testing unless prior Department approval is received in writing. These reference methods are provided in 40 CFR 60, Appendix A, and adopted by reference in Rule 62-204.800, F.A.C. [40 CFR 60; 40 CFR 60.8; and 0310047-002-AC]

**B.18. Annual Tests Required.** During each federal fiscal year (October 1 - September 30), an annual compliance tests shall be performed in accordance with the specified EPA Reference methods for the following pollutants.

- a. CO Emissions: Annual compliance testing for CO may be conducted at less than capacity when compliance testing is conducted concurrent with the annual NO<sub>x</sub> RATA testing, which is performed pursuant to 40 CFR 75. [0310047-002-AC; 40 CFR 60; 40 CFR 75; and Rule 62-297.310(7), F.A.C.]
- b. NO<sub>x</sub> Emissions: Annual compliance testing for NO<sub>x</sub> is not required. Continuous compliance with the NO<sub>x</sub> standards shall be demonstrated by the CEMS maintained in accordance with 40 CFR 75. {Permitting Note: The permittee conducted initial tests in accordance with EPA Method 20 to demonstrate compliance with Subpart GG in 40 CFR 60.} [0310047-002-AC; 40 CFR 60; and 40 CFR 75]
- c. VOC Emissions: No annual testing is required. Compliance with the CO emission limit serves as a surrogate. {Permitting Note: Pursuant to Permit No. 0310047-002-AC, the permittee conducted initial tests in accordance with EPA Method 25A to demonstrate compliance with VOC standards.} [0310047-002-AC]
- d. PM Emissions: No annual testing is required. Pursuant to Permit No. 0310047-002-AC, the permittee elected an opacity limit of 10 percent when firing oil in lieu of the PM limit and testing requirement. [0310047-002-AC and applicant requested]
- e. VE: An annual performance test is required to determine VE. Any combustion turbine that does not operate for more than 400 hours per year shall conduct a compliance test once per each five-year period, coinciding with the term of its air operation permit. {Permitting Note: Permit No. 0310047-002-AC specified a PM emissions limit of 17 lbs/hour (non-condensable only) when firing distillate oil. As allowed

**SECTION III. EMISSIONS UNIT SPECIFIC CONDITIONS**  
**SUBSECTION B. COMBUSTION TURBINE 7**

---

by this permit, the permittee elected an opacity limit of 10 percent when firing oil in lieu of the PM emissions limit and testing requirement.} [0310047-002-AC; Rule 62-297.310(7)(a)8., F.A.C.; and applicant requested]

f. SO<sub>2</sub> Emissions: No annual testing is required. Compliance with these limits shall be demonstrated by complying with the fuel sulfur monitoring and fuel consumption monitoring requirements of this subsection. [0310047-002-AC; 40 CFR 60; and 40 CFR 75]

**B.19. Continuous Compliance with the NO<sub>x</sub> Emission Limits.** Continuous compliance with the NO<sub>x</sub> emission limits shall be demonstrated with the CEMS based on the applicable averaging time of 24-hr block average. Based on CEMS data, a separate compliance determination is conducted at the end of each operating day and a new average emission rate is calculated from the arithmetic average of all valid hourly emission rates from the previous operating day. Valid hourly emission rates shall not include periods of start up, shutdown, or malfunction unless prohibited by Rule 62-210.700, F.A.C. A valid hourly emission rate shall be calculated for each hour in which at least two NO<sub>x</sub> concentrations are obtained at least 15 minutes apart. These excess emissions periods shall be reported as required in specific conditions **B.29.**, **B.30.** and **B.31.** [0310047-002-AC and 40 CFR 75]

**B.20. Compliance with the SO<sub>2</sub> and PM/PM<sub>10</sub> Emission Limits.** Notwithstanding the requirements of Rule 62-297.310(7), F.A.C., the method for determining compliance with the SO<sub>2</sub> and PM<sub>10</sub> standards is the use of natural gas (2 grains per 100 standard cubic feet, maximum) and distillate oil (0.05% sulfur by weight, maximum). [0310047-002-AC]

**B.21. Operating Rate During Testing.** Compliance testing shall be conducted with CT No. 7 operating at permitted capacity. Permitted capacity is defined as 90-100 percent of the manufacturer's rated heat input achievable for the average compressor inlet conditions during the test. If it is impracticable to test at permitted capacity, then the CT may be tested at less than permitted capacity. In such cases, the entire curve or table shall be adjusted downwards by the increment which reflects the reduced rate of operation at which compliance was demonstrated. This increment is equal to the difference between the manufacturer's heat input or fuel usage value and 110 percent of the value reached during the test. In this case, the data and calculations necessary to demonstrate the heat input or fuel usage rate correction shall be submitted to the Department with the compliance test report. Once the unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purpose of additional compliance testing to regain the authority to operate at the permitted capacity. Test procedures shall meet all applicable requirements (i.e., testing time frequency, minimum compliance duration, etc.) of Rule 62-204.800, F.A.C. {Permitting Note: The GE Heat Input Curves provided by the manufacturer are the nominal values to be used to aid in defining "full load" for stack testing purposes and do not constitute a limit on heat input.} [Rule 62-297.310(2), F.A.C. and 0310047-007-AC]

### **MONITORING OF OPERATIONS**

**B.22. Natural Gas Monitoring Schedule.** The following custom monitoring schedule for natural gas is approved in lieu of the daily sampling requirements of 40 CFR 60.334(b)(2):

- a. The permittee is committed to using a primary fuel of pipeline supplied natural gas (sulfur content less than 20 gr/100 scf pursuant to 40 CFR 75.11(d)(2)).
- b. This unit shall be monitored for SO<sub>2</sub> emissions using methods consistent with the requirements of 40 CFR 75.11 and certified by the EPA.. This custom fuel monitoring schedule will only be valid when pipeline natural gas is used as a primary fuel. If the primary fuel for this unit is changed to a higher sulfur fuel, SO<sub>2</sub> emissions must be accounted for as required pursuant to 40 CFR 75.11(d). [0310047-002-AC; 40 CFR 60; and 40 CFR 75]



**SECTION III. EMISSIONS UNIT SPECIFIC CONDITIONS**  
**SUBSECTION B. COMBUSTION TURBINE 7**

---

**B.23. Fuel Oil Monitoring Schedule.**

- a. For the purposes of demonstrating compliance with the SO<sub>2</sub> standard specified in this permit, the SO<sub>2</sub> standard in 40 CFR 60.333 and the limits on fuel sulfur content, the following sampling and analytical methods shall be used: ASTM D2880-71, 78 or 96, or D4294-98 (or equivalent) for the sulfur content of liquid fuels; and D1072-80 or 90 (Reapproved 1994), D3031-81, D4084-82 or D3246-81 or 94, or D3246-81, 92 or 96 (or equivalent) for the sulfur content of gaseous fuel. The owner or operator are responsible for ensuring that the procedures above are used for determination of fuel sulfur content.
- b. Analysis may be performed by the owner or operator, a service contractor retained by the owner or operator, the fuel vendor, or any other qualified agency pursuant to 40 CFR 60.335(d) and (e). For each shipment, the permittee shall retain records of the fuel sulfur analysis.

[0310047-002-AC; 0310047-013-AC; 40 CFR 60.335(d) & (e)]

**B.24. NO<sub>x</sub> and O<sub>2</sub> CEMS.** The permittee shall install, calibrate, maintain, and operate a CEMS in the stack to measure and record the NO<sub>x</sub> emissions and the O<sub>2</sub> content from this unit. Periods when NO<sub>x</sub> emissions (ppmv at 15% oxygen) are above the standards listed in this permit shall be provided to the Department's Bureau of Air Monitoring and Mobile Sources and the EQD pursuant to 40 CFR 75. [0310047-002-AC and 40 CFR 75]

**B.25. NO<sub>x</sub> CEMS in Lieu of Water-to-Fuel Ratio.** The NO<sub>x</sub> CEMS shall be used in lieu of the water-to-fuel ratio monitoring system for reporting excess emissions in accordance with 40 CFR 60.334(c)(1), Subpart GG. The calibration of the water-to-fuel ratio monitoring device required in 40 CFR 60.335(c)(2) will be replaced by the 40 CFR 75 certification tests of the NO<sub>x</sub> CEMS. Upon request from the Department and/or the EQD, the CEMS emission rates for NO<sub>x</sub> shall be corrected to ISO conditions to demonstrate compliance with the NO<sub>x</sub> standard in 40 CFR 60.332. [0310047-002-AC; 40 CFR 60; and 40 CFR 75]

**B.26. CEMS Requirements.** The NO<sub>x</sub> and O<sub>2</sub> CEMS shall comply with the certification and quality assurance, and any other applicable requirements of Rule 62-297.520, F.A.C., 40 CFR 60.13, including certification of each device in accordance with 40 CFR 60, Appendix B, Performance Specifications, and 40 CFR 60.7(a)(5) or 40 CFR 75. Quality assurance procedures must conform to all applicable sections of 40 CFR 60, Appendix F, or 40 CFR 75. Data on CEMS equipment specifications, manufacturer, type, calibration and maintenance needs shall be kept on file for future reference and use. [0310047-002-AC; 40 CFR 60; and 40 CFR 75]

**RECORDKEEPING AND REPORTING REQUIREMENTS**

**B.27. Records.** All measurements, records, and other data required to be maintained by the permittee shall be recorded in a permanent form and retained for at least five years following the date on which such measurements, records, or data are recorded. These records shall be made available to Department and/or EQD representatives upon request. [Rule 62-213.440, F.A.C. and 0310047-002-AC]

**B.28. Distillate Oil Consumption.** Records of the distillate oil consumption shall be maintained and made available to the Department and/or the EQD office(s) upon request. [Rule 62-213.440, F.A.C.]

**B.29. Excess Emissions, Notification.** See Appendix CC of this permit. [Rules 62-210.700(6) and 62-4.130, F.A.C. and 0310047-002-AC]

**B.30. Quarterly Excess Emissions Reports, Subpart GG.** With regard to the emissions standards in Subpart GG of 40 CFR 60, quarterly excess emission reports shall be submitted to the Department and EQD offices in accordance with 40 CFR 60.7(c). This unit shall comply with the CEMS frequency data report as specified in 40 CFR 60.7(c). Quarterly reports are due within 30 days following each calendar quarter. [0310047-002-AC; 0310047-013-AC; and 40 CFR 60.7(c)]

**SECTION III. EMISSIONS UNIT SPECIFIC CONDITIONS**  
**SUBSECTION B. COMBUSTION TURBINE 7**

---

**B.31. Quarterly Excess Emissions Reports, Permit Standards.** Periods of startup, shutdown, malfunction and fuel switching shall be monitored, recorded, and reported as excess emissions when emission levels exceed the permitted standards listed in this subsection. Following the same format in 40 CFR 60.7, quarterly excess emission reports shall be submitted to the Department and EQD offices. Quarterly reports are due within 30 days following each calendar quarter. [0310047-002-AC and 0310047-013-AC]

**MISCELLANEOUS**

**B.32. Operating Procedures.** Operating procedures shall include good operating practices and proper training of all operators and supervisors. The good operating practices shall meet the guidelines and procedures as established by the equipment manufacturers. All operators (including supervisors) of air pollution control devices shall be properly trained in plant specific equipment. [0310047-002-AC]

**B.33. New Source Performance Standards (NSPS).** CT No. 7 shall be in compliance with the applicable provisions of Subparts A and GG in 40 CFR 60 adopted by reference in Rule 62-204.800, F.A.C. The Subpart GG requirement to correct test data to ISO conditions applies. However, such correction is not required to demonstrate compliance with non-NSPS permit standards. See Appendix NA for the General Provisions and Appendix NGG for the Performance Standards for Stationary Gas Turbines. [0310047-002-AC and Subparts A and GG in 40 CFR 60]

**SECTION III. EMISSIONS UNIT SPECIFIC CONDITIONS**  
**SUBSECTION C. COMBUSTION TURBINE 8**

---

The specific conditions of this subsection apply to the following emissions unit.

EU No.	Emission Unit Description
-016	CT No. 8 – 172 MW General Electric PG7241 FA combustion turbine-electrical generator.

Emissions unit -016 is a combustion turbine (CT) manufactured by the General Electric Company (Model 7 FA) and is designated as CT No. 8. CT No. 8 began commercial operation on April 16, 2009. It is a simple cycle unit consisting of a nominal 172 MW (at 59° F) CT-electrical generator set equipped with Dry Low NO<sub>x</sub> (DLN-2.6) combustors. The nominal heat input rate to the combustion turbine is 1,804 MMBtu per hour when firing natural gas and 1,989 MMBtu per hour when firing distillate oil based on a compressor inlet air temperature of 59° F, the higher heating value (HHV) of each fuel, and 100% load. Exhaust gas exits a stack that is 18.0 feet in diameter and is 115 feet tall. Volumetric flow rate is 2,399,000 actual cubic feet per minute (acfm); exit temperature is 1,110 degrees Fahrenheit.

This emissions unit is regulated under 40 CFR 60, Subpart KKKK (Standards of Performance for Stationary Combustion Turbines for which Construction is Commenced after February 18, 2005), adopted by reference in Rule 62-204.800, F.A.C.; and 40 CFR 60, Subpart A, adopted by reference in Rule 62-204.800, F.A.C. The unit's construction was authorized by Department permits PSD-FL-386, PSD-FL-386A and PSD-FL-386B. A compliance assurance monitoring (CAM) plan is not required because compliance with the NO<sub>x</sub> standards is continuously demonstrated by data collected with the continuous emissions monitoring system (CEMS).

**APPLICABLE STANDARDS AND REGULATIONS**

- C.1. Permanent Shutdown.** The permittee was required to permanently shutdown CT Nos. 3, 4 and 5 (EU-003, 004 and 005) prior to commercial operation of CT No. 8 (EU-016). *{Permitting Note: Emissions decreases from the shutdown of these units were used in a PSD netting analysis to avoid PSD review on the new CT No. 8 for nitrogen oxides (NO<sub>x</sub>) and sulfur dioxide (SO<sub>2</sub>).}* [Rule 62-212.400(PSD), F.A.C.; 310047-015-AC, Specific Condition 1]
- C.2. BACT Determinations.** CT No. 8 was subject to determinations of the Best Available Control Technology (BACT) for particulate matter (PM/PM<sub>10</sub>). The project was minor for carbon monoxide (CO), nitrogen oxides (NO<sub>x</sub>), sulfur dioxide (SO<sub>2</sub>), and volatile organic compounds (VOC). [Rule 62-212.400(PSD), F.A.C.; 310047-015-AC, Specific Condition 2]
- C.3. NSPS Requirements.** The combustion turbine shall comply with the applicable New Source Performance Standards (NSPS) in 40 CFR 60, including: Subpart A (General Provisions) and Subpart KKKK (Standards of Performance for Stationary Combustion Turbines for which Construction is Commenced after February 18, 2005). See Appendix NA for the NSPS Subpart A provisions and Appendix NKKKK for the NSPS Subpart KKKK provisions. Separate reporting and monitoring may be required by the individual subparts. [Rule 62-204.800(8), F.A.C.; 40 CFR 60, Subparts A and KKKK; 310047-015-AC, Specific Condition 3]

**EQUIPMENT DESCRIPTION**

- C.4. Combustion Turbine.** The permittee is authorized to tune, operate, and maintain one General Electric Model PG7241(FA) combustion turbine-electrical generator set with a nominal generating capacity of 172 MW. The combustion turbine is equipped with a dry low-NO<sub>x</sub> (DLN) combustion system, automated combustion turbine control system, and an inlet air filtration system. The combustion turbine is designed for operation in simple cycle mode and has dual-fuel capability. [310047-015-AC, Specific Condition 4]

**SECTION III. EMISSIONS UNIT SPECIFIC CONDITIONS**  
**SUBSECTION C. COMBUSTION TURBINE 8**

---

**CONTROL TECHNOLOGY**

- C.5. DLN Combustion. The permittee shall operate and maintain the General Electric DLN 2.6 combustion system (or better) to control NO<sub>x</sub> emissions from the combustion turbine when firing natural gas. The system shall be maintained and tuned in accordance with the manufacturer's recommendations, industry standards or determined best practices. [0310047-015-AC, Specific Condition 5; 0310047-019-AC]
- C.6. Water Injection Technology. The permittee shall operate and maintain a water injection system to reduce NO<sub>x</sub> emissions when firing distillate oil. The system shall be maintained and tuned in accordance with the manufacturer's recommendations or industry standards. [0310047-015-AC, Specific Condition 6]

**PERFORMANCE REQUIREMENTS**

- C.7. Hours of Operation. The unit shall not operate more than 3,500 hours during any consecutive 12 months. Of this amount, the unit shall not fire distillate oil for more than 500 hours during any consecutive 12 months. [0310047-015-AC, Specific Condition 7; Rules 62-210.200(PTE) and 62-212.400(12), F.A.C.]
- C.8. Permitted Capacity. The nominal heat input rate to the combustion turbine is 1,804 MMBtu per hour when firing natural gas and 1,989 MMBtu per hour when firing distillate oil based on a compressor inlet air temperature of 59° F, the higher heating value (HHV) of each fuel, and 100% load. Heat input rates will vary depending upon combustion turbine characteristics, ambient conditions, and alternate methods of operation. The permittee has provided manufacturer's performance curves (or equations) that correct for site conditions to the Permitting and Compliance Authorities. Operating data may be adjusted for the appropriate site conditions in accordance with the performance curves and/or equations on file with the Department. [Rules 62-4.070(3), 62-212.400(PSD), and 62-210.200(PTE), F.A.C.; 0310047-015-AC, Specific Condition 8]
- C.9. Authorized Fuels. The combustion turbine shall fire natural gas as the primary fuel, which shall contain no more than 2 grains of sulfur per 100 standard cubic feet of natural gas. As a restricted alternate fuel, the combustion turbine may fire distillate oil containing no more than 0.05% sulfur by weight. [Rules 62-210.200(PTE) and 62-212.400 (BACT), F.A.C.; 0310047-015-AC, Specific Condition 9]
- C.10. Simple Cycle, Intermittent Operation. The combustion turbine shall operate only in simple cycle mode not to exceed the permitted hours of operation allowed by this permit. This restriction is based on the permittee's request, which formed the basis of the PSD applicability and BACT determinations and resulted in the emission standards specified in this permit. For any request to convert this unit to combined cycle operation by installing/connecting to heat recovery steam generators, including changes to the fuel quality or quantity related to combined cycle conversion which may cause an increase in short or long-term emissions, the permittee may be required to submit a full PSD permit application complete with a new proposal of the Best Available Control Technology as if the unit had never been built. [Rules 62-212.400(12) and 62-212.400(PSD), F.A.C.; 0310047-015-AC, Specific Condition 10]
- C.11. Operating Procedures. The Best Available Control Technology (BACT) determinations established by this permit rely on "good operating practices" to reduce emissions. Therefore all operators and supervisors shall be properly trained to operate and ensure maintenance of the combustion turbine, and pollution control systems in accordance with the guidelines and procedures established by each manufacturer. The training shall include good operating practices as well as methods for minimizing excess emissions. [Rules 62-4.070(3) and 62-212.400(BACT), F.A.C.; 0310047-015-AC, Specific Condition 11]

**SECTION III. EMISSIONS UNIT SPECIFIC CONDITIONS**  
**SUBSECTION C. COMBUSTION TURBINE 8**

**EMISSIONS STANDARDS**

**C.12. Emission Standards.** Emissions from the combustion turbine shall not exceed the following emissions standards.

Pollutant	Emission Standard <sup>e</sup>	Averaging Time	Compliance Method	Basis
CO <sup>a</sup> (Gas)	9.0 ppmvd @ 15% O <sub>2</sub>	3-hour test avg.	EPA Method 10 Test	Avoid PSD
	32.0 lb/hour			
CO <sup>a</sup> (Oil)	20.0 ppmvd @ 15% O <sub>2</sub>	3-hour test avg.	EPA Method 10 Test	
	66.0 lb/hour			
NO <sub>x</sub> <sup>b</sup> (Gas)	15.0 ppmvd @ 15% O <sub>2</sub>	4 hour rolling average	CEMS	NSPS and Avoid PSD
	108.3 lb/hour	3-hour test avg.	CEMS and EPA Method 19	
NO <sub>x</sub> <sup>b</sup> (Oil)	42 ppmvd @ 15% O <sub>2</sub>	4 hour rolling average	CEMS	NSPS and Avoid PSD
	335.0 lb/hour	3-hour test avg.	CEMS and EPA Method 19	
PM/PM <sub>10</sub> <sup>c</sup>	10% Opacity	6-minute block	EPA Method 9 Test	BACT
	Fuel sulfur specifications	N/A	Record Keeping	
SO <sub>2</sub> <sup>d</sup> (Gas)	2 grains sulfur (S)/100 SCF of gas	N/A	Record Keeping	Avoid PSD
SO <sub>2</sub> <sup>d</sup> (Oil)	0.05% sulfur by weight	N/A	Record Keeping	Avoid PSD

- a. The permittee conducted an initial test to demonstrate compliance with the CO emissions limits for the unit as constructed. Subsequent compliance tests shall be conducted prior to obtaining a renewed Title V operating permit.
- b. Continuous compliance shall be demonstrated with the 4-hour rolling average NO<sub>x</sub> emissions limit (ppmvd @ 15% O<sub>2</sub>) by data collected from the required continuous emissions monitoring system. (CEMS). If the CEMS data indicates that the 4-hour rolling average is in excess of the emission limit, excess emission reports must be filed.
- c. The fuel sulfur specifications combined with the efficient combustion design and operation of the combustion turbine represents BACT for PM/PM<sub>10</sub> emissions. No stack tests are required. Compliance with the CO and visible emissions standards shall serve as indicators of good combustion. *{Permitting Note: Maximum expected PM/PM<sub>10</sub> emissions are approximately 19 lb/hour on natural gas and 45.0 lb/hr on oil.}*
- d. The fuel sulfur specifications effectively limit the potential emissions of sulfur dioxide (SO<sub>2</sub>) from each combustion turbine. No stack tests are required.
- e. The mass emission rate standards are based on a turbine inlet condition of 59° F and the higher heating value of each fuel. Mass emission rates may be adjusted for actual test conditions in accordance with the performance curves and/or equations on file with the Department.

[Rule 62-212.400 (BACT), F.A.C.; Rule 62-4.070(3), F.A.C.; Rule 62-212.400(12), F.A.C. (Source Obligation); Rule 62-297.310(7)(a)3, F.A.C.; 0310047-015-AC, Specific Condition 12; 0310047-018-AC; 0310047-019-AC]

**SECTION III. EMISSIONS UNIT SPECIFIC CONDITIONS**  
**SUBSECTION C. COMBUSTION TURBINE 8**

---

**TESTING AND MONITORING REQUIREMENTS**

- C.13. Continuous Compliance.** Continuous compliance with the NO<sub>x</sub> emissions standard (ppmvd @ 15% O<sub>2</sub>) shall be demonstrated with data collected from the required continuous emissions monitoring systems (CEMS). [Rules 62-4.070(3), F.A.C.; 40 CFR 60 Subpart KKKK; 0310047-015-AC, Specific Condition 14]
- C.14. Testing Requirements.** All performance tests shall be conducted between 90% and 100% of permitted capacity in accordance with the requirements of Rule 62-297.310(2), F.A.C. [Rule 62-297.310(7)(a) and (b), F.A.C.; 40 CFR 60.8; 0310047-015-AC, Specific Condition 15]
- C.15. Test Methods.** Any required stack tests shall be performed in accordance with the following methods.

Method	Description of Method and Comments
7E	Determination of Nitrogen Oxide Emissions from Stationary Sources (Instrumental)
9	Visual Determination of the Opacity of Emissions from Stationary Sources
10	Determination of Carbon Monoxide Emissions from Stationary Sources Note: The method shall be based on a continuous sampling train. The ascarite trap may be omitted or the interference trap of section 10.1 may be used in lieu of the silica gel and ascarite traps.
19	Determination of Sulfur Dioxide Removal Efficiency and Particulate Matter, Sulfur Dioxide, and Nitrogen Oxide Emission Rates
20	Determination of Nitrogen Oxides, Sulfur Dioxide and Diluent Emissions from Stationary Combustion Turbines

The methods are described in 40 CFR 60, Appendix A, and adopted by reference in Rule 62-204.800, F.A.C. No other methods may be used for compliance testing unless prior written approval is received from the Department. Tests shall be conducted in accordance with the appropriate test method, the applicable requirements specified in Appendix CC of this permit, and the provisions in NSPS Subparts A and KKKK in 40 CFR 60 (summarized in Appendices NA and NKKKK, respectively, of this permit). [Rules 62-204.800 and 62-297.100, F.A.C.; 40 CFR 60, Subpart A, Subpart KKKK, and Appendix A; 0310047-015-AC, Specific Condition 16]

- C.16. Annual Testing.** During each federal fiscal year (October 1<sup>st</sup> to September 30<sup>th</sup>), annual compliance tests for visible emissions shall be conducted. For each visible emissions test, emissions of NO<sub>x</sub> recorded by the CEMS shall also be reported. If the unit does not operate for more than 400 hours in a federal fiscal year for a given fuel, then an annual visible emissions test is not required for that fuel. If annual visible emissions testing is not required due to this exclusion, a visible emissions compliance test shall be conducted prior to obtaining a renewed Title V operating permit. [Rules 62-4.070(3), 62-297.310(7)(a) and (b), F.A.C.; 0310047-015-AC, Specific Condition 18; 0310047-019-AC]
- C.17. Special Compliance Tests.** When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it shall require the owner or operator of the emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department. The Department may require the permittee to conduct additional tests after major replacement or major repair of any air pollution control equipment, such as the DLN combustors, etc. [Rule 62-297.310(7)(b), F.A.C.; 0310047-015-AC, Specific Condition 19]

**SECTION III. EMISSIONS UNIT SPECIFIC CONDITIONS**  
**SUBSECTION C. COMBUSTION TURBINE 8**

---

**EXCESS EMISSIONS**

*{Permitting Note: The following conditions apply only to the SIP-based emissions standards specified in Specific Condition C.12. Rule 62-210.700, F.A.C. (Excess Emissions) cannot vary or supersede any federal NSPS, NESHAP, or Acid Rain provision.}*

**C.18. Definitions.** Startup, shutdown, and malfunction are defined as follows:

- a. *Startup* is defined as the commencement of operation of any emissions unit which has shut down or ceased operation for a period of time sufficient to cause temperature, pressure, chemical or pollution control device imbalances, which result in excess emissions.
- b. *Shutdown* is the cessation of the operation of an emissions unit for any purpose.
- c. *Malfunction* is defined as any unavoidable mechanical and/or electrical failure of air pollution control equipment or process equipment or of a process resulting in operation in an abnormal or unusual manner.

[Rule 62-210.200(Definitions), F.A.C.; 0310047-015-AC, Specific Condition 20]

**C.19. Excess Emissions Prohibited.** Excess emissions caused entirely or in part by poor maintenance, poor operation or any other equipment or process failure that may reasonably be prevented during startup, shutdown or malfunction shall be prohibited. All such preventable emissions shall be included in any compliance determinations based on CEMS data. [Rule 62-210.700(4), F.A.C.; 0310047-015-AC, Specific Condition 21]

**C.20. Alternate Visible Emissions Standard.** Visible emissions during startup shall not exceed 20% opacity based on a 6-minute averaging period. [Rule 62-210.700(5), F.A.C.; 0310047-015-AC, Specific Condition 22]

**CONTINUOUS EMISSIONS MONITORING SYSTEM (CEMS) REQUIREMENTS**

**C.21. CEM Systems.** The permittee shall calibrate, maintain, and operate continuous emission monitoring systems (CEMS) to measure and record the emissions of NO<sub>x</sub> from the combustion turbine in a manner sufficient to demonstrate continuous compliance with the CEMS emission standards of this section.

- a. *NO<sub>x</sub> Monitor:* Each NO<sub>x</sub> monitor shall be certified pursuant to the specifications of 40 CFR 75 and comply with the applicable requirements of 40 CFR 60 Subpart KKKK. Quality assurance procedures shall conform to the requirements of 40 CFR 75. The RATA tests required for the NO<sub>x</sub> monitor shall be performed using EPA Method 20 or 7E in Appendix A of 40 CFR 60.
- b. *Diluent Monitor:* The oxygen (O<sub>2</sub>) or carbon dioxide (CO<sub>2</sub>) content of the flue gas shall be monitored at the location where NO<sub>x</sub> is monitored to correct the measured emissions rates to 15% oxygen. If a CO<sub>2</sub> monitor is installed, the oxygen content of the flue gas shall be calculated using F-factors that are appropriate for the fuel fired. Each monitor shall comply with the performance and quality assurance requirements of 40 CFR 75. For any hour in which the hourly average O<sub>2</sub> concentration exceeds 19.0 percent O<sub>2</sub> (or the hourly average CO<sub>2</sub> concentration is less than 1.0 percent CO<sub>2</sub>), a diluent cap value of 19.0 percent O<sub>2</sub> or 1.0 percent CO<sub>2</sub> (as applicable) may be used in the emission calculations.
- c. For purposes of determining compliance with the CEMS emissions standards of the permit, missing or excluded data shall not be substituted and bias corrected data shall not be used.

[Rules 62-4.070(3), 62-210.800, 62-212.400(BACT), 62-297.520, F.A.C.; 40 CFR 60.4350; 0310047-015-AC, Specific Condition 23; 0310047-018-AC]

**SECTION III. EMISSIONS UNIT SPECIFIC CONDITIONS**  
**SUBSECTION C. COMBUSTION TURBINE 8**

---

**REPORTING AND RECORD KEEPING REQUIREMENTS**

- C.22. Monitoring of Capacity.** The permittee shall monitor and record the operating rate of the combustion turbine on a daily average basis, considering the number of hours of operation during each day (including the times of startup, shutdown, and malfunction). This shall be achieved through monitoring daily rates of consumption and heat content of each allowable fuel in accordance with the provisions of 40 CFR 75 Appendix D, and recording the data using a monitoring component of the CEMS system required above. [Rules 62-4.070(3) and 62-212.400(PSD), F.A.C.; 0310047-015-AC, Specific Condition 24]
- C.23. Monthly Operations Summary.** By the 15<sup>th</sup> calendar day of each month, the permittee shall record the following for each fuel in a written or electronic log for the combustion turbine for the previous month of operation: hours of operation for the month and for the rolling 12-month total. Information recorded and stored as an electronic file shall be available for inspection and printing within at least three days of a request by the Department. The fuel consumption shall be monitored in accordance with the provisions of 40 CFR 75 Appendix D. [Rules 62-4.070(3) and 62-212.400(PSD), F.A.C.; 0310047-015-AC, Specific Condition 25; 0310047-018-AC]
- C.24. Fuel Sulfur Records.** The permittee shall monitor fuel sulfur in accordance with 40 CFR 60.4415 as summarized in Appendix NKKKK of this permit. [40 CFR 60, Subpart A, Subpart KKKK; 0310047-015-AC, Specific Condition 26]
- C.25. Stack Test Reports.** The owner or operator of an emissions unit for which a compliance test is required shall file a report with the Compliance Authority on the results of each such test. The required test report shall be filed with the Compliance Authority as soon as practical but no later than 45 days after the last sampling run of each test is completed. The test report shall provide sufficient detail on the emissions unit tested and the test procedures used to allow the Compliance Authority to determine if the test was properly conducted and the test results properly computed. As a minimum, the test report shall provide the applicable information specified in Rule 62-297.310(8), F.A.C. and summarized in Appendix CC of this permit. [Rule 62-297.310(8), F.A.C.; 0310047-015-AC, Specific Condition 27]
- C.26. CEMS RATA Reports.** At least 15 days prior to conducting any Relative Accuracy Test Assessments (RATA) on a CEMS, the permittee shall provide written notification to the Compliance Authority of the schedule (by letter, email, or fax). A summary of the RATA reports shall be provided upon written request of the Compliance Authority and in the SIP Excess Emissions Report as specified in Specific Condition C.27. [Rules 62-4.070(3) and 62-212.400(BACT), F.A.C.; 0310047-015-AC, Specific Condition 28]
- C.27. Emissions Reports.**
- a. *NSPS Emissions Report:* Within thirty (30) days following each calendar semiannual period, the permittee shall submit a report including any applicable periods of excess emissions and monitoring systems performance as defined in 40 CFR 60, Subpart KKKK (Standards of Performance for Stationary Combustion Turbines) that occurred during the previous semiannual period to the Compliance Authority.
  - b. *Malfunction Notification:* For each malfunction resulting in excess emissions that exceed two hours in any 24 hour period, the permittee shall notify the Compliance Authority within one working day of: the nature, extent, and duration of the excess emissions; the cause of the excess emissions; and the actions taken to correct the problem. In addition, the Compliance Authority may request a written summary report of the incident.
- [Rules 62-4.070(3), 62-4.130, 62-204.800, 62-210.700(6) and 62-212.400(BACT), F.A.C.; and 40 CFR 60.7 and 60.4395; 0310047-015-AC, Specific Condition 29; 0310047-018-AC]



---

**SECTION IV. ACID RAIN PART**

---

**Operated by: JEA**  
**ORIS code: 0666**

**SUBSECTION A. ACID RAIN UNITS**

The emissions units listed below are regulated under Acid Rain, Phase II.

<u>EU No.</u>	<u>Description</u>
-007	Boiler No. 8 (currently deactivated)
-008	Boiler No. 9 (currently deactivated)
-009	Boiler No. 10 (currently deactivated)
-015	Combustion Turbine #7 (start-up April 30, 2000)
-016	Combustion Turbine #8 (start-up April 16, 2009)

**A.1. Acid Rain Applications.** The permit applications (DEP Form Nos. 62-210.900(1)(a) and 62-210.900(1)(a)3., F.A.C.) submitted for this facility, as approved by the Department, are a part of this permit. The owners and operators of these acid rain units must comply with the standard requirements and special provisions set forth in the applications received on 06/07/2007, 07/31/2007 and 09/21/09. [Chapter 62-213 and Rule 62-214.320, F.A.C.]

**A.2. Summary of SO<sub>2</sub> Allowances.** The following table summarizes the SO<sub>2</sub> allowance allocations for each Acid Rain unit:

E.U. No.	EPA ID	SO <sub>2</sub> Allowances* for Each Year				
		2008	2009	2010	2011	2012
-007	8	196*	196*	196*	196*	196*
-008	9	553*	553*	553*	553*	553*
-009	10	1975*	1975*	1980*	1980*	1980*
-015	7	0*	0*	0*	0*	0*
-016	8	0*	0*	0*	0*	0*

\* The number of allowances held by an Acid Rain source in a unit account may differ from the number allocated by the EPA under Table 2 of 40 CFR 73.

**A.3. Emissions Allowances.** Emissions from sources subject to the Federal Acid Rain Program (Title IV) shall not exceed any allowances that the source lawfully holds under the Federal Acid Rain Program. Allowances shall not be used to demonstrate compliance with a non-Title IV applicable requirement of the Act.

- a. No permit revision shall be required for increases in emissions that are authorized by allowances acquired pursuant to the Federal Acid Rain Program, provided that such increases do not require a permit revision pursuant to Rule 62-213.400(3), F.A.C.
- b. No limit shall be placed on the number of allowances held by the source under the Federal Acid Rain Program.
- c. Allowances shall be accounted for under the Federal Acid Rain Program.

[Rule 62-213.440(1)(c), F.A.C.]

**A.4. Statement of Compliance.** The annual statement of compliance pursuant to Rule 62-213.440(3), F.A.C., shall be submitted within 60 days after the end of the calendar year. [Rule 62-214.420(11), F.A.C.]

**A.5. Comments, Notes and Justifications.** None.

**SECTION IV. ACID RAIN PART**

## Acid Rain Part Application

For more information, see instructions and refer to 40 CFR 72.30, 72.31, and 74; and Chapter 62-214, F.A.C.

This submission is:  New  Revised  Renewal

**STEP 1**

Identify the source by plant name, state, and ORIS or plant code.

JD Kennedy	Florida	0666
Plant name	State	ORIS/Plant Code

**STEP 2**

Enter the unit ID# for every Acid Rain unit at the Acid Rain source in column "a."

If unit a SO<sub>2</sub> Opt-in unit, enter "yes" in column "b".

For new units or SO<sub>2</sub> Opt-in units, enter the requested information in columns "d" and "e."

a	b	c	d	e
Unit ID#	SO <sub>2</sub> Opt-in Unit? (Yes or No)	Unit will hold allowances in accordance with 40 CFR 72.9(c)(1)	New or SO <sub>2</sub> Opt-in Units  Commence Operation Date	New or SO <sub>2</sub> Opt-in Units  Monitor Certification Deadline
CT7	No	Yes		
CT8	No	Yes	May 2009	
		Yes		
		Yes		
		Yes		
		Yes		
		Yes		
		Yes		
		Yes		
		Yes		
		Yes		
		Yes		
		Yes		
		Yes		

## SECTION IV. ACID RAIN PART

JD Kennedy

Plant Name (from STEP 1)

### STEP 3

#### Read the standard requirements.

#### Acid Rain Part Requirements.

- (1) The designated representative of each Acid Rain source and each Acid Rain unit at the source shall:
  - (i) Submit a complete Acid Rain Part application (including a compliance plan) under 40 CFR Part 72 and Rules 62-214.320 and 330, F.A.C., in accordance with the deadlines specified in Rule 62-214.320, F.A.C.; and
  - (ii) Submit in a timely manner any supplemental information that the DEP determines is necessary in order to review an Acid Rain Part application and issue or deny an Acid Rain Part;
- (2) The owners and operators of each Acid Rain source and each Acid Rain unit at the source shall:
  - (i) Operate the unit in compliance with a complete Acid Rain Part application or a superseding Acid Rain Part issued by the DEP; and
  - (ii) Have an Acid Rain Part.

#### Monitoring Requirements.

- (1) The owners and operators and, to the extent applicable, designated representative of each Acid Rain source and each Acid Rain unit at the source shall comply with the monitoring requirements as provided in 40 CFR Part 75, and Rule 62-214.420, F.A.C.
- (2) The emissions measurements recorded and reported in accordance with 40 CFR Part 75 shall be used to determine compliance by the unit with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program.
- (3) The requirements of 40 CFR Part 75 shall not affect the responsibility of the owners and operators to monitor emissions of other pollutants or other emissions characteristics at the unit under other applicable requirements of the Act and other provisions of the operating permit for the source.
- (4) For applications including a SO<sub>2</sub> Opt-in unit, a monitoring plan for each SO<sub>2</sub> Opt-in unit must be submitted with this application pursuant to 40 CFR 74.14(a). For renewal applications for SO<sub>2</sub> Opt-in units include an updated monitoring plan if applicable under 40 CFR 75.53(b).

#### Sulfur Dioxide Requirements.

- (1) The owners and operators of each source and each Acid Rain unit at the source shall:
  - (i) Hold allowances, as of the allowance transfer deadline, in the unit's compliance subaccount (after deductions under 40 CFR 73.34(c)), or in the compliance subaccount of another Acid Rain unit at the same source to the extent provided in 40 CFR 73.35(b)(3), not less than the total annual emissions of sulfur dioxide for the previous calendar year from the unit; and
  - (ii) Comply with the applicable Acid Rain emissions limitations for sulfur dioxide.
- (2) Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act.
- (3) An Acid Rain unit shall be subject to the requirements under paragraph (1) of the sulfur dioxide requirements as follows:
  - (i) Starting January 1, 2000, an Acid Rain unit under 40 CFR 72.8(a)(2); or
  - (ii) Starting on the later of January 1, 2000, or the deadline for monitor certification under 40 CFR Part 75, an Acid Rain unit under 40 CFR 72.6(a)(3).
- (4) Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program.
- (5) An allowance shall not be deducted in order to comply with the requirements under paragraph (1) of the sulfur dioxide requirements prior to the calendar year for which the allowance was allocated.
- (6) An allowance allocated by the Administrator under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the Acid Rain Part application, the Acid Rain Part, or an exemption under 40 CFR 72.7 or 72.8 and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization.
- (7) An allowance allocated by the Administrator under the Acid Rain Program does not constitute a property right.

Nitrogen Oxides Requirements. The owners and operators of the source and each Acid Rain unit at the source shall comply with the applicable Acid Rain emissions limitation for nitrogen oxides.

#### Excess Emissions Requirements.

- (1) The designated representative of an Acid Rain unit that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR Part 77.
- (2) The owners and operators of an Acid Rain unit that has excess emissions in any calendar year shall:
  - (i) Pay without demand the penalty required, and pay upon demand the interest on that penalty, as required by 40 CFR Part 77; and
  - (ii) Comply with the terms of an approved offset plan, as required by 40 CFR Part 77.

#### Recordkeeping and Reporting Requirements.

- (1) Unless otherwise provided, the owners and operators of the source and each Acid Rain unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time prior to the end of 5 years, in writing by the EPA or the DEP:
  - (i) The certificate of representation for the designated representative for the source and each Acid Rain unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with Rule 62-214.350, F.A.C.; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation changing the designated representative;
  - (ii) All emissions monitoring information, in accordance with 40 CFR Part 75, provided that to the extent that 40 CFR Part 75 provides for a 3-year period for recordkeeping, the 3-year period shall apply;
  - (iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the Acid Rain Program; and

**SECTION IV. ACID RAIN PART**

JD Kennedy Plant Name (from STEP 1)
--

**STEP 3,  
Continued.**

Recordkeeping and Reporting Requirements (cont)

- (iv) Copies of all documents used to complete an Acid Rain Part application and any other submission under the Acid Rain Program or to demonstrate compliance with the requirements of the Acid Rain Program.
- (2) The designated representative of an Acid Rain source and each Acid Rain unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR Part 72, Subpart I, and 40 CFR Part 75.

Liability.

- (1) Any person who knowingly violates any requirement or prohibition of the Acid Rain Program, a complete Acid Rain Part application, an Acid Rain Part, or an exemption under 40 CFR 72.7 or 72.8, including any requirement for the payment of any penalty owed to the United States, shall be subject to enforcement pursuant to section 113(c) of the Act.
- (2) Any person who knowingly makes a false, material statement in any record, submission, or report under the Acid Rain Program shall be subject to criminal enforcement pursuant to section 113(c) of the Act and 18 U.S.C. 1001.
- (3) No permit revision shall excuse any violation of the requirements of the Acid Rain Program that occurs prior to the date that the revision takes effect.
- (4) Each Acid Rain source and each Acid Rain unit shall meet the requirements of the Acid Rain Program.
- (5) Any provision of the Acid Rain Program that applies to an Acid Rain source (including a provision applicable to the designated representative of an Acid Rain source) shall also apply to the owners and operators of such source and of the Acid Rain units at the source.
- (6) Any provision of the Acid Rain Program that applies to an Acid Rain unit (including a provision applicable to the designated representative of an Acid Rain unit) shall also apply to the owners and operators of such unit. Except as provided under 40 CFR 72.44 (Phase II repowering extension plans) and 40 CFR 76.11 (NO<sub>x</sub> averaging plans), and except with regard to the requirements applicable to units with a common stack under 40 CFR Part 75 (including 40 CFR 75.16, 75.17, and 75.18), the owners and operators and the designated representative of one Acid Rain unit shall not be liable for any violation by any other Acid Rain unit of which they are not owners or operators or the designated representative and that is located at a source of which they are not owners or operators or the designated representative.
- (7) Each violation of a provision of 40 CFR Parts 72, 73, 74, 75, 78, 77, and 78 by an Acid Rain source or Acid Rain unit, or by an owner or operator or designated representative of such source or unit, shall be a separate violation of the Act.

Effect on Other Authorities.

No provision of the Acid Rain Program, an Acid Rain Part application, an Acid Rain Part, or an exemption under 40 CFR 72.7 or 72.8 shall be construed as:

- (1) Except as expressly provided in title IV of the Act, exempting or excluding the owners and operators and, to the extent applicable, the designated representative of an Acid Rain source or Acid Rain unit from compliance with any other provision of the Act, including the provisions of title I of the Act relating to applicable National Ambient Air Quality Standards or State Implementation Plans;
- (2) Limiting the number of allowances a unit can hold; provided, that the number of allowances held by the unit shall not affect the source's obligation to comply with any other provisions of the Act;
- (3) Requiring a change of any kind in any state law regulating electric utility rates and charges, affecting any state law regarding such state regulation, or limiting such state regulation, including any prudence review requirements under such state law;
- (4) Modifying the Federal Power Act or affecting the authority of the Federal Energy Regulatory Commission under the Federal Power Act; or,
- (5) Interfering with or impairing any program for competitive bidding for power supply in a state in which such program is established.

**STEP 4**  
For SO<sub>2</sub> Opt-in units only.

In column "f" enter the unit ID# for every SO<sub>2</sub> Opt-in unit identified in column "a" of STEP 2.

For column "g" describe the combustion unit and attach information and diagrams on the combustion unit's configuration.

In column "h" enter the hours.

f	g	h (not required for renewal application)
Unit ID#	Description of the combustion unit	Number of hours unit operated in the six months preceding initial application

**SECTION IV. ACID RAIN PART**

JD Kennedy Plant Name (from STEP 1)
--

**STEP 5**

For SO<sub>2</sub> Opt-in units only.  
(Not required for SO<sub>2</sub> Opt-in renewal applications.)

In column "i" enter the unit ID# for every SO<sub>2</sub> Opt-in unit identified in column "a" (and in column "r").

For columns "j" through "n," enter the information required under 40 CFR 74.20-74.25 and attach all supporting documentation required by 40 CFR 74.20-74.25.


i	j	k	l	m	n
Unit ID#	Baseline or Alternative Baseline under 40 CFR 74.20 (mmBtu)	Actual SO <sub>2</sub> Emissions Rate under 40 CFR 74.22 (lbs/mmBtu)	Allowable 1985 SO <sub>2</sub> Emissions Rate under 40 CFR 74.23 (lbs/mmBtu)	Current Allowable SO <sub>2</sub> Emissions Rate under 40 CFR 74.24 (lbs/mmBtu)	Current Promulgated SO <sub>2</sub> Emissions Rate under 40 CFR 74.25 (lbs/mmBtu)

**STEP 6**

For SO<sub>2</sub> Opt-in units only.

Attach additional requirements, certify and sign.

- A. If the combustion source seeks to qualify for a transfer of allowances from the replacement of thermal energy, a thermal energy plan as provided in 40 CFR 74.47 for combustion sources must be attached.
- B. A statement whether the combustion unit was previously an affected unit under 40 CFR 74.
- C. A statement that the combustion unit is not an affected unit under 40 CFR 72.6 and does not have an exemption under 40 CFR 72.7, 72.8, or 72.14.
- D. Attach a complete compliance plan for SO<sub>2</sub> under 40 CFR 72.40.
- E. The designated representative of the combustion unit shall submit a monitoring plan in accordance with 40 CFR 74.61. For renewal application, submit an updated monitoring plan if applicable under 40 CFR 75.53(b).
- F. The following statement must be signed by the designated representative or alternate designated representative of the combustion source: "I certify that the data submitted under 40 CFR Part 74, Subpart C, reflects actual operations of the combustion source and has not been adjusted in any way."

Signature _____		Date _____	
<b>Certification (for designated representative or alternate designated representative only)</b>			
I am authorized to make this submission on behalf of the owners and operators of the Acid Rain source or Acid Rain units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.			
Name Athena T. Mann		Title Vice President, Environmental Services	
Owner Company Name JEA			
Phone (904) 665-6252		E-mail address mannat@jea.com	
Signature 		Date 5/14/09	

**STEP 7**

Read the certification statement; provide name, title, owner company name, phone, and e-mail address; sign, and date.

# Acid Rain, CAIR, and Hg Budget Retired Unit Exemption

For more information, see Instructions and refer to 40 CFR 72.8, 96.105, 96.205, 96.305, and 60.4105; and Rules 62-214.340(2), 62-296.470, and 62-296.480, F.A.C.

This submission is:  New  Revised

**STEP 1**

Identify the unit by plant name, State, ORIS code and unit ID#.

JD Kennedy	FL	0666	8
Plant Name:	State:	ORIS/Plant Code	Unit ID#

Applicable Program(s):  Acid Rain  CAIR NO<sub>x</sub> Annual  CAIR SO<sub>2</sub>  CAIR NO<sub>x</sub> Ozone Season  
 ~ Mercury (Hg) Budget Trading

**STEP 2**

Identify the date on which the unit was (or will be) permanently retired.

10/1/2000

**STEP 3**

If an acid rain affected unit, identify the first full calendar year in which the unit meets (or will meet) the requirements of 40 CFR 72.8(d).

January 1, 2001

**STEP 4**

Read the special provisions.

**Acid Rain Special Provisions**

- (1) A unit exempt under Rule 62-214.340(2), F.A.C., shall not emit any sulfur dioxide and nitrogen oxides starting on the date that the exemption takes effect. The owners and operators of the unit will be allocated allowances in accordance with 40 CFR Part 73, Subpart B. If the unit is a Phase I unit, for each calendar year in Phase I, the designated representative of the unit shall submit a Phase I permit application in accordance with 40 CFR Part 72, Subparts C and D, and an annual certification report in accordance with 40 CFR 72.90 through 72.92 and is subject to 40 CFR 72.95 and 72.96.
- (2) A unit exempt under Rule 62-214.340(2), F.A.C., shall not resume operation unless the designated representative of the source that includes the unit submits a complete Acid Rain Part application under Rule 62-214.320, F.A.C., for the unit not less than 24 months prior to the date on which the unit is first to resume operation.
- (3) The owners and operators and, to the extent applicable, the designated representative of a unit exempt under Rule 62-214.340(2), F.A.C., shall comply with the requirements of Chapter 62-214, F.A.C., and the Acid Rain Program concerning all periods for which the exemption is not in effect, even if such requirements arise, or must be complied with, after the exemption takes effect.
- (4) For any period for which a unit is exempt under Rule 62-214.340(2), F.A.C., the unit is not an Acid Rain unit and is not eligible to be an opt-in source under 40 CFR Part 74. As a non-Acid Rain Unit, the unit shall continue to be subject to any other applicable requirements under Chapter 62-213, F.A.C.
- (5) For a period of 5 years from the date the records are created, the owners and operators of a unit exempt under Rule 62-214.340(2), F.A.C., shall retain at the source that includes the unit records demonstrating that the unit is permanently retired. The 5-year period for keeping records may be extended for cause, at any time prior to the end of the period, in writing by the EPA or the DEP. The owners and operators bear the burden of proof that the unit is permanently retired.
- (6) On the earlier of the following dates, a unit exempt under Rule 62-214.340(2), F.A.C., shall lose its exemption and become an Acid Rain Unit: (i) the date on which the designated representative submits an Acid Rain Part application under paragraph (2); or (ii) the date on which the designated representative is required under paragraph (2) to submit an Acid Rain Part application. For the purpose of applying monitoring requirements under 40 CFR Part 75, a unit that loses its exemption under Rule 62-214.340(2), F.A.C., shall be treated as a new unit that commenced commercial operation on the first date on which the unit resumes operation.

## SECTION IV. ACID RAIN PART

Plant Name (from STEP 1) JD Kennedy

### STEP 4 (continued)

#### CAIR Special Provisions

- (1) A unit exempt under 40 CFR 96.105(a), 96.205(a), or 96.305(a), shall not emit any sulfur dioxide or nitrogen oxides starting on the date that the exemption takes effect. The DEP will allocate CAIR NO<sub>x</sub> allowances in accordance with Rule 62-296.470, F.A.C.
- (2) For a period of 5 years from the date the records are created, the owners and operators of a unit exempt under Rule 62-296.470, F.A.C., shall retain at the source that includes the unit, records demonstrating that the unit is permanently retired. The 5-year period for keeping records may be extended for cause, at any time prior to the end of the period, in writing by the EPA or the DEP. The owners and operators bear the burden of proof that the unit is permanently retired.
- (3) The owners and operators and, to the extent applicable, the CAIR designated representative of a unit exempt under 40 CFR 96.105(a), 96.205(a), or 96.305(a), shall comply with the applicable requirements of the CAIR NO<sub>x</sub> Annual Trading Program, the CAIR SO<sub>2</sub> Trading Program, and the CAIR NO<sub>x</sub> Ozone Season Trading Program concerning all periods for which the exemption is not in effect, even if such requirements arise, or must be complied with, after the exemption takes effect.
- (4) A unit exempt under 40 CFR 96.105(a), 96.205(a), or 96.305(a), and located at a source that is required, or but for this exemption would be required, to have a title V operating permit shall not resume operation unless the CAIR designated representative of the source submits a complete CAIR Part application under Rule 62-213.420, F.A.C., for the unit before the date on which the unit resumes operation.
- (5) On the earlier of the following dates, a unit exempt under 40 CFR 96.105(a), 96.205(a), or 96.305(a) shall lose its exemption:
  - (i) the date on which the CAIR designated representative submits a CAIR Part application under Special Provision (4) above;
  - (ii) the date on which the CAIR designated representative is required under Special Provision (4) above to submit an CAIR Part application for the unit; or
  - (iii) the date on which the unit resumes operation, if the CAIR designated representative is not required to submit a CAIR Part application for the unit.
- (6) For the purpose of applying monitoring, reporting and recordkeeping requirements under 40 CFR Part 96, Subparts HH, HHH, and/or HHHH, a unit that loses its exemption under 40 CFR 96.105(a), 96.205(a), or 96.305(a), shall be treated as a unit that commences commercial operation on the first date on which the unit resumes operation.

#### Mercury (Hg) Budget Trading Special Provisions

- (1) A unit exempt under 40 CFR 60.4105(a) shall not emit any mercury starting on the date that the exemption takes effect.
- (2) The DEP will allocate Hg allowances under Rule 62-296.480, F.A.C.
- (3) For a period of 5 years from the date the records are created, the owners and operators of a unit exempt under 40 CFR 60.4105(a) shall retain at the source that includes the unit, records demonstrating that the unit is permanently retired. The 5-year period for keeping records may be extended for cause, at any before the end of the period, in writing by the EPA or the DEP. The owners and operators bear the burden of proof that the unit is permanently retired.
- (4) The owners and operators and, to the extent applicable, the Hg designated representative of a unit exempt under 40 CFR 60.4105(a) shall comply with the requirements of the Hg Budget Trading Program concerning all periods for which the exemption is not in effect, even if such requirements arise, or must be complied with, after the exemption takes effect.
- (5) A unit exempt under 40 CFR 60.4105(a) and located at a source that is required, or but for this exemption would be required, to have a title V operating permit shall not resume operation unless the Hg designated representative of the source submits a complete Hg Budget Part application under 40 CFR 60.4122 and Rule 62-213.420, F.A.C., for the unit before the date on which the unit resumes operation.
- (6) On the earlier of the following dates, a unit exempt under 40 CFR 60.4105(a) shall lose its exemption:
  - (i) the date on which the Hg designated representative submits a Hg Budget Part application for the unit under Special Provision (5);
  - (ii) the date on which the Hg designated representative is required under Special Provision (5) to submit a Hg Budget Part application for the unit; or
  - (iii) the date on which the unit resumes operation, if the Hg designated representative is not required to submit a Hg Budget Part application for the unit.
- (7) For the purpose of applying monitoring, reporting and recordkeeping requirements under 40 CFR 60.4170 through 60.4176, a unit that loses its exemption under 40 CFR 60.4105(a) shall be treated as a unit that commences operation and commercial operation on the first date on which the unit resumes operation.

SECTION IV. ACID RAIN PART

Plant Name (from STEP 1) JD Kennedy

**STEP 5**  
**Make Statement of Compliance.**


**Statement of Compliance**

I state that the unit identified above in STEP 1 was (or will be) permanently retired on the date identified in STEP 2 and will comply with the Special Provisions listed in STEP 4.

**STEP 6**  
**Read the certification and sign and date.**

**Certification (for designated representatives or alternate designated representatives only)**

I am authorized to make this submission on behalf of the owners and operators of the affected source and affected unit for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Name: Michael Brost		Title: Vice President, Electric Systems	
Owner Company Name: JEA			
Phone: (904) 665-7547		Email: brosmj@jea.com	
Signature 		Date 4-28-08	



# Acid Rain, CAIR, and Hg Budget Retired Unit Exemption

For more information, see instructions and refer to 40 CFR 72.8, 96.105, 96.205, 96.305, and 60.4105; and Rules 62-214.340(2), 62-296.470, and 62-296.480, F.A.C.

This submission is:  New  Revised

**STEP 1**

Identify the unit by plant name, State, ORIS code and unit ID#.

JD Kennedy	FL	0666	9
Plant Name:	State:	ORIS/Plant Code	Unit ID#

Applicable Program(s):  Acid Rain  CAIR NO<sub>x</sub> Annual  CAIR SO<sub>2</sub>  CAIR NO<sub>x</sub> Ozone Season  
 Mercury (Hg) Budget Trading

**STEP 2**

Identify the date on which the unit was (or will be) permanently retired.

10/1/2000

**STEP 3**

If an acid rain affected unit, identify the first full calendar year in which the unit meets (or will meet) the requirements of 40 CFR 72.8(d).

January 1, 2001

**STEP 4**

Read the special provisions.

**Acid Rain Special Provisions**

- (1) A unit exempt under Rule 62-214.340(2), F.A.C., shall not emit any sulfur dioxide and nitrogen oxides starting on the date that the exemption takes effect. The owners and operators of the unit will be allocated allowances in accordance with 40 CFR Part 73, Subpart B. If the unit is a Phase I unit, for each calendar year in Phase I, the designated representative of the unit shall submit a Phase I permit application in accordance with 40 CFR Part 72, Subparts C and D, and an annual certification report in accordance with 40 CFR 72.90 through 72.92 and is subject to 40 CFR 72.95 and 72.96.
- (2) A unit exempt under Rule 62-214.340(2), F.A.C., shall not resume operation unless the designated representative of the source that includes the unit submits a complete Acid Rain Part application under Rule 62-214.320, F.A.C., for the unit not less than 24 months prior to the date on which the unit is first to resume operation.
- (3) The owners and operators and, to the extent applicable, the designated representative of a unit exempt under Rule 62-214.340(2), F.A.C., shall comply with the requirements of Chapter 62-214, F.A.C., and the Acid Rain Program concerning all periods for which the exemption is not in effect, even if such requirements arise, or must be complied with, after the exemption takes effect.
- (4) For any period for which a unit is exempt under Rule 62-214.340(2), F.A.C., the unit is not an Acid Rain unit and is not eligible to be an opt-in source under 40 CFR Part 74. As a non-Acid Rain Unit, the unit shall continue to be subject to any other applicable requirements under Chapter 62-213, F.A.C.
- (5) For a period of 5 years from the date the records are created, the owners and operators of a unit exempt under Rule 62-214.340(2), F.A.C., shall retain at the source that includes the unit records demonstrating that the unit is permanently retired. The 5-year period for keeping records may be extended for cause, at any time prior to the end of the period, in writing by the EPA or the DEP. The owners and operators bear the burden of proof that the unit is permanently retired.
- (6) On the earlier of the following dates, a unit exempt under Rule 62-214.340(2), F.A.C., shall lose its exemption and become an Acid Rain Unit: (i) the date on which the designated representative submits an Acid Rain Part application under paragraph (2); or (ii) the date on which the designated representative is required under paragraph (2) to submit an Acid Rain Part application. For the purpose of applying monitoring requirements under 40 CFR Part 75, a unit that loses its exemption under Rule 62-214.340(2), F.A.C., shall be treated as a new unit that commenced commercial operation on the first date on which the unit resumes operation.

## SECTION IV. ACID RAIN PART

Plant Name (from STEP 1) JD Kennedy

### STEP 4 (continued)

#### CAIR Special Provisions

- (1) A unit exempt under 40 CFR 96.105(a), 96.205(a), or 96.305(a), shall not emit any sulfur dioxide or nitrogen oxides starting on the date that the exemption takes effect. The DEP will allocate CAIR NO<sub>x</sub> allowances in accordance with Rule 62-296.470, F.A.C.
- (2) For a period of 5 years from the date the records are created, the owners and operators of a unit exempt under Rule 62-296.470, F.A.C., shall retain at the source that includes the unit, records demonstrating that the unit is permanently retired. The 5-year period for keeping records may be extended for cause, at any time prior to the end of the period, in writing by the EPA or the DEP. The owners and operators bear the burden of proof that the unit is permanently retired.
- (3) The owners and operators and, to the extent applicable, the CAIR designated representative of a unit exempt under 40 CFR 96.105(a), 96.205(a), or 96.305(a), shall comply with the applicable requirements of the CAIR NO<sub>x</sub> Annual Trading Program, the CAIR SO<sub>2</sub> Trading Program, and the CAIR NO<sub>x</sub> Ozone Season Trading Program concerning all periods for which the exemption is not in effect, even if such requirements arise, or must be complied with, after the exemption takes effect.
- (4) A unit exempt under 40 CFR 96.105(a), 96.205(a), or 96.305(a), and located at a source that is required, or but for this exemption would be required, to have a title V operating permit shall not resume operation unless the CAIR designated representative of the source submits a complete CAIR Part application under Rule 62-213.420, F.A.C., for the unit before the date on which the unit resumes operation.
- (5) On the earlier of the following dates, a unit exempt under 40 CFR 96.105(a), 96.205(a), or 96.305(a) shall lose its exemption:
  - (i) the date on which the CAIR designated representative submits a CAIR Part application under Special Provision (4) above;
  - (ii) the date on which the CAIR designated representative is required under Special Provision (4) above to submit a CAIR Part application for the unit; or
  - (iii) the date on which the unit resumes operation, if the CAIR designated representative is not required to submit a CAIR Part application for the unit.
- (6) For the purpose of applying monitoring, reporting and recordkeeping requirements under 40 CFR Part 96, Subparts HH, HHH, and/or HHHH, a unit that loses its exemption under 40 CFR 96.105(a), 96.205(a), or 96.305(a), shall be treated as a unit that commences commercial operation on the first date on which the unit resumes operation.

#### Mercury (Hg) Budget Trading Special Provisions

- (1) A unit exempt under 40 CFR 60.4105(a) shall not emit any mercury starting on the date that the exemption takes effect.
- (2) The DEP will allocate Hg allowances under Rule 62-296.480, F.A.C.
- (3) For a period of 5 years from the date the records are created, the owners and operators of a unit exempt under 40 CFR 60.4105(a) shall retain at the source that includes the unit, records demonstrating that the unit is permanently retired. The 5-year period for keeping records may be extended for cause, at any before the end of the period, in writing by the EPA or the DEP. The owners and operators bear the burden of proof that the unit is permanently retired.
- (4) The owners and operators and, to the extent applicable, the Hg designated representative of a unit exempt under 40 CFR 60.4105(a) shall comply with the requirements of the Hg Budget Trading Program concerning all periods for which the exemption is not in effect, even if such requirements arise, or must be complied with, after the exemption takes effect.
- (5) A unit exempt under 40 CFR 60.4105(a) and located at a source that is required, or but for this exemption would be required, to have a title V operating permit shall not resume operation unless the Hg designated representative of the source submits a complete Hg Budget Part application under 40 CFR 60.4122 and Rule 62-213.420, F.A.C., for the unit before the date on which the unit resumes operation.
- (6) On the earlier of the following dates, a unit exempt under 40 CFR 60.4105(a) shall lose its exemption:
  - (i) the date on which the Hg designated representative submits a Hg Budget Part application for the unit under Special Provision (5);
  - (ii) the date on which the Hg designated representative is required under Special Provision (5) to submit a Hg Budget Part application for the unit; or
  - (iii) the date on which the unit resumes operation, if the Hg designated representative is not required to submit a Hg Budget Part application for the unit.
- (7) For the purpose of applying monitoring, reporting and recordkeeping requirements under 40 CFR 60.4170 through 60.4176, a unit that loses its exemption under 40 CFR 60.4105(a) shall be treated as a unit that commences operation and commercial operation on the first date on which the unit resumes operation.

SECTION IV. ACID RAIN PART

Plant Name (from STEP 1) JD Kennedy

**STEP 5**  
**Make Statement of Compliance.**


**Statement of Compliance**

I state that the unit identified above in STEP 1 was (or will be) permanently retired on the date identified in STEP 2 and will comply with the Special Provisions listed in STEP 4.

**STEP 6**  
**Read the certification and sign and date.**

**Certification (for designated representatives or alternate designated representatives only)**

I am authorized to make this submission on behalf of the owners and operators of the affected source and affected unit for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Name: Michael Brost		Title: Vice President, Electric Systems	
Owner Company Name: JEA			
Phone: (904) 665-7547		Email: brosmj@jea.com	
Signature 		Date 4-22-08	

# Acid Rain, CAIR, and Hg Budget Retired Unit Exemption

For more information, see instructions and refer to 40 CFR 72.8, 96.105, 96.205, 96.305, and 60.4105; and Rules 62-214.340(2), 62-296.470, and 62-296.480, F.A.C.

This submission is:  New  Revised

**STEP 1**

Identify the unit by plant name, State, ORIS code and unit ID#.

JD Kennedy Plant Name:	FL State:	0666 ORIS/Plant Code	10 Unit ID#
---------------------------	--------------	-------------------------	----------------

Applicable Program(s):  Acid Rain  CAIR NO<sub>x</sub> Annual  CAIR SO<sub>2</sub>  CAIR NO<sub>x</sub> Ozone Season  
 Mercury (Hg) Budget Trading

**STEP 2**

Identify the date on which the unit was (or will be) permanently retired.

10/1/2000

**STEP 3**

If an acid rain affected unit, identify the first full calendar year in which the unit meets (or will meet) the requirements of 40 CFR 72.8(d).

January 1, 2001

**STEP 4**

Read the special provisions.

**Acid Rain Special Provisions**

- (1) A unit exempt under Rule 62-214.340(2), F.A.C., shall not emit any sulfur dioxide and nitrogen oxides starting on the date that the exemption takes effect. The owners and operators of the unit will be allocated allowances in accordance with 40 CFR Part 73, Subpart B. If the unit is a Phase I unit, for each calendar year in Phase I, the designated representative of the unit shall submit a Phase I permit application in accordance with 40 CFR Part 72, Subparts C and D, and an annual certification report in accordance with 40 CFR 72.90 through 72.92 and is subject to 40 CFR 72.95 and 72.96.
- (2) A unit exempt under Rule 62-214.340(2), F.A.C., shall not resume operation unless the designated representative of the source that includes the unit submits a complete Acid Rain Part application under Rule 62-214.320, F.A.C., for the unit not less than 24 months prior to the date on which the unit is first to resume operation.
- (3) The owners and operators and, to the extent applicable, the designated representative of a unit exempt under Rule 62-214.340(2), F.A.C., shall comply with the requirements of Chapter 62-214, F.A.C., and the Acid Rain Program concerning all periods for which the exemption is not in effect, even if such requirements arise, or must be complied with, after the exemption takes effect.
- (4) For any period for which a unit is exempt under Rule 62-214.340(2), F.A.C., the unit is not an Acid Rain unit and is not eligible to be an opt-in source under 40 CFR Part 74. As a non-Acid Rain Unit, the unit shall continue to be subject to any other applicable requirements under Chapter 62-213, F.A.C.
- (5) For a period of 5 years from the date the records are created, the owners and operators of a unit exempt under Rule 62-214.340(2), F.A.C., shall retain at the source that includes the unit records demonstrating that the unit is permanently retired. The 5-year period for keeping records may be extended for cause, at any time prior to the end of the period, in writing by the EPA or the DEP. The owners and operators bear the burden of proof that the unit is permanently retired.
- (6) On the earlier of the following dates, a unit exempt under Rule 62-214.340(2), F.A.C., shall lose its exemption and become an Acid Rain Unit: (i) the date on which the designated representative submits an Acid Rain Part application under paragraph (2); or (ii) the date on which the designated representative is required under paragraph (2) to submit an Acid Rain Part application. For the purpose of applying monitoring requirements under 40 CFR Part 75, a unit that loses its exemption under Rule 62-214.340(2), F.A.C., shall be treated as a new unit that commenced commercial operation on the first date on which the unit resumes operation.

## SECTION IV. ACID RAIN PART

Plant Name (from STEP 1) JD Kennedy

### STEP 4 (continued)

#### CAIR Special Provisions

- (1) A unit exempt under 40 CFR 96.105(a), 96.205(a), or 96.305(a), shall not emit any sulfur dioxide or nitrogen oxides starting on the date that the exemption takes effect. The DEP will allocate CAIR NO<sub>x</sub> allowances in accordance with Rule 62-296.470, F.A.C.
- (2) For a period of 5 years from the date the records are created, the owners and operators of a unit exempt under Rule 62-296.470, F.A.C., shall retain at the source that includes the unit, records demonstrating that the unit is permanently retired. The 5-year period for keeping records may be extended for cause, at any time prior to the end of the period, in writing by the EPA or the DEP. The owners and operators bear the burden of proof that the unit is permanently retired.
- (3) The owners and operators and, to the extent applicable, the CAIR designated representative of a unit exempt under 40 CFR 96.105(a), 96.205(a), or 96.305(a), shall comply with the applicable requirements of the CAIR NO<sub>x</sub> Annual Trading Program, the CAIR SO<sub>2</sub> Trading Program, and the CAIR NO<sub>x</sub> Ozone Season Trading Program concerning all periods for which the exemption is not in effect, even if such requirements arise, or must be complied with, after the exemption takes effect.
- (4) A unit exempt under 40 CFR 96.105(a), 96.205(a), or 96.305(a), and located at a source that is required, or but for this exemption would be required, to have a title V operating permit shall not resume operation unless the CAIR designated representative of the source submits a complete CAIR Part application under Rule 62-213.420, F.A.C., for the unit before the date on which the unit resumes operation.
- (5) On the earlier of the following dates, a unit exempt under 40 CFR 96.105(a), 96.205(a), or 96.305(a) shall lose its exemption:
  - (i) the date on which the CAIR designated representative submits a CAIR Part application under Special Provision (4) above;
  - (ii) the date on which the CAIR designated representative is required under Special Provision (4) above to submit a CAIR Part application for the unit; or
  - (iii) the date on which the unit resumes operation, if the CAIR designated representative is not required to submit a CAIR Part application for the unit.
- (6) For the purpose of applying monitoring, reporting and recordkeeping requirements under 40 CFR Part 96, Subparts HHH, HHH, and/or HHHH, a unit that loses its exemption under 40 CFR 96.105(a), 96.205(a), or 96.305(a), shall be treated as a unit that commences commercial operation on the first date on which the unit resumes operation.

#### Mercury (Hg) Budget Trading Special Provisions

- (1) A unit exempt under 40 CFR 60.4105(a) shall not emit any mercury starting on the date that the exemption takes effect.
- (2) The DEP will allocate Hg allowances under Rule 62-296.480, F.A.C.
- (3) For a period of 5 years from the date the records are created, the owners and operators of a unit exempt under 40 CFR 60.4105(a) shall retain at the source that includes the unit, records demonstrating that the unit is permanently retired. The 5-year period for keeping records may be extended for cause, at any before the end of the period, in writing by the EPA or the DEP. The owners and operators bear the burden of proof that the unit is permanently retired.
- (4) The owners and operators and, to the extent applicable, the Hg designated representative of a unit exempt under 40 CFR 60.4105(a) shall comply with the requirements of the Hg Budget Trading Program concerning all periods for which the exemption is not in effect, even if such requirements arise, or must be complied with, after the exemption takes effect.
- (5) A unit exempt under 40 CFR 60.4105(a) and located at a source that is required, or but for this exemption would be required, to have a title V operating permit shall not resume operation unless the Hg designated representative of the source submits a complete Hg Budget Part application under 40 CFR 60.4122 and Rule 62-213.420, F.A.C., for the unit before the date on which the unit resumes operation.
- (6) On the earlier of the following dates, a unit exempt under 40 CFR 60.4105(a) shall lose its exemption:
  - (i) the date on which the Hg designated representative submits a Hg Budget Part application for the unit under Special Provision (5);
  - (ii) the date on which the Hg designated representative is required under Special Provision (5) to submit a Hg Budget Part application for the unit; or
  - (iii) the date on which the unit resumes operation, if the Hg designated representative is not required to submit a Hg Budget Part application for the unit.
- (7) For the purpose of applying monitoring, reporting and recordkeeping requirements under 40 CFR 60.4170 through 60.4176, a unit that loses its exemption under 40 CFR 60.4105(a) shall be treated as a unit that commences operation and commercial operation on the first date on which the unit resumes operation.

**SECTION IV. ACID RAIN PART**

---

Plant Name (from STEP 1) JD Kennedy

**STEP 5**  
**Make Statement of Compliance.**


**Statement of Compliance**

I state that the unit identified above in STEP 1 was (or will be) permanently retired on the date identified in STEP 2 and will comply with the Special Provisions listed in STEP 4.

**STEP 6**  
**Read the certification and sign and date.**

**Certification (for designated representatives or alternate designated representatives only)**

I am authorized to make this submission on behalf of the owners and operators of the affected source and affected unit for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Name: Michael Brost		Title: Vice President, Electric Systems	
Owner Company Name: JEA			
Phone: (904) 665-7547		Email: brosmj@jea.com	
Signature 		Date 4-28-08	

SECTION V. CAIR PART FORM

CLEAN AIR INTERSTATE RULE PROVISIONS

Clean Air Interstate Rule (CAIR).

Operated by: JEA

Plant: Kennedy Generating Station

ORIS Code: 0666

The emissions units below are regulated under the Clean Air Interstate Rule.

EU No.	EPA Unit ID#	Brief Description
015	7	CT No. 7 (Acid Rain Unit)
016	8	CT No. 8

1. Clean Air Interstate Rule Application. The Clean Air Interstate Rule Part Form submitted for this facility is a part of this permit. The owners and operators of these CAIR units as identified in this form must comply with the standard requirements and special provisions set forth in the revised CAIR Part Form (DEP Form No. 62-210.900(1)(b)) dated December 19, 2008, which is attached at the end of this section. [Chapter 62-213, F.A.C. and Rule 62-210.200, F.A.C.]

SECTION V. CAIR PART FORM

CLEAN AIR INTERSTATE RULE PROVISIONS

Clean Air Interstate Rule (CAIR) Part

For more information, see instructions and refer to 40 CFR 96.121, 96.122, 96.221, 96.222, 96.321 and 96.322; and Rule 62-296.470, F.A.C.

This submission is:  New  Revised  Renewal

STEP 1

Identify the source by plant name and ORIS or EIA plant code

Plant Name: JD Kennedy	State: Florida	ORIS or EIA Plant Code: 0666
------------------------	----------------	---------------------------------

STEP 2

In column "a" enter the unit ID# for every CAIR unit at the CAIR source.

In columns "b," "c," and "d," indicate to which CAIR program(s) each unit is subject by placing an "X" in the column(s).

For new units, enter the requested information in columns "e" and "f."

a	b	c	d	e	f
Unit ID#	Unit will hold nitrogen oxides (NO <sub>x</sub> ) allowances in accordance with 40 CFR 96.106(c)(1)	Unit will hold sulfur dioxide (SO <sub>2</sub> ) allowances in accordance with 40 CFR 96.208(c)(1)	Unit will hold NO <sub>x</sub> Ozone Season allowances in accordance with 40 CFR 96.306(c)(1)	New Units Expected Commence Commercial Operation Date	New Units Expected Monitor Certification Deadline
CT7	X	X	X		
CT8	X	X	X	May 2009	

DEP Form No. 62-210.900(1)(b) - Form Effective: 3/16/08



SECTION V. CAIR PART FORM

CLEAN AIR INTERSTATE RULE PROVISIONS

Plant Name (from STEP 1) JD Kennedy

STEP 3

Read the standard requirements.

CAIR NOx ANNUAL TRADING PROGRAM

CAIR Part Requirements.

- (1) The CAIR designated representative of each CAIR NOx source and each CAIR NOx unit at the source shall:
  - (i) Submit to the DEP a complete and certified CAIR Part form under 40 CFR 96.122 and Rule 92-296.470, F.A.C., in accordance with the deadlines specified in Rule 62-213.420, F.A.C.; and
  - (ii) [Reserved];
- (2) The owners and operators of each CAIR NOx source and each CAIR NOx unit at the source shall have a CAIR Part included in the Title V operating permit issued by the DEP under 40 CFR Part 96, Subpart CC, and operate the source and the unit in compliance with such CAIR Part.

Monitoring, Reporting, and Recordkeeping Requirements.

- (1) The owners and operators, and the CAIR designated representative, of each CAIR NOx source and each CAIR NOx unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR Part 96, Subpart HH, and Rule 62-296.470, F.A.C.
- (2) The emissions measurements recorded and reported in accordance with 40 CFR Part 96, Subpart HH, shall be used to determine compliance by each CAIR NOx source with the following CAIR NOx Emissions Requirements.

NOx Emission Requirements.

- (1) As of the allowance transfer deadline for a control period, the owners and operators of each CAIR NOx source and each CAIR NOx unit at the source shall hold, in the source's compliance account, CAIR NOx allowances available for compliance deductions for the control period under 40 CFR 96.154(a) in an amount not less than the tons of total NOx emissions for the control period from all CAIR NOx units at the source, as determined in accordance with 40 CFR Part 96, Subpart HH.
- (2) A CAIR NOx unit shall be subject to the requirements under paragraph (1) of the NOx Requirements starting on the later of January 1, 2009, or the deadline for meeting the unit's monitor certification requirements under 40 CFR 96.170(b)(1) or (2) and for each control period thereafter.
- (3) A CAIR NOx allowance shall not be deducted, for compliance with the requirements under paragraph (1) of the NOx Requirements, for a control period in a calendar year before the year for which the CAIR NOx allowance was allocated.
- (4) CAIR NOx allowances shall be held in, deducted from, or transferred into or among CAIR NOx Allowance Tracking System accounts in accordance with 40 CFR Part 96, Subparts FF and GG.
- (5) A CAIR NOx allowance is a limited authorization to emit one ton of NOx in accordance with the CAIR NOx Annual Trading Program. No provision of the CAIR NOx Annual Trading Program, the CAIR Part, or an exemption under 40 CFR 96.105 and no provision of law shall be construed to limit the authority of the state or the United States to terminate or limit such authorization.
- (6) A CAIR NOx allowance does not constitute a property right.
- (7) Upon recordation by the Administrator under 40 CFR Part 96, Subpart EE, FF, or GG, every allocation, transfer, or deduction of a CAIR NOx allowance to or from a CAIR NOx unit's compliance account is incorporated automatically in any CAIR Part of the source that includes the CAIR NOx unit.

Excess Emissions Requirements.

- If a CAIR NOx source emits NOx during any control period in excess of the CAIR NOx emissions limitation, then:
- (1) The owners and operators of the source and each CAIR NOx unit at the source shall surrender the CAIR NOx allowances required for deduction under 40 CFR 96.154(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act or applicable state law; and
  - (2) Each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR Part 96, Subpart AA, the Clean Air Act, and applicable state law.

Recordkeeping and Reporting Requirements.

- (1) Unless otherwise provided, the owners and operators of the CAIR NOx source and each CAIR NOx unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the DEP or the Administrator.
  - (i) The certificate of representation under 40 CFR 96.113 for the CAIR designated representative for the source and each CAIR NOx unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation under 40 CFR 96.113 changing the CAIR designated representative.
  - (ii) All emissions monitoring information, in accordance with 40 CFR Part 96, Subpart HH, of this part, provided that to the extent that 40 CFR Part 96, Subpart HH, provides for a 3-year period for recordkeeping, the 3-year period shall apply.
  - (iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR NOx Annual Trading Program.
  - (iv) Copies of all documents used to complete a CAIR Part form and any other submission under the CAIR NOx Annual Trading Program or to demonstrate compliance with the requirements of the CAIR NOx Annual Trading Program.
- (2) The CAIR designated representative of a CAIR NOx source and each CAIR NOx unit at the source shall submit the reports required under the CAIR NOx Annual Trading Program, including those under 40 CFR Part 96, Subpart HH.

## SECTION V. CAIR PART FORM

### CLEAN AIR INTERSTATE RULE PROVISIONS

Plant Name (from STEP 1) JD Kennedy

STEP 3,  
Continued

#### Liability.

- (1) Each CAIR NO<sub>x</sub> source and each CAIR NO<sub>x</sub> unit shall meet the requirements of the CAIR NO<sub>x</sub> Annual Trading Program.
- (2) Any provision of the CAIR NO<sub>x</sub> Annual Trading Program that applies to a CAIR NO<sub>x</sub> source or the CAIR designated representative of a CAIR NO<sub>x</sub> source shall also apply to the owners and operators of such source and of the CAIR NO<sub>x</sub> units at the source.
- (3) Any provision of the CAIR NO<sub>x</sub> Annual Trading Program that applies to a CAIR NO<sub>x</sub> unit or the CAIR designated representative of a CAIR NO<sub>x</sub> unit shall also apply to the owners and operators of such unit.

#### Effect on Other Authorities.

No provision of the CAIR NO<sub>x</sub> Annual Trading Program, a CAIR Part, or an exemption under 40 CFR 96.105 shall be construed as exempting or excluding the owners and operators, and the CAIR designated representative, of a CAIR NO<sub>x</sub> source or CAIR NO<sub>x</sub> unit from compliance with any other provision of the applicable, approved State Implementation Plan, a federally enforceable permit, or the Clean Air Act.

### CAIR SO<sub>2</sub> TRADING PROGRAM

#### CAIR Part Requirements.

- (1) The CAIR designated representative of each CAIR SO<sub>2</sub> source and each CAIR SO<sub>2</sub> unit at the source shall:
  - (i) Submit to the DEP a complete and certified CAIR Part form under 40 CFR 96.222 and Rule 62-296.470, F.A.C., in accordance with the deadlines specified in Rule 62-213.420, F.A.C.; and
  - (ii) [Reserved].
- (2) The owners and operators of each CAIR SO<sub>2</sub> source and each CAIR SO<sub>2</sub> unit at the source shall have a CAIR Part included in the Title V operating permit issued by the DEP under 40 CFR Part 96, Subpart CCC, for the source and operate the source and each CAIR unit in compliance with such CAIR Part.

#### Monitoring, Reporting, and Recordkeeping Requirements.

- (1) The owners and operators, and the CAIR designated representative, of each CAIR SO<sub>2</sub> source and each SO<sub>2</sub> CAIR unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR Part 96, Subpart HHH, and Rule 62-296.470, F.A.C.
- (2) The emissions measurements recorded and reported in accordance with 40 CFR Part 96, Subpart HHH, shall be used to determine compliance by each CAIR SO<sub>2</sub> source with the following CAIR SO<sub>2</sub> Emission Requirements.

#### SO<sub>2</sub> Emission Requirements.

- (1) As of the allowance transfer deadline for a control period, the owners and operators of each CAIR SO<sub>2</sub> source and each CAIR SO<sub>2</sub> unit at the source shall hold, in the source's compliance account, a tonnage equivalent in CAIR SO<sub>2</sub> allowances available for compliance deductions for the control period, as determined in accordance with 40 CFR 96.254(a) and (b), not less than the tons of total sulfur dioxide emissions for the control period from all CAIR SO<sub>2</sub> units at the source, as determined in accordance with 40 CFR Part 96, Subpart HHH.
- (2) A CAIR SO<sub>2</sub> unit shall be subject to the requirements under paragraph (1) of the Sulfur Dioxide Emission Requirements starting on the later of January 1, 2010 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 96.270(b)(1) or (2) and for each control period thereafter.
- (3) A CAIR SO<sub>2</sub> allowance shall not be deducted, for compliance with the requirements under paragraph (1) of the SO<sub>2</sub> Emission Requirements, for a control period in a calendar year before the year for which the CAIR SO<sub>2</sub> allowance was allocated.
- (4) CAIR SO<sub>2</sub> allowances shall be held in, deducted from, or transferred into or among CAIR SO<sub>2</sub> Allowance Tracking System accounts in accordance with 40 CFR Part 96, Subparts FFF and GGG.
- (5) A CAIR SO<sub>2</sub> allowance is a limited authorization to emit sulfur dioxide in accordance with the CAIR SO<sub>2</sub> Trading Program. No provision of the CAIR SO<sub>2</sub> Trading Program, the CAIR Part, or an exemption under 40 CFR 96.205 and no provision of law shall be construed to limit the authority of the state or the United States to terminate or limit such authorization.
- (6) A CAIR SO<sub>2</sub> allowance does not constitute a property right.
- (7) Upon recordation by the Administrator under 40 CFR Part 96, Subpart FFF or GGG, every allocation, transfer, or deduction of a CAIR SO<sub>2</sub> allowance to or from a CAIR SO<sub>2</sub> unit's compliance account is incorporated automatically in any CAIR Part of the source that includes the CAIR SO<sub>2</sub> unit.

#### Excess Emissions Requirements.

If a CAIR SO<sub>2</sub> source emits SO<sub>2</sub> during any control period in excess of the CAIR SO<sub>2</sub> emissions limitation, then:

- (1) The owners and operators of the source and each CAIR SO<sub>2</sub> unit at the source shall surrender the CAIR SO<sub>2</sub> allowances required for deduction under 40 CFR 96.254(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act or applicable state law; and
- (2) Each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR Part 96, Subpart AAA, the Clean Air Act, and applicable state law.

## SECTION V. CAIR PART FORM

### CLEAN AIR INTERSTATE RULE PROVISIONS

Plant Name (from STEP 1) JD Kennedy

STEP 3,  
Continued

#### Recordkeeping and Reporting Requirements.

- (1) Unless otherwise provided, the owners and operators of the CAIR SO<sub>2</sub> source and each CAIR SO<sub>2</sub> unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the Department or the Administrator.
  - (i) The certificate of representation under 40 CFR 96.213 for the CAIR designated representative for the source and each CAIR SO<sub>2</sub> unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation under 40 CFR 96.213 changing the CAIR designated representative.
  - (ii) All emissions monitoring information, in accordance with 40 CFR Part 96, Subpart HHH, of this part, provided that to the extent that 40 CFR Part 96, Subpart HHH, provides for a 3-year period for recordkeeping, the 3-year period shall apply.
  - (iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR SO<sub>2</sub> Trading Program.
  - (iv) Copies of all documents used to complete a CAIR Part form and any other submission under the CAIR SO<sub>2</sub> Trading Program or to demonstrate compliance with the requirements of the CAIR SO<sub>2</sub> Trading Program.
- (2) The CAIR designated representative of a CAIR SO<sub>2</sub> source and each CAIR SO<sub>2</sub> unit at the source shall submit the reports required under the CAIR SO<sub>2</sub> Trading Program, including those under 40 CFR Part 96, Subpart HHH.

#### Liability.

- (1) Each CAIR SO<sub>2</sub> source and each CAIR SO<sub>2</sub> unit shall meet the requirements of the CAIR SO<sub>2</sub> Trading Program.
- (2) Any provision of the CAIR SO<sub>2</sub> Trading Program that applies to a CAIR SO<sub>2</sub> source or the CAIR designated representative of a CAIR SO<sub>2</sub> source shall also apply to the owners and operators of such source and of the CAIR SO<sub>2</sub> units at the source.
- (3) Any provision of the CAIR SO<sub>2</sub> Trading Program that applies to a CAIR SO<sub>2</sub> unit or the CAIR designated representative of a CAIR SO<sub>2</sub> unit shall also apply to the owners and operators of such unit.

#### Effect on Other Authorities.

No provision of the CAIR SO<sub>2</sub> Trading Program, a CAIR Part, or an exemption under 40 CFR 96.205 shall be construed as exempting or excluding the owners and operators, and the CAIR designated representative, of a CAIR SO<sub>2</sub> source or CAIR SO<sub>2</sub> unit from compliance with any other provision of the applicable, approved State Implementation Plan, a federally enforceable permit, or the Clean Air Act.

### CAIR NO<sub>x</sub> OZONE SEASON TRADING PROGRAM

#### CAIR Part Requirements.

- (1) The CAIR designated representative of each CAIR NO<sub>x</sub> Ozone Season source and each CAIR NO<sub>x</sub> Ozone Season unit at the source shall:
  - (i) Submit to the DEP a complete and certified CAIR Part form under 40 CFR 96.322 and Rule 62-296.470, F.A.C., in accordance with the deadlines specified in Rule 62-213.420, F.A.C.; and
  - (ii) [Reserved].
- (2) The owners and operators of each CAIR NO<sub>x</sub> Ozone Season source required to have a Title V operating permit or air construction permit, and each CAIR NO<sub>x</sub> Ozone Season unit required to have a Title V operating permit or air construction permit at the source shall have a CAIR Part included in the Title V operating permit or air construction permit issued by the DEP under 40 CFR Part 96, Subpart CCCC, for the source and operate the source and the unit in compliance with such CAIR Part.

#### Monitoring, Reporting, and Recordkeeping Requirements.

- (1) The owners and operators, and the CAIR designated representative, of each CAIR NO<sub>x</sub> Ozone Season source and each CAIR NO<sub>x</sub> Ozone Season unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR Part 96, Subpart HHHH, and Rule 62-296.470, F.A.C.
- (2) The emissions measurements recorded and reported in accordance with 40 CFR Part 96, Subpart HHHH, shall be used to determine compliance by each CAIR NO<sub>x</sub> Ozone Season source with the following CAIR NO<sub>x</sub> Ozone Season Emissions Requirements.

#### NO<sub>x</sub> Ozone Season Emission Requirements.

- (1) As of the allowance transfer deadline for a control period, the owners and operators of each CAIR NO<sub>x</sub> Ozone Season source and each CAIR NO<sub>x</sub> Ozone Season unit at the source shall hold, in the source's compliance account, CAIR NO<sub>x</sub> Ozone Season allowances available for compliance deductions for the control period under 40 CFR 96.354(a) in an amount not less than the tons of total NO<sub>x</sub> emissions for the control period from all CAIR NO<sub>x</sub> Ozone Season units at the source, as determined in accordance with 40 CFR Part 96, Subpart HHHH.
- (2) A CAIR NO<sub>x</sub> Ozone Season unit shall be subject to the requirements under paragraph (1) of the NO<sub>x</sub> Ozone Season Emission Requirements starting on the later of May 1, 2009 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 96.370(b)(1),(2), or (3) and for each control period thereafter.
- (3) A CAIR NO<sub>x</sub> Ozone Season allowance shall not be deducted, for compliance with the requirements under paragraph (1) of the NO<sub>x</sub> Ozone Season Emission Requirements, for a control period in a calendar year before the year for which the CAIR NO<sub>x</sub> Ozone Season allowance was allocated.
- (4) CAIR NO<sub>x</sub> Ozone Season allowances shall be held in, deducted from, or transferred into or among CAIR NO<sub>x</sub> Ozone Season Allowance Tracking System accounts in accordance with 40 CFR Part 96, Subparts FFFF and GGGG.
- (5) A CAIR NO<sub>x</sub> Ozone Season allowance is a limited authorization to emit one ton of NO<sub>x</sub> in accordance with the CAIR NO<sub>x</sub> Ozone Season Trading Program. No provision of the CAIR NO<sub>x</sub> Ozone Season Trading Program, the CAIR Part, or an exemption under 40 CFR 96.305 and no provision of law shall be construed to limit the authority of the state or the United States to terminate or limit such authorization.
- (6) A CAIR NO<sub>x</sub> Ozone Season allowance does not constitute a property right.
- (7) Upon recordation by the Administrator under 40 CFR Part 96, Subpart EEEE, FFFF or GGGG, every allocation, transfer, or deduction of a CAIR NO<sub>x</sub> Ozone Season allowance to or from a CAIR NO<sub>x</sub> Ozone Season unit's compliance account is incorporated automatically in any CAIR Part of the source that includes the CAIR NO<sub>x</sub> Ozone Season unit.

**SECTION V. CAIR PART FORM**

**CLEAN AIR INTERSTATE RULE PROVISIONS**

Plant Name (from STEP 1) JD Kennedy

**STEP 3,  
Continued**

Excess Emissions Requirements.

If a CAIR NO<sub>x</sub> Ozone Season source emits NO<sub>x</sub> during any control period in excess of the CAIR NO<sub>x</sub> Ozone Season emissions limitation, then:

- (1) The owners and operators of the source and each CAIR NO<sub>x</sub> Ozone Season unit at the source shall surrender the CAIR NO<sub>x</sub> Ozone Season allowances required for deduction under 40 CFR 98.354(d)(1) and pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act or applicable state law, and
- (2) Each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR Part 98, Subpart AAAAA, the Clean Air Act, and applicable state law.

Recordkeeping and Reporting Requirements.

- (1) Unless otherwise provided, the owners and operators of the CAIR NO<sub>x</sub> Ozone Season source and each CAIR NO<sub>x</sub> Ozone Season unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the DEP or the Administrator.
  - (i) The certificate of representation under 40 CFR 98.313 for the CAIR designated representative for the source and each CAIR NO<sub>x</sub> Ozone Season unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation under 40 CFR 98.113 changing the CAIR designated representative.
  - (ii) All emissions monitoring information, in accordance with 40 CFR Part 96, Subpart HHHH, of this part, provided that to the extent that 40 CFR Part 96, Subpart HHHH, provides for a 3-year period for recordkeeping, the 3-year period shall apply.
  - (iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the CAIR NO<sub>x</sub> Ozone Season Trading Program.
  - (iv) Copies of all documents used to complete a CAIR Part form and any other submission under the CAIR NO<sub>x</sub> Ozone Season Trading Program or to demonstrate compliance with the requirements of the CAIR NO<sub>x</sub> Ozone Season Trading Program.
- (2) The CAIR designated representative of a CAIR NO<sub>x</sub> Ozone Season source and each CAIR NO<sub>x</sub> Ozone Season unit at the source shall submit the reports required under the CAIR NO<sub>x</sub> Ozone Season Trading Program, including those under 40 CFR Part 96, Subpart HHHH.

Liability.

- (1) Each CAIR NO<sub>x</sub> Ozone Season source and each CAIR NO<sub>x</sub> Ozone Season unit shall meet the requirements of the CAIR NO<sub>x</sub> Ozone Season Trading Program.
- (2) Any provision of the CAIR NO<sub>x</sub> Ozone Season Trading Program that applies to a CAIR NO<sub>x</sub> Ozone Season source or the CAIR designated representative of a CAIR NO<sub>x</sub> Ozone Season source shall also apply to the owners and operators of such source and of the CAIR NO<sub>x</sub> Ozone Season units at the source.
- (3) Any provision of the CAIR NO<sub>x</sub> Ozone Season Trading Program that applies to a CAIR NO<sub>x</sub> Ozone Season unit or the CAIR designated representative of a CAIR NO<sub>x</sub> Ozone Season unit shall also apply to the owners and operators of such unit.

Effect on Other Authorities.


No provision of the CAIR NO<sub>x</sub> Ozone Season Trading Program, a CAIR Part, or an exemption under 40 CFR 96.305 shall be construed as exempting or excluding the owners and operators, and the CAIR designated representative, of a CAIR NO<sub>x</sub> Ozone Season source or CAIR NO<sub>x</sub> Ozone Season unit from compliance with any other provision of the applicable, approved State Implementation Plan, a federally enforceable permit, or the Clean Air Act.

**STEP 4**

**Certification (for designated representative or alternate designated representative only)**

**Read the certification statement; provide name, title, owner company name, phone, and e-mail address; sign, and date.**

I am authorized to make this submission on behalf of the owners and operators of the CAIR source or CAIR units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Name: Athena T. Mann	Title: Vice President, Environmental Services
Company Owner Name: JEA	
Phone: (904) 665-6252	E-mail Address: mannat@jea.com
Signature 	Date 5/13/09

SECTION V. CAIR PART FORM

CLEAN AIR INTERSTATE RULE PROVISIONS

# Acid Rain, CAIR, and Hg Budget Retired Unit Exemption

For more information, see Instructions and refer to 40 CFR 72.8, 96.105, 96.205, 96.305, and 60.4105; and Rules 62-214.340(2), 62-295.470, and 62-296.480, F.A.C.

This submission is:  New  Revised

**STEP 1**

Identify the unit by plant name, State, ORIS code and unit ID#.

JD Kennedy Plant Name:	FL State:	0666 ORIS/Plant Code	CT3 Unit ID#
---------------------------	--------------	-------------------------	-----------------

Applicable Program(s): ~ Acid Rain  CAIR NO<sub>x</sub> Annual  CAIR SO<sub>2</sub>  CAIR NO<sub>x</sub> Ozone Season  
~ Mercury (Hg) Budget Trading

**STEP 2**

Identify the date on which the unit was (or will be) permanently retired.

4/1/2009

**STEP 3**

If an acid rain affected unit, identify the first full calendar year in which the unit meets (or will meet) the requirements of 40 CFR 72.8(d).

January 1, NA (not Acid Rain)

**STEP 4**

Read the special provisions.

**Acid Rain Special Provisions**

- (1) A unit exempt under Rule 62-214.340(2), F.A.C., shall not emit any sulfur dioxide and nitrogen oxides starting on the date that the exemption takes effect. The owners and operators of the unit will be allocated allowances in accordance with 40 CFR Part 73, Subpart B. If the unit is a Phase I unit, for each calendar year in Phase I, the designated representative of the unit shall submit a Phase I permit application in accordance with 40 CFR Part 72, Subparts C and D, and an annual certification report in accordance with 40 CFR 72.90 through 72.92 and is subject to 40 CFR 72.95 and 72.96.
- (2) A unit exempt under Rule 62-214.340(2), F.A.C., shall not resume operation unless the designated representative of the source that includes the unit submits a complete Acid Rain Part application under Rule 62-214.320, F.A.C., for the unit not less than 24 months prior to the date on which the unit is first to resume operation.
- (3) The owners and operators and, to the extent applicable, the designated representative of a unit exempt under Rule 62-214.340(2), F.A.C., shall comply with the requirements of Chapter 62-214, F.A.C., and the Acid Rain Program concerning all periods for which the exemption is not in effect, even if such requirements arise, or must be complied with, after the exemption takes effect.
- (4) For any period for which a unit is exempt under Rule 62-214.340(2), F.A.C., the unit is not an Acid Rain unit and is not eligible to be an opt-in source under 40 CFR Part 74. As a non-Acid Rain Unit, the unit shall continue to be subject to any other applicable requirements under Chapter 62-213, F.A.C.
- (5) For a period of 5 years from the date the records are created, the owners and operators of a unit exempt under Rule 62-214.340(2), F.A.C., shall retain at the source that includes the unit records demonstrating that the unit is permanently retired. The 5-year period for keeping records may be extended for cause, at any time prior to the end of the period, in writing by the EPA or the DEP. The owners and operators bear the burden of proof that the unit is permanently retired.
- (6) On the earlier of the following dates, a unit exempt under Rule 62-214.340(2), F.A.C., shall lose its exemption and become an Acid Rain Unit: (i) the date on which the designated representative submits an Acid Rain Part application under paragraph (2); or (ii) the date on which the designated representative is required under paragraph (2) to submit an Acid Rain Part application. For the purpose of applying monitoring requirements under 40 CFR Part 75, a unit that loses its exemption under Rule 62-214.340(2), F.A.C., shall be treated as a new unit that commenced commercial operation on the first date on which the unit resumes operation.

SECTION V. CAIR PART FORM

CLEAN AIR INTERSTATE RULE PROVISIONS

Plant Name (from STEP 1) JD Kennedy

STEP 4 (continued)

CAIR Special Provisions

- (1) A unit exempt under 40 CFR 96.105(a), 96.205(a), or 96.305(a), shall not emit any sulfur dioxide or nitrogen oxides starting on the date that the exemption takes effect. The DEP will allocate CAIR NOx allowances in accordance with Rule 62-296.470, F.A.C.
(2) For a period of 5 years from the date the records are created, the owners and operators of a unit exempt under Rule 62-296.470, F.A.C., shall retain at the source that includes the unit, records demonstrating that the unit is permanently retired. The 5-year period for keeping records may be extended for cause, at any time prior to the end of the period, in writing by the EPA or the DEP. The owners and operators bear the burden of proof that the unit is permanently retired.
(3) The owners and operators and, to the extent applicable, the CAIR designated representative of a unit exempt under 40 CFR 96.105(a), 96.205(a), or 96.305(a), shall comply with the applicable requirements of the CAIR NOx Annual Trading Program, the CAIR SO2 Trading Program, and the CAIR NOx Ozone Season Trading Program concerning all periods for which the exemption is not in effect, even if such requirements arise, or must be complied with, after the exemption takes effect.
(4) A unit exempt under 40 CFR 96.105(a), 96.205(a), or 96.305(a), and located at a source that is required, or but for this exemption would be required, to have a title V operating permit shall not resume operation unless the CAIR designated representative of the source submits a complete CAIR Part application under Rule 62-213.420, F.A.C., for the unit before the date on which the unit resumes operation.
(5) On the earlier of the following dates, a unit exempt under 40 CFR 96.105(a), 96.205(a), or 96.305(a) shall lose its exemption:
(i) the date on which the CAIR designated representative submits a CAIR Part application under Special Provision (4) above;
(ii) the date on which the CAIR designated representative is required under Special Provision (4) above to submit an CAIR Part application for the unit; or
(iii) the date on which the unit resumes operation, if the CAIR designated representative is not required to submit a CAIR Part application for the unit.
(6) For the purpose of applying monitoring, reporting and recordkeeping requirements under 40 CFR Part 96, Subparts HH, HHH, and/or HHHH, a unit that loses its exemption under 40 CFR 96.105(a), 96.205(a), or 96.305(a), shall be treated as a unit that commences commercial operation on the first date on which the unit resumes operation.

Mercury (Hg) Budget Trading Special Provisions

- (1) A unit exempt under 40 CFR 60.4105(a) shall not emit any mercury starting on the date that the exemption takes effect.
(2) The DEP will allocate Hg allowances under Rule 62-296.480, F.A.C.
(3) For a period of 5 years from the date the records are created, the owners and operators of a unit exempt under 40 CFR 60.4105(a) shall retain at the source that includes the unit, records demonstrating that the unit is permanently retired. The 5-year period for keeping records may be extended for cause, at any before the end of the period, in writing by the EPA or the DEP. The owners and operators bear the burden of proof that the unit is permanently retired.
(4) The owners and operators and, to the extent applicable, the Hg designated representative of a unit exempt under 40 CFR 60.4105(a) shall comply with the requirements of the Hg Budget Trading Program concerning all periods for which the exemption is not in effect, even if such requirements arise, or must be complied with, after the exemption takes effect.
(5) A unit exempt under 40 CFR 60.4105(a) and located at a source that is required, or but for this exemption would be required, to have a title V operating permit shall not resume operation unless the Hg designated representative of the source submits a complete Hg Budget Part application under 40 CFR 60.4122 and Rule 62-213.420, F.A.C., for the unit before the date on which the unit resumes operation.
(6) On the earlier of the following dates, a unit exempt under 40 CFR 60.4105(a) shall lose its exemption:
(i) the date on which the Hg designated representative submits a Hg Budget Part application for the unit under Special Provision (5);
(ii) the date on which the Hg designated representative is required under Special Provision (5) to submit a Hg Budget Part application for the unit; or
(iii) the date on which the unit resumes operation, if the Hg designated representative is not required to submit a Hg Budget Part application for the unit.
(7) For the purpose of applying monitoring, reporting and recordkeeping requirements under 40 CFR 60.4170 through 60.4176, a unit that loses its exemption under 40 CFR 60.4105(a) shall be treated as a unit that commences operation and commercial operation on the first date on which the unit resumes operation.

SECTION V. CAIR PART FORM

CLEAN AIR INTERSTATE RULE PROVISIONS

Plant Name (from STEP 1) JD Kennedy

**STEP 5**  
Make Statement of Compliance.


**Statement of Compliance**

I state that the unit identified above in STEP 1 was (or will be) permanently retired on the date identified in STEP 2 and will comply with the Special Provisions listed in STEP 4.

**STEP 6**  
Read the certification and sign and date.

**Certification (for designated representatives or alternate designated representatives only)**

I am authorized to make this submission on behalf of the owners and operators of the affected source and affected unit for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Name: Athena T. Mann	Title: Vice President, Environmental Services
Owner Company Name: JEA	
Phone: (904) 665-6252	Email: mannat@jea.com
Signature 	Date 5/12/09

SECTION V. CAIR PART FORM

CLEAN AIR INTERSTATE RULE PROVISIONS

# Acid Rain, CAIR, and Hg Budget Retired Unit Exemption

For more information, see instructions and refer to 40 CFR 72.8, 96.106, 96.205, 96.305, and 60.4105; and Rules 62-214.340(2), 62-296.470, and 62-296.480, F.A.C.

This submission is:  New  Revised

**STEP 1**

Identify the unit by plant name, State, ORIS code and unit ID#.

JD Kennedy Plant Name:	FL State:	0666 ORIS/Plant Code	CT4 Unit ID#
---------------------------	--------------	-------------------------	-----------------

Applicable Program(s): ~ Acid Rain  CAIR NO<sub>x</sub> Annual  CAIR SO<sub>2</sub>  CAIR NO<sub>x</sub> Ozone Season  
~ Mercury (Hg) Budget Trading

**STEP 2**

Identify the date on which the unit was (or will be) permanently retired.

4/1/2007

**STEP 3**

If an acid rain affected unit, identify the first full calendar year in which the unit meets (or will meet) the requirements of 40 CFR 72.8(d).

January 1, NA (not Acid Rain)

**STEP 4**

Read the special provisions.

**Acid Rain Special Provisions**

- (1) A unit exempt under Rule 62-214.340(2), F.A.C., shall not emit any sulfur dioxide and nitrogen oxides starting on the date that the exemption takes effect. The owners and operators of the unit will be allocated allowances in accordance with 40 CFR Part 73, Subpart B. If the unit is a Phase I unit, for each calendar year in Phase I, the designated representative of the unit shall submit a Phase I permit application in accordance with 40 CFR Part 72, Subparts C and D, and an annual certification report in accordance with 40 CFR 72.90 through 72.92 and is subject to 40 CFR 72.95 and 72.96.
- (2) A unit exempt under Rule 62-214.340(2), F.A.C., shall not resume operation unless the designated representative of the source that includes the unit submits a complete Acid Rain Part application under Rule 62-214.320, F.A.C., for the unit not less than 24 months prior to the date on which the unit is first to resume operation.
- (3) The owners and operators and, to the extent applicable, the designated representative of a unit exempt under Rule 62-214.340(2), F.A.C., shall comply with the requirements of Chapter 62-214, F.A.C., and the Acid Rain Program concerning all periods for which the exemption is not in effect, even if such requirements arise, or must be complied with, after the exemption takes effect.
- (4) For any period for which a unit is exempt under Rule 62-214.340(2), F.A.C., the unit is not an Acid Rain unit and is not eligible to be an opt-in source under 40 CFR Part 74. As a non-Acid Rain Unit, the unit shall continue to be subject to any other applicable requirements under Chapter 62-213, F.A.C.
- (5) For a period of 5 years from the date the records are created, the owners and operators of a unit exempt under Rule 62-214.340(2), F.A.C., shall retain at the source that includes the unit records demonstrating that the unit is permanently retired. The 5-year period for keeping records may be extended for cause, at any time prior to the end of the period, in writing by the EPA or the DEP. The owners and operators bear the burden of proof that the unit is permanently retired.
- (6) On the earlier of the following dates, a unit exempt under Rule 62-214.340(2), F.A.C., shall lose its exemption and become an Acid Rain Unit: (i) the date on which the designated representative submits an Acid Rain Part application under paragraph (2); or (ii) the date on which the designated representative is required under paragraph (2) to submit an Acid Rain Part application. For the purpose of applying monitoring requirements under 40 CFR Part 75, a unit that loses its exemption under Rule 62-214.340(2), F.A.C., shall be treated as a new unit that commenced commercial operation on the first date on which the unit resumes operation.



## SECTION V. CAIR PART FORM

### CLEAN AIR INTERSTATE RULE PROVISIONS

Plant Name (from STEP 1) JD Kennedy

#### STEP 4 (continued)

##### CAIR Special Provisions

- (1) A unit exempt under 40 CFR 96.105(a), 96.205(a), or 96.305(a), shall not emit any sulfur dioxide or nitrogen oxides starting on the date that the exemption takes effect. The DEP will allocate CAIR NO<sub>x</sub> allowances in accordance with Rule 62-296.470, F.A.C.
- (2) For a period of 5 years from the date the records are created, the owners and operators of a unit exempt under Rule 62-296.470, F.A.C., shall retain at the source that includes the unit, records demonstrating that the unit is permanently retired. The 5-year period for keeping records may be extended for cause, at any time prior to the end of the period, in writing by the EPA or the DEP. The owners and operators bear the burden of proof that the unit is permanently retired.
- (3) The owners and operators and, to the extent applicable, the CAIR designated representative of a unit exempt under 40 CFR 96.105(a), 96.205(a), or 96.305(a), shall comply with the applicable requirements of the CAIR NO<sub>x</sub> Annual Trading Program, the CAIR SO<sub>2</sub> Trading Program, and the CAIR NO<sub>x</sub> Ozone Season Trading Program concerning all periods for which the exemption is not in effect, even if such requirements arise, or must be complied with, after the exemption takes effect.
- (4) A unit exempt under 40 CFR 96.105(a), 96.205(a), or 96.305(a), and located at a source that is required, or but for this exemption would be required, to have a title V operating permit shall not resume operation unless the CAIR designated representative of the source submits a complete CAIR Part application under Rule 62-213.420, F.A.C., for the unit before the date on which the unit resumes operation.
- (5) On the earlier of the following dates, a unit exempt under 40 CFR 96.105(a), 96.205(a), or 96.305(a) shall lose its exemption:
  - (i) the date on which the CAIR designated representative submits a CAIR Part application under Special Provision (4) above;
  - (ii) the date on which the CAIR designated representative is required under Special Provision (4) above to submit a CAIR Part application for the unit; or
  - (iii) the date on which the unit resumes operation, if the CAIR designated representative is not required to submit a CAIR Part application for the unit.
- (6) For the purpose of applying monitoring, reporting and recordkeeping requirements under 40 CFR Part 96, Subparts HH, HHH, and/or HHHH, a unit that loses its exemption under 40 CFR 96.105(a), 96.205(a), or 96.305(a), shall be treated as a unit that commences commercial operation on the first date on which the unit resumes operation.

##### Mercury (Hg) Budget Trading Special Provisions

- (1) A unit exempt under 40 CFR 60.4105(a) shall not emit any mercury starting on the date that the exemption takes effect.
- (2) The DEP will allocate Hg allowances under Rule 62-296.480, F.A.C.
- (3) For a period of 5 years from the date the records are created, the owners and operators of a unit exempt under 40 CFR 60.4105(a) shall retain at the source that includes the unit, records demonstrating that the unit is permanently retired. The 5-year period for keeping records may be extended for cause, at any before the end of the period, in writing by the EPA or the DEP. The owners and operators bear the burden of proof that the unit is permanently retired.
- (4) The owners and operators and, to the extent applicable, the Hg designated representative of a unit exempt under 40 CFR 60.4105(a) shall comply with the requirements of the Hg Budget Trading Program concerning all periods for which the exemption is not in effect, even if such requirements arise, or must be complied with, after the exemption takes effect.
- (5) A unit exempt under 40 CFR 60.4105(a) and located at a source that is required, or but for this exemption would be required, to have a title V operating permit shall not resume operation unless the Hg designated representative of the source submits a complete Hg Budget Part application under 40 CFR 60.4122 and Rule 62-213.420, F.A.C., for the unit before the date on which the unit resumes operation.
- (6) On the earlier of the following dates, a unit exempt under 40 CFR 60.4105(a) shall lose its exemption:
  - (i) the date on which the Hg designated representative submits a Hg Budget Part application for the unit under Special Provision (5);
  - (ii) the date on which the Hg designated representative is required under Special Provision (5) to submit a Hg Budget Part application for the unit; or
  - (iii) the date on which the unit resumes operation, if the Hg designated representative is not required to submit a Hg Budget Part application for the unit.
- (7) For the purpose of applying monitoring, reporting and recordkeeping requirements under 40 CFR 60.4170 through 60.4176, a unit that loses its exemption under 40 CFR 60.4105(a) shall be treated as a unit that commences operation and commercial operation on the first date on which the unit resumes operation.

**SECTION V. CAIR PART FORM**

**CLEAN AIR INTERSTATE RULE PROVISIONS**

Plant Name (from STEP 1) JD Kennedy
-------------------------------------

**STEP 5**  
**Make Statement of Compliance.**


**Statement of Compliance**

I state that the unit identified above in STEP 1 was (or will be) permanently retired on the date identified in STEP 2 and will comply with the Special Provisions listed in STEP 4.

**STEP 6**  
**Read the certification and sign and date.**

**Certification (for designated representatives or alternate designated representatives only)**

I am authorized to make this submission on behalf of the owners and operators of the affected source and affected unit for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Name: Michael Brost		Title: Vice President, Electric Systems	
Owner Company Name: JEA			
Phone: (904) 665-7547		Email: brosmj@jea.com	
Signature			Date 4-28-08

SECTION V. CAIR PART FORM

CLEAN AIR INTERSTATE RULE PROVISIONS

# Acid Rain, CAIR, and Hg Budget Retired Unit Exemption

For more information, see instructions and refer to 40 CFR 72.8, 96.105, 96.205, 96.305, and 60.4105; and Rules 62-214.340(2), 62-296.470, and 62-296.480, F.A.C.

This submission is:  New  Revised

**STEP 1**

Identify the unit by plant name, State, ORIS code and unit ID#.

JD Kennedy	FL	0666	CT5
Plant Name:	State:	ORIS/Plant Code	Unit ID#

Applicable Program(s): - Acid Rain  CAIR NO<sub>x</sub> Annual  CAIR SO<sub>2</sub>  CAIR NO<sub>x</sub> Ozone Season  
 - Mercury (Hg) Budget Trading

**STEP 2**

Identify the date on which the unit was (or will be) permanently retired.

4/1/2007

**STEP 3**

If an acid rain affected unit, identify the first full calendar year in which the unit meets (or will meet) the requirements of 40 CFR 72.8(d).

January 1, NA (not Acid Rain)

**STEP 4**

Read the special provisions.

**Acid Rain Special Provisions**

- (1) A unit exempt under Rule 62-214.340(2), F.A.C., shall not emit any sulfur dioxide and nitrogen oxides starting on the date that the exemption takes effect. The owners and operators of the unit will be allocated allowances in accordance with 40 CFR Part 73, Subpart B. If the unit is a Phase I unit, for each calendar year in Phase I, the designated representative of the unit shall submit a Phase I permit application in accordance with 40 CFR Part 72, Subparts C and D, and an annual certification report in accordance with 40 CFR 72.90 through 72.92 and is subject to 40 CFR 72.95 and 72.96.
- (2) A unit exempt under Rule 62-214.340(2), F.A.C., shall not resume operation unless the designated representative of the source that includes the unit submits a complete Acid Rain Part application under Rule 62-214.320, F.A.C., for the unit not less than 24 months prior to the date on which the unit is first to resume operation.
- (3) The owners and operators and, to the extent applicable, the designated representative of a unit exempt under Rule 62-214.340(2), F.A.C., shall comply with the requirements of Chapter 62-214, F.A.C., and the Acid Rain Program concerning all periods for which the exemption is not in effect, even if such requirements arise, or must be complied with, after the exemption takes effect.
- (4) For any period for which a unit is exempt under Rule 62-214.340(2), F.A.C., the unit is not an Acid Rain unit and is not eligible to be an opt-in source under 40 CFR Part 74. As a non-Acid Rain Unit, the unit shall continue to be subject to any other applicable requirements under Chapter 62-213, F.A.C.
- (5) For a period of 5 years from the date the records are created, the owners and operators of a unit exempt under Rule 62-214.340(2), F.A.C., shall retain at the source that includes the unit records demonstrating that the unit is permanently retired. The 5-year period for keeping records may be extended for cause, at any time prior to the end of the period, in writing by the EPA or the DEP. The owners and operators bear the burden of proof that the unit is permanently retired.
- (6) On the earlier of the following dates, a unit exempt under Rule 62-214.340(2), F.A.C., shall lose its exemption and become an Acid Rain Unit: (i) the date on which the designated representative submits an Acid Rain Part application under paragraph (2); or (ii) the date on which the designated representative is required under paragraph (2) to submit an Acid Rain Part application. For the purpose of applying monitoring requirements under 40 CFR Part 75, a unit that loses its exemption under Rule 62-214.340(2), F.A.C., shall be treated as a new unit that commenced commercial operation on the first date on which the unit resumes operation.

SECTION V. CAIR PART FORM

CLEAN AIR INTERSTATE RULE PROVISIONS

Plant Name (from STEP 1) JD Kennedy

STEP 4  
(continued)

CAIR Special Provisions

- (1) A unit exempt under 40 CFR 96.105(a), 96.205(a), or 96.305(a), shall not emit any sulfur dioxide or nitrogen oxides starting on the date that the exemption takes effect. The DEP will allocate CAIR NO<sub>x</sub> allowances in accordance with Rule 62-296.470, F.A.C.
- (2) For a period of 5 years from the date the records are created, the owners and operators of a unit exempt under Rule 62-296.470, F.A.C., shall retain at the source that includes the unit, records demonstrating that the unit is permanently retired. The 5-year period for keeping records may be extended for cause, at any time prior to the end of the period, in writing by the EPA or the DEP. The owners and operators bear the burden of proof that the unit is permanently retired.
- (3) The owners and operators and, to the extent applicable, the CAIR designated representative of a unit exempt under 40 CFR 96.105(a), 96.205(a), or 96.305(a), shall comply with the applicable requirements of the CAIR NO<sub>x</sub> Annual Trading Program, the CAIR SO<sub>2</sub> Trading Program, and the CAIR NO<sub>x</sub> Ozone Season Trading Program concerning all periods for which the exemption is not in effect, even if such requirements arise, or must be complied with, after the exemption takes effect.
- (4) A unit exempt under 40 CFR 96.105(a), 96.205(a), or 96.305(a), and located at a source that is required, or but for this exemption would be required, to have a title V operating permit shall not resume operation unless the CAIR designated representative of the source submits a complete CAIR Part application under Rule 62-213.420, F.A.C., for the unit before the date on which the unit resumes operation.
- (5) On the earlier of the following dates, a unit exempt under 40 CFR 96.105(a), 96.205(a), or 96.305(a) shall lose its exemption:
  - (i) the date on which the CAIR designated representative submits a CAIR Part application under Special Provision (4) above;
  - (ii) the date on which the CAIR designated representative is required under Special Provision (4) above to submit a CAIR Part application for the unit; or
  - (iii) the date on which the unit resumes operation, if the CAIR designated representative is not required to submit a CAIR Part application for the unit.
- (6) For the purpose of applying monitoring, reporting and recordkeeping requirements under 40 CFR Part 96, Subparts HH, HHH, and/or HHHH, a unit that loses its exemption under 40 CFR 96.105(a), 96.205(a), or 96.305(a), shall be treated as a unit that commences commercial operation on the first date on which the unit resumes operation.

Mercury (Hg) Budget Trading Special Provisions

- (1) A unit exempt under 40 CFR 60.4105(a) shall not emit any mercury starting on the date that the exemption takes effect.
- (2) The DEP will allocate Hg allowances under Rule 62-296.480, F.A.C.
- (3) For a period of 5 years from the date the records are created, the owners and operators of a unit exempt under 40 CFR 60.4105(a) shall retain at the source that includes the unit, records demonstrating that the unit is permanently retired. The 5-year period for keeping records may be extended for cause, at any time before the end of the period, in writing by the EPA or the DEP. The owners and operators bear the burden of proof that the unit is permanently retired.
- (4) The owners and operators and, to the extent applicable, the Hg designated representative of a unit exempt under 40 CFR 60.4105(a) shall comply with the requirements of the Hg Budget Trading Program concerning all periods for which the exemption is not in effect, even if such requirements arise, or must be complied with, after the exemption takes effect.
- (5) A unit exempt under 40 CFR 60.4105(a) and located at a source that is required, or but for this exemption would be required, to have a title V operating permit shall not resume operation unless the Hg designated representative of the source submits a complete Hg Budget Part application under 40 CFR 60.4122 and Rule 62-213.420, F.A.C., for the unit before the date on which the unit resumes operation.
- (6) On the earlier of the following dates, a unit exempt under 40 CFR 60.4105(a) shall lose its exemption:
  - (i) the date on which the Hg designated representative submits a Hg Budget Part application for the unit under Special Provision (5);
  - (ii) the date on which the Hg designated representative is required under Special Provision (5) to submit a Hg Budget Part application for the unit; or
  - (iii) the date on which the unit resumes operation, if the Hg designated representative is not required to submit a Hg Budget Part application for the unit.
- (7) For the purpose of applying monitoring, reporting and recordkeeping requirements under 40 CFR 60.4170 through 60.4176, a unit that loses its exemption under 40 CFR 60.4105(a) shall be treated as a unit that commences operation and commercial operation on the first date on which the unit resumes operation.

SECTION V. CAIR PART FORM

CLEAN AIR INTERSTATE RULE PROVISIONS

Plant Name (from STEP 1) JD Kennedy

**STEP 5**  
Make Statement of Compliance.


**Statement of Compliance**

I state that the unit identified above in STEP 1 was (or will be) permanently retired on the date identified in STEP 2 and will comply with the Special Provisions listed in STEP 4.

**STEP 6**  
Read the certification and sign and date.

**Certification (for designated representatives or alternate designated representatives only)**

I am authorized to make this submission on behalf of the owners and operators of the affected source and affected unit for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Name: Michael Brost		Title: Vice President, Electric Systems	
Owner Company Name: JEA			
Phone: (904) 665-7547		Email: brosmj@jea.com	
Signature 		Date 4-28-08	

## SECTION VI. APPENDICES

---

### CONTENTS

- Appendix A-1. Formats: Abbreviations, Acronyms, Citations, and Identification Numbers
- Appendix I-1. List of Insignificant Emissions Units and/or Activities
- Appendix U-1. List of Unregulated Emissions Units and/or Activities
- Appendix GC. General Conditions
- Appendix CC. Common Conditions
- Appendix STR. Stack Testing Requirements
- Appendix CS. Table 297.310-1 Calibration Schedule
- Appendix NA. NSPS Subpart A - General Provisions
- Appendix NGG. NSPS Subpart GG - Stationary Gas Turbines
- Appendix NKKKK. NSPS Subpart KKKK - Stationary Gas Turbines
- Appendix TV-6. Title V Conditions (version dated 6/23/2006)
- Appendix JEPB. Rule 2 Conditions
- Appendix H. Permitting History

SECTION VI. APPENDIX A-1

FORMATS: ABBREVIATIONS, ACRONYMS, CITATIONS, AND IDENTIFICATION NUMBERS

(version dated 02/05/97)

**Abbreviations and Acronyms:**

°F: Degrees Fahrenheit  
**BACT:** Best Available Control Technology  
**CFR:** Code of Federal Regulations  
**DEP:** State of Florida, Department of Environmental Protection  
**DARM:** Division of Air Resource Management  
**EPA:** United States Environmental Protection Agency  
**F.A.C.:** Florida Administrative Code  
**F.S.:** Florida Statute  
**ISO:** International Standards Organization  
**LAT:** Latitude  
**LONG:** Longitude  
**MMBtu:** million British thermal units  
**MW:** Megawatt  
**ORIS:** Office of Regulatory Information Systems  
**SOA:** Specific Operating Agreement  
**UTM:** Universal Transverse Mercator

**Citations:**

*The following examples illustrate the methods used in this permit to abbreviate and cite the references of rules, regulations, guidance memorandums, permit numbers, and ID numbers.*

Code of Federal Regulations:

*Example:* [40 CFR 60.334]

Where: 40           reference to Title 40  
          CFR       reference to Code of Federal Regulations  
          60        reference to Part 60  
          60.334   reference to Regulation 60.334

Florida Administrative Code (F.A.C.) Rules:

*Example:* [Rule 62-213, F.A.C.]

Where: 62           reference to Title 62  
          62-213     reference to Chapter 62-213  
          62-213.205 reference to Rule 62-213.205, F.A.C.

**ISO:** International Standards Organization refers to those conditions at 288 degrees K, 60 percent relative humidity, and 101.3 kilopascals pressure.

SECTION VI. APPENDIX A-1

FORMATS: ABBREVIATIONS, ACRONYMS, CITATIONS, AND IDENTIFICATION NUMBERS

---

**Identification Numbers:**

Facility Identification (ID) Number:

*Example:* Facility ID No.: 1050221

*Where:*

105 = 3-digit number code identifying the facility is located in Polk County  
0221 = 4-digit number assigned by state database.

Permit Numbers:

*Example:* 1050221-002-AV, or  
1050221-001-AC, or  
1050221-003-AO, or  
1050221-004-AF

*Where:*

AC = Air Construction Permit  
AV = Air Operation Permit (Title V Source)  
AO = Air Operation Permit  
AF = Federally Enforceable State Operation Permit  
105 = 3-digit number code identifying the facility is located in Polk County  
0221 = 4-digit number assigned by permit tracking database  
001 or 002 = 3-digit sequential project number assigned by permit tracking database

*Example:* PSD-FL-185  
PA95-01  
AC53-208321

*Where:*

PSD = Prevention of Significant Deterioration Permit  
PA = Power Plant Siting Act Permit  
AC = old Air Construction Permit numbering  
208321 = identifies the specific permit project number



**SECTION VI. APPENDIX I-1**

**LIST OF INSIGNIFICANT EMISSIONS UNITS AND/OR ACTIVITIES**

The facilities, emissions units, or pollutant-emitting activities listed in Rule 62-210.300(3)(a), F.A.C., Categorical Exemptions, are exempt from the permitting requirements of Chapters 62-210 and 62-4, F.A.C.; provided, however, that exempt emissions units shall be subject to any applicable emission limiting standards and the emissions from exempt emissions units or activities shall be considered in determining the potential emissions of the facility containing such emissions units. Emissions units and pollutant-emitting activities exempt from permitting under Rule 62-210.300(3)(a), F.A.C., shall not be exempt from the permitting requirements of Chapter 62-213, F.A.C., if they are contained within a Title V source; however, such emissions units and activities shall be considered insignificant for Title V purposes provided they also meet the criteria of Rule 62-213.430(6)(b), F.A.C. No emissions unit shall be entitled to an exemption from permitting under Rule 62-210.300(3)(a), F.A.C., if its emissions, in combination with the emissions of other units and activities at the facility, would cause the facility to emit or have the potential to emit any pollutant in such amount as to make the facility a Title V source.

The below listed emissions units and/or activities are considered insignificant pursuant to Rule 62-213.430(6), F.A.C.

Brief Description of Emissions Units and/or Activities:

**A. Storage Tanks.**

1. JEA Tank #5	Magnesium Oxide	10,000 gallons
2. JEA Tank #6	Lube Oil - Units 9/10	9,400 gallons
3. JEA Tank #7	Lube Oil - Units 8/9	4,800 gallons
4. JEA Tank #8	Black Start Diesel	3,000 gallons
5. JEA Tank #9	Mineral Acid	5,000 gallons
6. JEA Tank #10	Caustic	5,000 gallons
7. JEA Tank #11	Hypochloride	15,228 gallons
8. JEA Tank #12	FeSO <sub>4</sub>	2,500 gallons
9. JEA Tank #15	Sodium BiSulfite	2,500 gallons

**B. Emergency Generator.**

1. There is one emergency generator at this site. The emergency generator has historically fired less than 10,000 gallons per year of diesel fuel. The emergency generator draws its fuel from a single diesel fuel oil storage tank (the fuel oil sulfur content is equal to or less than 0.5%, by weight).

**C. Black-start Generators.**

1. There are two black-start generators at this site. These generators have historically fired a total amount of less than 10,000 gallons per year. They draw their fuel from a single diesel storage tank (the fuel oil delivered is the same as that delivered for the emergency generator, i.e., with a sulfur content equal to or less than 0.5%, by weight).

**D. Fuel Gas Heater.**

1. There is one approximately 3.2 MMBtu/hr natural gas fired heater at this site.

SECTION VI. APPENDIX U-1

LIST OF UNREGULATED EMISSIONS UNITS AND/OR ACTIVITIES

Unregulated Emissions Units and/or Activities. An emissions unit which emits no “emissions-limited pollutant” and which is subject to no unit-specific work practice standard, though it may be subject to regulations applied on a facility-wide basis (e.g., unconfined emissions, odor, general opacity) or to regulations that require only that it be able to prove exemption from unit-specific emissions or work practice standards.

**E.U. ID No.**    **Brief Description of Emissions Units and/or Activity**

- 010            Storage Tanks (tanks 1 and 4)
- 014            Storage Tank (tank 13)

A. EU-010: Storage Tanks.

- 1. JEA Tank #1            No. 6 Fuel Oil Storage            4,578,000 gallons
- 2. JEA Tank #4            No. 6 Fuel Oil Storage            4,578,000 gallons

B. EU-014: Storage Tank.

- 1. JEA Tank #13            No. 2 Fuel Oil Storage            1,512,000 gallons

**SECTION VI. APPENDIX GC**  
**GENERAL CONDITIONS**

---

The permittee shall comply with the following general conditions from Rule 62-4.160, F.A.C.

1. The terms, conditions, requirements, limitations, and restrictions set forth in this permit are "Permit Conditions" and are binding and enforceable pursuant to Sections 403.161, 403.727, or 403.859 through 403.861, F.S. The permittee is placed on notice that the Department will review this permit periodically and may initiate enforcement action for any violation of these conditions.
2. This permit is valid only for the specific processes and operations applied for and indicated in the approved drawings or exhibits. Any unauthorized deviation from the approved drawings, exhibits, specifications, or conditions of this permit may constitute grounds for revocation and enforcement action by the Department.
3. As provided in Subsections 403.087(6) and 403.722(5), F.S., the issuance of this permit does not convey and vested rights or any exclusive privileges. Neither does it authorize any injury to public or private property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations. This permit is not a waiver or approval of any other Department permit that may be required for other aspects of the total project which are not addressed in the permit.
4. This permit conveys no title to land or water, does not constitute State recognition or acknowledgment of title, and does not constitute authority for the use of submerged lands unless herein provided and the necessary title or leasehold interests have been obtained from the State. Only the Trustees of the Internal Improvement Trust Fund may express State opinion as to title.
5. This permit does not relieve the permittee from liability for harm or injury to human health or welfare, animal, or plant life, or property caused by the construction or operation of this permitted source, or from penalties therefore; nor does it allow the permittee to cause pollution in contravention of F.S. and Department rules, unless specifically authorized by an order from the Department.
6. The permittee shall properly operate and maintain the facility and systems of treatment and control (and related appurtenances) that are installed or used by the permittee to achieve compliance with the conditions of this permit, as required by Department rules. This provision includes the operation of backup or auxiliary facilities or similar systems when necessary to achieve compliance with the conditions of the permit and when required by Department rules.
7. The permittee, by accepting this permit, specifically agrees to allow authorized Department personnel, upon presentation of credentials or other documents as may be required by law and at a reasonable time, access to the premises, where the permitted activity is located or conducted to:
  - a. Have access to and copy and records that must be kept under the conditions of the permit;
  - b. Inspect the facility, equipment, practices, or operations regulated or required under this permit, and,
  - c. Sample or monitor any substances or parameters at any location reasonably necessary to assure compliance with this permit or Department rules.

Reasonable time may depend on the nature of the concern being investigated.

8. If, for any reason, the permittee does not comply with or will be unable to comply with any condition or limitation specified in this permit, the permittee shall immediately provide the Department with the following information:
  - a. A description of and cause of non-compliance; and
  - b. The period of noncompliance, including dates and times; or, if not corrected, the anticipated time the non-compliance is expected to continue, and steps being taken to reduce, eliminate, and prevent recurrence of the non-compliance.

The permittee shall be responsible for any and all damages which may result and may be subject to enforcement action by the Department for penalties or for revocation of this permit.

**SECTION VI. APPENDIX GC**  
**GENERAL CONDITIONS**

---

9. In accepting this permit, the permittee understands and agrees that all records, notes, monitoring data and other information relating to the construction or operation of this permitted source which are submitted to the Department may be used by the Department as evidence in any enforcement case involving the permitted source arising under the F.S. or Department rules, except where such use is prescribed by Sections 403.73 and 403.111, F.S. Such evidence shall only be used to the extent it is consistent with the Florida Rules of Civil Procedure and appropriate evidentiary rules.
10. The permittee agrees to comply with changes in Department rules and F.S. after a reasonable time for compliance, provided, however, the permittee does not waive any other rights granted by F.S. or Department rules.
11. This permit is transferable only upon Department approval in accordance with Rules 62-4.120 and 62-730.300, F.A.C., as applicable. The permittee shall be liable for any non-compliance of the permitted activity until the transfer is approved by the Department.
12. This permit or a copy thereof shall be kept at the work site of the permitted activity.
13. This permit also constitutes:
  - a. Determination of Best Available Control Technology (Not Applicable);
  - b. Determination of Prevention of Significant Deterioration (Not Applicable); and,
  - c. Compliance with New Source Performance Standards (NSPS Subparts A and GG).
14. The permittee shall comply with the following:
  - a. Upon request, the permittee shall furnish all records and plans required under Department rules. During enforcement actions, the retention period for all records will be extended automatically unless otherwise stipulated by the Department.
  - b. The permittee shall hold at the facility or other location designated by this permit records of all monitoring information (including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation) required by the permit, copies of all reports required by this permit, and records of all data used to complete the application or this permit. These materials shall be retained at least three years from the date of the sample, measurement, report, or application unless otherwise specified by Department rule.  

{Permitting note: The conditional exemption for asphalt concrete plants at Rule 62-210.300(3)(c)2.g., F.A.C., requires the retention of all records for five (5) years.}
  - c. Records of monitoring information shall include:
    - (1) The date, exact place, and time of sampling or measurements;
    - (2) The person responsible for performing the sampling or measurements;
    - (3) The dates analyses were performed;
    - (4) The person responsible for performing the analyses;
    - (5) The analytical techniques or methods used; and
    - (6) The results of such analyses.
15. When requested by the Department, the permittee shall within a reasonable time furnish any information required by law which is needed to determine compliance with the permit. If the permittee becomes aware that relevant facts were not submitted or were incorrect in the permit application or in any report to the Department, such facts or information shall be corrected promptly.

**SECTION VI. APPENDIX CC**  
**COMMON CONDITIONS**

---

Unless otherwise specified in the permit, the following conditions apply to all emissions units and activities at the facility.

**EMISSIONS AND CONTROLS**

1. **Plant Operation, Problems:** If temporarily unable to comply with any of the conditions of the permit due to breakdown of equipment or destruction by fire, wind or other cause, the permittee shall notify each Compliance Authority as soon as possible, but at least within one working day, excluding weekends and holidays. The notification shall include: pertinent information as to the cause of the problem; steps being taken to correct the problem and prevent future recurrence; and, where applicable, the owner's intent toward reconstruction of destroyed facilities. Such notification does not release the permittee from any liability for failure to comply with the conditions of this permit or the regulations. [Rule 62-4.130, F.A.C.]
2. **Circumvention:** The permittee shall not circumvent the air pollution control equipment or allow the emission of air pollutants without this equipment operating properly. [Rule 62-210.650, F.A.C.]
3. **Excess Emissions, Allowed:** Excess emissions resulting from startup, shutdown or malfunction of any emissions unit shall be permitted providing (1) best operational practices to minimize emissions are adhered to and (2) the duration of excess emissions shall be minimized but in no case exceed two hours in any 24 hour period unless specifically authorized by the Department for longer duration. This state provision cannot be used to vary any applicable NSPS requirements from 40 CFR 60. [Rule 62-210.700(1), F.A.C.]
4. **Excess Emissions, Prohibited:** Excess emissions caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure that may reasonably be prevented during startup, shutdown or malfunction shall be prohibited. This state provision cannot be used to vary any applicable NSPS requirements from 40 CFR 60. [Rule 62-210.700(4), F.A.C.]
5. **Excess Emissions, Notification:** In case of excess emissions resulting from malfunctions, the permittee shall notify the Department or the appropriate Local Program (designee) in accordance with Rule 62-4.130, F.A.C. A full written report on the malfunctions shall be submitted in a quarterly report, if requested by the Department or its designee. This state provision cannot be used to vary any applicable NSPS requirements from 40 CFR 60. [Rule 62-210.700(6), F.A.C.]
6. **General Pollutant Emission Limiting Standards. Volatile Organic Compounds Emissions or Organic Solvents Emissions:** No person shall store, pump, handle, process, load, unload or use in any process or installation, volatile organic compounds or organic solvents without applying known and existing vapor emission control devices or systems deemed necessary and ordered by the Department or its designee.

Such controls include the following:

- a. Tightly cover or close all VOC containers when they are not in use.
- b. Tightly cover all open tanks which contain VOCs when they are not in use.
- c. Maintain all pipes, valves, fittings, etc., which handle VOCs in good operating condition.
- d. Confine rags used with VOCs to tightly closed, fire-proof containers when not in use.
- e. Immediately confine and clean up VOC spills and make sure wastes are placed in closed containers for reuse, recycling or proper disposal.

{Permitting Note: Nothing has been deemed necessary at the time of issuance of this permit.}

[Rule 62-296.320(1), F.A.C.]

7. **Not Federally Enforceable. General Pollutant Emission Limiting Standards. Objectionable Odor Prohibited:** No person shall cause, suffer, allow or permit the discharge of air pollutants, which cause or contribute to an objectionable odor. An "objectionable odor" means any odor present in the outdoor atmosphere which by itself or in combination with other odors, is or may be harmful or injurious to human health or welfare, which unreasonably interferes with the comfortable use and enjoyment of life or property, or which creates a nuisance. [Rules 62-296.320(2) and 62-210.200(Definitions), F.A.C.]

**SECTION VI. APPENDIX CC**  
**COMMON CONDITIONS**

---

8. General Particulate Emissions Limiting Standard. General Visible Emissions Standard: Except for emissions units that are subject to a particulate matter or opacity limit set forth or established by rule and reflected by conditions in this permit, no person shall cause, let, permit, suffer or allow to be discharged into the atmosphere the emissions of air pollutants from any activity equal to or greater than 20 percent opacity. EPA Method 9 is the method of compliance pursuant to Chapter 62-297, F.A.C. [Rules 62-296.320(4)(b)1. & 4., F.A.C.]
9. Unconfined Particulate Emissions: No person shall cause, let, permit, suffer or allow the emission of unconfined particulate matter from any activity, including vehicular movement; transportation of materials; construction, alteration, demolition or wrecking; or industrially related activities such as loading, unloading, storing or handling; without taking reasonable precautions to prevent such emission.

Reasonable precautions include the following:

- a. Paving and maintenance of roads, parking areas and yards.
- b. Application of water or other dust suppressants to control emission from such activities as demolition of buildings, grading roads, construction, and land clearing.
- c. Application of asphalt, water, or other dust suppressants to unpaved roads, yards, open stock piles and similar activities.
- d. Removal of particulate matter from roads and other paved areas under the control of the owner or operator of the facility to prevent reentrainment, and from buildings or work areas to prevent particulate from becoming airborne.
- e. Landscaping or planting of vegetation.
- f. Use of hoods, fans, filters, and similar equipment to contain, capture and/or vent particulate matter.
- g. Confining abrasive blasting where possible.
- h. Enclosure or covering of conveyor systems.
- i. Posting and enforcing a speed limit for vehicles traveling on roadways on site.

[Rule 62-296.320(4)(c), F.A.C.]

**RECORDS AND REPORTS**

10. Records Retention: All measurements, records, and other data required by this permit shall be documented in a permanent, legible format and retained for at least five (5) years following the date on which such measurements, records, or data are recorded. Records shall be made available to the Department or its designee upon request. [Rule 62-213.440(1)(b)2., F.A.C.]
11. Annual Operating Report: The permittee shall submit an annual report that summarizes the actual operating rates and emissions from this facility. Annual operating reports shall be submitted to the Compliance Authority by March 1<sup>st</sup> of each year. [Rule 62-210.370(3), F.A.C.]
12. When appropriate, any recording, monitoring, or reporting requirements that are time-specific shall be in accordance with the effective date of the permit, which defines day one. [Rule 62-213.440, F.A.C.]

**SECTION VI. APPENDIX STR**  
**STACK TESTING REQUIREMENTS**

---

Unless otherwise specified in the permit, the following conditions apply to all emissions units and activities at the facility.

**COMPLIANCE TESTING REQUIREMENTS**

1. Required Number of Test Runs: For mass emission limitations, a compliance test shall consist of three complete and separate determinations of the total air pollutant emission rate through the test section of the stack or duct and three complete and separate determinations of any applicable process variables corresponding to the three distinct time periods during which the stack emission rate was measured; provided, however, that three complete and separate determinations shall not be required if the process variables are not subject to variation during a compliance test, or if three determinations are not necessary in order to calculate the unit's emission rate. The three required test runs shall be completed within one consecutive five-day period. In the event that a sample is lost or one of the three runs must be discontinued because of circumstances beyond the control of the owner or operator, and a valid third run cannot be obtained within the five-day period allowed for the test, the Secretary or his or her designee may accept the results of two complete runs as proof of compliance, provided that the arithmetic mean of the two complete runs is at least 20% below the allowable emission limiting standard. [Rule 62-297.310(1), F.A.C.]
2. Operating Rate During Testing: Testing of emissions shall be conducted with the emissions unit operating at permitted capacity. If it is impractical to test at permitted capacity, an emissions unit may be tested at less than the maximum permitted capacity; in this case, subsequent emissions unit operation is limited to 110 percent of the test rate until a new test is conducted. Once the unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purpose of additional compliance testing to regain the authority to operate at the permitted capacity. Permitted capacity is defined as 90 to 100 percent of the maximum operation rate allowed by the permit. [Rule 62-297.310(2), F.A.C.]
3. Calculation of Emission Rate: For each emissions performance test, the indicated emission rate or concentration shall be the arithmetic average of the emission rate or concentration determined by each of the three separate test runs unless otherwise specified in a particular test method or applicable rule. [Rule 62-297.310(3), F.A.C.]
4. Applicable Test Procedures: Tests shall be conducted in accordance with all applicable requirements of Chapter 62-297, F.A.C.
  - a. *Required Sampling Time*.
    - (1) Unless otherwise specified in the applicable rule, the required sampling time for each test run shall be no less than one hour and no greater than four hours, and the sampling time at each sampling point shall be of equal intervals of at least two minutes.
    - (2) Opacity Compliance Tests. When either EPA Method 9 or DEP Method 9 is specified as the applicable opacity test method, the required minimum period of observation for a compliance test shall be sixty (60) minutes for emissions units which emit or have the potential to emit 100 tons per year or more of particulate matter, and thirty (30) minutes for emissions units which have potential emissions less than 100 tons per year of particulate matter and are not subject to a multiple-valued opacity standard. The opacity test observation period shall include the period during which the highest opacity emissions can reasonably be expected to occur. Exceptions to these requirements are as follows:
      - (a) For batch, cyclical processes, or other operations which are normally completed within less than the minimum observation period and do not recur within that time, the period of observation shall be equal to the duration of the batch cycle or operation completion time.
      - (b) The observation period for special opacity tests that are conducted to provide data to establish a surrogate standard pursuant to Rule 62-297.310(5)(k), F.A.C., Waiver of Compliance Test Requirements, shall be established as necessary to properly establish the relationship between a proposed surrogate standard and an existing mass emission limiting standard.
      - (c) The minimum observation period for opacity tests conducted by employees or agents of the Department to verify the day-to-day continuing compliance of a unit or activity with an applicable opacity standard shall be twelve minutes.
  - b. *Minimum Sample Volume*. Unless otherwise specified in the applicable rule or test method, the minimum sample volume per run shall be 25 dry standard cubic feet.

**SECTION VI. APPENDIX STR**  
**STACK TESTING REQUIREMENTS**

---

- c. *Required Flow Rate Range.* For EPA Method 5 particulate sampling, acid mist/sulfur dioxide, and fluoride sampling which uses Greenburg Smith type impingers, the sampling nozzle and sampling time shall be selected such that the average sampling rate will be between 0.5 and 1.0 actual cubic feet per minute, and the required minimum sample volume will be obtained.
- d. *Calibration of Sampling Equipment.* Calibration of the sampling train equipment shall be conducted in accordance with the schedule shown in Table 297.310-1, F.A.C. (See Appendix CS)
- e. *Allowed Modification to EPA Method 5.* When EPA Method 5 is required, the following modification is allowed: the heated filter may be separated from the impingers by a flexible tube.

[Rule 62-297.310(4), F.A.C.]

5. Determination of Process Variables [Rule 62-297.310(5), F.A.C.]

- a. *Required Equipment.* The owner or operator of an emissions unit for which compliance tests are required shall install, operate, and maintain equipment or instruments necessary to determine process variables, such as process weight input or heat input, when such data are needed in conjunction with emissions data to determine the compliance of the emissions unit with applicable emission limiting standards.
- b. *Accuracy of Equipment.* Equipment or instruments used to directly or indirectly determine process variables, including devices such as belt scales, weight hoppers, flow meters, and tank scales, shall be calibrated and adjusted to indicate the true value of the parameter being measured with sufficient accuracy to allow the applicable process variable to be determined within 10% of its true value.

6. Sampling Facilities: The permittee shall install permanent stack sampling ports and provide sampling facilities that meet the requirements of Rule 62-297.310(6), F.A.C. *Sampling facilities include sampling ports, work platforms, access to work platforms, electrical power, and sampling equipment support. All stack sampling facilities must also comply with all applicable Occupational Safety and Health Administration (OSHA) Safety and Health Standards described in 29 CFR Part 1910, Subparts D and E. [Rule 62-297.310(6), F.A.C.]*

- a. *Permanent Test Facilities.* The owner or operator of an emissions unit for which a compliance test, other than a visible emissions test, is required on at least an annual basis, shall install and maintain permanent stack sampling facilities.
- b. *Temporary Test Facilities.* The owner or operator of an emissions unit that is not required to conduct a compliance test on at least an annual basis may use permanent or temporary stack sampling facilities. If the owner chooses to use temporary sampling facilities on an emissions unit, and the Department elects to test the unit, such temporary facilities shall be installed on the emissions unit within 5 days of a request by the Department and remain on the emissions unit until the test is completed.

c. *Sampling Ports.*

- (1) All sampling ports shall have a minimum inside diameter of 3 inches.
- (2) The ports shall be capable of being sealed when not in use.
- (3) The sampling ports shall be located in the stack at least 2 stack diameters or equivalent diameters downstream and at least 0.5 stack diameter or equivalent diameter upstream from any fan, bend, constriction or other flow disturbance.
- (4) For emissions units for which a complete application to construct has been filed prior to December 1, 1980, at least two sampling ports, 90 degrees apart, shall be installed at each sampling location on all circular stacks that have an outside diameter of 15 feet or less. For stacks with a larger diameter, four sampling ports, each 90 degrees apart, shall be installed. For emissions units for which a complete application to construct is filed on or after December 1, 1980, at least two sampling ports, 90 degrees apart, shall be installed at each sampling location on all circular stacks that have an outside diameter of 10 feet or less. For stacks with larger diameters, four sampling ports, each 90 degrees apart, shall be installed. On horizontal circular ducts, the ports shall be located so that the probe can enter the stack vertically, horizontally or at a 45 degree angle.
- (5) On rectangular ducts, the cross sectional area shall be divided into the number of equal areas in accordance with EPA Method 1. Sampling ports shall be provided which allow access to each sampling point. The ports



**SECTION VI. APPENDIX STR**  
**STACK TESTING REQUIREMENTS**

---

shall be located so that the probe can be inserted perpendicular to the gas flow.

d. *Work Platforms.*

- (1) Minimum size of the working platform shall be 24 square feet in area. Platforms shall be at least 3 feet wide.
- (2) On circular stacks with 2 sampling ports, the platform shall extend at least 110 degrees around the stack.
- (3) On circular stacks with more than two sampling ports, the work platform shall extend 360 degrees around the stack.
- (4) All platforms shall be equipped with an adequate safety rail (ropes are not acceptable), toe board, and hinged floor-opening cover if ladder access is used to reach the platform. The safety rail directly in line with the sampling ports shall be removable so that no obstruction exists in an area 14 inches below each sample port and 6 inches on either side of the sampling port.

e. *Access to Work Platform.*

- (1) Ladders to the work platform exceeding 15 feet in length shall have safety cages or fall arresters with a minimum of 3 compatible safety belts available for use by sampling personnel.
- (2) Walkways over free-fall areas shall be equipped with safety rails and toe boards.

f. *Electrical Power.*

- (1) A minimum of two 120-volt AC, 20-amp outlets shall be provided at the sampling platform within 20 feet of each sampling port.
- (2) If extension cords are used to provide the electrical power, they shall be kept on the plant's property and be available immediately upon request by sampling personnel.

g. *Sampling Equipment Support.*

- (1) A three-quarter inch eyebolt and an angle bracket shall be attached directly above each port on vertical stacks and above each row of sampling ports on the sides of horizontal ducts.
  - (a) The bracket shall be a standard 3 inch × 3 inch × one-quarter inch equal-legs bracket which is 1 and one-half inches wide. A hole that is one-half inch in diameter shall be drilled through the exact center of the horizontal portion of the bracket. The horizontal portion of the bracket shall be located 14 inches above the centerline of the sampling port.
  - (b) A three-eighth inch bolt which protrudes 2 inches from the stack may be substituted for the required bracket. The bolt shall be located 15 and one-half inches above the centerline of the sampling port.
  - (c) The three-quarter inch eyebolt shall be capable of supporting a 500 pound working load. For stacks that are less than 12 feet in diameter, the eyebolt shall be located 48 inches above the horizontal portion of the angle bracket. For stacks that are greater than or equal to 12 feet in diameter, the eyebolt shall be located 60 inches above the horizontal portion of the angle bracket. If the eyebolt is more than 120 inches above the platform, a length of chain shall be attached to it to bring the free end of the chain to within safe reach from the platform.
- (2) A complete monorail or dual rail arrangement may be substituted for the eyebolt and bracket.
- (3) When the sample ports are located in the top of a horizontal duct, a frame shall be provided above the port to allow the sample probe to be secured during the test.

7. Frequency of Compliance Tests: The following provisions apply only to those emissions units that are subject to an emissions limiting standard for which compliance testing is required. [Rule 62-297.310(7), F.A.C.]

a. *General Compliance Testing.*

1. The owner or operator of a new or modified emissions unit that is subject to an emission limiting standard shall conduct a compliance test that demonstrates compliance with the applicable emission limiting standard prior to obtaining an operation permit for such emissions unit.
2. For excess emission limitations for particulate matter specified in Rule 62-210.700, F.A.C., a compliance test shall be conducted annually while the emissions unit is operating under soot blowing conditions in each federal fiscal year during which soot blowing is part of normal emissions unit operation, except that such test

**SECTION VI. APPENDIX STR**  
**STACK TESTING REQUIREMENTS**

---

shall not be required in any federal fiscal year in which a fossil fuel steam generator does not burn liquid and/or solid fuel for more than 400 hours other than during startup.

3. The owner or operator of an emissions unit that is subject to any emission limiting standard shall conduct a compliance test that demonstrates compliance with the applicable emission limiting standard prior to obtaining a renewed operation permit. Emissions units that are required to conduct an annual compliance test may submit the most recent annual compliance test to satisfy the requirements of this provision. In renewing an air operation permit pursuant to sub-subparagraph 62-210.300(2)(a)3.b., c., or d., F.A.C., the Department shall not require submission of emission compliance test results for any emissions unit that, during the year prior to renewal:
    - (a) Did not operate; or
    - (b) In the case of a fuel burning emissions unit, burned liquid and/or solid fuel for a total of no more than 400 hours,
  4. During each federal fiscal year (October 1 – September 30), unless otherwise specified by rule, order, or permit, the owner or operator of each emissions unit shall have a formal compliance test conducted for:
    - (a) Visible emissions, if there is an applicable standard;
    - (b) Each of the following pollutants, if there is an applicable standard, and if the emissions unit emits or has the potential to emit: 5 tons per year or more of lead or lead compounds measured as elemental lead; 30 tons per year or more of acrylonitrile; or 100 tons per year or more of any other regulated air pollutant; and
    - (c) c. Each NESHAP pollutant, if there is an applicable emission standard.
  5. An annual compliance test for particulate matter emissions shall not be required for any fuel burning emissions unit that, in a federal fiscal year, does not burn liquid and/or solid fuel, other than during startup, for a total of more than 400 hours.
  6. For fossil fuel steam generators on a semi-annual particulate matter emission compliance testing schedule, a compliance test shall not be required for any six-month period in which liquid and/or solid fuel is not burned for more than 200 hours other than during startup.
  7. For emissions units electing to conduct particulate matter emission compliance testing quarterly pursuant to paragraph 62-296.405(2)(a), F.A.C., a compliance test shall not be required for any quarter in which liquid and/or solid fuel is not burned for more than 100 hours other than during startup.
  8. Any combustion turbine that does not operate for more than 400 hours per year shall conduct a visible emissions compliance test once per each five-year period, coinciding with the term of its air operation permit.
  9. The owner or operator shall notify the Department, at least 15 days prior to the date on which each formal compliance test is to begin, of the date, time, and place of each such test, and the test contact person who will be responsible for coordinating and having such test conducted for the owner or operator.
  10. An annual compliance test conducted for visible emissions shall not be required for units exempted from air permitting pursuant to subsection 62-210.300(3), F.A.C.; units determined to be insignificant pursuant to subparagraph 62-213.300(2)(a)1., F.A.C., or paragraph 62-213.430(6)(b), F.A.C.; or units permitted under the General Permit provisions in paragraph 62-210.300(4)(a) or Rule 62-213.300, F.A.C., unless the general permit specifically requires such testing.
- b. *Special Compliance Tests.* When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it shall require the owner or operator of the emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department.
  - c. *Waiver of Compliance Test Requirements.* If the owner or operator of an emissions unit that is subject to a compliance test requirement demonstrates to the Department, pursuant to the procedure established in Rule 62-

**SECTION VI. APPENDIX STR**  
**STACK TESTING REQUIREMENTS**

---

297.620, F.A.C., that the compliance of the emissions unit with an applicable weight emission limiting standard can be adequately determined by means other than the designated test procedure, such as specifying a surrogate standard of no visible emissions for particulate matter sources equipped with a bag house or specifying a fuel analysis for sulfur dioxide emissions, the Department shall waive the compliance test requirements for such emissions units and order that the alternate means of determining compliance be used, provided, however, the provisions of paragraph 62-297.310(7)(b), F.A.C., shall apply.

**RECORDS AND REPORTS**

8. Test Reports: [Rule 62-297.310(8), F.A.C.]
- a. The owner or operator of an emissions unit for which a compliance test is required shall file a report with the Department on the results of each such test.
  - b. The required test report shall be filed with the Department as soon as practical but no later than 45 days after the last sampling run of each test is completed.
  - c. The test report shall provide sufficient detail on the emissions unit tested and the test procedures used to allow the Department to determine if the test was properly conducted and the test results properly computed. As a minimum, the test report, other than for an EPA or DEP Method 9 test, shall provide the following information.
    1. The type, location, and designation of the emissions unit tested.
    2. The facility at which the emissions unit is located.
    3. The owner or operator of the emissions unit.
    4. The normal type and amount of fuels used and materials processed, and the types and amounts of fuels used and material processed during each test run.
    5. The means, raw data and computations used to determine the amount of fuels used and materials processed, if necessary to determine compliance with an applicable emission limiting standard.
    6. The type of air pollution control devices installed on the emissions unit, their general condition, their normal operating parameters (pressure drops, total operating current and GPM scrubber water), and their operating parameters during each test run.
    7. A sketch of the duct within 8 stack diameters upstream and 2 stack diameters downstream of the sampling ports, including the distance to any upstream and downstream bends or other flow disturbances.
    8. The date, starting time and duration of each sampling run.
    9. The test procedures used, including any alternative procedures authorized pursuant to Rule 62-297.620, F.A.C. Where optional procedures are authorized in this chapter, indicate which option was used.
    10. The number of points sampled and configuration and location of the sampling plane.
    11. For each sampling point for each run, the dry gas meter reading, velocity head, pressure drop across the stack, temperatures, average meter temperatures and sample time per point.
    12. The type, manufacturer and configuration of the sampling equipment used.
    13. Data related to the required calibration of the test equipment.
    14. Data on the identification, processing and weights of all filters used.
    15. Data on the types and amounts of any chemical solutions used.
    16. Data on the amount of pollutant collected from each sampling probe, the filters, and the impingers, are reported separately for the compliance test.
    17. The names of individuals who furnished the process variable data, conducted the test, analyzed the samples and prepared the report.
    18. All measured and calculated data required to be determined by each applicable test procedure for each run.
    19. The detailed calculations for one run that relate the collected data to the calculated emission rate.
    20. The applicable emission standard and the resulting maximum allowable emission rate for the emissions unit

**SECTION VI. APPENDIX STR**  
**STACK TESTING REQUIREMENTS**

---

plus the test result in the same form and unit of measure.

21. A certification that, to the knowledge of the owner or his authorized agent, all data submitted are true and correct. When a compliance test is conducted for the Department or its agent, the person who conducts the test shall provide the certification with respect to the test procedures used. The owner or his authorized agent shall certify that all data required and provided to the person conducting the test are true and correct to his knowledge.

**SECTION VI. APPENDIX CS**  
**TABLE 297-310-1 CALIBRATION SCHEDULE**

(version dated 10/7/96)

ITEM	MINIMUM CALIBRATION FREQUENCY	REFERENCE INSTRUMENT	TOLERANCE
Liquid in glass thermometer	Annually	ASTM Hg in glass ref. thermometer or equivalent, or thermometric points	+/-2%
Bimetallic thermometer	Quarterly	Calibration liquid in glass thermometer	5 degrees F
Thermocouple	Annually	ASTM Hg in glass ref. thermometer, NBS calibrated reference and potentiometer	5 degrees F
Barometer	Monthly	Hg barometer or NOAA station	+/-1% scale
Pitot Tube	When required or when damaged	By construction or measurements in wind tunnel D greater than 16" and standard pitot tube	See EPA Method 2, Fig. 2-2 & 2-3
Probe Nozzles	Before each test or when nicked, dented, or corroded	Micrometer	+/-0.001" mean of at least three readings Max. deviation between readings 0.004"
Dry Gas Meter and Orifice Meter	1. Full Scale: Annually - When received; - When 5% change observed. 2. One Point: Semiannually 3. Check after each test series	Spirometer or calibrated wet test or dry gas test meter  Comparison check	2%  5%

Note: This table is referenced in Rule 62-297.310(4)(d), F.A.C.

**SECTION VI. APPENDIX NA**  
**NSPS SUBPART A - GENERAL PROVISIONS**

---

**Subpart A - General Provisions for 40 CFR 60**

**40 CFR 60.1 Applicability.**

- (a) Except as provided in 40 CFR 60 subparts B and C, the provisions of this part apply to the owner or operator of any stationary source which contains an affected facility, the construction or modification of which is commenced after the date of publication in this part of any standard (or, if earlier, the date of publication of any proposed standard) applicable to that facility.
- (b) Any new or revised standard of performance promulgated pursuant to section 111(b) of the Act shall apply to the owner or operator of any stationary source which contains an affected facility, the construction or modification of which is commenced after the date of publication in this part of such new or revised standard (or, if earlier, the date of publication of any proposed standard) applicable to that facility.
- (c) In addition to complying with the provisions of this part, the owner or operator of an affected facility may be required to obtain an operating permit issued to stationary sources by an authorized State air pollution control agency or by the Administrator of the U.S. Environmental Protection Agency (EPA) pursuant to Title V of the Clean Air Act (CAA) as amended November 15, 1990 (42 U.S.C. 7661).

**40 CFR 60.5 Determination of construction or modification.**

- (a) When requested to do so by an owner or operator, the Administrator will make a determination of whether action taken or intended to be taken by such owner or operator constitutes construction (including reconstruction) or modification or the commencement thereof within the meaning of this part.
- (b) The Administrator will respond to any request for a determination under paragraph (a) of this section within 30 days of receipt of such request.

**40 CFR 60.6 Review of plans.**

- (a) When requested to do so by an owner or operator, the Administrator will review plans for construction or modification for the purpose of providing technical advice to the owner or operator.
- (b) (1) A separate request shall be submitted for each construction or modification project.  
(2) Each request shall identify the location of such project, and be accompanied by technical information describing the proposed nature, size, design, and method of operation of each affected facility involved in such project, including information on any equipment to be used for measurement or control of emissions.
- (c) Neither a request for plans review nor advice furnished by the Administrator in response to such request shall:
  - (1) relieve an owner or operator of legal responsibility for compliance with any provision of this part or of any applicable State or local requirement, or
  - (2) prevent the Administrator from implementing or enforcing any provision of this part or taking any other action authorized by the Act.

**40 CFR 60.7 Notification and recordkeeping.**

- (a) Any owner or operator subject to the provisions of this part shall furnish the Administrator written notification or, if acceptable to both the Administrator and the owner or operator of a source, electronic notification, as follows:
  - (1) A notification of the date construction (or reconstruction as defined under 40 CFR 60.15) of an affected facility is commenced postmarked no later than 30 days after such date. This requirement shall not apply in the case of mass-produced facilities which are purchased in completed form.
  - (2) Reserved.
  - (3) A notification of the actual date of initial startup of an affected facility postmarked within 15 days after such date.
  - (4) A notification of any physical or operational change to an existing facility which may increase the emission rate of any air pollutant to which a standard applies, unless that change is specifically exempted under an applicable

**SECTION VI. APPENDIX NA**  
**NSPS SUBPART A - GENERAL PROVISIONS**

---

subpart or in 40 CFR 60.14(e). This notice shall be postmarked 60 days or as soon as practicable before the change is commenced and shall include information describing the precise nature of the change, present and proposed emission control systems, productive capacity of the facility before and after the change, and the expected completion date of the change. The Administrator may request additional relevant information subsequent to this notice.

- (5) A notification of the date upon which demonstration of the continuous monitoring system performance commences in accordance with 40 CFR 60.13(c). Notification shall be postmarked not less than 30 days prior to such date.
  - (6) A notification of the anticipated date for conducting the opacity observations required by 40 CFR 60.11(e)(1) of this part. The notification shall also include, if appropriate, a request for the Administrator to provide a visible emissions reader during a performance test. The notification shall be postmarked not less than 30 days prior to such date.
  - (7) A notification that continuous opacity monitoring system data results will be used to determine compliance with the applicable opacity standard during a performance test required by 40 CFR 60.8 in lieu of Method 9 observation data as allowed by 40 CFR 60.11(e)(5). This notification shall be postmarked not less than 30 days prior to the date of the performance test.
- (b) Any owner or operator subject to the provisions of this part shall maintain records of the occurrence and duration of any startup, shutdown, or malfunction in the operation of an affected facility; any malfunction of the air pollution control equipment; or any periods during which a continuous monitoring system or monitoring device is inoperative.
  - (c) Each owner or operator required to install a continuous monitoring system (CMS) or monitoring device shall submit an excess emissions and monitoring systems performance report (excess emissions are defined in applicable subparts) and/or a summary report form (see paragraph (d) of this section) to the Administrator semiannually, except when: more frequent reporting is specifically required by an applicable subpart; or the Administrator, on a case-by-case basis, determines that more frequent reporting is necessary to accurately assess the compliance status of the source. All reports shall be postmarked by the 30th day following the end of each six-month period. Written reports of excess emissions shall include the following information:
    - (1) The magnitude of excess emissions computed in accordance with 40 CFR 60.13(h), any conversion factor(s) used, and the date and time of commencement and completion of each time period of excess emissions. The process operating time during the reporting period.
    - (2) Specific identification of each period of excess emissions that occurs during startups, shutdowns, and malfunctions of the affected facility. The nature and cause of any malfunction (if known), the corrective action taken or preventative measures adopted.
    - (3) The date and time identifying each period during which the continuous monitoring system was inoperative except for zero and span checks and the nature of the system repairs or adjustments.
    - (4) When no excess emissions have occurred or the continuous monitoring system(s) have not been inoperative, repaired, or adjusted, such information shall be stated in the report.
  - (d) The summary report form shall contain the information and be in the format shown in Figure 1 unless otherwise specified by the Administrator. One summary report form shall be submitted for each pollutant monitored at each affected facility.
    - (1) If the total duration of excess emissions for the reporting period is less than 1 percent of the total operating time for the reporting period and CMS downtime for the reporting period is less than 5 percent of the total operating time for the reporting period, only the summary report form shall be submitted and the excess emission report described in 40 CFR 60.7(c) need not be submitted unless requested by the Administrator.
    - (2) If the total duration of excess emissions for the reporting period is 1 percent or greater of the total operating time for the reporting period or the total CMS downtime for the reporting period is 5 percent or greater of the total operating time for the reporting period, the summary report form and the excess emission report described in 40 CFR 60.7(c) shall both be submitted.

**SECTION VI. APPENDIX NA**  
**NSPS SUBPART A - GENERAL PROVISIONS**

**Figure 1. Summary Report**  
**Gaseous and Opacity Excess Emission and Monitoring System Performance**

Company: \_\_\_\_\_

Address: \_\_\_\_\_

Process Unit(s) Description: \_\_\_\_\_

Emission Limitation: \_\_\_\_\_

Pollutant (Circle One): SO<sub>2</sub> NO<sub>x</sub> TRS H<sub>2</sub>S CO Opacity

Reporting Period Dates: From \_\_\_\_\_ to \_\_\_\_\_

Total source operating time in reporting period <sup>1</sup>: \_\_\_\_\_

Monitor Manufacturer: \_\_\_\_\_

Monitor Model No.: \_\_\_\_\_

Date of Latest CMS Certification or Audit: \_\_\_\_\_

Emission Data Summary <sup>1</sup>	CMS Performance Summary <sup>1</sup>
1. Duration of excess emissions in reporting period due to: a. Startup/shutdown ..... _____ b. Control equipment problems ..... _____ c. Process problems ..... _____ d. Other known causes ..... _____ e. Unknown causes ..... _____ 2. Total duration of excess emissions ..... _____ 3. $\frac{[\text{Total duration of excess emissions}] \times (100\%)}{[\text{Total source operating time}]}$ ..... % <sup>2</sup>	1. CMS downtime in reporting period due to: a. Monitor equipment malfunctions ..... _____ b. Non-Monitor equipment malfunctions ..... _____ c. Quality assurance calibration ..... _____ d. Other known causes ..... _____ e. Unknown causes ..... _____ 2. Total CMS Downtime ..... _____ 3. $\frac{[\text{Total CMS Downtime}] \times (100\%)}{[\text{Total source operating time}]}$ ..... % <sup>2</sup>

<sup>1</sup> For opacity, record all times in minutes. For gases, record all times in hours.

<sup>2</sup> For the reporting period: If the total duration of excess emissions is 1 percent or greater of the total operating time or the total CMS downtime is 5 percent or greater of the total operating time, both the summary report form and the excess emission report described in 40 CFR 60.7(c) shall be submitted.

*On a separate page, describe any changes since last quarter in CMS, process or controls.*

I certify that the information contained in this report is true, accurate, and complete.

Name: \_\_\_\_\_

Signature: \_\_\_\_\_

Title: \_\_\_\_\_

Date: \_\_\_\_\_



**SECTION VI. APPENDIX NA**  
**NSPS SUBPART A - GENERAL PROVISIONS**

---

- (e) (1) Notwithstanding the frequency of reporting requirements specified in paragraph (c) of this section, an owner or operator who is required by an applicable subpart to submit excess emissions and monitoring systems performance reports (and summary reports) on a quarterly (or more frequent) basis may reduce the frequency of reporting for that standard to semiannual if the following conditions are met:
- (i) For 1 full year (e.g., 4 quarterly or 12 monthly reporting periods) the affected facility's excess emissions and monitoring systems reports submitted to comply with a standard under this part continually demonstrate that the facility is in compliance with the applicable standard;
  - (ii) The owner or operator continues to comply with all recordkeeping and monitoring requirements specified in this subpart and the applicable standard; and
  - (iii) The Administrator does not object to a reduced frequency of reporting for the affected facility, as provided in paragraph (e)(2) of this section.
- (2) The frequency of reporting of excess emissions and monitoring systems performance (and summary) reports may be reduced only after the owner or operator notifies the Administrator in writing of his or her intention to make such a change and the Administrator does not object to the intended change. In deciding whether to approve a reduced frequency of reporting, the Administrator may review information concerning the source's entire previous performance history during the required recordkeeping period prior to the intended change, including performance test results, monitoring data, and evaluations of an owner or operator's conformance with operation and maintenance requirements. Such information may be used by the Administrator to make a judgment about the source's potential for noncompliance in the future. If the Administrator disapproves the owner or operator's request to reduce the frequency of reporting, the Administrator will notify the owner or operator in writing within 45 days after receiving notice of the owner or operator's intention. The notification from the Administrator to the owner or operator will specify the grounds on which the disapproval is based. In the absence of a notice of disapproval within 45 days, approval is automatically granted.
- (3) As soon as monitoring data indicate that the affected facility is not in compliance with any emission limitation or operating parameter specified in the applicable standard, the frequency of reporting shall revert to the frequency specified in the applicable standard, and the owner or operator shall submit an excess emissions and monitoring systems performance re-port (and summary report, if required) at the next appropriate reporting period following the noncomplying event. After demonstrating compliance with the applicable standard for another full year, the owner or operator may again request approval from the Administrator to reduce the frequency of reporting for that standard as provided for in paragraphs (e)(1) and (e)(2) of this section.
- (f) Any owner or operator subject to the provisions of this part shall maintain a file of all measurements, including continuous monitoring system, monitoring device, and performance testing measurements; all continuous monitoring system performance evaluations; all continuous monitoring system or monitoring device calibration checks; adjustments and maintenance performed on these systems or devices; and all other information required by this part recorded in a permanent form suitable for inspection. The file shall be retained for at least two years following the date of such measurements, maintenance, reports, and records, except as follows:
- (1) This paragraph applies to owners or operators required to install a continuous emissions monitoring system (CEMS) where the CEMS installed is automated, and where the calculated data averages do not exclude periods of CEMS breakdown or malfunction. An automated CEMS records and reduces the measured data to the form of the pollutant emission standard through the use of a computerized data acquisition system. In lieu of maintaining a file of all CEMS sub-hourly measurements as required under paragraph (f) of this section, the owner or operator shall retain the most recent consecutive three averaging periods of sub-hourly measurements and a file that contains a hard copy of the data acquisition system algorithm used to reduce the measured data into the reportable form of the standard.
  - (2) This paragraph applies to owners or operators required to install a CEMS where the measured data is manually reduced to obtain the reportable form of the standard, and where the calculated data averages do not exclude periods of CEMS breakdown or malfunction. In lieu of maintaining a file of all CEMS sub-hourly measurements as required under paragraph (f) of this section, the owner or operator shall retain all sub-hourly measurements for the

**SECTION VI. APPENDIX NA**  
**NSPS SUBPART A - GENERAL PROVISIONS**

---

most recent reporting period. The sub-hourly measurements shall be retained for 120 days from the date of the most recent summary or excess emission report submitted to the Administrator.

- (3) The Administrator or delegated authority, upon notification to the source, may require the owner or operator to maintain all measurements as required by paragraph (f) of this section, if the Administrator or the delegated authority determines these records are required to more accurately assess the compliance status of the affected source.
- (g) If notification substantially similar to that in 40 CFR 60.7(a) is required by any other State or local agency, sending the Administrator a copy of that notification will satisfy the requirements of 40 CFR 60.7(a).
- (h) Individual subparts of this part may include specific provisions which clarify or make inapplicable the provisions set forth in this section.

**40 CFR 60.8 Performance tests.**

- (a) Within 60 days after achieving the maximum production rate at which the affected facility will be operated, but not later than 180 days after initial startup of such facility and at such other times as may be required by the Administrator under section 114 of the Act, the owner or operator of such facility shall conduct performance test(s) and furnish the Administrator a written report of the results of such performance test(s).
- (b) Performance tests shall be conducted and data reduced in accordance with the test methods and procedures contained in each applicable subpart unless the Administrator (1) specifies or approves, in specific cases, the use of a reference method with minor changes in methodology, (2) approves the use of an equivalent method, (3) approves the use of an alternative method the results of which he has determined to be adequate for indicating whether a specific source is in compliance, (4) waives the requirement for performance tests because the owner or operator of a source has demonstrated by other means to the Administrator's satisfaction that the affected facility is in compliance with the standard, or (5) approves shorter sampling times and smaller sample volumes when necessitated by process variables or other factors. Nothing in 40 CFR 60.8 shall be construed to abrogate the Administrator's authority to require testing under section 114 of the Act.
- (c) Performance tests shall be conducted under such conditions as the Administrator shall specify to the plant operator based on representative performance of the affected facility. The owner or operator shall make available to the Administrator such records as may be necessary to determine the conditions of the performance tests. Operations during periods of startup, shutdown, and malfunction shall not constitute representative conditions for the purpose of a performance test nor shall emissions in excess of the level of the applicable emission limit during periods of startup, shutdown, and malfunction be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard.
- (d) The owner or operator of an affected facility shall provide the Administrator at least 30 days prior notice of any performance test, except as specified under other subparts, to afford the Administrator the opportunity to have an observer present. If after 30 days notice for an initially scheduled performance test, there is a delay (due to operational problems, etc.) in conducting the scheduled performance test, the owner or operator of an affected facility shall notify the administrator (or delegated State or local agency) as soon as possible of any delay in the original test date, either by providing at least 7 days prior notice of the rescheduled date of the performance test, or by arranging a rescheduled date with the Administrator (or delegated State or local agency) by mutual agreement.
- (e) The owner or operator of an affected facility shall provide, or cause to be provided, performance testing facilities as follows:
  - (1) Sampling ports adequate for test methods applicable to such facility. This includes
    - (i) constructing the air pollution control system such that volumetric flow rates and pollutant emission rates can be accurately determined by applicable test methods and procedures and
    - (ii) providing a stack or duct free of cyclonic flow during performance tests, as demonstrated by applicable test methods and procedures.
  - (2) Safe sampling platform(s).

**SECTION VI. APPENDIX NA**  
**NSPS SUBPART A - GENERAL PROVISIONS**

---

- (3) Safe access to sampling platform(s).
- (4) Utilities for sampling and testing equipment.
- (f) Unless otherwise specified in the applicable subpart, each performance test shall consist of three separate runs using the applicable test method. Each run shall be conducted for the time and under the conditions specified in the applicable standard. For the purpose of determining compliance with an applicable standard, the arithmetic means of results of the three runs shall apply. In the event that a sample is accidentally lost or conditions occur in which one of the three runs must be discontinued because of forced shutdown, failure of an irreplaceable portion of the sample train, extreme meteorological conditions, or other circumstances, beyond the owner or operator's control, compliance may, upon the Administrator's approval, be determined using the arithmetic mean of the results of the two other runs.

**40 CFR 60.9 Availability of information.**

The availability to the public of information provided to, or otherwise obtained by, the Administrator under this part shall be governed by part 2 of this chapter. (Information submitted voluntarily to the Administrator for the purposes of §§ 60.5 and 60.6 is governed by §§ 2.201 through 2.213 of this chapter and not by § 2.301 of this chapter.)

**40 CFR 60.10 State authority.**

The provisions of 40 CFR 60 shall not be construed in any manner to preclude any State or political subdivision thereof from:

- (a) Adopting and enforcing any emission standard or limitation applicable to an affected facility, provided that such emission standard or limitation is not less stringent than the standard applicable to such facility.
- (b) Requiring the owner or operator of an affected facility to obtain permits, licenses, or approvals prior to initiating construction, modification, or operation of such facility.

**40 CFR 60.11 Compliance with standards and maintenance requirements.**

- (a) Compliance with standards in this part, other than opacity standards, shall be determined only by performance tests established by 40 CFR 60.8, unless otherwise specified in the applicable standard.
- (b) Compliance with opacity standards in this part shall be determined by conducting observations in accordance with Method 9 in appendix A of this part, any alternative method that is approved by the Administrator, or as provided in 40 CFR 60.11(e)(5). For purposes of determining initial compliance, the minimum total time of observations shall be 3 hours (30 6-minute averages) for the performance test or other set of observations (meaning those fugitive-type emission sources subject only to an opacity standard).
- (c) The opacity standards set forth in this part shall apply at all times except during periods of startup, shutdown, malfunction, and as otherwise provided in the applicable standard.
- (d) At all times, including periods of startup, shutdown, and malfunction, owners and operators shall, to the extent practicable, maintain and operate any affected facility including associated air pollution control equipment in a manner consistent with good air pollution control practice for minimizing emissions. Determination of whether acceptable operating and maintenance procedures are being used will be based on information available to the Administrator which may include, but is not limited to, monitoring results, opacity observations, review of operating and maintenance procedures, and inspection of the source.
- (e) (1) For the purpose of demonstrating initial compliance, opacity observations shall be conducted concurrently with the initial performance test required in 40 CFR 60.8 unless one of the following conditions apply. If no performance test under 40 CFR 60.8 is required, then opacity observations shall be conducted within 60 days after achieving the maximum production rate at which the affected facility will be operated but no later than 180 days after initial startup of the facility. If visibility or other conditions prevent the opacity observations from being conducted concurrently with the initial performance test required under 40 CFR 60.8, the source owner or operator shall reschedule the opacity observations as soon after the initial performance test as possible, but not later than 30 days thereafter, and shall advise the Administrator of the rescheduled date. In these cases, the 30-day prior notification to the Administrator required in 40 CFR 60.7(a)(6) shall be waived. The rescheduled opacity observations shall be

**SECTION VI. APPENDIX NA**  
**NSPS SUBPART A - GENERAL PROVISIONS**

---

conducted (to the extent possible) under the same operating conditions that existed during the initial performance test conducted under 40 CFR 60.8. The visible emissions observer shall determine whether visibility or other conditions prevent the opacity observations from being made concurrently with the initial performance test in accordance with procedures contained in Method 9 of Appendix B of this part. Opacity readings of portions of plumes which contain condensed, uncombined water vapor shall not be used for purposes of determining compliance with opacity standards. The owner or operator of an affected facility shall make available, upon request by the Administrator, such records as may be necessary to determine the conditions under which the visual observations were made and shall provide evidence indicating proof of current visible observer emission certification. Except as provided in 40 CFR 60.11(e)(5), the results of continuous monitoring by transmissometer which indicate that the opacity at the time visual observations were made was not in excess of the standard are probative but not conclusive evidence of the actual opacity of an emission, provided that the source shall meet the burden of proving that the instrument used meets (at the time of the alleged violation) Performance Specification 1 in Appendix B of 40 CFR 60, has been properly maintained and (at the time of the alleged violation) that the resulting data have not been altered in any way.

- (2) Except as provided in 40 CFR 60.11(e)(3), the owner or operator of an affected facility to which an opacity standard in this part applies shall conduct opacity observations in accordance with 40 CFR 60.11(b), shall record the opacity of emissions, and shall report to the Administrator the opacity results along with the results of the initial performance test required under 40 CFR 60.8. The inability of an owner or operator to secure a visible emissions observer shall not be considered a reason for not conducting the opacity observations concurrent with the initial performance test.
- (3) The owner or operator of an affected facility to which an opacity standard in this part applies may request the Administrator to determine and to record the opacity of emissions from the affected facility during the initial performance test and at such times as may be required. The owner or operator of the affected facility shall report the opacity results. Any request to the Administrator to determine and to record the opacity of emissions from an affected facility shall be included in the notification required in 40 CFR 60.7(a)(6). If, for some reason, the Administrator cannot determine and record the opacity of emissions from the affected facility during the performance test, then the provisions of 40 CFR 60.7(e)(1) shall apply.
- (4) The owner or operator of an affected facility using a continuous opacity monitor (transmissometer) shall record the monitoring data produced during the initial performance test required by 40 CFR 60.8 and shall furnish the Administrator a written report of the monitoring results along with Method 9 and 40 CFR 60.8 performance test results.
- (5) The owner or operator of an affected facility subject to an opacity standard may submit, for compliance purposes, continuous opacity monitoring system (COMS) data results produced during any performance test required under 40 CFR 60.8 in lieu of Method 9 observation data. If an owner or operator elects to submit COMS data for compliance with the opacity standard, he shall notify the Administrator of that decision, in writing, at least 30 days before any performance test required under 40 CFR 60.8 is conducted. Once the owner or operator of an affected facility has notified the Administrator to that effect, the COMS data results will be used to determine opacity compliance during subsequent tests required under 40 CFR 60.8 until the owner or operator notifies the Administrator, in writing, to the contrary. For the purpose of determining compliance with the opacity standard during a performance test required under 40 CFR 60.8 using COMS data, the minimum total time of COMS data collection shall be averages of all 6-minute continuous periods within the duration of the mass emission performance test. Results of the COMS opacity determinations shall be submitted along with the results of the performance test required under 60.8. The owner or operator of an affected facility using a COMS for compliance purposes is responsible for demonstrating that the COMS meets the requirements specified in 40 CFR 60.13(c), that the COMS has been properly maintained and operated, and that the resulting data have not been altered in any way. If COMS data results are submitted for compliance with the opacity standard for a period of time during which Method 9 data indicates noncompliance, the Method 9 data will be used to determine compliance with the opacity standard.
- (6) Upon receipt from an owner or operator of the written reports of the results of the performance tests required by 40 CFR 60.8, the opacity observation results and observer certification required by 40 CFR 60.11(e)(1), and the

**SECTION VI. APPENDIX NA**  
**NSPS SUBPART A - GENERAL PROVISIONS**

---

COMS results, if applicable, the Administrator will make a finding concerning compliance with opacity and other applicable standards. If COMS data results are used to comply with an opacity standard, only those results are required to be submitted along with the performance test results required by 40 CFR 60.8. If the Administrator finds that an affected facility is in compliance with all applicable standards for which performance tests are conducted in accordance with 40 CFR 60.8 of this part but during the time such performance tests are being conducted fails to meet any applicable opacity standard, the shall notify the owner or operator and advise him that he may petition the Administrator within 10 days of receipt of notification to make appropriate adjustment to the opacity standard for the affected facility.

- (7) The Administrator will grant such a petition upon a demonstration by the owner or operator that the affected facility and associated air pollution control equipment was operated and maintained in a manner to minimize the opacity of emissions during the performance tests; that the performance tests were performed under the conditions established by the Administrator; and that the affected facility and associated air pollution control equipment were incapable of being adjusted or operated to meet the applicable opacity standard.
  - (8) The Administrator will establish an opacity standard for the affected facility meeting the above requirements at a level at which the source will be able, as indicated by the performance and opacity tests, to meet the opacity standard at all times during which the source is meeting the mass or concentration emission standard. The Administrator will promulgate the new opacity standard in the Federal Register.
- (f) Special provisions set forth under an applicable subpart of 40 CFR 60 shall supersede any conflicting provisions of 40 CFR 60.11.

**40 CFR 60.12 Circumvention.**

No owner or operator subject to the provisions of this part shall build, erect, install, or use any article, machine, equipment or process, the use of which conceals an emission which would otherwise constitute a violation of an applicable standard. Such concealment includes, but is not limited to, the use of gaseous diluents to achieve compliance with an opacity standard or with a standard which is based on the concentration of a pollutant in the gases discharged to the atmosphere.

**40 CFR 60.13 Monitoring requirements.**

- (a) For the purposes of this section, all continuous monitoring systems required under applicable subparts shall be subject to the provisions of this section upon promulgation of performance specifications for continuous monitoring systems under Appendix B of 40 CFR 60 and, if the continuous monitoring system is used to demonstrate compliance with emission limits on a continuous basis, Appendix F to 40 CFR 60, unless otherwise specified in an applicable subpart or by the Administrator. Appendix F is applicable December 4, 1987.
- (b) All continuous monitoring systems and monitoring devices shall be installed and operational prior to conducting performance tests under 40 CFR 60.8. Verification of operational status shall, as a minimum, include completion of the manufacturer's written requirements or recommendations for installation, operation, and calibration of the device.
- (c) If the owner or operator of an affected facility elects to submit continuous opacity monitoring system (COMS) data for compliance with the opacity standard as provided under 40 CFR 60.11(e)(5), he/she shall conduct a performance evaluation of the COMS as specified in Performance Specification 1, Appendix B, of 40 CFR 60 before the performance test required under 40 CFR 60.8 is conducted. Otherwise, the owner or operator of an affected facility shall conduct a performance evaluation of the COMS or continuous emission monitoring system (CEMS) during any performance test required under 40 CFR 60.8 or within 30 days thereafter in accordance with the applicable performance specification in Appendix B of 40 CFR 60. The owner or operator of an affected facility shall conduct COMS or CEMS performance evaluations at such other times as may be required by the Administrator under section 114 of the Act.
  - (1) The owner or operator of an affected facility using a COMS to determine opacity compliance during any performance test required under 40 CFR 60.8 and as described in 40 CFR 60.11(e)(5), shall furnish the Administrator two or, upon request, more copies of a written report of the results of the COMS performance evaluation described in 40 CFR 60.13(c) at least 10 days before the performance test required under 40 CFR 60.8 is conducted.

**SECTION VI. APPENDIX NA**  
**NSPS SUBPART A - GENERAL PROVISIONS**

---

- (2) Except as provided in 40 CFR 60.13(c)(1), the owner or operator of an affected facility shall furnish the Administrator within 60 days of completion two or, upon request, more copies of a written report of the results of the performance evaluation.
- (d) (1) Owners and operators of a CEMS installed in accordance with the provisions of this part, must check the zero (or low level value between 0 and 20 percent of span value) and span (50 to 100 percent of span value) calibration drifts at least once daily in accordance with a written procedure. The zero and span shall, as a minimum, be adjusted whenever the 24-hour zero drift or 24-hour span drift exceeds two times the limits of the applicable performance specifications in Appendix B. The system must allow the amount of excess zero and span drift measured at the 24-hour interval checks to be recorded and quantified, whenever specified. For a COMS, the optical surfaces, exposed to the effluent gases, must be cleaned before performing the zero and upscale drift adjustments, except for systems using automatic zero adjustments. The optical surfaces must be cleaned when the cumulative automatic zero compensation exceeds 4 percent opacity.
- (2) Unless otherwise approved by the Administrator, the following procedures shall be followed for continuous monitoring systems measuring opacity of emissions. Minimum procedures shall include a method for producing a simulated zero opacity condition and an upscale (span) opacity condition using a certified neutral density filter or other related technique to produce a known obscuration of the light beam. Such procedures shall provide a system check of the analyzer internal optical surfaces and all electronic circuitry including the lamp and photo detector assembly.
- (e) Except for system breakdowns, repairs, calibration checks, and zero and span adjustments required under 40 CFR 60.13(d), all continuous monitoring systems shall be in continuous operation and shall meet minimum frequency of operation requirements as follows:
- (1) All continuous monitoring systems referenced by 40 CFR 60.13(c) for measuring opacity of emissions shall complete a minimum of one cycle of sampling and analyzing for each successive 10-second period and one cycle of data recording for each successive 6-minute period.
- (2) All continuous monitoring systems referenced by 40 CFR 60.13(c) for measuring emissions, except opacity, shall complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period.
- (f) All continuous monitoring systems or monitoring devices shall be installed such that representative measurements of emissions or process parameters from the affected facility are obtained. Additional procedures for location of continuous monitoring systems contained in the applicable Performance Specifications of appendix B of 40 CFR 60 shall be used.
- (g) (1) When more than one continuous monitoring system is used to measure the emissions from only one affected facility (e.g. multiple breechings, multiple outlets), the owner or operator shall report the results as required from each continuous monitoring system. When the effluent from one affected facility is released to the atmosphere through more than one point, the owner or operator shall install an applicable continuous monitoring system on each separate effluent unless installation of fewer systems is approved by the Administrator.
- (2) When the effluents from two or more affected facilities subject to the same opacity standard are combined before being released to the atmosphere, the owner or operator may either install a continuous opacity monitoring system at a location monitoring the combined effluent or install an opacity combiner system comprised of opacity and flow monitoring systems on each stream, and shall report as per 40 CFR 60.7(c) on the combined effluent. When the affected facilities are not subject to the same opacity standard applicable, except for documented periods of shutdown of the affected facility, subject to the most stringent opacity standard shall apply
- (3) When the effluents from two or more affected facilities subject to the same emissions standard, other than opacity, are combined before released to the atmosphere, the owner or operator may install applicable continuous monitoring systems on each effluent or on the combined effluent. When the affected facilities are not subject to the continuous monitoring standard, separate continuous monitoring systems shall be installed on each effluent and the owner or operator shall report as required for each affected facility.

**SECTION VI. APPENDIX NA**  
**NSPS SUBPART A - GENERAL PROVISIONS**

---

- (h) Owners or operators of all continuous monitoring systems for measurement of opacity shall reduce all data to 6-minute averages and for continuous monitoring systems other than opacity to 1-hour averages for time periods as defined in 40 CFR 60.2. Six-minute opacity averages shall be calculated from 36 or more data points equally spaced over each 6-minute period. For continuous monitoring systems other than opacity, 1-hour averages shall be computed from four or more data points equally spaced over each 1-hour period. Data recorded during periods of continuous system breakdowns, repairs, calibration checks, and zero and span adjustments shall not be included in the data averages computed under this paragraph. For owners or operators complying with the requirements in 40 CFR 60.7(f)(1) or (2), data averages must include any data recorded during periods of monitor breakdown or malfunction. An arithmetic or integrated average of all data may be used. The data may be recorded in reduced or non reduced form (e.g., ppm pollutant and percent O<sub>2</sub> or ng or pollutant per J of heat input). All excess emissions shall be converted into units of the standard using the applicable conversion procedures specified in subparts. After conversion into units of the standard, the data may be rounded to the same number of significant digits as used in the applicable subparts to specify the emission limit (e.g., rounded to the nearest 1 percent opacity).
- (i) After receipt and consideration of written application, the Administrator may approve alternatives to any monitoring procedures or requirements of this part including, but not limited to the following:
- (1) Alternative monitoring requirements when installation of a continuous monitoring system or monitoring device specified by this part would not provide accurate measurements due to liquid water or other interferences caused by substances in the effluent gases.
  - (2) Alternative monitoring requirements when the affected facility is infrequently operated.
  - (3) Alternative monitoring requirements to accommodate continuous monitoring systems that require additional measurements to correct for stack moisture conditions.
  - (4) Alternative locations for installing continuous monitoring systems or monitoring devices when the owner or operator can demonstrate that installation at alternate locations will enable accurate and representative measurements.
  - (5) Alternative methods of converting pollutant concentration measurements to units of the standards.
  - (6) Alternative procedures for performing daily checks of zero and span drift that do not involve use of span gases or test cells.
  - (7) Alternatives to the A.S.T.M. test methods or sampling procedures specified by any subpart.
  - (8) Alternative continuous monitoring systems that do not meet the design or performance requirements in Performance Specification 1, Appendix B, but adequately demonstrate a definite and consistent relationship between its measurements and the measurements of opacity by a system complying with the requirements in Performance Specification 1. The Administrator may require that such demonstration be performed for each affected facility.
  - (9) Alternative monitoring requirements when the effluent from a single affected facility or the combined effluent from two or more affected facilities is released to the atmosphere through more than one point.
- (j) An alternative to the relative accuracy (RA) test specified in Performance Specification 2 of appendix B may be requested as follows:
- (1) An alternative to the reference method tests for determining RA is available for sources with emission rates demonstrated to be less than 50 percent of the applicable standard. A source owner or operator may petition the Administrator to waive the RA test in section 8.4 of Performance Specification 2 and substitute the procedures in section 16.0 if the results of a performance test conducted according to the requirements in 40 CFR 60.8 of this subpart or other tests performed following the criteria in 40 CFR 60.8 demonstrate that the emission rate of the pollutant of interest in the units of the applicable standard is less than 50 percent of the applicable standard. For sources subject to standards expressed as control efficiency levels, a source owner or operator may petition the Administrator to waive the RA test and substitute the procedures in section 16.0 of Performance Specification 2 if the control device exhaust emission rate is less than 50 percent of the level needed to meet the control efficiency

**SECTION VI. APPENDIX NA**  
**NSPS SUBPART A - GENERAL PROVISIONS**

---

requirement. The alternative procedures do not apply if the continuous emission monitoring system is used to determine compliance continuously with the applicable standard. The petition to waive the RA test shall include a detailed description of the procedures to be applied. Included shall be location and procedure for conducting the alternative, the concentration or response levels of the alternative RA materials, and the other equipment checks included in the alternative procedure. The Administrator will review the petition for completeness and applicability. The determination to grant a waiver will depend on the intended use of the CEMS data (e.g., data collection purposes other than NSPS) and may require specifications more stringent than in Performance Specification 2 (e.g., the applicable emission limit is more stringent than NSPS).

- (2) The waiver of a CEMS RA test will be reviewed and may be rescinded at such time, following successful completion of the alternative RA procedure that the CEMS data indicate the source emissions approaching the level. The criterion for reviewing the waiver is the collection of CEMS data showing that emissions have exceeded 70 percent of the applicable standard for seven, consecutive, averaging periods as specified by the applicable regulation(s). For sources subject to standards expressed as control efficiency levels, the criterion for reviewing the waiver is the collection of CEMS data showing that exhaust emissions have exceeded 70 percent of the level needed to meet the control efficiency requirement for seven, consecutive, averaging periods as specified by the applicable regulation(s) [e.g., 40 CFR 60.45(g)(2) and 40 CFR 60.45(g)(3), 40 CFR 60.73(e), and 40 CFR 60.84(e)]. It is the responsibility of the source operator to maintain records and determine the level of emissions relative to the criterion on the waiver of RA testing. If this criterion is exceeded, the owner or operator must notify the Administrator within 10 days of such occurrence and include a description of the nature and cause of the increasing emissions. The Administrator will review the notification and may rescind the waiver and require the owner or operator to conduct a RA test of the CEMS as specified in section 8.4 of Performance Specification 2.

**40 CFR 60.14 Modification.**

- (a) Except as provided under 40 CFR 60.14(e) and 40 CFR 60.14(f), any physical or operational change to an existing facility which results in an increase in the emission rate to the atmosphere of any pollutant to which a standard applies shall be considered a modification within the meaning of section 111 of the Act. Upon modification, an existing facility shall become an affected facility for each pollutant to which a standard applies and for which there is an increase in the emission rate to the atmosphere.
- (b) Emission rate shall be expressed as kg/hr (lbs./hour) of any pollutant discharged into the atmosphere for which a standard is applicable. The Administrator shall use the following to determine emission rate:
- (1) Emission factors as specified in the latest issue of "Compilation of Air Pollutant Emission Factors", EPA Publication No. AP-42, or other emission factors determined by the Administrator to be superior to AP-42 emission factors, in cases where utilization of emission factors demonstrates that the emission level resulting from the physical or operational change will either clearly increase or clearly not increase.
- (2) Material balances, continuous monitor data, or manual emission tests in cases where utilization of emission factors as referenced in 40 CFR 60.14(b)(1) does not demonstrate to the Administrator's satisfaction whether the emission level resulting from the physical or operational change will either clearly increase or clearly not increase, or where an owner or operator demonstrates to the Administrator's satisfaction that there are reasonable grounds to dispute the result obtained by the Administrator utilizing emission factors as referenced in 40 CFR 60.14(b)(1). When the emission rate is based on results from manual emission tests or continuous monitoring systems, the procedures specified in 40 CFR 60 appendix C of 40 CFR 60 shall be used to determine whether an increase in emission rate has occurred. Tests shall be conducted under such conditions as the Administrator shall specify to the owner or operator based on representative performance of the facility. At least three valid test runs must be conducted before and at least three after the physical or operational change. All operating parameters which may affect emissions must be held constant to the maximum feasible degree for all test runs.
- (c) The addition of an affected facility to a stationary source as an expansion to that source or as a replacement for an existing facility shall not by itself bring within the applicability of this part any other facility within that source.
- (d) [Reserved]
- (e) The following shall not, by themselves, be considered modifications under this part:



**SECTION VI. APPENDIX NA**  
**NSPS SUBPART A - GENERAL PROVISIONS**

---

- (1) Maintenance, repair, and replacement which the Administrator determines to be routine for a source category, subject to the provisions of 40 CFR 60.14(c) and 40 CFR 60.15.
  - (2) An increase in production rate of an existing facility, if that increase can be accomplished without a capital expenditure on that facility.
  - (3) An increase in the hours of operation.
  - (4) Use of an alternative fuel or raw material if, prior to the date any standard under this part becomes applicable to that source type, as provided by 40 CFR 60.1, the existing facility was designed to accommodate that alternative use. A facility shall be considered to be designed to accommodate an alternative fuel or raw material if that use could be accomplished under the facility's construction specifications as amended prior to the change. Conversion to coal required for energy considerations, as specified in section 111(a)(8) of the Act, shall not be considered a modification.
  - (5) The addition or use of any system or device whose primary function is the reduction of air pollutants, except when an emission control system is removed or is replaced by a system which the Administrator determines to be less environmentally beneficial.
  - (6) The relocation or change in ownership of an existing facility.
- (f) Special provisions set forth under an applicable subpart of this part shall supersede any conflicting provisions of this section.
- (g) Within 180 days of the completion of any physical or operational change subject to the control measures specified in 40 CFR 60.14(a), compliance with all applicable standards must be achieved.
- (h) No physical change, or change in the method of operation, at an existing electric utility steam generating unit shall be treated as a modification for the purposes of this section provided that such change does not increase the maximum hourly emissions of any pollutant regulated under this section above the maximum hourly emissions achievable at that unit during the 5 years prior to the change.
- (i) Repowering projects that are awarded funding from the Department of Energy as permanent clean coal technology demonstration projects (or similar projects funded by EPA) are exempt from the requirements of this section provided that such change does not increase the maximum hourly emissions of any pollutant regulated under this section above the maximum hourly emissions achievable at that unit during the five years prior to the change.
- (j) (1) Repowering projects that qualify for an extension under section 409(b) of the Clean Air Act are exempt from the requirements of this section, provided that such change does not increase the actual hourly emissions of any pollutant regulated under this section above the actual hourly emissions achievable at that unit during the 5 years prior to the change.
- (2) This exemption shall not apply to any new unit that:
- (i) Is designated as a replacement for an existing unit;
  - (ii) Qualifies under section 409(b) of the Clean Air Act for an extension of an emission limitation compliance date under section 405 of the Clean Air Act; and
  - (iii) Is located at a different site than the existing unit.
- (k) The installation, operation, cessation, or removal of a temporary clean coal technology demonstration project is exempt from the requirements of this section. A *temporary clean coal control technology demonstration project*, for the purposes of this section is a clean coal technology demonstration project that is operated for a period of 5 years or less, and which complies with the State implementation plan for the State in which the project is located and other requirements necessary to attain and maintain the national ambient air quality standards during the project and after it is terminated.
- (l) The reactivation of a very clean coal-fired electric utility steam generating unit is exempt from the requirements of this section.

**SECTION VI. APPENDIX NA**  
**NSPS SUBPART A - GENERAL PROVISIONS**

---

**40 CFR 60.15 Reconstruction.**

- (a) An existing facility, upon reconstruction, becomes an affected facility, irrespective of any change in emission rate.
- (b) "Reconstruction" means the replacement of components of an existing facility to such an extent that:
  - (1) The fixed capital cost of the new components exceeds 50 percent of the fixed capital cost that would be required to construct a comparable entirely new facility, and
  - (2) It is technologically and economically feasible to meet the applicable standards set forth in this part.
- (c) "Fixed capital cost" means the capital needed to provide all the depreciable components.
- (d) If an owner or operator of an existing facility proposes to replace components, and the fixed capital cost of the new components exceeds 50 percent of the fixed capital cost that would be required to construct a comparable entirely new facility, he shall notify the Administrator of the proposed replacements. The notice must be postmarked 60 days (or as soon as practicable) before construction of the replacements is commenced and must include the following information:
  - (1) Name and address of the owner or operator.
  - (2) The location of the existing facility.
  - (3) A brief description of the existing facility and the components which are to be replaced.
  - (4) A description of the existing air pollution control equipment and the proposed air pollution control equipment.
  - (5) An estimate of the fixed capital cost of the replacements and of constructing a comparable entirely new facility.
  - (6) The estimated life of the existing facility after the replacements.
  - (7) A discussion of any economic or technical limitations the facility may have in complying with the applicable standards of performance after the proposed replacements.
- (e) The Administrator will determine, within 30 days of the receipt of the notice required by 40 CFR 60.15(d) and any additional information he may reasonably require, whether the proposed replacement constitutes reconstruction.
- (f) The Administrator's determination under 40 CFR 60.15(e) shall be based on:
  - (1) The fixed capital cost of the replacements in comparison to the fixed capital cost that would be required to construct a comparable entirely new facility;
  - (2) The estimated life of the facility after the replacements compared to the life of a comparable entirely new facility;
  - (3) The extent to which the components being replaced cause or contribute to the emissions from the facility; and
  - (4) Any economic or technical limitations on compliance with applicable standards of performance which are inherent in the proposed replacements.
- (g) Individual subparts of this part may include specific provisions which refine and delimit the concept of reconstruction set forth in this section.

**40 CFR 60.18 General control device requirements.**

- (a) *Introduction.* This section contains requirements for control devices used to comply with applicable subparts of parts 60 and 61. The requirements are placed here for administrative convenience and only apply to facilities covered by subparts referring to this section.
- (b) *Flares.* Paragraphs (c) through (f) apply to flares. *(Not applicable.)*

**40 CFR 60.19 General notification and reporting requirements.**

- (a) For the purposes of this part, time periods specified in days shall be measured in calendar days, even if the word "calendar" is absent, unless otherwise specified in an applicable requirement.

**SECTION VI. APPENDIX NA**  
**NSPS SUBPART A - GENERAL PROVISIONS**

---

- (b) For the purposes of this part, if an explicit postmark deadline is not specified in an applicable requirement for the submittal of a notification, application, report, or other written communication to the Administrator, the owner or operator shall postmark the submittal on or before the number of days specified in the applicable requirement. For example, if a notification must be submitted 15 days before a particular event is scheduled to take place, the notification shall be post-marked on or before 15 days preceding the event; likewise, if a notification must be submitted 15 days after a particular event takes place, the notification shall be delivered or postmarked on or before 15 days following the end of the event. The use of reliable non-Government mail carriers that provide indications of verifiable delivery of information required to be submitted to the Administrator, similar to the post-mark provided by the U.S. Postal Service, or alternative means of delivery, including the use of electronic media, agreed to by the permitting authority, is acceptable.
- (c) Notwithstanding time periods or postmark deadlines specified in this part for the submittal of information to the Administrator by an owner or operator, or the review of such information by the Administrator, such time periods or deadlines may be changed by mutual agreement between the owner or operator and the Administrator. Procedures governing the implementation of this provision are specified in paragraph (f) of this section.
- (d) If an owner or operator of an affected facility in a State with delegated authority is required to submit periodic reports under this part to the State, and if the State has an established timeline for the submission of periodic reports that is consistent with the reporting frequency(ies) specified for such facility under this part, the owner or operator may change the dates by which periodic reports under this part shall be submitted (without changing the frequency of reporting) to be consistent with the State's schedule by mutual agreement between the owner or operator and the State. The allowance in the previous sentence applies in each State beginning 1 year after the affected facility is required to be in compliance with the applicable subpart in this part. Procedures governing the implementation of this provision are specified in paragraph (f) of this section.
- (e) If an owner or operator supervises one or more stationary sources affected by standards set under this part and standards set under part 61, part 63, or both such parts of this chapter, he/she may arrange by mutual agreement between the owner or operator and the Administrator (or the State with an approved permit program) a common schedule on which periodic reports required by each applicable standard shall be submitted throughout the year. The allowance in the previous sentence applies in each State beginning 1 year after the stationary source is required to be in compliance with the applicable subpart in this part, or 1 year after the stationary source is required to be in compliance with the applicable 40 CFR part 61 or part 63 of this chapter standard, whichever is latest. Procedures governing the implementation of this provision are specified in paragraph (f) of this section.
- (f) (1) (i) Until an adjustment of a time period or postmark deadline has been approved by the Administrator under paragraphs (f)(2) and (f)(3) of this section, the owner or operator of an affected facility remains strictly subject to the requirements of this part.
- (ii) An owner or operator shall request the adjustment provided for in paragraphs (f)(2) and (f)(3) of this section each time he or she wishes to change an applicable time period or postmark deadline specified in this part.
- (2) Notwithstanding time periods or postmark deadlines specified in this part for the submittal of information to the Administrator by an owner or operator, or the review of such information by the Administrator, such time periods or deadlines may be changed by mutual agreement between the owner or operator and the Administrator. An owner or operator who wishes to request a change in a time period or postmark deadline for a particular requirement shall request the adjustment in writing as soon as practicable before the subject activity is required to take place. The owner or operator shall include in the request whatever information he or she considers useful to convince the Administrator that an adjustment is warranted.
- (3) If, in the Administrator's judgment, an owner or operator's request for an adjustment to a particular time period or postmark deadline is warranted, the Administrator will approve the adjustment. The Administrator will notify the owner or operator in writing of approval or disapproval of the request for an adjustment within 15 calendar days of receiving sufficient information to evaluate the request.
- (4) If the Administrator is unable to meet a specified deadline, he or she will notify the owner or operator of any significant delay and inform the owner or operator of the amended schedule.

**SECTION VI. APPENDIX NGG**  
**NSPS SUBPART GG – STATIONARY GAS TURBINES**

---

(updated 4/27/06)

**SUBPART GG. STANDARDS OF PERFORMANCE FOR STATIONARY GAS TURBINES**

**40 CFR 60.330 Applicability and designation of affected facility.**

- (a) The provisions of this subpart are applicable to the following affected facilities: All stationary gas turbines with a heat input at peak load equal to or greater than 10.7 gigajoules (10 million Btu) per hour, based on the lower heating value of the fuel fired.
- (b) Any facility under paragraph (a) of this section which commences construction, modification, or reconstruction after October 3, 1977, is subject to the requirements of this part except as provided in paragraphs (e) and (j) of 40 CFR 60.332.

**40 CFR 60.331 Definitions.**

As used in this subpart, all terms not defined herein shall have the meaning given them in the Act and in subpart A of this part.

- (a) *Stationary gas turbine* means any simple cycle gas turbine, regenerative cycle gas turbine or any gas turbine portion of a combined cycle steam/electric generating system that is not self propelled. It may, however, be mounted on a vehicle for portability.
- (b) *Simple cycle gas turbine* means any stationary gas turbine which does not recover heat from the gas turbine exhaust gases to preheat the inlet combustion air to the gas turbine, or which does not recover heat from the gas turbine exhaust gases to heat water or generate steam.
- (c) *Regenerative cycle gas turbine* means any stationary gas turbine which recovers heat from the gas turbine exhaust gases to preheat the inlet combustion air to the gas turbine.
- (d) *Combined cycle gas turbine* means any stationary gas turbine which recovers heat from the gas turbine exhaust gases to heat water or generate steam.
- (e) *Emergency gas turbine* means any stationary gas turbine which operates as a mechanical or electrical power source only when the primary power source for a facility has been rendered inoperable by an emergency situation.
- (f) *Ice fog* means an atmospheric suspension of highly reflective ice crystals.
- (g) *ISO standard day conditions* means 288 degrees Kelvin, 60 percent relative humidity and 101.3 kilopascals pressure.
- (h) *Efficiency* means the gas turbine manufacturer's rated heat rate at peak load in terms of heat input per unit of power output based on the lower heating value of the fuel.
- (i) *Peak load* means 100 percent of the manufacturer's design capacity of the gas turbine at ISO standard day conditions.
- (j) *Base load* means the load level at which a gas turbine is normally operated.
- (k) *Fire-fighting turbine* means any stationary gas turbine that is used solely to pump water for extinguishing fires.
- (l) *Turbines employed in oil/gas production or oil/gas transportation* means any stationary gas turbine used to provide power to extract crude oil/natural gas from the earth or to move crude oil/natural gas, or products refined from these substances through pipelines.

**SECTION VI. APPENDIX NGG**  
**NSPS SUBPART GG – STATIONARY GAS TURBINES**

---

- (m) A *Metropolitan Statistical Area* or *MSA* as defined by the Department of Commerce.
- (n) *Offshore platform gas turbines* means any stationary gas turbine located on a platform in an ocean.
- (o) *Garrison facility* means any permanent military installation.
- (p) *Gas turbine model* means a group of gas turbines having the same nominal air flow, combustor inlet pressure, combustor inlet temperature, firing temperature, turbine inlet temperature and turbine inlet pressure.
- (q) *Electric utility stationary gas turbine* means any stationary gas turbine constructed for the purpose of supplying more than one-third of its potential electric output capacity to any utility power distribution system for sale.
- (r) *Emergency fuel* is a fuel fired by a gas turbine only during circumstances, such as natural gas supply curtailment or breakdown of delivery system, that make it impossible to fire natural gas in the gas turbine.
- (s) Unit operating hour means a clock hour during which any fuel is combusted in the affected unit. If the unit combusts fuel for the entire clock hour, it is considered to be a full unit operating hour. If the unit combusts fuel for only part of the clock hour, it is considered to be a partial unit operating hour.
- (t) Excess emissions means a specified averaging period over which either:
  - (1) The NO<sub>x</sub> emissions are higher than the applicable emission limit in 40 CFR 60.332;
  - (2) The total sulfur content of the fuel being combusted in the affected facility exceeds the limit specified in 40 CFR 60.333; or
  - (3) The recorded value of a particular monitored parameter is outside the acceptable range specified in the parameter monitoring plan for the affected unit.
- (u) Natural gas means a naturally occurring fluid mixture of hydrocarbons (e.g., methane, ethane, or propane) produced in geological formations beneath the Earth's surface that maintains a gaseous state at standard atmospheric temperature and pressure under ordinary conditions. Natural gas contains 20.0 grains or less of total sulfur per 100 standard cubic feet. Equivalents of this in other units are as follows: 0.068 weight percent total sulfur, 680 parts per million by weight (ppmw) total sulfur, and 338 parts per million by volume (ppmv) at 20 degrees Celsius total sulfur. Additionally, natural gas must either be composed of at least 70 percent methane by volume or have a gross calorific value between 950 and 1100 British thermal units (Btu) per standard cubic foot. Natural gas does not include the following gaseous fuels: landfill gas, digester gas, refinery gas, sour gas, blast furnace gas, coal-derived gas, producer gas, coke oven gas, or any gaseous fuel produced in a process which might result in highly variable sulfur content or heating value.
- (v) Duct burner means a device that combusts fuel and that is placed in the exhaust duct from another source, such as a stationary gas turbine, internal combustion engine, kiln, etc., to allow the firing of additional fuel to heat the exhaust gases before the exhaust gases enter a heat recovery steam generating unit.
- (w) Lean premix stationary combustion turbine means any stationary combustion turbine where the air and fuel are thoroughly mixed to form a lean mixture for combustion in the combustor. Mixing may occur before or in the combustion chamber. A unit which is capable of operating in both lean premix and diffusion flame modes is considered a lean premix stationary combustion turbine when it is in the lean premix mode, and it is considered a diffusion flame stationary combustion turbine when it is in the diffusion flame mode.
- (x) Diffusion flame stationary combustion turbine means any stationary combustion turbine where fuel and air are injected at the combustor and are mixed only by diffusion prior to ignition. A unit which is capable of operating in both lean premix and diffusion flame modes is considered a lean premix stationary combustion turbine when it is in the lean premix mode, and it is considered a diffusion flame stationary combustion turbine when it is in the diffusion flame mode.

SECTION VI. APPENDIX NGG

NSPS SUBPART GG – STATIONARY GAS TURBINES

- (y) Unit operating day means a 24-hour period between 12:00 midnight and the following midnight during which any fuel is combusted at any time in the unit. It is not necessary for fuel to be combusted continuously for the entire 24-hour period.

**40 CFR 60.332 Standard for nitrogen oxides.**

- (a) On and after the date on which the performance test required by 40 CFR 60.8 is completed, every owner or operator subject to the provisions of this subpart as specified in paragraphs (b), (c), and (d) of this section shall comply with one of the following, except as provided in paragraphs (e), (f), (g), (h), (i), (j), (k), and (l) of this section.

- (1) No owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere from any stationary gas turbine, any gases which contain nitrogen oxides in excess of:

$$\text{STD} = 0.0075[14.4/Y] + F$$

where:

STD = allowable ISO corrected (if required as given in 40 CFR 60.335(b)(1)) NO<sub>x</sub> emission concentration (percent by volume at 15 percent oxygen and on a dry basis),

Y = manufacturer's rated heat rate at manufacturer's rated load (kilojoules per watt hour) or, actual measured heat rate based on lower heating value of fuel as measured at actual peak load for the facility. The value of Y shall not exceed 14.4 kilojoules per watt hour, and

F = NO<sub>x</sub> emission allowance for fuel-bound nitrogen as defined in paragraph (a)(4) of this section.

- (2) No owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere from any stationary gas turbine, any gases which contain nitrogen oxides in excess of:

$$\text{STD} = 0.0150[14.4/Y] + F$$

where:

STD = allowable ISO corrected (if required as given in 40 CFR 60.335(b)(1)) NO<sub>x</sub> emission concentration (percent by volume at 15 percent oxygen and on a dry basis),

Y = manufacturer's rated heat rate at manufacturer's rated peak load (kilojoules per watt hour), or actual measured heat rate based on lower heating value of fuel as measured at actual peak load for the facility. The value of Y shall not exceed 14.4 kilojoules per watt hour, and

F = NO<sub>x</sub> emission allowance for fuel-bound nitrogen as defined in paragraph (a)(4) of this section.

- (3) The use of F in paragraphs (a)(1) and (2) of this section is optional. That is, the owner or operator may choose to apply a NO<sub>x</sub> allowance for fuel-bound nitrogen and determine the appropriate F-value in accordance with paragraph (a)(4) of this section or may accept an F-value of zero.

- (4) If the owner or operator elects to apply a NO<sub>x</sub> emission allowance for fuel-bound nitrogen, F shall be defined according to the nitrogen content of the fuel during the most recent performance test required under 40 CFR 60.8 as follows:

**SECTION VI. APPENDIX NGG**

**NSPS SUBPART GG – STATIONARY GAS TURBINES**

Fuel-bound nitrogen (% by weight)      F (NO<sub>x</sub>% by volume)

N ≤ 0.015.....	0
0.015 < N ≤ 0.1.....	0.04(N)
0.1 < N ≤ 0.25.....	0.004 + 0.0067(N - 0.1)
N > 0.25.....	0.005

where:

N = the nitrogen content of the fuel (percent by weight).or:

Manufacturers may develop and submit to EPA custom fuel-bound nitrogen allowances for each gas turbine model they manufacture. These fuel-bound nitrogen allowances shall be substantiated with data and must be approved for use by the Administrator before the initial performance test required by 40 CFR 60.8. Notices of approval of custom fuel-bound nitrogen allowances will be published in the Federal Register.

- (b) Electric utility stationary gas turbines with a heat input at peak load greater than 107.2 gigajoules per hour (100 million Btu/hour) based on the lower heating value of the fuel fired shall comply with the provisions of paragraph (a)(1) of this section.
- (c) Stationary gas turbines with a heat input at peak load equal to or greater than 10.7 gigajoules per hour (10 million Btu/hour) but less than or equal to 107.2 gigajoules per hour (100 million Btu/hour) based on the lower heating value of the fuel fired, shall comply with the provisions of paragraph (a)(2) of this section.
- (d) Stationary gas turbines with a manufacturer's rated base load at ISO conditions of 30 megawatts or less except as provided in 40 CFR 60.332(b) shall comply with paragraph (a)(2) of this section.
- (e) Stationary gas turbines with a heat input at peak load equal to or greater than 10.7 gigajoules per hour (10 million Btu/hour) but less than or equal to 107.2 gigajoules per hour (100 million Btu/hour) based on the lower heating value of the fuel fired and that have commenced construction prior to October 3, 1982 are exempt from paragraph (a) of this section.
- (f) Stationary gas turbines using water or steam injection for control of NO<sub>x</sub> emissions are exempt from paragraph (a) when ice fog is deemed a traffic hazard by the owner or operator of the gas turbine.
- (g) Emergency gas turbines, military gas turbines for use in other than a garrison facility, military gas turbines installed for use as military training facilities, and fire fighting gas turbines are exempt from paragraph (a) of this section.
- (h) Stationary gas turbines engaged by manufacturers in research and development of equipment for both gas turbine emission control techniques and gas turbine efficiency improvements are exempt from paragraph (a) on a case-by-case basis as determined by the Administrator.
- (i) Exemptions from the requirements of paragraph (a) of this section will be granted on a case-by-case basis as determined by the Administrator in specific geographical areas where mandatory water restrictions are required by governmental agencies because of drought conditions. These exemptions will be allowed only while the mandatory water restrictions are in effect.
- (j) Stationary gas turbines with a heat input at peak load greater than 107.2 gigajoules per hour that commenced construction, modification, or reconstruction between the dates of October 3, 1977, and January 27, 1982, and were required in the September 10, 1979, Federal Register (44 FR 52792) to comply with paragraph (a)(1) of this section, except electric utility stationary gas turbines, are exempt from paragraph (a) of this section.

**SECTION VI. APPENDIX NGG**

**NSPS SUBPART GG – STATIONARY GAS TURBINES**

---

- (k) Stationary gas turbines with a heat input greater than or equal to 10.7 gigajoules per hour (10 million Btu/hour) when fired with natural gas are exempt from paragraph (a)(2) of this section when being fired with an emergency fuel.
- (l) Regenerative cycle gas turbines with a heat input less than or equal to 107.2 gigajoules per hour (100 million Btu/hour) are exempt from paragraph (a) of this section.

**40 CFR 60.333 Standard for sulfur dioxide.**

On and after the date on which the performance test required to be conducted by 40 CFR 60.8 is completed, every owner or operator subject to the provision of this subpart shall comply with one or the other of the following conditions:

- (a) No owner or operator subject to the provisions of this subpart shall cause to be discharged into the atmosphere from any stationary gas turbine any gases which contain sulfur dioxide in excess of 0.015 percent by volume at 15 percent oxygen and on a dry basis.
- (b) No owner or operator subject to the provisions of this subpart shall burn in any stationary gas turbine any fuel which contains total sulfur in excess of 0.8 percent by weight (8000 ppmw).

**40 CFR 60.334 Monitoring of operations.**

- (a) Except as provided in paragraph (b) of this section, the owner or operator of any stationary gas turbine subject to the provisions of this subpart and using water or steam injection to control NO<sub>x</sub> emissions shall install, calibrate, maintain and operate a continuous monitoring system to monitor and record the fuel consumption and the ratio of water or steam to fuel being fired in the turbine.
- (b) The owner or operator of any stationary gas turbine that commenced construction, reconstruction or modification after October 3, 1977, but before July 8, 2004, and which uses water or steam injection to control NO<sub>x</sub> emissions may, as an alternative to operating the continuous monitoring system described in paragraph (a) of this section, install, certify, maintain, operate, and quality-assure a continuous emission monitoring system (CEMS) consisting of NO<sub>x</sub> and O<sub>2</sub> monitors. As an alternative, a CO<sub>2</sub> monitor may be used to adjust the measured NO<sub>x</sub> concentrations to 15 percent O<sub>2</sub> by either converting the CO<sub>2</sub> hourly averages to equivalent O<sub>2</sub> concentrations using Equation F-14a or F-14b in appendix F to part 75 of this chapter and making the adjustments to 15 percent O<sub>2</sub>, or by using the CO<sub>2</sub> readings directly to make the adjustments, as described in Method 20. If the option to use a CEMS is chosen, the CEMS shall be installed, certified, maintained and operated as follows:
  - (1) Each CEMS must be installed and certified according to PS 2 and 3 (for diluent) of 40 CFR part 60, appendix B, except the 7-day calibration drift is based on unit operating days, not calendar days. Appendix F, Procedure 1 is not required. The relative accuracy test audit (RATA) of the NO<sub>x</sub> and diluent monitors may be performed individually or on a combined basis, i.e., the relative accuracy tests of the CEMS may be performed either:
    - (i) On a ppm basis (for NO<sub>x</sub>) and a percent O<sub>2</sub> basis for oxygen; or
    - (ii) On a ppm at 15 percent O<sub>2</sub> basis; or
    - (iii) On a ppm basis (for NO<sub>x</sub>) and a percent CO<sub>2</sub> basis (for a CO<sub>2</sub> monitor that uses the procedures in Method 20 to correct the NO<sub>x</sub> data to 15 percent O<sub>2</sub>).
  - (2) As specified in 40 CFR 60.13(e)(2), during each full unit operating hour, each monitor must complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each 15-minute quadrant of the hour, to validate the hour. For partial unit operating hours, at least one valid data point must be obtained for each quadrant of the hour in which the unit operates. For unit operating hours in which required quality assurance and maintenance activities are performed on the CEMS, a minimum of two valid data points (one in each of two quadrants) are required to validate the hour.
  - (3) For purposes of identifying excess emissions, CEMS data must be reduced to hourly averages as specified in 40 CFR 60.13(h).
    - (i) For each unit operating hour in which a valid hourly average, as described in paragraph (b)(2) of this section, is obtained for both NO<sub>x</sub> and diluent, the data acquisition and handling system must calculate and record the



## SECTION VI. APPENDIX NGG

### NSPS SUBPART GG – STATIONARY GAS TURBINES

hourly NO<sub>x</sub> emissions in the units of the applicable NO<sub>x</sub> emission standard under 40 CFR 60.332(a), i.e., percent NO<sub>x</sub> by volume, dry basis, corrected to 15 percent O<sub>2</sub> and International Organization for Standardization (ISO) standard conditions (if required as given in 40 CFR 60.335(b)(1)). For any hour in which the hourly average O<sub>2</sub> concentration exceeds 19.0 percent O<sub>2</sub>, a diluent cap value of 19.0 percent O<sub>2</sub> may be used in the emission calculations.

- (ii) A worst case ISO correction factor may be calculated and applied using historical ambient data. For the purpose of this calculation, substitute the maximum humidity of ambient air (H<sub>o</sub>), minimum ambient temperature (T<sub>a</sub>), and minimum combustor inlet absolute pressure (P<sub>o</sub>) into the ISO correction equation.
  - (iii) If the owner or operator has installed a NO<sub>x</sub> CEMS to meet the requirements of part 75 of this chapter, and is continuing to meet the ongoing requirements of part 75 of this chapter, the CEMS may be used to meet the requirements of this section, except that the missing data substitution methodology provided for at 40 CFR part 75, subpart D, is not required for purposes of identifying excess emissions. Instead, periods of missing CEMS data are to be reported as monitor downtime in the excess emissions and monitoring performance report required in 40 CFR 60.7(c).
- (c) For any turbine that commenced construction, reconstruction or modification after October 3, 1977, but before July 8, 2004, and which does not use steam or water injection to control NO<sub>x</sub> emissions, the owner or operator may, but is not required to, for purposes of determining excess emissions, use a CEMS that meets the requirements of paragraph (b) of this section. Also, if the owner or operator has previously submitted and received EPA, State, or local permitting authority approval of a procedure for monitoring compliance with the applicable NO<sub>x</sub> emission limit under 40 CFR 60.332, that approved procedure may continue to be used.
- (d) The owner or operator of any new turbine constructed after July 8, 2004, and which uses water or steam injection to control NO<sub>x</sub> emissions may elect to use either the requirements in paragraph (a) of this section for continuous water or steam to fuel ratio monitoring or may use a NO<sub>x</sub> CEMS installed, certified, operated, maintained, and quality-assured as described in paragraph (b) of this section.
- (e) The owner or operator of any new turbine that commences construction after July 8, 2004, and which does not use water or steam injection to control NO<sub>x</sub> emissions, may, but is not required to, elect to use a NO<sub>x</sub> CEMS installed, certified, operated, maintained, and quality-assured as described in paragraph (b) of this section. Other acceptable monitoring approaches include periodic testing approved by EPA or the State or local permitting authority or continuous parameter monitoring as described in paragraph (f) of this section.
- (f) The owner or operator of a new turbine that commences construction after July 8, 2004, which does not use water or steam injection to control NO<sub>x</sub> emissions may, but is not required to, perform continuous parameter monitoring as follows:
- (1) For a diffusion flame turbine without add-on selective catalytic reduction controls (SCR), the owner or operator shall define at least four parameters indicative of the unit's NO<sub>x</sub> formation characteristics and shall monitor these parameters continuously.
  - (2) For any lean premix stationary combustion turbine, the owner or operator shall continuously monitor the appropriate parameters to determine whether the unit is operating in low-NO<sub>x</sub> mode.
  - (3) For any turbine that uses SCR to reduce NO<sub>x</sub> emissions, the owner or operator shall continuously monitor appropriate parameters to verify the proper operation of the emission controls.
  - (4) For affected units that are also regulated under part 75 of this chapter, if the owner or operator elects to monitor NO<sub>x</sub> emission rate using the methodology in appendix E to part 75 of this chapter, or the low mass emissions methodology in 40 CFR 75.19 of this chapter, the requirements of this paragraph (f) may be met by performing the parametric monitoring described in section 2.3 of appendix E or in 40 CFR 75.19(c)(1)(iv)(H) of this chapter.
- (g) The steam or water to fuel ratio or other parameters that are continuously monitored as described in paragraphs (a), (d) or (f) of this section shall be monitored during the performance test required under 40 CFR 60.8, to establish acceptable values and ranges. The owner or operator may supplement the performance test data with engineering analyses, design specifications, manufacturer's recommendations and other relevant information to define the acceptable parametric ranges more precisely. The owner or operator shall develop and keep on-site a parameter monitoring plan which

**SECTION VI. APPENDIX NGG**  
**NSPS SUBPART GG – STATIONARY GAS TURBINES**

---

explains the procedures used to document proper operation of the NO<sub>x</sub> emission controls. The plan shall include the parameter(s) monitored and the acceptable range(s) of the parameter(s) as well as the basis for designating the parameter(s) and acceptable range(s). Any supplemental data such as engineering analyses, design specifications, manufacturer's recommendations and other relevant information shall be included in the monitoring plan. For affected units that are also subject to part 75 of this chapter and that use the low mass emissions methodology in 40 CFR 75.19 of this chapter or the NO<sub>x</sub> emission measurement methodology in appendix E to part 75, the owner or operator may meet the requirements of this paragraph by developing and keeping on-site (or at a central location for unmanned facilities) a quality-assurance plan, as described in 40 CFR 75.19 (e)(5) or in section 2.3 of appendix E and section 1.3.6 of appendix B to part 75 of this chapter.

- (h) The owner or operator of any stationary gas turbine subject to the provisions of this subpart:
- (1) Shall monitor the total sulfur content of the fuel being fired in the turbine, except as provided in paragraph (h)(3) of this section. The sulfur content of the fuel must be determined using total sulfur methods described in 40 CFR 60.335(b)(10). Alternatively, if the total sulfur content of the gaseous fuel during the most recent performance test was less than 0.4 weight percent (4000 ppmw), ASTM D4084-82, 94, D5504-01, D6228-98, or Gas Processors Association Standard 2377-86 (all of which are incorporated by reference-see 40 CFR 60.17), which measure the major sulfur compounds may be used; and
  - (2) Shall monitor the nitrogen content of the fuel combusted in the turbine, if the owner or operator claims an allowance for fuel bound nitrogen (i.e., if an F-value greater than zero is being or will be used by the owner or operator to calculate STD in 40 CFR 60.332). The nitrogen content of the fuel shall be determined using methods described in 40 CFR 60.335(b)(9) or an approved alternative.
  - (3) Notwithstanding the provisions of paragraph (h)(1) of this section, the owner or operator may elect not to monitor the total sulfur content of the gaseous fuel combusted in the turbine, if the gaseous fuel is demonstrated to meet the definition of natural gas in 40 CFR 60.331(u), regardless of whether an existing custom schedule approved by the administrator for subpart GG requires such monitoring. The owner or operator shall use one of the following sources of information to make the required demonstration:
    - (i) The gas quality characteristics in a current, valid purchase contract, tariff sheet or transportation contract for the gaseous fuel, specifying that the maximum total sulfur content of the fuel is 20.0 grains/100 scf or less; or
    - (ii) Representative fuel sampling data which show that the sulfur content of the gaseous fuel does not exceed 20 grains/100 scf. At a minimum, the amount of fuel sampling data specified in section 2.3.1.4 or 2.3.2.4 of appendix D to part 75 of this chapter is required.
  - (4) For any turbine that commenced construction, reconstruction or modification after October 3, 1977, but before July 8, 2004, and for which a custom fuel monitoring schedule has previously been approved, the owner or operator may, without submitting a special petition to the Administrator, continue monitoring on this schedule.
- (i) The frequency of determining the sulfur and nitrogen content of the fuel shall be as follows:
- (1) Fuel oil. For fuel oil, use one of the total sulfur sampling options and the associated sampling frequency described in sections 2.2.3, 2.2.4.1, 2.2.4.2, and 2.2.4.3 of appendix D to part 75 of this chapter (i.e., flow proportional sampling, daily sampling, sampling from the unit's storage tank after each addition of fuel to the tank, or sampling each delivery prior to combining it with fuel oil already in the intended storage tank). If an emission allowance is being claimed for fuel-bound nitrogen, the nitrogen content of the oil shall be determined and recorded once per unit operating day.
  - (2) Gaseous fuel. Any applicable nitrogen content value of the gaseous fuel shall be determined and recorded once per unit operating day. For owners and operators that elect not to demonstrate sulfur content using options in paragraph (h)(3) of this section, and for which the fuel is supplied without intermediate bulk storage, the sulfur content value of the gaseous fuel shall be determined and recorded once per unit operating day.
  - (3) Custom schedules. Notwithstanding the requirements of paragraph (i)(2) of this section, operators or fuel vendors may develop custom schedules for determination of the total sulfur content of gaseous fuels, based on the design and operation of the affected facility and the characteristics of the fuel supply. Except as provided in paragraphs (i)(3)(i) and (i)(3)(ii) of this section, custom schedules shall be substantiated with data and shall be approved by the Administrator before they can be used to comply with the standard in 40 CFR 60.333.

SECTION VI. APPENDIX NGG

NSPS SUBPART GG – STATIONARY GAS TURBINES

- (i) The two custom sulfur monitoring schedules set forth in paragraphs (i)(3)(i)(A) through (D) and in paragraph (i)(3)(ii) of this section are acceptable, without prior Administrative approval:
  - (A) The owner or operator shall obtain daily total sulfur content measurements for 30 consecutive unit operating days, using the applicable methods specified in this subpart. Based on the results of the 30 daily samples, the required frequency for subsequent monitoring of the fuel's total sulfur content shall be as specified in paragraph (i)(3)(i)(B), (C), or (D) of this section, as applicable.
  - (B) If none of the 30 daily measurements of the fuel's total sulfur content exceeds 0.4 weight percent (4000 ppmw), subsequent sulfur content monitoring may be performed at 12 month intervals. If any of the samples taken at 12-month intervals has a total sulfur content between 0.4 and 0.8 weight percent (4000 and 8000 ppmw), follow the procedures in paragraph (i)(3)(i)(C) of this section. If any measurement exceeds 0.8 weight percent (8000 ppmw), follow the procedures in paragraph (i)(3)(i)(D) of this section.
  - (C) If at least one of the 30 daily measurements of the fuel's total sulfur content is between 0.4 and 0.8 weight percent (4000 and 8000 ppmw), but none exceeds 0.8 weight percent (8000 ppmw), then:
    - (1) Collect and analyze a sample every 30 days for three months. If any sulfur content measurement exceeds 0.8 weight percent (8000 ppmw), follow the procedures in paragraph (i)(3)(i)(D) of this section. Otherwise, follow the procedures in paragraph (i)(3)(i)(C)(2) of this section.
    - (2) Begin monitoring at 6-month intervals for 12 months. If any sulfur content measurement exceeds 0.8 weight percent (8000 ppmw), follow the procedures in paragraph (i)(3)(i)(D) of this section. Otherwise, follow the procedures in paragraph (i)(3)(i)(C)(3) of this section.
    - (3) Begin monitoring at 12-month intervals. If any sulfur content measurement exceeds 0.8 weight percent (8000 ppmw), follow the procedures in paragraph (i)(3)(i)(D) of this section. Otherwise, continue to monitor at this frequency.
  - (D) If a sulfur content measurement exceeds 0.8 weight percent (8000 ppmw), immediately begin daily monitoring according to paragraph (i)(3)(i)(A) of this section. Daily monitoring shall continue until 30 consecutive daily samples, each having a sulfur content no greater than 0.8 weight percent (8000 ppmw), are obtained. At that point, the applicable procedures of paragraph (i)(3)(i)(B) or (C) of this section shall be followed.
- (ii) The owner or operator may use the data collected from the 720-hour sulfur sampling demonstration described in section 2.3.6 of appendix D to part 75 of this chapter to determine a custom sulfur sampling schedule, as follows:
  - (A) If the maximum fuel sulfur content obtained from the 720 hourly samples does not exceed 20 grains/100 scf (i.e., the maximum total sulfur content of natural gas as defined in 40 CFR 60.331(u)), no additional monitoring of the sulfur content of the gas is required, for the purposes of this subpart.
  - (B) If the maximum fuel sulfur content obtained from any of the 720 hourly samples exceeds 20 grains/100 scf, but none of the sulfur content values (when converted to weight percent sulfur) exceeds 0.4 weight percent (4000 ppmw), then the minimum required sampling frequency shall be one sample at 12 month intervals.
  - (C) If any sample result exceeds 0.4 weight percent sulfur (4000 ppmw), but none exceeds 0.8 weight percent sulfur (8000 ppmw), follow the provisions of paragraph (i)(3)(i)(C) of this section.
  - (D) If the sulfur content of any of the 720 hourly samples exceeds 0.8 weight percent (8000 ppmw), follow the provisions of paragraph (i)(3)(i)(D) of this section.
- (j) For each affected unit that elects to continuously monitor parameters or emissions, or to periodically determine the fuel sulfur content or fuel nitrogen content under this subpart, the owner or operator shall submit reports of excess emissions and monitor downtime, in accordance with 40 CFR 60.7(c). Excess emissions shall be reported for all periods of unit operation, including startup, shutdown and malfunction. For the purpose of reports required under 40 CFR 60.7(c), periods of excess emissions and monitor downtime that shall be reported are defined as follows:
  - (1) Nitrogen oxides.
    - (i) For turbines using water or steam to fuel ratio monitoring:
      - (A) An excess emission shall be any unit operating hour for which the average steam or water to fuel ratio, as measured by the continuous monitoring system, falls below the acceptable steam or water to fuel ratio

## SECTION VI. APPENDIX NGG

### NSPS SUBPART GG – STATIONARY GAS TURBINES

- needed to demonstrate compliance with 40 CFR 60.332, as established during the performance test required in 40 CFR 60.8. Any unit operating hour in which no water or steam is injected into the turbine shall also be considered an excess emission.
- (B) A period of monitor downtime shall be any unit operating hour in which water or steam is injected into the turbine, but the essential parametric data needed to determine the steam or water to fuel ratio are unavailable or invalid.
- (C) Each report shall include the average steam or water to fuel ratio, average fuel consumption, ambient conditions (temperature, pressure, and humidity), gas turbine load, and (if applicable) the nitrogen content of the fuel during each excess emission. You do not have to report ambient conditions if you opt to use the worst case ISO correction factor as specified in 40 CFR 60.334(b)(3)(ii), or if you are not using the ISO correction equation under the provisions of 40 CFR 60.335(b)(1).
- (ii) If the owner or operator elects to take an emission allowance for fuel bound nitrogen, then excess emissions and periods of monitor downtime are as described in paragraphs (j)(1)(ii)(A) and (B) of this section.
- (A) An excess emission shall be the period of time during which the fuel-bound nitrogen (N) is greater than the value measured during the performance test required in 40 CFR 60.8 and used to determine the allowance. The excess emission begins on the date and hour of the sample which shows that N is greater than the performance test value, and ends with the date and hour of a subsequent sample which shows a fuel nitrogen content less than or equal to the performance test value.
- (B) A period of monitor downtime begins when a required sample is not taken by its due date. A period of monitor downtime also begins on the date and hour that a required sample is taken, if invalid results are obtained. The period of monitor downtime ends on the date and hour of the next valid sample.
- (iii) For turbines using NO<sub>x</sub> and diluent CEMS:
- (A) An hour of excess emissions shall be any unit operating hour in which the 4-hour rolling average NO<sub>x</sub> concentration exceeds the applicable emission limit in 40 CFR 60.332(a)(1) or (2). For the purposes of this subpart, a "4-hour rolling average NO<sub>x</sub> concentration" is the arithmetic average of the average NO<sub>x</sub> concentration measured by the CEMS for a given hour (corrected to 15 percent O<sub>2</sub> and, if required under 40 CFR 60.335(b)(1), to ISO standard conditions) and the three unit operating hour average NO<sub>x</sub> concentrations immediately preceding that unit operating hour.
- (B) A period of monitor downtime shall be any unit operating hour in which sufficient data are not obtained to validate the hour, for either NO<sub>x</sub> concentration or diluent (or both).
- (C) Each report shall include the ambient conditions (temperature, pressure, and humidity) at the time of the excess emission period and (if the owner or operator has claimed an emission allowance for fuel bound nitrogen) the nitrogen content of the fuel during the period of excess emissions. You do not have to report ambient conditions if you opt to use the worst case ISO correction factor as specified in 40 CFR 60.334(b)(3)(ii), or if you are not using the ISO correction equation under the provisions of 40 CFR 60.335(b)(1).
- (iv) For owners or operators that elect, under paragraph (f) of this section, to monitor combustion parameters or parameters that document proper operation of the NO<sub>x</sub> emission controls:
- (A) An excess emission shall be a 4-hour rolling unit operating hour average in which any monitored parameter does not achieve the target value or is outside the acceptable range defined in the parameter monitoring plan for the unit.
- (B) A period of monitor downtime shall be a unit operating hour in which any of the required parametric data are either not recorded or are invalid.
- (2) Sulfur dioxide. If the owner or operator is required to monitor the sulfur content of the fuel under paragraph (h) of this section:
- (i) For samples of gaseous fuel and for oil samples obtained using daily sampling, flow proportional sampling, or sampling from the unit's storage tank, an excess emission occurs each unit operating hour included in the period beginning on the date and hour of any sample for which the sulfur content of the fuel being fired in the gas turbine exceeds 0.8 weight percent and ending on the date and hour that a subsequent sample is taken that demonstrates compliance with the sulfur limit.
- (ii) If the option to sample each delivery of fuel oil has been selected, the owner or operator shall immediately switch to one of the other oil sampling options (i.e., daily sampling, flow proportional sampling, or sampling

## SECTION VI. APPENDIX NGG

### NSPS SUBPART GG – STATIONARY GAS TURBINES

from the unit's storage tank) if the sulfur content of a delivery exceeds 0.8 weight percent. The owner or operator shall continue to use one of the other sampling options until all of the oil from the delivery has been combusted, and shall evaluate excess emissions according to paragraph (j)(2)(i) of this section. When all of the fuel from the delivery has been burned, the owner or operator may resume using the as-delivered sampling option.

- (iii) A period of monitor downtime begins when a required sample is not taken by its due date. A period of monitor downtime also begins on the date and hour of a required sample, if invalid results are obtained. The period of monitor downtime shall include only unit operating hours, and ends on the date and hour of the next valid sample.
- (3) *Ice fog*. Each period during which an exemption provided in 40 CFR 60.332(f) is in effect shall be reported in writing to the Administrator quarterly. For each period the ambient conditions existing during the period, the date and time the air pollution control system was deactivated, and the date and time the air pollution control system was reactivated shall be reported. All quarterly reports shall be postmarked by the 30th day following the end of each calendar quarter.
- (4) *Emergency fuel*. Each period during which an exemption provided in 40 CFR 60.332(k) is in effect shall be included in the report required in 40 CFR 60.7(c). For each period, the type, reasons, and duration of the firing of the emergency fuel shall be reported.
- (5) All reports required under 40 CFR 60.7(c) shall be postmarked by the 30th day following the end of each 6-month period.

#### 40 CFR 60.335 Test methods and procedures.

- (a) The owner or operator shall conduct the performance tests required in 40 CFR 60.8, using either
  - (1) EPA Method 20,
  - (2) ASTM D6522-00 (incorporated by reference, see 40 CFR 60.17), or
  - (3) EPA Method 7E and either EPA Method 3 or 3A in appendix A to this part, to determine NO<sub>x</sub> and diluent concentration.
  - (4) Sampling traverse points are to be selected following Method 20 or Method 1, (non-particulate procedures) and sampled for equal time intervals. The sampling shall be performed with a traversing single-hole probe or, if feasible, with a stationary multi-hole probe that samples each of the points sequentially. Alternatively, a multi-hole probe designed and documented to sample equal volumes from each hole may be used to sample simultaneously at the required points.
  - (5) Notwithstanding paragraph (a)(4) of this section, the owner or operator may test at few points than are specified in Method 1 or Method 20 if the following conditions are met:
    - (i) You may perform a stratification test for NO<sub>x</sub> and diluent pursuant to
      - (A) [Reserved]
      - (B) The procedures specified in section 6.5.6.1(a) through (e) appendix A to part 75 of this chapter.
    - (ii) Once the stratification sampling is completed, the owner or operator may use the following alternative sample point selection criteria for the performance test:
      - (A) If each of the individual traverse point NO<sub>x</sub> concentrations, normalized to 15 percent O<sub>2</sub>, is within 10 percent of the mean normalized concentration for all traverse points, then you may use 3 points (located either 16.7, 50.0, and 83.3 percent of the way across the stack or duct, or, for circular stacks or ducts greater than 2.4 meters (7.8 feet) in diameter, at 0.4, 1.2, and 2.0 meters from the wall). The 3 points shall be located along the measurement line that exhibited the highest average normalized NO<sub>x</sub> concentration during the stratification test; or
      - (B) If each of the individual traverse point NO<sub>x</sub> concentrations, normalized to 15 percent O<sub>2</sub>, is within 5 percent of the mean normalized concentration for all traverse points, then you may sample at a single point, located at least 1 meter from the stack wall or at the stack centroid.
  - (6) Other acceptable alternative reference methods and procedures are given in paragraph (c) of this section.
- (b) The owner or operator shall determine compliance with the applicable nitrogen oxides emission limitation in 40 CFR 60.332 and shall meet the performance test requirements of 40 CFR 60.8 as follows:

SECTION VI. APPENDIX NGG

NSPS SUBPART GG – STATIONARY GAS TURBINES

- (1) For each run of the performance test, the mean nitrogen oxides emission concentration ( $NO_{x_0}$ ) corrected to 15 percent  $O_2$  shall be corrected to ISO standard conditions using the following equation. Notwithstanding this requirement, use of the ISO correction equation is optional for: Lean premix stationary combustion turbines; units used in association with heat recovery steam generators (HRSG) equipped with duct burners; and units equipped with add-on emission control devices:

$$NO_x = (NO_{x_0})(P_r/P_o)^{0.5} e^{19(H_o - 0.00633)} (288[\text{deg}]\text{K}/T_a)^{1.53}$$

where:

$NO_x$  = emission concentration of  $NO_x$  at 15 percent  $O_2$  and ISO standard ambient conditions, ppm by volume, dry basis,

$NO_{x_0}$  = mean observed  $NO_x$  concentration, ppm by volume, dry basis, at 15 percent  $O_2$ ,

$P_r$  = reference combustor inlet absolute pressure at 101.3 kilopascals ambient pressure, mm Hg,

$P_o$  = observed combustor inlet absolute pressure at test, mm Hg,

$H_o$  = observed humidity of ambient air, g  $H_2O$ /g air,

$e$  = transcendental constant, 2.718, and

$T_a$  = ambient temperature, [deg]K.

- (2) The 3-run performance test required by 40 CFR 60.8 must be performed within 5 percent at 30, 50, 75, and 90-to-100 percent of peak load or at four evenly-spaced load points in the normal operating range of the gas turbine, including the minimum point in the operating range and 90-to-100 percent of peak load, or at the highest achievable load point if 90-to-100 percent of peak load cannot be physically achieved in practice. If the turbine combusts both oil and gas as primary or backup fuels, separate performance testing is required for each fuel. Notwithstanding these requirements, performance testing is not required for any emergency fuel (as defined in 40 CFR 60.331).
- (3) For a combined cycle turbine system with supplemental heat (duct burner), the owner or operator may elect to measure the turbine  $NO_x$  emissions after the duct burner rather than directly after the turbine. If the owner or operator elects to use this alternative sampling location, the applicable  $NO_x$  emission limit in 40 CFR 60.332 for the combustion turbine must still be met.
- (4) If water or steam injection is used to control  $NO_x$  with no additional post-combustion  $NO_x$  control and the owner or operator chooses to monitor the steam or water to fuel ratio in accordance with 40 CFR 60.334(a), then that monitoring system must be operated concurrently with each EPA Method 20, ASTM D6522-00 (incorporated by reference, see 40 CFR 60.17), or EPA Method 7E run and shall be used to determine the fuel consumption and the steam or water to fuel ratio necessary to comply with the applicable 40 CFR 60.332  $NO_x$  emission limit.
- (5) If the owner operator elects to claim an emission allowance for fuel bound nitrogen as described in 40 CFR 60.332, then concurrently with each reference method run, a representative sample of the fuel used shall be collected and analyzed, following the applicable procedures described in 40 CFR 60.335(b)(9). These data shall be used to determine the maximum fuel nitrogen content for which the established water (or steam) to fuel ratio will be valid.
- (6) If the owner or operator elects to install a CEMS, the performance evaluation of the CEMS may either be conducted separately (as described in paragraph (b)(7) of this section) or as part of the initial performance test of the affected unit.
- (7) If the owner or operator elects to install and certify a  $NO_x$  CEMS under 40 CFR 60.334(e), then the initial performance test required under 40 CFR 60.8 may be done in the following alternative manner:
- (i) Perform a minimum of 9 reference method runs, with a minimum time per run of 21 minutes, at a single load level, between 90 and 100 percent of peak (or the highest physically achievable) load.
  - (ii) Use the test data both to demonstrate compliance with the applicable  $NO_x$  emission limit under 40 CFR 60.332 and to provide the required reference method data for the RATA of the CEMS described under 40 CFR 60.334(b).
  - (iii) The requirement to test at three additional load levels is waived.
- (8) If the owner or operator elects under 40 CFR 60.334(f) to monitor combustion parameters or parameters indicative of proper operation of  $NO_x$  emission controls, the appropriate parameters shall be continuously monitored and

## SECTION VI. APPENDIX NGG

### NSPS SUBPART GG – STATIONARY GAS TURBINES

---

recorded during each run of the initial performance test, to establish acceptable operating ranges, for purposes of the parameter monitoring plan for the affected unit, as specified in 40 CFR 60.334(g).

- (9) To determine the fuel bound nitrogen content of fuel being fired (if an emission allowance is claimed for fuel bound nitrogen), the owner or operator may use equipment and procedures meeting the requirements of:
    - (i) For liquid fuels, ASTM D2597-94 (Reapproved 1999), D6366-99, D4629-02, D5762-02 (all of which are incorporated by reference, see 40 CFR 60.17); or
    - (ii) For gaseous fuels, shall use analytical methods and procedures that are accurate to within 5 percent of the instrument range and are approved by the Administrator.
  - (10) If the owner or operator is required under 40 CFR 60.334(i)(1) or (3) to periodically determine the sulfur content of the fuel combusted in the turbine, a minimum of three fuel samples shall be collected during the performance test. Analyze the samples for the total sulfur content of the fuel using:
    - (i) For liquid fuels, ASTM D129-00, D2622-98, D4294-02, D1266-98, D5453-00 or D1552-01 (all of which are incorporated by reference, see 40 CFR 60.17); or
    - (ii) For gaseous fuels, ASTM D1072-80, 90 (Reapproved 1994); D3246-81, 92, 96; D4468-85 (Reapproved 2000); or D6667-01 (all of which are incorporated by reference, see 40 CFR 60.17). The applicable ranges of some ASTM methods mentioned above are not adequate to measure the levels of sulfur in some fuel gases. Dilution of samples before analysis (with verification of the dilution ratio) may be used, subject to the prior approval of the Administrator.
  - (11) The fuel analyses required under paragraphs (b)(9) and (b)(10) of this section may be performed by the owner or operator, a service contractor retained by the owner or operator, the fuel vendor, or any other qualified agency.
- (c) The owner or operator may use the following as alternatives to the reference methods and procedures specified in this section:
- (1) Instead of using the equation in paragraph (b)(1) of this section, manufacturers may develop ambient condition correction factors to adjust the nitrogen oxides emission level measured by the performance test as provided in 40 CFR 60.8 to ISO standard day conditions.

**SECTION VI. APPENDIX NKKKK**  
**NSPS SUBPART KKKK – STATIONARY GAS TURBINES**

---

**Federal Regulations Adopted by Reference**

IN ACCORDANCE WITH RULE 62-204.800, F.A.C., THE FOLLOWING FEDERAL REGULATION IN TITLE 40 OF THE CODE OF FEDERAL REGULATIONS (CFR) WAS ADOPTED BY REFERENCE. THE ORIGINAL FEDERAL RULE NUMBERING HAS BEEN RETAINED.

*FEDERAL REVISION DATE: JULY 6, 2006*

*STATE RULE EFFECTIVE DATE: JANUARY 8, 2007*

*STANDARDIZED CONDITIONS REVISION DATE: NOVEMBER 16, 2009*

**40 CFR PART 60, SUBPART KKKK—STANDARDS OF PERFORMANCE FOR STATIONARY COMBUSTION TURBINES**

Source: 71 FR 38497, July 6, 2006, unless otherwise noted.

**Introduction**

**§ 60.4300 WHAT IS THE PURPOSE OF THIS SUBPART?**

This subpart establishes emission standards and compliance schedules for the control of emissions from stationary combustion turbines that commenced construction, modification or reconstruction after February 18, 2005.

**Applicability**

**§ 60.4305 DOES THIS SUBPART APPLY TO MY STATIONARY COMBUSTION TURBINE?**

- (a) If you are the owner or operator of a stationary combustion turbine with a heat input at peak load equal to or greater than 10.7 gigajoules (10 MMBtu) per hour, based on the higher heating value of the fuel, which commenced construction, modification, or reconstruction after February 18, 2005, your turbine is subject to this subpart. Only heat input to the combustion turbine should be included when determining whether or not this subpart is applicable to your turbine. Any additional heat input to associated heat recovery steam generators (HRSG) or duct burners should not be included when determining your peak heat input. However, this subpart does apply to emissions from any associated HRSG and duct burners.
- (b) Stationary combustion turbines regulated under this subpart are exempt from the requirements of subpart GG of this part. Heat recovery steam generators and duct burners regulated under this subpart are exempted from the requirements of subparts Da, Db, and Dc of this part.

**§ 60.4310 WHAT TYPES OF OPERATIONS ARE EXEMPT FROM THESE STANDARDS OF PERFORMANCE?**

- (a) Emergency combustion turbines, as defined in §60.4420(i), are exempt from the nitrogen oxides (NO<sub>x</sub>) emission limits in §60.4320.
- (b) Stationary combustion turbines engaged by manufacturers in research and development of equipment for both combustion turbine emission control techniques and combustion turbine efficiency improvements are exempt from the NO<sub>x</sub> emission limits in §60.4320 on a case-by-case basis as determined by the Administrator.
- (c) Stationary combustion turbines at integrated gasification combined cycle electric utility steam generating units that are subject to subpart Da of this part are exempt from this subpart.
- (d) Combustion turbine test cells/stands are exempt from this subpart.

**Emission Limits**

**§ 60.4315 WHAT POLLUTANTS ARE REGULATED BY THIS SUBPART?**

The pollutants regulated by this subpart are nitrogen oxide (NO<sub>x</sub>) and sulfur dioxide (SO<sub>2</sub>).



SECTION VI. APPENDIX NKKKK

NSPS SUBPART KKKK – STATIONARY GAS TURBINES

**§ 60.4320 WHAT EMISSION LIMITS MUST I MEET FOR NITROGEN OXIDES (NO<sub>x</sub>)?**

- (a) You must meet the emission limits for NO<sub>x</sub> specified in Table 1 to this subpart.
- (b) If you have two or more turbines that are connected to a single generator, each turbine must meet the emission limits for NO<sub>x</sub>.

**§ 60.4325 WHAT EMISSION LIMITS MUST I MEET FOR NO<sub>x</sub> IF MY TURBINE BURNS BOTH NATURAL GAS AND DISTILLATE OIL (OR SOME OTHER COMBINATION OF FUELS)?**

You must meet the emission limits specified in Table 1 to this subpart. If your total heat input is greater than or equal to 50 percent natural gas, you must meet the corresponding limit for a natural gas-fired turbine when you are burning that fuel. Similarly, when your total heat input is greater than 50 percent distillate oil and fuels other than natural gas, you must meet the corresponding limit for distillate oil and fuels other than natural gas for the duration of the time that you burn that particular fuel.

**§ 60.4330 WHAT EMISSION LIMITS MUST I MEET FOR SULFUR DIOXIDE (SO<sub>2</sub>)?**

- (a) If your turbine is located in a continental area, you must comply with either paragraph (a)(1) or (a)(2) of this section. If your turbine is located in Alaska, you do not have to comply with the requirements in paragraph (a) of this section until January 1, 2008.
  - (1) You must not cause to be discharged into the atmosphere from the subject stationary combustion turbine any gases which contain SO<sub>2</sub> in excess of 110 nanograms per Joule (ng/J) (0.90 pounds per megawatt-hour (lb/MWh)) gross output, or
  - (2) You must not burn in the subject stationary combustion turbine any fuel which contains total potential sulfur emissions in excess of 26 ng SO<sub>2</sub>/J (0.060 lb SO<sub>2</sub>/MMBtu) heat input. If your turbine simultaneously fires multiple fuels, each fuel must meet this requirement.
- (b) If your turbine is located in a noncontinental area or a continental area that the Administrator determines does not have access to natural gas and that the removal of sulfur compounds would cause more environmental harm than benefit, you must comply with one or the other of the following conditions:
  - (1) You must not cause to be discharged into the atmosphere from the subject stationary combustion turbine any gases which contain SO<sub>2</sub> in excess of 780 ng/J (6.2 lb/MWh) gross output, or
  - (2) You must not burn in the subject stationary combustion turbine any fuel which contains total sulfur with potential sulfur emissions in excess of 180 ng SO<sub>2</sub>/J (0.42 lb SO<sub>2</sub>/MMBtu) heat input. If your turbine simultaneously fires multiple fuels, each fuel must meet this requirement.

**General Compliance Requirements**

**§ 60.4333 WHAT ARE MY GENERAL REQUIREMENTS FOR COMPLYING WITH THIS SUBPART?**

- (a) You must operate and maintain your stationary combustion turbine, air pollution control equipment, and monitoring equipment in a manner consistent with good air pollution control practices for minimizing emissions at all times including during startup, shutdown, and malfunction.
- (b) When an affected unit with heat recovery utilizes a common steam header with one or more combustion turbines, the owner or operator shall either:
  - (1) Determine compliance with the applicable NO<sub>x</sub> emissions limits by measuring the emissions combined with the emissions from the other unit(s) utilizing the common heat recovery unit; or
  - (2) Develop, demonstrate, and provide information satisfactory to the Administrator on methods for apportioning the combined gross energy output from the heat recovery unit for each of the affected combustion turbines. The Administrator may approve such demonstrated substitute methods for apportioning the combined gross energy

## SECTION VI. APPENDIX NKKKK

### NSPS SUBPART KKKK – STATIONARY GAS TURBINES

output measured at the steam turbine whenever the demonstration ensures accurate estimation of emissions related under this part.

#### Monitoring

#### § 60.4335 HOW DO I DEMONSTRATE COMPLIANCE FOR NO<sub>x</sub> IF I USE WATER OR STEAM INJECTION?

- (a) If you are using water or steam injection to control NO<sub>x</sub> emissions, you must install, calibrate, maintain and operate a continuous monitoring system to monitor and record the fuel consumption and the ratio of water or steam to fuel being fired in the turbine when burning a fuel that requires water or steam injection for compliance.
- (b) Alternatively, you may use continuous emission monitoring, as follows:
  - (1) Install, certify, maintain, and operate a continuous emission monitoring system (CEMS) consisting of a NO<sub>x</sub> monitor and a diluent gas (oxygen (O<sub>2</sub>) or carbon dioxide (CO<sub>2</sub>)) monitor, to determine the hourly NO<sub>x</sub> emission rate in parts per million (ppm) or pounds per million British thermal units (lb/MMBtu); and
  - (2) For units complying with the output-based standard, install, calibrate, maintain, and operate a fuel flow meter (or flow meters) to continuously measure the heat input to the affected unit; and
  - (3) For units complying with the output-based standard, install, calibrate, maintain, and operate a watt meter (or meters) to continuously measure the gross electrical output of the unit in megawatt-hours; and
  - (4) For combined heat and power units complying with the output-based standard, install, calibrate, maintain, and operate meters for useful recovered energy flow rate, temperature, and pressure, to continuously measure the total thermal energy output in British thermal units per hour (Btu/h).

#### § 60.4340 HOW DO I DEMONSTRATE CONTINUOUS COMPLIANCE FOR NO<sub>x</sub> IF I DO NOT USE WATER OR STEAM INJECTION?

- (a) If you are not using water or steam injection to control NO<sub>x</sub> emissions, you must perform annual performance tests in accordance with §60.4400 to demonstrate continuous compliance. If the NO<sub>x</sub> emission result from the performance test is less than or equal to 75 percent of the NO<sub>x</sub> emission limit for the turbine, you may reduce the frequency of subsequent performance tests to once every 2 years (no more than 26 calendar months following the previous performance test). If the results of any subsequent performance test exceed 75 percent of the NO<sub>x</sub> emission limit for the turbine, you must resume annual performance tests.
- (b) As an alternative, you may install, calibrate, maintain and operate one of the following continuous monitoring systems:
  - (1) Continuous emission monitoring as described in §§60.4335(b) and 60.4345, or
  - (2) Continuous parameter monitoring as follows:
    - (i) For a diffusion flame turbine without add-on selective catalytic reduction (SCR) controls, you must define parameters indicative of the unit's NO<sub>x</sub> formation characteristics, and you must monitor these parameters continuously.
    - (ii) For any lean premix stationary combustion turbine, you must continuously monitor the appropriate parameters to determine whether the unit is operating in low-NO<sub>x</sub> mode.
    - (iii) For any turbine that uses SCR to reduce NO<sub>x</sub> emissions, you must continuously monitor appropriate parameters to verify the proper operation of the emission controls.
    - (iv) For affected units that are also regulated under part 75 of this chapter, with state approval you can monitor the NO<sub>x</sub> emission rate using the methodology in appendix E to part 75 of this chapter, or the low mass emissions methodology in §75.19, the requirements of this paragraph (b) may be met by performing the parametric monitoring described in section 2.3 of part 75 appendix E or in §75.19(c)(1)(iv)(H).

**SECTION VI. APPENDIX NKKKK**  
**NSPS SUBPART KKKK – STATIONARY GAS TURBINES**

---

**§ 60.4345 WHAT ARE THE REQUIREMENTS FOR THE CONTINUOUS EMISSION MONITORING SYSTEM EQUIPMENT, IF I CHOOSE TO USE THIS OPTION?**

If the option to use a NO<sub>x</sub>CEMS is chosen:

- (a) Each NO<sub>x</sub> diluent CEMS must be installed and certified according to Performance Specification 2 (PS 2) in appendix B to this part, except the 7-day calibration drift is based on unit operating days, not calendar days. With state approval, Procedure 1 in appendix F to this part is not required. Alternatively, a NO<sub>x</sub> diluent CEMS that is installed and certified according to appendix A of part 75 of this chapter is acceptable for use under this subpart. The relative accuracy test audit (RATA) of the CEMS shall be performed on a lb/MMBtu basis.
- (b) As specified in §60.13(e)(2), during each full unit operating hour, both the NO<sub>x</sub> monitor and the diluent monitor must complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each 15-minute quadrant of the hour, to validate the hour. For partial unit operating hours, at least one valid data point must be obtained with each monitor for each quadrant of the hour in which the unit operates. For unit operating hours in which required quality assurance and maintenance activities are performed on the CEMS, a minimum of two valid data points (one in each of two quadrants) are required for each monitor to validate the NO<sub>x</sub> emission rate for the hour.
- (c) Each fuel flow meter shall be installed, calibrated, maintained, and operated according to the manufacturer's instructions. Alternatively, with state approval, fuel flow meters that meet the installation, certification, and quality assurance requirements of appendix D to part 75 of this chapter are acceptable for use under this subpart.
- (d) Each watt meter, steam flow meter, and each pressure or temperature measurement device shall be installed, calibrated, maintained, and operated according to manufacturer's instructions.
- (e) The owner or operator shall develop and keep on-site a quality assurance (QA) plan for all of the continuous monitoring equipment described in paragraphs (a), (c), and (d) of this section. For the CEMS and fuel flow meters, the owner or operator may, with state approval, satisfy the requirements of this paragraph by implementing the QA program and plan described in section 1 of appendix B to part 75 of this chapter.

**§ 60.4350 HOW DO I USE DATA FROM THE CONTINUOUS EMISSION MONITORING EQUIPMENT TO IDENTIFY EXCESS EMISSIONS?**

For purposes of identifying excess emissions:

- (a) All CEMS data must be reduced to hourly averages as specified in §60.13(h).
- (b) For each unit operating hour in which a valid hourly average, as described in §60.4345(b), is obtained for both NO<sub>x</sub> and diluent monitors, the data acquisition and handling system must calculate and record the hourly NO<sub>x</sub> emission rate in units of ppm or lb/MMBtu, using the appropriate equation from method 19 in appendix A of this part. For any hour in which the hourly average O<sub>2</sub> concentration exceeds 19.0 percent O<sub>2</sub> (or the hourly average CO<sub>2</sub> concentration is less than 1.0 percent CO<sub>2</sub>), a diluent cap value of 19.0 percent O<sub>2</sub> or 1.0 percent CO<sub>2</sub> (as applicable) may be used in the emission calculations.
- (c) Correction of measured NO<sub>x</sub> concentrations to 15 percent O<sub>2</sub> is not allowed.

Permitting Note: Based on correspondence with EPA's Office of Air Quality and Planning Standards, this requirement should have been removed when NSPS Subpart KKKK was revised to add concentration-based standards (ppmv corrected to 15% oxygen) in addition to the output-based standards (lb/MWh). The regulation is currently under reconsideration for several issues. In the mean time, EPA states that the intent is to allow sources complying with the optional concentration-based standards to correct to 15% oxygen.

- (d) If you have installed and certified a NO<sub>x</sub> diluent CEMS to meet the requirements of part 75 of this chapter, states can approve that only quality assured data from the CEMS shall be used to identify excess emissions under this subpart. Periods where the missing data substitution procedures in subpart D of part 75 are applied are to be reported as monitor downtime in the excess emissions and monitoring performance report required under §60.7(c).
- (e) All required fuel flow rate, steam flow rate, temperature, pressure, and megawatt data must be reduced to hourly averages.

**SECTION VI. APPENDIX NKKKK**  
**NSPS SUBPART KKKK – STATIONARY GAS TURBINES**

(f) Calculate the hourly average NO<sub>x</sub> emission rates, in units of the emission standards under §60.4320, using either ppm for units complying with the concentration limit or the following equation for units complying with the output based standard:

(1) For simple-cycle operation:

$$E = \frac{(\text{NO}_x)_h * (\text{HI})_h}{P} \quad (\text{Eq. 1})$$

Where:

E = hourly NO<sub>x</sub> emission rate, in lb/MWh,

(NO<sub>x</sub>)<sub>h</sub> = hourly NO<sub>x</sub> emission rate, in lb/MMBtu,

(HI)<sub>h</sub> = hourly heat input rate to the unit, in MMBtu/h, measured using the fuel flow meter(s), *e.g.*, calculated using Equation D-15a in appendix D to part 75 of this chapter, and

P = gross energy output of the combustion turbine in MW.

(2) For combined-cycle and combined heat and power complying with the output-based standard, use Equation 1 of this subpart, except that the gross energy output is calculated as the sum of the total electrical and mechanical energy generated by the combustion turbine, the additional electrical or mechanical energy (if any) generated by the steam turbine following the heat recovery steam generator, and 100 percent of the total useful thermal energy output that is not used to generate additional electricity or mechanical output, expressed in equivalent MW, as in the following equations:

$$P = (\text{Pe})_t + (\text{Pe})_c + P_s + P_o \quad (\text{Eq. 2})$$

Where:

P = gross energy output of the stationary combustion turbine system in MW.

(Pe)<sub>t</sub> = electrical or mechanical energy output of the combustion turbine in MW,

(Pe)<sub>c</sub> = electrical or mechanical energy output (if any) of the steam turbine in MW, and

$$P_s = \frac{Q * H}{3.413 \times 10^6 \text{ Btu/MWh}} \quad (\text{Eq. 3})$$

Where:

P<sub>s</sub> = useful thermal energy of the steam, measured relative to ISO conditions, not used to generate additional electric or mechanical output, in MW,

Q = measured steam flow rate in lb/h,

H = enthalpy of the steam at measured temperature and pressure relative to ISO conditions, in Btu/lb, and 3.413 x 10<sup>6</sup> = conversion from Btu/h to MW.

P<sub>o</sub> = other useful heat recovery, measured relative to ISO conditions, not used for steam generation or performance enhancement of the combustion turbine.

(3) For mechanical drive applications complying with the output-based standard, use the following equation:

$$E = \frac{(\text{NO}_x)_m}{\text{BL} * \text{AL}} \quad (\text{Eq. 4})$$

Where:

E = NO<sub>x</sub> emission rate in lb/MWh,

(NO<sub>x</sub>)<sub>m</sub> = NO<sub>x</sub> emission rate in lb/h,

**SECTION VI. APPENDIX NKKKK**  
**NSPS SUBPART KKKK – STATIONARY GAS TURBINES**

---

BL = manufacturer's base load rating of turbine, in MW, and

AL = actual load as a percentage of the base load.

- (g) For simple cycle units without heat recovery, use the calculated hourly average emission rates from paragraph (f) of this section to assess excess emissions on a 4-hour rolling average basis, as described in §60.4380(b)(1).
- (h) For combined cycle and combined heat and power units with heat recovery, use the calculated hourly average emission rates from paragraph (f) of this section to assess excess emissions on a 30 unit operating day rolling average basis, as described in §60.4380(b)(1).

**§ 60.4355 HOW DO I ESTABLISH AND DOCUMENT A PROPER PARAMETER MONITORING PLAN?**

- (a) The steam or water to fuel ratio or other parameters that are continuously monitored as described in §§60.4335 and 60.4340 must be monitored during the performance test required under §60.8, to establish acceptable values and ranges. You may supplement the performance test data with engineering analyses, design specifications, manufacturer's recommendations and other relevant information to define the acceptable parametric ranges more precisely. You must develop and keep on-site a parameter monitoring plan which explains the procedures used to document proper operation of the NO<sub>x</sub> emission controls. The plan must:
  - (1) Include the indicators to be monitored and show there is a significant relationship to emissions and proper operation of the NO<sub>x</sub> emission controls,
  - (2) Pick ranges (or designated conditions) of the indicators, or describe the process by which such range (or designated condition) will be established,
  - (3) Explain the process you will use to make certain that you obtain data that are representative of the emissions or parameters being monitored (such as detector location, installation specification if applicable),
  - (4) Describe quality assurance and control practices that are adequate to ensure the continuing validity of the data,
  - (5) Describe the frequency of monitoring and the data collection procedures which you will use (e.g., you are using a computerized data acquisition over a number of discrete data points with the average (or maximum value) being used for purposes of determining whether an exceedance has occurred), and
  - (6) Submit justification for the proposed elements of the monitoring. If a proposed performance specification differs from manufacturer recommendation, you must explain the reasons for the differences. You must submit the data supporting the justification, but you may refer to generally available sources of information used to support the justification. You may rely on engineering assessments and other data, provided you demonstrate factors which assure compliance or explain why performance testing is unnecessary to establish indicator ranges. When establishing indicator ranges, you may choose to simplify the process by treating the parameters as if they were correlated. Using this assumption, testing can be divided into two cases:
    - (i) All indicators are significant only on one end of range (e.g., for a thermal incinerator controlling volatile organic compounds (VOC) it is only important to insure a minimum temperature, not a maximum). In this case, you may conduct your study so that each parameter is at the significant limit of its range while you conduct your emissions testing. If the emissions tests show that the source is in compliance at the significant limit of each parameter, then as long as each parameter is within its limit, you are presumed to be in compliance.
    - (ii) Some or all indicators are significant on both ends of the range. In this case, you may conduct your study so that each parameter that is significant at both ends of its range assumes its extreme values in all possible combinations of the extreme values (either single or double) of all of the other parameters. For example, if there were only two parameters, A and B, and A had a range of values while B had only a minimum value, the combinations would be A high with B minimum and A low with B minimum. If both A and B had a range, the combinations would be A high and B high, A low and B low, A high and B low, A low and B high. For the case of four parameters all having a range, there are 16 possible combinations.

## SECTION VI. APPENDIX NKKKK

### NSPS SUBPART KKKK – STATIONARY GAS TURBINES

- (b) For affected units that are also subject to part 75 of this chapter and that have state approval to use the low mass emissions methodology in §75.19 or the NO<sub>x</sub> emission measurement methodology in appendix E to part 75, you may meet the requirements of this paragraph by developing and keeping on-site (or at a central location for unmanned facilities) a QA plan, as described in §75.19(e)(5) or in section 2.3 of appendix E to part 75 of this chapter and section 1.3.6 of appendix B to part 75 of this chapter.

#### **§ 60.4360 HOW DO I DETERMINE THE TOTAL SULFUR CONTENT OF THE TURBINE'S COMBUSTION FUEL?**

You must monitor the total sulfur content of the fuel being fired in the turbine, except as provided in §60.4365. The sulfur content of the fuel must be determined using total sulfur methods described in §60.4415. Alternatively, if the total sulfur content of the gaseous fuel during the most recent performance test was less than half the applicable limit, ASTM D4084, D4810, D5504, or D6228, or Gas Processors Association Standard 2377 (all of which are incorporated by reference, see §60.17), which measure the major sulfur compounds, may be used.

#### **§ 60.4365 HOW CAN I BE EXEMPTED FROM MONITORING THE TOTAL SULFUR CONTENT OF THE FUEL?**

You may elect not to monitor the total sulfur content of the fuel combusted in the turbine, if the fuel is demonstrated not to exceed potential sulfur emissions of 26 ng SO<sub>2</sub>/J (0.060 lb SO<sub>2</sub>/MMBtu) heat input for units located in continental areas and 180 ng SO<sub>2</sub>/J (0.42 lb SO<sub>2</sub>/MMBtu) heat input for units located in noncontinental areas or a continental area that the Administrator determines does not have access to natural gas and that the removal of sulfur compounds would cause more environmental harm than benefit. You must use one of the following sources of information to make the required demonstration:

- (a) The fuel quality characteristics in a current, valid purchase contract, tariff sheet or transportation contract for the fuel, specifying that the maximum total sulfur content for oil use in continental areas is 0.05 weight percent (500 ppmw) or less and 0.4 weight percent (4,000 ppmw) or less for noncontinental areas, the total sulfur content for natural gas use in continental areas is 20 grains of sulfur or less per 100 standard cubic feet and 140 grains of sulfur or less per 100 standard cubic feet for noncontinental areas, has potential sulfur emissions of less than less than 26 ng SO<sub>2</sub>/J (0.060 lb SO<sub>2</sub>/MMBtu) heat input for continental areas and has potential sulfur emissions of less than less than 180 ng SO<sub>2</sub>/J (0.42 lb SO<sub>2</sub>/MMBtu) heat input for noncontinental areas; or
- (b) Representative fuel sampling data which show that the sulfur content of the fuel does not exceed 26 ng SO<sub>2</sub>/J (0.060 lb SO<sub>2</sub>/MMBtu) heat input for continental areas or 180 ng SO<sub>2</sub>/J (0.42 lb SO<sub>2</sub>/MMBtu) heat input for noncontinental areas. At a minimum, the amount of fuel sampling data specified in section 2.3.1.4 or 2.3.2.4 of appendix D to part 75 of this chapter is required.

#### **§ 60.4370 HOW OFTEN MUST I DETERMINE THE SULFUR CONTENT OF THE FUEL?**

The frequency of determining the sulfur content of the fuel must be as follows:

- (a) *Fuel oil.* For fuel oil, use one of the total sulfur sampling options and the associated sampling frequency described in sections 2.2.3, 2.2.4.1, 2.2.4.2, and 2.2.4.3 of appendix D to part 75 of this chapter ( *i.e.* , flow proportional sampling, daily sampling, sampling from the unit's storage tank after each addition of fuel to the tank, or sampling each delivery prior to combining it with fuel oil already in the intended storage tank).
- (b) *Gaseous fuel.* If you elect not to demonstrate sulfur content using options in §60.4365, and the fuel is supplied without intermediate bulk storage, the sulfur content value of the gaseous fuel must be determined and recorded once per unit operating day.
- (c) *Custom schedules.* Notwithstanding the requirements of paragraph (b) of this section, operators or fuel vendors may develop custom schedules for determination of the total sulfur content of gaseous fuels, based on the design and operation of the affected facility and the characteristics of the fuel supply. Except as provided in paragraphs (c)(1) and (c)(2) of this section, custom schedules shall be substantiated with data and shall be approved by the Administrator before they can be used to comply with the standard in §60.4330.

**SECTION VI. APPENDIX NKKKK**  
**NSPS SUBPART KKKK – STATIONARY GAS TURBINES**

---

- (1) The two custom sulfur monitoring schedules set forth in paragraphs (c)(1)(i) through (iv) and in paragraph (c)(2) of this section are acceptable, without prior Administrative approval:
  - (i) The owner or operator shall obtain daily total sulfur content measurements for 30 consecutive unit operating days, using the applicable methods specified in this subpart. Based on the results of the 30 daily samples, the required frequency for subsequent monitoring of the fuel's total sulfur content shall be as specified in paragraph (c)(1)(ii), (iii), or (iv) of this section, as applicable.
  - (ii) If none of the 30 daily measurements of the fuel's total sulfur content exceeds half the applicable standard, subsequent sulfur content monitoring may be performed at 12-month intervals. If any of the samples taken at 12-month intervals has a total sulfur content greater than half but less than the applicable limit, follow the procedures in paragraph (c)(1)(iii) of this section. If any measurement exceeds the applicable limit, follow the procedures in paragraph (c)(1)(iv) of this section.
  - (iii) If at least one of the 30 daily measurements of the fuel's total sulfur content is greater than half but less than the applicable limit, but none exceeds the applicable limit, then:
    - (A) Collect and analyze a sample every 30 days for 3 months. If any sulfur content measurement exceeds the applicable limit, follow the procedures in paragraph (c)(1)(iv) of this section. Otherwise, follow the procedures in paragraph (c)(1)(iii)(B) of this section.
    - (B) Begin monitoring at 6-month intervals for 12 months. If any sulfur content measurement exceeds the applicable limit, follow the procedures in paragraph (c)(1)(iv) of this section. Otherwise, follow the procedures in paragraph (c)(1)(iii)(C) of this section.
    - (C) Begin monitoring at 12-month intervals. If any sulfur content measurement exceeds the applicable limit, follow the procedures in paragraph (c)(1)(iv) of this section. Otherwise, continue to monitor at this frequency.
  - (iv) If a sulfur content measurement exceeds the applicable limit, immediately begin daily monitoring according to paragraph (c)(1)(i) of this section. Daily monitoring shall continue until 30 consecutive daily samples, each having a sulfur content no greater than the applicable limit, are obtained. At that point, the applicable procedures of paragraph (c)(1)(ii) or (iii) of this section shall be followed.
- (2) The owner or operator may use the data collected from the 720-hour sulfur sampling demonstration described in section 2.3.6 of appendix D to part 75 of this chapter to determine a custom sulfur sampling schedule, as follows:
  - (i) If the maximum fuel sulfur content obtained from the 720 hourly samples does not exceed 20 grains/100 scf, no additional monitoring of the sulfur content of the gas is required, for the purposes of this subpart.
  - (ii) If the maximum fuel sulfur content obtained from any of the 720 hourly samples exceeds 20 grains/100 scf, but none of the sulfur content values (when converted to weight percent sulfur) exceeds half the applicable limit, then the minimum required sampling frequency shall be one sample at 12 month intervals.
  - (iii) If any sample result exceeds half the applicable limit, but none exceeds the applicable limit, follow the provisions of paragraph (c)(1)(iii) of this section.
  - (iv) If the sulfur content of any of the 720 hourly samples exceeds the applicable limit, follow the provisions of paragraph (c)(1)(iv) of this section.

**Reporting**

**§ 60.4375 WHAT REPORTS MUST I SUBMIT?**

- (a) For each affected unit required to continuously monitor parameters or emissions, or to periodically determine the fuel sulfur content under this subpart, you must submit reports of excess emissions and monitor downtime, in accordance with §60.7(c). Excess emissions must be reported for all periods of unit operation, including start-up, shutdown, and malfunction.

SECTION VI. APPENDIX NKKKK

NSPS SUBPART KKKK – STATIONARY GAS TURBINES

- (b) For each affected unit that performs annual performance tests in accordance with §60.4340(a), you must submit a written report of the results of each performance test before the close of business on the 60th day following the completion of the performance test.

**§ 60.4380 HOW ARE EXCESS EMISSIONS AND MONITOR DOWNTIME DEFINED FOR NO<sub>x</sub>?**

For the purpose of reports required under §60.7(c), periods of excess emissions and monitor downtime that must be reported are defined as follows:

- (a) For turbines using water or steam to fuel ratio monitoring:
- (1) An excess emission is any unit operating hour for which the 4-hour rolling average steam or water to fuel ratio, as measured by the continuous monitoring system, falls below the acceptable steam or water to fuel ratio needed to demonstrate compliance with §60.4320, as established during the performance test required in §60.8. Any unit operating hour in which no water or steam is injected into the turbine when a fuel is being burned that requires water or steam injection for NO<sub>x</sub> control will also be considered an excess emission.
  - (2) A period of monitor downtime is any unit operating hour in which water or steam is injected into the turbine, but the essential parametric data needed to determine the steam or water to fuel ratio are unavailable or invalid.
  - (3) Each report must include the average steam or water to fuel ratio, average fuel consumption, and the combustion turbine load during each excess emission.
- (b) For turbines using continuous emission monitoring, as described in §§60.4335(b) and 60.4345:
- (1) An excess emissions is any unit operating period in which the 4-hour or 30-day rolling average NO<sub>x</sub> emission rate exceeds the applicable emission limit in §60.4320. For the purposes of this subpart, a “4-hour rolling average NO<sub>x</sub> emission rate” is the arithmetic average of the average NO<sub>x</sub> emission rate in ppm or ng/J (lb/MWh) measured by the continuous emission monitoring equipment for a given hour and the three unit operating hour average NO<sub>x</sub> emission rates immediately preceding that unit operating hour. Calculate the rolling average if a valid NO<sub>x</sub> emission rate is obtained for at least 3 of the 4 hours. For the purposes of this subpart, a “30-day rolling average NO<sub>x</sub> emission rate” is the arithmetic average of all hourly NO<sub>x</sub> emission data in ppm or ng/J (lb/MWh) measured by the continuous emission monitoring equipment for a given day and the twenty-nine unit operating days immediately preceding that unit operating day. A new 30-day average is calculated each unit operating day as the average of all hourly NO<sub>x</sub> emissions rates for the preceding 30 unit operating days if a valid NO<sub>x</sub> emission rate is obtained for at least 75 percent of all operating hours.
  - (2) A period of monitor downtime is any unit operating hour in which the data for any of the following parameters are either missing or invalid: NO<sub>x</sub> concentration, CO<sub>2</sub> or O<sub>2</sub> concentration, fuel flow rate, steam flow rate, steam temperature, steam pressure, or megawatts. The steam flow rate, steam temperature, and steam pressure are only required if you will use this information for compliance purposes.
  - (3) For operating periods during which multiple emissions standards apply, the applicable standard is the average of the applicable standards during each hour. For hours with multiple emissions standards, the applicable limit for that hour is determined based on the condition that corresponded to the highest emissions standard.
- (c) For turbines required to monitor combustion parameters or parameters that document proper operation of the NO<sub>x</sub> emission controls:
- (1) An excess emission is a 4-hour rolling unit operating hour average in which any monitored parameter does not achieve the target value or is outside the acceptable range defined in the parameter monitoring plan for the unit.
  - (2) A period of monitor downtime is a unit operating hour in which any of the required parametric data are either not recorded or are invalid.

**§ 60.4385 HOW ARE EXCESS EMISSIONS AND MONITORING DOWNTIME DEFINED FOR SO<sub>2</sub>?**

If you choose the option to monitor the sulfur content of the fuel, excess emissions and monitoring downtime are defined as follows:



SECTION VI. APPENDIX NKKKK

NSPS SUBPART KKKK – STATIONARY GAS TURBINES

- (a) For samples of gaseous fuel and for oil samples obtained using daily sampling, flow proportional sampling, or sampling from the unit's storage tank, an excess emission occurs each unit operating hour included in the period beginning on the date and hour of any sample for which the sulfur content of the fuel being fired in the combustion turbine exceeds the applicable limit and ending on the date and hour that a subsequent sample is taken that demonstrates compliance with the sulfur limit.
- (b) If the option to sample each delivery of fuel oil has been selected, you must immediately switch to one of the other oil sampling options (i.e., daily sampling, flow proportional sampling, or sampling from the unit's storage tank) if the sulfur content of a delivery exceeds 0.05 weight percent. You must continue to use one of the other sampling options until all of the oil from the delivery has been combusted, and you must evaluate excess emissions according to paragraph (a) of this section. When all of the fuel from the delivery has been burned, you may resume using the as-delivered sampling option.
- (c) A period of monitor downtime begins when a required sample is not taken by its due date. A period of monitor downtime also begins on the date and hour of a required sample, if invalid results are obtained. The period of monitor downtime ends on the date and hour of the next valid sample.

**§ 60.4390 WHAT ARE MY REPORTING REQUIREMENTS IF I OPERATE AN EMERGENCY COMBUSTION TURBINE OR A RESEARCH AND DEVELOPMENT TURBINE?**

- (a) If you operate an emergency combustion turbine, you are exempt from the NO<sub>x</sub> limit and must submit an initial report to the Administrator stating your case.
- (b) Combustion turbines engaged by manufacturers in research and development of equipment for both combustion turbine emission control techniques and combustion turbine efficiency improvements may be exempted from the NO<sub>x</sub> limit on a case-by-case basis as determined by the Administrator. You must petition for the exemption.

**§ 60.4395 WHEN MUST I SUBMIT MY REPORTS?**

All reports required under §60.7(c) must be postmarked by the 30th day following the end of each 6-month period.

**Performance Tests**

**§ 60.4400 HOW DO I CONDUCT THE INITIAL AND SUBSEQUENT PERFORMANCE TESTS, REGARDING NO<sub>x</sub>?**

- (a) You must conduct an initial performance test, as required in §60.8. Subsequent NO<sub>x</sub> performance tests shall be conducted on an annual basis (no more than 14 calendar months following the previous performance test).
  - (1) There are two general methodologies that you may use to conduct the performance tests. For each test run:
    - (i) Measure the NO<sub>x</sub> concentration (in parts per million (ppm)), using EPA Method 7E or EPA Method 20 in appendix A of this part. For units complying with the output based standard, concurrently measure the stack gas flow rate, using EPA Methods 1 and 2 in appendix A of this part, and measure and record the electrical and thermal output from the unit. Then, use the following equation to calculate the NO<sub>x</sub> emission rate:

$$E = \frac{1.194 \times 10^{-7} * (NO_x)_c * Q_{std}}{P} \quad (\text{Eq. 5})$$

Where:

- E = NO<sub>x</sub> emission rate, in lb/MWh
- 1.194 × 10<sup>-7</sup> = conversion constant, in lb/dscf-ppm
- (NO<sub>x</sub>)<sub>c</sub> = average NO<sub>x</sub> concentration for the run, in ppm
- Q<sub>std</sub> = stack gas volumetric flow rate, in dscf/hr

SECTION VI. APPENDIX NKKKK

NSPS SUBPART KKKK – STATIONARY GAS TURBINES

P = gross electrical and mechanical energy output of the combustion turbine, in MW (for simple-cycle operation), for combined-cycle operation, the sum of all electrical and mechanical output from the combustion and steam turbines, or, for combined heat and power operation, the sum of all electrical and mechanical output from the combustion and steam turbines plus all useful recovered thermal output not used for additional electric or mechanical generation, in MW, calculated according to §60.4350(f)(2); or

(ii) Measure the NO<sub>x</sub> and diluent gas concentrations, using either EPA Methods 7E and 3A, or EPA Method 20 in appendix A of this part. Concurrently measure the heat input to the unit, using a fuel flow meter (or flow meters), and measure the electrical and thermal output of the unit. Use EPA Method 19 in appendix A of this part to calculate the NO<sub>x</sub> emission rate in lb/MMBtu. Then, use Equations 1 and, if necessary, 2 and 3 in §60.4350(f) to calculate the NO<sub>x</sub> emission rate in lb/MWh.

(2) Sampling traverse points for NO<sub>x</sub> and (if applicable) diluent gas are to be selected following EPA Method 20 or EPA Method 1 (non-particulate procedures), and sampled for equal time intervals. The sampling must be performed with a traversing single-hole probe, or, if feasible, with a stationary multi-hole probe that samples each of the points sequentially. Alternatively, a multi-hole probe designed and documented to sample equal volumes from each hole may be used to sample simultaneously at the required points.

(3) Notwithstanding paragraph (a)(2) of this section, you may test at fewer points than are specified in EPA Method 1 or EPA Method 20 in appendix A of this part if the following conditions are met:

(i) You may perform a stratification test for NO<sub>x</sub> and diluent pursuant to

(A) [Reserved], or

(B) The procedures specified in section 6.5.6.1(a) through (e) of appendix A of part 75 of this chapter.

(ii) Once the stratification sampling is completed, you may use the following alternative sample point selection criteria for the performance test:

(A) If each of the individual traverse point NO<sub>x</sub> concentrations is within ± 10 percent of the mean concentration for all traverse points, or the individual traverse point diluent concentrations differs by no more than ± 5ppm or ± 0.5 percent CO<sub>2</sub>(or O<sub>2</sub>) from the mean for all traverse points, then you may use three points (located either 16.7, 50.0 and 83.3 percent of the way across the stack or duct, or, for circular stacks or ducts greater than 2.4 meters (7.8 feet) in diameter, at 0.4, 1.2, and 2.0 meters from the wall). The three points must be located along the measurement line that exhibited the highest average NO<sub>x</sub> concentration during the stratification test; or

(B) For turbines with a NO<sub>x</sub> standard greater than 15 ppm @ 15% O<sub>2</sub>, you may sample at a single point, located at least 1 meter from the stack wall or at the stack centroid if each of the individual traverse point NO<sub>x</sub> concentrations is within ± 5 percent of the mean concentration for all traverse points, or the individual traverse point diluent concentrations differs by no more than ± 3ppm or ± 0.3 percent CO<sub>2</sub> (or O<sub>2</sub>) from the mean for all traverse points; or

(C) For turbines with a NO<sub>x</sub> standard less than or equal to 15 ppm @ 15% O<sub>2</sub>, you may sample at a single point, located at least 1 meter from the stack wall or at the stack centroid if each of the individual traverse point NO<sub>x</sub> concentrations is within ± 2.5 percent of the mean concentration for all traverse points, or the individual traverse point diluent concentrations differs by no more than ± 1ppm or ± 0.15 percent CO<sub>2</sub> (or O<sub>2</sub>) from the mean for all traverse points.

(b) The performance test must be done at any load condition within plus or minus 25 percent of 100 percent of peak load. You may perform testing at the highest achievable load point, if at least 75 percent of peak load cannot be achieved in practice. You must conduct three separate test runs for each performance test. The minimum time per run is 20 minutes.

(1) If the stationary combustion turbine combusts both oil and gas as primary or backup fuels, separate performance testing is required for each fuel.

## SECTION VI. APPENDIX NKKKK

### NSPS SUBPART KKKK – STATIONARY GAS TURBINES

- (2) For a combined cycle and CHP turbine systems with supplemental heat (duct burner), you must measure the total NO<sub>x</sub> emissions after the duct burner rather than directly after the turbine. The duct burner must be in operation during the performance test.
- (3) If water or steam injection is used to control NO<sub>x</sub> with no additional post-combustion NO<sub>x</sub> control and you choose to monitor the steam or water to fuel ratio in accordance with §60.4335, then that monitoring system must be operated concurrently with each EPA Method 20 or EPA Method 7E run and must be used to determine the fuel consumption and the steam or water to fuel ratio necessary to comply with the applicable §60.4320 NO<sub>x</sub> emissions limit.
- (4) Compliance with the applicable emission limit in §60.4320 must be demonstrated at each tested load level. Compliance is achieved if the three-run arithmetic average NO<sub>x</sub> emissions rate at each tested level meets the applicable emission limit in §60.4320.
- (5) If you elect to install a CEMS, the performance evaluation of the CEMS may either be conducted separately or (as described in §60.4405) as part of the initial performance test of the affected unit.
- (6) The ambient temperature must be greater than 0 °F during the performance test.

#### **§ 60.4405 HOW DO I PERFORM THE INITIAL PERFORMANCE TEST IF I HAVE CHOSEN TO INSTALL A NO<sub>x</sub>-DILUENT CEMS?**

If you elect to install and certify a NO<sub>x</sub>-diluent CEMS under §60.4345, then the initial performance test required under §60.8 may be performed in the following alternative manner:

- (a) Perform a minimum of nine RATA reference method runs, with a minimum time per run of 21 minutes, at a single load level, within plus or minus 25 percent of 100 percent of peak load. The ambient temperature must be greater than 0 °F during the RATA runs.
- (b) For each RATA run, concurrently measure the heat input to the unit using a fuel flow meter (or flow meters) and measure the electrical and thermal output from the unit.
- (c) Use the test data both to demonstrate compliance with the applicable NO<sub>x</sub> emission limit under §60.4320 and to provide the required reference method data for the RATA of the CEMS described under §60.4335.
- (d) Compliance with the applicable emission limit in §60.4320 is achieved if the arithmetic average of all of the NO<sub>x</sub> emission rates for the RATA runs, expressed in units of ppm or lb/MWh, does not exceed the emission limit.

#### **§ 60.4410 HOW DO I ESTABLISH A VALID PARAMETER RANGE IF I HAVE CHOSEN TO CONTINUOUSLY MONITOR PARAMETERS?**

If you have chosen to monitor combustion parameters or parameters indicative of proper operation of NO<sub>x</sub> emission controls in accordance with §60.4340, the appropriate parameters must be continuously monitored and recorded during each run of the initial performance test, to establish acceptable operating ranges, for purposes of the parameter monitoring plan for the affected unit, as specified in §60.4355.

#### **§ 60.4415 HOW DO I CONDUCT THE INITIAL AND SUBSEQUENT PERFORMANCE TESTS FOR SULFUR?**

- (a) You must conduct an initial performance test, as required in §60.8. Subsequent SO<sub>2</sub> performance tests shall be conducted on an annual basis (no more than 14 calendar months following the previous performance test). There are three methodologies that you may use to conduct the performance tests.
  - (1) If you choose to periodically determine the sulfur content of the fuel combusted in the turbine, a representative fuel sample would be collected following ASTM D5287 (incorporated by reference, see §60.17) for natural gas or ASTM D4177 (incorporated by reference, see §60.17) for oil. Alternatively, for oil, you may follow the procedures for manual pipeline sampling in section 14 of ASTM D4057 (incorporated by reference, see §60.17). The fuel analyses of this section may be performed either by you, a service contractor retained by you, the fuel vendor, or any other qualified agency. Analyze the samples for the total sulfur content of the fuel using:

## SECTION VI. APPENDIX NKKKK

### NSPS SUBPART KKKK – STATIONARY GAS TURBINES

- (i) For liquid fuels, ASTM D129, or alternatively D1266, D1552, D2622, D4294, or D5453 (all of which are incorporated by reference, see §60.17); or
  - (ii) For gaseous fuels, ASTM D1072, or alternatively D3246, D4084, D4468, D4810, D6228, D6667, or Gas Processors Association Standard 2377 (all of which are incorporated by reference, see §60.17).
- (2) Measure the SO<sub>2</sub> concentration (in parts per million (ppm)), using EPA Methods 6, 6C, 8, or 20 in appendix A of this part. In addition, the American Society of Mechanical Engineers (ASME) standard, ASME PTC 19–10–1981–Part 10, “Flue and Exhaust Gas Analyses,” manual methods for sulfur dioxide (incorporated by reference, see §60.17) can be used instead of EPA Methods 6 or 20. For units complying with the output based standard, concurrently measure the stack gas flow rate, using EPA Methods 1 and 2 in appendix A of this part, and measure and record the electrical and thermal output from the unit. Then use the following equation to calculate the SO<sub>2</sub> emission rate:

$$E = \frac{1.664 \times 10^{-7} * (SO_2)_c * Q_{std}}{P} \quad (\text{Eq. 6})$$

Where:

E = SO<sub>2</sub> emission rate, in lb/MWh

$1.664 \times 10^{-7}$  = conversion constant, in lb/dscf-ppm

(SO<sub>2</sub>)<sub>c</sub> = average SO<sub>2</sub> concentration for the run, in ppm

Q<sub>std</sub> = stack gas volumetric flow rate, in dscf/hr

P = gross electrical and mechanical energy output of the combustion turbine, in MW (for simple-cycle operation), for combined-cycle operation, the sum of all electrical and mechanical output from the combustion and steam turbines, or, for combined heat and power operation, the sum of all electrical and mechanical output from the combustion and steam turbines plus all useful recovered thermal output not used for additional electric or mechanical generation, in MW, calculated according to §60.4350(f)(2); or

- (3) Measure the SO<sub>2</sub> and diluent gas concentrations, using either EPA Methods 6, 6C, or 8 and 3A, or 20 in appendix A of this part. In addition, you may use the manual methods for sulfur dioxide ASME PTC 19–10–1981–Part 10 (incorporated by reference, see §60.17). Concurrently measure the heat input to the unit, using a fuel flow meter (or flow meters), and measure the electrical and thermal output of the unit. Use EPA Method 19 in appendix A of this part to calculate the SO<sub>2</sub> emission rate in lb/MMBtu. Then, use Equations 1 and, if necessary, 2 and 3 in §60.4350(f) to calculate the SO<sub>2</sub> emission rate in lb/MWh.

(b) [Reserved]

### Definitions

#### § 60.4420 WHAT DEFINITIONS APPLY TO THIS SUBPART?

As used in this subpart, all terms not defined herein will have the meaning given them in the Clean Air Act and in subpart A (General Provisions) of this part.

*Combined cycle combustion turbine* means any stationary combustion turbine which recovers heat from the combustion turbine exhaust gases to generate steam that is only used to create additional power output in a steam turbine.

*Combined heat and power combustion turbine* means any stationary combustion turbine which recovers heat from the exhaust gases to heat water or another medium, generate steam for useful purposes other than additional electric generation, or directly uses the heat in the exhaust gases for a useful purpose.

*Combustion turbine model* means a group of combustion turbines having the same nominal air flow, combustor inlet pressure, combustor inlet temperature, firing temperature, turbine inlet temperature and turbine inlet pressure.

## SECTION VI. APPENDIX NKKKK

### NSPS SUBPART KKKK – STATIONARY GAS TURBINES

---

*Combustion turbine test cell/stand* means any apparatus used for testing uninstalled stationary or uninstalled mobile (motive) combustion turbines.

*Diffusion flame stationary combustion turbine* means any stationary combustion turbine where fuel and air are injected at the combustor and are mixed only by diffusion prior to ignition.

*Duct burner* means a device that combusts fuel and that is placed in the exhaust duct from another source, such as a stationary combustion turbine, internal combustion engine, kiln, etc., to allow the firing of additional fuel to heat the exhaust gases before the exhaust gases enter a heat recovery steam generating unit.

*Efficiency* means the combustion turbine manufacturer's rated heat rate at peak load in terms of heat input per unit of power output—based on the higher heating value of the fuel.

*Emergency combustion turbine* means any stationary combustion turbine which operates in an emergency situation. Examples include stationary combustion turbines used to produce power for critical networks or equipment, including power supplied to portions of a facility, when electric power from the local utility is interrupted, or stationary combustion turbines used to pump water in the case of fire or flood, etc. Emergency stationary combustion turbines do not include stationary combustion turbines used as peaking units at electric utilities or stationary combustion turbines at industrial facilities that typically operate at low capacity factors. Emergency combustion turbines may be operated for the purpose of maintenance checks and readiness testing, provided that the tests are required by the manufacturer, the vendor, or the insurance company associated with the turbine. Required testing of such units should be minimized, but there is no time limit on the use of emergency combustion turbines.

*Excess emissions* means a specified averaging period over which either (1) the NO<sub>x</sub> emissions are higher than the applicable emission limit in §60.4320; (2) the total sulfur content of the fuel being combusted in the affected facility exceeds the limit specified in §60.4330; or (3) the recorded value of a particular monitored parameter is outside the acceptable range specified in the parameter monitoring plan for the affected unit.

*Gross useful output* means the gross useful work performed by the stationary combustion turbine system. For units using the mechanical energy directly or generating only electricity, the gross useful work performed is the gross electrical or mechanical output from the turbine/generator set. For combined heat and power units, the gross useful work performed is the gross electrical or mechanical output plus the useful thermal output (i.e., thermal energy delivered to a process).

*Heat recovery steam generating unit* means a unit where the hot exhaust gases from the combustion turbine are routed in order to extract heat from the gases and generate steam, for use in a steam turbine or other device that utilizes steam. Heat recovery steam generating units can be used with or without duct burners.

*Integrated gasification combined cycle electric utility steam generating unit* means a coal-fired electric utility steam generating unit that burns a synthetic gas derived from coal in a combined-cycle gas turbine. No solid coal is directly burned in the unit during operation.

*ISO conditions* means 288 Kelvin, 60 percent relative humidity and 101.3 kilopascals pressure.

*Lean premix stationary combustion turbine* means any stationary combustion turbine where the air and fuel are thoroughly mixed to form a lean mixture before delivery to the combustor. Mixing may occur before or in the combustion chamber. A lean premixed turbine may operate in diffusion flame mode during operating conditions such as startup and shutdown, extreme ambient temperature, or low or transient load.

*Natural gas* means a naturally occurring fluid mixture of hydrocarbons (e.g., methane, ethane, or propane) produced in geological formations beneath the Earth's surface that maintains a gaseous state at standard atmospheric temperature and pressure under ordinary conditions. Additionally, natural gas must either be composed of at least 70 percent methane by volume or have a gross calorific value between 950 and 1,100 British thermal units (Btu) per standard cubic foot. Natural gas does not include the following gaseous fuels: landfill gas, digester gas, refinery gas, sour gas, blast furnace gas, coal-derived gas, producer gas, coke oven gas, or any gaseous fuel produced in a process which might result in highly variable sulfur content or heating value.

*Noncontinental area* means the State of Hawaii, the Virgin Islands, Guam, American Samoa, the Commonwealth of Puerto Rico, the Northern Mariana Islands, or offshore platforms.

**SECTION VI. APPENDIX NKKKK**

**NSPS SUBPART KKKK – STATIONARY GAS TURBINES**

*Peak load* means 100 percent of the manufacturer's design capacity of the combustion turbine at ISO conditions.

*Regenerative cycle combustion turbine* means any stationary combustion turbine which recovers heat from the combustion turbine exhaust gases to preheat the inlet combustion air to the combustion turbine.

*Simple cycle combustion turbine* means any stationary combustion turbine which does not recover heat from the combustion turbine exhaust gases to preheat the inlet combustion air to the combustion turbine, or which does not recover heat from the combustion turbine exhaust gases for purposes other than enhancing the performance of the combustion turbine itself.

*Stationary combustion turbine* means all equipment, including but not limited to the turbine, the fuel, air, lubrication and exhaust gas systems, control systems (except emissions control equipment), heat recovery system, and any ancillary components and sub-components comprising any simple cycle stationary combustion turbine, any regenerative/recuperative cycle stationary combustion turbine, any combined cycle combustion turbine, and any combined heat and power combustion turbine based system. Stationary means that the combustion turbine is not self propelled or intended to be propelled while performing its function. It may, however, be mounted on a vehicle for portability.

*Unit operating day* means a 24-hour period between 12 midnight and the following midnight during which any fuel is combusted at any time in the unit. It is not necessary for fuel to be combusted continuously for the entire 24-hour period.

*Unit operating hour* means a clock hour during which any fuel is combusted in the affected unit. If the unit combusts fuel for the entire clock hour, it is considered to be a full unit operating hour. If the unit combusts fuel for only part of the clock hour, it is considered to be a partial unit operating hour.

*Useful thermal output* means the thermal energy made available for use in any industrial or commercial process, or used in any heating or cooling application, i.e., total thermal energy made available for processes and applications other than electrical or mechanical generation. Thermal output for this subpart means the energy in recovered thermal output measured against the energy in the thermal output at 15 degrees Celsius and 101.325 kilopascals of pressure.

**Table 1—to Subpart KKKK of Part 60—Nitrogen Oxide Emission Limits for New Stationary Combustion Turbines**

Combustion turbine type	Combustion turbine heat input at peak load (HHV)	NO <sub>x</sub> emission standard
New turbine firing natural gas, electric generating	≤ 50 MMBtu/h	42 ppm at 15 percent O <sub>2</sub> or 290 ng/J of useful output (2.3 lb/MWh).
New turbine firing natural gas, mechanical drive	≤ 50 MMBtu/h	100 ppm at 15 percent O <sub>2</sub> or 690 ng/J of useful output (5.5 lb/MWh).
New turbine firing natural gas	> 50 MMBtu/h and ≤ 850 MMBtu/h	25 ppm at 15 percent O <sub>2</sub> or 150 ng/J of useful output (1.2 lb/MWh).
New, modified, or reconstructed turbine firing natural gas	> 850 MMBtu/h	15 ppm at 15 percent O <sub>2</sub> or 54 ng/J of useful output (0.43 lb/MWh)
New turbine firing fuels other than natural gas, electric generating	≤ 50 MMBtu/h	96 ppm at 15 percent O <sub>2</sub> or 700 ng/J of useful output (5.5 lb/MWh).
New turbine firing fuels other than natural gas, mechanical drive	≤ 50 MMBtu/h	150 ppm at 15 percent O <sub>2</sub> or 1,100 ng/J of useful output (8.7 lb/MWh).
New turbine firing fuels other than natural gas	> 50 MMBtu/h and ≤	74 ppm at 15 percent O <sub>2</sub> or

**SECTION VI. APPENDIX NKKKK**

**NSPS SUBPART KKKK – STATIONARY GAS TURBINES**

Combustion turbine type	Combustion turbine heat input at peak load (HHV)	NO <sub>x</sub> emission standard
	850 MMBtu/h	460 ng/J of useful output (3.6 lb/MWh).
New, modified, or reconstructed turbine firing fuels other than natural gas	> 850 MMBtu/h	42 ppm at 15 percent O <sub>2</sub> or 160 ng/J of useful output (1.3 lb/MWh).
Modified or reconstructed turbine	≤ 50 MMBtu/h	150 ppm at 15 percent O <sub>2</sub> or 1,100 ng/J of useful output (8.7 lb/MWh).
Modified or reconstructed turbine firing natural gas	> 50 MMBtu/h and ≤ 850 MMBtu/h	42 ppm at 15 percent O <sub>2</sub> or 250 ng/J of useful output (2.0 lb/MWh).
Modified or reconstructed turbine firing fuels other than natural gas	> 50 MMBtu/h and ≤ 850 MMBtu/h	96 ppm at 15 percent O <sub>2</sub> or 590 ng/J of useful output (4.7 lb/MWh).
Turbines located north of the Arctic Circle (latitude 66.5 degrees north), turbines operating at less than 75 percent of peak load, modified and reconstructed offshore turbines, and turbine operating at temperatures less than 0 °F	≤ 30 MW output	150 ppm at 15 percent O <sub>2</sub> or 1,100 ng/J of useful output (8.7 lb/MWh).
Turbines located north of the Arctic Circle (latitude 66.5 degrees north), turbines operating at less than 75 percent of peak load, modified and reconstructed offshore turbines, and turbine operating at temperatures less than 0 °F	> 30 MW output	96 ppm at 15 percent O <sub>2</sub> or 590 ng/J of useful output (4.7 lb/MWh).
Heat recovery units operating independent of the combustion turbine	All sizes	54 ppm at 15 percent O <sub>2</sub> or 110 ng/J of useful output (0.86 lb/MWh).

**SECTION VI. APPENDIX TV-6**  
**TITLE V CONDITIONS**

(version dated 06/23/06)

[Note: This appendix includes "canned conditions" developed from the "Title V Core List."]

Chapter 62-4, F.A.C.

1. **Not federally enforceable. General Prohibition.** Any stationary installation which will reasonably be expected to be a source of pollution shall not be operated, maintained, constructed, expanded, or modified without the appropriate and valid permits issued by the Department, unless the source is exempted by Department rule. The Department may issue a permit only after it receives reasonable assurance that the installation will not cause pollution in violation of any of the provisions of Chapter 403, F.S., or the rules promulgated thereunder. A permitted installation may only be operated, maintained, constructed, expanded or modified in a manner that is consistent with the terms of the permit. [Rule 62-4.030, Florida Administrative Code (F.A.C.); and, Section 403.087, Florida Statute (F.S.)]

2. **Not federally enforceable. Procedures to Obtain Permits and Other Authorizations; Applications.**

(1) Any person desiring to obtain a permit from the Department shall apply on forms prescribed by the Department and shall submit such additional information as the Department by law may require.

(2) All applications and supporting documents shall be filed in quadruplicate with the Department.

(3) To ensure protection of public health, safety, and welfare, any construction, modification, or operation of an installation which may be a source of pollution, shall be in accordance with sound professional engineering practices pursuant to Chapter 471, F.S. All applications for a Department permit shall be certified by a professional engineer registered in the State of Florida except, when the application is for renewal of an air pollution operation permit at a non-Title V source as defined in Rule 62-210.200, F.A.C., or where professional engineering is not required by Chapter 471, F.S. Where required by Chapter 471 or 492, F.S., applicable portions of permit applications and supporting documents which are submitted to the Department for public record shall be signed and sealed by the professional(s) who prepared or approved them.

(4) Processing fees for air construction permits shall be in accordance with Rule 62-4.050(4), F.A.C.

(5)(a) To be considered by the Department, each application must be accompanied by the proper processing fee. The fee shall be paid by check, payable to the Department of Environmental Protection. The fee is non-refundable except as provided in Section 120.60, F.S., and in this section.

(b) When an application is received without the required fee, the Department shall acknowledge receipt of the application and shall immediately notify the applicant by certified mail that the required fee was not received and advise the applicant of the correct fee. The Department shall take no further action until the correct fee is received. If a fee was received by the Department which is less than the amount required, the Department shall return the fee along with the written notification.

(c) Upon receipt of the proper application fee, the permit processing time requirements of Sections 120.60(2) and 403.0876, F.S., shall begin.

(d) If the applicant does not submit the required fee within ten days of receipt of written notification, the Department shall either return the unprocessed application or arrange with the applicant for the pick up of the application.

(e) If an applicant submits an application fee in excess of the required fee, the permit processing time requirements of Sections 120.60(2) and 403.0876, F.S., shall begin upon receipt, and the Department shall refund to the applicant the amount received in excess of the required fee.

(6) Any substantial modification to a complete application shall require an additional processing fee determined pursuant to the schedule set forth in Rule 62-4.050, F.A.C., and shall restart the time requirements of Sections 120.60 and 403.0876, F.S. For purposes of this subsection, the term "substantial modification" shall mean a modification which is reasonably expected to lead to substantially different environmental impacts which require a detailed review.

(7) Modifications to existing permits proposed by the permittee which require substantial changes in the existing permit or require substantial evaluation by the Department of potential impacts of the proposed modifications shall require the same fee as a new application for the same time duration except for modification under Chapter 62-45, F.A.C.

[Rule 62-4.050, F.A.C.]



## SECTION VI. APPENDIX TV-6

### TITLE V CONDITIONS

3. Standards for Issuing or Denying Permits. Except as provided at Rule 62-213.460, F.A.C., the issuance of a permit does not relieve any person from complying with the requirements of Chapter 403, F.S., or Department rules.

[Rule 62-4.070(7), F.A.C.]

4. Modification of Permit Conditions.

(1) For good cause and after notice and an administrative hearing, if requested, the Department may require the permittee to conform to new or additional conditions. The Department shall allow the permittee a reasonable time to conform to the new or additional conditions and on application of the permittee the Department may grant additional time. For the purpose of this section, good cause shall include, but not be limited to, any of the following: (also, see Condition No. 38.)

(a) A showing that an improvement in effluent or emission quality or quantity can be accomplished because of technological advances without unreasonable hardship.

(b) A showing that a higher degree of treatment is necessary to effect the intent and purpose of Chapter 403, F.S.

(c) A showing of any change in the environment or surrounding conditions that requires a modification to conform to applicable air or water quality standards.

(e) Adoption or revision of Florida Statutes, rules, or standards which require the modification of a permit condition for compliance.

(2) A permittee may request a modification of a permit by applying to the Department.

(3) A permittee may request that a permit be extended as a modification of the permit. Such a request must be submitted to the Department in writing before the expiration of the permit. Upon timely submittal of a request for extension, unless the permit automatically expires by statute or rule, the permit will remain in effect until final agency action is taken on the request. For construction permits, an extension shall be granted if the applicant can demonstrate reasonable assurances that, upon completion, the extended permit will comply with the standards and conditions required by applicable regulation. For all other permits, an extension shall be granted if the applicant can demonstrate reasonable assurances that the extended permit will comply with the standards and conditions applicable to the original permit. A permit for which the permit application fee was prorated in accordance with Rule 62-4.050(4)(v), F.A.C., shall not be extended. In no event shall a permit be extended or remain in effect longer than the time limits established by statute or rule.

[Rule 62-4.080, F.A.C.]

5. Renewals. Prior to 180 days before the expiration of a permit issued pursuant to Chapter 62-213, F.A.C., the permittee shall apply for a renewal of a permit using forms incorporated by reference in the specific rule chapter for that kind of permit. A renewal application shall be timely and sufficient. If the application is submitted prior to 180 days before expiration of the permit, it will be considered timely and sufficient. If the renewal application is submitted at a later date, it will not be considered timely and sufficient unless it is submitted and made complete prior to the expiration of the operation permit. When the application for renewal is timely and sufficient, the existing permit shall remain in effect until the renewal application has been finally acted upon by the Department or, if there is court review of the Department's final agency action, until a later date is required by Section 120.60, F.S., provided that, for renewal of a permit issued pursuant to Chapter 62-213, F.A.C., the applicant complies with the requirements of Rules 62-213.420(1)(b)3. and 4., F.A.C.

[Rule 62-4.090, F.A.C.]

6. Suspension and Revocation.

(1) Permits shall be effective until suspended, revoked, surrendered, or expired and shall be subject to the provisions of Chapter 403, F.S., and rules of the Department.

(2) Failure to comply with pollution control laws and rules shall be grounds for suspension or revocation.

(3) A permit issued pursuant to Chapter 62-4, F.A.C., shall not become a vested property right in the permittee. The Department may revoke any permit issued by it if it finds that the permit holder or his agent:

(a) Submitted false or inaccurate information in his application or operational reports.

(b) Has violated law, Department orders, rules or permit conditions.

(c) Has failed to submit operational reports or other information required by Department rules.

(d) Has refused lawful inspection under Section 403.091, F.S.

(4) No revocation shall become effective except after notice is served by personal services, certified mail, or newspaper notice pursuant to Section 120.60(7), F.S., upon the person or persons named therein and a hearing held if requested within the time specified in the notice. The

## SECTION VI. APPENDIX TV-6

### TITLE V CONDITIONS

notice shall specify the provision of the law, or rule alleged to be violated, or the permit condition or Department order alleged to be violated, and the facts alleged to constitute a violation thereof.

[Rule 62-4.100, F.A.C.]

7. **Not federally enforceable.** Financial Responsibility. The Department may require an applicant to submit proof of financial responsibility and may require the applicant to post an appropriate bond to guarantee compliance with the law and Department rules.

[Rule 62-4.110, F.A.C.]

8. Transfer of Permits.

(1) Within 30 days after the sale or legal transfer of a permitted facility, an "Application for Transfer of Permit" (DEP Form 62-1.201(1)) must be submitted to the Department. This form must be completed with the notarized signatures of both the permittee and the proposed new permittee. For air permits, an "Application for Transfer of Air Permit" (DEP Form 62-210.900(7)) shall be submitted.

(2) The Department shall approve the transfer of a permit unless it determines that the proposed new permittee cannot provide reasonable assurances that conditions of the permit will be met. The determination shall be limited solely to the ability of the new permittee to comply with the conditions of the existing permit, and it shall not concern the adequacy of these permit conditions. If the Department proposes to deny the transfer, it shall provide both the permittee and the proposed new permittee a written objection to such transfer together with notice of a right to request a Chapter 120, F.S., proceeding on such determination.

(3) Within 30 days of receiving a properly completed Application for Transfer of Permit form, the Department shall issue a final determination. The Department may toll the time for making a determination on the transfer by notifying both the permittee and the proposed new permittee that additional information is required to adequately review the transfer request. Such notification shall be served within 30 days of receipt of an Application for Transfer of Permit form, completed pursuant to Rule 62-4.120(1), F.A.C. If the Department fails to take action to approve or deny the transfer within 30 days of receipt of the completed Application for Transfer of Permit form, or within 30 days of receipt of the last item of timely requested additional information, the transfer shall be deemed approved.

(4) The permittee is encouraged to apply for a permit transfer prior to the sale or legal transfer of a permitted facility. However, the transfer shall not be effective prior to the sale or legal transfer.

(5) Until this transfer is approved by the Department, the permittee and any other person constructing, operating, or maintaining the permitted facility shall be liable for compliance with the terms of the permit. The permittee transferring the permit shall remain liable for corrective actions that may be required as a result of any violations occurring prior to the sale or legal transfer of the facility.

[Rule 62-4.120, F.A.C.]

9. Plant Operation-Problems. If the permittee is temporarily unable to comply with any of the conditions of the permit due to breakdown of equipment or destruction by hazard of fire, wind or by other cause, the permittee shall immediately notify the Department. Notification shall include pertinent information as to the cause of the problem, and what steps are being taken to correct the problem and to prevent its recurrence, and where applicable, the owner's intent toward reconstruction of destroyed facilities. Such notification does not release the permittee from any liability for failure to comply with Department rules. (also, see Condition No. 10.)

[Rule 62-4.130, F.A.C.]

10. For purposes of notification to the Department pursuant to Condition No. 9., Condition No. 12.(8), and Rule 62-4.130, F.A.C., Plant Operation-Problems, "immediately" shall mean the same day, if during a workday (i.e., 8:00 a.m. - 5:00 p.m.), or the first business day after the incident, excluding weekends and holidays; and, for purposes of 40 CFR 70.6(a)(3)(iii)(B), "prompt" shall have the same meaning as "immediately". [also, see Conditions Nos. 9. and 12.(8).]

[40 CFR 70.6(a)(3)(iii)(B)]

11. **Not federally enforceable.** Review. Failure to request a hearing within 14 days of receipt of notice of proposed or final agency action on a permit application or as otherwise required in Chapter 62-103, F.A.C., shall be deemed a waiver of the right to an administrative hearing.

[Rule 62-4.150, F.A.C.]

## SECTION VI. APPENDIX TV-6

### TITLE V CONDITIONS

12. Permit Conditions. All permits issued by the Department shall include the following general conditions:

- (1) The terms, conditions, requirements, limitations and restrictions set forth in this permit, are "permit conditions" and are binding and enforceable pursuant to Sections 403.141, 403.727, or 403.859 through 403.861, F.S. The permittee is placed on notice that the Department will review this permit periodically and may initiate enforcement action for any violation of these conditions.
- (2) This permit is valid only for the specific processes and operations applied for and indicated in the approved drawings or exhibits. Any unauthorized deviation from the approved drawings, exhibits, specifications, or conditions of this permit may constitute grounds for revocation and enforcement action by the Department.
- (3) As provided in Subsections 403.987(6) and 403.722(5), F.S., the issuance of this permit does not convey any vested rights or any exclusive privileges. Neither does it authorize any injury to public or private property or any invasion of personal rights, nor any infringement of federal, state, or local laws or regulations. This permit is not a waiver of or approval of any other Department permit that may be required for other aspects of the total project which are not addressed in this permit.
- (4) This permit conveys no title to land or water, does not constitute State recognition or acknowledgment of title, and does not constitute authority for the use of submerged lands unless herein provided and the necessary title or leasehold interests have been obtained from the State. Only the Trustees of the Internal Improvement Trust Fund may express State opinion as to title.
- (5) This permit does not relieve the permittee from liability for harm or injury to human health or welfare, animal, or plant life, or property caused by the construction or operation of this permitted source, or from penalties therefore; nor does it allow the permittee to cause pollution in contravention of F.S. and Department rules, unless specifically authorized by an order from the Department.
- (6) The permittee shall properly operate and maintain the facility and systems of treatment and control (and related appurtenances) that are installed and used by the permittee to achieve compliance with the conditions of this permit, as required by Department rules. This provision includes the operation of backup or auxiliary facilities or similar systems when necessary to achieve compliance with the conditions of the permit and when required by Department rules.
- (7) The permittee, by accepting this permit, specifically agrees to allow authorized Department personnel, upon presentation of credentials or other documents as may be required by law and at reasonable times, access to the premises where the permitted activity is located or conducted to:
  - (a) Have access to and copy any records that must be kept under conditions of the permit;
  - (b) Inspect the facility, equipment, practices, or operations regulated or required under this permit; and
  - (c) Sample or monitor any substances or parameters at any location reasonably necessary to assure compliance with this permit or Department rules. Reasonable time may depend on the nature of the concern being investigated.
- (8) If, for any reason, the permittee does not comply with or will be unable to comply with any condition or limitation specified in this permit, the permittee shall immediately provide the Department with the following information: **(also, see Condition No. 10.)**
  - (a) A description of and cause of noncompliance; and
  - (b) The period of noncompliance, including dates and times; or, if not corrected, the anticipated time the noncompliance is expected to continue, and steps being taken to reduce, eliminate, and prevent recurrence of the noncompliance. The permittee shall be responsible for any and all damages which may result and may be subject to enforcement action by the Department for penalties or for revocation of this permit.
- (9) In accepting this permit, the permittee understands and agrees that all records, notes, monitoring data and other information relating to the construction or operation of this permitted source which are submitted to the Department may be used by the Department as evidence in any enforcement case involving the permitted source arising under the Florida Statutes or Department rules, except where such use is prescribed by Sections 403.111 and 403.73, F.S. Such evidence shall only be used to the extent it is consistent with the Florida Rules of Civil Procedure and appropriate evidentiary rules.
- (10) The permittee agrees to comply with changes in Department rules and Florida Statutes after a reasonable time for compliance; provided, however, the permittee does not waive any other rights granted by Florida Statutes or Department rules.
- (11) This permit is transferable only upon Department approval in accordance with Rule 62-4.120, F.A.C., as applicable. The permittee shall be liable for any non-compliance of the permitted activity until the transfer is approved by the Department.
- (12) This permit or a copy thereof shall be kept at the work site of the permitted activity.
- (14) The permittee shall comply with the following:
  - (a) Upon request, the permittee shall furnish all records and plans required under Department rules. During enforcement actions, the retention period for all records will be extended automatically unless otherwise stipulated by the Department.

## SECTION VI. APPENDIX TV-6

### TITLE V CONDITIONS

(b) The permittee shall hold at the facility or other location designated by this permit records of all monitoring information (including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation) required by the permit, copies of all reports required by this permit, and records of all data used to complete the application for this permit. These materials shall be retained at least five (5) years from the date of the sample, measurement, report, or application unless otherwise specified by Department rule.

(c) Records of monitoring information shall include:

1. The date, exact place, and time of sampling or measurements;
2. The person responsible for performing the sampling or measurements;
3. The dates analyses were performed;
4. The person responsible for performing the analyses;
5. The analytical techniques or methods used;
6. The results of such analyses.

(15) When requested by the Department, the permittee shall within a reasonable time furnish any information required by law which is needed to determine compliance with the permit. If the permittee becomes aware the relevant facts were not submitted or were incorrect in the permit application or in any report to the Department, such facts or information shall be corrected promptly.

[Rules 62-4.160 and 62-213.440(1)(b), F.A.C.]

#### 13. Construction Permits.

(1) No person shall construct any installation or facility which will reasonably be expected to be a source of air pollution without first applying for and receiving a construction permit from the Department unless exempted by statute or Department rule. In addition to the requirements of Chapter 62-4, F.A.C., applicants for a Department Construction Permit shall submit the following as applicable:

(a) A completed application on forms furnished by the Department.

(b) An engineering report covering:

1. Plant description and operations,
2. Types and quantities of all waste material to be generated whether liquid, gaseous or solid,
3. Proposed waste control facilities,
4. The treatment objectives,
5. The design criteria on which the control facilities are based, and
6. Other information deemed relevant.

Design criteria submitted pursuant to Rule 62-4.210(1)(b)5., F.A.C., shall be based on the results of laboratory and pilot-plant scale studies whenever such studies are warranted. The design efficiencies of the proposed waste treatment facilities and the quantities and types of pollutants in the treated effluents or emissions shall be indicated. Work of this nature shall be subject to the requirements of Chapter 471, F.S. Where confidential records are involved, certain information may be kept confidential pursuant to Section 403.111, F.S.

(c) The owners' written guarantee to meet the design criteria as accepted by the Department and to abide by Chapter 403, F.S., and the rules of the Department as to the quantities and types of materials to be discharged from the installation. The owner may be required to post an appropriate bond or other equivalent evidence of financial responsibility to guarantee compliance with such conditions in instances where the owner's financial resources are inadequate or proposed control facilities are experimental in nature.

(2) The construction permit may contain conditions and an expiration date as determined by the Secretary or the Secretary's designee.

(3) When the Department issues a permit to construct, the permittee shall be allowed a period of time, specified in the permit, to construct, and to operate and test to determine compliance with Chapter 403, F.S., and the rules of the Department and, where applicable, to apply for and receive an operation permit. The Department may require tests and evaluations of the treatment facilities by the permittee at his/her expense.

[Rule 62-4.210, F.A.C.]

14. **Not federally enforceable.** Operation Permit for New Sources. To properly apply for an operation permit for new sources the applicant shall submit the appropriate fee and certification that construction was completed, noting any deviations from the conditions in the construction permit and test results where appropriate.

[Rule 62-4.220, F.A.C.]

## SECTION VI. APPENDIX TV-6

### TITLE V CONDITIONS

#### Chapters 28-106 and 62-110, F.A.C.

15. Public Notice, Public Participation, and Proposed Agency Action. The permittee shall comply with all of the requirements for public notice, public participation, and proposed agency action pursuant to Rules 62-110.106 and 62-210.350, F.A.C.

[Rules 62-110.106, 62-210.350 and 62-213.430(1)(b), F.A.C.]

16. Administrative Hearing. The permittee shall comply with all of the requirements for a petition for administrative hearing or waiver of right to administrative proceeding pursuant to Rules 28-106.201, 28-106.301 and 62-110.106, F.A.C.

[Rules 28-106.201, 28-106.301 and 62-110.106, F.A.C.]

#### Chapter 62-204, F.A.C.

17. Asbestos. This permit does not authorize any demolition or renovation of the facility or its parts or components which involves asbestos removal. This permit does not constitute a waiver of any of the requirements of Chapter 62-257, F.A.C., and 40 CFR 61, Subpart M, National Emission Standard for Asbestos, adopted and incorporated by reference in Rule 62-204.800, F.A.C. Compliance with Chapter 62-257, F.A.C., and 40 CFR 61, Subpart M, Section 61.145, is required for any asbestos demolition or renovation at the source.

[40 CFR 61; Rule 62-204.800, F.A.C.; and, Chapter 62-257, F.A.C.]

#### Chapter 62-210, F.A.C.

18. Permits Required. Unless exempted from permitting pursuant to Rule 62-210.300(3)(a) or (b), F.A.C., or Rule 62-4.040, F.A.C., or unless specifically authorized by provision of Rule 62-210.300(4), F.A.C., or Rule 62-213.300, F.A.C., the owner or operator of any facility or emissions unit which emits or can reasonably be expected to emit any air pollutant shall obtain an appropriate permit from the Department prior to beginning construction, reconstruction pursuant to 40 CFR 60.15 or 63.2, modification, or the addition of pollution control equipment; or to authorize initial or continued operation of the emissions unit; or to establish a PAL or Air Emissions Bubble. All emissions limitations, controls, and other requirements imposed by such permits shall be at least as stringent as any applicable limitations and requirements contained in or enforceable under the State Implementation Plan (SIP) or that are otherwise federally enforceable. Except as provided at Rule 62-213.460, F.A.C., issuance of a permit does not relieve the owner or operator of a facility or an emissions unit from complying with any applicable requirements, any emission limiting standards or other requirements of the air pollution rules of the Department or any other such requirements under federal, state, or local law.

(1) Air Construction Permits.

(a) Unless exempt from permitting pursuant to Rule 62-210.300(3)(a) or (b), F.A.C., or Rule 62-4.040, F.A.C., an air construction permit shall be obtained by the owner or operator of any proposed new, reconstructed, or modified facility or emissions unit, or any new pollution control equipment prior to the beginning of construction, reconstruction pursuant to 40 CFR 60.15 or 63.2, or modification of the facility or emissions unit or addition of the pollution control equipment; or to establish a PAL; in accordance with all applicable provisions of Chapter 62-210, F.A.C., Chapter 62-212, F.A.C., and Chapter 62-4, F.A.C. Except as provided under Rule 62-213.415, F.A.C., the owner or operator of any facility seeking to create or change an air emissions bubble shall obtain an air construction permit in accordance with all the applicable provisions of Chapter 62-210, F.A.C., Chapters 62-212 and 62-4, F.A.C. The construction permit shall be issued for a period of time sufficient to allow construction, reconstruction or modification of the facility or emissions unit or addition of the air pollution control equipment; and operation while the owner or operator of the new, reconstructed or modified facility or emissions unit or the new pollution control equipment is conducting tests or otherwise demonstrating initial compliance with the conditions of the construction permit.

(b) Notwithstanding the expiration of an air construction permit, all limitations and requirements of such permit that are applicable to the design and operation of the permitted facility or emissions unit shall remain in effect until the facility or emissions unit is permanently shut down, except for any such limitation or requirement that is obsolete by its nature (such as a requirement for initial compliance testing) or any such limitation or requirement that is changed in accordance with the provisions of Rule 62-210.300(1)(b)1., F.A.C. Either the applicant or the Department can propose that certain conditions be considered obsolete. Any conditions or language in an air construction permit that are included for informational purposes only, if they are transferred to the air operation permit, shall be transferred for

**SECTION VI. APPENDIX TV-6**  
**TITLE V CONDITIONS**

---

informational purposes only and shall not become enforceable conditions unless voluntarily agreed to by the permittee or otherwise required under Department rules.

1. Except for those limitations or requirements that are obsolete, all limitations and requirements of an air construction permit shall be included and identified in any air operation permit for the facility or emissions unit. The limitations and requirements included in the air operation permit can be changed, and thereby superseded, through the issuance of an air construction permit, federally enforceable state air operation permit, federally enforceable air general permit, or Title V air operation permit; provided, however, that:
  - a. Any change that would constitute an administrative correction may be made pursuant to Rule 62-210.360, F.A.C.;
  - b. Any change that would constitute a modification, as defined at Rule 62-210.200, F.A.C., shall be accomplished only through the issuance of an air construction permit; and
  - c. Any change in a permit limitation or requirement that originates from a permit issued pursuant to 40 CFR 52.21, Rule 62-204.800(11)(d)2., F.A.C., Rule 62-212.400, F.A.C., Rule 62-212.500, F.A.C., or any former codification of Rule 62-212.400 or Rule 62-212.500, F.A.C., shall be accomplished only through the issuance of a new or revised air construction permit under Rule 62-204.800(11)(d)2., Rule 62-212.400 or Rule 62-212.500, F.A.C., as appropriate.
2. The force and effect of any change in a permit limitation or requirement made in accordance with the provisions of Rule 62-210.300(1)(b)1., F.A.C., shall be the same as if such change were made to the original air construction permit.
3. Nothing in Rule 62-210.300(1)(b), F.A.C., shall be construed as to allow operation of a facility or emissions unit without a valid air operation permit.

(2) Air Operation Permits. Upon expiration of the air operation permit for any existing facility or emissions unit, subsequent to construction or modification, or subsequent to the creation of or change to a bubble, and demonstration of compliance with the conditions of the construction permit for any new or modified facility or emissions unit, any air emissions bubble, or as otherwise provided in Chapter 62-210, F.A.C., or Chapter 62-213, F.A.C., the owner or operator of such facility or emissions unit shall obtain a renewal air operation permit, an initial air operation permit or air general permit, or an administrative correction or revision of an existing air operation permit, whichever is appropriate, in accordance with all applicable provisions of Chapter 62-210, F.A.C., Chapter 62-213, F.A.C., and Chapter 62-4, F.A.C.

- (a) Minimum Requirements for All Air Operation Permits. At a minimum, a permit issued pursuant to this subsection shall:
  1. Specify the manner, nature, volume and frequency of the emissions permitted, and the applicable emission limiting standards or performance standards, if any;
  2. Require proper operation and maintenance of any pollution control equipment by qualified personnel, where applicable in accordance with the provisions of any operation and maintenance plan required by the air pollution rules of the Department.
  3. Contain an effective date stated in the permit which shall not be earlier than the date final action is taken on the application and be issued for a period, beginning on the effective date, as provided below.
    - a. The operation permit for an emissions unit which is in compliance with all applicable rules and in operational condition, and which the owner or operator intends to continue operating, shall be issued or renewed for a five-year period, except that, for Title V sources subject to Rule 62-213.420(1)(a)1., F.A.C., operation permits shall be extended until 60 days after the due date for submittal of the facility's Title V permit application as specified in Rule 62-213.420(1)(a)1., F.A.C.
    - b. Except as provided in Rule 62-210.300(2)(a)3.d., F.A.C., the operation permit for an emissions unit which has been shut down for six months or more prior to the expiration date of the current operation permit, shall be renewed for a period not to exceed five years from the date of shutdown, even if the emissions unit is not maintained in operational condition, provided:
      - (i) the owner or operator of the emissions unit demonstrates to the Department that the emissions unit may need to be reactivated and used, or that it is the owner's or operator's intent to apply to the Department for a permit to construct a new emissions unit at the facility before the end of the extension period; and
      - (ii) the owner or operator of the emissions unit agrees to and is legally prohibited from providing the allowable emission permitted by the renewed permit as an emissions offset to any other person under Rule 62-212.500, F.A.C.; and
      - (iii) the emissions unit was operating in compliance with all applicable rules as of the time the source was shut down.
    - c. Except as provided in Rule 62-210.300(2)(a)3.d., F.A.C., the operation permit for an emissions unit which has been shut down for five years or more prior to the expiration date of the current operation permit shall be renewed for a maximum period not to exceed ten years from the date of shutdown, even if the emissions unit is not maintained in operational condition,

## SECTION VI. APPENDIX TV-6

### TITLE V CONDITIONS

provided the conditions given in Rule 62-210.300(2)(a)3.b., F.A.C., are met and the owner or operator demonstrates to the Department that failure to renew the permit would constitute a hardship, which may include economic hardship.

d. The operation permit for an electric utility generating unit on cold standby or long-term reserve shutdown shall be renewed for a five-year period, and additional five-year periods, even if the unit is not maintained in operational condition, provided the conditions given in Rules 62-210.300(2)(a)3.b.(i) through (iii), F.A.C., are met.

4. In the case of an emissions unit permitted pursuant to Rules 62-210.300(2)(a)3.b., c., and d., F.A.C., include reasonable notification and compliance testing requirements for reactivation of such emissions unit and provide that the owner or operator demonstrate to the Department prior to reactivation that such reactivation would not constitute reconstruction pursuant to Rule 62-204.800(8), F.A.C.

[Rules 62-210.300(1) & (2), F.A.C.]

19. **Not federally enforceable. Notification of Startup.** The owners or operator of any emissions unit or facility which has a valid air operation permit which has been shut down more than one year, shall notify the Department in writing of the intent to start up such emissions unit or facility, a minimum of 60 days prior to the intended startup date.

(a) The notification shall include information as to the startup date, anticipated emission rates or pollutants released, changes to processes or control devices which will result in changes to emission rates, and any other conditions which may differ from the valid outstanding operation permit.

(b) If, due to an emergency, a startup date is not known 60 days prior thereto, the owner shall notify the Department as soon as possible after the date of such startup is ascertained.

[Rule 62-210.300(5), F.A.C.]

20. **Emissions Unit Reclassification.**

(a) Any emissions unit whose operation permit has been revoked as provided for in Chapter 62-4, F.A.C., shall be deemed permanently shut down for purposes of Rule 62-212.500, F.A.C. Any emissions unit whose permit to operate has expired without timely renewal or transfer may be deemed permanently shut down, provided, however, that no such emissions unit shall be deemed permanently shut down if, within 20 days after receipt of written notice from the Department, the emissions unit owner or operator demonstrates that the permit expiration resulted from inadvertent failure to comply with the requirements of Rule 62-4.090, F.A.C., and that the owner or operator intends to continue the emissions unit in operation, and either submits an application for an air operation permit or complies with permit transfer requirements, if applicable.

(b) If the owner or operator of an emissions unit which is so permanently shut down, applies to the Department for a permit to reactivate or operate such emissions unit, the emissions unit will be reviewed and permitted as a new emissions unit.

[Rule 62-210.300(6), F.A.C.]

21. **Transfer of Air Permits.**

(a) An air permit is transferable only after submission of an Application for Transfer of Air Permit (DEP Form 62-210.900(7)) and Department approval in accordance with Rule 62-4.120, F.A.C. For Title V permit transfers only, a complete application for transfer of air permit shall include the requirements of 40 CFR 70.7(d)(1)(iv), adopted and incorporated by reference at Rule 62-204.800, F.A.C. Within 30 days after approval of the transfer of permit, the Department shall update the permit by an administrative permit correction pursuant to Rule 62-210.360, F.A.C.

(b) For an air general permit, the provision of Rules 62-210.300(7)(a) and 62-4.120, F.A.C., do not apply. Thirty (30) days before using an air general permit, the new owner must submit an air general permit notification to the Department in accordance with Rule 62-210.300(4), F.A.C., or Rule 62-213.300(2)(b), F.A.C.

[Rule 62-210.300(7), F.A.C.]

22. **Public Notice and Comment.**

(1) Public Notice of Proposed Agency Action.

(a) A notice of proposed agency action on permit application, where the proposed agency action is to issue the permit, shall be published by any applicant for:

1. An air construction permit;

## SECTION VI. APPENDIX TV-6

### TITLE V CONDITIONS

2. An air operation permit, permit renewal or permit revision subject to Rule 62-210.300(2)(b), F.A.C., (i.e., a FESOP), except as provided in Rule 62-210.300(2)(b)1.b., F.A.C.; or
  3. An air operation permit, permit renewal, or permit revision subject to Chapter 62-213, F.A.C., except Title V air general permits or those permit revisions meeting the requirements of Rule 62-213.412(1), F.A.C.
- (b) The notice required by Rule 62-210.350(1)(a), F.A.C., shall be published in accordance with all otherwise applicable provisions of Rule 62-110.106, F.A.C. A public notice under Rule 62-210.350(1)(a)1., F.A.C., for an air construction permit may be combined with any required public notice under Rule 62-210.350(1)(a)2. or 3., F.A.C., for air operation permits. If such notices are combined, the public notice must comply with the requirements for both notices.
- (c) Except as otherwise provided at Rules 62-210.350(2), (5), and (6), F.A.C., each notice of intent to issue an air construction permit shall provide a 14-day period for submittal of public comments.
- (2) Additional Public Notice Requirements for Emissions Units Subject to Prevention of Significant Deterioration or Nonattainment - Area Preconstruction Review.
- (a) Before taking final agency action on a construction permit application for any proposed new or modified facility or emissions unit subject to the preconstruction review requirements of Rule 62-212.400 or 62-212.500, F.A.C., the Department shall comply with all applicable provisions of Rule 62-110.106, F.A.C., and provide an opportunity for public comment which shall include as a minimum the following:
1. A complete file available for public inspection in at least one location in the district affected which includes the information submitted by the owner or operator, exclusive of confidential records under Section 403.111, F.S., and the Department's analysis of the effect of the proposed construction or modification on ambient air quality, including the Department's preliminary determination of whether the permit should be approved or disapproved;
  2. A 30-day period for submittal of public comments; and
  3. A notice, by advertisement in a newspaper of general circulation in the county affected, specifying the nature and location of the proposed facility or emissions unit, whether BACT or LAER has been determined, the degree of PSD increment consumption expected, if applicable, and the location of the information specified in paragraph 1. above; and notifying the public of the opportunity for submitting comments and requesting a public hearing.
- (b) The notice provided for in Rule 62-210.350(2)(a)3., F.A.C., shall be prepared by the Department and published by the applicant in accordance with all applicable provisions of Rule 62-110.106, F.A.C., except that the applicant shall cause the notice to be published no later than thirty (30) days prior to final agency action.
- (c) A copy of the notice provided for in Rule 62-210.350(2)(a)3., F.A.C., shall also be sent by the Department to the Regional Office of the U. S. Environmental Protection Agency and to all other state and local officials or agencies having cognizance over the location of such new or modified facility or emissions unit, including local air pollution control agencies, chief executives of city or county government, regional land use planning agencies, and any other state, Federal Land Manager, or Indian Governing Body whose lands may be affected by emissions from the new or modified facility or emissions unit.
- (d) A copy of the notice provided for in Rule 62-210.350(2)(a)3., F.A.C., shall be displayed in the appropriate district, branch and local program offices.
- (e) An opportunity for public hearing shall be provided in accordance with Chapter 120, F.S., and Rule 62-110.106, F.A.C.
- (f) Any public comments received shall be made available for public inspection in the location where the information specified in Rule 62-210.350(2)(a)1., F.A.C., is available and shall be considered by the Department in making a final determination to approve or deny the permit.
- (g) The final determination shall be made available for public inspection at the same location where the information specified in Rule 62-210.350(2)(a)1., F.A.C., was made available.
- (h) For a proposed new or modified emissions unit which would be located within 100 kilometers of any Federal Class I area or whose emissions may affect any Federal Class I area, and which would be subject to the preconstruction review requirements of Rule 62-212.400 or 62-212.500, F.A.C.:
1. The Department shall mail or transmit to the Administrator a copy of the initial application for an air construction permit and notice of every action related to the consideration of the permit application.
  2. The Department shall mail or transmit to the Federal Land Manager of each affected Class I area a copy of any written notice of intent to apply for an air construction permit; the initial application for an air construction permit, including all required analyses and



## SECTION VI. APPENDIX TV-6

### TITLE V CONDITIONS

demonstrations; any subsequently submitted information related to the application; the preliminary determination and notice of proposed agency action on the permit application; and any petition for an administrative hearing regarding the application or the Department's proposed action. Each such document shall be mailed or transmitted to the Federal Land Manager within fourteen (14) days after its receipt by the Department.

(3) Additional Public Notice Requirements for Facilities Subject to Operation Permits for Title V Sources.

(a) Before taking final agency action to issue a new, renewed, or revised air operation permit subject to Chapter 62-213, F.A.C., the Department shall comply with all applicable provisions of Rule 62-110.106, F.A.C., and provide an opportunity for public comment which shall include as a minimum the following:

1. A complete file available for public inspection in at least one location in the district affected which includes the information submitted by the owner or operator, exclusive of confidential records under Section 403.111, F.S.; and
2. A 30-day period for submittal of public comments.

(b) The notice provided for in Rule 62-210.350(3)(a), F.A.C., shall be prepared by the Department and published by the applicant in accordance with all applicable provisions of Rule 62-110.106, F.A.C., except that the applicant shall cause the notice to be published no later than thirty (30) days prior to final agency action. If written comments received during the 30-day comment period on a draft permit result in the Department's issuance of a revised draft permit in accordance with Rule 62-213.430(1), F.A.C., the Department shall require the applicant to publish another public notice in accordance with Rule 62-210.350(1)(a), F.A.C.

(c) The notice shall identify:

1. The facility;
2. The name and address of the office at which processing of the permit occurs;
3. The activity or activities involved in the permit action;
4. The emissions change involved in any permit revision;
5. The name, address, and telephone number of a Department representative from whom interested persons may obtain additional information, including copies of the permit draft, the application, and all relevant supporting materials, including any permit application, compliance plan, permit, monitoring report, and compliance statement required pursuant to Chapter 62-213, F.A.C. (except for information entitled to confidential treatment pursuant to Section 403.111, F.S.), and all other materials available to the Department that are relevant to the permit decision;
6. A brief description of the comment procedures required by Rule 62-210.350(3), F.A.C.;
7. The time and place of any hearing that may be held, including a statement of procedure to request a hearing (unless a hearing has already been scheduled); and
8. The procedures by which persons may petition the Administrator to object to the issuance of the proposed permit after expiration of the Administrator's 45-day review period.

[Rules 62-210.350(1) thru (3), F.A.C.]

23. Administrative Permit Corrections.

(1) A facility owner shall notify the Department by letter of minor corrections to information contained in a permit. Such notifications shall include:

- (a) Typographical errors noted in the permit;
- (b) Name, address or phone number change from that in the permit;
- (c) A change requiring more frequent monitoring or reporting by the permittee;
- (d) A change in ownership or operational control of a facility, subject to the following provisions:
  1. The Department determines that no other change in the permit is necessary;
  2. The permittee and proposed new permittee have submitted an Application for Transfer of Air Permit, and the Department has approved the transfer pursuant to Rule 62-210.300(7), F.A.C.; and
  3. The new permittee has notified the Department of the effective date of sale or legal transfer.
- (e) Changes listed at 40 CFR 72.83(a)(1), (2), (6), (9) and (10), adopted and incorporated by reference at Rule 62-204.800, F.A.C., and changes made pursuant to Rules 62-214.340(1) and (2), F.A.C., to Title V sources subject to emissions limitations or reductions pursuant to 42 USC ss. 7651-7651o;

**SECTION VI. APPENDIX TV-6**  
**TITLE V CONDITIONS**

---

(f) Changes listed at 40 CFR 72.83(a)(11) and (12), adopted and incorporated by reference at Rule 62-204.800, F.A.C., to Title V sources subject to emissions limitations or reductions pursuant to 42 USC ss. 7651-7651o, provided the notification is accompanied by a copy of any EPA determination concerning the similarity of the change to those listed at Rule 62-210.360(1)(c), F.A.C.; and

(g) Any other similar minor administrative change at the source.

(2) Upon receipt of any such notification, the Department shall within 60 days correct the permit and provide a corrected copy to the owner.

(3) After first notifying the owner, the Department shall correct any permit in which it discovers errors of the types listed at Rules 62-210.360(1)(a) and (b), F.A.C., and provide a corrected copy to the owner.

(4) For Title V source permits, other than general permits, a copy of the corrected permit shall be provided to EPA and any approved local air program in the county where the facility or any part of the facility is located.

[Rule 62-210.360, F.A.C.]

**24. Emissions Computation and Reporting.**

(1) **Applicability.** This rule sets forth required methodologies to be used by the owner or operator of a facility for computing actual emissions, baseline actual emissions, and net emissions increase, as defined at Rule 62-210.200, F.A.C., and for computing emissions for purposes of the reporting requirements of subsection 62-210.370(3) and paragraph 62-212.300(1)(c), F.A.C., or of any permit condition that requires emissions be computed in accordance with this rule. This rule is not intended to establish methodologies for determining compliance with the emission limitations of any air permit.

(2) **Computation of Emissions.** For any of the purposes set forth in subsection 62-210.370(1), F.A.C., the owner or operator of a facility shall compute emissions in accordance with the requirements set forth in this subsection.

(a) **Basic Approach.** The owner or operator shall employ, on a pollutant-specific basis, the most accurate of the approaches set forth below to compute the emissions of a pollutant from an emissions unit; provided, however, that nothing in this rule shall be construed to require installation and operation of any continuous emissions monitoring system (CEMS), continuous parameter monitoring system (CPMS), or predictive emissions monitoring system (PEMS) not otherwise required by rule or permit, nor shall anything in this rule be construed to require performance of any stack testing not otherwise required by rule or permit.

1. If the emissions unit is equipped with a CEMS meeting the requirements of paragraph 62-210.370(2)(b), F.A.C., the owner or operator shall use such CEMS to compute the emissions of the pollutant, unless the owner or operator demonstrates to the department that an alternative approach is more accurate because the CEMS represents still-emerging technology.

2. If a CEMS is not available or does not meet the requirements of paragraph 62-210.370(2)(b), F.A.C., but emissions of the pollutant can be computed pursuant to the mass balance methodology of paragraph 62-210.370(2)(c), F.A.C., the owner or operator shall use such methodology, unless the owner or operator demonstrates to the department that an alternative approach is more accurate.

3. If a CEMS is not available or does not meet the requirements of paragraph 62-210.370(2)(b), F.A.C., and emissions cannot be computed pursuant to the mass balance methodology, the owner or operator shall use an emission factor meeting the requirements of paragraph 62-210.370(2)(d), F.A.C., unless the owner or operator demonstrates to the department that an alternative approach is more accurate.

(b) **Continuous Emissions Monitoring System (CEMS).**

1. An owner or operator may use a CEMS to compute emissions of a pollutant for purposes of this rule provided:

a. The CEMS complies with the applicable certification and quality assurance requirements of 40 CFR Part 60, Appendices B and F, or, for an acid rain unit, the certification and quality assurance requirements of 40 CFR Part 75, all adopted by reference at Rule 62-204.800, F.A.C.; or

b. The owner or operator demonstrates that the CEMS otherwise represents the most accurate means of computing emissions for purposes of this rule.

2. Stack gas volumetric flow rates used with the CEMS to compute emissions shall be obtained by the most accurate of the following methods as demonstrated by the owner or operator:

a. A calibrated flowmeter that records data on a continuous basis, if available; or

b. The average flow rate of all valid stack tests conducted during a five-year period encompassing the period over which the emissions are being computed, provided all stack tests used shall represent the same operational and physical configuration of the unit.

## SECTION VI. APPENDIX TV-6

### TITLE V CONDITIONS

3. The owner or operator may use CEMS data in combination with an appropriate f-factor, heat input data, and any other necessary parameters to compute emissions if such method is demonstrated by the owner or operator to be more accurate than using a stack gas volumetric flow rate as set forth at subparagraph 62-210.370(2)(b)2., F.A.C., above.
- (c) Mass Balance Calculations.
1. An owner or operator may use mass balance calculations to compute emissions of a pollutant for purposes of this rule provided the owner or operator:
    - a. Demonstrates a means of validating the content of the pollutant that is contained in or created by all materials or fuels used in or at the emissions unit; and
    - b. Assumes that the emissions unit emits all of the pollutant that is contained in or created by any material or fuel used in or at the emissions unit if it cannot otherwise be accounted for in the process or in the capture and destruction of the pollutant by the unit's air pollution control equipment.
  2. Where the vendor of a raw material or fuel which is used in or at the emissions unit publishes a range of pollutant content from such material or fuel, the owner or operator shall use the highest value of the range to compute the emissions, unless the owner or operator demonstrates using site-specific data that another content within the range is more accurate.
  3. In the case of an emissions unit using coatings or solvents, the owner or operator shall document, through purchase receipts, records and sales receipts, the beginning and ending VOC inventories, the amount of VOC purchased during the computational period, and the amount of VOC disposed of in the liquid phase during such period.
- (d) Emission Factors.
1. An owner or operator may use an emission factor to compute emissions of a pollutant for purposes of this rule provided the emission factor is based on site-specific data such as stack test data, where available, unless the owner or operator demonstrates to the department that an alternative emission factor is more accurate. An owner or operator using site-specific data to derive an emission factor, or set of factors, shall meet the following requirements.
    - a. If stack test data are used, the emission factor shall be based on the average emissions per unit of input, output, or gas volume, whichever is appropriate, of all valid stack tests conducted during at least a five-year period encompassing the period over which the emissions are being computed, provided all stack tests used shall represent the same operational and physical configuration of the unit.
    - b. Multiple emission factors shall be used as necessary to account for variations in emission rate associated with variations in the emissions unit's operating rate or operating conditions during the period over which emissions are computed.
    - c. The owner or operator shall compute emissions by multiplying the appropriate emission factor by the appropriate input, output or gas volume value for the period over which the emissions are computed. The owner or operator shall not compute emissions by converting an emission factor to pounds per hour and then multiplying by hours of operation, unless the owner or operator demonstrates that such computation is the most accurate method available.
  2. If site-specific data are not available to derive an emission factor, the owner or operator may use a published emission factor directly applicable to the process for which emissions are computed. If no directly-applicable emission factor is available, the owner or operator may use a factor based on a similar, but different, process.
- (e) Accounting for Emissions During Periods of Missing Data from CEMS, PEMS, or CPMS. In computing the emissions of a pollutant, the owner or operator shall account for the emissions during periods of missing data from CEMS, PEMS, or CPMS using other site-specific data to generate a reasonable estimate of such emissions.
- (f) Accounting for Emissions During Periods of Startup and Shutdown. In computing the emissions of a pollutant, the owner or operator shall account for the emissions during periods of startup and shutdown of the emissions unit.
- (g) Fugitive Emissions. In computing the emissions of a pollutant from a facility or emissions unit, the owner or operator shall account for the fugitive emissions of the pollutant, to the extent quantifiable, associated with such facility or emissions unit.
- (h) Recordkeeping. The owner or operator shall retain a copy of all records used to compute emissions pursuant to this rule for a period of five years from the date on which such emissions information is submitted to the department for any regulatory purpose.
- (3) Annual Operating Report for Air Pollutant Emitting Facility.
- (a) The Annual Operating Report for Air Pollutant Emitting Facility (DEP Form No. 62-210.900(5)) shall be completed each year.
  - (c) The annual operating report shall be submitted to the appropriate Department of Environmental Protection (DEP) division, district or DEP-approved local air pollution control program office by March 1 of the following year.

## SECTION VI. APPENDIX TV-6

### TITLE V CONDITIONS

(d) Beginning with 2007 annual emissions, emissions shall be computed in accordance with the provisions of Rule 62-210.370(2), F.A.C., for purposes of the annual operating report.

[Rules 62-210.370(1), (2) and (3)(a), (c) & (d), F.A.C.]

25. Circumvention. No person shall circumvent any air pollution control device, or allow the emission of air pollutants without the applicable air pollution control device operating properly.

[Rule 62-210.650, F.A.C.]

26. Forms and Instructions. The forms used by the Department in the stationary source control program are adopted and incorporated by reference in this section. The forms are listed by rule number, which is also the form number, with the subject, title and effective date. Copies of forms may be obtained by writing to the Department of Environmental Protection, Division of Air Resource Management, 2600 Blair Stone Road, Tallahassee, Florida 32399-2400, or by accessing the Division's website at [www.dep.state.fl.us/air](http://www.dep.state.fl.us/air). The requirement of Rule 62-4.050(2), F.A.C., to file application forms in quadruplicate is waived if an air permit application is submitted using the Department's electronic application form.

(1) Application for Air Permit - Long Form, Form and Instructions (Effective 02-02-2006).

(a) Acid Rain Part, Form and Instructions (Effective 06-16-2003).

1. Repowering Extension Plan, Form and Instructions (Effective 07/01/1995).
2. New Unit Exemption, Form and Instructions (Effective 04/16/2001).
3. Retired Unit Exemption, Form and Instructions (Effective 04/16/2001).
4. Phase II NOx Compliance Plan, Form and Instructions (Effective 01/06/1998).
5. Phase II NOx Averaging Plan, Form (Effective 01/06/1998).

(b) Reserved.

(5) Annual Operating Report for Air Pollutant Emitting Facility, Form and Instructions (Effective 02/11/1999).

(7) Application for Transfer of Air Permit – Title V Source, (Effective 04/16/2001).

[Rule 62-210.900, F.A.C.]

#### Chapter 62-213, F.A.C.

27. Responsible Official.

(1) Each Title V source must identify a responsible official on each application for Title V permit, permit revision, and permit renewal. For sources with only one responsible official, this is how the Title V source designates the responsible official.

(2) Each Title V source may designate more than one responsible official, provided a primary responsible official is designated as responsible for the certifications of all other designated responsible officials. Any action taken by the primary responsible official shall take precedence over any action taken by any other designated responsible official.

(3) Any facility initially designating more than one responsible official or changing the list of responsible officials must submit a Responsible Official Notification Form (DEP Form No. 62-213.900(8)) designating all responsible officials for a Title V source, stating which responsible official is the primary responsible official, and providing an effective date for any changes to the list of responsible officials. Each individual listed on the Responsible Official Notification Form must meet the definition of responsible official given at Rule 62-210.200, F.A.C.

(4) A Title V source with only one responsible official shall submit DEP Form No. 62-213.900(8) for a change in responsible official.

(5) No person shall take any action as a responsible official at a Title V source unless designated a responsible official as required by this rule, except that the existing responsible official of any Title V source which has a change in responsible official during the term of the permit and before the effective date of this rule may continue to act as a responsible official until the first submittal of DEP Form No. 62-213.900(8) or the next application for Title V permit, permit revision or permit renewal, whichever comes first.

[Rules 62-213.202(1) thru (5), F.A.C.]

28. Annual Emissions Fee. Each Title V source permitted to operate in Florida must pay between January 15 and March 1 of each year, upon written notice from the Department, an annual emissions fee in an amount determined as set forth in Rule 62-213.205(1), F.A.C.

## SECTION VI. APPENDIX TV-6

### TITLE V CONDITIONS

(1)(g) If the Department has not received the fee by February 15 of the year following the calendar year for which the fee is calculated, the Department will send the primary responsible official of the Title V source a written warning of the consequences for failing to pay the fee by March 1. If the fee is not postmarked by March 1 of the year due, the Department shall impose, in addition to the fee, a penalty of 50 percent of the amount of the fee unpaid plus interest on such amount computed in accordance with Section 220.807, F.S. If the Department determines that a submitted fee was inaccurately calculated, the Department shall either refund to the permittee any amount overpaid or notify the permittee of any amount underpaid. The Department shall not impose a penalty or interest on any amount underpaid, provided that the permittee has timely remitted payment of at least 90 percent of the amount determined to be due and remits full payment within 60 days after receipt of notice of the amount underpaid. The Department shall waive the collection of underpayment and shall not refund overpayment of the fee, if the amount is less than 1 percent of the fee due, up to \$50.00. The Department shall make every effort to provide a timely assessment of the adequacy of the submitted fee. Failure to pay timely any required annual emissions fee, penalty, or interest constitutes grounds for permit revocation pursuant to Rule 62-4.100, F.A.C.

(1)(i) Any documentation of actual hours of operation, actual material or heat input, actual production amount, or actual emissions used to calculate the annual emissions fee shall be retained by the owner for a minimum of five (5) years and shall be made available to the Department upon request.

(1)(j) A completed DEP Form 62-213.900(1), "Major Air Pollution Source Annual Emissions Fee Form", must be submitted by a responsible official with the annual emissions fee.

[Rules 62-213.205, (1)(g), (1)(i) & (1)(j), F.A.C.]

29. Reserved.

30. Reserved.

31. Air Operation Permit Fees. No permit application processing fee, renewal fee, modification fee or amendment fee is required for an operation permit for a Title V source.

[Rule 62-213.205(4), F.A.C.]

32. Permits and Permit Revisions Required. All Title V sources are subject to the permit requirements of Chapter 62-213, F.A.C., except those Title V sources permissible pursuant to Rule 62-213.300, F.A.C., Title V Air General Permits.

(1) No Title V source may operate except in compliance with Chapter 62-213, F.A.C.

(2) Except as provided in Rule 62-213.410, F.A.C., no source with a permit issued under the provisions of Chapter 62-213, F.A.C., shall make any changes in its operation without first applying for and receiving a permit revision if the change meets any of the following:

- (a) Constitutes a modification;
- (b) Violates any applicable requirement;
- (c) Exceeds the allowable emissions of any air pollutant from any unit within the source;
- (d) Contravenes any permit term or condition for monitoring, testing, recordkeeping, reporting or of a compliance certification requirement;
- (e) Requires a case-by-case determination of an emission limitation or other standard or a source specific determination of ambient impacts, or a visibility or increment analysis under the provisions of Chapter 62-212 or 62-296, F.A.C.;
- (f) Violates a permit term or condition which the source has assumed for which there is no corresponding underlying applicable requirement to which the source would otherwise be subject;
- (g) Results in the trading of emissions among units within a source except as specifically authorized pursuant to Rule 62-213.415, F.A.C.;
- (h) Results in the change of location of any relocatable facility identified as a Title V source pursuant to paragraph (a)-(e), (g) or (h) of the definition of "major source of air pollution" at Rule 62-210.200, F.A.C.;
- (i) Constitutes a change at an Acid Rain Source under the provisions of 40 CFR 72.81(a)(1), (2), or (3), (b)(1) or (b)(3), hereby incorporated by reference;
- (j) Constitutes a change in a repowering plan, nitrogen oxides averaging plan, or nitrogen oxides compliance deadline extension at an Acid Rain Source.

[Rules 62-213.400(1) & (2), F.A.C.]

JEA  
Kennedy Generating Station

Air Permit No. 0310047-020-AV  
Facility ID No. 0310047

## SECTION VI. APPENDIX TV-6

### TITLE V CONDITIONS

33. Changes Without Permit Revision. Title V sources having a valid permit issued pursuant to Chapter 62-213, F.A.C., may make the following changes without permit revision, provided that sources shall maintain source logs or records to verify periods of operation:

- (1) Permitted sources may change among those alternative methods of operation;
- (2) A permitted source may implement operating changes, as defined in Rule 62-210.200, F.A.C., after the source submits any forms required by any applicable requirement and provides the Department and EPA with at least 7 days written notice prior to implementation. The source and the Department shall attach each notice to the relevant permit;

(a) The written notice shall include the date on which the change will occur, and a description of the change within the permitted source, the pollutants emitted and any change in emissions, and any term or condition becoming applicable or no longer applicable as a result of the change;

(b) The permit shield described in Rule 62-213.460, F.A.C., shall not apply to such changes;

- (3) Permitted sources may implement changes involving modes of operation only in accordance with Rule 62-213.415, F.A.C.

[Rule 62-213.410, F.A.C.]

34. Immediate Implementation Pending Revision Process.

(1) Those permitted Title V sources making any change that constitutes a modification pursuant to the definition of modification at Rule 62-210.200, F.A.C., but which would not constitute a modification pursuant to 42 USC 7412(a) or to 40 CFR 52.01, 60.2, or 61.15, adopted and incorporated by reference at Rule 62-204.800, F.A.C., may implement such change prior to final issuance of a permit revision, provided the change:

(a) Does not violate any applicable requirement;

(b) Does not contravene any permit term or condition for monitoring, testing, recordkeeping or reporting, or any compliance certification requirement;

(c) Does not require or change a case-by-case determination of an emission limitation or other standard, or a source-specific determination of ambient impacts, or a visibility or increment analysis under the provisions of Chapter 62-212 or 62-296, F.A.C.;

(d) Does not seek to establish or change a permit term or condition for which there is no corresponding underlying applicable requirement and which the source has assumed to avoid an applicable requirement to which the source would otherwise be subject including any federally enforceable emissions cap or federally enforceable alternative emissions limit.

(2) A Title V source may immediately implement such changes after they have been incorporated into the terms and conditions of a new or revised construction permit issued pursuant to Chapter 62-212, F.A.C., and after the source provides to EPA, the Department, each affected state and any approved local air program having geographic jurisdiction over the source, a copy of the source's application for operation permit revision. The Title V source may conform its application for construction permit to include all information required by Rule 62-213.420, F.A.C., in lieu of submitting separate application forms.

(3) The Department shall process the application for operation permit revision in accordance with the provisions of Chapter 62-213, F.A.C., except that the Department shall issue a draft permit revision or a determination to deny the revision within 60 days of receipt of a complete application for operation permit revision or, if the Title V source has submitted a construction permit application conforming to the requirements of Rule 62-213.420, F.A.C., the Department shall issue a draft permit or a determination to deny the revision at the same time the Department issues its determination on issuance or denial of the construction permit application. The Department shall not take final action on the operation permit revision application until all the requirements of Rules 62-213.430(1)(a), (c), (d), and (e), F.A.C., have been complied with.

(4) Pending final action on the operation permit revision application, the source shall implement the changes in accordance with the terms and conditions of the source's new or revised construction permit. If any terms and conditions of the new or revised construction permit have not been complied with prior to the issuance of the draft operation permit revision, the operation permit shall include a compliance plan in accordance with the provisions of Rule 62-213.440(2), F.A.C.

(5) The permit shield described in Rule 62-213.460, F.A.C., shall not apply to such changes until after the Department takes final action to issue the operation permit revision.

(6) If the Department denies the source's application for operation permit revision, the source shall cease implementation of the proposed changes.

[Rule 62-213.412, F.A.C.]

## SECTION VI. APPENDIX TV-6

### TITLE V CONDITIONS

#### 35. Permit Applications.

(1) Duty to Apply. For each Title V source, the owner or operator shall submit a timely and complete permit application in compliance with the requirements of Rules 62-213.420, F.A.C., and Rules 62-4.050(1) through (3), F.A.C.

(a) Timely Application.

3. For purposes of permit renewal, a timely application is one that is submitted in accordance with Rule 62-4.090, F.A.C.

(b) Complete Application.

1. Any applicant for a Title V permit, permit revision or permit renewal must submit an application on DEP Form No. 62-210.900(1), which must include all the information specified by Rule 62-213.420(3), F.A.C., except that an application for permit revision must contain only that information related to the proposed change(s) from the currently effective Title V permit and any other requirements that become applicable at the time of application. The applicant shall include information concerning fugitive emissions and stack emissions in the application. Each application for permit, permit revision or permit renewal shall be certified by a responsible official in accordance with Rule 62-213.420(4), F.A.C.

2. For those applicants submitting initial permit applications pursuant to Rule 62-213.420(1)(a)1., F.A.C., a complete application shall be an application that substantially addresses all the information required by the application form number 62-210.900(1), and such applications shall be deemed complete within sixty days of receipt of a signed and certified application unless the Department notifies the applicant of incompleteness within that time. For all other applicants, the applications shall be deemed complete sixty days after receipt, unless the Department, within sixty days after receipt of a signed application for permit, permit revision or permit renewal, requests additional documentation or information needed to process the application. An applicant making timely and complete application for permit, or timely application for permit renewal as described by Rule 62-4.090(1), F.A.C., shall continue to operate the source under the authority and provisions of any existing valid permit or Florida Electrical Power Plant Siting Certification, and in accordance with applicable requirements of the Acid Rain Program, until the conclusion of proceedings associated with its permit application or until the new permit becomes effective, whichever is later, provided the applicant complies with all the provisions of Rules 62-213.420(1)(b)3. and 4., F.A.C. Failure of the Department to request additional information within sixty days of receipt of a properly signed application shall not impair the Department's ability to request additional information pursuant to Rules 62-213.420(1)(b)3. and 4., F.A.C.

3. For those permit applications submitted pursuant to the provisions of Rule 62-213.420(1)(a)1., F.A.C., the Department shall notify the applicant if the Department becomes aware at any time during processing of the application that the application contains incorrect or incomplete information. The applicant shall submit the corrected or supplementary information to the Department within ninety days unless the applicant has requested and been granted additional time to submit the information. Failure of an applicant to submit corrected or supplementary information requested by the Department within ninety days or such additional time as requested and granted shall render the application incomplete.

4. For all applications other than those addressed at Rule 62-213.420(1)(b)3., F.A.C., should the Department become aware, during processing of any application that the application contains incorrect information, or should the Department become aware, as a result of comment from an affected State, an approved local air program, EPA, or the public that additional information is needed to evaluate the application, the Department shall notify the applicant within 30 days. When an applicant becomes aware that an application contains incorrect or incomplete information, the applicant shall submit the corrected or supplementary information to the Department. If the Department notifies an applicant that corrected or supplementary information is necessary to process the permit, and requests a response, the applicant shall provide the information to the Department within ninety days of the Department request unless the applicant has requested and been granted additional time to submit the information or, the applicant shall, within ninety days, submit a written request that the Department process the application without the information. Failure of an applicant to submit corrected or supplementary information requested by the Department within ninety days, or such additional time as requested and granted, or to demand in writing within ninety days that the application be processed without the information shall render the application incomplete. Nothing in this section shall limit any other remedies available to the Department.

[Rules 62-213.420(1)(a)3. and 62-213.420(1)(b)1., 2., 3. & 4., F.A.C.]

36. Confidential Information. Whenever an applicant submits information under a claim of confidentiality pursuant to Section 403.111, F.S., the applicant shall also submit a copy of all such information and claim directly to EPA. (also, see Condition No. 50.)

[Rule 62-213.420(2), F.A.C.]

## SECTION VI. APPENDIX TV-6

### TITLE V CONDITIONS

37. Standard Application Form and Required Information. Applications shall be submitted under Chapter 62-213, F.A.C., on forms provided by the Department and adopted by reference in Rule 62-210.900(1), F.A.C. The information as described in Rule 62-210.900(1), F.A.C., shall be included for the Title V source and each emissions unit. An application must include information sufficient to determine all applicable requirements for the Title V source and each emissions unit and to evaluate a fee amount pursuant to Rule 62-213.205, F.A.C. [Rule 62-213.420(3), F.A.C.]

38. a. Permit Renewal and Expiration. Permits being renewed are subject to the same requirements that apply to permit issuance at the time of application for renewal. Permit renewal applications shall contain that information identified in Rules 62-210.900(1) and 62-213.420(3), F.A.C. Unless a Title V source submits a timely application for permit renewal in accordance with the requirements of Rule 62-4.090(1), F.A.C., the existing permit shall expire and the source's right to operate shall terminate. No Title V permit will be issued for a new term except through the renewal process.

b. Permit Revision Procedures. Permit revisions shall meet all requirements of Chapter 62-213, F.A.C., including those for content of applications, public participation, review by approved local programs and affected states, and review by EPA, as they apply to permit issuance and permit renewal, except that permit revisions for those activities implemented pursuant to Rule 62-213.412, F.A.C., need not meet the requirements of Rule 62-213.430(1)(b), F.A.C. The Department shall require permit revision in accordance with the provisions of Rule 62-4.080, F.A.C., and 40 CFR 70.7(f), whenever any source becomes subject to any condition listed at 40 CFR 70.7(f)(1), hereby adopted and incorporated by reference. The below requirements from 40 CFR 70.7(f) are adopted and incorporated by reference in Rule 62-213.430(4), F.A.C.:

o 40 CFR 70.7(f): Reopening for Cause. (also, see Condition No. 4.)

(1) This section contains provisions from 40 CFR 70.7(f) that specify the conditions under which a Title V permit shall be reopened prior to the expiration of the permit. A Title V permit shall be reopened and revised under any of the following circumstances:

(i) Additional applicable requirements under the Act become applicable to a major Part 70 source with a remaining permit term of 3 or more years. Such a reopening shall be completed not later than 18 months after promulgation of the applicable requirement. No such reopening is required if the effective date of the requirement is later than the date on which the permit is due to expire, unless the original permit or any of its terms and conditions has been extended pursuant to 40 CFR 70.4(h)(10)(i) or (ii).

(ii) Additional requirements (including excess emissions requirements) become applicable to an affected source under the acid rain program. Upon approved by the Administrator, excess emissions offset plans shall be deemed to be incorporated into the permit.

(iii) The permitting authority or EPA determines that the permit contains a material mistake or that inaccurate statements were made in establishing the emissions standards or other terms or conditions of the permit.

(iv) The Administrator or the permitting authority determines that the permit must be revised or revoked to assure compliance with the applicable requirements.

(2) Proceedings to reopen and issue a permit shall follow the same procedures as apply to initial permit issuance and shall affect only those parts of the permit for which cause to reopen exists. Such reopening shall be made as expeditiously as practicable.

(3) Reopenings under 40 CFR 70.7(f)(1) shall not be initiated before a notice of such intent is provided to the Part 70 source by the permitting authority at least 30 days in advance of the date that the permit is to be reopened, except that the permitting authority may provide a shorter time period in the case of an emergency.

[Rules 62-213.430(3) & (4), F.A.C.; and, 40 CFR 70.7(f)]

39. Insignificant Emissions Units or Pollutant-Emitting Activities.

(a) All requests for determination of insignificant emissions units or activities made pursuant to Rule 62-213.420(3)(n), F.A.C., shall be processed in conjunction with the permit, permit renewal or permit revision application submitted pursuant to Chapter 62-213, F.A.C. Insignificant emissions units or activities shall be approved by the Department consistent with the provisions of Rule 62-4.040(1)(b), F.A.C. Emissions units or activities which are added to a Title V source after issuance of a permit under Chapter 62-213, F.A.C., shall be incorporated into the permit at its next renewal, provided such emissions units or activities have been exempted from the requirement to obtain an air construction permit and also qualify as insignificant pursuant to Rule 62-213.430(6), F.A.C.

(b) An emissions unit or activity shall be considered insignificant if all of the following criteria are met:

1. Such unit or activity would be subject to no unit-specific applicable requirement;



## SECTION VI. APPENDIX TV-6

### TITLE V CONDITIONS

2. Such unit or activity, in combination with other units or activities proposed as insignificant, would not cause the facility to exceed any major source threshold(s) as defined in Rule 62-213.420(3)(c)1., F.A.C., unless it is acknowledged in the permit application that such units or activities would cause the facility to exceed such threshold(s);
3. Such unit or activity would not emit or have the potential to emit:
  - a. 500 pounds per year or more of lead and lead compounds expressed as lead;
  - b. 1,000 pounds per year or more of any hazardous air pollutant;
  - c. 2,500 pounds per year or more of total hazardous air pollutants; or
  - d. 5.0 tons per year or more of any other regulated pollutant.

[Rule 62-213.430(6), F.A.C.]

40. Permit Duration. Permits for sources subject to the Federal Acid Rain Program shall be issued for terms of five years, provided that the initial Acid Rain Part may be issued for a term less than five years where necessary to coordinate the term of such part with the term of a Title V permit to be issued to the source. Operation permits for Title V sources may not be extended as provided in Rule 62-4.080(3), F.A.C., if such extension will result in a permit term greater than five years.

[Rule 62-213.440(1)(a), F.A.C.]

41. Monitoring Information. All records of monitoring information shall specify the date, place, and time of sampling or measurement and the operating conditions at the time of sampling or measurement, the date(s) analyses were performed, the company or entity that performed the analyses, the analytical techniques or methods used, and the results of such analyses.

[Rule 62-213.440(1)(b)2.a., F.A.C.]

42. Retention of Records. Retention of records of all monitoring data and support information shall be for a period of at least 5 years from the date of the monitoring sample, measurement, report, or application. Support information includes all calibration and maintenance records and all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by the permit.

[Rule 62-213.440(1)(b)2.b., F.A.C.]

43. Monitoring Reports. The permittee shall submit reports of any required monitoring at least every six (6) months. All instances of deviations from permit requirements must be clearly identified in such reports.

[Rule 62-213.440(1)(b)3.a., F.A.C.]

44. Deviation from Permit Requirements Reports. The permittee shall report in accordance with the requirements of Rules 62-210.700(6) and 62-4.130, F.A.C., deviations from permit requirements, including those attributable to upset conditions as defined in the permit. Reports shall include the probable cause of such deviations, and any corrective actions or preventive measures taken.

[Rule 62-213.440(1)(b)3.b., F.A.C.]

45. Reports. All reports shall be accompanied by a certification by a responsible official, pursuant to Rule 62-213.420(4), F.A.C.

[Rule 62-213.440(1)(b)3.c., F.A.C.]

46. If any portion of the final permit is invalidated, the remainder of the permit shall remain in effect.

[Rule 62-213.440(1)(d)1., F.A.C.]

47. It shall not be a defense for a permittee in an enforcement action that maintaining compliance with any permit condition would necessitate halting of or reduction of the source activity.

[Rule 62-213.440(1)(d)3., F.A.C.]

48. Any Title V source shall comply with all the terms and conditions of the existing permit until the Department has taken final action on any permit renewal or any requested permit revision, except as provided at Rule 62-213.412(2), F.A.C.

[Rule 62-213.440(1)(d)4., F.A.C.]

## SECTION VI. APPENDIX TV-6

### TITLE V CONDITIONS

49. A situation arising from sudden and unforeseeable events beyond the control of the source which causes an exceedance of a technology-based emissions limitation because of unavoidable increases in emissions attributable to the situation and which requires immediate corrective action to restore normal operation, shall be an affirmative defense to an enforcement action in accordance with the provisions and requirements of 40 CFR 70.6(g)(2) and (3), hereby adopted and incorporated by reference.

[Rule 62-213.440(1)(d)5., F.A.C.]

50. Confidentiality Claims. Any permittee may claim confidentiality of any data or other information by complying with Rule 62-213.420(2), F.A.C. (also, see Condition No. 36.)

[Rule 62-213.440(1)(d)6., F.A.C.]

51. Statement of Compliance. (a)2. The permittee shall submit a Statement of Compliance with all terms and conditions of the permit that includes all the provisions of 40 CFR 70.6(c)(5)(iii), incorporated by reference at Rule 62-204.800, F.A.C., using DEP Form No. 62-213.900(7). Such statement shall be accompanied by a certification in accordance with Rule 62-213.420(4), F.A.C., for Title V requirements and with Rule 62-214.350, F.A.C., for Acid Rain requirements. Such statements shall be submitted (postmarked) to the Department and EPA:

a. Annually, within 60 days after the end of each calendar year during which the Title V permit was effective, or more frequently if specified by Rule 62-213.440(2), F.A.C., or by any other applicable requirement; and

b. Within 60 days after submittal of a written agreement for transfer of responsibility as required pursuant to 40 CFR 70.7(d)(1)(iv), adopted and incorporated by reference at Rule 62-204.800, F.A.C., or within 60 days after permanent shutdown of a facility permitted under Chapter 62-213, F.A.C.; provided that, in either such case, the reporting period shall be the portion of the calendar year the permit was effective up to the date of transfer of responsibility or permanent facility shutdown, as applicable.

3. In lieu of individually identifying all applicable requirements and specifying times of compliance with, non-compliance with, and deviation from each, the responsible official may use DEP Form No. 62-213.900(7) as such statement of compliance so long as the responsible official identifies all reportable deviations from and all instances of non-compliance with any applicable requirements and includes all information required by the federal regulation relating to each reportable deviation and instance of non-compliance.

(b) The responsible official may treat compliance with all other applicable requirements as a surrogate for compliance with Rule 62-296.320(2), Objectionable Odor Prohibited.

[Rules 62-213.440(3)(a)2. & 3. and (b), F.A.C.]

52. Permit Shield. Except as provided in Chapter 62-213, F.A.C., compliance with the terms and conditions of a permit issued pursuant to Chapter 62-213, F.A.C., shall, as of the effective date of the permit, be deemed compliance with any applicable requirements in effect, provided that the source included such applicable requirements in the permit application. Nothing in Rule 62-213.460, F.A.C., or in any permit shall alter or affect the ability of EPA or the Department to deal with an emergency, the liability of an owner or operator of a source for any violation of applicable requirements prior to or at the time of permit issuance, or the requirements of the Federal Acid Rain Program.

[Rule 62-213.460, F.A.C.]

53. Forms and Instructions. The forms used by the Department in the Title V source operation program are adopted and incorporated by reference in Rule 62-213.900, F.A.C. The form is listed by rule number, which is also the form number, and with the subject, title, and effective date. Copies of forms may be obtained by writing to the Department of Environmental Protection, Division of Air Resource Management, 2600 Blair Stone Road, Tallahassee, Florida 32399-2400, or by contacting the appropriate permitting authority.

(1) Major Air Pollution Source Annual Emissions Fee Form. (Effective 01/03/2001)

(7) Statement of Compliance Form. (Effective 06/02/2002)

(8) Responsible Official Notification Form. (Effective 06/02/2002)

[Rule 62-213.900, F.A.C.: Forms (1), (7) and (8)]

Chapter 62-256, F.A.C.

## SECTION VI. APPENDIX TV-6

### TITLE V CONDITIONS

54. **Not federally enforceable.** Open Burning. This permit does not authorize any open burning nor does it constitute any waiver of the requirements of Chapter 62-256, F.A.C. Source shall comply with Chapter 62-256, F.A.C., for any open burning at the source.  
[Chapter 62-256, F.A.C.]

#### Chapter 62-281, F.A.C.

55. Refrigerant Requirements. Any facility having refrigeration equipment, including air conditioning equipment, which uses a Class I or II substance (listed at 40 CFR 82, Subpart A, Appendices A and B), and any facility which maintains, services, or repairs motor vehicles using a Class I or Class II substance as refrigerant must comply with all requirements of 40 CFR 82, Subparts B and F, and with Rule 62-281.100, F.A.C. Those requirements include the following restrictions:

- (1) Any facility having any refrigeration equipment normally containing 50 (fifty) pounds of refrigerant, or more, must keep servicing records documenting the date and type of all service and the quantity of any refrigerant added pursuant to 40 CFR 82.166;
  - (2) No person repairing or servicing a motor vehicle may perform any service on a motor vehicle air conditioner (MVAC) involving the refrigerant for such air conditioner unless the person has been properly trained and certified as provided at 40 CFR 82.34 and 40 CFR 82.40, and properly uses equipment approved pursuant to 40 CFR 82.36 and 40 CFR 82.38, and complies with 40 CFR 82.42;
  - (3) No person may sell or distribute, or offer for sale or distribution, any substance listed as a Class I or Class II substance at 40 CFR 82, Subpart A, Appendices A and B, except in compliance with Rule 62-281.100, F.A.C., and 40 CFR 82.34(b), 40 CFR 82.42, and/or 40 CFR 82.166;
  - (4) No person maintaining, servicing, repairing, or disposing of appliances may knowingly vent or otherwise release into the atmosphere any Class I or Class II substance used as a refrigerant in such equipment and no other person may open appliances (except MVACs as defined at 40 CFR 82.152) for service, maintenance or repair unless the person has been properly trained and certified pursuant to 40 CFR 82.161 and unless the person uses equipment certified for that type of appliance pursuant to 40 CFR 82.158 and unless the person observes the practices set forth at 40 CFR 82.156 and 40 CFR 82.166;
  - (5) No person may dispose of appliances (except small appliances, as defined at 40 CFR 82.152) without using equipment certified for that type of appliance pursuant to 40 CFR 82.158 and without observing the practices set forth at 40 CFR 82.156 and 40 CFR 82.166;
  - (6) No person may recover refrigerant from small appliances, MVACs and MVAC-like appliances (as defined at 40 CFR 82.152), except in compliance with the requirements of 40 CFR 82, Subpart F.
- [40 CFR 82; and, Chapter 62-281, F.A.C. (**Chapter 62-281, F.A.C., is not federally enforceable**)]

#### Chapter 62-296, F.A.C.

56. Industrial, Commercial, and Municipal Open Burning Prohibited. Open burning in connection with industrial, commercial, or municipal operations is prohibited, except when:

- (a) Open burning is determined by the Department to be the only feasible method of operation and is authorized by an air permit issued pursuant to Chapter 62-210 or 62-213, F.A.C.; or
- (b) An emergency exists which requires immediate action to protect human health and safety; or
- (c) A county or municipality would use a portable air curtain incinerator to burn yard trash generated by a hurricane, tornado, fire or other disaster and the air curtain incinerator would otherwise be operated in accordance with the permitting exemption criteria of Rule 62-210.300(3), F.A.C.

[Rule 62-296.320(3), F.A.C.]

57. Unconfined Emissions of Particulate Matter.

(4)(c)1. No person shall cause, let, permit, suffer or allow the emissions of unconfined particulate matter from any activity, including vehicular movement; transportation of materials; construction; alteration; demolition or wrecking; or industrially related activities such as loading, unloading, storing or handling; without taking reasonable precautions to prevent such emissions.

3. Reasonable precautions include the following:
  - a. Paving and maintenance of roads, parking areas and yards.

**SECTION VI. APPENDIX TV-6**

**TITLE V CONDITIONS**

- b. Application of water or chemicals to control emissions from such activities as demolition of buildings, grading roads, construction, and land clearing.
- c. Application of asphalt, water, oil, chemicals or other dust suppressants to unpaved roads, yards, open stock piles and similar activities.
- d. Removal of particulate matter from roads and other paved areas under the control of the owner or operator of the facility to prevent reentrainment, and from buildings or work areas to prevent particulate from becoming airborne.
- e. Landscaping or planting of vegetation.
- f. Use of hoods, fans, filters, and similar equipment to contain, capture and/or vent particulate matter.
- g. Confining abrasive blasting where possible.
- h. Enclosure or covering of conveyor systems.

4. In determining what constitutes reasonable precautions for a particular facility, the Department shall consider the cost of the control technique or work practice, the environmental impacts of the technique or practice, and the degree of reduction of emissions expected from a particular technique or practice.

[Rules 62-296.320(4)(c)1., 3., & 4. F.A.C.]

SECTION VI. APPENDIX JEPB

RULE 2 CONDITIONS

JACKSONVILLE ENVIRONMENTAL PROTECTION BOARD

RULE 2

AIR POLLUTION CONTROL

Effective 03/18/85

Amended 12/15/85

Amended 06/18/86

Amended 06/15/88

Amended 10/27/88

Amended 12/20/88

Amended 07/09/90

Amended 10/22/92

Repealed, renumbered and readopted 01/10/93

Amended 12/19/94, Effective 01/11/95

Amended 09/11/95, Effective 10/05/95

Amended 11/12/96, Effective 12/16/96

Amended 06/08/98, Effective 07/02/98

Amended 11/08/99, Effective 12/05/99

Amended 09/11/00, Effective 10/08/00

Amended 08/13/01, Effective 09/06/01

Amended 08/12/02, Effective 09/04/02

Amended 11/10/03, Effective 12/10/03

Amended 10/11/04, Effective 11/03/04

Amended 06/13/05, Effective 07/04/05

Amended 9/11/06, Effective 10/03/06

**SECTION VI. APPENDIX JEPB**

**RULE 2 CONDITIONS**

**RULE OF THE  
JACKSONVILLE ENVIRONMENTAL PROTECTION BOARD  
RULE 2  
AIR POLLUTION CONTROL**

**INDEX**

**PART I - GENERAL PROVISIONS**

- 2.101 Definitions
- 2.102 Authority and Intent
- 2.103 Severability
- 2.104 Registration and Reports
- 2.105 Maintenance of Pollution Control Devices
- 2.106 General Restrictions
- 2.107 Air Pollution Prohibited
- 2.108 Enforcement
- 2.109 Investigations - Right of Entry
- 2.110 Penalties and Injunctive Relief

**PART II - AIR POLLUTION CONTROL - GENERAL PROVISIONS**

- 2.201 Adopts 62-204 FAC by reference

**PART III - STATIONARY SOURCES - GENERAL REQUIREMENTS**

- 2.301 Adopts 62-210 FAC by reference

**PART IV - STATIONARY SOURCES - PRECONSTRUCTION REVIEW**

- 2.401 Adopts 62-212 FAC by reference

**PART V - OPERATION PERMITS FOR MAJOR SOURCES OF AIR POLLUTION**

- 2.501 Adopts 62-213 FAC by reference

**PART VI - GASOLINE VAPOR CONTROL**

- 2.601 Adopts 62-252 FAC by reference
- 2.602 Expanded Stage I Controls in Duval County

**PART VII - OPEN BURNING AND FROST PROTECTION FIRES**

- 2.701 Open Burning and Frost Protection Fires

**PART VIII - AMBIENT AIR QUALITY STANDARDS**

- 2.801 Ambient Air Quality Standard for Aggregate Reduced Sulfur (ARS)

**PART IX - AIR POLLUTION EPISODES**

- 2.901 Air Pollution Episodes - Local Rules

**PART X - STATIONARY SOURCES EMISSION STANDARDS**

- 2.1001 Adopts 62-296 FAC by reference

**PART XI - STATIONARY SOURCES - EMISSIONS MONITORING**

- 2.1101 Adopts 62-297 FAC by reference

**SECTION VI. APPENDIX JEPB**

---

**RULE 2 CONDITIONS**

**PART XII - AIR POLLUTION NUISANCE RULES**

- 2.1201 General Standard for Volatile Organic Compounds
- 2.1202 Emissions from Ships and Locomotives
- 2.1203 Air Pollution Nuisances

**SECTION VI. APPENDIX JEPB**

---

**RULE 2 CONDITIONS**

**PART XIII - PERMITS - GENERAL PROVISIONS**

2.1301 Adopts 62-4 FAC by reference

2.1302 Adopts 120.57 FS and 28-106.111(2) FAC, 28-106.201 FAC, 28-106.301 FAC, and  
62-110.106 FAC by reference



**SECTION VI. APPENDIX JEPB**

**RULE 2 CONDITIONS**

**TRACKING TABLE FOR THE AMENDMENT OF CURRENT RULE 2**

Current Rule 2 Sections	Amended Rule 2 Sections
Part I - General Provisions 2.101 2.102 2.103 2.104 2.105 2.106 2.107 2.108 2.109 2.110	Part I - General Provisions NO CHANGE
Part II 2.201 (Adopts 62-204 FAC)	Part II 2.201 AMENDED (Adopts 62-204 FAC)
Part III 2.301 (Adopts 62-210 FAC)	Part III 2.301 AMENDED (Adopts 62-210 FAC)
Part IV 2.401 (Adopts 62-212 FAC)	Part IV 2.401 AMENDED (Adopts 62-212)
Part V 2.501 (Adopts 62-213 FAC)	Part V 2.501 (Adopts 62-213) NO CHANGE
Part VI 2.601 (Adopts 62-252 FAC)	Part VI 2.601 NO CHANGE
2.602	2.602 NO CHANGE
Part VII 2.701 (Adopts 62-256 FAC)	Part VII 2.701 NO CHANGE (Adopts 62-256 FAC in its entirety instead of by reference)
Part VIII 2.801 Ambient Air Quality Standards for Aggregate	Part VIII 2.801 NO CHANGE

JEA  
Kennedy Generating Station

Air Permit No. 0310047-020-AV  
Facility ID No. 0310047

**SECTION VI. APPENDIX JEPB**  
**RULE 2 CONDITIONS**

---

Reduced Sulfur	
Part IX 2.901 Air Pollution Episodes - Local Rules	Part IX 2.901 NO CHANGE

**SECTION VI. APPENDIX JEPB**  
**RULE 2 CONDITIONS**

---

Part X 2.1001 (Adopts 62-296 FAC)	Part X 2.1001 AMENDED (Adopts 62-296 FAC)	
Part XI 2.1101 (Adopts 62-297 FAC)	Part XI 2.1101 (Adopts 62-297 FAC)	NO CHANGE
Part XII 2.1201 2.1202 2.1203	Part XII 2.1201 2.1202 2.1203	NO CHANGE NO CHANGE NO CHANGE
Part XIII 2.1301 (Adopts 62-4) 2.1302 (Adopts 120.57 FS, 28-106.111(2) FAC, 28-106.201 FAC, 28-106.301 FAC, and 62-110.106 FAC)	Part XIII 2.1301 2.1302	NO CHANGE NO CHANGE

**SECTION VI. APPENDIX JEPB**

**RULE 2 CONDITIONS**

**RULES OF THE  
JACKSONVILLE ENVIRONMENTAL PROTECTION BOARD**

**JACKSONVILLE ENVIRONMENTAL PROTECTION BOARD  
RULE 2**

**AIR POLLUTION CONTROL**

**PART I  
GENERAL PROVISIONS**

**2.101 Definitions**

In this rule, unless the context otherwise requires:

- A. The definitions included in Chapters 62-4, 62-204, 62-210, 62-252, and 62-256, Florida Administrative Code, are adopted and incorporated in this rule by reference, except that:
  - 1. the word Department means the Environmental Resource Management Department.
  - 2. the word Secretary means the Director of the Environmental Resource Management Department.
- B. Board means the Jacksonville Environmental Protection Board.
- C. Department means the Environmental Resource Management Department, City of Jacksonville.
- D. Division means the Environmental Quality Division of the Environmental Resource Management Department.

[History: Effective 3/18/85, Amended 1/10/93, Amended 12/19/94, Amended 9/11/95, Amended 11/12/96, Amended 6/8/98, Amended 10/11/04]

**2.102 Authority and Intent**

The Jacksonville Environmental Protection Board adopts these rules as the City's standards with respect to air pollution control. The specific Authority for adopting these rules is found in Section 100.201, Section 362.104(c) and Section 73.102, Ordinance Code. The law implemented is Chapter 362, Ordinance Code. The Board intends that where any locally more stringent provision conflicts with a provision of the Florida Administrative Code adopted by reference, the locally more stringent provision shall apply.

[History: Formerly EPB Rule 2 Preface; Effective 3/18/85; Amended and renumbered 1/10/93]

**2.103 Severability**

The provisions of these air pollution control rules are severable. If one or more of the provisions should be invalidated, the Board intends that the other portions should become effective or remain in effect.

[History: Formerly EPB 2.104, Effective 3/18/85; Renumbered 1/10/93]

**2.104 Registration and Reports**

A person engaging in an activity or operation which is or may be a source of air pollution shall register with the Department and file reports with the Department at or within times and as required by the Board or the Department.

[History: Formerly S.362.103(a), City Ordinance Code; EPB 2.105; Effective 3/18/85; Amended and renumbered 1/10/93]

**SECTION VI. APPENDIX JEPB**

**RULE 2 CONDITIONS**

---

**2.105 Maintenance of Pollution Control Devices**

Air pollution control devices and systems shall be properly and consistently maintained in order to maintain emissions in compliance with the standards of the Board.

[History: Formerly S.362.103, City Ordinance Code; EPB 2.108; Effective 3/18/85; renumbered 1/10/93]

**2.106 General Restrictions**

No plant or source shall operate at capacities which exceed the limits of operation of control devices or exceed the capability of the plant or control devices to maintain the air pollution emissions within the limitations imposed by this rule or by permit conditions.

[History: Formerly S.362.106, City Ordinance Code; EPB 2.109; Effective 3/18/85; renumbered 1/10/93]

**2.107 Air Pollution Prohibited**

No person shall cause or permit the discharge or emission of air pollutants from an installation in quantities prohibited by law, by the rules of the State Department of Environmental Protection or by the rules of the Board.

[History: Formerly S.362.201, City Ordinance Code; EPB 2.201; Effective 3/18/85; renumbered 1/10/93, Amended 12/19/94]

**2.108 Enforcement**

This rule shall be enforced by the Department in accordance with the provisions of Chapters 360 and 362, Ordinance Code.

[History: New, Effective 1/10/93]

**2.109 Investigations - Right of Entry**

Inspections and investigations made to determine compliance with the provisions of this rule shall be made in accordance with the provisions of Section 360.109; Ordinance Code, and Board Rule 1, Part VIII.

[History: New, Effective 1/10/93]

**2.110 Penalties and Injunctive Relief**

Violations of this rule shall be punishable by civil penalties specified in Chapter 360, Part 7, Section 362.110, Ordinance Code; and to injunctive relief as provided in Section 360.407, Ordinance Code.

[History: New, Effective 1/10/93]

**SECTION VI. APPENDIX JEPB**

**RULE 2 CONDITIONS**

**PART II**

**AIR POLLUTION CONTROL - GENERAL PROVISIONS**

**2.201**

Chapter 62-204, Florida Administrative Code, is adopted and incorporated in this rule by reference as the City's general provisions for air pollution control.

[History: Effective 1/10/93, Amended 12/19/94, Amended 9/11/95, Amended 11/12/96, Amended 6/08/98, Amended 11/08/99, Amended 9/11/00, Amended 08/13/01, Amended 08/12/02, Amended 11/10/03, Amended 10/11/04, Amended 6/13/05, Amended, 9/11/06.] Note: The rules covered by this part were previously adopted by reference under former EPB rule sections 2.601, 2.801, 2.901 and 2.902.

**PART III**

**STATIONARY SOURCES - GENERAL REQUIREMENTS**

**2.301**

Chapter 62-210, Florida Administrative Code, is adopted and incorporated in this rule by reference as the City's general requirements for stationary sources.

[History: Effective 1/10/93, Amended 12/19/94, Amended 9/11/95, Amended and renumbered 11/12/96, Amended 6/08/98, Amended 11/08/99, Amended 08/13/01, Amended 08/12/02, Amended 11/10/03, Amended 6/13/05, Amended 9/11/06.] Note: The rules covered by this part were previously adopted by reference under former EPB rule section 2.201.

**PART IV**

**STATIONARY SOURCES - PRECONSTRUCTION REVIEW**

**2.401**

Chapter 62-212, Florida Administrative Code, is adopted and incorporated in this rule by reference as the City's preconstruction review requirements for stationary sources.

[History: Effective 1/10/93, Amended 12/19/94, Amended 9/11/95, Amended and renumbered 11/12/96, Amended 6/08/98, Amended 9/11/00, Amended 9/11/06.] Note: The rules covered by this part were previously adopted by reference under former EPB rule section 2.301.

**PART V**

**OPERATION PERMITS FOR MAJOR SOURCES OF AIR POLLUTION**

**2.501**

Chapter 62-213, Florida Administrative Code, is adopted and incorporated in this rule by reference as the City's operation permit requirements for major sources of air pollution.

[History: New, Effective 12/19/94, Amended 9/11/95, Amended and Renumbered 11/12/96, Amended 6/08/98, Amended 11/08/99, Amended 08/13/01, Amended 08/12/02, Amended 11/10/03.] Note: The rules covered by this part were previously adopted by reference under former EPB rule section 2.1202.

**SECTION VI. APPENDIX JEPB**  
**RULE 2 CONDITIONS**

---

**SECTION VI. APPENDIX JEPB  
RULE 2 CONDITIONS**

**PART VI  
GASOLINE VAPOR CONTROL**

**2.601**

Chapter 62-252, Florida Administrative Code, is adopted and incorporated in this rule by reference as the City's gasoline vapor control standards.

[History: Effective 1/10/93, Amended 12/19/94, Amended and renumbered 11/12/96] Note: The rules covered by this part were previously adopted by reference under former EPB rule section 2.401.

**2.602 Expanded Stage I Controls in Duval County**

A. The applicability criteria of Paragraph 62-252.300(1), FAC notwithstanding, all gasoline dispensing facilities in Duval County regardless of monthly throughput, shall be subject to emission limiting standards and control technology requirements as set forth in 62-252.300(2), FAC except that gasoline storage tanks with less than 1000 gallons capacity are exempt from this requirement.

B. Gasoline dispensing facilities in existence in Duval County upon the effective date of this rule, and not previously subject to 62-252.300, FAC, shall install Stage I vapor recovery control technology at the time of any vehicular fuel petroleum storage tank system replacement or upgrade, other than spill containment as shown in Table UST, Section 62-761.510 (See Appendix A). Gasoline dispensing facilities built after the effective date of this rule shall be subject to Section 2.402 A. upon construction.

C. Gasoline tank trucks or trailers used to deliver gasoline to any facility subject to section 2.602 must be equipped as required in Section 62-252.300, FAC.

D. Stage I vapor recovery control technology required by this rule shall conform with equipment specifications pursuant to "Design Criteria for Stage I Vapor Control Systems at Gasoline Service Stations." United States Environmental Protection Agency, Research Triangle Park, NC, November, 1975. Copies are available for review in the offices of the Environmental Quality Division, Environmental Resource Management Department, City of Jacksonville.

[History: Formerly EPB 2.207 B, Effective 10/22/92; Amended and Renumbered 1/10/93, Amended 12/19/94, Amended 9/11/95, Amended and renumbered 11/12/96 , Amended 11/08/99] Note: The rules covered by this part were previously adopted by reference under former EPB rule section 2.402.

CHAPTER 62-761.510 TABLE UST						Appendix A
Year Tank or Integral Piping Installed	1989	1992	1995	1998	2004	2009
+Before 1970	O	B		ACFL	D	E
+1970 - 1975		SBL		ACF	D	E
+1976 - 1980		B	SL	ACF	D	E
+1981 - 09/01/84		B		ACFL	D	E
+09/02/84	B		ACFL	D	E	
+Other*	B		ACFL	D	E	

Key to Table UST

\* = All systems with a capacity between 110 gallons and 550 gallons, all marine fueling facilities as defined in Section 376.031, F.S., and those systems of greater than 550 gallon capacity that use less than 1,000 gallons per month or 10,000 gallons per year.



**SECTION VI. APPENDIX JEPB**

**RULE 2 CONDITIONS**

A =

- (1) Small diameter piping that was protected from corrosion by June 30, 1992, shall have:
  - (a) For pressurized piping, line leak detectors with automatic shutoff, or flow restriction in accordance with Rule 62-761.640(3)(d), F.A.C.; or
  - (b) For suction integral piping:
    1. Secondary containment in accordance with Rule 62-761.500(1)(e), F.A.C.;
    2. A single check valve installed in accordance with Rule 62-761.610(4)(a)3., F.A.C.;
    3. An annual line tightness test in accordance with Rule 62-761.610(4)(a)1., F.A.C.; or
    4. External monthly monitoring or release detection in accordance with Rule 62-761.610(4)(a)1.b., F.A.C.
- (2) Bulk product piping in contact with soil shall be upgraded with secondary containment unless the piping is:
  - (a) Constructed of corrosion resistant materials or upgraded with cathodic protection; and
  - (b) Tested on an annual basis in accordance with API RP 1110, ASME B31.4, or an equivalent method approved by the Department in accordance with Rule 62-761.850, F.A.C.

B = Vehicular fuel petroleum storage tank systems shall be upgraded with spill containment.

C = Secondary containment in accordance with Rule 62-761.500(1)(e), F.A.C., shall be required for the following:

- (1) Concrete storage tanks;
- (2) Hazardous substance storage tank systems; and
- (3) For pollutant storage tank systems, the storage tank or small diameter piping not protected from corrosion by June 30, 1992.

D =

- (1) Secondary containment shall be installed for small diameter piping extending over surface waters.
- (2) Secondary containment for remote fill-pipes associated with Category-A and Category-B systems.

E = Pollutant storage tanks and small diameter piping protected from corrosion on or before June 30, 1992, and all manifolded piping, shall be upgraded with secondary containment.

F =

- (1) Storage tank systems, excluding vehicular fuel petroleum storage tank systems, shall be upgraded with spill containment, dispenser liners (as applicable), and overfill protection.
- (2) Unless contained within secondary containment, swing-joints and flex-connectors that are not protected from corrosion shall be protected from corrosion. Facilities that have pressurized small diameter piping and that have not met the foregoing standard on or before July 13, 1998 shall protect the submersible turbine pump from corrosion or provide corrosion protection for the submersible turbine pump if the pump is not installed within secondary containment. Corrosion protection is not required for the submersible turbine pump riser.

L =

- (1) Category-A USTs and their integral piping systems that contain vehicular fuel, and that are not protected from corrosion, shall have secondary containment, or be upgraded with secondary containment in accordance with Rule 62-761.500, F.A.C.
- (2) Dispenser liners and overfill protection equipment shall be installed at UST Category-A systems containing vehicular fuel.

O = UST Category-A vehicular fuel storage tank systems subject to Chapter 17-61, F.A.C.,(1984), shall be retrofitted for corrosion protection.

S = Secondary containment for storage tanks and integral piping not protected from corrosion.

SECTION VI. APPENDIX JEPB

RULE 2 CONDITIONS

PART VII

OPEN BURNING AND FROST PROTECTION FIRES

2.701

A. Declaration and Intent.

(1) The Department finds and declares that the open burning of materials outdoors and the use of outdoor heating devices result in or contribute to air pollution. The Department further finds that regulation of open burning and outdoor heating devices will reduce air pollution significantly.

(2) It is the intent of the Department to require that open burning be conducted in a manner, under conditions, and within certain periods that will reduce or eliminate the deleterious and noisome effect of air pollution caused by open burning.

(3) It is the intent of the Department to phase out, over a period of years, open burning of certain unapproved material and heating devices which are presently being used for crop protection against frost and freezing and to require that only materials and heating devices which emit a minimum of air pollution be used.

(4) The Department finds that certain fuels release less air pollution when burned than do other fuels. Therefore, the Department intends to approve fuels which contribute only a minimum of air pollution and allow their use for cold or frost protection and to phase out, over a period of years, all fuels which do not meet Department specifications.

(5) The Department finds that there are several alternative disposal methods for pesticide containers that are environmentally preferable to open burning. It is the intent of the department that individuals seeking to dispose of pesticide containers as provided in this chapter consider recycling, landfilling, on-site burial, and incineration prior to engaging in open burning.

B. Definitions.

The following words, phrases, or terms when used in this chapter shall, unless the content otherwise indicates, have the following meanings:

(1) "Air curtain incinerator" is a portable or stationary combustion device that directs a plane of high velocity forced draft air through a manifold head into a pit with vertical walls in such a manner as to maintain a curtain of air over the surface of the pit and a recirculating motion of air under the curtain. An air curtain incinerator is controlled burning as defined in Florida Administrative Code Rule 62-701.300(3).

(2) "Air pollution" is the presence in the outdoor atmosphere of the state of any one or more substances or contaminants in quantities which are or may be potentially harmful or injurious to human health or welfare, animal or plant life, or property, or unreasonably interfere with the enjoyment of life or property, including outdoor recreation.

(3) "Air pollution episode" is any occurrence of elevated levels of pollutants in the atmosphere which require hasty and unusual abatement action.

(4) "Approved fuel" shall mean fuel approved by the Department to emit or release a minimum of pollutants when burned.

(5) "Clean dry wood" means wood (including lighter pine), lumber or tree and shrub trunks, branches, and limbs which are free of paint, pentachlorophenol, creosote, tar, asphalt, or other wood preservatives and which when burned does not emit excessive visible emissions.

(6) "Department" is the Environmental Resource Management Department.

(7) "Department air stagnation advisory" is a temporary prohibition of open burning activities by the Department that is based upon a Department forecast of a stagnant atmospheric meteorological condition that does not allow the dispersion of air pollutants.

(8) "Excessive visible emissions" are air pollutants emitted in such quantity as to obscure an observer's view to a degree equal to or greater than Number Two (or 40% opacity) on the Ringelmann Smoke Chart as published in the U.S. Bureau of Mines Information Circular No. 7718.

## SECTION VI. APPENDIX JEPB

### RULE 2 CONDITIONS

- (9) "Extinguished" means the absence of any visible flames, smoke or emissions.
- (10) "Garbage" means all kitchen and table food waste, animal or vegetative waste that is attendant with or results from the storage, packaging, preparation, cooking or handling of food materials.
- (11) "Group I containers" means combustible containers which formerly contained organic or metallo-organic pesticides, except organic mercury, lead, cadmium, or arsenic compounds.
- (12) "Land clearing debris" is uprooted or cleared vegetation resulting from a land clearing operation and does not include yard trash.
- (13) "Land clearing operation" means the uprooting clearing of vegetation in connection with construction for buildings, rights-of-way, residential, commercial, or industrial development, or the initial clearing of vegetation to enhance property value; but does not include the maintenance burning of yard trash resulting from fallen limbs, branches, or leaves, or any other routine property clean-up activities.
- (14) "National Weather Service air stagnation advisory" is an advisory issued by the National Weather Service to caution local and regional agencies of meteorological conditions which are conducive to poor dispersion and that are expected to persist for at least 36 hours.
- (15) "Non-rural land clearing" is any land clearing operation that is conducted in urban or residential areas, incorporated or unincorporated cities or towns, or in any nonrural areas as designated by the Department and shall not include any land clearing operation that is associated with country, livestock or with agricultural activities.
- (16) "Nuisance" means any open burning activity which is potentially harmful or injurious to human health or property or which is annoying or offensive to occupants of three or more occupied residences.
- (17) "Open burning" means the burning of any matter in such a manner that the products of combustion resulting from the burning are emitted directly into the outdoor atmosphere without passing through a stack or chimney.
- (18) "Open field" means any location in a well ventilated cleared area that is at least 200 feet in all directions from any wooded area or occupied building(s), and 100 feet from any public road.
- (19) "Outdoor heating device" means any apparatus, machine, equipment, or other contrivance in which is burned any type of fuel capable of producing air pollution, used outdoors for the purpose of giving protection from cold or frosts.
- (20) "Pesticide" means any substance or mixture substances intended for preventing, destroying, repelling, or mitigating any insects, rodents, nematodes, fungi, weeds, or other forms of plant or animal life or viruses, except viruses or fungi on or in living man or other animals, which the Department of Agriculture and Consumer Services shall declare to be a pest, and any substance or mixture of substances intended for use as a plant regulator, defoliant, or desiccant.
- (21) "Residential land clearing" is a land clearing operation that is conducted by the homeowner or an individual contracted by the homeowner of an existing residential dwelling of not more than two family units for the purpose of initially clearing vegetation on the property.
- (22) "Sunset" is official sunset as set forth by the U.S. Naval Observatory (tables are available at National Weather Service offices).
- (23) "Trash" means construction or demolition debris, and other debris such as paper, cardboard, cloth, glass, street sweepings, vehicle tires and other like matter.
- (24) "Waste pesticide containers" means any containers made of combustible materials, including but not limited to paper, plastic, or burlap, which formerly contained pesticides and which the manufacturer or formulator provided as an end user conveyance for the specified product.
- (25) "Yard trash" means vegetative matter resulting from landscaping and yard maintenance operations and includes materials such as tree and shrub trimmings, grass clippings, palm fronds, trees and tree stumps.
- C. Prohibitions.
- (1) Any open burning not specifically allowed by this chapter or by Florida Administrative Code Chapter 5I-2 is prohibited. No person shall ignite, cause to be ignited, permit to be ignited, any material which will result in any prohibited open burning as defined in this section; nor shall any person suffer, allow, burn,

## SECTION VI. APPENDIX JEPB

### RULE 2 CONDITIONS

conduct or maintain any prohibited open burning. The Division of Forestry or any authorized fire control agency empowered by law or ordinance to extinguish unlawful burning may extinguish or cause to be extinguished, any fire that is unauthorized or does not comply with this rule. Any person responsible for unlawful open burning shall bear any applicable costs involved in extinguishing the fire.

(2) No person shall use or operate any outdoor heating device or burn any unapproved fuel for cold or frost protection except as provided in this chapter.

(3) The open burning of tires, rubber material, Bunker C residual oil, asphalt, roofing material, tar, railroad cross ties, other creosoted lumber, plastics except for polyethelene black plastic mulch used in agriculture, garbage, or trash other than yard trash and household paper products is prohibited. Open burning of yard trash and household paper products is prohibited except as provided in Florida Administrative Code Rule 62-256.700(1). Open burning of waste pesticide containers is prohibited except as provided in Florida Administrative Code Rule 62-256.700(6).

(4) Any open burning that is allowed by this chapter such as the burning of waste pesticide containers, yard trash, and land clearing debris is restricted to the site where the material was generated and may not be transported to another property to be open burned, with the following exceptions:

(a) Land clearing debris that is generated by the commercial land clearing activities of a person may be transported offsite to be burned by an Air Curtain Incinerator that is owned or operated by that person and without a Florida Administrative Code Rules 62-210 air pollution permit provided that it:

1. Will be transported to property that is owned or leased by the person who generated the land clearing debris, and
2. Meets a setback distance of 300 feet from occupied buildings for Air Curtain Incinerators with vertical refractory-lined walls and with forced underdraft air, or
3. Meets a setback distance of 1000 feet from occupied buildings for all other Air Curtain Incinerators.

(b) Land clearing debris generated from the activities of one or more persons may be transported offsite to be burned by an Air Curtain Incinerator with an appropriate Department air pollution permit.

(5) Open burning within one thousand (1000) feet of any active runway of a Department of Transportation approved public airport is prohibited. The Division of Forestry or any fire control agency authorized by law or ordinance to extinguish unlawful burning may extinguish or cause to be extinguished, any open burning that is within one thousand (1000) feet of an active airport runway that reduces or potentially reduces visibility at the airport.

(6) Open burning in particulate and ozone nonattainment areas as specified in Florida Administrative Code Rule 62-275 or in the area of influence as defined in Florida Administrative Code Rule 62-296 may be temporarily suspended when the Department determines that ambient air concentrations of total suspended particulate or ozone may near or exceed the primary or secondary standards for these pollutants.

(7) No open burning may be conducted during a National Weather Service Air Stagnation Advisory, a Department Air Stagnation Advisory, an Air Pollution Episode, or if the Division of Forestry determines that weather conditions are unfavorable for safe burning.

(8) Open burning which reduces visibility on public roadways to less than one thousand (1,000) feet is prohibited.

(9) Nothing in this chapter may be construed to allow open burning which violates other laws, rules, regulations, or ordinances.

#### D. Agricultural and Silvicultural Fires.

Pursuant to section 8 of the Florida Environmental Reorganization Act, Chapter 75-22, Laws of Florida, 1975, this section has been transferred to the State of Florida Department of Agriculture and Consumer Services, Division of Forestry. (See Chapter 5I-2, Florida Administrative Code.)

#### E. Burning for Cold or Frost Protection.

(1) Intent. The purpose of this rule is to allow the use of open burning and outdoor heating devices to prevent damage to agricultural products from cold and frost in a manner which provides the maximum

**SECTION VI. APPENDIX JEPB**

**RULE 2 CONDITIONS**

protection to the quality of the ambient air in Florida. Furthermore, this rule will minimize air pollution by restricting the use of open fires and outdoor heating devices to times and temperatures when absolutely necessary to prevent cold damage.

(2) Approval. Open burning or the use of outdoor heating devices for frost or cold protection in connection with agricultural operations is allowed, provided the fuel and the heating device used have approval from the Environmental Regulation Commission prior to use, or have been authorized by the Secretary pursuant to Florida Administrative Code Rule 62-256.450(4).

(a) The following fuels are approved for use:

1. No. 2 diesel fuel
2. No. 2 fuel oil
3. Propane gas
4. Alcohol (ethanol or methanol)
5. Butane
6. Liquid petroleum gas
7. Petroleum coke
8. Charcoal
9. Clean dry wood
10. Methane

(b) The following heating devices are approved for use:

1. Spot heater – Spot heaters
2. HY-LO Return Stack – Scheu Products Company
3. HY-LO Large Cone – Scheu Products Company
4. Brader Heater – Brader Heaters, Inc.
5. Georges Heater – Georges Enterprises, Inc.
6. Agri-Heat Heater – Agri-Heat, Inc.
7. A conical heater – Fulton-Cole Seed Company
8. Orchard-Rite Heater – Orchard Rite, Ltd.
9. "Return Stack" 2000 used heaters approved for W. H. Clark Fruit Co.
10. Radiant Omni-Heater – New Draulics, Inc.
11. HY-LO Lazy Flame Heater – Scheu Products Company
12. Sun Heater Model 2 – Fleming-Troutner Agricultural Heating, Inc.
13. Self Vaporizing Model M. B. S.-1 – Burners, Inc.
14. HY-LO Auto Clean Stack – Scheu Products Company
15. Mobil Tree Heat – Mobil Oil Corporation
16. Fireball – Sebring Forest Products

(c) Criteria for approval of new fuels:

Any person desiring to have a fuel approved for frost protection related open burning shall submit a petition to the Environmental Regulation Commission requesting that such fuel be added to Florida Administrative Code Rule 62-256.450(2)(a). The petition shall contain the following information:

1. Name, address, and telephone number of applicant;
2. Trade name or other designation of fuel;
3. Chemical composition of fuel;
4. The composition and quantity of air contaminants given off per unit of fuel; and
5. The expected rate of use of the fuel.

(d) Criteria for approval of new outdoor heating devices:

Any person desiring to have an outdoor heating device approved shall submit a petition to the Environmental Regulation Commission requesting that such device be added to Florida Administrative Code Rule 62-56.450(2)(b). The petition shall contain the following information:

1. Name, address and telephone number of applicant;

**SECTION VI. APPENDIX JEPB**  
**RULE 2 CONDITIONS**

---

2. Trade name or other designation of the device;
  3. Brief description of the device;
  4. Type of fuel that is used in the device;
  5. The composition and quantity of air contaminants; and
  6. Evidence that the device does not emit more than five-tenths gram per minute of unconsumed solid carbonaceous matter or particulate matter.
- (3) Operating Conditions. Open burning of approved fuels and the use of approved outdoor heating devices for frost or cold protection in connection with agricultural operations shall be in accordance with the following requirements:
- (a) Open fires or outdoor heating devices for the protection of agricultural crops from cold or frost shall not be ignited until the ambient temperature drops to 32° F, except as provided in subsection (b), below.
  - (b) Open fires or outdoor heating devices for the protection of subtropical fruit, crops, and foliage such as mangos, papayas, etc., may be ignited at temperatures above 32° F if the threshold temperature for cold damage for that plant is higher.
  - (c) Temperature measurement for cold and frost protection burning shall be measured using a Standard Cotton Region Shelter or a Standard Fruit Frost Station.
- (4) Exceptions.
- (a) Although Florida Administrative Code Rule 62-256.450(1) through (3) are intended to provide adequate measures to conserve fuel, protect the atmosphere, and allow for protection of agricultural crops, hard to predict circumstances may require exceptions to this section. Therefore, the Secretary is authorized to grant exceptions and allow the use of heating devices and fuels not included on the published list in the event of prolonged cold weather and shortage of approved fuels.
  - (b) Exceptions may be granted to persons who possess approved heating devices and who had possessed sufficient approved fuels for at least 20 hours of burning provided that:
    1. More than a total of 20 hours of temperatures of 25° F or lower has occurred during the season;
    2. Sufficient approved fuels and clean dry wood are not available for adequate protection from cold or frost;
    3. The burning of unapproved fuel is necessary to prevent irreparable damage to agricultural crops;
    4. There is no forecast of a condition which might cause an air pollution episode as defined by Florida Administrative Code Rule 17-211.
  - (c) The Secretary shall make a public declaration and disseminate it to the news media when it is determined that an exception is necessary. The declaration shall include the following:
    1. A list of the fuels that can be used and the conditions under which they can be used.
    2. The pollution potential and possible adverse health effects.
  - (d) In no case shall the Secretary allow the burning of Bunker C residual oil, tires, rubber materials, asphalt, tar, railroad cross ties, other creosoted materials, or plastics, as fuel.

**F. Land Clearing.**

The following rules apply to non-rural land clearing open burning:

- (1) Open burning of wooden material or vegetation generated by a land clearing operation (except for agricultural, silvicultural, or forestry operations) or the demolition of a structure is allowed provided that all of the following conditions are met:
  - (a) The open burning meets one of the following setback requirements:
    1. Three hundred (300) feet or more away from any occupied building for residential land clearing, or
    2. Three hundred (300) feet or more away from any occupied building if an Air Curtain Incinerator is used, or
    3. One thousand (1,000) feet or more away from any occupied building if an Air Curtain Incinerator is not used.
  - (b) The open burning is setback one hundred (100) feet or more away from any public highway or road and the prevailing winds direct the smoke away from the public highway or road.

## SECTION VI. APPENDIX JEPB

### RULE 2 CONDITIONS

- (c) The open burning is ignited after 9:00 a.m. and is extinguished one hour before sunset.
  - (d) The open burning is attended at all times.
  - (e) The open burning authorized herein is not intended to relieve any person from complying with any other applicable law, rules, or ordinances, including Chapter 590, Florida Statutes, and rules of the Division of Forestry.
  - (f) The piles of materials to be burned shall be of such size that the burning will be completed within the designated time given in paragraph 62-256.500(1)(c). This is not intended to relieve any person from complying with restrictions on size and numbers of piles imposed by the appropriate local fire control authorities.
  - (g) The moisture content and composition of the material to be burned shall be favorable to good burning which will minimize air pollution. Wet or green vegetative materials shall not be burned.
  - (h) The starter fuel and materials to be ignited shall not emit excessive visible emissions when burned. Tires or other prohibited materials listed in Florida Administrative Code Rule 62-256.300 shall not be used as starter fuels.
  - (i) The amount of dirt in a land clearing open burning operation shall be minimized to enhance combustion and reduce emissions.
  - (j) Prior to open burning for the demolition of a structure, all insulation, electrical wiring, linoleum, carpeting, roofing material such as tar paper and asphalt shingles, or other excessive smoke producing or potentially air toxic material shall be removed.
- (2) The use of Air Curtain Incinerators is allowed for the combustion of land clearing debris. No Department permits are required for air curtain incinerators that are designed and used as portable units and that will not operate on any one site for more than six months in any year. This does not relieve any person from the requirement of obtaining authorization to use a portable Air Curtain Incinerator, when necessary, from the Division of Forestry, or any local fire control authority. Air Curtain Incinerators may operate as portable units provided that the following conditions are met:
- (a) Pit width, length, and side walls shall be properly maintained so that the combustion of the waste within the pit will be maintained at an adequate temperature and with sufficient air recirculation to provide enough residence time and mixing for complete combustion and control of emissions. Pit width shall not exceed twelve (12) feet, and vertical side walls shall be maintained.
  - (b) No waste may be positioned to be burned above the level of the air curtain in the pit.
  - (c) The types of materials to be burned are restricted to land clearing debris. The Department shall authorize upon request the burning of wastes consisting only of clean dry wood used as defined in subsection 62-256.200(5), F.A.C.
  - (d) Excessive visible emissions are not allowed except for a period of up to 30 minutes during startups and shutdowns, as those terms are defined in Florida Administrative Code Rule 62-296.
- (3) Air Curtain Incinerators that are intended to be stationary units, i.e. continuously operate at one site for more than six months, or operate at any Department-permitted landfill, must obtain a Department air pollution permit pursuant to Florida Administrative Code Rule 62-210.
- (4) If the open burning resulting from a land clearing operation is creating a nuisance, or if changing weather or atmospheric conditions create a real or potential fire safety or air pollution problem, the Department may suspend or defer open burning until conditions change.
- (5) Exceptions to the setback requirements shall be granted by the Department if the applicant obtains a signed statement from every affected resident within the setback area who waives his objections to the open burning associated with the land clearing operation. Statements must be received by the Department 48 hours in advance of the burning.
- (6) Notwithstanding the provisions of Florida Administrative Code Rules 62-256.300(4)(a)2., 62-256.500(1)(a)2. and 62-256.500(1)(c), refractory-lined air curtain incinerators with forced underdraft air may commence burning at sunrise and may be charged until sunset, provided they maintain a setback distance of

**SECTION VI. APPENDIX JEPB**

**RULE 2 CONDITIONS**

1000 feet from occupied building located off-site and do not create a nuisance. During such times as the air curtain incinerator is not in operation, public access to the air curtain incinerator shall be restricted.

**G. Industrial, Commercial, Municipal, and Research Open Burning.**

(1) Open burning in connection with industrial, commercial, or municipal operations is prohibited, except when the open burning is determined by the Department to be the only feasible method of operation and prior approval is obtained from the Department, or when an emergency exists which requires immediate action to protect human health and safety, or in connection with county or municipal operations to burn hurricane, tornado, fire, or other disaster generated yard trash using an Air Curtain Incinerator as specified in Florida Administrative Code Rule 62-256.500(2).

(2) Open burning and the use of outdoor heating devices which are essential to a research project are allowed provided prior approval is obtained from the Department.

(3) The application for approval under this section shall include the following:

- (a) The name, address, and telephone number of the person submitting the application;
- (b) The type of business or activity involved;
- (c) A description of the proposed equipment and operating practices, the type, quantity, composition and amount of air contaminants to be released to the atmosphere;
- (d) The schedule of burning operations, if known;
- (e) The exact location of requested open burning;
- (f) If applicable, reasons why no method other than open burning is feasible; and
- (g) Evidence that the proposed open burning has been approved by the fire control authority which has jurisdiction.

(4) Nothing herein shall relieve any person from complying with any other applicable laws, rules and ordinances, including Chapter 590, Florida Statutes, and rules of the Division of Forestry.

(5) The Department shall approve such operations or research projects only on specified conditions which protect the ambient air from pollutants and contaminants to the greatest extent, and may limit the approval to a specified time.

**H. Open Burning Allowed.**

(1) Open burning to reduce yard trash and household paper products generated on occupied residential premises of not more than two family units is allowed in ozone attainment areas as specified in Florida Administrative Code Chapter 62-275 without Department authorization provided that all of the following conditions are met:

- (a) The open burning does not produce smoke, soot, odors, visible emissions, heat, flame, radiation, or other conditions to such a degree as to create a nuisance.
- (b) The open burning is one hundred (100) feet or more from any occupied building other than that owned or leased by the individual doing the burning and fifty (50) feet or more from any public highway or road and is ignited after 9:00 a.m. and is extinguished one hour before sunset providing that no visible smoke will be allowed over any adjacent residence or over the road that would cause a nuisance. These setback requirements apply in counties that are not specifically listed in 62-256.700(1)(c).
- (c) The open burning is three hundred (300) feet or more from any occupied building other than that owned or leased by the individual doing the burning and one hundred (100) feet or more from any public highway or road and is ignited after 9:00 a.m. and is extinguished one hour before sunset providing that no visible smoke will be allowed over any adjacent residence or over the road that would cause a nuisance. The requirements in this section apply in the following counties: Dade, Broward, Pinellas, Hillsborough, Palm Beach, Duval, Orange, Polk, Brevard, Volusia, Escambia, Lee, Sarasota, Pasco, Seminole, Alachua, Manatee, Leon, Marion, Okaloosa, Lake, Bay, St. Lucie, and Collier.
- (d) The open burning is fifty (50) feet or more from any residence on the property where the burning is being conducted.
- (e) The open burning is attended and adequate fire extinguishing equipment is readily available at all times.
- (f) The moisture content and composition of material to be burned shall be favorable to good burning which will minimize air pollution. Green or wet materials may be not be burned.



**SECTION VI. APPENDIX JEPB**  
**RULE 2 CONDITIONS**

---

- (g) The open burning is not prohibited by any local, county, municipal, or other governmental rule, regulation, law, or ordinance.
- (h) The open burning is enclosed in a noncombustible container or ground excavation covered by a metal mesh or grill, and is setback at least 25 feet from any woodlands, forest, or brush.
- (2) Open burning to reduce yard trash generated on occupied residential premises of not more than two family units in areas that are designated as non-attainment or maintenance areas for ozone as defined in Florida Administrative Code Rule 62-2 is allowed if a municipal, county or commercial solid waste collection service for yard trash is not available on a periodic basis of at least once a week. Prior authorization shall be obtained from the Department. The open burning must comply with all of the conditions contained in Florida Administrative Code Rule 62-256.700(1), and does not relieve any person from complying with any other applicable laws, rules and ordinances, including Chapter 590, Florida Statutes, and rules of the Division of Forestry.
- (3) A camp fire, bonfire, or other fire will be allowed that is used solely for recreational purposes, for ceremonial occasions, for outdoor noncommercial preparation of food, or on cold days for warming of outdoor workers, as long as excessive visible emissions are not emitted.
- (4) Open burning for the flaring of waste gases is allowed for reasons of safety, as long as excessive visible emissions are not emitted.
- (5) Open burning is allowed for the instruction and training of organized fire fighters or industrial employees under the supervision of the appropriate public fire control official provided that:
  - (a) The burning activities are conducted by a full-time municipal fire control agency in accordance with the National Fire Protection Association document, "Live Fire Training Evolutions in Structures (NFPA 1403)," as revised February 10, 1992, and hereby adopted and incorporated by reference as the accepted practice for fire training instruction. Nothing herein shall be construed as relieving any person from complying with any other applicable laws, rules and ordinances, including Chapter 590, Florida Statutes, and rules of the Division of Forestry.
  - (b) The Division of Forestry, the Department, and local fire control officials are notified in advance of the time and place of the burning exercise.
- (6) Subject to all of the following conditions, waste pesticide containers may be burned in open fields by the owner of the crops, the owner's authorized employee or caretaker, or by commercial pesticide applicators hired by the owner or caretaker.
  - (a) Plastic containers must be the original container provided by the pesticide manufacturer or formulator as end user conveyance for the specific product, and not reused containers designed for other products.
  - (b) Containers must be classified as Group I Containers and bear label instructions stating that small quantities of the containers may be burned in open fields by the user of the pesticide when such open burning is permitted by State and local regulations.
  - (c) The quantity of containers to be burned each day per parcel treated shall not exceed the amount accumulated during one day's use of pesticide. No more than 500 pounds of pesticide containers shall be burned per day at any specific location. If more than one fire is to be set in any area each specific burning location shall be at least 1,000 yards from each other location at which burning will occur concurrently.
  - (d) All Group I Containers which are to be disposed by open burning shall be completely empty and free of residual material pursuant to the following criteria:
    - 1. Plastic containers including inner liners shall be triple rinsed with the same kind of solvent used to dilute the spray mixture in the field. The rinse liquids from the containers shall be added to the spray mixture in the field.
    - 2. Paper containers shall be emptied by a final shaking and tapping of the sides and bottom to remove clinging particles. All loosened particles shall be added to the spray mixture or application in the field.
  - (e) The open burning shall meet the following conditions:
    - 1. The open burning does not produce smoke, soot, odors, visible emissions, heat, flame, radiation, or other conditions to such a degree as to create a nuisance.

**SECTION VI. APPENDIX JEPB**

**RULE 2 CONDITIONS**

2. The open burning is two hundred feet or more away from any farm workers or occupied buildings and is one hundred feet or more away from any public road.
3. The fire is ignited after 9:00 A.M. and is extinguished one hour before sunset of the same day.
4. The person responsible for the burning is in attendance at an upwind location from the fire for the entire period of the burn (until all flame and smoke have dissipated).
5. The open burning is enclosed in a noncombustible container or ground excavation covered by a metal grill.
6. Nothing herein shall relieve any person from complying with any other applicable laws, rules and ordinances, including Chapter 590, Florida Statutes, and rules of the Division of Forestry.

[History: New, Effective 11/03/04. Note: The rules covered by this part were previously adopted and incorporated by reference in this part.]

**SECTION VI. APPENDIX JEPB**

**RULE 2 CONDITIONS**

**PART IX**

**AIR POLLUTION EPISODES**

**2.901 Air Pollution Episode - Local Rules**

**A. City-Wide Episode Control Plans**

The Department shall prepare appropriate city-wide episode control plans to reduce air pollution levels based upon the plans submitted by sources of pollutants as required in JEPB Rule 2.104. The objective of the plans shall be to bring about a diminution of the particular air contaminants by curtailing the operations of industrial, business or other activities, the conduct of which is essential to the health and welfare of the community.

**B. Episode Alert**

In the event that an exceedance of the ambient air quality standards, as defined in JEPB Rule 2.201, is reached, the Department shall notify the following persons:

- A. Mayor.
- B. Public Health Officer.
- C. Regional and State officers, State Department of Environmental Protection.
- D. Board Members.
- E. Local public official and public safety personnel having responsibilities or interests in air pollution.
- F. Air pollution sources which require alert data in order to execute emergency control plans.
- G. General public, through available media of communication.

**C. Coordination**

Upon notification of a high air pollution episode, the Department will coordinate monitoring and enforcement activities with the State Department of Environmental Protection if the State Department of Environmental Protection elects to participate.

[History: Formerly S. 362.405 - S. 362.408, Ordinance Code, EPB 2.405 - 2.408; Effective 3/18/85; Amended and Renumbered 1/10/93, Amended 12/19/94, Amended and renumbered 11/12/96]. Note: The rules covered by this part were previously adopted under former EPB rule section 2.702.

**SECTION VI. APPENDIX JEPB**

**RULE 2 CONDITIONS**

**PART X**

**STATIONARY SOURCES - EMISSION STANDARDS**

**2.1001**

Chapter 62-296, Florida Administrative Code, is adopted and incorporated in this rule by reference as the City's emission standards for stationary sources.

[History: Effective 1/10/93, Amended 12/19/94, Amended 9/11/95, Amended and renumbered 11/12/96, Amended 6/08/98, Amended 11/08/99, Amended 9/11/06.] Note: The rules covered by this part were previously adopted by reference under former EPB rule section 2.901.

**SECTION VI. APPENDIX JEPB**

**RULE 2 CONDITIONS**

**PART XI**

**STATIONARY SOURCES - EMISSION MONITORING**

**2.1101**

Chapter 62-297, Florida Administrative Code, is adopted and incorporated in this rule by reference as the City's emission monitoring requirements for stationary sources.

[History: Effective 1/10/93, Amended 12/19/94, Amended and renumbered 11/12/96, Amended 6/08/98, Amended 11/08/99, Amended 11/10/03, Amended 10/11/04.] Note: The rules covered by this part were previously adopted by reference under former EPB rule section 2.1001.

**SECTION VI. APPENDIX JEPB**

**RULE 2 CONDITIONS**

**PART XII**

**AIR POLLUTION NUISANCE RULES**

**2.1201 General Standard for Volatile Organic Compounds**

Persons shall use reasonable care to avoid discharging, leaking, spilling, seeping, pouring, or dumping volatile organic compounds or organic solvents. [History: Formerly S.362.206, City Ordinance Code; EPB 2.205 B.2.; Effective 3/18/85; Renumbered 1/10/93, Renumbered 11/12/96]. Note: The rules covered by this part were previously adopted by reference under former EPB rule section 2.1101.

**2.1202 Emissions from Ships and Locomotives**

**A. Applicability**

This rule applies to the operation of ships and locomotives at all places within the borders of Duval County, Florida.

**B. Definitions**

1. "Cold boiler light off" - The light off of a steam boiler without the use of steam from an operating shipboard boiler or shore steam, to preheat the boiler furnace and combustion air.
2. "Distillate Fuel" - Liquid fuels distilled, usually from crude petroleum and conforming to the properties of Nos. 1 through 4 fuel oils as specified in ASTM D 396-80.
3. "Emergency boiler shut down" - An unscheduled, immediate cessation of boiler operation caused by a failure of the boiler and/or boiler auxiliaries, a fire in the machinery spaces or a similar unforeseeable casualty which all preventable measures could not have eliminated.

**C. Prohibited Acts**

No person, including owners, ships' captains and engineers, shall cause, let, permit, suffer or allow:

1. Visible emissions from ships or locomotives greater than twenty percent (20%) opacity, except that visible emission as great as forty percent (40%) opacity shall be permissible for no more than two minute in an hour.
2. Operation of any shipboard steam boiler without posting and maintaining in a conspicuous place within plain view of the boiler operators a warning placard as shown in Attachment 1.
3. The blowing of steam boiler tubes, economizers, air heaters, stacks or any other boiler components for the purpose of removing accumulated soot while in the port of Jacksonville, except in the event of an emergency threatening life or property.
4. Operation of any steam boiler without having in charge of the engine room an engineer duly licensed by the country of the vessels registry or by the United States Coast Guard. Proof of identity and license of said engineer shall be maintained on-board the vessel and shall be made available for inspection to the Department upon request.
5. Emergency boiler shut-downs, the light off of a cold boiler or boiler pressure relief valve safety test, without giving notice to the Department. In the case of cold boiler light off and boiler pressure relief valve safety tests, notification shall be by telephone and shall be given prior to the test or light off. Notification shall be given by telephone as soon as possible following an emergency boiler shut-down. Each notice required by this part shall include the following information:
  - a. Name of vessel.
  - b. Location of vessel.
  - c. Time of reported event.
  - d. Name of operator in charge of the vessel and of the engine room.
6. A cold boiler light off using any fuel other than distillate fuel.

**D. Exemptions**

1. Visible emissions caused by an emergency boiler shut-down or by boiler pressure relief valve safety tests shall be exempt from the opacity limits of Section 2.1202 C.1. above, provided that -
  - a. Best operational practices to minimize emissions are adhered to.

**SECTION VI. APPENDIX JEPB**

**RULE 2 CONDITIONS**

b. The duration of the excess emission shall be minimized, but in no case shall exempted emissions exceed 30 minutes in any 24-hour period, and

c. Notification of the emergency boiler shut-down or safety valve test shall have been provided in a timely manner, pursuant to the requirements of Section 2.1202 C.5. above.

2. In the event of a visible emission in excess of the opacity limits of Section 2.1202 C.1. caused by an emergency boiler shut-down or by boiler safety valve tests, a written report shall be submitted within 30 days, if requested by the Department, detailing the exact cause of the excess emission and the operational practices taken to minimize the emission.

**E. Equipment Specifications.**

In addition to the payment of any fines, penalties or settlements tendered in resolution of said violations, a vessel which is the source of an emission, in violation of Section 2.1202 C., shall be subject to the equipment specifications set forth below. This Section will apply if the violations are admitted or uncontested, or if contested, are found by the Board or by a court of competent jurisdiction to have occurred.

1. Vessels powered by steam boilers and subject to this Section shall be equipped with smoke detectors and alarms which immediately alert engineers on watch in the engine room of any excessive smoke emitted from the ship. Smoke detectors shall, at all times, be calibrated, operated and maintained in accordance with manufacturer's written specifications. The manufacturer's specification, together with written records of all instrument calibrations and maintenance performed, shall be maintained on-board the vessel and shall be made available for inspection to the Department upon request.

2. Smoke detectors and alarms required by this section shall be installed and calibrated as soon as possible, but not later than six months from the date of Citation if uncontested, or if contested, not later than six months from the date of determination by the Board or Court that the violation occurred.

3. Whenever the smoke detector required by this section measures an emission into the atmosphere in excess of forty percent (40%) opacity, notice shall be given by telephone to the Department immediately upon discovery of the excess emission and shall include the following information:

- a. Name of vessel.
- b. Location of vessel.
- c. Time of discovery of excessive emission.
- d. Duration of excessive emission.
- e. Suspected cause of excessive emission.
- f. Corrective action taken to abate the excessive emission.
- g. Name of operator in charge of the vessel and of the engine room.

**F. Compliance Test Method**

Determinations of the opacity of emissions, pursuant to Section 2.1202 C.1., above, shall be made using United States Environmental Protection Agency Reference Method No. 9 (40 Code of Federal Regulation (CFR) 60, Appendix A). Only determinations made by qualified observers trained and certified in accordance with Reference Method No. 9 shall be used to enforce the opacity limits.

**G. Penalties and Injunctive Relief**

Violations of this rule shall be punishable by civil penalties specified in Section 362.110, Ordinance Code and to injunctive relief as provided in Section 360.407, Ordinance Code.

**H. Enforcement**

This rule shall be enforced by the Department in accordance with the provisions of Chapter 360 and 362, Ordinance Code.

**I. Air Pollution Nuisance Prohibited**

Nothing in this rule shall in any manner be construed as authorizing or legalizing the creation or maintenance of an air pollution nuisance, as defined in Environmental Protection Board Rule 2.1203. A violation of this rule does not, in and of itself, constitute an air pollution nuisance, as defined in Board Rule 2.1203.

**J. Effective Date**

**SECTION VI. APPENDIX JEPB**

**RULE 2 CONDITIONS**

This rule shall become effective twenty days following adoption by the Board and filing with the Council Secretary. [History: Formerly S 362.208, City Ordinance Code; EPB 2.206; Effective 7/9/90; Amended and renumbered 1/10/93, Amended and renumbered 11/12/96, Amended 9/11/00] Note: The rules covered by this part were previously adopted by reference under former EPB rule section 2.1102.

**2.1203 Air Pollution Nuisances**

**A. Preamble**

An Environmental Protection Board rule; developed pursuant to the rule making powers of the Board as defined in Section 360.108, Ordinance Code; prohibiting the creation of public air pollution nuisances that would adversely affect human welfare or cause damage to property or unreasonably interfere with the enjoyment of life or property or the conduct of business; providing procedures for notification to the source in the event of occurrence of a nuisance; and defining the elements of property damage.

**B. Air Pollution Nuisance Defined**

1. The term "air pollution nuisance" shall mean the presence in the atmosphere, from any source or sources whatever, of any air contaminant, including but not limited to smoke, ashes, dust, dirt, grime, soot, acids, fumes, gases, vapors, abrasive blasting grit, paint, or any other substance or combination of substances, in such amounts as to adversely affect human welfare; or cause harm or damage to property or unreasonably interfere with the enjoyment of life or property or the conduct of business.

In order for the Board to abate a nuisance under this section, the nuisance must be a public nuisance, as opposed to a private nuisance, although a nuisance may be both public and private. A public nuisance affects rights common to the whole community or a considerable number of persons and not merely some particular person. After the Department has received and validated citizen complaints from ten or more persons who do not live in the same household within a one year period or less, each alleging an adverse affect to that person's human welfare or damage to his own property, or unreasonable interference with enjoyment of life or property or the conduct of business, the source responsible shall be deemed a public nuisance. In addition, and irrespective of the number or frequency of complaints, damage to property or unreasonable interference with the enjoyment of life or property or the conduct of business which occurs in or on any public way or place, including but not limited to parks, playgrounds, recreational area, schools, street, highways, bodies of water, or any publicly owned land or buildings, shall be deemed a public nuisance.

2. For the purpose of this rule, source means any stationary point source as defined in Section 62-210.200, FAC, any unconfined or area source and any mobile source, including but not limited to automobiles, trucks, buses, locomotives and ships.

**C. Exceptions**

1. Objectionable odors are not included under this section.

2. In the case of a permitted source of air pollution equipped with continuous emission monitors (CEMs) which measure the air pollutant alleged to have caused the nuisance and which meet applicable Federal performance specifications for continuous emissions monitors, the submission of CEM data showing compliance with applicable emission limiting standards during the time of the air pollution nuisance shall constitute prima facie evidence of no violation of the provisions of this rule.

**D. Elements of property damage**

Pursuant to this rule, property damage shall include, but is not limited to the deposition, impaction, settling or condensation of an air pollution nuisance, as defined in Section B on any property at any point beyond the property limits of the premises occupied or used by the person responsible for the emission into the atmosphere of the air pollution nuisance as defined in Section B, so as to cause:

1. Excessive corrosion of metal surfaces as demonstrated by comparison with similar surfaces in the general area or other portions of the same structures.

2. Etching or discoloration of surface coatings.



**SECTION VI. APPENDIX JEPB**

**RULE 2 CONDITIONS**

3. Soiling in amounts which necessitate additional cleaning of property not otherwise required or refinishing of coated or polished surfaces.
4. Discoloration or soiling over and above normal wear and tear resulting from the tracking of deposited material onto carpets or other types of finished floor covering which necessitate cleaning not otherwise required.
5. Impaction of paint droplets or other coating materials onto surfaces.

**E. Air Pollution Nuisance Prohibited**

No person who owns or operates a source which emits air contaminants as defined in Section B shall cause, suffer, allow or permit the emission or escape into the atmosphere of an air pollution nuisance, as defined in Section B: and nothing in this rule shall, in any manner be construed as authorizing or legalizing the creation or maintenance of an air pollution nuisance, as defined in Section B.

**F. Civil Penalties and Injunctive Relief**

Persons who cause an air pollution nuisance, as defined in Section B shall be subject to civil penalties specified in Section 362.110, Ordinance Code; as well as to injunctive relief as specified in Section 360.407, Ordinance Code.

**G. Source Notification Procedures**

The Department shall make all reasonable attempts to notify the owner or operator of the source alleged to be causing a nuisance not later than the next business day after the Department has initially identified the source as the suspected cause of the complaint.

[History: Formerly EPB 2.211; Effective December 1985; Amended and renumbered 1/10/93, Amended 12/19/94, Amended and renumbered 11/12/96] Note: The rules covered by this part were previously adopted by reference under former EPB rule section 2.1103.

NOTICE TO SHIPS  
WHILE IN THE PORT OF JACKSONVILLE

# EXCESSIVE SMOKE

The Jacksonville Ordinance Code prohibits the emission into the air of visible smoke greater than 20 percent (20%) opacity, except that a visible emission as great as 40 percent (40%) opacity shall be permissible for not more than two minutes in any hour.

Soot blowing except in an emergency threatening life or property, is prohibited.

Violation of these and all other applicable rules of the City of Jacksonville are punishable by fines of up to \$10,000 per day, for each separate offense.

To report cold boiler lightoffs, emergency boiler shutdown, boiler safety testing or excess emission call

**630-4900**

**SECTION VI. APPENDIX JEPB**

**RULE 2 CONDITIONS**

**PART XIII**

**PERMITS - GENERAL PROVISIONS**

**2.1301 Air Pollution Source Permits**

Chapter 62-4, Florida Administrative Code, is adopted and incorporated into this rule by reference as the City's air pollution source permitting requirements.

[History: New, Effective 12/19/94, Amended 9/11/95, Amended and Renumbered 11/12/96, Amended 11/08/99, Amended 08/13/01] Note: The rules covered by this part were previously adopted by reference under former EPB rule section 2.1201.

**2.1302 Air Pollution Source Permit Hearings and Public Notice Requirements**

Section 120.57, Florida Statutes, and Rules 62-110.106, 28-106.110, 28-106.201, and 28-106.301, Florida Administrative Code are adopted by reference as the Board requirements for hearings and public notice in conjunction with air pollution permitting.

[History: New, Effective 12/19/94, Amended and Renumbered 9/11/95, Amended and Renumbered 11/12/96, Amended 11/8/99]. Note: The rules covered by this part were previously adopted by reference under former EPB rule section 2.1204.

**SECTION VI. APPENDIX H**  
**PERMITTING HISTORY**

E.U. ID No.	Description	Permit No.	Effective Date	Expiration Date	Project Type
All	Facility	0310047-001-AV	01/01/1998	12/31/2001	Initial
All	Facility	0310047-012-AV	01/01/2003	12/31/2007	Renewal
All	Facility	0310047-016-AV	01/01/2008	12/31/2012	Renewal
-016	CT No. 8 (Acid Rain Unit)	0310047-015-AC		12/31/08	Construction Permit
-016	CT No. 8 (Acid Rain Unit)	0310047-018-AC			Construction Permit
-016	CT No. 8 (Acid Rain Unit)	0310047-019-AC			Construction Permit

## Friday, Barbara

---

**To:** chanjm@jea.com  
**Cc:** Gianazza, N. Bert; 'Forney, Kathleen@epamail.epa.gov'; Oquendo, Ana@epamail.epa.gov; ROBINSON@coj.net; Kirts, Christopher; Gibson, Victoria; Cascio, Tom  
**Subject:** JEA - KENNEDY GENERATING STATION; 0310047-020-AV  
**Attachments:** SignedNoticeofFinalPermit2010.pdf

Dear Sir/ Madam:

Attached is the official **Notice of Final Permit** for the project referenced below. Click on the link displayed below to access the permit project documents and send a "reply" message verifying receipt of the document(s) provided in the link; this may be done by selecting "Reply" on the menu bar of your e-mail software, noting that you can view the documents, and then selecting "Send".

*Note: We must receive verification that you are able to access the documents. Your immediate reply will preclude subsequent e-mail transmissions to verify accessibility of the document(s).*

Attention: Tom Cascio

Owner/Company Name: JEA  
Facility Name: KENNEDY  
Project Number: 0310047-020-AV  
Permit Status: FINAL  
Permit Activity: PERMIT REVISION  
Facility County: DUVAL

Click on the following link to access the permit project documents:

[http://ARM-PERMIT2K.dep.state.fl.us/adh/prod/pdf\\_permit\\_zip\\_files/0310047.020.AV.F\\_pdf.zip](http://ARM-PERMIT2K.dep.state.fl.us/adh/prod/pdf_permit_zip_files/0310047.020.AV.F_pdf.zip)

The Bureau of Air Regulation is issuing electronic documents for permits, notices and other correspondence in lieu of hard copies through the United States Postal System, to provide greater service to the applicant and the engineering community. Access these documents by clicking on the link provided above, or search for other project documents using the "*Air Permit Documents Search*" website at <http://www.dep.state.fl.us/air/emission/apds/default.asp> . "

Permit project documents that are addressed in this email may require immediate action within a specified time frame. Please open and review the document(s) as soon as possible, and verify that they are accessible. Please advise this office of any changes to your e-mail address or that of the Engineer-of-Record. If you have any problems opening the documents or would like further information, please contact the Florida Department of Environmental Protection, Bureau of Air Regulation.

Barbara Friday  
Bureau of Air Regulation  
Division of Air Resource Management (DARM)  
(850)921-9524

## Friday, Barbara

---

**From:** Chansler, James M. - Chief Operating Officer [ChanJM@jea.com]  
**To:** Friday, Barbara  
**Sent:** Tuesday, March 09, 2010 11:58 AM  
**Subject:** Read: JEA - KENNEDY GENERATING STATION; 0310047-020-AV

Your message was read on Tuesday, March 09, 2010 11:58:04 AM (GMT-05:00) Eastern Time (US & Canada).

## Friday, Barbara

---

**From:** Microsoft Exchange  
**To:** 'chanjm@jea.com'; Gianazza, N. Bert  
**Sent:** Tuesday, March 09, 2010 10:54 AM  
**Subject:** Relayed: JEA - KENNEDY GENERATING STATION; 0310047-020-AV

**Delivery to these recipients or distribution lists is complete, but delivery notification was not sent by the destination:**

'chanjm@jea.com'

Gianazza, N. Bert

**Subject:** JEA - KENNEDY GENERATING STATION; 0310047-020-AV

---

Sent by Microsoft Exchange Server 2007

## Friday, Barbara

---

**From:** Gianazza, N. Bert [GianNB@jea.com]  
**To:** Friday, Barbara  
**Sent:** Tuesday, March 09, 2010 10:55 AM  
**Subject:** Read: JEA - KENNEDY GENERATING STATION; 0310047-020-AV

Your message was read on Tuesday, March 09, 2010 10:55:02 AM (GMT-05:00) Eastern Time (US & Canada).



## Friday, Barbara

---

**From:** Gianazza, N. Bert [GianNB@jea.com]  
**Sent:** Tuesday, March 09, 2010 11:00 AM  
**To:** Friday, Barbara  
**Cc:** Chansler, James M. - Chief Operating Officer; Mann, Athena T. - Vice President, Environmental Services; Holbrooks, Kevin E. - Director, Compliance  
**Subject:** RE: JEA - KENNEDY GENERATING STATION; 0310047-020-AV

Barbara,

My R.O. and I have received this email and are able to access the documents.

Bert

---

**From:** Friday, Barbara [mailto:Barbara.Friday@dep.state.fl.us]  
**Sent:** Tuesday, March 09, 2010 10:54 AM  
**To:** Chansler, James M. - Chief Operating Officer  
**Cc:** Gianazza, N. Bert; Forney.Kathleen@epamail.epa.gov; Oquendo.Ana@epamail.epa.gov; ROBINSON@coj.net; Kirts, Christopher; Gibson, Victoria; Cascio, Tom  
**Subject:** JEA - KENNEDY GENERATING STATION; 0310047-020-AV

Dear Sir/ Madam:

Attached is the official **Notice of Final Permit** for the project referenced below. Click on the link displayed below to access the permit project documents and send a "reply" message verifying receipt of the document(s) provided in the link; this may be done by selecting "Reply" on the menu bar of your e-mail software, noting that you can view the documents, and then selecting "Send".

*Note: We must receive verification that you are able to access the documents. Your immediate reply will preclude subsequent e-mail transmissions to verify accessibility of the document(s).*

Attention: Tom Cascio

Owner/Company Name: JEA  
Facility Name: KENNEDY  
Project Number: 0310047-020-AV  
Permit Status: FINAL  
Permit Activity: PERMIT REVISION  
Facility County: DUVAL

Click on the following link to access the permit project documents:

[http://ARM-PERMIT2K.dep.state.fl.us/adh/prod/pdf\\_permit\\_zip\\_files/0310047.020.AV.F\\_pdf.zip](http://ARM-PERMIT2K.dep.state.fl.us/adh/prod/pdf_permit_zip_files/0310047.020.AV.F_pdf.zip)

The Bureau of Air Regulation is issuing electronic documents for permits, notices and other correspondence in lieu of hard copies through the United States Postal System, to provide greater service to the applicant and the engineering community. Access these documents by clicking on the link provided above, or search for other project documents using the "Air Permit Documents Search" website at <http://www.dep.state.fl.us/air/emission/apds/default.asp> . "

Permit project documents that are addressed in this email may require immediate action within a specified time frame. Please open and review the document(s) as soon as possible, and verify that they are accessible. Please advise this office of any changes to your e-mail address or that of the Engineer-of-Record. If you have any problems opening the documents or would like further information, please contact the Florida Department of Environmental Protection, Bureau of Air Regulation.

Barbara Friday  
Bureau of Air Regulation  
Division of Air Resource Management (DARM)  
(850)921-9524

*The Department of Environmental Protection values your feedback as a customer. DEP Secretary Michael W. Sole is committed to continuously assessing and improving the level and quality of services provided to you. Please take a few minutes to comment on the quality of service you received. Simply click on [this link to the DEP Customer Survey](#). Thank you in advance for completing the survey.*

-----  
Florida has a very broad Public Records Law. Virtually all written communications to or from State and Local Officials and employees are public records available to the public and media upon request. JEA does not differentiate between personal and business e-mails. E-mail sent on the JEA system will be considered public and will only be withheld from disclosure if deemed confidential pursuant to State Law. Under Florida law, e-mail addresses are public records. If you do not want your e-mail address released in response to a public-records request, do not send electronic mail to this entity. Instead, contact JEA by phone or in writing.

**Friday, Barbara**

---

**From:** Mail Delivery System [MAILER-DAEMON@mseive01.rtp.epa.gov]  
**To:** Forney.Kathleen@epamail.epa.gov; Oquendo.Ana@epamail.epa.gov  
**Sent:** Tuesday, March 09, 2010 10:54 AM  
**Subject:** Relayed: JEA - KENNEDY GENERATING STATION; 0310047-020-AV

**Delivery to these recipients or distribution lists is complete, but delivery notification was not sent by the destination:**

[Forney.Kathleen@epamail.epa.gov](mailto:Forney.Kathleen@epamail.epa.gov)

[Oquendo.Ana@epamail.epa.gov](mailto:Oquendo.Ana@epamail.epa.gov)

Subject: JEA - KENNEDY GENERATING STATION; 0310047-020-AV

**Friday, Barbara**

---

**From:** Microsoft Exchange  
**To:** 'ROBINSON@coj.net'  
**Sent:** Tuesday, March 09, 2010 10:54 AM  
**Subject:** Relayed: JEA - KENNEDY GENERATING STATION; 0310047-020-AV

**Delivery to these recipients or distribution lists is complete, but delivery notification was not sent by the destination:**

'ROBINSON@coj.net'

Subject: JEA - KENNEDY GENERATING STATION; 0310047-020-AV

---

Sent by Microsoft Exchange Server 2007

## Friday, Barbara

---

**From:** Robinson, Richard [ROBINSON@coj.net]  
**Sent:** Tuesday, March 09, 2010 4:07 PM  
**To:** Friday, Barbara  
**Subject:** RE: JEA - KENNEDY GENERATING STATION; 0310047-020-AV

Hi Barbara,

I was able to access the subject documents through the e-mail link below.

Thanks,


Richard

### *Richard L. Robinson, P.E.*

Environmental Engineering Manager  
Environmental Quality Division  
City of Jacksonville, Florida  
407 North Laura Street, Third Floor  
Jacksonville, FL 32202  
Phone: (904) 255-7201  
Fax: (904) 588-0518  
E-Mail: [robinson@coj.net](mailto:robinson@coj.net)

*Subscribe to EnviroFlash now to have Jacksonville air quality information delivered straight to your inbox: <http://jacksonville.enviroflash.info>. EnviroFlash not only gives subscribers daily information about air quality, but it also lets you know how to change your outdoor activities to protect your health. Air quality affects everyone, but it's especially important for people with respiratory illnesses like asthma, those with heart conditions, older adults and families with young children.*

Please note: that under Florida's very broad public records law, e-mail communications to and from City officials may be subject to public disclosure.

 Please consider the environment before printing this email.

---

**From:** Friday, Barbara [<mailto:Barbara.Friday@dep.state.fl.us>]  
**Sent:** Tuesday, March 09, 2010 10:54 AM  
**To:** [chanjm@jea.com](mailto:chanjm@jea.com)  
**Cc:** Gianazza, N. Bert; [Forney.Kathleen@epamail.epa.gov](mailto:Forney.Kathleen@epamail.epa.gov); [Oquendo.Ana@epamail.epa.gov](mailto:Oquendo.Ana@epamail.epa.gov); Robinson, Richard; Kirts, Christopher; Gibson, Victoria; Cascio, Tom  
**Subject:** JEA - KENNEDY GENERATING STATION; 0310047-020-AV

Dear Sir/ Madam:

Attached is the official **Notice of Final Permit** for the project referenced below. Click on the link displayed below to access the permit project documents and send a "reply" message verifying receipt of the document(s) provided in the link; this may be done by selecting "Reply" on the menu bar of your e-mail software, noting that you can view the documents, and then selecting "Send".

*Note: We must receive verification that you are able to access the documents. Your immediate reply will preclude subsequent e-mail transmissions to verify accessibility of the document(s).*

Attention: Tom Cascio

Owner/Company Name: JEA

Facility Name: KENNEDY

Project Number: 0310047-020-AV

Permit Status: FINAL

Permit Activity: PERMIT REVISION

Facility County: DUVAL

Click on the following link to access the permit project documents:

[http://ARM-PERMIT2K.dep.state.fl.us/adh/prod/pdf\\_permit\\_zip\\_files/0310047.020.AV.F\\_pdf.zip](http://ARM-PERMIT2K.dep.state.fl.us/adh/prod/pdf_permit_zip_files/0310047.020.AV.F_pdf.zip)

The Bureau of Air Regulation is issuing electronic documents for permits, notices and other correspondence in lieu of hard copies through the United States Postal System, to provide greater service to the applicant and the engineering community. Access these documents by clicking on the link provided above, or search for other project documents using the “*Air Permit Documents Search*” website at <http://www.dep.state.fl.us/air/emission/apds/default.asp> . “

Permit project documents that are addressed in this email may require immediate action within a specified time frame. Please open and review the document(s) as soon as possible, and verify that they are accessible. Please advise this office of any changes to your e-mail address or that of the Engineer-of-Record. If you have any problems opening the documents or would like further information, please contact the Florida Department of Environmental Protection, Bureau of Air Regulation.

Barbara Friday  
Bureau of Air Regulation  
Division of Air Resource Management (DARM)  
(850)921-9524

*The Department of Environmental Protection values your feedback as a customer. DEP Secretary Michael W. Sole is committed to continuously assessing and improving the level and quality of services provided to you. Please take a few minutes to comment on the quality of service you received. Simply click on [this link to the DEP Customer Survey](#). Thank you in advance for completing the survey.*

## Friday, Barbara

---

**From:** Microsoft Exchange  
**To:** Kirts, Christopher; Cascio, Tom; Gibson, Victoria  
**Sent:** Tuesday, March 09, 2010 10:54 AM  
**Subject:** Delivered: JEA - KENNEDY GENERATING STATION; 0310047-020-AV

### Your message has been delivered to the following recipients:

Kirts, Christopher

Cascio, Tom

Gibson, Victoria

Subject: JEA - KENNEDY GENERATING STATION; 0310047-020-AV

---

Sent by Microsoft Exchange Server 2007

## Friday, Barbara

---

**From:** Kirts, Christopher  
**To:** Friday, Barbara  
**Sent:** Thursday, March 11, 2010 8:00 AM  
**Subject:** Read: JEA - KENNEDY GENERATING STATION; 0310047-020-AV

Your message was read on Thursday, March 11, 2010 8:00:26 AM (GMT-05:00) Eastern Time (US & Canada).



## Friday, Barbara

---

**From:** Gibson, Victoria  
**To:** Friday, Barbara  
**Sent:** Tuesday, March 09, 2010 11:44 AM  
**Subject:** Read: JEA - KENNEDY GENERATING STATION; 0310047-020-AV

Your message was read on Tuesday, March 09, 2010 11:43:49 AM (GMT-05:00) Eastern Time (US & Canada).