

STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION

**NOTICE OF ADMINISTRATIVELY CORRECTED TITLE V OPERATION PERMIT**

In the Matter of a Request for Administrative Correction:


Mr. Walter P. Bussells  
Managing Director & CEO  
JEA  
21 West Church Street  
Jacksonville, Florida 32202

Project No.: 0310047-010-AV  
Kennedy Generating Station

Enclosed is an ADMINISTRATIVE CORRECTION to the Title V Operation Permit, Revision No. 0310047-006-AV, for the operation of the Combustion Turbine #7 located at 4215 Talleyrand Avenue, Jacksonville, Duval County. This correction is issued pursuant to Rule 62-210.360, Florida Administrative Code and Chapter 403, Florida Statutes (F.S.). The following changes are made at the applicant's request dated May 18, 2001, and received May 21, 2001: 1) to reflect the change in the name of the permittee from "Jacksonville Electric Authority" to "JEA"; 2) to correct a typo in specific condition No. D.4., specifically change "...and 1260" to "...or 1260", which was established in a SIP construction permit, No. 0310047-002-AC, issued/clerked March 8, 1999; and, 3) to incorporate an Administrative Permit Correction, issued/clerked May 22, 2000, of specific condition No. 40 of the SIP construction permit, No. 0310047-002-AC (No. D.34. in the Title V Operation Permit, Revision No. 0310047-006-AV), which changed the submittal due date of the "data on CEM equipment specifications, manufacturer, type, calibration and maintenance needs, and its proposed location" from "90 days prior to installation" to "45 days prior to installation" for review purposes. This corrective action does not alter the effective dates of the permit.

Any party to this order (permit administrative correction) has the right to seek judicial review of it under Section 120.68 of the Florida Statutes, by the filing of a Notice of Appeal under Rule 9.110 of the Florida Rules of Appellate Procedure, with the clerk of the Department of Environmental Protection in the Office of General Counsel, 3900 Commonwealth Boulevard, Mail Station #35, Tallahassee, Florida, 32399-3000; and by filing a copy of the Notice of Appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal. The Notice of Appeal must be filed within thirty days from the date this notice is filed with the clerk of the permitting authority.

Executed in Tallahassee, Florida.



C. H. Fancy, P.E.  
Chief  
Bureau of Air Regulation

**CERTIFICATE OF SERVICE**

The undersigned duly designated deputy agency clerk hereby certifies that this NOTICE OF ADMINISTRATIVELY CORRECTED PERMIT (including the DETERMINATION) was sent by certified mail (\*) and copies were mailed by U.S. Mail before the close of business on 5/30/01 to the person(s) listed or as otherwise noted:

Mr. Walter P. Bussells\*, Managing Director & CEO, JEA  
Mr. Jon P. Eckenbach, Executive Vice President/Designated Representative, JEA  
Mr. N. Bert Gianazza, P.E., JEA, Application Contact  
Mr. Chris Kirts, DAPA, NED  
USEPA, Region 4 (INTERNET E-mail Memorandum)

5/30/01 cc = Bruce Mitchell  
Reading File

Clerk Stamp

FILING AND ACKNOWLEDGMENT FILED, on this date, pursuant to §120.52(7), Florida Statutes, with the designated Department Clerk, receipt of which is hereby acknowledged.

  
(Clerk)

5/30/01  
(Date)

| SENDER: COMPLETE THIS SECTION  | COMPLETE THIS SECTION ON DELIVERY  |
|--|--|
| <ul style="list-style-type: none"> <li>Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.</li> <li>Print your name and address on the reverse so that we can return the card to you.</li> <li>Attach this card to the back of the mailpiece, or on the front if space permits.</li> </ul> | <p>A. Received by (Please Print Clearly) <b>T. HEARNEY</b> B. Date of Delivery <b>JUN 04 2001</b></p> <p>C. Signature <b>X</b> <i>T. Hearney</i> <input type="checkbox"/> Agent <input type="checkbox"/> Addressee</p> <p>D. Is delivery address different from item 1? <input type="checkbox"/> Yes<br/>If YES, enter delivery address below: <input type="checkbox"/> No</p> |
| <p>1. Article Addressed to:<br/>Mr. Walter P. Bussells<br/>Managing Director &amp; CEO<br/>Jacksonville Electric<br/>Authority<br/>21 West Church Street<br/>Jacksonville, Florida 32202</p>   | <p>3. Service Type<br/> <input checked="" type="checkbox"/> Certified Mail <input type="checkbox"/> Express Mail<br/> <input type="checkbox"/> Registered <input type="checkbox"/> Return Receipt for Merchandise<br/> <input type="checkbox"/> Insured Mail <input type="checkbox"/> C.O.D.</p> <p>4. Restricted Delivery? (Extra Fee) <input type="checkbox"/> Yes</p>       |
| <p>2. Article Number (Copy from service label)<br/>7000 0600 0021 6524 3936</p>  |  |
| <p>PS Form 3811, July 1999 Domestic Return Receipt 102595-99-M-1789</p>  |  |

**U.S. Postal Service**  
**CERTIFIED MAIL RECEIPT**  
*(Domestic Mail Only; No Insurance Coverage Provided)*

Article Sent To:  
Mr. Walter P. Bussells

|   |           |                  |
|---|-----------|------------------|
| Postage   | \$        | Postmark<br>Here |
| Certified Fee                                     |           |                  |
| Return Receipt Fee<br>(Endorsement Required)      |           |                  |
| Restricted Delivery Fee<br>(Endorsement Required) |           |                  |
| <b>Total Postage &amp; Fees</b>                   | <b>\$</b> |                  |

Name (Please Print Clearly) (to be completed by mailer)  
Mr. Walter P. Bussells

Street, Apt. No., or PO Box No.  
21 West Church Street

City, State, ZIP+4  
Jacksonville, Florida 32202

PS Form 3800, July 1999 See Reverse for Instructions

7000 0600 0021 6524 3936

ADMINISTRATIVE CORRECTION TO TITLE V OPERATION PERMIT DETERMINATION

JEA: Kennedy Generating Station

FINAL Title V Operation Permit Revision No.: 0310047-006-AV  
PROJECT No.: 0310047-010-AV

1. The name of the permittee is changed from "Jacksonville Electric Authority" to "JEA".
2. The following specific condition D.4. is changed as follows:

FROM:

Hours of Operation. The maximum allowable hours of operation in any 12-month period (MAXHROP) for this CT are 4050 hours on pipeline natural gas and 1260 on virgin distillate No. 2 fuel oil or the hours calculated pursuant to the following formula:

$$\text{MAXHROP} = 4050 - (3.215 \times \text{ACTHROPFO})$$

Where: ACTHROPFO = actual hours of operation on fuel oil.

[Rules 62-4.160(2) and 62-210.200(PTE), F.A.C.; and, 0310047-002-AC]

TO:

Hours of Operation. The maximum allowable hours of operation in any 12-month period (MAXHROP) for this CT are 4050 hours on pipeline natural gas or 1260 on virgin distillate No. 2 fuel oil or the hours calculated pursuant to the following formula:

$$\text{MAXHROP} = 4050 - (3.215 \times \text{ACTHROPFO})$$

Where: ACTHROPFO = actual hours of operation on fuel oil.

[Rules 62-4.160(2) and 62-210.200(PTE), F.A.C.; and, 0310047-002-AC]

3. The following specific condition D.34. is changed as follows:

FROM:

Continuous Monitoring System Reports. The monitoring devices shall comply with the certification and quality assurance, and any other applicable requirements of Rule 62-297.520, F.A.C., 40 CFR 60.13, including certification of each device in accordance with 40 CFR 60, Appendix B, Performance Specifications, and 40 CFR 60.7(a)(5) or 40 CFR 75. Quality assurance procedures must conform to all applicable sections of 40 CFR 60, Appendix F, or 40 CFR 75. Data on CEM equipment specifications, manufacturer, type, calibration and maintenance needs, and its proposed location shall be provided to the Department's Northeast District and Jacksonville RESD's Air & Water Quality Division Offices for review at least 90 days prior to installation.

[0310047-002-AC; and, 40 CFR 75]

TO:

Continuous Monitoring System Reports. The monitoring devices shall comply with the certification and quality assurance, and any other applicable requirements of Rule 62-297.520, F.A.C., 40 CFR 60.13, including certification of each device in accordance with 40 CFR 60, Appendix B, Performance Specifications, and 40 CFR 60.7(a)(5) or 40 CFR 75. Quality assurance procedures must conform to all applicable sections of 40 CFR 60, Appendix F, or 40 CFR 75. Data on CEM equipment specifications, manufacturer, type, calibration and maintenance needs, and its proposed location shall be provided to the U.S. EPA Region 4, the Department's Bureau of Ambient Monitoring and Mobile Sources in Tallahassee, the Department's Northeast District, and the Jacksonville RESD's Air & Water Quality Division Offices for review at least 45 days prior to installation.

[0310047-002-AC; Administrative Permit Correction to 0310047-002-AC, dated/clerked 5/22/2000; and, 40 CFR 75]

21 West Church Street  
Jacksonville, Florida 32202-3139

RECEIVED

MAY 21 2001

BUREAU OF AIR REGULATION



May 18, 2001

Mr. Bruce Mitchell, P.E.  
Environmental Administrator  
Department of Environmental Protection  
Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, FL 32399-2400

ELECTRIC

WATER

SEWER

RE: Kennedy Generating Station, Permit No. 0310047-008-AV  
Request for Administrative Permit Correction

Project No.: 0310047-010-AV

Dear Mr. Mitchell:

Per our conversation, please issue an administrative permit correction to the above referenced permit incorporating the below minor revisions:

- Change the name of the permittee from Jacksonville Electric Authority to JEA, our new name after the merger with the city water and sewer department.
- Correct a typo in specific condition D.4. Specifically, "and 1260" should be "or 1260".
- Please incorporate the change made to specific condition 40 in permit No. 0310047-002-AC through a permit correction dated May 22, 2000.

If you have any questions with regard to this matter, please contact me at (904) 665-6247.

Sincerely,

A handwritten signature in black ink, appearing to read 'N. Bert Gianazza'.

N. Bert Gianazza, P.E.  
Environmental Permitting  
& Compliance Group



# Department of Environmental Protection

RECEIVED

Division of Air Resource Management

MAR 12 2004

## RESPONSIBLE OFFICIAL NOTIFICATION FORM

BUREAU OF AIR REGULATION

Note: A responsible official is not necessarily a designated representative under the Acid Rain Program. To become a designated representative, submit a certificate of representation to the U.S. Environmental Protection Agency (EPA) in accordance with 40 CFR Part 72.24.

### Identification of Facility

Facility F Dist Kennedy 0310047 Brandy Branch 0310485

|   |                  |
|---|------------------|
| 1. Facility Owner/Company Name:<br>JEA  |                  |
| 2. Site Name: Kennedy and Brandy Branch<br>Generating Stations                              | 3. County: Duval |
| 4. Title V Air Operation Permit/Project No. (leave blank for initial Title V applications): |                  |

### Notification Type (Check one or more)

INITIAL: Notification of responsible officials for an initial Title V application.

RENEWAL: Notification of responsible officials for a renewal Title V application.

CHANGE: Notification of change in responsible official(s).  
Effective date of change in responsible official(s) \_\_\_\_\_

### Primary Responsible Official

|  |
|--|
| 1. Name and Position Title of Responsible Official:<br>James Chansler, Vice President of Operations and Maintenance  |
| 2. Responsible Official Mailing Address:<br>Organization/Firm: JEA<br>Street Address: 21 West Church Street<br>City: Jacksonville State: FL Zip Code: 32202  |
| 3. Responsible Official Telephone Numbers:<br>Telephone: (904 ) 665-4433 Fax: (904 ) 665- 7263   |
| 4. Responsible Official Qualification (Check one or more of the following options, as applicable):<br><input checked="" type="checkbox"/> For a corporation, the president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy or decision-making functions for the corporation, or a duly authorized representative of such person if the representative is responsible for the overall operation of one or more manufacturing, production, or operating facilities applying for or subject to a permit under Chapter 62-213, F.A.C.<br><input type="checkbox"/> For a partnership or sole proprietorship, a general partner or the proprietor, respectively.<br><input checked="" type="checkbox"/> For a municipality, county, state, federal, or other public agency, either a principal executive officer or ranking elected official.<br><input checked="" type="checkbox"/> The designated representative at an Acid Rain source. |
| 5. Responsible Official Statement:<br><br><i>I, the undersigned, am a responsible official, as defined in Rule 62-210.200, F.A.C., of the Title V source addressed in this notification. I hereby certify, based on information and belief formed after reasonable inquiry, that the statements made in this notification are true, accurate and complete. Further, I certify that I have authority over the decisions of all other responsible officials, if any, for purposes of Title V permitting.</i><br><br>Signature _____ Date 3.9.04  |

**Additional Responsible Official**

|   |
|---|
| 1. Name and Position Title of Responsible Official:<br><u>Bruce Hill, Director of Electric Production of the CTs</u>  |
| 2. Responsible Official Mailing Address:<br>Organization/Firm: Kennedy Generating Station<br>Street Address: 4215 Tallyrand Avenue<br>City: Jacksonville State: FL Zip Code: 32206  |
| 3. Responsible Official Telephone Numbers:<br>Telephone: (904 )665-6263 Fax: ( 904 ) 665- 4398  |
| 4. Responsible Official Qualification ( <i>Check one or more of the following options, as applicable</i> ):<br><input checked="" type="checkbox"/> For a corporation, the president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy or decision-making functions for the corporation, or a duly authorized representative of such person if the representative is responsible for the overall operation of one or more manufacturing, production, or operating facilities applying for or subject to a permit under Chapter 62-213, F.A.C.<br><input type="checkbox"/> For a partnership or sole proprietorship, a general partner or the proprietor, respectively.<br><input type="checkbox"/> For a municipality, county, state, federal, or other public agency, either a principal executive officer or ranking elected official.<br><input type="checkbox"/> The designated representative at an Acid Rain source. |

3-17-04 12  
Done:  
RBM

**Mitchell, Bruce**

---

**To:** Boutwell, Barbara  
**Cc:** Fancy, Clair; Sheplak, Scott  
**Subject:** Posting for EPA an Admin. Correction for JEA-Kennedy Generating Station: 0310047-006-AV.

6/1/2001

Dear Barbara,

Here's the project for posting (attached). Many thanks.

Bruce

0310047.admincorr.do

c