

## DeVore, Christy

---

**From:** Waters, G. Dwain [GDWATERS@southernco.com]  
**Sent:** Monday, April 12, 2010 10:20 AM  
**To:** DeVore, Christy; Koerner, Jeff  
**Cc:** White, Kevin  
**Subject:** Minor comments: Crist Pre-Draft Permit for Review and Comment

**Importance:** High

Only a few minor comments and Gulf is good to go.

- 1) Page 6 technical document; 3rd paragraph: has a typo in last sentence: "don"
- 2) Permit: Add Kevin White to cc list.
- 3) Permit: Page 6; item #3. FGD Bypass: add "with authorized fuels" after: The permittee may bypass "with authorized fuels" the FGD system.... This makes it clear that we can use natural gas to supplemental fire as you already added this in the technical document.
- 4) Just need to make sure you understand that the Inlet CEM FGD SO2 monitor noted in items 8, 10, 13 on page 7 is not certified. It is a operational FGD monitor that is not required. Again, there are no test ports in the inlet duct for testing or certifying this monitor. We will maintain this monitor with daily calcs, etc. We can conduct quarterly "Linearity Tests" on it to insure its accuracy.

That's it. Thanks again for the opportunity to comment. Dwain

G. Dwain Waters, Q.E.P.  
Special Projects and Environmental Assets Coordinator  
Gulf Power Company  
One Energy Place  
Pensacola, Florida 32520-0328  
Phone: (850) 444-6080  
Cell: (850) 336-6527  
Fax: (850) 444-6217  
[gdwaters@southernco.com](mailto:gdwaters@southernco.com)

---

**From:** DeVore, Christy [mailto:Christy.DeVore@dep.state.fl.us]  
**Sent:** Friday, April 09, 2010 2:05 PM  
**To:** Waters, G. Dwain  
**Cc:** Gibson, Victoria; Koerner, Jeff  
**Subject:** Crist Pre-Draft Permit for Review and Comment

Have a great weekend, enjoy.

*Christy DeVore, P.E.*  
Professional Engineer II  
Division of Air Resource Management  
Bureau of Air Regulation  
New Source Review  
2600 Blair Stone Road, MS#5505  
Tallahassee, FL 32399-2400  
Telephone (850) 921-8968

FAX (850) 921-9533

*The Department of Environmental Protection values your feedback as a customer. DEP Secretary Michael W. Sole is committed to continuously assessing and improving the level and quality of services provided to you. Please take a few minutes to comment on the quality of service you received. Simply click on [this link to the DEP Customer Survey](#). Thank you in advance for completing the survey.*