

DeVore, Christy

From: Waters, G. Dwain [GDWATERS@southernco.com]
Sent: Friday, February 26, 2010 3:47 PM
To: DeVore, Christy
Subject: RE: Crist Revised SAM Cap

For NOx only. The CEM rate as NOx lb/mmbtu * heat input from fuel for all units for the period Jun06 - May 08. This was the high mass total for all 4 units post any NOx controls were placed in service on any of the 4 units. I don't have readily available month by month CEM data for Jun06-May08 since we store it my fiscal year for Acid Rain reports. It would take some time to look this up. I do have the CEM rate on a month by month, but not mass month by month. Hope this makes sense.

G. Dwain Waters, Q.E.P.
Special Projects and Environmental Assets Coordinator
Gulf Power Company
One Energy Place
Pensacola, Florida 32520-0328
Phone: (850) 444-6080
Cell: (850) 336-6527
Fax: (850) 444-6217
gdwaters@southernco.com

From: DeVore, Christy [mailto:Christy.DeVore@dep.state.fl.us]
Sent: Friday, February 26, 2010 2:05 PM
To: Waters, G. Dwain
Subject: RE: Crist Revised SAM Cap

Please explain how NOx was calculated. Was the fuel data used and the NOx lb/MMBtu from CEMs? The cap requires CEMs data be used. Thanks.

*Christy DeVore, P.E.
Bureau of Air Regulation
New Source Review
Telephone (850) 921-8968*

-----Original Message-----

From: Waters, G. Dwain [mailto:GDWATERS@southernco.com]
Sent: Thursday, February 25, 2010 2:56 PM
To: Koerner, Jeff; DeVore, Christy
Subject: Crist Revised SAM Cap
Importance: High

Please find attached the Crist revised SAM Cap summary table for the HSC and Turbine Projects. Please call me if you have any questions. Thanks, Dwain

G. Dwain Waters, Q.E.P.
Special Projects and Environmental Assets Coordinator Gulf Power Company One Energy
Place
Pensacola, Florida 32520-0328
Phone: (850) 444-6080
Cell: (850) 336-6527
Fax: (850) 444-6217
gdwaters@southernco.com