

DeVore, Christy

From: Waters, G. Dwain [GDWATERS@southernco.com]
Sent: Monday, February 22, 2010 5:26 PM
To: DeVore, Christy
Subject: RE: Crist RAI

For Cr 6 Turbine Baseline dates

SO2 Oct 06 - Sep 08
NOx Dec 05 - Nov 07
PM Jun 06 - May 08 (Heat input Jun06-May 08 * 5 yr avg PM test rate)
CO June 06 - May 08 (Heat input June06- May 08 * AP42 factor)
VOC June 06 - May 08 (Heat input June06-May 08 * Ap-42 factor)

G. Dwain Waters, Q.E.P.
Special Projects and Environmental Assets Coordinator
Gulf Power Company
One Energy Place
Pensacola, Florida 32520-0328
Phone: (850) 444-6080
Cell: (850) 336-6527
Fax: (850) 444-6217
gdwaters@southernco.com

From: DeVore, Christy [mailto:Christy.DeVore@dep.state.fl.us]
Sent: Monday, February 22, 2010 2:45 PM
To: Waters, G. Dwain
Subject: Crist RAI

Where is the information showing the 2-year period used for the pollutants other than SAM? Jeff remembers you mentioning it and I'm looking for it. Thanks.

Christy DeVore, P.E.
Professional Engineer II
Division of Air Resource Management
Bureau of Air Regulation
New Source Review
2600 Blair Stone Road, MS#5505
Tallahassee, FL 32399-2400
Telephone (850) 921-8968
FAX (850) 921-9533