

## DeVore, Christy

---

**From:** DeVore, Christy  
**Sent:** Tuesday, February 23, 2010 3:47 PM  
**To:** 'Waters, G. Dwain'  
**Subject:** RE: Crist RAI

As we discussed the same baseline periods must be used for all the units, so what you provided below needs to be for Units, 4, 5 and 7 too. The baseline periods can change for different pollutants as shown below. I looked at the tables and am not seeing the baseline periods, so I can't verify it's the same for all the units. Let me know when you call us back. Thank you.

*Christy DeVore, P.E.  
Bureau of Air Regulation  
New Source Review  
Telephone (850) 921-8968*

---

**From:** Waters, G. Dwain [mailto:GDWATERS@southernco.com]  
**Sent:** Monday, February 22, 2010 5:26 PM  
**To:** DeVore, Christy  
**Subject:** RE: Crist RAI

For Cr 6 Turbine Baseline dates

SO2 Oct 06 - Sep 08  
NOx Dec 05 - Nov 07  
PM Jun 06 - May 08 (Heat input Jun06-May 08 \* 5 yr avg PM test rate)  
CO June 06 - May 08 (Heat input June06- May 08 \* AP42 factor)  
VOC June 06 - May 08 (Heat input June06-May 08 \* Ap-42 factor)

G. Dwain Waters, Q.E.P.  
Special Projects and Environmental Assets Coordinator  
Gulf Power Company  
One Energy Place  
Pensacola, Florida 32520-0328  
Phone: (850) 444-6080  
Cell: (850) 336-6527  
Fax: (850) 444-6217  
[gdwaters@southernco.com](mailto:gdwaters@southernco.com)

---

**From:** DeVore, Christy [mailto:Christy.DeVore@dep.state.fl.us]  
**Sent:** Monday, February 22, 2010 2:45 PM  
**To:** Waters, G. Dwain  
**Subject:** Crist RAI

Where is the information showing the 2-year period used for the pollutants other than SAM? Jeff remembers you mentioning it and I'm looking for it. Thanks.

*Christy DeVore, P.E.  
Professional Engineer II*

Division of Air Resource Management  
Bureau of Air Regulation  
New Source Review  
2600 Blair Stone Road, MS#5505  
Tallahassee, FL 32399-2400  
Telephone (850) 921-8968  
FAX (850) 921-9533