

RECEIVED

MAY 17 2012

DIVISION OF AIR
RESOURCE MANAGEMENT



Hand Delivery

April 30, 2012

Mr. Rick Bradburn
Florida Department of Environmental Protection
Northwest District
160 Governmental Center
Pensacola, FL 32501-5794

Dear Mr. Bradburn:

**RE: CRIST ELECTRIC GENERATING PLANT
PLANT WIDE QUARTERLY SAM UPDATE
PERMIT No: 0330045-028-AC**

Below please find Table 1 indicating Plant Crist's current compliance status with the Plant-wide SO3 limit of 165.5 tons per consecutive 12 months, as outlined in Specific Condition 8 of Air Construction Permit 0330045-028-AC. The results in Table 1 reflect the SO3 reductions as verified by quarterly test results.


Table 1

Plant Crist 12 Month SO3 Emissions Summary	
Month-Year	SO3 Emissions (tons)
Apr-2011	3.08
May-2011	3.20
Jun-2011	2.42
Jul-2011	2.76
Aug-2011	2.88
Sep-2011	2.07
Oct-2011	1.61
Nov-2011	1.72
Dec-2011	6.36
Jan-2012	7.95
Feb-2012	7.13
Mar-2012	9.26
Total	50.44
Compliance Margin	70%

As noted in the Test Plan submitted on April 5, 2012, SO3 testing is planned in June 2012 after startup on the SCR on Unit 6, and a final report will follow.

If you have any questions or need further information regarding the draft test protocol, please call me at 850.444.6144.

Sincerely,



Gregory N. Terry
Air Quality Programs Supervisor

cc: w/att: Jim Vick, Gulf Power Company
Jora Maxwell, Gulf Power Company
Jeff Koerner, FDEP-Tallahassee