

## Florida Department of Environmental Protection

Bob Martinez Center 2600 Blair Stone Road, MS#5505 Tallahassee, Florida 32399-2400 Rick Scott Governor

Jennifer Carroll
Lt. Governor

Herschel T. Vinyard Jr. Secretary

August 17, 2012

Ms. Lynda Crum, Associate Regional Counsel United States Environmental Protection Agency, Region 4 Office of Environmental Accountability Office of Legal Support 61 Forsyth Street SW Atlanta, GA 30303

Re:

Air Program: Gulf Power Company's Application for Certification of Pollution Control Facility

Crist Electric Generating Plant

Dear Ms. Crum:

Enclosed is a signed copy of an "Application for Certification of Pollution Control Facility" (EPA Form 3300-1) submitted by the Gulf Power Company. The Gulf Power Company is requesting this certification for the selective catalytic reduction system (SCR) installed on Unit 6 at the Crist Electric Generating Plant in Pensacola, Florida. In accordance with the instructions on the EPA forms and 40 CFR 20.6, the State is required to certify that the facility described in the application has been constructed in conformity with state requirements. The state requirement applicable to this facility is the requirement to obtain an air construction permit for the new control equipment. The new equipment was installed to reduce nitrogen oxides emissions and facilitate compliance with the Clean Air Interstate Rule (CAIR) and the DEP-Gulf Power Ozone Agreement. My staff has certified that the Gulf Power Company obtained the appropriate state air construction permit and that the SCR system is in operation.

I am forwarding the application to you for a determination and federal certification that the facility is a "treatment facility" pursuant to 40 CFR 20.8, 26 USC 169 and rules promulgated thereunder.

If you have any questions, please contact Jeff Koerner at 850-717-9083.

Sincerely,

Brian Accardo, Director

Division of Air Resource Management

BA/ik

Enclosure

cc: Kay Prince, C

Kay Prince, Chief, Air Planning Branch, EPA Region 4

James O. Vick, Director of Environmental Affairs, Gulf Power Company

Greg Terry, Gulf Power Company

GULF POWER
A SOUTHERN COMPANY

July 17, 2012

### **APPLICATION FOR CERTIFICATION**

Pollution Control Facility (2012)
Via US Mail and Electronic Mail - Electronic Receipt Requested

DEPARTMENT OF ENVIRONMENTAL PROTECTION

IJUL 25 12012

SITING COORDINATION

Cindy Mulkey, Program Administrator Email: SCO@dep.state.fl.us Florida Department of Environmental Protection Office of Siting Coordination Douglas Building, MS# 48 3900 Commonwealth Boulevard Tallahassee, FL 32399-3000

Dear Ms. Mulkey:

Enclosed please find a signed copy of an "Application for Certification of Pollution Control Facility". This application consists of EPA Form 3300-1 for the following pollution control facility:

Plant Crist Unit 6- Selective Catalytic Reduction (SCR) System

According to instructions supplied by the U.S. Environmental Protection Agency (EPA), the State of Florida must grant certification through EPA Form 3300-1, enclosed. After processing, the form should be forwarded to the address below or returned to Gulf Power for forwarding.

Lynda Crum, Associate Regional Counsel USEPA, Region 4
Office of Environmental Accountability
Office of Legal Support
61 Forsyth St. SW
Atlanta, GA 30303

A copy of the signed State Certification should also be mailed to Gulf Power Environmental Affairs, attention Greg Terry. If the facility is denied certification, please provide Gulf Power a written explanation of the rationale for the determination. The remaining copy of the application may be retained by the State for its records.

We appreciate your review of this application. If you need any assistance in this process, please contact Greg Terry at (850) 444-6144, gnterry@southernco.com.

Sincerely,

James O. Vick

Director of Environmental Affairs

Cc:

Lvnda Crum, EPA

Greg Terry, Gulf Power Company

RECEIVED

JUL 26 2012

DIVISION OF AIR RESOURCE MANAGEMENT

#### **ENVIRONMENTAL PROTECTION AGENCY**

APPLICATION FOR CERTIFICATION OF POLLUTION CONTROL FACILITY (Pursuant to Section 169 of the Internal Revenue Code of 1954, as amended)

NO CERTIFICATION MAY BE MADE UNLESS A COMPLETED APPLICATION FORM HAS BEEN RECEIVED (26 U.S.C. ξ169; 40 C.F.R. PART 20). IF NO CLAIM OF BUSINESS CONFIDENTIALITY ACCOMPANIES THIS INFORMATION WHEN IT IS RECEIVED BY EPA, IT MAY BE MADE AVAILABLE TO THE PUBLIC BY EPA WITHOUT FURTHER NOTICE. INFORMATION COVERED BY A CLAIM OF CONFIDENTIALITY WILL BE DISCLOSED BY EPA ONLY TO THE EXTENT, AND BY MEANS OF THE PROCEDURES, SET FORTH IN TITLE 40, CODE OF FEDERAL REGULATIONS, PART 2, 41 C.F.R. 26902 et seq., SEPTEMBER 1, 1976.

A BUSINESS CONFIDENTIALITY CLAIM COVERING ALL OR PART OF THE INFORMATION FURNISHED IN OR WITH THIS APPLICATION MAY BE ASSERTED BY PLACING AN (OR ATTACHING TO) THE INFORMATION AT THE TIME IT IS SUBMITTED TO EPA, A COVER SHEET STAMPED OR TYPED LEGEND, OR OTHER SUITABLE FORM OF NOTICE EMPLOYING LANGUAGE SUCH AS "TRADE SECRET," "PROPRIETARY," OR "COMPANY CONFIDENTIAL." ALLEGEDLY CONFIDENTIAL PORTIONS OF OTHERWISE NON-CONFIDENTIAL DOCUMENTS SHOULD BE CLEARLY IDENTIFIED, AND MAY BE SUBMITTED SEPARATELY TO FACILITATE IDENTIFICATION AND HANDLING BY EPA. IF THE APPLICANT DESIRES CONFIDENTIAL TREATMENT ONLY UNTIL A CERTAIN DATE OR UNTIL THE OCCURRENCE OF A CERTAIN EVENT, THE NOTICE SHOULD SO STATE.

Application is hereby made for certification of the pollution control facility described herein. The following is submitted in accordance with provisions of Part 20 of Title 40 of the Code of Federal Regulations and to the best of my knowledge and belief is true and correct.

APPLICANT	DATE
Michael L. Burroughs	July 18, 2012
SIGNATURE	STREET ADDRESS, CITY, STATE, ZIP CODE
Michael Glurrought	One Energy Place, Pensacola, FL 32520-0100
Vice-President and Senior Production Officer	

#### SECTION A - IDENTITY AND LOCATION OF CONTROL FACILITY

I. FULL BUSINESS NAME OF API	PLICANT			OWNERSHIP
		[] INDIVIDU		
		[ ] PARTNER [X] CORPOR		
<ol> <li>PERSON TO CONTACT REGAL</li> <li>Greg Terry, Air Quality Programs Super</li> </ol>	RDING THIS APPLICATION (Name and Ti	tle)		: <b>LEPHONE</b> <del>444</del> -61 <del>44</del>
Greg Ferry, All Quality Frograms Superv	vi301		030-	
ADDRESS (Street, City, State, Zip Cod				
One Energy Place, Pensacola, Florida, 325	520-0328			
	CEIVE CERTIFICATION (Name and Title)	· · · · ·		
Michael L. Burroughs, Vice-President and	d Senior Production Officer			
5. BUSINESS NAME OF PLANT (IF	different from Item I) (Street, City, State, Zip	Code)	6. AI	PPLICANT'S EMPLOYER
Crist Electric Generating Plant			ID.	ENTIFICATION NO.
11999 Pate Street Pensacoia, FL 32514			59-02	76810
1 DESCRIBE THE EACH ITY FOR MAILI	SECTION B - DESCRIPTION ( CH CERTIFICATION IS SOUGHT. INCLUDE			IDED AND
	I CRITERIA, ENGINEERING REPORT AND/OI			
DESCRIBE FUNCTION AND OPERA	ATION OF FACILITY: Gulf Power will install o	on Plant Crist Unit 6		
is designed to provide no less than ar	85% reduction of nitrogen oxides when ope	erating.		
2. IS FACILITY IN OPERATION?	A. IF "YES" DATE FACILITY	B. IF "NO" DATE F	ACILITY	3. IF FACILITY CONSISTS OF A
2. IS FACILITY IN GILBATION:	WAS PLACED IN OPERATION	IS EXPECTED TO		BUILDING, IS IT EXCLUSIVE-
[X] YES ] NO		PLACED IN OPE	RATION	LY FOR CONTROL OF
		May 2012		POLLUTION? [X] YES [] NO
	December 31, 1975 ONLY) AFFECT THE OPERA ) MOST DIRECTLY ASSOCIATED WITH THE			rty in
REDUCE THE TOTAL OPERATING	CITY [ ] YES [ X ] NO EXTEND THE USI	EFUL LIFE? [ ] YES	[X]NO	
a. IF THE ANSWER TO ANY OF TH	IE ABOVE IS "YES" IS THE PERCENTAGE BY \	WHICH THE OPERA	TING UNIT WA	S EFFECTED
	NCREASES, EXTENSIONS, OR REDUCTIONS	EXCEEDING 5% ST	ATE THE RATIO	NALE AND
FURNISH THE DATA USED TO ARRIVE AT THE PERCENTAGE(S) GIVEN IN RESPONSE TO ITEM 4(a).				
	SECTION C - DESCRIPTION OF COMM			Υ
	N CONNECTION WITH WHICH FACILITY I valled fired, dry bottom boiler used to			Lat a maximum heat input of
3704.8 million Btu per hour when	n firing pulverized coal, natural gas, or	distillate fuel oll.	NOX emission	is are currently controlled by Low
NOX Burners and by a Selective I	Non-Catalytic Reduction (SNCR) syster	n designed to ach	ileve no less ti	han a 20% reduction in NOX
emissions as measured across the	e SNCR unit inlet and outlet. The design e selective catalytic reduction system we	ined target ammo which will be instal	onia siip ievel iled on linit 6	is 5 ppmy corrected to 3% O2 will be used to reduce the amount
of NOx in the flue gas.	. Selective education system w	Willest Will be mistal	iled on onle o	Will be used to reduce the amount
STANDARD INDUSTRIAL CLASSIFI	CATION (CIC) CODE NI IMPER	r		
4911	,			
3. DATE THAT EACH PLANT OR OTHER PROPERTY IN CONNECTION WITH WHICH FACILITY IS OR WILL BE USED, COMMENCE OPERATION.				
PLANT OR PROPERTY			DATE	
A. Plant Crist commenced commercial operation with Unit I (now retired)			January I, 1945	
B. Unit 6 commenced commercial operation		May 31, 1970		
c				
<u> </u>	<u> </u>	•		

Form Approved OMB No. 158-R0013

	SECTION C - DESCRIPTION OF COMM	EPCIAL PROCESS OF ACTIVITY
SECTION C - DESCRIPTION OF COMMERCIAL PROCESS OR ACTIVITY  4A. IF FACILITY IS OR WILL BE USED IN CONNECTION WITH MORE THAN ONE PLANT OR PROPERTY, AND IF ONE OR MORE OF THE PLANTS OR PROPERTIES IN CONNECTION WITH WHICH THE FACILITY IS OR WILL BE USED WAS NOT IN OPERATION PRIOR TO JANUARY I, 1976, STATE THE PERCENTAGE OF THE COST OF FACILITY WHICH IS ALLOCABLE TO THE PLANT(S) OR PROPERTY(IES) IN OPERATION PRIOR TO THAT DATE		
Not Applicable		
4B. DESCRIBE THE REASONING AT	ND FURNISH THE DATA USED TO ARRIVE AT TH	HE PERCENTAGE GIVEN IN RESPONSE TO ITEM 4(A).
Not Applicable		
	OTION OR FUNCTIONS IN ADDITION TO THE A PF FACILITY ALLOCABLE TO THE ABATEMENT O	
ITEM 5(A).	ND FURNISH THE DATA USED TO ARRIVE AT TH	HE PERCENTAGE GIVEN IN RESPONSE TO
Not Applicable	HARACTERISTICS (To be completed only in	connection with facilities for the control of water pollution)
DESCRIBE THE EFFECT OF POLLUTION CONTROL FACILITY IN TERMS OF QUANTITY AND QUALITY OF EMISSION AND OF WASTES OR BY-PRODUCTS REMOVED, ALTERED, DISPOSED OF, OR PREVENTED. IF FEASIBLE, ATTACH PROCESS FLOW OR SCHEMATIC DIAGRAM WITH MATERIAL BALANCES OF THE WASTE OR WASTEWATER STREAM OR DISCHARGE. REPORT EITHER ON ACTUAL BASIS OR, IF FACILITY IS NOT YET IN OPERATION, ON DESIGN BASIS (Use Standard Units - pounds/gallon, grams/liter. ppm, etc.).		
Not Applicable  I. HOURS PLANT OR PROPER	TY IS IN OPERATION a. Per Month: Min	n Max Avg
		Max Avg
2. WASTEWATER	WITHOUT POLLUTION CONTROL FACE	LITY WITHOUT POLLUTION CONTROL FACILITY
DISCHARGE IN		
(A) GALLONS PER	a. Min Max Avg	Min Max Avg
MINUTE, (B) MILLIONS OF GALLONS	b. Min Max Avg	Min Max Avg
		· · · · · · · · · · · · · · · · · · ·
3. POLLUTANTS OR WASTE I	PRODUCTS	
3.a	Min Max Avg	Min Max Avg
3.b	Min Max Avg	Min Max Avg
3.c	Min, Max Avg	Min Max Avg
3,.d	Min Max Avg	Min Max Avg
3.e	Min Max, Avg	Min Max Avg
3.f	Min Max Avg	Min Max Avg
3.g	Min, Max Avg	Min Max Avg
3.h	Min Max Avg	Min Max Avg
3.i	Міп Мах Avg	Min Max Avg
3.j	Min Max Avg	Min Max Avg

Form Approved OMB No. 158-R0013

OF POLLUTANTS.	. COMPOSITE) AND FREQUENCY OF SAMPLING AND METI	HODS USED TO DETERMINE QUANTITIES
	FACILITY TO PREPARE WASTEWATER FOR RECEIPT BY APTMENT? IF "YES", SKIP ITEMS 6, 7 AND 8 AND IDENTIFY RE	
	AM OF WATER INTO WHICH WASTEWATER FROM THE P 5 USED, IS OR WILL BE DISCHARGED.	LANT OR PROPERTY, IN CONNECTION
7. DESCRIBE LOCATION OF DISC	HARGE OR OUTFALL WITH RESPECT TO RECEIVING WAT	TERS.
[] YES [] NO IF "NO," PR	TREAM OF WATER A NAVIGABLE WATERWAY OF THE UI OCEED TO ITEM 9. CORPS OF ENGINEERS DISCHARGE PERMIT BEEN APPLIED F	
EXPLAIN, THEN PROCEED  B. IF ANSWER TO ITEM 8A IS '  (1) IF "YES," ATTACH COP'		PERMIT BEEN ISSUED? [] YES [] NO _OMIT ITEM 9.
IF ITEM 8B HAS NOT BEEN ANSW STANDARDS.	ERED "YES," IDENTIFY STATE AND LOCAL WATER POLLU	TION CONTROL REQUIREMENTS AND
DESCRIBE THE EFFECT OF POLLU EMISSION AND OF WASTES OR B FLOW OR SCHEMATIC DIAGRAM	CHARACTERISTICS (To be completed only in connection CONTROL FACILITY IN TERMS OF QUANTITY AND Y-PRODUCTS REMOVED, ALTERED, DISPOSED OF, OR PREWITH MATERIAL BALANCES OF POLLUTANTS IN THE EMITY IS NOT YET IN OPERATION, ON DESIGN BASIS.  RTY IS IN OPERATION  a. Per Month: Min No Per Year: MIN	QUALITY OF EMISSION AND OF VENTED. IF FEASIBLE, ATTACH PROCESS ISSION STREAM. REPORT EITHER
2. POLLUTANTS TO BE CONTROLLED (Specify each)	a. NOx b	
3. VOLUMETRIC FLOW RATE OF EMISSION (actual cubic feet/minute)	Min Max Avgat°F	Min Max Avg at°F
4. CONCENTRATION (In volume % of gaseous components)	a. Min Max0.50 Avg0.50_ at°F b. Min Max Avgat _°F	Min Max. <u>0.15                                    </u>
Both values are lb/mmBTU	c. Min Max Avg at °F  d. Min Max Avg at °F	Min Max Avg at °F  Min Max Avg at °F
5. CONCENTRATION (grains/cubic feet of all particulate matter)  6. CONCENTRATION	Min Max Avg at°F	Min Max Avg at°F
(grains/cubic feet of any particulate listed in E-2 above)	Min Max Avg at°	Min Max Avg at °F

7. DESCRIBE METHOD OF DETERM	MINING RATES, CONCENTRATION AND CHARACTERISTICS OF EMISSIONS.	
Based on Design Specifications.		
8. IDENTIFY APPLICABLE STATE A	ND LOCAL AIR POLLUTION CONTROL REQUIREMENTS AND STANDARDS.	
For NOx emissions, Crist Units 4 -5-	6-7 are required to meet a plant-wide 30-day average of 0.20 lb/mmBtu permit limit.	
	COST INFORMATION (See Note to instructions for this section	
	ATERIAL WHICH, WITHOUT THE CONTROL FACILITY, WOULD BE LOST AND WHICH IS SE OF THE FACILITY? [ ] YES [X] NO	
A. IF YES, IDENTIFY		
B. INDICATE THE DISPOSITION OF EACH TYPE OF RECOVERED MATERIAL, INCLUDING IF APPLICABLE, THE SALE OR SIMILAR DISPOSITION OF RECLAIMED OR RECOVERED MATERIAL TO INDUSTRIAL WASTE RECOVERY FIRMS OR OTHERS.		
	A. MATERIAL RECOVERED AND SOLD	\$ 
2. ANNUAL COST	B. OTHER	s
RECOVERY		
	C. TOTAL	\$
3. TOTAL AVERAGE ANNUAL MA	NTENANCE AND OPERATING COSTS	
(Not applicable if no cost recovery is reported in Item 2)		

# ENVIRONMENTAL PROTECTION AGENCY NOTICE OF STATE CERTIFICATION (Pursuant to Section 169 of the Internal Revenue Code of 1954, as amended) WATER OR AIR POLLUTION CONTROL AGENCY OR AUTHORITY - DEPT. OF NATURAL RESOURCES, ENVIRONMENTAL PROTECTION DIVISION, AIR POLLUTION BRANCH

It is hereby certified that the control facility described in the attached application is in conformity with State and local programs and requirements for the control of [] water pollution [X] air pollution, as required by section 169 of the Internal Revenue Code of 1954, as amended, and regulations issued thereunder. According to the applicant, this control facility [X] was placed [] will be placed in operation on

In the case of control facility not yet in operation, this notice is certification only that the control facility, if constructed and operated in accordance with the application, will be in conformity with State and local programs or requirements for abatement or control of water or air pollution.

I. NAME OF APPLICANT Gulf Power Company	2. PERSON AUTHORIZED TO RECEIVE CERTIFICATION Michael L. Burroughs
ADDRESS (Street, City, State, Zip Code)	TITLE
One Energy Place Pensacola, FL 32520-0100	Vice-President and Senior Production Officer  ADDRESS (Street, City, State, Zip Code)  One Energy Place Pensacola, FL 32520-0100

#### 3. DESCRIPTION OF CONTROL FACILITY

- Basic Design Specifications: The SCR system is designed for a NOX conversion efficiency of 85% based on an inlet NOX emissions rate of 0.50 lb/MMBtu.
- Catalyst Design Specifications: Catalyst typically consist of titanium dioxide and molybdenum oxide with vanadium pentoxide as the active component. The catalyst is fabricated by applying ceramic catalyst material to a perforated stainless steel mesh grid plate. The catalyst structure will be a honey-comb or plate type. The operational temperature range is approximately 600° to 800° F. The initial configuration is for a catalyst volume of approximately 460 cubic meters (16,260 cubic feet) divided between three catalyst layers. The design inlet NOX concentration is 0.5 lb/MMBtu and the design output NOX emissions is 0.07 lb/MMBtu.
- Ammonia Storage and Mixing: Anhydrous ammonia will be stored on site in three 20,500 gallon tanks (two tanks are existing, one new tank will be built as part of this project). Ammonia is diluted with air (< 10% by volume) and injected into the SCR inlet duct through the ammonia injection grid (AIG), which is divided into about two dozen zones. Each zone is equipped with a flow indicator and manual control valve for tuning the AIG to match the inlet NOX profile. Effective ammonia distribution and NOX conversion are dependent on the velocity profile entering the AIG. A static mixer installed upstream of the AIG creates flow resistance, flattens the velocity profile, and provides uniform gas flow. Downstream of the AIG, a second static mixer is positioned at the AIG injection points to impart a swirl to the diluted ammonia and promote good mixing with the flue gas. For 85% NOX conversion, the design molar ratio of ammonia-to-NOX is 0.95 at SCR inlet.

Ammonia Control System: The ammonia control system consists of a control loop with a cascaded, feedforward control scheme. Process monitors will provide NOX emission rate data collected at the inlet to and the outlet from the SCR system. The ammonia injection rate is set based on a variety of input data including the measured NOX rates at the SCR inlet/outlet, the outlet NOX set point, the heat input to the boiler, the actual NOX rate measured by the stack monitor, and a scaling factor based on the molecular weights of ammonia and NOX. The system is capable of continually adjusting flow control valves to fine tune the ammonia injection rate based on changing gas stream conditions.

- Ammonia Silp: The design target ammonia silp level is less than 5 ppmv measured at the stack. There are no provisions for continuously monitoring ammonia concentration in the flue gas. When ammonia measurements in the flue gas are required, a wet chemical method will be utilized. These measurements are taken periodically over the operating life of the SCR catalyst. More frequent tracking of ammonia slip will be monitored by measuring the amount of residual ammonia adsorbed by the fly ash. Fly ash samples will be measured periodically using an ion-specific electrode. Ammonia slip may also be estimated from the ammonia injection monitoring system based on the NOX rate at the SCR inlet/outlet and the ammonia injection rate.
- Gas Sampling Grid (GSG): During commissioning and periodically over the life of the system, it will be necessary to tune the AIG to optimize the distribution of ammonia in the SCR inlet duct relative to the NOX distribution to provide optimum NOX conversion with minimum ammonia slip. To facilitate tuning, a manual gas sampling grid (GSG) is installed downstream of the last catalyst layer. The GSG allows a high-resolution traverse of the flue gas stream for composition across the outlet of the SCR, which can be used to precisely adjust the AIG. The GSG is comprised of individual small-bore (~½") heavy-wall pipes extending from outside the SCR to distributed sampling locations below the last catalyst layer. Portable equipment is used to sample and measure gas concentrations using the GSG.
- SCR Bypass: The SCR design incorporates dampers and ductwork to provide the capability of bypassing the SCR system. The bypass is most commonly used to gradually heat or cool the catalyst structure to minimize thermal fatigue during startup and shutdown. During catalyst maintenance and repair, it would also allow access to the SCR reactor without requiring complete shutdown of the Unit 6 boiler.

4. LOCATION OF CONTROL FACILITY (Street, City, State, Zip Code)	5. RECEIVING BODY OR STREAM OF WATER, IF AN'
Crist Electric Generating Plant	Not Applicable
11999 Pate Street	

Pensacola, FL 32514

Form Approved OMB No. 158-R0013

6. USE IF THE CONTROL FACILITY CERTIFIED HEREBY IS IN CONFORMITY WITH CONTROL OF [ ] WATER POLLUTION [X] AIR POLLUTION.	THE FOLLOWING APPLICABLE STATE PLAN OR REQUIREMENTS FOR THE
THIS 17 DAY OF PUGUST 2012	SIGNED (Official of State Agency)
STATE CERTIFICATION NUMBER	Program Administrator

Office of Permitting and confliance Division of Air Resource Mangament Floride Department of Environmental Protection

#### U.S. ENVIRONMENTAL PROTECTION AGENCY

#### NOTICE OF FEDERAL CERTIFICATION

(Pursuant to Section 169 of the Internal Revenue Code of 1954, as amended)

PLEASE TAKE NOTICE that pursuant to section 169 of the Internal Revenue Code of 1954, as amended, and Part 20 of Title 40 of the Code of Federal Regulations, the control facility identified herein

[ ] Is certified

[X] Will, if constructed, reconstructed, acquired, erected, installed and operated in accordance with the accompanying application, be certified

as being in compliance with the applicable regulations of Federal agencies and the general policies of the Untied States for cooperation with the States in the prevention and abatement of [ ] water pollution [ X] air pollution under the Federal Water Pollution Control Act, as amended (33 U.S.C. 1251 et seq.) or the Clean Air Act, as amended (42 U.S.C. 1857 et seq.). This certification is based on facts furnished by the applicant, and is valid for purposes of section 169 only to the extent that such facts are complete and accurate.

#### I. NAME OF APPLICANT

ADDRESS (Street, City, State, Zip Code)

Gulf Power Company

One Energy Place

2. EMPLOYER IDENTIFICATION NUMBER

Pensacola, FL 32520-0100

#### PERSON AUTHORIZED TO RECEIVE CERTIFICATION

NAME

Michael L. Burroughs

ADDRESS (Street, City, State, Zip Code) One Energy Place

TITLE

Vice-President and Senior Production Officer

Pensacola, FL 32520-0100

#### 4. DESCRIPTION OF CONTROL FACILITY

- Basic Design Specifications: The SCR system is designed for a NOX conversion efficiency of 85% based on an inlet NOX emissions rate of 0.50 lb/MMBtu.
- · Catalyst Design Specifications: Catalyst typically consist of titanium dioxide and molybdenum oxide with vanadium pentoxide as the active component. The catalyst is fabricated by applying ceramic catalyst material to a perforated stainless steel mesh grid plate. The catalyst structure will be a honey-comb or plate type. The operational temperature range is approximately 600° to 800° F. The initial configuration is for a catalyst volume of approximately 460 cubic meters (16,260 cubic feet) divided between three catalyst layers. The design inlet NOX concentration is 0.5 lb/MMBtu and the design output NOX emissions is 0.07
- · Armonia Storage and Mixing: Anhydrous ammonia will be stored on site in three 20,500 gallon tanks (two tanks are existing, one new tank will be built as part of this project). Ammonla is diluted with air (< 10% by volume) and injected into the SCR injet duct through the ammonia injection grid (AIG), which is divided into about two dozen zones. Each zone is equipped with a flow Indicator and manual control valve for tuning the AIG to match the inlet NOX profile. Effective ammonia distribution and NOX conversion are dependent on the velocity profile entering the AIG. A static mixer installed upstream of the AIG creates flow resistance, flattens the velocity profile, and provides uniform gas flow. Downstream of the AIG, a second static mixer is positioned at the AIG injection points to impart a swirl to the diluted ammonia and promote good mixing with the flue gas. For 85% NOX conversion, the design molar ratio of ammonia-to-NOX is 0.95 at SCR inlet.

Ammonia Control System: The ammonia control system consists of a control loop with a cascaded, feed forward control scheme. Process monitors will provide NOX emission rate data collected at the inlet to and the outlet from the SCR system. The ammonia injection rate is set based on a variety of input data including the measured NOX rates at the SCR inlet/outlet, the outlet NOX set point, the heat input to the boiler, the actual NOX rate measured by the stack monitor, and a scaling factor based on the molecular weights of ammonia and NOX. The system is capable of continually adjusting flow control valves to finetune the ammonia injection rate based on changing gas stream conditions.

- Ammonia Slip: The design target ammonia slip level is less than 5 ppmv measured at the stack. There are no provisions for continuously monitoring ammonia concentration in the flue gas. When ammonia measurements in the flue gas are required, a wet chemical method will be utilized. These measurements are taken periodically over the operating life of the SCR catalyst. More frequent tracking of ammonia slip will be monitored by measuring the amount of residual ammonia adsorbed by the fly ash. Fly ash samples will be measured periodically using an ion-specific electrode. Ammonia slip may also be estimated from the ammonia injection monitoring system based on the NOX rate at the SCR inlet/outlet and the ammonia injection rate.
- · Gas Sampling Grid (GSG): During commissioning and periodically over the life of the system, it will be necessary to tune the AIG to optimize the distribution of ammonia in the SCR inlet duct relative to the NOX distribution to provide optimum NOX conversion with minimum ammonia slip. To facilitate tuning, a manual gas sampling grid (GSG) is installed downstream of the last catalyst layer. The GSG allows a high-resolution traverse of the flue gas stream for composition across the outlet of the SCR, which can be used to precisely adjust the AIG. The GSG is comprised of individual small-bore (~½") heavy-wall pipes extending from outside the SCR to distributed sampling locations below the last catalyst layer. Portable equipment is used to sample and measure gas concentrations using the GSG.
- SCR Bypass: The SCR design incorporates dampers and ductwork to provide the capability of bypassing the SCR system. The bypass is most commonly used to gradually heat or cool the catalyst structure to minimize thermal fatigue during startup and shutdown. During catalyst maintenance and repair, it would also allow access to the SCR reactor without requiring complete shutdown of the Unit 6 boiler.

Form Approved OMB No. 158-R0013

Crist Electric Generating Plant 11999 Pate Street Pensacola, FL 32514		
ERATE PROFITS THROUGH THE RECOVERY AND SALES		
HE ONLY FUNCTION OF WHICH IS THE ABATEMENT		
OR CONTROL OF POLLUTION, AS DETERMINED IN ACCORDANCE WITH SECTION 1.169-2(2)(I) OF THE INCOME TAX REGULATIONS.		
NNECTION WITH PLANTS OR PROPERTIES THAT WERE		
IN SERVICE ON OR BEFORE DECEMBER 31, 1975.		
[ ] B% OF THE AMORTIZABLE BASIS OF THE FACILITY IS ALLOCABLE TO ITS USE IN CONNECTION WITH PLANTS OR		
PROPERTIES THAT WERE IN SERVICE ON OR BEFORE DECEMBER 31, 1975.		
10.[X] A. THE CONTROL FACILITY PERFORMS NO FUNCTION IN ADDITION TO THE ABATEMENT OR CONTROL OF POLLUTION.		
[ ] B% OF THE AMORTIZABLE BASIS OF THE FACILITY IS ALLOCABLE TO THE ABATEMENT OR CONTROL OF POLLUTION.		
SIGNATURE		
TITLE		