

**Title V**

**CRIST ELECTRIC**

**GENERATING**

**PLANT PERMIT**

**APPLICATION**

**Volume V**

EUS-5

SANDERS ENGINEERING & ANALYTICAL SERVICES, INC.

**PARTICULATE EMISSIONS TEST REPORT**  
**STEADY STATE OPERATIONS**

*FOR*

**GULF POWER COMPANY**

*Plant Crist, Unit 6*  
*Pensacola, Florida*



*April 3, 1996*

1568 LEROY STEVENS ROAD

MOBILE, ALABAMA 36695 • 205/633-4120

**TEST REPORT CERTIFICATION**

In regard to these tests, we certify that, to the best of our knowledge, all of the data regarding the testing performed by our agents is true and correct.

Date 4-9-96

Signature Edward R. Harris

**TABLE OF CONTENTS**

INTRODUCTION..... 1

SUMMARY AND DISCUSSION OF RESULTS ..... 2

PROCESS DESCRIPTION..... 4

    Source Air Flow ..... 4

    Operation During Testing ..... 5

SAMPLE POINT LOCATION..... 6

PARTICULATE SAMPLING PROCEDURE (EPA Method 17) ..... 7

    Particulate Sample Recovery ..... 8

    Particulate Analytical Procedures ..... 9

APPENDIX A EQUATIONS AND FIELD DATA SHEETS..... 10

APPENDIX B SAMPLE CALCULATIONS..... 11

APPENDIX C QUALITY CONTROL ..... 12

APPENDIX D OPERATIONAL DATA..... 13

**LIST OF TABLES**

TABLE I. SUMMARY OF PARTICULATE TESTING.....3

**ILLUSTRATIONS**

FIGURE 1. AIR FLOW SCHEMATIC ..... 5

FIGURE 2. SAMPLE POINT LOCATIONS ..... 6

FIGURE 3. PARTICULATE SAMPLING TRAIN ..... 7


### **3. PROCESS DESCRIPTION**

The process consists of a steam electric generating unit firing bituminous coal for the production of electric energy. The coal is received by barge, and loaded directly onto the conveyor feeding the plant, or onto the stockpile and later loaded onto the conveyor belt transporting the coal to the plant. The coal from the conveyor is loaded into bunkers capable of holding between 36 to 48 hours supply of coal. The coal is then fed to pulverizing mills before being fired in the unit through the burners. Upon combustion of the coal in the fire box, approximately 20 percent of the ash falls to the bottom of the boiler and is removed by the ash removal system. The remaining 80 percent exits with the flue gases through the heat exchange and economizer sections of the furnace, and is collected by electrostatic precipitators.

#### **3.1. Source Air Flow**

As shown in Figure 1, the flue gases exit the boiler and are separated into ducts A and B before entering air preheaters. They are then routed to a cold side ESP. The flue gases exiting the cold side ESP are exhausted through a stack into the atmosphere.

Figure 1. Air Flow Schematic



### 3.2. Operation During Testing



The average heat input during steady state operation, as based on F-factor calculations, was 3557 million BTU per hour resulting in the production of approximately 320 megawatts of electricity. Precipitator data supplied by Gulf Power personnel is given in Appendix D.



4. SAMPLE POINT LOCATION

The sample point locations and outlet duct schematic are presented in Figure 2. Method 1 was used for determination of the number and location of sampling points. The minimum number of points (25) required for rectangular stacks was met by sampling a total of 30 points.

Figure 2. Sample Point Locations




**5. PARTICULATE SAMPLING PROCEDURE (EPA Method 17)**

The sampling procedure utilized is that specified in **40 CFR, Part 60, Appendix A, Method 17**, as modified by the governing regulatory agency. A brief description of this procedure is as follows:

The first impingers were partially filled with 100 milliliters of deionized water. The next impinger was left empty to act as a moisture trap. Preweighed 6 to 16 mesh indication silica gel was added to the last impinger. The sampling equipment manufactured by Lear Siegler (Model 100) or Sanders Engineering

**Figure 3. Particulate Sampling Train**



(Model 200) was assembled as shown in the attached drawing. The system was leak checked by plugging the inlet to the nozzle and pulling a 15 inch mercury vacuum. A leakage rate not in excess of 0.02 cubic feet per minute was considered acceptable.

The inside dimensions of the stack liner were measured and recorded. The required number of sampling points were marked on the probe for easy visibility. The range of velocity pressure, the percent moisture, and the temperature of the effluent gases were determined. From this data, the correct nozzle size and the nomograph multiplication factor were determined.

Crushed ice was placed around the impingers. The nozzle was placed on the first traverse point with the tip pointing directly into the gas stream. The pump was started immediately and the flow was adjusted to isokinetic sampling conditions. After the required time interval had elapsed, the probe was repositioned to the next traverse point and isokinetic sampling was re-established. This was performed for each point until the run was completed. Readings were taken at each point and recorded on the field data sheet. At the conclusion of each run, the pump was turned off and the final readings were recorded.

### **5.1. Particulate Sample Recovery**

Care was exercised in moving the collection train to the sample recovery area to minimize the loss of collected sample, or the gain of extraneous particulate matter. The volume of water in the impingers was measured, the silica gel impinger was weighed and recorded on the field data sheet. The nozzle, and all sample-exposed surfaces were washed with reagent grade acetone into a clean sample container. A brush was used to loosen any adhering particulate matter and subsequent washings were placed into the container. The filter was carefully removed from the fritted support and placed in a clean separate sample container. A sample of the acetone used in the washing was saved for a blank laboratory analysis.

## **5.2. Particulate Analytical Procedures**

The filter and any loose particulate matter were transferred from the sample container to a clean, tared weighing dish. The filter was placed in a desiccator for at least 24 hours and then weighed to the nearest 0.1 milligram until a constant weight was obtained. The original weight of the filter was deducted, and the weight gain was recorded to the nearest 0.1 milligram.

The wash solution was transferred to a clean, tared beaker. The solution was evaporated to dryness, desiccated to a constant weight, and the weight gain was recorded to the nearest 0.1 milligram.

**APPENDIX A EQUATIONS AND FIELD DATA SHEETS**

## EQUATIONS

$$1. \quad P_s = P_{\text{bar}} + \frac{P_g}{13.6}$$

$$2. \quad P_m = P_{\text{bar}} + \frac{\overline{\Delta H}}{13.6}$$

$$3. \quad V_s = K_p C_p \sqrt{\Delta P} \sqrt{\frac{T_s}{M_s P_s}}$$

$$4. \quad V_{m(\text{Std})} = K_1 V_m Y \left[ \frac{P_{\text{bar}} + \frac{\overline{\Delta H}}{13.6}}{\overline{T}_m} \right]$$

$$5. \quad V_w(\text{Std}) = 0.04707 V_{Ic}$$

$$6. \quad B_{ws} = \frac{V_w(\text{Std})}{V_{m(\text{Std})} + V_w(\text{Std})}$$

$$7. \quad M_d = 0.44 (\%CO_2) + 0.32 (\%O_2) + 0.28 (\%N_2 + \%CO)$$

$$8. \quad M_s = M_d(1 - B_{ws}) + 18(B_{ws})$$

$$9. \quad EA = \left[ \frac{(\%O_2 - 0.5 (\%CO))}{0.264 (\%N_2) - ((\%O_2) - 0.5 (\%CO))} \right] 100$$

$$10. \quad Q_a = (V_s) (A_s) (60)$$

$$11. \quad Q_s = Q_a (1 - B_{ws}) \frac{(528)}{\bar{T}_s} \frac{(P_s)}{29.92}$$

$$12. \quad E_H = \left( \frac{PMR}{H_I} \right)$$

$$13. \quad E = C_d F_{O_2} \left( \frac{20.9}{20.9 - \%O_2} \right)$$

$$14. \quad C_s = 0.0154 \frac{M_n}{V_{m(Std)}}$$

$$15. \quad C_{50} = \frac{21 C_s}{21 - [(1.5) (\%O_2) - 0.133 (N_2) - 0.75 (\%CO)]}$$

$$16. \quad C_{12} = \frac{C_s (12)}{\%CO_2}$$

$$17. \quad PMR = (C_s) (Q_s) \frac{(60)}{7000}$$

$$18. \quad V_n = \left[ (0.002669) (V_{1c}) + \frac{V_m Y}{\bar{T}_m} \left( p_{bar} + \frac{\bar{\Delta H}}{13.6} \right) \right] \frac{\bar{T}_s}{P_s}$$

$$19. \quad I = \frac{100 V_n}{(60) \emptyset V_s A_n}$$

## NOMENCLATURE

- $A_n$  = Cross-sectional area of nozzle, ft<sup>2</sup>
- $A_s$  = Cross sectional area of stack, ft<sup>2</sup>
- $B_{ws}$  = Water vapor in the gas stream,  
proportion by volume (dimensionless)
- $C_p$  = Pitot tube coefficient (dimensionless) (0.84)
- $C_s$  = Particulate concentration, grains/SDCF
- $C_d$  = Particulate concentration, lbs/SDCF
- $C_{12}$  = Particulate concentration ( $C_s$  adjusted to 12% CO )  
grains/SDCF
- $C_{50}$  = Particulate concentration ( $C_s$  adjusted to 50% excess air)  
grains/SDCF
- EA = Excess air, %
- E = Emission in lb/mmBTU
- $E_H$  = Emission in lb/mmBTU, based on heat input
- $H_I$  = Total Heat Input, Million BTU per Hour (MMBTU/hr)
- I = Percent of isokinetic sampling
- $K_1$  = 17.64 °R/ inches Hg
- $K_p$  = Pitot tube constant,  
$$85.49 \text{ ft/sec} \left[ \frac{(\text{lb/lb-mole}) (\text{in. Hg})}{(^\circ\text{R}) (\text{inc. H}_2\text{O})} \right]^{\frac{1}{2}}$$
- $M_n$  = Total amount of particulate collected, mg
- $M_d$  = Molecular weight of stack gas; dry basis, lb/lb mole
- $M_s$  = Molecular weight of stack gas; wet basis, lb/lb mole
- $P_{bar}$  = Barometric pressure at the sampling site, in. Hg



## NOMENCLATURE (continued)

- $P_m$  = Meter pressure, in. Hg
- $P_s$  = Absolute stack pressure, in. Hg
- $P_g$  = Stack static pressure, in. H<sub>2</sub>O
- PMR = Particulate mass rate, lb/Hr
- $Q_a$  = Volumetric flow rate ACFM
- $Q_s$  = Volumetric flow rate SDCFM
- $V_s$  = Average stack gas velocity, ft/sec
- $V_{lc}$  = Total volume of liquid collected in impingers & silica gel, ml
- $V_m$  = Volume of gas sample as measured by dry gas meter, ACF
- $V_{m(std)}$  = Volume of gas sample measured by dry gas meter,  
corrected to standard conditions, SDCF
- $V_{w(std)}$  = Volume of water vapor in gas sample, corrected to standard  
conditions, SCF
- $V_n$  = Volume collected at stack conditions through nozzle, ACF
- Y = Dry gas meter calibration factor (dimensionless)
- $\Delta H$  = Average pressure difference of orifice, in. H<sub>2</sub>O
- $\Delta P$  = Velocity head of stack gas, in. H<sub>2</sub>O
- $\overline{\sqrt{\Delta P}}$  = Average of square roots of the velocity pressure, in. H<sub>2</sub>O
- $\emptyset$  = Total sampling time, minutes
- %CO<sub>2</sub>, %O<sub>2</sub>, N<sub>2</sub>, %CO - Number % by volume, dry basis, from gas analysis
- $F_{O_2}$  = Oxygen based F factor (9820 SDCF/mmbTU for bituminous coal)
- $T_s$  = Temperature of the stack, °R (°F + 460)



SANDERS ENGINEERING & ANALYTICAL SERVICES, Inc.

1568 Leroy Stevens Rd.
Mobile, AL 36695

Office: (205) 633-4120
FAX#: (205) 633-2285

USE FOR FLOW
DATA
RUNS
4, 2, 3

FIELD DATA SHEET

COMPANY GPCO DATE 4-3-96 DGM# S-101
PLANT Crist OPERATOR ELM ΔHa 0.74
UNIT #6 Steady State METHOD 17 PROBE N/A
liner length 21'

Table for Run 1: NOZZLE CALIBRATION (PRE/POST), FILTER NUMBER (1162), METER READING (FINAL/INITIAL/NET), LEAK CHECK (SYSTEM/PITOT), VOLUME OF LIQUID WATER COLLECTED (IMP. 1-4), GAS ANALYSIS (O2, CO2, CO), STATIC, BAROMETRIC.

Table for Run 2: NOZZLE CALIBRATION (PRE/POST), FILTER NUMBER (1163), METER READING (FINAL/INITIAL/NET), LEAK CHECK (SYSTEM/PITOT), VOLUME OF LIQUID WATER COLLECTED (IMP. 1-4), GAS ANALYSIS (O2, CO2, CO), STATIC, BAROMETRIC.

Table for Run 3: NOZZLE CALIBRATION (PRE/POST), FILTER NUMBER (1164), METER READING (FINAL/INITIAL/NET), LEAK CHECK (SYSTEM/PITOT), VOLUME OF LIQUID WATER COLLECTED (IMP. 1-4), GAS ANALYSIS (O2, CO2, CO), STATIC, BAROMETRIC.

Port #	Time	Gas Meter Vol. (cu. ft.)	Vel. Head ΔP in. H <sub>2</sub> O	Orifice Head ΔH in. H <sub>2</sub> O	Temperature (F)					Vac. in. H <sub>g</sub>	
					Stack	Probe	Hot Box	Imp.	Gas Meter In		Gas Meter Out
5-1	8:08	565.000	1.25	1.42	334	N/A	N/A	49	69	70	5
2	:10	566.300	1.15	1.30	335			✓	70	69	5
3	:12	567.600	1.25	1.42	334			✓	70	70	5
4	:14	568.900	1.25	1.42	327			✓	70	70	5
5	:16	570.100	1.50	1.70	328			✓	71	70	5
6	:18	571.400	1.85	2.10	329			✓	71	71	6
4-1	8:20	573.000	1.10	1.25	334			✓	72	71	4
2	:22	574.200	1.25	1.44	336			52	72	72	5
3	:24	575.400	1.30	1.50	336			✓	73	72	5
4	:26	576.800	1.30	1.50	330			✓	72	72	5
5	:28	578.100	1.25	1.44	331			✓	73	73	5
6	:30	579.400	1.15	1.32	331			✓	73	73	5
3-1	8:33	580.690	1.35	1.56	334			✓	74	74	5
2	:35	582.000	1.05	1.21	337			✓	74	74	5
3	:37	583.200	1.35	1.57	336			✓	75	74	5
4	:39	584.500	1.15	1.33	331			56	75	75	5
5	:41	585.800	.95	1.10	331			✓	75	75	4
6	:43	586.900	1.10	1.27	332			✓	76	75	4.5
2-1	8:45	588.125	1.25	1.45	336			✓	76	76	5
2	:47	589.400	1.25	1.45	338			✓	76	76	5
3	:49	590.700	1.60	1.86	336			✓	76	76	6
4	:51	592.000	1.50	1.74	332			✓	77	77	6
5	:53	593.500	1.20	1.39	333			✓	77	77	5
6	:55	594.800	1.55	1.80	333			✓	77	78	6
1-1	:58	596.235	1.45	1.68	331			59	78	78	5
2	9:00	597.700	2.0	2.34	338			✓	78	78	8
3	:02	599.200	1.65	1.93	338			✓	78	78	7
4	:04	600.700	1.45	1.69	334			✓	79	79	6
5	:06	602.100	1.20	1.40	334			✓	79	79	6.5
6	:08	603.400	2.25	2.63	335			✓	79	79	8
Final	9:10	605.020	1.16								

Check Indicates Temperatures Meet Required Limits.

Company GPCO

859,853

Date 4-3-96

Site Crist #6 Steady State

Run # 1

Page 2 Of 4

Flow RATA RUN 1 STARTS HERE

Port #	Time	Gas Meter Vol. (cu. ft.)	Vel. Head ΔP in. H <sub>2</sub> O	Orifice Head ΔH in. H <sub>2</sub> O	Temperature (F)						Vac. in. H <sub>2</sub>
					Stack	Probe	Hot Box	Imp.	Gas Meter		
									In	Out	
1-1	9:41	608.100	1.40	1.64	334	N/A	N/A	51	81	81	5
2	:43	609.400	2.0	2.36	342			✓	81	81	6
3	:45	611.000	1.60	1.89	334			✓	81	81	5
4	:47	612.600	1.40	1.65	336			✓	81	81	5
5	:49	613.900	1.45	1.71	335			✓	82	82	5
6	:51	615.400	2.25	2.66	336			✓	82	82	6
2-1	9:53	617.075	1.27	1.50	342			✓	82	82	4
2	:55	618.500	1.27	1.50	343			✓	83	82	4.5
3	:57	619.600	1.40	1.65	343			53	82	82	5
4	:59	621.200	1.50	1.77	337			✓	83	82	5
5	10:01	622.500	1.25	1.47	337			✓	83	82	5
6	:03	623.900	1.45	1.71	337			✓	83	83	5
3-1	10:06	625.230	1.20	1.41	343			✓	83	83	3
2	:08	626.800	1.20	1.41	345			✓	83	82	4.5
3	:10	627.800	1.30	1.53	343			✓	83	82	5
4	:12	629.100	1.20	1.41	338			✓	83	82	5
5	:14	630.400	.90	1.06	338			✓	83	82	4
6	:16	631.600	1.15	1.36	338			✓	83	83	4
4-1	10:19	632.875	1.10	1.30	345			✓	83	83	4
2	:21	634.200	1.31	1.54	346			✓	84	83	5
3	:23	635.500	1.23	1.45	346			56	84	84	5
4	:25	636.800	1.27	1.50	338			✓	84	84	5
5	:27	638.200	1.23	1.45	337			✓	84	84	5
6	:29	639.400	1.15	1.36	337			✓	84	84	5
5-1	:31	640.690	1.40	1.65	345			✓	85	84	5
2	:33	642.000	1.23	1.44	346			✓	85	84	5
3	:35	643.300	1.25	1.46	346			✓	85	84	5
4	:37	644.600	1.20	1.41	338			✓	85	84	5
5	:39	646.000	1.55	1.82	338			✓	85	85	6
6	:41	647.400	1.90	2.23	339			✓	85	85	6
Final	10:43	648.978									

1.164

Check indicates Temperatures Meet Required Limits.

Company GPCO

862,661

Date 4-3-96

Site Crist #6 S.S.

Run # 2

Page 3 Of 4

Port # Point #	Time	Gas Meter Vol. (cu. ft.)	Vel. Head ΔP in. H <sub>2</sub> O	Orifice Head ΔH in. H <sub>2</sub> O	Temperature (F)						Vac. in. H <sub>2</sub>
					Stack	Probe	Hot Box	Imp.	Gas Meter		
									In	Out	
S-1	12:03	657.500	1.45	1.42	346	N/A	N/A	50	81	81	5
2	:05	658.800	1.24	1.22	351			✓	82	81	5
3	:07	659.950	1.16	1.14	351			✓	81	81	4
4	:09	661.100	1.21	1.19	342			✓	82	81	4
5	:11	662.300	1.43	1.40	343			✓	82	81	4.5
6	:13	663.800	2.0	1.96	343			✓	81	81	6
4-1	12:15	665.138	1.20	1.18	348			✓	81	81	4
2	:17	666.200	1.40	1.37	351			✓	81	81	4
3	:19	667.400	1.30	1.27	350			49	81	81	4
4	:21	668.800	1.40	1.37	344			✓	82	81	4
5	:23	670.000	1.25	1.23	343			✓	82	81	4
6	:25	671.100	1.24	1.21	344			52	82	81	4
3-1	12:28	672.470	1.30	1.27	350			✓	81	81	3
2	:30	673.600	1.12	1.09	351			✓	82	81	3
3	:32	674.800	1.26	1.23	350			✓	82	81	3
4	:34	676.000	1.22	1.19	346			✓	81	81	4
5	:36	677.150	0.99	.96	345			✓	81	81	4
6	:38	678.250	1.08	1.05	344			✓	82	81	4
2-1	12:41	679.315	1.25	1.22	350			✓	82	81	3
2	:43	680.500	1.32	1.29	351			✓	82	81	4
3	:45	681.700	1.50	1.46	349			✓	82	82	5
4	:47	682.900	1.60	1.56	344			✓	82	82	5
5	:49	684.500	1.25	1.22	344			57	83	83	5
6	:51	685.500	1.70	1.66	344			✓	83	83	5.5
1-1	12:53	687.074	1.26	1.23	345			✓	84	83	3.5
2	:55	688.100	1.95	1.90	351			✓	84	84	6
3	:57	689.700	1.60	1.56	348			✓	84	84	6
4	:59	691.000	1.40	1.37	344			59	85	84	5
5	13:01	692.400	1.23	1.20	345			✓	85	84	5
6	:03	693.600	2.30	2.25	346			✓	85	85	7
Comal	13:05	695.100									

Check Indicates Temperatures Meet Required Limits.

Company GPCO

866,205

Date 4-3-96

Site Cristob S.S.

Run # 3

Page 4 Of 4

## LABORATORY ANALYSIS & CHAIN OF CUSTODY

COMPANY/PLANT: GPCO / Crist

UNIT #: 6 DATE OF TEST: 4/3/96 TYPE OF TEST:  M-5  M-17  OTHER \_\_\_\_\_

SAMPLE #	RELINQUISHED BY	RECEIVED BY	TIME	DATE	REASON FOR CHANGE
1162	S.H.	S.H.	7:15	4-5-96	Analysis
1163					
1164					

UNIT # 6 Steady State

RUN # <u>1</u>	FILTER # <u>1162</u>	BEAKER # <u>7</u>	WASH (ML) <u>40</u>
FINAL WEIGHT	<u>123.4</u>	<u>69927.9</u>	
INITIAL WEIGHT	<u>120.5</u>	<u>69925.3</u>	
DIFFERENCE	<u>2.9</u>	<u>2.6</u>	
CORRECTED TOTAL WEIGHT		<u>5.5</u>	
RUN # <u>2</u>	FILTER # <u>1163</u>	BEAKER # <u>6</u>	WASH (ML) <u>40</u>
FINAL WEIGHT	<u>122.4</u>	<u>63816.4</u>	
INITIAL WEIGHT	<u>120.2</u>	<u>63815.0</u>	
DIFFERENCE	<u>2.2</u>	<u>1.4</u>	
CORRECTED TOTAL WEIGHT		<u>3.6</u>	
RUN # <u>3</u>	FILTER # <u>1164</u>	BEAKER # <u>27</u>	WASH (ML) <u>40</u>
FINAL WEIGHT	<u>122.7</u>	<u>68103.9</u>	
INITIAL WEIGHT	<u>120.7</u>	<u>68102.5</u>	
DIFFERENCE	<u>2.0</u>	<u>1.4</u>	
CORRECTED TOTAL WEIGHT		<u>3.4</u>	
RUN # _____	FILTER # _____	BEAKER # _____	WASH (ML) _____
FINAL WEIGHT			
INITIAL WEIGHT			
DIFFERENCE			
CORRECTED TOTAL WEIGHT			

UNIT # \_\_\_\_\_

RUN # _____	FILTER # _____	BEAKER # _____	WASH (ML) _____
FINAL WEIGHT			
INITIAL WEIGHT			
DIFFERENCE			
CORRECTED TOTAL WEIGHT			
RUN # _____	FILTER # _____	BEAKER # _____	WASH (ML) _____
FINAL WEIGHT			
INITIAL WEIGHT			
DIFFERENCE			
CORRECTED TOTAL WEIGHT			
WASH SOLVENT BLANK (ML) _____		BEAKER # _____	WASH (ML) _____
FINAL WEIGHT			
INITIAL WEIGHT			
DIFFERENCE			
CORRECTION FACTOR (MG/ML)			

ALL WEIGHTS ARE IN MILLIGRAMS (MG)

**APPENDIX B SAMPLE CALCULATIONS**

**Input and Constants**

```

          3
    9820 ft
f := -----
      mm btu

pg := -(0.5 in. H2O)
pbar := 30.25 in. Hg.
Ahavg := 1.574 in. H2O
y := 1.038
tm := 74.4 °F
o2 := 5.5
co2 := 12.5

          3
vm := 40.02 ft
vlc := 71. ml
theta := 60 min
nozdia := 0.208 in.
ts := 333.5 °F

          2
as := 270. ft
mm := 5.5 mg
numberofpoints := 30

          0.5
sqrtAp := 1.1621 in. H2O

          lb in. Hg.      0.5
      85.49 1 ft 1 (-----)
          lb-mole °R in. H2O
kp := -----
          1 sec

cp := 0.84

      17.64 °R
k1 := -----
      in. Hg.
    
```



$$ts = \frac{(ts + 460 \text{ } ^\circ\text{F}) \text{ } ^\circ\text{R}}{\text{ } ^\circ\text{F}}$$

793.5 °R

$$tm = \frac{(tm + 460 \text{ } ^\circ\text{F}) \text{ } ^\circ\text{R}}{\text{ } ^\circ\text{F}}$$

534.4 °R

$$n2 = 100 - o2 - co2$$

82.

$$an = \frac{\text{nozdia}^2 \text{ } 3.1416}{4 \left( \frac{12 \text{ in.}^2}{\text{ft}} \right)}$$

0.000235969 ft<sup>2</sup>

**Calculations**

**Equation 1**

$$p_s = p_{bar} + \frac{\rho g}{13.6 \text{ in. H}_2\text{O}} \times 1 \text{ in. Hg.}$$

30.2132 in. Hg.

**Equation 2**

$$p_m = p_{bar} + \frac{\Delta h_{avg}}{13.6 \text{ in. H}_2\text{O}} \times \text{in. Hg.}$$

30.3657 in. Hg.

**Equation 3**

$$k_1 v_m y \left( p_{bar} + \frac{\Delta h_{avg}}{13.6 \text{ in. H}_2\text{O}} \right) \times \text{in. Hg.}$$

$$v_{mstd} = \frac{\text{---}}{t_m}$$

<sup>3</sup>  
41.638 ft

**Equation 4**

$$v_{wstd} = \frac{0.04707 \text{ ft} \times v_{lc}^3}{m_l}$$

<sup>3</sup>  
3.34197 ft

**Equation 5**

$$b_{ws} = \frac{v_{wstd}}{v_{mstd} + v_{wstd}}$$

0.074299

**Equation 6**

$$md = \frac{(0.44 \text{ co}_2 + 0.32 \text{ o}_2 + 0.28 \text{ n}_2) \text{ lb}}{\text{lb-mole}}$$

$$\frac{30.22 \text{ lb}}{\text{lb-mole}}$$

**Equation 7**

$$ms = md (1 - bws) + \frac{bws \text{ 18 lb}}{\text{lb-mole}}$$

$$\frac{29.3121 \text{ lb}}{\text{lb-mole}}$$

**Equation 8**

$$vs = kp \text{ cp } \sqrt{t_p} \left( \frac{ts \text{ 0.5}}{ms \text{ ps}} \right)$$

$$\frac{78.9932 \text{ ft}}{\text{sec}}$$

**Equation 9**

$$qa = \frac{vs \text{ as } 60 \text{ sec}}{\text{min}}$$

$$\frac{1.27969 \text{ } 10^6 \text{ } 3 \text{ ft}}{\text{min}}$$

**Equation 10**

$$qs = \frac{qa (1 - bws) 528 \text{ } ^\circ\text{R ps}}{ts \text{ 29.92 in. Hg.}}$$

$$\frac{795973. \text{ } 3 \text{ ft}}{\text{min}}$$

Equation 11

$$cs = \frac{0.0154 \text{ gr mn}}{\text{mg vmstd}}$$

$$\frac{0.0020342 \text{ gr}}{\text{ft}^3}$$

Equation 12

$$pmr = \frac{cs \text{ qs } 60 \text{ min}}{\text{hour} \frac{7000 \text{ gr}}{\text{lb}}}$$

$$\frac{13.8786 \text{ lb}}{\text{hour}}$$

Equation 13

$$e = \frac{cs \text{ f } 20.9 \text{ } 1 \text{ lb}}{(20.9 - o_2) 7000 \text{ gr}}$$

$$\frac{0.00387286 \text{ lb}}{\text{mm btu}}$$

Equation 14

$$vn = \frac{0.002669 \text{ in. Hg. ft}^3 \text{ vlc} \text{ } \frac{vm \text{ y pm}}{tm}}{\text{ml } ^\circ R}$$

$$\frac{\text{ps}}{\text{ft}^3}$$

$$66.9697 \text{ ft}^3$$

Equation 15

$$i = \frac{100 \% \text{ vn}}{60 \text{ sec theta vs an}} \text{ min}$$

99.8001 %

Equation 16

$$hi = \frac{\text{pmr}}{e} \text{ hour}$$

3583.54 mm btu

**APPENDIX C QUALITY CONTROL**

**INITIAL  
METER CALIBRATION FORM - DGM**

DATE:	12-05-95	Box No.	S-101		
Ref. DGM Ser. #	1044453	Calibrated By	EDWARD HARRIS		
RUN #	1	2	3	4	5
DELTA H (DGM)	0.50	1.00	1.50	2.00	3.00
Y (Ref. DGM)	1.014	1.014	1.014	1.014	1.014
Reference DGM					
Gas Vol. Initial	19.500	25.177	31.500	38.100	45.000
Gas Vol. Final	25.177	31.500	38.100	45.000	51.466
Meter Box DGM					
Gas Vol. Initial	24.400	30.000	36.261	42.805	49.615
Gas Vol. Final	30.000	36.261	42.805	49.615	56.004
Reference DGM					
Temp.	Avg.	Avg.	Avg.	Avg.	Avg.
Deg F Initial	66	67	67	67	67
Deg F Final	67	67	67	67	67
Meter Box DGM					
Temp. Initial In	66	67	68	69	69
Temp. Initial Out	66	67	68	69	69
Temp. Final In	66	67	69	69	69
Temp. Final Out	66	67	69	69	69
P Bar IN. Hg	30.08	30.08	30.08	30.08	30.08
Time (sec.)	873	688	582	525	404
Meter Calibration					
Factor (Y)	1.026	1.022	1.022	1.026	1.023
Qm (C.F.M.)	0.399	0.563	0.695	0.806	0.981
Km (Std Pressure)	0.727	0.726	0.730	0.733	0.730
DELTA Ha	1.77	1.78	1.75	1.73	1.75
Average Y (Meter Calibration Factor)				1.024	
Average Km (Standard Pressure)				0.729	
Average DELTA Ha of Orifice				1.755	

<p>Y = <math>\leq .03</math>          Max &amp; Min <math>\leq .02</math> from Avg          Final Avg within 5% of Initial Avg  <math>\Delta Ha = \text{Max \&amp; Min} \leq .2</math> from Avg</p>
---

# POST TEST QUALITY ASSURANCE

Date: 4/5/96

BOX #: S-101

Ref. Meter: 1044453

Calibrated By: EDWARD HARRIS

## DRY GAS METER

		Unit	Run 1	Run 2	Run 3
<b>FIELD METER</b>	<b>ΔH</b>	In. H <sub>2</sub> O	1.50	1.50	1.50
	<i>Initial Gas Volume</i>	Ft. <sup>3</sup>	952.600	958.500	964.090
	<i>Final Gas Volume</i>	Ft. <sup>3</sup>	958.500	964.090	969.783
	<i>Initial Temp. In</i>	°F	61	61	61
	<i>Initial Temp. Out</i>	°F	61	60	61
	<i>Final Temp. In</i>	°F	62	61	61
	<i>Final Temp. Out</i>	°F	60	61	61
<b>REF. METER</b>	<b>Y</b>	<i>Dimensionless</i>	1.014	1.014	1.014
	<i>Initial Gas Volume</i>	Ft. <sup>3</sup>	582.700	589.006	595.000
	<i>Final Gas Volume</i>	Ft. <sup>3</sup>	589.006	595.000	601.000
	<i>Initial Temp.</i>	°F	58	58	58
	<i>Final Temp.</i>	°F	58	58	58
	<b>Barometric Pressure</b>	In. Hg	30.02	30.02	30.02
	<b>Time</b>	sec	513	494	496
	<b>Meter Calibration Factor</b>	<i>Dimensionless</i>	1.086	1.089	1.071
	<b>ΔH<sub>s</sub></b>	In. H <sub>2</sub> O	1.460	1.498	1.506
	<b>Average Y</b>	<i>Dimensionless</i>	1.082		
	<b>Initial Y</b>	<i>Dimensionless</i>	1.038		
	<b>Percent Error</b>	%	4.2 (Allowed 5.0%)		

## DIFFERENTIAL PRESSURE GAUGE

Ref. Pressure In H <sub>2</sub> O	Magnehelic Pressure In H <sub>2</sub> O	Percent Error (+/- 5%)
0.5	0.5	0
1.0	1.0	0
1.5	1.5	0

## TEMPERATURE SENSOR

Ref. Temp. (°F)	Thermocouple Temp.	Percent Error (Allowed 1.5% of Absolute)
310	310	0

## ARENOLD BAROMETER

Reference Barometer	Test Barometer	0.1 Diff. Allowed
30.02	30.02	0



### MAGEHELIC CALIBRATION

BOX	2879	S-100	C-133	C-175	S-102	S-101	S-103
SER. NO.	91126AM 91	9126A M91	9126A M91	R90125 MR6	R74D	R22D	R20208 A617
RANGE	0-2	0-2	0-2	0-2	0-5	0-2	0-2
REFERENCE READING	FIELD DEVICE READING						
0.000		0.00	0.00	0.00	0.00	0.00	0.00
0.050							
0.150							
0.200							
0.250							
0.450							
0.50	0.50	0.51	0.50	0.51	0.51	0.50	0.50
1.00	0.99	1.01	0.98	1.01	1.01	0.98	1.01
1.30							
1.80	1.80	1.82	1.79	1.82	1.81	1.79	1.82
2.50							
4.50							
5.0							
9.0							
13.0							
22.0							

SIGNATURE: Edward J. Dennis

DATE: 12-5-95

# MAGEHELIC CALIBRATION

BOX #1

SER. NO.	10720- AB68	R1061- 6AG48	R5031- SEB76	R1062- 9JA82	R1051- 3MR42	R90124 RI119
RANGE	0-0.25	0-0.50	0-2	0-5	0-10	0-25
REFERENCE READING	FIELD DEVICE READING					
0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.050	0.050					
0.150	0.150	0.140				
0.200	0.190					
0.250		0.250				
0.450		0.450				
0.50			0.50			
1.00			1.00			
1.30				1.30		
1.80			1.80			
2.50				2.50	2.48	
4.50				4.50		
5.0					5.0	5.0
9.0					9.02	
13.0						13.0
22.0						22.0

SIGNATURE:

*Edward R. Harris*

DATE:

12/22/95

**MAGEHELIC CALIBRATION**  
BOX #2

SER. NO.	10819-DR2	R1090-2AG18	RS0315-EB93	R1062-9TA87	30830-AM79	R1072-2MC5
RANGE	0-0.25	0-0.50	0-2	0-5	0-10	0-25
REFERENCE READING	FIELD DEVICE READING					
0.000	0.000	0.000	0.00	0.00	0.0	0.0
0.050	0.050					
0.150	0.155	0.152				
0.200	0.205					
0.250		0.256				
0.450		0.456				
0.50			0.52			
1.00			1.04			
1.30				1.32		
1.80			1.83			
2.50				2.55	2.49	
4.50				4.50		
5.0					4.9	5.2
9.0					8.8	
13.0						12.9
22.0						22.0

SIGNATURE: Edward L. Harris  
DATE: 12/22/75

**MAGEHELIC CALIBRATION**  
BOX #3

SER. NO.	R10908AG71 MRR1	R0112642	R10608CF20 CF20
RANGE	0-0.50	0-2.0	0-10
REFERENCE READING	FIELD DEVICE READING		
0.000	0.00	0.00	0.0
0.050			
0.150	0.149		
0.200			
0.250	0.240		
0.450	0.450		
0.50		0.50	
1.00		0.98	
1.50			
1.80		1.78	
2.50			2.5
4.50			
5.0			5.0
9.0			9.0
13.0			
22.0			

SIGNATURE:

*Edward L. Harris*

DATE:

12/22/95

**MAGEHELIC CALIBRATION**  
BOX #4

SER. NO.	R22D	R90051 6GT21	R90101 5CD102
RANGE	0-0.50	0-5	0-25
REFERENCE READING	FIELD DEVICE READING		
0.000	0.000	0.00	0.0
0.050			
0.150	0.151		
0.200			
0.250	0.251		
0.450	0.455		
0.50			
1.00			
1.30		1.27	
1.80			
2.50		2.52	
4.50		4.55	
5.0			5.0
9.0			
13.0			13.0
22.0			21.6

SIGNATURE:

*Edward L. Harris*

DATE:

12/22/95

**TEMPERATURE CALIBRATIONS - DEGREES FAHRENHEIT**

REFERENCE DEVICE READING*	0 DEG. F	210 DEG.	420 DEG.	630 DEG.	840 DEG.	1050 DEG.	1260 DEG.	1470 DEG.	1680 DEG.	1900 DEG.
2879	0	217	421	630	839	1050	1260	1471	1681	1900
METER BOX #1 C-133 11580	0	212	423	635	842	1053	1264	1475	1679	1910
METER BOX #2 C-175 15962	0	211	423	627	839	1052	1265	1475	1687	1903
METER BOX #5 S-100 15751	2	211	417	628	844	1062	1279	1491	1698	1907
METER BOX #6 S-101 15751	0	210	419	628	839	1058	1255	1473	1691	1900
PORTABLE THERMOCOUPLE #2 (Blue)	2	209	415	628	837	1053	1260	1468	1679	1908
PORTABLE THERMOCOUPLE #2 (Green)	2	211	417	627	842	1058	1273	1484	1688	1896
PINK T140293	-1	208	415	624	840	1056	1272	1482	1687	1894
PORTABLE THERMOCOUPLE (Yellow)	0	210	419	632	840	1050	1259	1470	1680	1901
PORTABLE THERMOCOUPLE T-105998 (Black)	1	209	416	625	839	1055	1270	1481	1684	1891
METER BOX S-102	-2	209	417	625	837	1049	1259	1462	1658	1890
METER BOX S-103	4	215	423	632	844	1057	1266	1471	1667	1895

**DATE:**

12-05-95

**SIGNATURE:**

*Edward L. Harris*


\* Reference Device is an Omega Engineering CL505-A calibrated reference thermocouple-potentiometer system.





**SANDERS ENGINEERING & ANALYTICAL SERVICES, Inc.**

1588 Leroy Stevens Rd. Office: (205) 833-4120  
 Mobile, AL 36606 FAX#: (205) 833-8286




**Notes:**


$1.05 D_t \leq 1.50 D_t$

$P_A = P_B$


The Pitot used was within the following geometric specifications:  
 $D_t$  between 0.48 and 0.95 cm (3/16 and 3/8 in.)  
 $C_p = 0.84$



Minimum pitot-sample probe separation needed to prevent interference



OR



Proper thermocouple placement to prevent interference.




**SANDERS ENGINEERING &  
ANALYTICAL SERVICES, Inc.**


1588 Jeroy Stevens Rd.  
Mobile, Al. 36688

Office: (205) 633-4120  
FAX: (205) 633-2205

Proper pilot tube-sampling nozzle configuration to prevent aero-dynamic interference; bottomhook type nozzle; centers of nozzle and pilot opening aligned;  $D_i$  between 0.48 and 0.66 cm (3/16 and 3/8 in.)



Bottom view showing minimum pilot/nozzle separation



Side view; to prevent pilot tube from interfering with the gas flow streamlines approaching the nozzle, the impact pressure opening plane of the pilot tube shall be even with or above the nozzle entry plane.









Best Available Copy

**SANDERS ENGINEERING &  
ANALYTICAL SERVICES, Inc.**

1600 Leroy Stevens Rd.    Office: (205) 833-4120  
Mobile, AL 36686        FAX: (205) 833-8288

Types of face-opening misalignment that can result from field use or improper construction of type 'B' pitot tubes. These will not affect the baseline value of  $C_p(u)$  so long as  $\alpha_1$  and  $\alpha_2 < 10^\circ$ ,  $\theta_1$  and  $\theta_2 < 5^\circ$ , and  $0.32$  cm (1/8 in.)



**APPENDIX D OPERATIONAL DATA**

CRIST UNIT 6 COMPLIANCE TEST

RUN# 1  
 TYPE Steadystate  
 LOAD 320

DATA SHEET  
 PASS \_\_\_\_\_ FAIL \_\_\_\_\_  
 P.E.R. \_\_\_\_\_

DATE 3-3-96  
 START TIME 0808  
 STOP TIME 0910  
 WEATHER Clear  
 AMBIENT TEMP -70'

AIR/GAS TEMPERATURES (DEG. F)	
PT. 1 6A AH INLET AIR	<u>82</u>
PT. 2 6A AH OUTLET AIR	<u>598</u>
PT. 3 6B AH INLET AIR	<u>85</u>
PT. 4 6B AH OUTLET AIR	<u>586</u>
PT. 5 LH ECONO OUT GAS	<u>702</u>
PT. 6 RH ECONO OUT GAS	<u>733</u>
PT. 7 LH AH OUTLET GAS	<u>336</u>
PT. 8 RH AH OUTLET GAS	<u>366</u>

DRAFT INDICATION (IN. OF H2O)

6A F.D. FAN DISCHARGE	<u>14.0</u>
6B F.D. FAN DISCHARGE	<u>14.5</u>
6A AH GAS DIFF.	<u>10.2</u>
6B AH GAS DIFF.	<u>10.0</u>
FURNACE PRESSURE	<u>77</u>
WINDBOX PRESSURE	<u>7.5</u>
FURNACE GAS	<u>2.5</u>
ECONO INLET GAS	<u>2.5</u>
ECONO OUTLET PSI	<u>7.0</u>
I.D. DUCT PRESSURE	<u>20.2</u>
6A I.D. SUCTION	<u>22</u>
6B I.D. SUCTION	<u>20</u>

DAMPER POSITIONS	
SUPERHEAT/REHEAT	<u>65/35</u>
6A F.D. FAN INLET	<u>75</u>
6B F.D. FAN INLET	<u>82</u>
6A I.D. FAN INLET	<u>53</u>
6B I.D. FAN INLET	<u>58</u>
6A HOT AIR RECIRC.	<u>0</u>
6B HOT AIR RECIRC.	<u>0</u>

FAN AMPS

6A I.D. FAN	<u>420</u>
6B I.D. FAN	<u>415</u>
6A F.D. FAN	<u>283.0/293.0/286.5</u>
6B F.D. FAN	<u>210.4/216.8/209.8</u>
6A HAR FAN	<u>0</u>
6B HAR FAN	<u>0</u>

CAPACITY	
6 MINUTE AVG.	<u>1.50</u>
6A INSTANT	<u>0</u>
6B INSTANT	<u>10</u>
6A O2	<u>4.0</u>
6B O2	<u>3.25</u>
STACK O2	<u>3.8</u>
SO2 CHART	<u>1.58</u>

SUPERHEAT TEMPERATURE	<u>1000</u>
REHEAT TEMPERATURE	<u>1000</u>
THROTTLE PRESSURE	<u>2375</u>
FEEDWATER FLOW (MLBPHR)	<u>2.15</u>
TOTAL AIR FLOW "	<u>2.45</u>
STEAM FLOW "	<u>2.3</u>
CONDENSATE FLOW "	<u>1.8</u>
GV SETTER POSITION	<u>824</u>

BAROMETER	<u>30.20</u>
CONDENSER VAC	<u>27.20</u>
BACKPRESSURE	<u>2.50</u>
6A/6B COND IN	<u>82 / 83</u>
6A/6B COND OUT	<u>106 / 105</u>

## PULVERIZER READINGS

MILL AMPS      PA FAN AMPS      COAL FLOW      P.A. FLOW      MILL DIFF.      MILL TEMP

6A	55	90	65	140	9	150
6B	52	112	65	130	9	155
6C	56	96	66	140	9	155
6D	56	110	65	140	10	155

## PULVERIZER DAMPER POSITIONS (%)

HOT AIR DAMPER

PRIMARY FLOW DAMPER

AIR REGISTERS

6A	80	55	29 77 74 50
6B	60	66	29 77 74 50
6C	70	55	33 76 76 30
6D	84	63	32 73 74 51

0808

0910

COMMENTS      A-765857

A-766532

B-440470

B-441147

C-642731

C-643436

D-593886

D-894571

CRIST UNIT 6 COMPLIANCE TEST

Run# 2  
 TYPE Steady State  
 LOAD 320

DATA SHEET  
 PASS \_\_\_\_\_ FAIL \_\_\_\_\_  
 P.E.R. \_\_\_\_\_

DATE 4-3-96  
 START TIME 0941  
 STOP TIME 1043  
 WEATHER clear  
 AMBIENT TEMP -70

AIR/GAS TEMPERATURES (DEG. F)	
PT. 1	6A AH INLET AIR <u>82</u>
PT. 2	6B AH OUTLET AIR <u>598</u>
PT. 3	6B AH INLET AIR <u>85</u>
PT. 4	6B AH OUTLET AIR <u>582</u>
PT. 5	LH ECONO OUT GAS <u>702</u>
PT. 6	RH ECONO OUT GAS <u>733</u>
PT. 7	LH AH OUTLET GAS <u>336</u>
PT. 8	RH AH OUTLET GAS <u>366</u>

DRAFT INDICATION (IN. OF H2O)

6A F.D. FAN DISCHARGE	<u>12.5</u>
6B F.D. FAN DISCHARGE	<u>15.</u>
6A AH GAS DIFF.	<u>12.5</u>
6B AH GAS DIFF.	<u>10.0</u>
FURNACE PRESSURE	<u>0</u>
WINDBOX PRESSURE	<u>.75</u>
FURNACE GAS	<u>.5</u>
ECONO INLET GAS	<u>3.0</u>
ECONO OUTLET PSI	<u>4.0</u>
I.D. DUCT PRESSURE	<u>22.5</u>
6A I.D. SUCTION	<u>22.0</u>
6B I.D. SUCTION	<u>20.5</u>

DAMPER POSITIONS

SUPERHEAT/REHEAT	<u>70</u>	<u>30</u>
6A F.D. FAN INLET	<u>73</u>	
6B F.D. FAN INLET	<u>80</u>	
6A I.D. FAN INLET	<u>53</u>	
6B I.D. FAN INLET	<u>58</u>	
6A HOT AIR RECIRC.	<u>0</u>	
6B HOT AIR RECIRC.	<u>0</u>	

FAN AMPS

6A I.D. FAN	<u>425</u>
6B I.D. FAN	<u>410</u>
6A F.D. FAN	<u>283.0 293.0 286.5</u>
6B F.D. FAN	<u>210.4 216.8 209.8</u>
6A HAR FAN	<u>—</u>
6B HAR FAN	<u>—</u>

CAPACITY	
6 MINUTE AVG.	<u>150</u>
6A INSTANT.	<u>0</u>
6B INSTANT.	<u>10</u>
6A O2	<u>4.0</u>
6B O2	<u>3.0</u>
STACK O2	<u>3.8</u>
SO2 CHART	<u>1.58</u>

BAROMETER	<u>30.80</u>
CONDENSER VAC	<u>27.55</u>
BACK PRESSURE	
6A O2 COND IN	<u>82 / 83</u>
6B O2 COND OUT	<u>106 / 105</u>

SUPERHEAT TEMPERATURE	<u>1000</u>
REHEAT TEMPERATURE	<u>1000</u>
THROTTLE PRESSURE	<u>2375</u>
FEEDWATER FLOW (MLBPHR)	<u>2.15</u>
TOTAL AIR FLOW "	<u>2.45</u>
STEAM FLOW "	<u>2.3</u>
CONDENSATE FLOW "	<u>1.9</u>
GV SETTER POSITION	<u>824</u>

## PULVERIZER READINGS

	MILL AMPS	PA FAN AMPS	COAL FLOW	P.A. FLOW	MILL DIFF.	MILL TEMP
6A	55	90	65	140	9	165
6B	50	110	64	130	9	170
6C	54	95	66	140	9	165
6D	54	105	65	140	10	170

## PULVERIZER DAMPER POSITIONS (%)

	HOT AIR DAMPER	PRIMARY FLOW DAMPER	AIR REGISTERS
6A	81	56	29 77 75 50
6B	60	66	29 77 75 50
6C	73	55	34 76 76 30
6D	81	62	32 73 74 51

COMMENTS	A	B	C	D
	766840	767503		
	441455	442118		
	643756	644446		
	894883	895555		

CRIST UNIT & COMPLIANCE TEST

Run# 3  
 TYPE Steady State  
 LOAD 320

DATA SHEET  
 PASS      FAIL       
 P.E.R.     

DATE 4-3-96  
 START TIME 1203  
 STOP TIME 1305  
 WEATHER Clear  
 AMBIENT TEMP -70°

AIR/GAS TEMPERATURES (DEG. F)	
PT. 1 6A AH INLET AIR	<u>93</u>
PT. 2 6A AH OUTLET AIR	<u>610</u>
PT. 3 6B AH INLET AIR	<u>93</u>
PT. 4 6B AH OUTLET AIR	<u>597</u>
PT. 5 LH ECONO OUT GAS	<u>701</u>
PT. 6 RH ECONO OUT GAS	<u>731</u>
PT. 7 LH AH OUTLET GAS	<u>345</u>
PT. 8 RH AH OUTLET GAS	<u>376</u>

DRAFT INDICATION (IN. OF H2O)

6A F.D. FAN DISCHARGE	<u>12.5</u>
6B F.D. FAN DISCHARGE	<u>15</u>
6A AH GAS DIFF.	<u>12.5</u>
6B AH GAS DIFF.	<u>10.5</u>
FURNACE PRESSURE	<u>0</u>
WINDBOX PRESSURE	<u>+7.5</u>
FURNACE GAS	<u>77</u>
ECONO INLET GAS	<u>2.7</u>
ECONO OUTLET PSI	<u>7.0</u>
I.D. DUCT PRESSURE	<u>19.</u>
6A I.D. SUCTION	<u>24</u>
6B I.D. SUCTION	<u>20</u>

DAMPER POSITIONS

SUPERHEAT/REHEAT	<u>75/25</u>
6A F.D. FAN INLET	<u>71</u>
6B F.D. FAN INLET	<u>79</u>
6A I.D. FAN INLET	<u>54</u>
6B I.D. FAN INLET	<u>58</u>
6A HOT AIR RECIRC.	<u>0</u>
6B HOT AIR RECIRC.	<u>0</u>

OPACITY

6 MINUTE AVG.	<u><del>1.7</del> 1.7</u>
6A INSTANT.	<u>.02</u>
6B INSTANT.	<u>.06</u>
6A O2	<u>2.9</u>
6B O2	<u>2.8</u>
STACK O2	<u>3.8</u>
SO2 CHART	<u>2.9/28</u>

BAROMETER	<u>30<sup>20</sup></u>
CONDENSER VAC	<u>27<sup>20</sup></u>
BACKPRESSURE	<u>3.00</u>
6A/6B COND IN	<u>111/88</u>
6A/6B COND OUT	<u>110/88</u>

FAN AMPS

6A I.D. FAN	<u>4.20</u>
6B I.D. FAN	<u>4.10</u>
6A F.D. FAN	<u>283.0 293.0 286.5</u>
6B F.D. FAN	<u>210.4 216.8 209.8</u>
6A HAR FAN	<u>0</u>
6B HAR FAN	<u>0</u>

SUPERHEAT TEMPERATURE	<u>1000</u>
REHEAT TEMPERATURE	<u>1000</u>
THROTTLE PRESSURE	<u>2375</u>
FEEDWATER FLOW (MLPHR)	<u>2.2</u>
TOTAL AIR FLOW "	<u>2.4</u>
STEAM FLOW "	<u>2.3</u>
CONDENSATE FLOW "	<u>1.8</u>
GV SETTER POSITION	<u>824</u>

## PULVERIZER READINGS

MILL AMPS	PA FAN AMPS	COAL FLOW	P.A. FLOW	MILL DIFF.	MILL TEMP
6A 53	90	65	140	9	165
6B 50	112	64	130	9	170
6C 53	97	66	140	9	170
6D 53	112	65	140	10	170

## PULVERIZER DAMPER POSITIONS (%)

HOT AIR DAMPER	PRIMARY FLOW DAMPER	AIR REGISTERS
	56	
6A 76	56	32 76 79 50
6B 58	65	29 77 75 50
6C 73	55	34 76 76 30
6D 80	62	32 74 74 51

1305

COMMENTS	A-768332	A 768998
	B-442948	B 443617
	C-645311	C 646007
	D-896396	D 897074



=====  
 Hourly Emission Measurement Summary  
 Gulf Power Company  
 Crist Unit 6  
 Pensacola, Florida  
 =====

Today's Date: 04/03/96  
 Today's Time: 14:45:49

Report Date: 04/03/96  
 Report Hour: 08 - 09

Opacity Percent	01-06	1.5	31-36	1.5
	07-12	1.5	37-42	1.5
	13-18	1.5	43-48	1.5
	19-24	1.5	49-54	1.5
	25-30	1.5	55-60	1.5

Hourly Averages	S02	NOX	CO2
Measured	633.0 ppm	287.2 ppm	12.3 %
Bias Adjusted	645.0 ppm	287.2 ppm	12.3 %
Rate	1.5 lb/mmbtu	0.5 lb/mmbtu	
Bias Adjusted	1.5 lb/mmbtu	0.5 lb/mmbtu	
3 Hr Avg			
Mass Emissions	5062.0 lb/mmbtu		337.7 ton/hr
Bias Adjusted	5462.3 lb/hr		357.6 ton/hr
Bias Factor	1.019	1.000	1.000
Source	1	1	1
Heat Input	3291.8		
Load Range	9.4		
Zero Calibration	3.2 ppm	0.7 ppm	0.0 %
Expected Value	0.0 ppm	0.0 ppm	0.0 %
Span Calibration	2681.6 ppm	896.6 ppm	16.5 %
Expected Value	2632.9 ppm	896.6 ppm	17.0 %

Hourly Averages	Flow	Gross Generation	Opacity
Measured	48174000 scfh	319.6 MWge	
Bias Adjusted	51016266 scfh		
Bias Factor	1.059		
Source	1		
Zero Calibration	-1.3 scfh		0.0 %
Expected Value	0.0 scfh		0.0 %
Span Calibration	851.5 scfh		49.0 %
Expected Value	875.0 scfh		47.4 %

Instrument Status	Opacity Monitor	Normal
	S02 Analyzer	Normal
	NOX Analyzer	Normal
	CO2 Analyzer	Normal
	Flow Monitor	Normal

Legend	** Excess Emissions	## Insufficient Data
	!! Fans Off	\$\$ Boiler Off

=====  
 Hourly Emission Measurement Summary  
 Gulf Power Company  
 Crist Unit 6  
 Pensacola, Florida  
 =====

Today's Date: 04/03/96  
 Today's Time: 14:49:47

Report Date: 04/03/96  
 Report Hour: 09 - 10

Opacity Percent	01-06	1.6	31-36	1.6
	07-12	1.5	37-42	1.5
	13-18	1.5	43-48	1.5
	19-24	1.5	49-54	1.5
	25-30	1.5	55-60	1.5

Hourly Averages	S02	NOX	CO2
Measured	627.7 ppm	292.1 ppm	12.3 %
Bias Adjusted	639.6 ppm	292.1 ppm	12.3 %
Rate	1.5 lb/mmbtu	0.5 lb/mmbtu	
Bias Adjusted	1.5 lb/mmbtu	0.5 lb/mmbtu	
3 Hr Avg			
Mass Emissions	5043.4 lb/mmbtu		339.3 ton/hr
Bias Adjusted	5442.2 lb/hr		359.3 ton/hr
Bias Factor	1.019	1.000	1.000
Source	1	1	1
Heat Input	3307.4		
Load Range	9.4		
Zero Calibration	3.2 ppm	0.7 ppm	0.0 %
Expected Value	0.0 ppm	0.0 ppm	0.0 %
Span Calibration	2681.6 ppm	896.6 ppm	16.5 %
Expected Value	2632.9 ppm	896.6 ppm	17.0 %

Hourly Averages	Flow	Gross Generation	Opacity
Measured	48402000 scfh	318.3 MWge	
Bias Adjusted	51257718 scfh		
Bias Factor	1.059		
Source	1		
Zero Calibration	-1.3 scfh		0.0 %
Expected Value	0.0 scfh		0.0 %
Span Calibration	851.5 scfh		49.0 %
Expected Value	875.0 scfh		47.4 %

Instrument Status	Opacity Monitor	Normal
	S02 Analyzer	Normal
	NOX Analyzer	Normal
	CO2 Analyzer	Normal
	Flow Monitor	Normal

Legend	** Excess Emissions	## Insufficient Data
	!! Fans Off	\$\$ Boiler Off

=====  
 Hourly Emission Measurement Summary  
 Gulf Power Company  
 Crist Unit 6  
 Pensacola, Florida  
 =====

Today's Date: 04/03/96  
 Today's Time: 14:53:01

Report Date: 04/03/96  
 Report Hour: 10 - 11

Opacity Percent	01-06	1.5	31-36	1.5
	07-12	1.5	37-42	1.7
	13-18	1.5	43-48	1.5
	19-24	1.5	49-54	1.5
	25-30	1.5	55-60	1.5

Hourly Averages	S02	NOX	CO2
Measured	626.7 ppm	288.5 ppm	12.3 %
Bias Adjusted	638.6 ppm	288.5 ppm	12.3 %
Rate	1.5 lb/mmbtu	0.5 lb/mmbtu	
Bias Adjusted	1.5 lb/mmbtu	0.5 lb/mmbtu	
3 Hr Avg			
Mass Emissions	5038.5 lb/mmbtu		339.5 ton/hr
Bias Adjusted	5437.1 lb/hr		359.5 ton/hr
Bias Factor	1.019	1.000	1.000
Source	1	1	1
Heat Input	3309.5		
Load Range	9.4		
Zero Calibration	3.2 ppm	0.7 ppm	0.0 %
Expected Value	0.0 ppm	0.0 ppm	0.0 %
Span Calibration	2681.6 ppm	896.6 ppm	16.5 %
Expected Value	2632.9 ppm	896.6 ppm	17.0 %

Hourly Averages	Flow	Gross Generation	Opacity
Measured	48432000 scfh	317.8 MWge	
Bias Adjusted	51289488 scfh		
Bias Factor	1.059		
Source	1		
Zero Calibration	-1.3 scfh		0.0 %
Expected Value	0.0 scfh		0.0 %
Span Calibration	851.5 scfh		49.0 %
Expected Value	875.0 scfh		47.4 %

Instrument Status	Opacity Monitor	Normal
	S02 Analyzer	Normal
	NOX Analyzer	Normal
	CO2 Analyzer	Normal
	Flow Monitor	Normal

Legend	** Excess Emissions	## Insufficient Data
	!! Fans Off	\$\$ Boiler Off

=====  
 Hourly Emission Measurement Summary  
 Gulf Power Company  
 Crist Unit 6  
 Pensacola, Florida  
 =====

Today's Date: 04/03/96  
 Today's Time: 14:59:00

Report Date: 04/03/96  
 Report Hour: 11 - 12

Opacity Percent	01-06	1.6	31-36	1.6
	07-12	1.7	37-42	1.7
	13-18	1.7	43-48	1.7
	19-24	1.5	49-54	1.8
	25-30	1.4	55-60	1.6

Hourly Averages	S02	NOX	CO2
Measured	628.7 ppm	288.5 ppm	12.3 %
Bias Adjusted	640.6 ppm	288.5 ppm	12.3 %
Rate	1.5 lb/mmbtu	0.5 lb/mmbtu	
Bias Adjusted	1.5 lb/mmbtu	0.5 lb/mmbtu	
3 Hr Avg			
Mass Emissions	5043.9 lb/mmbtu		338.8 ton/hr
Bias Adjusted	5442.6 lb/hr		358.8 ton/hr
Bias Factor	1.019	1.000	1.000
Source	1	1	1
Heat Input	3302.5		
Load Range	9.4		
Zero Calibration	3.2 ppm	0.7 ppm	0.0 %
Expected Value	0.0 ppm	0.0 ppm	0.0 %
Span Calibration	2681.6 ppm	896.6 ppm	16.5 %
Expected Value	2632.9 ppm	896.6 ppm	17.0 %

Hourly Averages	Flow	Gross Generation	Opacity
Measured	48330000 scfh	317.6 MWge	
Bias Adjusted	51181470 scfh		
Bias Factor	1.059		
Source	1		
Zero Calibration	-1.3 scfh		0.0 %
Expected Value	0.0 scfh		0.0 %
Span Calibration	851.5 scfh		49.0 %
Expected Value	875.0 scfh		47.4 %

Instrument Status	Opacity Monitor	Normal
	S02 Analyzer	Normal
	NOX Analyzer	Normal
	CO2 Analyzer	Normal
	Flow Monitor	Normal

Legend                    \*\* Excess Emissions            ## Insufficient Data  
                              !! Fans Off                        \$\$ Boiler Off

=====  
 Hourly Emission Measurement Summary  
 Gulf Power Company  
 Crist Unit 6  
 Pensacola, Florida  
 =====

Today's Date: 04/03/96  
 Today's Time: 15:07:42

Report Date: 04/03/96  
 Report Hour: 12 - 13

Opacity Percent	01-06	1.6	31-36	1.7
	07-12	1.8	37-42	1.8
	13-18	1.9	43-48	1.9
	19-24	1.9	49-54	1.9
	25-30	1.8	55-60	1.9

Hourly Averages	S02	NOX	C02
Measured	631.4 ppm	288.7 ppm	12.3 %
Bias Adjusted	643.4 ppm	288.7 ppm	12.3 %
Rate	1.5 lb/mmbtu	0.5 lb/mmbtu	
Bias Adjusted	1.5 lb/mmbtu	0.5 lb/mmbtu	
3 Hr Avg			
Mass Emissions	5041.7 lb/mmbtu		337.2 ton/hr
Bias Adjusted	5440.6 lb/hr		357.1 ton/hr
Bias Factor	1.019	1.000	1.000
Source	1	1	1
Heat Input	3286.9		
Load Range	9.4		
Zero Calibration	3.2 ppm	0.7 ppm	0.0 %
Expected Value	0.0 ppm	0.0 ppm	0.0 %
Span Calibration	2681.6 ppm	896.6 ppm	16.5 %
Expected Value	2632.9 ppm	896.6 ppm	17.0 %

Hourly Averages	Flow	Gross Generation	Opacity
Measured	48102000 scfh	317.1 MWge	
Bias Adjusted	50940018 scfh		
Bias Factor	1.059		
Source	1		
Zero Calibration	-1.3 scfh		0.0 %
Expected Value	0.0 scfh		0.0 %
Span Calibration	851.5 scfh		49.0 %
Expected Value	875.0 scfh		47.4 %

Instrument Status	Opacity Monitor	Normal
	S02 Analyzer	Normal
	NOX Analyzer	Normal
	C02 Analyzer	Normal
	Flow Monitor	Normal

Legend                    \*\* Excess Emissions            ## Insufficient Data  
                              !! Fans Off                        \$\$ Boiler Off

=====  
 Hourly Emission Measurement Summary  
 Gulf Power Company  
 Crist Unit 6  
 Pensacola, Florida  
 =====

Today's Date: 04/03/96  
 Today's Time: 15:18:35

Report Date: 04/03/96  
 Report Hour: 13 - 14

Opacity Percent	01-06	1.8	31-36	1.9
	07-12	1.8	37-42	1.9
	13-18	1.9	43-48	1.9
	19-24	1.9	49-54	1.9
	25-30	1.9	55-60	1.9

Hourly Averages	S02	NOX	C02
Measured	637.2 ppm	288.5 ppm	12.4 %
Bias Adjusted	649.3 ppm	288.5 ppm	12.4 %
Rate	1.5 lb/mmbtu	0.5 lb/mmbtu	
Bias Adjusted	1.5 lb/mmbtu	0.5 lb/mmbtu	
3 Hr Avg			
Mass Emissions	5124.2 lb/mmbtu		342.4 ton/hr
Bias Adjusted	5529.5 lb/hr		362.6 ton/hr
Bias Factor	1.019	1.000	1.000
Source	1	1	1
Heat Input	3337.2		
Load Range	9.3		
Zero Calibration	3.2 ppm	0.7 ppm	0.0 %
Expected Value	0.0 ppm	0.0 ppm	0.0 %
Span Calibration	2681.6 ppm	896.6 ppm	16.5 %
Expected Value	2632.9 ppm	896.6 ppm	17.0 %

Hourly Averages	Flow	Gross Generation	Opacity
Measured	48444000 scfh	316.0 MWge	
Bias Adjusted	51302196 scfh		
Bias Factor	1.059		
Source	1		
Zero Calibration	-1.3 scfh		0.0 %
Expected Value	0.0 scfh		0.0 %
Span Calibration	851.5 scfh		49.0 %
Expected Value	875.0 scfh		47.4 %

Instrument Status	Opacity Monitor	Normal
	S02 Analyzer	Normal
	NOX Analyzer	Normal
	C02 Analyzer	Normal
	Flow Monitor	Normal

Legend                    \*\* Excess Emissions            ## Insufficient Data  
                           !! Fans Off                    \$\$ Boiler Off

Best Available Copy

*4th*  


---

**START**  
*Run!*  
*Steady*  
*State*

```

L                                     SIGNAL SCALES L
L                                     AC Amps___ 400 L
L AC Ampe  229.02 3 Qtime  ~  2 IE-On  ~  1 BC Ste  ~ OFF AC Volts___ 575 L
L AC Volts 399.12 3 Qlevel ~  0 IE-Off ~  0 BCMA    ~ 20 DCMA     ___ 2000 L
L DCMA     1180.8 3 Sback  ~  7 x Bkg  ~  0 BCHnt  ~  0 DCKV    ___ 120  L
L DCKV     61.18 3 Stime  ~  2 Maxchk ~  UN BCHId  ~  0 ZDDDDDDDDDDDDDDDD4 L
L Spks/Min  .00 3 Framp  ~  6          BCalq   ~ 1V
L Degs On  103.54 3 Sramp  ~ 10 EMS Blk ~  UN BCQch  ~ 10 Status   ___ 2000 L
L KWatt Pwr 91.4 3 x Sbk  ~ 30 EMstim ~  3 IBCmin ~ 100 # Scans  ___ 192 L
L           3 x Dft  ~ 25 PUR%  ~  0 IBCinc ~ 10 3Un/Off  ~ ON  L
L           3 x Max  ~ 150 frpsav ~  UN BC Mode __ IDLE 3FEP #    ___ 1  L
L           3 lmax  ~ 225 Smode   __ kVMA 3Limits  ___ 0001 L
L           3 ilim  ~ 225 kVSPK   ~ 20  ***** L
L leme      225 3 mAmx   __ 1250  f0000000000000000 L
L           3 KVmax ~ 65 mAspks/m  0 Unset   __ 21.6 f0 0 L
L Next Screen.... 7 uvtAC  ~ 50 kVspks/m  0 nkVhi   __ 86.1 f0 PARAMETERS 0L
L Last Screen.... 7 uvtDC  ~ 12 Arcs       0 nkVlo   __ 49.4 f0 AVC # IRB-5B0L
L Help..... 7 uvdly  ~ 30 Manual   OFF okVhi   __ .0 f0 Version 55 0L
L Main Menu..... 7          Scn Errs 0000 tkVlo   __ .0 f000000000000000 L
L *****08:22:33 04/03/96***** LLLLLLLLLLLLLLLLL
  
```

Messages:

PERIODIC SCAN COMPLETE ON-FRONT END # 2

F1-MNU F2-HLP F3-EMS F4-AVC F5-ALM F6-AUX F7-RAF F8-V1 F9-NEXT F10-LAST

```

L                                     SIGNAL SCALES L
L                                     AC Amps___ 400 L
L AC Ampe  227.45 3 Qtime  ~  2 IE-On  ~  1 BC Ste  ~ OFF AC Volts___ 575 L
L AC Volts 392.33 3 Qlevel ~  0 IE-Off ~  0 BCMA    ~ 20 DCMA     ___ 2000 L
L DCMA     1176.5 3 Sback  ~  7 x Bkg  ~  0 BCHnt  ~  0 DCKV    ___ 120  L
L DCKV     61.65 3 Stime  ~  2 Maxchk ~  UN BCHId  ~  0 ZDDDDDDDDDDDDDDDD4 L
L Spks/Min  .00 3 Framp  ~  6          BCalq   ~ 1V
L Degs On  103.05 3 Sramp  ~ 10 EMS Blk ~  UN BCQch  ~ 10 Status   ___ 2000 L
L KWatt Pwr 89.12 3 x Sbk  ~ 30 EMS Blk ~  3 IBCmin ~ 100 # Scans  ___ 88 L
  
```

3 x Max ~ 150 Irpsav ~ UN BC Mode IDLE 3FEP # 1  
 3  
 3 lmax ~ 225 Smode ~ kVmA  
 3Precip UN111  
 3Limits 0001  
 BC Setpt. 225 3 llim ~ 225 kVSPK ~ 20  
 3 mAmx ~ 1250  
 3 kVmax ~ 65 mAspks/m 0 Unset 21.6 0  
 Next Screen ~ 50 kVspks/m 0 nkVhi 86.1 0 PARAMETERS  
 Last Screen ~ 12 Arce 0 nkVlo 48.9 0 AVC # TRB-5B0  
 Help ~ 30 Manual OFF okVhi .0 0 Version 55 0  
 Main Menu ~ Scn Errs 0000 tkVlo .0 0  
 09:31:05 04/03/96

Run1  
 Steady  
 State  
 4th

Messages:  
 PERIODIC SCAN COMPLETE ON FRONT END # 2  
 F1-MNU F2-HLP F3-EMS F4-AVC F5-ALM F6-AUX F7-RAP F8-VI F9-NEXT F10-LAST  
 09:42:57 04/03/96 HIGH HOPPER LEVEL ON # LV-A50 \*\*\* ALARM RESET \*\*\*  
 09:43:01 04/03/96 HIGH HOPPER LEVEL ON # LV-A50 \*\*\* ALARM DETECTED \*\*\*  
 09:46:08 04/03/96 HIGH HOPPER LEVEL ON # LV-A13 \*\*\* ALARM DETECTED \*\*\*  
 09:57:42 04/03/96 HIGH HOPPER LEVEL ON # LV-A14 \*\*\* ALARM DETECTED \*\*\*

SIGNAL SCALES  
 AC Amps 229.02 3 Qtime ~ 2 IE-On ~ 1 BC Sts ~ OFF AC Amps 400  
 AC Volts 387.84 3 Qlevel ~ 0 IE-Off ~ 0 BCmA ~ 20 AC Volts 575  
 DCmA 1168.6 3 Sback ~ 7 x Bkg ~ 0 BCHnt ~ 0 DCmA 2000  
 DCKV 60.24 3 Stime ~ 2 Maxchk ~ ON BCHld ~ 0 DCKV 120  
 3pks/Min .00 3 Framp ~ 6 BCAlg ~ IV ZDDDDDDDDDDDDDD4  
 Degs On 103.10 3 Sramp ~ 10 EMS Blk ~ ON BCrch ~ 10 3Status 2000  
 kWatt Pwr 88.8 3 x Sbk ~ 30 EMStim ~ 3 IBCmin ~ 10 3# Scans 236  
 3 x Dft ~ 25 PUR% ~ 0 IBCinc ~ 10 3On/Off ~ UN  
 3 x Max ~ 150 Irpsav ~ ON BC Mode IDLE 3FEP # 1  
 3  
 3 lmax ~ 225 Smode ~ kVmA  
 3Limits 0001  
 BC Setpt. 225 3 llim ~ 225 kVSPK ~ 20  
 3 mAmx ~ 1250  
 3 kVmax ~ 65 mAspks/m 0 Unset 21.6 0  
 Next Screen ~ 50 kVspks/m 0 nkVhi 86.1 0 PARAMETERS  
 Last Screen ~ 12 Arce 0 nkVlo 48.9 0 AVC # TRB-5B0  
 Help ~ 30 Manual OFF okVhi .0 0 Version 55 0  
 Main Menu ~ Scn Errs 0000 tkVlo .0 0  
 10:12:39 04/03/96

5th  
 START  
 Run2  
 Steady  
 State

Messages: ALARMS PENDING IN SYSTEM !!!  
 DRY CONTACT - START IS NOW CLOSED  
 PERIODIC SCAN COMPLETE ON FRONT END # 2  
 F1-MNU F2-HLP F3-EMS F4-AVC F5-ALM F6-AUX F7-RAP F8-VI F9-NEXT F10-LAST  
 10:32:15 04/03/96 HIGH HOPPER LEVEL ON # LV-A13 \*\*\* ALARM RESET \*\*\*  
 10:45:02 04/03/96 HIGH HOPPER LEVEL ON # LV-A24 \*\*\* ALARM DETECTED \*\*\*

SIGNAL SCALES  
 AC Amps 225.88 3 Qtime ~ 2 IE-On ~ 1 BC Sts ~ OFF AC Amps 400

STOP 2



Best Available Copy

```

DCKV 61.18 3 Stime 2 Maxchk UN BChId 0 DCKV 120 L
Spks/Min 1.00 3 Framp 6 BCAlq 1V ZDDDDDDDDDDDDDD4L
Deds On 106.17 3 Sramp 10 EMS BIK UN BChch 10 SStatus 2000 L
KWatt Pwr 89.6 3 x Sbk 30 EMstim 3 IBCmin 100 # Scans 218 L
3 x Dft 25 PORZ 0 IBCinc 10 SOn/Off UN L
3 x Max 150 Irpsav UN BC Mode IDLE SFEP # 1 L
3 lmax 225 Smode kVma
BC Setpt. 225 3 Ilim 225 KVSPK 20
Iems 225 3 mAmax 1250
KVmax 65 mAsps/m 0 Unset 21.6 10 0L
Next Screen 2 uvTAC 50 KVspks/m 0 nkVh1 85.6 10 PARAMETERS 0L
Last Screen 2 uvTDC 12 Arce 0 nkV10 49.4 10 AVC # TRB-5B0L
Help 2 uvDly 30 Manual OFF okVh1 .0 10 Version 55 0L
Main Menu 2 Scn Errs 0000 fkV10 .0 100000000000000L

```

Steady State

Messages: ALARMS PENDING IN SYSTEM !!!

PERIODIC SCAN COMPLETE ON FRONT END # 2  
 F1-MNU F2-HLP F3-EMS F4-AVC F5-ALM F6-AUX F7-RAF F8-VI F9-NEXT F10-LAST

```

SIGNAL SCALES L
AC Amps 64.31 3 Qtime 2 IE-On 1 BC Sts OFF AC Amps 400 L
AC Volts 263.82 3 Ulevel 0 IE-Off 0 BCMA 20 AC Volts 575 L
DCMA 203.9 3 Sback 7 x Bkg 0 BChnt 0 DCMA 2000 L
DCKV 61.18 3 Stime 2 Maxchk UN BChId 0 DCKV 120 L
Spks/Min 42.00 3 Framp 6 BCAlq 1V ZDDDDDDDDDDDDDD4L
Deds On 72.79 3 Sramp 10 EMS BIK UN BChch 10 SStatus 2000 L
KWatt Pwr 17.0 3 x Sbk 30 EMstim 3 IBCmin 150 # Scans 191 L
3 x Dft 25 PORZ 0 IBCinc 10 SOn/Off UN L
3 x Max 150 Irpsav UN BC Mode IDLE SFEP # 1 L
3 lmax 183 Smode kVma
BC Setpt. 183 3 Ilim 183 KVSPK 20
Iems 75 3 mAmax 850
KVmax 70 mAsps/m 34 Unset 25.4 10 0L
Next Screen 2 uvTAC 50 KVspks/m 8 nkVh1 73.9 10 PARAMETERS 0L
Last Screen 2 uvTDC 12 Arce 7 nkV10 59.3 10 AVC # TRA-1A0L
Help 2 uvDly 30 Manual OFF okVh1 .0 10 Version 55 0L
Main Menu 2 Scn Errs 0002 fkV10 .0 100000000000000L

```

START RUN 3 Steady State

Messages: NO CONTACT - START IS NOW CLOSED

F1-MNU F2-HLP F3-EMS F4-AVC F5-ALM F6-AUX F7-RAF F8-VI F9-NEXT F10-LAST

11:58:44 04/03/96 HIGH HOPPER LEVEL ON # LV-A24 \*\*\* ALARM RESET \*\*\*

```

SIGNAL SCALES L
AC Amps 51.76 3 Qtime 2 IE-On 1 BC Sts OFF AC Amps 400 L
AC Volts 252.55 3 Ulevel 0 IE-Off 0 BCMA 20 AC Volts 575 L
DCMA 117.6 3 Sback 7 x Bkg 0 BChnt 0 DCMA 2000 L
DCKV 47.06 3 Stime 2 Maxchk UN BChId 0 DCKV 120 L
Spks/Min 49.00 3 Framp 6 BCAlq 1V ZDDDDDDDDDDDDDD4L
Deds On 64.83 3 Sramp 10 EMS BIK UN BChch 10 SStatus 2000 L
KWatt Pwr 13.1 3 x Sbk 30 EMstim 3 IBCmin 150 # Scans 98 L
3 x Dft 25 PORZ 0 IBCinc 10 SOn/Off UN L
3 x Max 150 Irpsav UN BC Mode IDLE SFEP # 1 L
3 lmax 193 Smode kVma

```

Best Available Copy

```

/ 1.0ms..... / 5.3 mAmAx..... ~ 850
/ ..... / Pmax..... ~ 70 mAspks/m_ 22 Unset..... 25.4 [0 ..... 0]
/ Next Screen..... / uvtAC..... ~ 50 kVspks/m_ 27 nkVhi..... 72.9 [0 PARAMETERS 0]
/ Last Screen..... / uvtDC..... ~ 12 Arcs..... 9 nkVlo..... 60.2 [0 AVC # TRA-1A0]
/ Help..... / uvdly..... ~ 30 Manual OFF okVhi..... .0 [0 Version 55 0]
/ Main Menu..... / ..... Scn Errs_0002 fkVlo..... .0 [0000000000000000]
/ ~~~~~/ ~~~~~13:03:22 04/03/96 ~~~~~/ ~~~~~

```

Messages:

PERIODIC SCAN COMPLETE ON FRONT END # 2

F1-MNU F2 HLP F3-EMS F4-AVC F5-ALM F6-AUX F7-RAP F8-VI F9-NEXT F10-LAST

STOP  
RUN 3

13:28:08 04/03/96 HIGH HOPPER LEVEL ON # LV-A24 \*\*\* ALARM DETECTED \*\*\*

13:28:26 04/03/96 HIGH HOPPER LEVEL ON # LV-A24 \*\*\* ALARM RESET \*\*\*

13:28:29 04/03/96 HIGH HOPPER LEVEL ON # LV-A24 \*\*\* ALARM DETECTED \*\*\*

13:28:34 04/03/96 HIGH HOPPER LEVEL ON # LV-A24 \*\*\* ALARM RESET \*\*\*

SANDERS ENGINEERING & ANALYTICAL SERVICES, INC.

**PARTICULATE EMISSIONS TEST REPORT  
SOOT BLOWING OPERATIONS**

*FOR*

**GULF POWER COMPANY**  
*Plant Crist, Unit 6  
Pensacola, Florida*



*April 2, 1996*

1568 LEROY STEVENS ROAD

MOBILE, ALABAMA 36695 • 205/633-4120

**TEST REPORT CERTIFICATION**

In regard to these tests, we certify that, to the best of our knowledge, all of the data regarding the testing performed by our agents is true and correct.

Date 4-9-96

Signature Edward L. Harris

**TABLE OF CONTENTS**

INTRODUCTION..... 1

SUMMARY AND DISCUSSION OF RESULTS ..... 2

PROCESS DESCRIPTION..... 4

    Source Air Flow ..... 4

    Operation During Testing ..... 5

SAMPLE POINT LOCATION..... 6

PARTICULATE SAMPLING PROCEDURE (EPA Method 17) ..... 7

    Particulate Sample Recovery ..... 8

    Particulate Analytical Procedures..... 9

APPENDIX A EQUATIONS AND FIELD DATA SHEETS..... 10

APPENDIX B SAMPLE CALCULATIONS ..... 11

APPENDIX C QUALITY CONTROL ..... 12

APPENDIX D OPERATIONAL DATA..... 13

**LIST OF TABLES**

TABLE I. SUMMARY OF PARTICULATE TESTING..... 3

**ILLUSTRATIONS**

FIGURE 1. AIR FLOW SCHEMATIC ..... 5

FIGURE 2. SAMPLE POINT LOCATIONS..... 6

FIGURE 3. PARTICULATE SAMPLING TRAIN..... 7

## **1. INTRODUCTION**

Sanders Engineering & Analytical Services, Inc. (SEAS) performed particulate emissions testing during soot blowing operations at Gulf Power Company, Plant Crist, Unit 6, located in Pensacola, Florida. The testing was conducted on April 2, 1996. The testing was performed in accordance with the applicable U.S. EPA procedures specified at **40 CFR, Part 60, Appendix A, Methods 1, 2, 3, 4, and 17.**

The purpose of the test was to demonstrate compliance with the rules and regulations of the Florida Department of Environmental Protection, and to meet the necessary requirements contained in the permit to operate issued by the Florida Department of Environmental Protection.

The test was conducted by Mr. Edward Harris, Mr. Robert Gunn and Mr. Dean Holmes of Sanders Engineering & Analytical Services, Inc., and was coordinated with Mr. John McPherson of Gulf Power Company. The Florida Department of Environmental Protection was notified so their representative could be present to observe the testing.

The test was conducted in accordance with the guidelines of the Florida Department of Environmental Protection. Further discussion of the test methods are included later in the report.



## **2. SUMMARY AND DISCUSSION OF RESULTS**

The results of the particulate emissions test for the soot blowing runs, along with the results of the computations, are summarized in Table I. The equations used in the calculations of the results, along with the completed field data sheets for the testing, are presented in Appendix A. The sample calculations of the first run are presented in Appendix B. The quality control checks of the equipment used in the sampling program are included in Appendix C.

The results of the testing indicate the particulate emission rate during soot blowing for Plant Crist, Unit 6, is 0.005 LBS/MMBTU. The applicable Florida Department of Environmental Protection rules and regulations require an emission rate of no greater than 0.30 LBS/MMBTU. The results of the testing indicate that the unit is in compliance with the particulate emission condition of the permit to operate issued by the Florida Department of Environmental Protection.

**TABLE I. PARTICULATE EMISSIONS TEST RESULTS  
GULF POWER COMPANY  
PLANT CRIST, UNIT 6 - SOOT BLOWING  
4/2/96**

		<u>RUN 1</u>	<u>RUN 2</u>	<u>RUN 3</u>
Title of Run				
Sampling Time -Start	Military	10:49	12:25	14:08
Sampling Time -Stop	Military	11:53	13:29	14:11
F Factor	SDCF/MMBTU	9820	9820	9820
Plant Load	Megawatts	320.0	320.0	320.0
Static Pressure	In. H2O	-0.50	-0.50	-0.50
Barometric Pressure	In. Hg	30.20	30.20	30.20
Average dH	In. H2O	1.383	1.539	1.270
Meter correction		1.038	1.038	1.038
Avg. Meter Temp.	Deg. F	64.3	71.3	77.4
% O2	%	6.3	6.9	6.9
%CO2	%	12.0	12.0	11.5
Volume Metered	ACF	37.715	39.685	36.500
Volume Water	Ml	73.0	68.5	75.0
Sampling Time	Minutes	60	60	60
Nozzle Diameter	Inches	0.206	0.208	0.199
Avg. Stack Temp.	Deg. F	344.4	347.9	347.5
Area of Stack	Sq. Feet	270.0000	270.0000	270.0000
Wt. of Part.	Mg.	6.0	9.1	5.2
Number of Points		30	30	30
Avg. Sqrt dP	In. H2O	1.1251	1.1602	1.1427

**RESULTS OF COMPUTATIONS**

		<u>RUN 1</u>	<u>RUN 2</u>	<u>RUN 3</u>	<u>Average</u>
Volume of Gas Sampled	SDCF	39.911	41.460	37.671	
H2O vapor in Gas Stream	PERCENT	7.9	7.2	8.6	7.9
Avg. Stack Gas Velocity	FT/SEC	77.2	79.6	78.7	78.5
Volumetric Flow Rate	SDCFM	762,017	788,667	768,818	773,167
Volumetric Flow Rate	SWCFM	827,622	850,002	840,865	839,496
Volumetric Flow Rate	ACF/M	1,250,753	1,290,164	1,275,559	1,272,159
Particulate Conc.	Grs/SDCF	0.002	0.003	0.002	0.003
Particulate Conc.	Grs/ACF	0.001	0.002	0.001	0.002
Particulate Mass Rate	Lb/Hr	15.1	22.8	14.0	17.3
Particulate Mass Rate	Lb/MMBtu	0.005	0.007	0.004	0.005
Heat Input	MMBTU/Hr	3252.45	3227.87	3146.62	3208.98
Percent of Isokinetic	%	101.9	100.3	102.1	


### **3. PROCESS DESCRIPTION**

The process consists of a steam electric generating unit firing bituminous coal for the production of electric energy. The coal is received by barge, and loaded directly onto the conveyor feeding the plant, or onto the stockpile and later loaded onto the conveyor belt transporting the coal to the plant. The coal from the conveyor is loaded into bunkers capable of holding between 36 to 48 hours supply of coal. The coal is then fed to pulverizing mills before being fired in the unit through the burners. Upon combustion of the coal in the fire box, approximately 20 percent of the ash falls to the bottom of the boiler and is removed by the ash removal system. The remaining 80 percent exits with the flue gases through the heat exchange and economizer sections of the furnace, and is collected by electrostatic precipitators.

#### **3.1. Source Air Flow**

As shown in Figure 1, the flue gases exit the boiler and are separated into ducts A and B before entering air preheaters. They are then routed to a cold side ESP. The flue gases exiting the cold side ESP are exhausted through a stack into the atmosphere.

Figure 1. Air Flow Schematic





**3.2. Operation During Testing**

The average heat input during soot blowing operation, as based on F-factor calculations, was 3208.98 million BTU per hour resulting in the production of approximately 320 megawatts of electricity. Precipitator data supplied by Gulf Power personnel is given in Appendix D.

4. SAMPLE POINT LOCATION

The sample point locations and outlet duct schematic are presented in Figure 2. Method 1 was used for determination of the number and location of sampling points. The minimum number of points (25) required for rectangular stacks was met by sampling a total of 30 points.

Figure 2. Sample Point Locations




**5. PARTICULATE SAMPLING PROCEDURE (EPA Method 17)**

The sampling procedure utilized is that specified in **40 CFR, Part 60, Appendix A, Method 17**, as modified by the governing regulatory agency. A brief description of this procedure is as follows:

The first impingers were partially filled with 100 milliliters of deionized water. The next impinger was left empty to act as a moisture trap. Preweighed 6 to 16 mesh indication silica gel was added to the last impinger. The sampling equipment manufactured by Lear Siegler (Model 100) or Sanders Engineering

**Figure 3. Particulate Sampling Train**



(Model 200) was assembled as shown in the attached drawing. The system was leak checked by plugging the inlet to the nozzle and pulling a 15 inch mercury vacuum. A leakage rate not in excess of 0.02 cubic feet per minute was considered acceptable.

The inside dimensions of the stack liner were measured and recorded. The required number of sampling points were marked on the probe for easy visibility. The range of velocity pressure, the percent moisture, and the temperature of the effluent gases were determined. From this data, the correct nozzle size and the nomograph multiplication factor were determined.

Crushed ice was placed around the impingers. The nozzle was placed on the first traverse point with the tip pointing directly into the gas stream. The pump was started immediately and the flow was adjusted to isokinetic sampling conditions. After the required time interval had elapsed, the probe was repositioned to the next traverse point and isokinetic sampling was re-established. This was performed for each point until the run was completed. Readings were taken at each point and recorded on the field data sheet. At the conclusion of each run, the pump was turned off and the final readings were recorded.

### **5.1. Particulate Sample Recovery**

Care was exercised in moving the collection train to the sample recovery area to minimize the loss of collected sample, or the gain of extraneous particulate matter. The volume of water in the impingers was measured, the silica gel impinger was weighed and recorded on the field data sheet. The nozzle, and all sample-exposed surfaces were washed with reagent grade acetone into a clean sample container. A brush was used to loosen any adhering particulate matter and subsequent washings were placed into the container. The filter was carefully removed from the fritted support and placed in a clean separate sample container. A sample of the acetone used in the washing was saved for a blank laboratory analysis.

## **5.2. Particulate Analytical Procedures**

The filter and any loose particulate matter were transferred from the sample container to a clean, tared weighing dish. The filter was placed in a desiccator for at least 24 hours and then weighed to the nearest 0.1 milligram until a constant weight was obtained. The original weight of the filter was deducted, and the weight gain was recorded to the nearest 0.1 milligram.

The wash solution was transferred to a clean, tared beaker. The solution was evaporated to dryness, desiccated to a constant weight, and the weight gain was recorded to the nearest 0.1 milligram.



**APPENDIX A EQUATIONS AND FIELD DATA SHEETS**

## EQUATIONS

$$1. \quad P_s = P_{\text{bar}} + \frac{P_g}{13.6}$$

$$2. \quad P_m = P_{\text{bar}} + \frac{\overline{\Delta H}}{13.6}$$

$$3. \quad V_s = K_p C_p \sqrt{\Delta P} \sqrt{\frac{\overline{T_s}}{M_s P_s}}$$

$$4. \quad V_{m(\text{Std})} = K_1 V_m Y \left[ \frac{P_{\text{bar}} + \frac{\overline{\Delta H}}{13.6}}{\overline{T_m}} \right]$$

$$5. \quad V_{w(\text{Std})} = 0.04707 V_{1c}$$

$$6. \quad B_{ws} = \frac{V_{w(\text{Std})}}{V_{m(\text{Std})} + V_{w(\text{Std})}}$$

$$7. \quad M_d = 0.44 (\%CO_2) + 0.32 (\%O_2) + 0.28 (\%N_2 + \%CO)$$

$$8. \quad M_s = M_d(1 - B_{ws}) + 18(B_{ws})$$

$$9. \quad EA = \left[ \frac{(\%O_2 - 0.5 (\%CO))}{0.264 (\%N_2 - ((\%O_2) - 0.5 (\%CO)))} \right] 100$$

$$10. \quad Q_a = (V_s) (A_s) (60)$$

$$11. \quad Q_s = Q_a (1 - B_{ws}) \frac{(528)}{\bar{T}_s} \frac{(P_s)}{29.92}$$

$$12. \quad E_H = \left( \frac{PMR}{H_I} \right)$$

$$13. \quad E = C_d F_{O_2} \left( \frac{20.9}{20.9 - \%O_2} \right)$$

$$14. \quad C_s = 0.0154 \frac{M_n}{V_{m(Std)}}$$

$$15. \quad C_{50} = \frac{21 C_s}{21 - [(1.5) (\%O_2) - 0.133 (N_2) - 0.75 (\%CO)]}$$

$$16. \quad C_{12} = \frac{C_s (12)}{\%CO_2}$$

$$17. \quad PMR = (C_s) (Q_s) \frac{(60)}{7000}$$

$$18. \quad V_n = \left[ (0.002669) (V_{1c}) + \frac{V_m Y}{\bar{T}_m} \left( p_{bar} + \frac{\bar{\Delta H}}{13.6} \right) \right] \frac{\bar{T}_s}{p_s}$$

$$19. \quad I = \frac{100 V_n}{(60) \emptyset V_s A_n}$$

## NOMENCLATURE

- $A_n$  = Cross-sectional area of nozzle, ft<sup>2</sup>
- $A_s$  = Cross sectional area of stack, ft<sup>2</sup>
- $B_{ws}$  = Water vapor in the gas stream,  
proportion by volume (dimensionless)
- $C_p$  = Pitot tube coefficient (dimensionless) (0.84)
- $C_s$  = Particulate concentration, grains/SDCF
- $C_d$  = Particulate concentration, lbs/SDCF
- $C_{12}$  = Particulate concentration ( $C_s$  adjusted to 12% CO )  
grains/SDCF
- $C_{50}$  = Particulate concentration ( $C_s$  adjusted to 50% excess air)  
grains/SDCF
- $EA$  = Excess air, %
- $E$  = Emission in lb/mmBTU
- $E_H$  = Emission in lb/mmBTU, based on heat input
- $H_I$  = Total Heat Input, Million BTU per Hour (MMBTU/hr)
- $I$  = Percent of isokinetic sampling
- $K_1$  = 17.64 °R/ inches Hg
- $K_p$  = Pitot tube constant,  
$$85.49 \text{ ft/sec} \left[ \frac{(\text{lb/lb-mole}) (\text{in. Hg})}{(^{\circ}\text{R}) (\text{inc. H}_2\text{O})} \right]^{\frac{1}{2}}$$
- $M_n$  = Total amount of particulate collected, mg
- $M_d$  = Molecular weight of stack gas; dry basis, lb/lb mole
- $M_s$  = Molecular weight of stack gas; wet basis, lb/lb mole
- $P_{bar}$  = Barometric pressure at the sampling site, in. Hg

## NOMENCLATURE (continued)

- $P_m$  = Meter pressure, in. Hg
- $P_s$  = Absolute stack pressure, in. Hg
- $P_g$  = Stack static pressure, in. H<sub>2</sub>O
- PMR = Particulate mass rate, lb/Hr
- $Q_a$  = Volumetric flow rate ACFM
- $Q_s$  = Volumetric flow rate SDCFM
- $V_s$  = Average stack gas velocity, ft/sec
- $V_{ic}$  = Total volume of liquid collected in impingers & silica gel, ml
- $V_m$  = Volume of gas sample as measured by dry gas meter, ACF
- $V_{m(std)}$  = Volume of gas sample measured by dry gas meter,  
corrected to standard conditions, SDCF
- $V_{w(std)}$  = Volume of water vapor in gas sample, corrected to standard  
conditions, SCF
- $V_n$  = Volume collected at stack conditions through nozzle, ACF
- Y = Dry gas meter calibration factor (dimensionless)
- $\Delta H$  = Average pressure difference of orifice, in. H<sub>2</sub>O
- $\Delta P$  = Velocity head of stack gas, in. H<sub>2</sub>O
- $\sqrt{\Delta P}$  = Average of square roots of the velocity pressure, in. H<sub>2</sub>O
- $\emptyset$  = Total sampling time, minutes
- %CO<sub>2</sub>, %O<sub>2</sub>, N<sub>2</sub>, %CO - Number % by volume, dry basis, from gas analysis
- $F_{O_2}$  = Oxygen based F factor (9820 SDCF/mmBTU for bituminous coal)
- $T_s$  = Temperature of the stack, °R (°F + 460)



SANDERS ENGINEERING & ANALYTICAL SERVICES, Inc.

1568 Larcy Stevens Rd.  
Mobile, AL 36695

Office: (205) 633-4120  
FAX#: (205) 633-2285

AREA = 270 ft<sup>2</sup>

FIELD DATA SHEET

COMPANY GPCO DATE 4-2-96 DGM# S-101  
 PLANT Crist OPERATOR ERN ΔHa 0.74  
 UNIT #6 <sup>SOOT</sup> BLOW METHOD 17 PROBE N/A  
liner length

RUN 1

NOZZLE CALIBRATION		FILTER NUMBER
PRE	POST	
<u>.206</u>	<u>.206</u>	<u>1337</u>
<u>.206</u>	<u>.206</u>	
<u>.206</u>	<u>.206</u>	
<u>.206</u>	<u>.206</u>	
AVERAGE	AVERAGE	

RUN 2

NOZZLE CALIBRATION		FILTER NUMBER
PRE	POST	
<u>.209</u>	<u>.208</u>	<u>1338</u>
<u>.208</u>	<u>.209</u>	
<u>.208</u>	<u>.208</u>	
<u>.208</u>	<u>.208</u>	
AVERAGE	AVERAGE	

RUN 3

NOZZLE CALIBRATION		FILTER NUMBER
PRE	POST	
<u>.199</u>	<u>.199</u>	<u>1339</u>
<u>.199</u>	<u>.199</u>	
<u>.199</u>	<u>.199</u>	
<u>.199</u>	<u>.199</u>	
AVERAGE	AVERAGE	

METER READING

<u>473.065</u>	FINAL
<u>435.350</u>	INITIAL
<u>37.715</u>	NET

METER READING

<u>514.585</u>	FINAL
<u>474.900</u>	INITIAL
<u>39.685</u>	NET

METER READING

<u>553.500</u>	FINAL
<u>517.000</u>	INITIAL
<u>36.500</u>	NET

LEAK CHECK

SYSTEM		PITOT	
Pre	Post	Pre	Post
<u>20</u>	<u>15</u>	<input checked="" type="checkbox"/> <u>impac</u>	<input checked="" type="checkbox"/> <u>impac</u>
<u>0.010</u>	<u>0.005</u>	<input checked="" type="checkbox"/> <u>static</u>	<input checked="" type="checkbox"/> <u>static</u>
<small>in. hg</small>	<small>in. hg</small>	<small>cm</small>	<small>cm</small>

LEAK CHECK

SYSTEM		PITOT	
Pre	Post	Pre	Post
<u>15</u>	<u>20</u>	<input checked="" type="checkbox"/> <u>impac</u>	<input checked="" type="checkbox"/> <u>impac</u>
<u>0.005</u>	<u>0.005</u>	<input checked="" type="checkbox"/> <u>static</u>	<input checked="" type="checkbox"/> <u>static</u>
<small>in. hg</small>	<small>in. hg</small>	<small>cm</small>	<small>cm</small>

LEAK CHECK

SYSTEM		PITOT	
Pre	Post	Pre	Post
<u>15</u>	<u>10</u>	<input checked="" type="checkbox"/> <u>impac</u>	<input checked="" type="checkbox"/> <u>impac</u>
<u>0.000</u>	<u>0.000</u>	<input checked="" type="checkbox"/> <u>static</u>	<input checked="" type="checkbox"/> <u>static</u>
<small>in. hg</small>	<small>in. hg</small>	<small>cm</small>	<small>cm</small>

VOLUME OF LIQUID WATER COLLECTED

IMP. 1	IMP. 2	IMP. 3	IMP. 4
<u>166</u>	<u>100</u>	<u>0</u>	<u>1482.0</u>
<u>100</u>	<u>100</u>	<u>0</u>	<u>1475.0</u>
<u>6</u>	<u>6</u>	<u>0</u>	<u>7.0</u>
NET	NET	NET	NET
			TOTAL <u>73.0</u>

VOLUME OF LIQUID WATER COLLECTED

IMP. 1	IMP. 2	IMP. 3	IMP. 4
<u>160</u>	<u>100</u>	<u>0</u>	<u>1460.0</u>
<u>100</u>	<u>100</u>	<u>0</u>	<u>1451.5</u>
<u>60</u>	<u>0</u>	<u>0</u>	<u>8.5</u>
NET	NET	NET	NET
			TOTAL <u>68.5</u>

VOLUME OF LIQUID WATER COLLECTED

IMP. 1	IMP. 2	IMP. 3	IMP. 4
<u>166</u>	<u>100</u>	<u>0</u>	<u>1491.0</u>
<u>100</u>	<u>100</u>	<u>0</u>	<u>1482.0</u>
<u>66</u>	<u>0</u>	<u>0</u>	<u>9.0</u>
NET	NET	NET	NET
			TOTAL <u>75.0</u>

GAS ANALYSIS

O <sub>2</sub> <u>6.3 %</u>	STATIC <u>-0.50</u>
CO <sub>2</sub> <u>12.0 %</u>	BAROMETRIC
CO <u>-</u>	<u>30.20</u>
	<small>in. hg</small>

GAS ANALYSIS

O <sub>2</sub> <u>6.9 %</u>	STATIC <u>-0.50</u>
CO <sub>2</sub> <u>12.0 %</u>	BAROMETRIC
CO <u>-</u>	<u>30.20</u>
	<small>in. hg</small>

GAS ANALYSIS

O <sub>2</sub> <u>6.9 %</u>	STATIC <u>-0.50</u>
CO <sub>2</sub> <u>11.5 %</u>	BAROMETRIC
CO <u>-</u>	<u>30.20</u>
	<small>in. hg</small>

Bob  
Dean

Port # Point #	Time	Gas Meter Vol. (cu. ft.)	Vel. Head $\Delta P$ in. H <sub>2</sub> O	Orifice Head $\Delta H$ in. H <sub>2</sub> O	Temperature (F)						Vac. in. H <sub>g</sub>
					Stack	Probe	Hot Box	Imp.	Gas Meter		
									In	Out	
1-1	10:49	435.3500	1.20	1.28	337	N/A	N/A	49	61	61	2
2	:51	436.650	1.50	1.62	345			✓	60	61	3
3	:53	437.900	1.20	1.30	342			✓	61	61	3
4	:55	439.200	1.25	1.35	339			✓	61	61	3
5	:57	440.400	1.30	1.40	340			✓	61	61	3
6	:59	441.700	2.10	2.27	341			✓	61	61	5
2-1	11:02	443.270	1.0	1.08	346			✓	62	61	2
2	:04	444.300	1.30	1.40	347			53	62	62	2.5
3	:06	445.600	1.25	1.35	346			✓	63	62	2.5
4	:08	446.800	1.47	1.59	341			✓	63	62	3
5	:10	448.200	1.30	1.40	341			✓	63	62	3
6	:12	449.500	1.70	1.84	342			✓	63	63	3.5
3-1	11:15	450.965	1.25	1.35	347			✓	64	64	2.5
2	:17	452.200	1.15	1.25	348			55	64	64	2.5
3	:19	453.400	1.20	1.30	347			✓	65	64	2.5
4	:21	454.600	1.15	1.25	345			✓	65	65	3
5	:23	455.900	.95	1.03	344			✓	65	65	2
6	:25	456.900	.84	.91	343			✓	65	65	2
4-1	11:28	458.000	1.10	1.19	348			✓	65	65	2
2	:30	459.000	1.15	1.25	350			✓	65	65	2.5
3	:32	460.400	1.15	1.25	349			✓	67	66	2.5
4	:34	461.500	1.20	1.30	343			57	67	66	3
5	:36	462.800	1.20	1.30	343			✓	67	67	3
6	:38	463.950	1.10	1.19	344			✓	67	67	3
5-1	11:41	465.171	1.40	1.52	346			✓	68	67	3
2	:43	466.500	1.20	1.30	349			✓	68	67	3
3	:45	467.650	1.25	1.35	348			✓	68	67	3
4	:47	469.000	1.15	1.26	344			✓	68	67	3
5	:49	470.200	1.45	1.59	343			✓	68	67	3
6	:51	471.500	1.85	2.03	345			✓	68	67	5
Final	11:53	473.065									

Check indicates Temperatures Meet Required Limits.

Company GPCO Date 4-2-96  
 Site Crist #6 Run # 1 Page 2 Of 4

Port # Point #	Time	Gas Meter Vol. (cu. ft.)	Vel. Head ΔP in. H <sub>2</sub> O	Orifice Head ΔH in. H <sub>2</sub> O	Temperature (F)						Vac. in. H <sub>g</sub>
					Stack	Probe	Hot Box	Imp.	Gas Meter		
									In	Out	
5-1	12:25	474.900	1.45	1.64	350	N/A	N/A	53	68	68	5
2	:27	476.300	1.20	1.36	352			✓	68	68	4
3	:29	477.500	1.24	1.40	352			✓	69	69	4
4	:31	478.900	1.10	1.24	348			✓	69	68	4
5	:33	480.100	1.25	1.41	349			✓	69	69	4
6	:35	481.400	1.80	2.04	350			53	69	69	5
4-1	12:38	482.895	1.05	1.19	352			✓	69	69	3
2	:40	484.200	1.30	1.47	352			✓	70	69	4
3	:42	485.350	1.25	1.41	352			✓	70	70	4
4	:44	486.600	1.25	1.41	347			✓	71	70	4
5	:46	488.100	1.15	1.30	347			✓	71	70	4
6	:48	489.200	1.20	1.36	347			✓	71	70	4
3-1	12:51	490.380	1.35	1.53	350			✓	72	71	4
2	:53	491.700	1.25	1.41	350			✓	71	71	4
3	:55	493.000	1.25	1.41	349			✓	71	71	4
4	:57	494.300	1.35	1.53	347			✓	72	71	5
5	:59	495.600	.95	1.07	347			55	72	71	4
6	13:01	496.700	1.20	1.36	346			✓	72	72	4
2-1	:04	497.960	1.35	1.53	348			✓	72	72	5
2	:06	499.200	1.20	1.36	350			✓	73	72	4
3	:08	500.500	1.50	1.70	349			✓	73	73	5
4	:10	501.900	1.70	1.93	345			✓	73	73	5.5
5	:12	503.400	1.25	1.41	346			✓	74	73	5
6	:14	504.700	1.65	1.87	346			✓	74	73	5
1-1	13:17	506.180	1.29	1.46	343			57	74	73	3
2	:19	507.300	1.80	2.04	348			✓	74	73	6
3	:21	508.800	1.70	1.93	348			✓	74	73	6
4	:23	510.350	1.42	1.61	343			✓	74	73	5.5
5	:25	511.700	1.05	1.20	342			✓	74	73	4
6	:27	512.900	2.25	2.58	343			✓	74	73	6
Final	13:29	514.585									

Check indicates Temperatures Meet Required Limits.

K=1.148

Company GPCO 850,002 Date 4-2-96  
 Site Crist #6 Run # 2 Page 3 Of 4



K=962

Port # Point #	Time	Gas Meter Vcl. (cu. ft.)	Vel. Head $\Delta P$ in. H <sub>2</sub> O	Orifice Head $\Delta H$ in. H <sub>2</sub> O	Temperature (F)						Vac. in. H <sub>g</sub>
					Stack	Probe	Hot Box	Imp.	Gas Meter		
									In	Out	
1-1	14:08	517.000	1.20	1.15	339	N/A	N/A	50	74	74	4
2	:10	518.200	2.0	1.92	349			✓	74	74	6
3	:12	519.500	1.65	1.58	350			✓	74	74	5
4	:14	521.000	1.40	1.34	346			✓	75	75	5
5	:16	522.400	1.35	1.29	345			✓	75	75	4
6	:18	523.500	2.20	2.11	346			✓	76	76	6
2-1	14:20	525.035	1.25	1.20	350			51	76	76	3
2	:22	526.300	1.25	1.20	352			✓	76	76	3
3	:24	527.400	1.50	1.44	350			✓	77	76	4.5
4	:26	528.700	1.40	1.35	346			✓	77	76	4.5
5	:28	530.000	1.25	1.20	345			✓	77	76	4
6	:30	531.100	1.50	1.44	345			✓	77	77	4.5
3-1	14:33	532.370	1.30	1.25	349			✓	77	77	4
2	:35	533.550	1.05	1.01	350			55	77	77	4
3	:37	534.700	1.35	1.30	349			✓	78	77	4
4	:39	535.800	1.30	1.25	345			✓	78	77	4
5	:41	537.100	.85	.82	345			✓	78	77	4
6	:43	538.100	1.10	1.06	345			✓	78	78	4
4-1	14:46	539.245	1.0	.96	350			✓	79	78	4
2	:48	540.400	1.20	1.15	351			✓	79	79	4
3	:50	541.500	1.10	1.06	352			✓	79	79	4
4	:52	542.600	1.35	1.30	347			✓	79	79	5
5	:54	543.900	1.20	1.15	346			✓	80	79	5
6	:56	545.200	.70	.67	347			59	80	79	3
5-1	14:59	546.063	1.40	1.35	350			✓	80	80	4
2	:01	547.200	1.25	1.20	351			✓	80	79	4
3	:03	548.400	1.27	1.22	350			✓	80	79	4
4	:05	549.750	1.15	1.11	345			✓	80	79	4
5	:07	550.850	1.25	1.20	344			✓	80	79	4
6	:09	551.950	1.90	1.83	345			✓	80	79	5
Final	14:11	553.500									

Check Indicates Temperatures Meet Required Limits.

Company GPCO

Date 4-2-96

Site Crist #6

Run # 3

Page 4 Of 4

## LABORATORY ANALYSIS & CHAIN OF CUSTODY

COMPANY/PLANT: Gulf Power Co., Plant Crist

UNIT #: 6 DATE OF TEST: 4/2-3/96 TYPE OF TEST:  M-5  M-17  OTHER \_\_\_\_\_

SAMPLE #	RELINQUISHED BY	RECEIVED BY	TIME	DATE	REASON FOR CHANGE
1337	<del>ERT</del>	<del>QGW</del>	<del>5:40 PM</del>	<del>4/2/96</del>	<del>Analysis</del>
1338	<del>ERT</del>	<del>QGW</del>	<del>5:40 PM</del>	<del>4/2/96</del>	<del>Analysis</del>
1339	<del>ERT</del>	<del>QGW</del>	<del>5:40 PM</del>	<del>4/2/96</del>	<del>Analysis</del>

UNIT # 6 (Soot Blowing)

RUN # <u>1</u>	FILTER # <u>1337</u>	BEAKER # <u>20</u>	WASH (ML) <u>35</u>
FINAL WEIGHT	<u>125.2</u>	<u>64143.4</u>	
INITIAL WEIGHT	<u>120.6</u>	<u>64142.0</u>	
DIFFERENCE	<u>4.6</u>	<u>1.4</u>	
CORRECTED TOTAL WEIGHT		<u>6.0</u>	
RUN # <u>2</u>	FILTER # <u>1338</u>	BEAKER # <u>29</u>	WASH (ML) <u>39</u>
FINAL WEIGHT	<u>130.5</u>	<u>68128.5</u>	
INITIAL WEIGHT	<u>123.7</u>	<u>68126.2</u>	
DIFFERENCE	<u>6.8</u>	<u>2.3</u>	
CORRECTED TOTAL WEIGHT		<u>9.1</u>	
RUN # <u>3</u>	FILTER # <u>1339</u>	BEAKER # <u>30</u>	WASH (ML) <u>46</u>
FINAL WEIGHT	<u>126.9</u>	<u>67078.5</u>	
INITIAL WEIGHT	<u>122.0</u>	<u>67078.2</u>	
DIFFERENCE	<u>4.9</u>	<u>0.3</u>	
CORRECTED TOTAL WEIGHT		<u>5.2</u>	
RUN # _____	FILTER # _____	BEAKER # _____	WASH (ML) _____
FINAL WEIGHT	<u>N/A</u>		
INITIAL WEIGHT			
DIFFERENCE			
CORRECTED TOTAL WEIGHT			

UNIT # \_\_\_\_\_

RUN # _____	FILTER # _____	BEAKER # _____	WASH (ML) _____
FINAL WEIGHT			
INITIAL WEIGHT			
DIFFERENCE			
CORRECTED TOTAL WEIGHT			
RUN # _____	FILTER # _____	BEAKER # _____	WASH (ML) _____
FINAL WEIGHT			
INITIAL WEIGHT			
DIFFERENCE			
CORRECTED TOTAL WEIGHT			
WASH SOLVENT BLANK (ML)		BEAKER # _____	WASH (ML) _____
FINAL WEIGHT			
INITIAL WEIGHT			
DIFFERENCE			
CORRECTION FACTOR (MG/ML)			

ALL WEIGHTS ARE IN MILLIGRAMS (MG)

**APPENDIX B SAMPLE CALCULATIONS**

**Input and Constants**

```

          3
    9820 ft
f := -----
    mm btu

pg := -(0.5 in. H2O)
pbar := 30.2 in. Hg.
Δhavg := 1.383 in. H2O
y := 1.038
tm := 64.3 °F
o2 := 6.3
co2 := 12.

          3
vm := 37.715 ft
vlc := 73. ml
theta := 60 min
nozdia := 0.206 in.
ts := 344.4 °F

          2
as := -270. ft
mn := 6. mg
numberofpoints := 30

          0.5
sqrtAp := 1.1251 in. H2O

          lb in. Hg.    0.5
    85.49 1 ft 1 (-----)
          lb-mole °R in. H2O
kp := -----
          1 sec

cp := 0.84

    17.64 °R
k1 := -----
    in. Hg.

```

$$t_s = \frac{(t_s + 460 \text{ }^\circ\text{F}) \text{ }^\circ\text{R}}{\text{ }^\circ\text{F}}$$

804.4 °R

$$t_m = \frac{(t_m + 460 \text{ }^\circ\text{F}) \text{ }^\circ\text{R}}{\text{ }^\circ\text{F}}$$

524.3 °R

$$n_2 = 100 - o_2 - co_2$$

81.7

$$a_n = \frac{\text{nozdia}^2 \cdot 3.1416}{4 \left( \frac{12 \text{ in.}^2}{\text{ft}} \right)}$$

0.000231453 ft<sup>2</sup>

**Calculations**

**Equation 1**

$$p_s = p_{bar} + \frac{pg}{13.6 \text{ in. H}_2\text{O}} \times 1 \text{ in. Hg.}$$

30.1632 in. Hg.

**Equation 2**

$$p_m = p_{bar} + \frac{\Delta h_{avg}}{13.6 \text{ in. H}_2\text{O}} \times \text{in. Hg.}$$

30.3017 in. Hg.

**Equation 3**

$$k_1 v_m \gamma \left( p_{bar} + \frac{\Delta h_{avg}}{13.6 \text{ in. H}_2\text{O}} \right) \times \text{in. Hg.}$$

$$v_{mstd} = \frac{\text{-----}}{tm}$$

39.9114 ft<sup>3</sup>

**Equation 4**

$$v_{wstd} = \frac{0.04707 \text{ ft}^3 v_{lc}}{m_l}$$

3.43611 ft<sup>3</sup>

**Equation 5**

$$bws = \frac{v_{wstd}}{v_{mstd} + v_{wstd}}$$

0.0792689

Equation 6

$$md = \frac{(0.44 \text{ co}_2 + 0.32 \text{ o}_2 + 0.28 \text{ n}_2) \text{ lb}}{\text{lb-mole}}$$

$$\frac{30.172 \text{ lb}}{\text{lb-mole}}$$

Equation 7

$$ms = md (1 - bws) + \frac{bws \text{ 18 lb}}{\text{lb-mole}}$$

$$\frac{29.2071 \text{ lb}}{\text{lb-mole}}$$

Equation 8

$$vs = kp \text{ cp } \sqrt{ts} \Delta p \left( \frac{0.5}{ms \text{ ps}} \right)$$

$$\frac{77.2037 \text{ ft}}{\text{sec}}$$

Equation 9

$$qa = \frac{vs \text{ as } 60 \text{ sec}}{\text{min}}$$

$$\frac{1.2507 \text{ } 10^6 \text{ } 3 \text{ ft}}{\text{min}}$$

Equation 10

$$qs = \frac{qa (1 - bws) 528 \text{ } ^\circ\text{R ps}}{ts \text{ 29.92 in. Hg.}}$$

$$\frac{762016. \text{ } 3 \text{ ft}}{\text{min}}$$

Equation 11

$$cs = \frac{0.0154 \text{ gr mn}}{\text{mg vmstd}}$$

$$\frac{0.00231513 \text{ gr}}{\text{ft}^3}$$

Equation 12

$$pmr = \frac{cs \text{ qs } 60 \text{ min}}{\text{hour} \frac{7000 \text{ gr}}{\text{lb}}}$$

$$\frac{15.1214 \text{ lb}}{\text{hour}}$$

Equation 13

$$e = \frac{cs \text{ f } 20.9 \text{ } 1 \text{ lb}}{(20.9 - o_2) 7000 \text{ gr}}$$

$$\frac{0.00464924 \text{ lb}}{\text{mm btu}}$$

Equation 14

$$vn = \frac{0.002669 \text{ in. Hg. ft}^3 \text{ vlc} \text{ } \frac{\text{vm y pm}}{\text{tm}}}{\text{ps}}$$

$$\frac{65.5342 \text{ ft}^3}{\text{ml } ^\circ\text{R}}$$



Equation 15

$$i = \frac{100 \% \text{ vn}}{60 \text{ sec theta vs an}} \text{ min}$$

101.874 %

Equation 16

$$hi = \frac{\text{par}}{e} \text{ hour}$$

3252.45 mm btu

**APPENDIX C QUALITY CONTROL**

**INITIAL  
METER CALIBRATION FORM - DGM**

DATE: 12-05-95 Box No. S-101

Ref. DGM Ser. #	1044453	Calibrated By			EDWARD HARRIS
RUN #	1	2	3	4	5
DELTA H (DGM)	0.50	1.00	1.50	2.00	3.00
Y (Ref. DGM)	1.014	1.014	1.014	1.014	1.014
Reference DGM					
Gas Vol. Initial	19.500	25.177	31.500	38.100	45.000
Gas Vol. Final	25.177	31.500	38.100	45.000	51.466
Meter Box DGM					
Gas Vol. Initial	24.400	30.000	36.261	42.805	49.615
Gas Vol. Final	30.000	36.261	42.805	49.615	56.004
Reference DGM					
Temp.		Avg.	Avg.	Avg.	Avg.
Deg F Initial		66	67	67	67
Deg F Final		67	67	67	67
Meter Box DGM					
Temp. Initial In		66	67	68	69
Temp. Initial Out		66	67	68	69
Temp. Final In		66	67	69	69
Temp. Final Out		66	67	69	69
P Bar IN. Hg	30.08	30.08	30.08	30.08	30.08
Time (sec.)	873	688	582	525	404
Meter Calibration					
Factor (Y)	1.026	1.022	1.022	1.026	1.023
Qm (C.F.M.)	0.399	0.563	0.695	0.806	0.981
Km (Std Pressure)	0.727	0.726	0.730	0.733	0.730
DELTA Ha	1.77	1.78	1.75	1.73	1.75
Average Y (Meter Calibration Factor)				1.024	
Average Km (Standard Pressure)				0.729	
Average DELTA Ha of Orifice				1.755	

$Y \leq .03$   
 Max & Min  $\leq .02$  from Avg  
 Final Avg within 5% of Initial Avg  
 $\Delta Ha = \text{Max \& Min} \leq .2$  from Avg

# POST TEST QUALITY ASSURANCE

Date: 4/5/96

BOX #: S-101

Ref. Meter: 1044453

Calibrated By: EDWARD HARRIS

## DRY GAS METER

		Unit	Run 1	Run 2	Run 3
<b>FIELD METER</b>	<b><math>\Delta H</math></b>	In. H <sub>2</sub> O	1.50	1.50	1.50
	<i>Initial Gas Volume</i>	Ft. <sup>3</sup>	952.600	958.500	964.090
	<i>Final Gas Volume</i>	Ft. <sup>3</sup>	958.500	964.090	969.783
	<i>Initial Temp. In</i>	°F	61	61	61
	<i>Initial Temp. Out</i>	°F	61	60	61
	<i>Final Temp. In</i>	°F	62	61	61
	<i>Final Temp. Out</i>	°F	60	61	61
<b>REF. METER</b>	<b>Y</b>	<i>Dimensionless</i>	1.014	1.014	1.014
	<i>Initial Gas Volume</i>	Ft. <sup>3</sup>	582.700	589.006	595.000
	<i>Final Gas Volume</i>	Ft. <sup>3</sup>	589.006	595.000	601.000
	<i>Initial Temp.</i>	°F	58	58	58
	<i>Final Temp.</i>	°F	58	58	58
	<b>Barometric Pressure</b>	In. Hg	30.02	30.02	30.02
	<b>Time</b>	sec	513	494	496
	<b>Meter Calibration Factor</b>	<i>Dimensionless</i>	1.086	1.089	1.071
	<b><math>\Delta H_s</math></b>	In. H <sub>2</sub> O	1.460	1.498	1.506
	<b>Average Y</b>	<i>Dimensionless</i>	1.082		
	<b>Initial Y</b>	<i>Dimensionless</i>	1.038		
	<b>Percent Error</b>	%	4.2 (Allowed 5.0%)		

## DIFFERENTIAL PRESSURE GAUGE

Ref. Pressure In H <sub>2</sub> O	Magnehelic Pressure In H <sub>2</sub> O	Percent Error (+/- 5%)
0.5	0.5	0
1.0	1.0	0
1.5	1.5	0

## TEMPERATURE SENSOR

Ref. Temp. (°F)	Thermocouple Temp.	Percent Error (Allowed 1.5% of Absolute)
310	310	0

## ARENOLD BAROMETER

Reference Barometer	Test Barometer	0.1 Diff. Allowed
30.02	30.02	0

# POST TEST QUALITY ASSURANCE

Date: 4/5/96

BOX #: S-101

Ref. Meter: 1044453

Callbrated By: EDWARD HARRIS

## DRY GAS METER

		Unit	Run 1	Run 2	Run 3
<b>FIELD METER</b>	<b><math>\Delta H</math></b>	In. H <sub>2</sub> O	1.50	1.50	1.50
	<i>Initial Gas Volume</i>	Ft. <sup>3</sup>	952.600	958.500	964.090
	<i>Final Gas Volume</i>	Ft. <sup>3</sup>	958.500	964.090	969.783
	<i>Initial Temp. In</i>	°F	61	61	61
	<i>Initial Temp. Out</i>	°F	61	60	61
	<i>Final Temp. In</i>	°F	62	61	61
	<i>Final Temp. Out</i>	°F	60	61	61
<b>REF. METER</b>	<b>Y</b>	<i>Dimensionless</i>	1.014	1.014	1.014
	<i>Initial Gas Volume</i>	Ft. <sup>3</sup>	582.700	589.006	595.000
	<i>Final Gas Volume</i>	Ft. <sup>3</sup>	589.006	595.000	601.000
	<i>Initial Temp.</i>	°F	58	58	58
	<i>Final Temp.</i>	°F	58	58	58
	<b>Barometric Pressure</b>	In. Hg	30.02	30.02	30.02
	<b>Time</b>	sec	513	494	496
	<b>Meter Calibration Factor</b>	<i>Dimensionless</i>	1.086	1.089	1.071
	<b><math>\Delta H_s</math></b>	In. H <sub>2</sub> O	1.460	1.498	1.506
	<b>Average Y</b>	<i>Dimensionless</i>	1.082		
	<b>Initial Y</b>	<i>Dimensionless</i>	1.038		
	<b>Percent Error</b>	%	4.2 (Allowed 5.0%)		

## DIFFERENTIAL PRESSURE GAUGE

Ref. Pressure In H <sub>2</sub> O	Magnehelic Pressure In H <sub>2</sub> O	Percent Error (+/- 5%)
0.5	0.5	0
1.0	1.0	0
1.5	1.5	0

## TEMPERATURE SENSOR

Ref. Temp. (°F)	Thermocouple Temp.	Percent Error (Allowed 1.5% of Absolute)
310	310	0

## ARENOLD BAROMETER

Reference Barometer	Test Barometer	0.1 Diff. Allowed
30.02	30.02	0

### MAGEHELIC CALIBRATION

BOX	2879	S-100	C-133	C-175	S-102	S-101	S-103
SER. NO.	91126AM 91	9126A M91	R90125 MR6	R74D	R22D	R20208 A617	
RANGE	0-2	0-2	0-2	0-2	0-5	0-2	0-2
REFERENCE READING	FIELD DEVICE READING						
0.000		0.00	0.00	0.00	0.00	0.00	0.00
0.050							
0.150							
0.200							
0.250							
0.450							
0.50	0.50	0.51	0.50	0.51	0.51	0.50	0.50
1.00	0.99	1.01	0.98	1.01	1.01	0.98	1.01
1.30							
1.80	1.80	1.82	1.79	1.82	1.81	1.79	1.82
2.50							
4.50							
5.0							
9.0							
13.0							
22.0							

SIGNATURE: Edward L. Harris

DATE: 12-5-95

**MAGEHELIC CALIBRATION**  
BOX #1

SER. NO.	10720- AB68	R1061- 6AG48	R5031- SEB76	R1062- 9JA82	R1051- 3MR42	R90124- RI119
RANGE	0-0.25	0-0.50	0-2	0-5	0-10	0-25
REFERENCE READING	FIELD DEVICE READING					
0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.050	0.050					
0.150	0.150	0.140				
0.200	0.190					
0.250		0.250				
0.450		0.450				
0.50			0.50			
1.00			1.00			
1.30				1.30		
1.80			1.80			
2.50				2.50	2.48	
4.50				4.50		
5.0					5.0	5.0
9.0					9.02	
13.0						13.0
22.0						22.0

SIGNATURE: Edward R. Harris  
DATE: 12/22/95

**MAGEHELIC CALIBRATION**  
BOX #2

SER. NO.	10819-DR2	R1090-2AG18	R50315-EB93	R1062-9TA87	30830-AM79	R1072-2MC5
RANGE	0-0.25	0-0.50	0-2	0-5	0-10	0-25
REFERENCE READING	FIELD DEVICE READING					
0.000	0.000	0.000	0.00	0.00	0.0	0.0
0.050	0.050					
0.150	0.155	0.152				
0.200	0.205					
0.250		0.256				
0.450		0.456				
0.50			0.52			
1.00			1.04			
1.30				1.32		
1.80			1.83			
2.50				2.55	2.49	
4.50				4.50		
5.0					4.9	5.2
9.0					8.8	
13.0						12.9
22.0						22.0

SIGNATURE: Edward K. Harris  
DATE: 12/22/95



**MAGEHELIC CALIBRATION**  
**BOX #3**

SER. NO.	R10908AG71 MRR1	R0112642	R10608CF20 CF20
RANGE	0-0.50	0-2.0	0-10
REFERENCE READING	FIELD DEVICE READING		
0.000	0.00	0.00	0.0
0.050			
0.150	0.149		
0.200			
0.250	0.240		
0.450	0.450		
0.50		0.50	
1.00		0.98	
1.50			
1.80		1.78	
2.50			2.5
4.50			
5.0			5.0
9.0			9.0
13.0			
22.0			

SIGNATURE:

*Edward L. Harris*

DATE:

12/22/95

**MAGEHELIC CALIBRATION**  
BOX #4

SER. NO.	R22D	R90051	R90101
		6GT21	5CD102
RANGE	0-0.50	0-5	0-25
REFERENCE READING	FIELD DEVICE READING		
0.000	0.000	0.00	0.0
0.050			
0.150	0.151		
0.200			
0.250	0.251		
0.450	0.455		
0.50			
1.00			
1.30		1.27	
1.80			
2.50		2.52	
4.50		4.55	
5.0			5.0
9.0			
13.0			13.0
22.0			21.6

SIGNATURE:

*Edward L. Harris*

DATE:

12/22/95

**TEMPERATURE CALIBRATIONS - DEGREES FAHRENHEIT**

REFERENCE DEVICE READING*	0 DEG. F	210 DEG.	420 DEG.	630 DEG.	840 DEG.	1050 DEG.	1260 DEG.	1470 DEG.	1680 DEG.	1900 DEG.
2879	0	217	421	630	839	1050	1260	1471	1681	1900
METER BOX #1 C-133 11580	0	212	423	635	842	1053	1264	1475	1679	1910
METER BOX #2 C-175 15962	0	211	423	627	839	1052	1265	1475	1687	1903
METER BOX #5 S-100 15751	2	211	417	628	844	1062	1279	1491	1698	1907
METER BOX #6 S-101 15751	0	210	419	628	839	1058	1255	1473	1691	1900
PORTABLE THERMOCOUPLE # 2 (Blue)	2	209	415	628	837	1053	1260	1468	1679	1908
PORTABLE THERMOCOUPLE # 2 (Green)	2	211	417	627	842	1058	1273	1484	1688	1896
PINK T140293	-1	208	415	624	840	1056	1272	1482	1687	1894
PORTABLE THERMOCOUPLE (Yellow)	0	210	419	632	840	1050	1259	1470	1680	1901
PORTABLE THERMOCOUPLE T-105998 (Black)	1	209	416	625	839	1055	1270	1481	1684	1891
METER BOX S-102	-2	209	417	625	837	1049	1259	1462	1658	1890
METER BOX S-103	4	215	423	632	844	1057	1266	1471	1667	1895

**DATE:**

12-05-95

**SIGNATURE:**


*Edward L. Harris*

\* Reference Device is an Omega Engineering CL505-A calibrated reference thermocouple-potentiometer system.



**SANDERS ENGINEERING- & ANALYTICAL SERVICES, Inc.**


1668 Leroy Stevens Rd. Office: (205) 833-4120  
 McAlle, AL 36006 FAX#: (205) 833-8208




**Notes:**

1.05  $D_1 \leq 1.50 D_2$

$P_A = P_B$




OR



Proper thermocouple placement to prevent interference.

The Pilot used was within the following geometric specifications:  
 $D_1$  between 0.48 and 0.65 cm (3/16 and 3/8 in.)  
 $C_p = 0.84$



Minimum pilot-sample probe separation needed to prevent interference




**SANDERS ENGINEERING &  
ANALYTICAL SERVICES, Inc.**


1600 J. Gray Stevens Rd.  
Mobile, Al. 36608

Office: (205) 833-4120  
FAX: (205) 833-2205

Proper pilot tube-sampling nozzle configuration to prevent aero-dynamic interference; batonhook type nozzle; centers of nozzle and pilot opening aligned;  $D_1$  between 0.48 and 0.65 cm (3/16 and 3/8 in.)



Bottom view showing minimum pilot/nozzle separation









Side view; to prevent pilot tube from interfering with the gas flow streamlines approaching the nozzle, the impact pressure opening plane of the pilot tube shall be even with or above the nozzle entry plane.

**SANDERS ENGINEERING & ANALYTICAL SERVICES, Inc.**

1588 Leroy Stevens Rd. Office: (205) 833-4120  
 Mobile, Al. 36685 FAX: (205) 833-2285

Types of face-opening misalignment that can result from field use or improper construction of type 'B' pilot tubes. These will not affect the baseline value of  $C_p(a)$  so long as  $\alpha_1$  and  $\alpha_2 \leq 10^\circ$ ,  $D_1$  and  $D_2 \leq 5^\circ$ ,  $\pm 0.32$  cm (1/8 in.)



**APPENDIX D OPERATIONAL DATA**

RUN# 1  
TYPE Soot Blow  
LOAD 320

DATA SHEET  
PASS \_\_\_\_\_ FAIL \_\_\_\_\_  
P.E.R. \_\_\_\_\_

DATE 3/2/95  
START TIME ~~0820~~ 1049  
STOP TIME 1153  
WEATHER CLEAR  
AMBIENT TEMP -66°F

AIR/GAS TEMPERATURES (DEG. F)	
PT. 1	6A AH INLET AIR <u>81</u>
PT. 2	6A AH OUTLET AIR <u><del>604</del> 618</u>
PT. 3	6B AH INLET AIR <u>79.54</u>
PT. 4	6B AH OUTLET AIR <u><del>617</del> 608</u>
PT. 5	6A ECONO OUT GAS <u>743 723</u>
PT. 6	6B ECONO OUT GAS <u>743 742</u>
PT. 7	6A AH OUTLET GAS <u>347 339</u>
PT. 8	6B AH OUTLET GAS <u>376 376</u>

DRAFT INDICATION (IN. OF H2O)

6A F.D. FAN DISCHARGE	<u>14</u>
6B F.D. FAN DISCHARGE	<u>14</u>
6A AH GAS DIFF.	<u>12.5</u>
6B AH GAS DIFF.	<u>11.5</u>
FURNACE PRESSURE	<u>0</u>
WINDBOX PRESSURE	<u>6.8</u>
FURNACE GAS	<u>-1.6</u>
ECONO INLET GAS	<u>3</u>
ECONO OUTLET PSI	<u>5.9</u>
I.D. DUCT PRESSURE	<u>21.5</u>
6A I.D. SUCTION	<u>24</u>
6B I.D. SUCTION	<u>21</u>

DAMPER POSITIONS

SUPERHEAT/REHEAT	<u>75/25</u>
6A F.D. FAN INLET	<u>70</u>
6B F.D. FAN INLET	<u>78</u>
6A I.D. FAN INLET	<u>51</u>
6B I.D. FAN INLET	<u>54</u>
6A HOT AIR RECIRC.	<u>0</u>
6B HOT AIR RECIRC.	<u>0</u>

FAN AMPS

6A I.D. FAN	<u>460</u>
6B I.D. FAN	<u>430</u>
6A F.D. FAN	<u>(1)271 (2)278 (3)273</u>
6B F.D. FAN	<u>(1)215 (2)223 (3)219</u>
6A HAR FAN	<u>0</u>
6B HAR FAN	<u>0</u>

CAPACITY

6 MINUTE AVG.	<u>1.5</u>
6A INSTANT.	<u>1.4</u>
6B INSTANT.	<u>1.5</u>
6A O2	<u><del>4.7</del> 4.5</u>
6B O2	<u>2.8 3.0</u>
STACK O2	<u>3.8</u>
SO2 CHART	<u>1.49</u>
BAROMETER	<u>30.08</u>
CONDENSER VAC	<u>28.05</u>
BOILER PRESSURE	<u>2.03</u>
6A/6B COND IN	<u>79 / <del>79</del> 79</u>
6A/6B COND OUT	<u>102 / 102</u>

SUPERHEAT TEMPERATURE	<u>995</u>
REHEAT TEMPERATURE	<u>995</u>
THROTTLE PRESSURE	<u>2400</u>
FEEDWATER FLOW (MLBPHR)	<u>2.25</u>
TOTAL AIR FLOW	<u>2.5</u>
STEAM FLOW	<u>2.35</u>
CONDENSATE FLOW	<u>1.95</u>
GV SETTER POSITION	<u>0820</u>



# PULVERIZER READINGS

MILL AMPS		PA FAN AMPS	COAL FLOW	P.A. FLOW	MILL DIFF.	MILL TEMP
6A	50	93	66	140	10.5	165
6B	51	99	52	130	7	170
6C	53	94	68	140	9	165
6D	51	105	67	140	10.2	170

## PULVERIZER DAMPER POSITIONS (%)

HOT AIR DAMPER		PRIMARY FLOW DAMPER	AIR REGISTERS			
6A	80	62	32	34	58	59
6B	55	58	32	32	58	64
6C	75	56	29	30	58	63
6D	80	65	31	31	50	65

COMMENTS	COAL INT.	START	Re-1049	
			<del>STOP</del> Start	STOP
	A	784323	754649	755428
	B	432210	434426	435062
	C	629630	631113	631910
	D	884205	885628	886389
1153				

DISREGARD  
 A Feeder  
 plugged @  
 1055 hr.

RUN# 2  
TYPE Soot Blow  
LOAD 320

DATA SHEET  
PASS \_\_\_\_\_ FAIL \_\_\_\_\_  
P.E.R. \_\_\_\_\_

DATE 4-2-96  
START TIME 1225  
STOP TIME 1329  
WEATHER CLEAR  
AMBIENT TEMP 66°

AIR/GAS TEMPERATURES (DEG. F)	
PT. 1	6A AH INLET AIR 87
PT. 2	6A AH OUTLET AIR 616
PT. 3	6B AH INLET AIR 88
PT. 4	6B AH OUTLET AIR 602
PT. 5	6A ECONO OUT GAS 732
PT. 6	6A AH ECONO OUT GAS 747
PT. 7	6A AH OUTLET GAS 350
PT. 8	6A AH OUTLET GAS 376

DRAFT INDICATION (IN. OF H2O)

6A F.D. FAN DISCHARGE	13
6B F.D. FAN DISCHARGE	14
6A AH GAS DIFF.	11.5
6B AH GAS DIFF.	11
FURNACE PRESSURE	0
WINDBOX PRESSURE	7
FURNACE GAS	-5
ECONO INLET GAS	2.2
ECONO OUTLET PSI	5.9
I.D. DUCT PRESSURE	21.8
6 A I.D. SUCTION	23
6 B I.D. SUCTION	21

DAMPER POSITIONS

SUPERHEAT/REHEAT	60/40
6A F.D. FAN INLET	70
6B F.D. FAN INLET	80
6A I.D. FAN INLET	56
6B I.D. FAN INLET	60
6A HOT AIR RECIRC.	0
6B HOT AIR RECIRC.	0

CAPACITY

6 MINUTE AVG.	1.7
6A INSTANT.	1.4
6B INSTANT.	1.4
6A O2	4.7
6B O2	3.3
STACK O2	4.2
SO2 CHART	1.45

BAROMETER	30.09
CONDENSER VAC	27.80
COND. PRESSURE	2.29
6A/6B COND IN	83/83
6A/6B COND OUT	105/104

FAN AMPS

6A I.D. FAN	4.60
6B I.D. FAN	4.20
6A F.D. FAN	264/274/268
6B F.D. FAN	217/224/218
6A HAR FAN	0
6B HAR FAN	0

SUPERHEAT TEMPERATURE	1800
REHEAT TEMPERATURE	995
THROTTLE PRESSURE	2375
FEEDWATER FLOW (ML/PHR)	2.15
TOTAL AIR FLOW	2.45
STEAM FLOW	2.3
CONDENSATE FLOW	1.9
GV SETTER POSITION	820

# PULVERIZER READINGS

MILL AMPS		PA FAN AMPS	COAL FLOW	P.A. FLOW	MILL DIFF.	MILL TEMP
6A	51	93	68	144	10.2	165
6B	50	109	54	135	7.2	170
6C	51	97	70	145	8.8	168
6D	52	113	68	142	10	170

## PULVERIZER DAMPER POSITIONS (%)

HOT AIR DAMPER		PRIMARY FLOW DAMPER	AIR REGISTERS			
6A	78	60	32	34	58	59
6B	54	56	32	32	58	64
6C	75	55	29	30	58	63
6D	80	64	31	31	50	65

START
END  
Coal @ 1240
@ 1329  
INT

COMMENTS	A	B	C	D
	755923	435466	632416	886873
	756516	935950	633026	887456

CRIST UNIT 6 COMPLIANCE TEST

Run# 3  
 TYPE Sootblow  
 LOAD 320

DATA SHEET  
 PASS \_\_\_\_\_ FAIL \_\_\_\_\_  
 P.E.R. \_\_\_\_\_

DATE 4-2-96  
 START TIME 1416  
 STOP TIME 1511  
 WEATHER CLEAR  
 AMBIENT TEMP -66°

AIR/GAS TEMPERATURES (DEG. F)	
PT. 1 6A AH INLET AIR	<u>90</u>
PT. 2 6A AH OUTLET AIR	<u>210</u>
PT. 3 6B AH INLET AIR	<u>92</u>
PT. 4 6B AH OUTLET AIR	<u>594</u>
PT. 5 LH ECONO OUT GAS	<u>736</u>
PT. 6 RH ECONO OUT GAS	<u>746</u>
PT. 7 LH AH OUTLET GAS	<u>350</u>
PT. 8 RH AH OUTLET GAS	<u>375</u>

DRAFT INDICATION (IN. OF H2O)

6A F.D. FAN DISCHARGE	<u>13</u>
6B F.D. FAN DISCHARGE	<u>14</u>
6A AH GAS DIFF.	<u>10.5</u>
6B AH GAS DIFF.	<u>10</u>
FURNACE PRESSURE	<u>0</u>
WINDBOX PRESSURE	<u>7</u>
FURNACE GAS	<u>-4</u>
ECONO INLET GAS	<u>2</u>
ECONO OUTLET PSI	<u>4</u>
I.D. DUCT PRESSURE	<u>21.5</u>
6A I.D. SUCTION	<u>22.5</u>
6B I.D. SUCTION	<u>20.5</u>

DAMPER POSITIONS

SUPERHEAT/REHEAT	<u>02/38</u>
6A F.D. FAN INLET	<u>70</u>
6B F.D. FAN INLET	<u>80</u>
6A I.D. FAN INLET	<u>54</u>
6B I.D. FAN INLET	<u>58</u>
6A HOT AIR RECIRC.	<u>0</u>
6B HOT AIR RECIRC.	<u>0</u>

OPACITY

6 MINUTE AVG.	<u>1.9</u>
6A INSTANT.	<u>1.9</u>
6B INSTANT.	<u>1.9</u>
6A O2	<u>3.3</u>
6B O2	<u>3.25</u>
STACK O2	<u>4.2</u>
SO2 CHART	<u>1.49</u>

BAROMETER	<u>30.06</u>
CONDENSER VAC	<u>27.40</u>
BACK PRESSURE	<u>2.46</u>
6A/6B COND IN	<u>84/84</u>
6A/6B COND OUT	<u>106/107</u>

FAN AMPS

6A I.D. FAN	<u>460</u>
6B I.D. FAN	<u>420</u>
6A F.D. FAN	<u>266/273/268</u>
6B F.D. FAN	<u>216/222/215</u>
6A HAR FAN	<u>0</u>
6B HAR FAN	<u>0</u>

SUPERHEAT TEMPERATURE	<u>1000</u>
REHEAT TEMPERATURE	<u>1000</u>
THROTTLE PRESSURE	<u>2375</u>
FEEDWATER FLOW (MLBPHR)	<u>2.15</u>
TOTAL AIR FLOW	<u>2.45</u>
STEAM FLOW	<u>2.3</u>
CONDENSATE FLOW	<u>1.9</u>
GV SETTER POSITION	<u>820</u>

## PULVERIZER READINGS

	MILL AMPS	PA FAN AMPS	COAL FLOW	P.A. FLOW	MILL DIFF.	MILL TEMP
6A	52	92	70	145	7.0	165
6B	49	109	54	130	7	170
6C	54	98	70	145	8.5	170
6D	52	112	68	144	10.5	170

## PULVERIZER DAMPER POSITIONS (%)

	HOT AIR DAMPER	PRIMARY FLOW DAMPER	AIR REGISTERS			
6A	78	62	32	34	59	59
6B	52	57	32	32	58	64
6C	75	57	30	30	58	63
6D	82	64	31	31	50	65

COAL INT.  
@ 1422

@ 1511

COMMENTS	A	B	C	D	A	B	C	D
	757066				757626			
	436399				436857			
	633587				634160			
	887991				888541			

=====  
 Hourly Emission Measurement Summary  
 Gulf Power Company  
 Crist Unit 6  
 Pensacola, Florida  
 =====

Today's Date: 04/03/96  
 Today's Time: 15:22:59

Report Date: 04/02/96  
 Report Hour: 09 - 10

Opacity Percent	01-06	1.4	31-36	1.5
	07-12	1.4	37-42	1.5
	13-18	1.4	43-48	1.5
	19-24	1.5	49-54	1.5
	25-30	1.4	55-60	1.5

Hourly Averages	S02	NOX	CO2
Measured	608.9 ppm	208.7 ppm	12.4 %
Bias Adjusted	620.5 ppm	208.7 ppm	12.4 %
Rate	1.4 lb/mmbtu	0.3 lb/mmbtu	
Bias Adjusted	1.5 lb/mmbtu	0.3 lb/mmbtu	
3 Hr Avg			
Mass Emissions	3858.3 lb/mmbtu		269.7 ton/hr
Bias Adjusted	4163.8 lb/hr		285.7 ton/hr
Bias Factor	1.019	1.000	1.000
Source	1	1	1
Heat Input	2629.6		
Load Range	8.1		
Zero Calibration	2.6 ppm	0.8 ppm	0.0 %
Expected Value	0.0 ppm	0.0 ppm	0.0 %
Span Calibration	2679.8 ppm	892.0 ppm	16.6 %
Expected Value	2632.9 ppm	896.6 ppm	17.0 %

Hourly Averages	Flow	Gross Generation	Opacity
Measured	38172000 scfh	273.4 MWge	
Bias Adjusted	40424148 scfh		
Bias Factor	1.059		
Source	1		
Zero Calibration	-1.4 scfh		0.0 %
Expected Value	0.0 scfh		0.0 %
Span Calibration	861.5 scfh		49.0 %
Expected Value	875.0 scfh		47.4 %

Instrument Status	Opacity Monitor	Normal
	S02 Analyzer	Normal
	NOX Analyzer	Normal
	CO2 Analyzer	Normal
	Flow Monitor	Normal

Legend	** Excess Emissions	## Insufficient Data
	!! Fans Off	\$\$ Boiler Off

=====  
 Hourly Emission Measurement Summary  
 Gulf Power Company  
 Crist Unit 6  
 Pensacola, Florida  
 =====

Today's Date: 04/03/96  
 Today's Time: 15:25:57

Report Date: 04/02/96  
 Report Hour: 10 - 11

Opacity Percent	01-06	1.5	31-36	1.5
	07-12	1.5	37-42	1.5
	13-18	1.5	43-48	1.5
	19-24	1.5	49-54	1.5
	25-30	1.5	55-60	1.6

Hourly Averages	S02	NOX	CO2
Measured	625.2 ppm	272.2 ppm	12.7 %
Bias Adjusted	637.1 ppm	272.2 ppm	12.7 %
Rate	1.4 lb/mmbtu	0.4 lb/mmbtu	
Bias Adjusted	1.5 lb/mmbtu	0.4 lb/mmbtu	
3 Hr Avg			
Mass Emissions	4175.2 lb/mmbtu		291.2 ton/hr
Bias Adjusted	4505.7 lb/hr		308.4 ton/hr
Bias Factor	1.019	1.000	1.000
Source	1	1	1
Heat Input	2838.4		
Load Range	8.9		
Zero Calibration	2.6 ppm	0.8 ppm	0.0 %
Expected Value	0.0 ppm	0.0 ppm	0.0 %
Span Calibration	2679.8 ppm	892.0 ppm	16.6 %
Expected Value	2632.9 ppm	896.6 ppm	17.0 %

Hourly Averages	Flow	Gross Generation	Opacity
Measured	40230000 scfh	302.7 MWge	
Bias Adjusted	42603570 scfh		
Bias Factor	1.059		
Source	1		
Zero Calibration	-1.4 scfh		0.0 %
Expected Value	0.0 scfh		0.0 %
Span Calibration	861.5 scfh		49.0 %
Expected Value	875.0 scfh		47.4 %

Instrument Status	Opacity Monitor	Normal
	S02 Analyzer	Normal
	NOX Analyzer	Normal
	CO2 Analyzer	Normal
	Flow Monitor	Normal

Legend                    \*\* Excess Emissions            ## Insufficient Data  
                               !! Fans Off                        \$\$ Boiler Off

=====  
 Hourly Emission Measurement Summary  
 Gulf Power Company  
 Crist Unit 6  
 Pensacola, Florida  
 =====

Today's Date: 04/03/96  
 Today's Time: 15:29:16

Report Date: 04/02/96  
 Report Hour: 11 - 12

Opacity Percent	01-06	1.5	31-36	1.5
	07-12	1.5	37-42	1.5
	13-18	1.5	43-48	1.5
	19-24	1.5	49-54	1.5
	25-30	1.5	55-60	1.5

Hourly Averages	S02	NOX	CO2
Measured	626.2 ppm	333.5 ppm	12.8 %
Bias Adjusted	638.1 ppm	333.5 ppm	12.8 %
Rate	1.4 lb/mmbtu	0.5 lb/mmbtu	
Bias Adjusted	1.4 lb/mmbtu	0.5 lb/mmbtu	
3 Hr Avg			
Mass Emissions	4383.3 lb/mmbtu		307.6 ton/hr
Bias Adjusted	4730.2 lb/hr		325.8 ton/hr
Bias Factor	1.019	1.000	1.000
Source	1	1	1
Heat Input	2998.6		
Load Range	9.4		
Zero Calibration	2.6 ppm	0.8 ppm	0.0 %
Expected Value	0.0 ppm	0.0 ppm	0.0 %
Span Calibration	2679.8 ppm	892.0 ppm	16.6 %
Expected Value	2632.9 ppm	896.6 ppm	17.0 %

Hourly Averages	Flow	Gross Generation	Opacity
Measured	42168000 scfh	318.2 MWge	
Bias Adjusted	44655912 scfh		
Bias Factor	1.059		
Source	1		
Zero Calibration	-1.4 scfh		0.0 %
Expected Value	0.0 scfh		0.0 %
Span Calibration	861.5 scfh		49.0 %
Expected Value	875.0 scfh		47.4 %

Instrument Status	Opacity Monitor	Normal
	S02 Analyzer	Normal
	NOX Analyzer	Normal
	CO2 Analyzer	Normal
	Flow Monitor	Normal

Legend                    \*\* Excess Emissions            ## Insufficient Data  
                              !! Fans Off                        \$\$ Boiler Off



=====  
 Hourly Emission Measurement Summary  
 Gulf Power Company  
 Crist Unit 6  
 Pensacola, Florida  
 =====

Today's Date: 04/03/96  
 Today's Time: 15:31:24

Report Date: 04/02/96  
 Report Hour: 12 - 13

Opacity Percent	01-06	1.5	31-36	1.5
	07-12	1.7	37-42	1.5
	13-18	1.8	43-48	1.8
	19-24	1.7	49-54	1.7
	25-30	1.6	55-60	1.8

Hourly Averages	S02	NOX	CO2
Measured	616.3 ppm	328.6 ppm	12.6 %
Bias Adjusted	628.0 ppm	328.6 ppm	12.6 %
Rate	1.4 lb/mmbtu	0.5 lb/mmbtu	
Bias Adjusted	1.4 lb/mmbtu	0.5 lb/mmbtu	
3 Hr Avg			
Mass Emissions	4339.2 lb/mmbtu		304.6 ton/hr
Bias Adjusted	4682.4 lb/hr		322.5 ton/hr
Bias Factor	1.019	1.000	1.000
Source	1	1	1
Heat Input	2968.9		
Load Range	9.4		
Zero Calibration	2.6 ppm	0.8 ppm	0.0 %
Expected Value	0.0 ppm	0.0 ppm	0.0 %
Span Calibration	2679.8 ppm	892.0 ppm	16.6 %
Expected Value	2632.9 ppm	896.6 ppm	17.0 %

Hourly Averages	Flow	Gross Generation	Opacity
Measured	42414000 scfh	317.2 MWge	
Bias Adjusted	44916426 scfh		
Bias Factor	1.059		
Source	1		
Zero Calibration	-1.4 scfh		0.0 %
Expected Value	0.0 scfh		0.0 %
Span Calibration	861.5 scfh		49.0 %
Expected Value	875.0 scfh		47.4 %

Instrument Status	Opacity Monitor	Normal
	S02 Analyzer	Normal
	NOX Analyzer	Normal
	CO2 Analyzer	Normal
	Flow Monitor	Normal

Legend	** Excess Emissions	## Insufficient Data
	!! Fans Off	\$\$ Boiler Off

=====  
 Hourly Emission Measurement Summary  
 Gulf Power Company  
 Crist Unit 6  
 Pensacola, Florida  
 =====

Today's Date: 04/03/96  
 Today's Time: 15:33:49

Report Date: 04/02/96  
 Report Hour: 13 - 14

Opacity Percent	01-06	1.6	31-36	1.9
	07-12	1.5	37-42	1.7
	13-18	1.7	43-48	1.7
	19-24	1.9	49-54	1.9
	25-30	1.9	55-60	2.0

Hourly Averages	S02	NOX	CO2
Measured	609.6 ppm	326.3 ppm	12.6 %
Bias Adjusted	621.2 ppm	326.3 ppm	12.6 %
Rate	1.4 lb/mmbtu	0.5 lb/mmbtu	
Bias Adjusted	1.4 lb/mmbtu	0.5 lb/mmbtu	
3 Hr Avg			
Mass Emissions	4270.2 lb/mmbtu		303.0 ton/hr
Bias Adjusted	4608.2 lb/hr		320.9 ton/hr
Bias Factor	1.019	1.000	1.000
Source	1	1	1
Heat Input	2953.8		
Load Range	9.4		
Zero Calibration	2.6 ppm	0.8 ppm	0.0 %
Expected Value	0.0 ppm	0.0 ppm	0.0 %
Span Calibration	2679.8 ppm	892.0 ppm	16.6 %
Expected Value	2632.9 ppm	896.6 ppm	17.0 %

Hourly Averages	Flow	Gross Generation	Opacity
Measured	42198000 scfh	317.5 MWge	
Bias Adjusted	44687682 scfh		
Bias Factor	1.059		
Source	1		
Zero Calibration	-1.4 scfh		0.0 %
Expected Value	0.0 scfh		0.0 %
Span Calibration	861.5 scfh		49.0 %
Expected Value	875.0 scfh		47.4 %

Instrument Status	Opacity Monitor	Normal
	S02 Analyzer	Normal
	NOX Analyzer	Normal
	CO2 Analyzer	Normal
	Flow Monitor	Normal

Legend	** Excess Emissions	## Insufficient Data
	!! Fans Off	\$\$ Boiler Off

=====  
 Hourly Emission Measurement Summary  
 Gulf Power Company  
 Crist Unit 6  
 Pensacola, Florida  
 =====

Today's Date: 04/03/96  
 Today's Time: 15:35:44

Report Date: 04/02/96  
 Report Hour: 14 - 15

Opacity Percent	01-06	2.0	31-36	2.0
	07-12	2.0	37-42	2.0
	13-18	1.9	43-48	2.0
	19-24	1.9	49-54	2.0
	25-30	1.9	55-60	2.0

Hourly Averages	S02	NOX	CO2
Measured	608.3 ppm	326.5 ppm	12.6 %
Bias Adjusted	619.9 ppm	326.5 ppm	12.6 %
Rate	1.4 lb/mmbtu	0.5 lb/mmbtu	
Bias Adjusted	1.4 lb/mmbtu	0.5 lb/mmbtu	
3 Hr Avg			
Mass Emissions	4254.4 lb/mmbtu		302.5 ton/hr
Bias Adjusted	4591.3 lb/hr		320.4 ton/hr
Bias Factor	1.019	1.000	1.000
Source	1	1	1
Heat Input	2949.2		
Load Range	9.4		
Zero Calibration	2.6 ppm	0.8 ppm	0.0 %
Expected Value	0.0 ppm	0.0 ppm	0.0 %
Span Calibration	2679.8 ppm	892.0 ppm	16.6 %
Expected Value	2632.9 ppm	896.6 ppm	17.0 %

Hourly Averages	Flow	Gross Generation	Opacity
Measured	42132000 scfh	317.6 MWge	
Bias Adjusted	44617788 scfh		
Bias Factor	1.059		
Source	1		
Zero Calibration	-1.4 scfh		0.0 %
Expected Value	0.0 scfh		0.0 %
Span Calibration	861.5 scfh		49.0 %
Expected Value	875.0 scfh		47.4 %

Instrument Status	Opacity Monitor	Normal
	S02 Analyzer	Normal
	NOX Analyzer	Normal
	CO2 Analyzer	Normal
	Flow Monitor	Normal

Legend                    \*\* Excess Emissions            ## Insufficient Data  
                              !! Fans Off                        \$\$ Boiler Off

# BEST AVAILABLE COPY

```

/                               SIGNAL SCALES
/ AC Amps___ 59.61 3 Utime_____ 2 IE-On_____ 1 BC Sts_____ * OFF AC Amps___ 400 /
/ AC Volts___ 232.25 3 Qlevel_____ 0 IE-Off_____ 0 BCMA_____ * 20 AC Volts___ 575 /
/ DCmA_____ 188.2 3 Sback_____ 7 x Bks_____ 0 BChnt_____ * 0 DCmA_____ 2000 /
/ UCRV_____ 47.53 3 Stime_____ 2 Maxchr_____ UN BChic_____ * 0 UCRV_____ 120 /
/ Sps/Rin_____ 52.99 3 Frasp_____ 6 BChic_____ * 1V ***** /
/ Dens On_____ 57.56 3 Sramp_____ 10 EMS BIP_____ UN BChch_____ * 10 BStatus_____ 2000 /
/ xrat: Pwr_____ 13.8 3 x SBK_____ 30 EMStim_____ 3 IBChin_____ * 150 BScans_____ 78 /
/                               3 x DTT_____ 25 FUNK_____ 0 IBLinc_____ * 10 BUN/DTT_____ UN /
/                               3 y Max_____ 150 Irpeav_____ UN BC Mode_____ IDLE BPF #_____ 1 /
/                               3 lmax_____ 183 Bmode_____ KVMA BRecip_____ UN11 /
/                               3 ilim_____ 183 KVSPF_____ * 20 BLimits_____ 999V /
/                               3 Bmax_____ 850 ***** /
/                               / KVmax_____ 70 mAspsk/a_____ 4 Unset_____ 25.4 /0 /0 /
/ Back screen..... 7 uvTAD_____ 50 KVspsk/a_____ 48 nKVhi_____ 67.3 /0 PARAMETERS /0 /
/ Last screen..... 7 uvTDC_____ 12 nRce_____ 7 nKVlo_____ 53.2 /0 AVC # IKA-140 /
/ Help..... 7 uvDLY_____ 30 Manual_____ OFF nKVhi_____ 40 /0 Version 8570 /
/ Main Menu..... 7 Bcn Errs_0002 nKVlo_____ 40 ***** /
/ *****14:10:01 09/02/76***** /

```

Messages:

F1-RUN F2-HLP F3-EMS F4-AVC F5-ALM F6-AUX F7-RAP F8-VI F9-NEXT F10-LAST

END  
OF  
2<sup>ND</sup>  
RUN

Sootblc

Cr 6.96r3

BEST AVAILABLE COPY

PRECIPITATOR

⊗ 1ST RUN

INITIAL PRINT SCREEN

Sootblow

UNIT	TYPE	STATUS	TIME	TEMP	PRESS	FLOW	ALARM
01	01	OK	00:00	100	1.0	100	0
02	02	OK	00:00	100	1.0	100	0
03	03	OK	00:00	100	1.0	100	0
04	04	OK	00:00	100	1.0	100	0
05	05	OK	00:00	100	1.0	100	0
06	06	OK	00:00	100	1.0	100	0
07	07	OK	00:00	100	1.0	100	0
08	08	OK	00:00	100	1.0	100	0
09	09	OK	00:00	100	1.0	100	0
10	10	OK	00:00	100	1.0	100	0
11	11	OK	00:00	100	1.0	100	0
12	12	OK	00:00	100	1.0	100	0
13	13	OK	00:00	100	1.0	100	0
14	14	OK	00:00	100	1.0	100	0
15	15	OK	00:00	100	1.0	100	0
16	16	OK	00:00	100	1.0	100	0
17	17	OK	00:00	100	1.0	100	0
18	18	OK	00:00	100	1.0	100	0
19	19	OK	00:00	100	1.0	100	0
20	20	OK	00:00	100	1.0	100	0
21	21	OK	00:00	100	1.0	100	0
22	22	OK	00:00	100	1.0	100	0
23	23	OK	00:00	100	1.0	100	0
24	24	OK	00:00	100	1.0	100	0
25	25	OK	00:00	100	1.0	100	0
26	26	OK	00:00	100	1.0	100	0
27	27	OK	00:00	100	1.0	100	0
28	28	OK	00:00	100	1.0	100	0
29	29	OK	00:00	100	1.0	100	0
30	30	OK	00:00	100	1.0	100	0
31	31	OK	00:00	100	1.0	100	0
32	32	OK	00:00	100	1.0	100	0
33	33	OK	00:00	100	1.0	100	0
34	34	OK	00:00	100	1.0	100	0
35	35	OK	00:00	100	1.0	100	0
36	36	OK	00:00	100	1.0	100	0
37	37	OK	00:00	100	1.0	100	0
38	38	OK	00:00	100	1.0	100	0
39	39	OK	00:00	100	1.0	100	0
40	40	OK	00:00	100	1.0	100	0
41	41	OK	00:00	100	1.0	100	0
42	42	OK	00:00	100	1.0	100	0
43	43	OK	00:00	100	1.0	100	0
44	44	OK	00:00	100	1.0	100	0
45	45	OK	00:00	100	1.0	100	0
46	46	OK	00:00	100	1.0	100	0
47	47	OK	00:00	100	1.0	100	0
48	48	OK	00:00	100	1.0	100	0
49	49	OK	00:00	100	1.0	100	0
50	50	OK	00:00	100	1.0	100	0
51	51	OK	00:00	100	1.0	100	0
52	52	OK	00:00	100	1.0	100	0
53	53	OK	00:00	100	1.0	100	0
54	54	OK	00:00	100	1.0	100	0
55	55	OK	00:00	100	1.0	100	0
56	56	OK	00:00	100	1.0	100	0
57	57	OK	00:00	100	1.0	100	0
58	58	OK	00:00	100	1.0	100	0
59	59	OK	00:00	100	1.0	100	0
60	60	OK	00:00	100	1.0	100	0
61	61	OK	00:00	100	1.0	100	0
62	62	OK	00:00	100	1.0	100	0
63	63	OK	00:00	100	1.0	100	0
64	64	OK	00:00	100	1.0	100	0
65	65	OK	00:00	100	1.0	100	0
66	66	OK	00:00	100	1.0	100	0
67	67	OK	00:00	100	1.0	100	0
68	68	OK	00:00	100	1.0	100	0
69	69	OK	00:00	100	1.0	100	0
70	70	OK	00:00	100	1.0	100	0
71	71	OK	00:00	100	1.0	100	0
72	72	OK	00:00	100	1.0	100	0
73	73	OK	00:00	100	1.0	100	0
74	74	OK	00:00	100	1.0	100	0
75	75	OK	00:00	100	1.0	100	0
76	76	OK	00:00	100	1.0	100	0
77	77	OK	00:00	100	1.0	100	0
78	78	OK	00:00	100	1.0	100	0
79	79	OK	00:00	100	1.0	100	0
80	80	OK	00:00	100	1.0	100	0
81	81	OK	00:00	100	1.0	100	0
82	82	OK	00:00	100	1.0	100	0
83	83	OK	00:00	100	1.0	100	0
84	84	OK	00:00	100	1.0	100	0
85	85	OK	00:00	100	1.0	100	0
86	86	OK	00:00	100	1.0	100	0
87	87	OK	00:00	100	1.0	100	0
88	88	OK	00:00	100	1.0	100	0
89	89	OK	00:00	100	1.0	100	0
90	90	OK	00:00	100	1.0	100	0
91	91	OK	00:00	100	1.0	100	0
92	92	OK	00:00	100	1.0	100	0
93	93	OK	00:00	100	1.0	100	0
94	94	OK	00:00	100	1.0	100	0
95	95	OK	00:00	100	1.0	100	0
96	96	OK	00:00	100	1.0	100	0
97	97	OK	00:00	100	1.0	100	0
98	98	OK	00:00	100	1.0	100	0
99	99	OK	00:00	100	1.0	100	0
100	100	OK	00:00	100	1.0	100	0

NO.	NAME	UNIT	MODE	TIME	STATUS
100	...	...	...	...	...
101	...	...	...	...	...
102	...	...	...	...	...
103	...	...	...	...	...
104	...	...	...	...	...
105	...	...	...	...	...
106	...	...	...	...	...
107	...	...	...	...	...
108	...	...	...	...	...
109	...	...	...	...	...
110	...	...	...	...	...
111	...	...	...	...	...
112	...	...	...	...	...
113	...	...	...	...	...
114	...	...	...	...	...
115	...	...	...	...	...
116	...	...	...	...	...
117	...	...	...	...	...
118	...	...	...	...	...
119	...	...	...	...	...
120	...	...	...	...	...

BEST AVAILABLE COPY

FINAL PRINT SCREEN  
1560tblow

Best Available Copy

0	02	2000	UN	*				
IRA-3A	76.86	193.92	305.9	40.47	0	62.11	75	1
0	00	2000	UN	*				
IRA-3B	76.86	196.18	298.0	40.00	0	64.54	75	1
0	02	2000	UN	*				
IRA-3A	76.86	196.18	298.0	39.53	0	63.20	75	1
0	02	2000	UN	*				
IRB-3B	76.86	193.92	313.7	39.06	0	62.89	75	1
0	02	2000	UN	*				
IRA-4A	72.16	175.88	305.9	39.53	0	61.88	75	1
0	00	2000	UN	*				
IRA-4B	75.29	187.16	274.5	37.65	0	61.47	75	1
0	02	2000	UN	*				
IRB-4A	75.29	193.92	305.9	37.65	0	60.58	75	1
0	02	2000	UN	*				
IRB-4B	75.29	184.90	274.5	37.65	0	59.71	75	1
0	02	2000	UN	*				
IRA-5A	225.88	383.33	1168.6	64.00	0	107.39	225	1
0	03	2000	UN	*				
IRA-5B	225.88	381.08	1152.9	60.71	0	110.65	225	1
0	03	2000	UN	*				
IRB-5A	225.88	408.14	1184.3	60.24	0	110.67	225	1
0	03	2000	UN	*				
IRB-5B	227.45	405.88	1152.9	60.24	0	103.61	225	1
0	03	2000	UN	*				

\*

\*

"A" RAPPERS

\*

AUXILIARY SYSTEMS STATUS

\*

\*

DPA-1 OFF DPA-2 OFF DSA-1 ON DSA-2 OFF  
 OFF DSA-3 OFF \* DSA-4 OFF DSA-5 OFF USA-1 OFF USA-2 OFF  
 OFF

START  
 ZWD  
 RUN  
 Sootblow

```

Amps 105.10 3 Qtime ~ 2 IE-Un ~ 1 BC Sts ~ OFF AC Amps 400 L
Volts 317.94 3 Qlevel ~ 0 IE-Off ~ 0 BCMA ~ 20 AC Volts 575 L
mA 313.7 3 Sback ~ 7 x Bkg ~ 0 BCHnt ~ 0 DCMA 2000 L
kV 64.00 3 Stime ~ 2 Maxchk ~ UN BCHid ~ 0 DCKV 120 L
CS/Min 43.00 3 Framp ~ 6 BCAlq ~ IV Z0000000000000004L
IS Un 90.08 3 Sramp ~ 10 EMS BLK ~ UN BCWch ~ 10 SStatus 2000 L
Att Pwr 33.4 3 x Sbk ~ 30 EMStim ~ 3 IBCmin ~ 150 S# Scans 24 L
3 x Dft ~ 25 PURZ ~ 0 IBCinc ~ 10 SOn/Off UN L
3 x Max ~ 150 IPreav ~ UN BC Mode IDLE SFEP # 1 L
3 lmax ~ 183 Smode kWMA Sprecip UN11 L
3 llim ~ 183 KVSFK ~ 20 Slimits 0000 L
IE 183 3 mamax ~ 850
7 KVmax ~ 70 mASPKS/m 25 Unset 25.4 L 0L
7 uvtAC ~ 50 KVSps/m 20 nkVhi 79.1 L 0 PARAMEIERS 0L
7 uvtDL ~ 12 ARCS ~ 7 nkVlo 59.8 L 0 AVU # IRA-1A0L
7 uvtDiy ~ 30 Manual OFF nkVhi 10 L 0 Version 55 0L
7 Scn Errs 0002 frVlo 10 L 000000000000000L
12:43:15 04/02/96

```

BEST AVAILABLE COPY

```

    [ Amps 59.61 3 Qtime ~ 2 IE-On ~ 1 BC Sts ~ OFF AC Amps 400 [
    [ Volts 232.25 3 Qlevel ~ 0 IE-Off ~ 0 BCmA ~ 20 AC Volts 575 [
    [ DCmA 188.2 3 Sback ~ 7 x Bkq ~ 0 BCHnt ~ 0 DCmA 2000 [
    [ DCKV 47.53 3 Stime ~ 2 Maxchk ~ ON BCHid ~ 0 DCKV 120 [
    [ Spks/Min 52.00 3 Framp ~ 6 BCAlg ~ IV ZDDDDDDDDDDDDDD9 [
    [ Dens On 57.56 3 Sramp ~ 10 EMS Blk ~ ON BCCh ~ 10 JStatus 2000 [
    [ kWatt Pwr 13.8 3 x Sbk ~ 30 EMstim ~ 3 IBCmin ~ 150 J# Scans 98 [
    [ 3 x Dft ~ 25 POR2 ~ 0 IBCinc ~ 10 JOn/Off ~ ON [
    [ 3 x Max ~ 150 Irsav ~ ON BC Mode IDLE JFEP # 1 [
    [ 3 Jprecip UN111 [
    [ 3 lmax ~ 183 Smode KVMA Jlimits 0000 [
    [ GC Setpt. 183 3 ilim ~ 183 KVSPR ~ 20 JXXXXXXXXXXXX [
    [ Iems 75 3 mAmx ~ 850 J000000000000000 [
    [ 3 kvmax ~ 70 mAepks/m 4 Unset 25.4 J0 01 [
    [ Next Screen..... 2 uvTAC ~ 50 kVepks/m 48 nkVhi 67.3 J0 PARAMETERS 01 [
    [ Last Screen..... 7 uvTDC ~ 12 Arce ~ 7 nkVlo 53.2 J0 AVC # 1KA-1A01 [
    [ Help..... 7 uvDly ~ 30 Manual OFF okVhi 1.0 J0 Version 55 01 [
    [ Main Menu..... 7 Scn Erre_0002 tkVlo 1.0 J000000000000000 [
    JXXXXXXXXXXXX14:10:01 04/02/96XXXXXXXXXXXXXXXXXXXXXXXXXXXX
  
```

Messages:

F1-MNU F2-HLP F3-EMS F4-AVC F5-ALM F6-AUX F7-RAP F8-VI F9-NEXT F10-LAST

END  
OF  
2ND  
RUN

Sootblow



BEST AVAILABLE COPY

3RD  
RUN  
START!  
Sootblow

```

                                     SIGNAL SCALES /
/ AC Ampe   117.65  S utime    ~  2 IE-Un   ~  1 BC Ste  ~ OFF AC Ampe   400 /
/ AC Volts  329.71  S vlevel  ~  0 IE-Off  ~  0 BCma    ~  20 AC Volts  575 /
/ DLma     360.8   S Sback   ~  7 x Wkd   ~  0 BCHnt   ~  0 DCma    ~ 2000 /
/ DCkV     65.41  S Stime   ~  2 Maxchk  ~  UN BCHld   ~  0 DCkV    ~ 120 /
/ Spks/Min  46.00  S Framp   ~  6          ~  BCHld   ~  1V /0000000000000000/
/ Deqs On   73.88  S Sramp   ~ 10 EMS BIK  ~  UN BCrch  ~ 10 SStatus  2000 /
/ kWatt Pwr  38.2  S x Sbk    ~ 30 EMstim  ~  3 lBCmin  ~ 150 S# Scans  27 /
/           3 v Off  ~ 25 PURZ    ~  0 lBCinc  ~ 10 SOn/Off  ~ UN /
/           3 x Max  ~ 150 lpsav   ~  UN BC Mode  IDLE SFEP #    1 /
/           3          ~  Smode   ~  KVMA  Sprecip  UNIT1 /
/           3 lmax   ~ 183 Smode   ~  KVMA  Slimits  0000 /
/ BC Setpt.  183  S liim    ~ 183 KVSPK  ~  20  /0000000000000000/
/ lpsav     183  S mamax  ~ 850          ~  /0000000000000000/
/           3 kvmax   ~  70 mAsps/m  23 Unset   25.4 /0
/ Next Screen.....% uvTAC   ~  50 kVspks/m  23 nkVhi   80.0 /0 PARAMETERS /0
/ Last Screen.....% uvTDC   ~  12 Arcs     ~  9 nkVlo   58.8 /0 AVC # TRA-1A0/
/ Help.....% uvDly    ~  30 Manual  ~ OFF okVhi   10 /0 Version  55 /0
/ Main Menu.....%          ~  Scn Errs 0002 tkVlo   10 /0000000000000000/
/0000000000000000/04:29:17 04/02/96 /0000000000000000/
Messages: ALARMS PENDING IN SYSTEM !!!

```

F1-MNU F2-HLP F3-EMS F4-AVC F5-ALM F6-AUX F7-RAF F8-V1 F9-NEXT F10-LAS1  
 4:36:18 04/02/96 HIGH HOPPER LEVEL ON # LV-B13 \*\*\* ALARM RESET \*\*\*  
 14:48:47 04/02/96 HIGH HOPPER LEVEL ON # LV-A12 \*\*\* ALARM RESET \*\*\*

*	IRA 4A	225.88	378.82	1129.4	63.06	0	112.23	225	1	0
0	2000		ON *							
*	IRA-4B	227.45	396.86	1168.6	59.29	1	111.93	225	1	0
2	2000		ON *							
*	IRB-4A	225.88	423.92	1152.9	60.71	0	113.31	225	1	0
	2000		ON *							
*	IRB-4B	225.88	396.86	1051.0	60.71	0	105.98	225	1	0
2	2000		ON *							
*	IRA-5A	225.88	387.84	1152.9	62.12	0	109.47	225	1	0
3	2000		ON *							
*	IRA-5B	225.88	383.33	1160.8	61.18	0	113.48	225	1	0
3	2000		ON *							
*	IRB-5A	229.02	401.37	1176.5	59.29	0	111.72	225	1	0
3	2000		ON *							
*	IRB-5B	230.59	403.63	1168.6	60.24	0	106.35	225	1	0
3	2000		ON *							

-----\*

\* \* \* \* \*

"A" RAPPERS

AUXILIARY SYSTEMS STATUS

\* \* \* \* \*

\* DPA-1            OFF            DPA-2            OFF

```

/                               SIGNAL SCALES /
/ AC Amps  119.22  3 Qtime  ~  2 IE-On  ~  1 RC Sts  ~ OFF AC Amps  400 /
/ AC Volts  333.73  3 Qlevel  ~  0 IE-Off  ~  0 BCMA  ~  20 AC Volts  575 /
/ DCMA  ~  376.5  3 Sback  ~  7 x Bkg  ~  0 BCHnt  ~  0 DCMA  2000 /
/ DCKV  ~  66.35  3 Stime  ~  2 Maxchk  ~ UN BCHld  ~  0 DCKV  120 /
/ Spks/Min  48.00  3 Framp  ~  6 BCAlq  ~  IV ZDDDDDDDDDDDDDD4/
/ Dens On  94.31  3 Sramp  ~  10 EMS Bk  ~ UN BCCh  ~  10 SStatus  2000 /
/ Kwatt Pwr  39.8  3 x Sbk  ~  30 EMStim  ~  3 IRCmin  ~ 150 S# Scans  90 /
/           ~  3 x Dft  ~  25 PUKZ  ~  0 IRCinc  ~  10 SOn/Off  ~ UN /
/           ~  3 x Max  ~ 150 Irpsav  ~ UN EC Mode  IDLE SFEF #  1 /
/           ~  3                               SPrcep  UN111 /
/           ~  3 lmax  ~ 183 Smode  ~ KVMA Slimits  0000 /
/ RC Setpt.  183  3 Ilim  ~ 183 KVSPK  ~  20 ~~~~~~ /
/ Iems  ~  75  3 mAmx  ~  850 L0000000000000000 /
/           ~  7 KVmax  ~  70 mAsps/m  26 Unset  25.4 L0  0L /
/ Next Screen..... 7 uvTAD  ~  50 KVspks/m  22 nkVhi  31.4 L0 PARAMETERS 0L /
/ Last Screen..... 7 uvTDC  ~  12 Arce  ~  9 nkVlo  60.2 L0 AVC # IRA-1A0L /
/ Help..... 7 uvDiy  ~  30 Manual  ~ OFF okVhi  .0 L0 Version  55 0L /
/ Main Menu..... 7          Scn Errs 0002 tkVlo  .0 L0000000000000000L /
~~~~~15:29:13 04/02/98~~~~~

```

Messages: ALARMS PENDING IN SYSTEM !!!

F1-RUN F2-HLP F3-EMS F4-AVC F5-ALM F6-AUX F7-RAP F8-VI F9-NEXT F10-LAST

3RD  
RUN  
STOP

Sootblow

SANDERS ENGINEERING & ANALYTICAL SERVICES, INC.

**PARTICULATE EMISSIONS TEST REPORT  
STEADY STATE OPERATIONS**

*FOR*

**GULF POWER COMPANY**  
*Plant Crist, Unit 7  
Pensacola, Florida*



*December 7, 1994*

1568 LEROY STEVENS ROAD

MOBILE, ALABAMA 36695 • 205/633-4120



SANDERS ENGINEERING & ANALYTICAL SERVICES, INC.

1568 LEROY STEVENS ROAD MOBILE ALABAMA 36695 • 205 / 833-4120

ENVIRONMENTAL ENGINEERING  
AIR & WATER QUALITY MODELING  
ENVIRONMENTAL ASSESSMENTS  
PSD ANALYSIS  
EMERGENCY RESPONSE MONITORING

AMBIENT AIR MONITORING  
CONTINUOUS IN-STACK MONITORING  
SOURCE TESTING  
VISIBLE EMISSIONS TESTING  
CONSULTING SERVICES

TEST REPORT CERTIFICATION

In regard to this test, we certify that, to the best of our knowledge, all of the data regarding the testing performed by our agents is true and correct.

Sanders Engineering & Analytical  
Services, Inc.

Dated: 12-19-94

By: Joseph C. Sanders

## TABLE OF CONTENTS

1. INTRODUCTION .....	1
2. SUMMARY AND DISCUSSION OF RESULTS .....	2
3. PROCESS DESCRIPTION .....	4
3.1. Source Air Flow .....	5
3.2. Operation During Testing .....	6
4. SAMPLE POINT LOCATIONS .....	7
5. PARTICULATE SAMPLING PROCEDURE (EPA Method 17) .....	8
5.1. Particulate Sample Recovery .....	9
5.2. Particulate Analytical Procedures .....	10
A P P E N D I X A PARTICULATE FIELD DATA SHEETS .....	11
A P P E N D I X B EQUATIONS AND SAMPLE CALCULATIONS .....	12
A P P E N D I X C QUALITY CONTROL .....	13
A P P E N D I X D OPERATIONAL DATA .....	14

**LIST OF TABLES**

TABLE I. RESULTS AND COMPUTATIONS OF PARTICULATE TESTING . . . . 3

## ILLUSTRATIONS

FIGURE 1.	AIR FLOW SCHEMATIC .....	5
FIGURE 2.	SAMPLE POINT LOCATIONS .....	7
FIGURE 3.	PARTICULATE SAMPLING TRAIN (EPA Method 17) .....	8

## 1. INTRODUCTION

Sanders Engineering & Analytical Services, Inc. (SEAS), performed a particulate emissions test at Gulf Power Company, Plant Crist, Unit 7, located in Pensacola, Florida. The test was conducted on December 7, 1994, during steady state operations. The testing was performed in accordance with the applicable U.S. EPA procedures specified at **40 CFR, Part 60, Appendix A, Methods 1, 2, 3, 4 and 17.**

The purpose of the test was to demonstrate compliance with the rules and regulations of the Florida Department of Environmental Protection, and to meet certain requirements contained in the permit to operate issued by the Florida Department of Environmental Protection.

The test was conducted by Mr. Jack Covington, Mr. Dean Holmes, and Mr. John Wilson of Sanders Engineering & Analytical Services, Inc., and was coordinated with Ms. Kristie Drury of Gulf Power Company. The Florida Department of Environmental Protection was notified so that a representative could be present to observe the testing.

The test was conducted in accordance with the rules and regulations of the Florida Department of Environmental Protection. Further discussion of the test methods are included later in the report.



## **2. SUMMARY AND DISCUSSION OF RESULTS**

The results of the particulate emissions test for the steady state runs, along with the results of the computations are summarized in Table I. The completed field data sheets for the particulate testing are presented in Appendix A. The equations used in the calculations of the results, along with the sample calculations of the first run, are presented in Appendix B. The quality control checks of the equipment used in the sampling program are included in Appendix C. The operational data taken during the performance of the test is included in Appendix D.

The results of the testing indicate the particulate emission rate during steady state operations for Plant Crist, Unit 7, is 0.037 LBS/MMBTU. The applicable Florida Department of Environmental Protection rules and regulations require an emission rate of no greater than 0.10 LBS/MMBTU. The results of the testing indicate that the unit is in compliance with the particulate emission condition of the permit to operate issued by the Florida Department of Environmental Protection.

**TABLE I  
PARTICULATE EMISSIONS TESTING  
GULF POWER COMPANY  
PLANT CRIST, UNIT 7, STEADY STATE  
12-07-94**

Title of Run		Run 1	Run 2	Run 3
F Factor	SDCF/MMBTU	9820.00	9820.00	9820.00
Static Pressure	IN. H2O	1.30	1.30	1.30
Barometric Pressure	In. Hg.	30.30	30.30	30.30
Average ΔH	In. H2O	1.066	1.091	1.192
Meter Correction		0.990	0.990	0.990
Avg Meter Temp.	DEG F	77.9	81.6	81.4
% O2	%	4.8	4.9	4.8
% CO2	%	14.0	13.5	13.5
Volume Metered	ACF	32.050	32.740	33.825
Volume Water	ML	76.4	62.5	63.6
Sampling Time	MINUTES	60	60	60
Nozzle Diameter	INCHES	0.184	0.184	0.189
Avg. Stack Temp.	DEG F	321.0	327.8	327.5
Area Of Stack	SQ. FEET	375.000	375.000	375.000
Wt. Of Part.	MG	54.7	33.2	38.1
Number Of Points		30	30	30
Avg. Sqrt. ΔP	In. H2O	1.129	1.142	1.132

**RESULTS OF COMPUTATIONS**


		RUN 1	RUN 2	RUN 3	AVERAGE
Sample Time	Military	0939-1043	1118-1222	1238-1342	
Volume of Gas Sampled	SDCF	31.610	32.074	33.157	32.280
Molecular Wt. Of St. Gas	LB/LB-MOLE	29.16	29.32	29.33	29.27
H2O Vapor in Gas Stream	PERCENT	10.2	8.4	8.3	9.0
Avg Stack Gas Velocity	FT/SEC	76.1	77.1	76.4	76.5
Volumetric Flow Rate	SDCFM	1055700	1082400	1073500	1070533
Volumetric Flow Rate	ACFM	1712000	1735400	1718400	1721933
Particulate Conc.	GRS/SDCF	0.027	0.016	0.018	0.020
Particulate Conc.	GRS/ACF	0.016	0.010	0.011	0.012
Particulate Mass Rate	LB/HR	241.1	147.9	162.8	183.9
Emission Rate	LBS/MMBTU	0.049	0.029	0.032	0.037
Heat Input	MMBTU/HR	4968.69	5062.81	5052.48	5027.99
Percent of Isokinetic		101.39	100.34	99.13	

### **3. PROCESS DESCRIPTION**

The process consists of a steam electric generating unit firing bituminous coal for the production of electric energy. The coal is received by barge, and loaded directly onto the conveyor feeding the plant, or onto the stockpile and later loaded onto the conveyor belt transporting the coal to the plant. The coal from the conveyor is loaded into bunkers capable of holding between 36 to 48 hours supply of coal. The coal is then fed to pulverizing mills before being fired in the unit through the burners. Upon combustion of the coal in the fire box, approximately 20 percent of the ash falls to the bottom of the boiler and is removed by the ash removal system. The remaining 80 percent exits with the flue gases through the heat exchange and economizer sections of the furnace, and is collected by electrostatic precipitators.

### 3.1. Source Air Flow

As shown in Figure 1, the flue gases exit the boiler and are separated into ducts A and B before entering air preheaters. They are then routed to a cold side ESP. The flue gases exiting the cold side ESP are exhausted through a stack into the atmosphere.



### **3.2. Operation During Testing**

The approximate heat input average during steady state operation, as based on F-factor calculations, was 5027.99 million BTU per hour resulting in the production of approximately 495 megawatts of electricity. Precipitator data supplied by Gulf Power personnel is given in Appendix D.

### 4. SAMPLE POINT LOCATIONS

The sample point locations and outlet duct schematic are presented in Figure 2. Method 1 was used for determination of the number and location of sampling points.

The minimum number of points (25) required for 180° rectangular stacks was met by sampling a total of 30 points.






Figure 2. Sample Point Locations

## 5. PARTICULATE SAMPLING PROCEDURE (EPA Method 17)

The sampling procedure utilized is that specified in 40 CFR, Part 60, Appendix A, Method 17, as modified by the governing regulatory agency. A brief description of this procedure is as follows:

The first impingers were partially filled with 100 milliliters of deionized water. The next impinger was left empty to act as a moisture trap. Preweighed 6 to 16 mesh indication silica gel was added to the last impinger. The sampling equipment manufactured by Lear



**Figure 3. Particulate Sampling Train (EPA Method 17)**

Siegler (Model 100) or Sanders Engineering (Model 200) was assembled as shown in the attached drawing. The system was leak checked by plugging the inlet to the nozzle and pulling a 15 inch mercury vacuum. A leakage rate not in excess of 0.02 cubic feet per minute was considered acceptable.

The inside dimensions of the stack liner were measured and recorded. The required number of sampling points were marked on the probe for easy visibility. The range of velocity pressure, the percent moisture, and the temperature of the effluent gases were determined. From this data, the correct nozzle size and the nomograph multiplication factor were determined.

Crushed ice was placed around the impingers. The nozzle was placed on the first traverse point with the tip pointing directly into the gas stream. The pump was started immediately and the flow was adjusted to isokinetic sampling conditions. After the required time interval had elapsed, the probe was repositioned to the next traverse point and isokinetic sampling was re-established. This was performed for each point until the run was completed. Readings were taken at each point and recorded on the field data sheet. At the conclusion of each run, the pump was turned off and the final readings were recorded.

### **5.1. Particulate Sample Recovery**

Care was exercised in moving the collection train to the sample recovery area to minimize the loss of collected sample, or the gain of extraneous particulate matter. The volume of water in the impingers was measured, the silica gel impinger was weighed and recorded on the field data sheet. The nozzle, and all sample-exposed surfaces were washed with reagent grade acetone into a clean sample container. A brush was used to loosen any adhering particulate matter and



subsequent washings were placed into the container. The filter was carefully removed from the fritted support and placed in a clean separate sample container. A sample of the acetone used in the washing was saved for a blank laboratory analysis.

## **5.2. Particulate Analytical Procedures**

The filter and any loose particulate matter were transferred from the sample container to a clean, tared weighing dish. The filter was placed in a desiccator for at least 24 hours and then weighed to the nearest 0.1 milligram until a constant weight was obtained. The original weight of the filter was deducted, and the weight gain was recorded to the nearest 0.1 milligram.

The wash solution was transferred to a clean, tared beaker. The solution was evaporated to dryness, desiccated to a constant weight, and the weight gain was recorded to the nearest 0.1 milligram.

**A P P E N D I X A PARTICULATE FIELD DATA SHEETS**



SANDERS ENGINEERING & ANALYTICAL SERVICES, Inc.

1568 Laroy Stevens Rd.  
Mobile, AL 36695

Office: (205) 633-4120  
FAX#: (205) 633-2285

FIELD DATA SHEET

COMPANY 616 River Co DATE 12-7-94 DGM# 5-100  
 PLANT Crist 07 OPERATOR JC ΔHa 75  
 UNIT 7 METHOD 17 PROBE NA CL. L. MIN. 22'  
 RUN 1 Steady State RUN 2 RUN 3  
 liner length

NOZZLE CALIBRATION

PRE	POST	FILTER NUMBER
<u>183</u>	<u>183</u>	
<u>184</u>	<u>184</u>	
<u>184</u>	<u>184</u>	
<u>184</u>	<u>184</u>	
<u>184</u>	<u>184</u>	
AVERAGE	AVERAGE	

NOZZLE CALIBRATION

PRE	POST	FILTER NUMBER
<u>183</u>	<u>183</u>	
<u>185</u>	<u>184</u>	
<u>184</u>	<u>184</u>	
<u>184</u>	<u>184</u>	
<u>184</u>	<u>184</u>	
AVERAGE	AVERAGE	

NOZZLE CALIBRATION

PRE	POST	FILTER NUMBER
<u>189</u>	<u>189</u>	
<u>189</u>	<u>189</u>	
<u>189</u>	<u>190</u>	
<u>189</u>	<u>189</u>	
<u>189</u>	<u>189</u>	
AVERAGE	AVERAGE	

METER READING

<u>110.450</u>	FINAL
<u>78.400</u>	INITIAL
<u>32.050</u>	NET

METER READING

<u>44.140</u>	FINAL
<u>11.400</u>	INITIAL
<u>32.740</u>	NET

METER READING

<u>78.825</u>	FINAL
<u>45.000</u>	INITIAL
<u>33.825</u>	NET

LEAK CHECK

SYSTEM		PITOT	
Pre	Post	Pre	Post
<input checked="" type="checkbox"/>	<u>18</u>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
<input checked="" type="checkbox"/>	<u>.010</u>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
cim	cim		

LEAK CHECK

SYSTEM		PITOT	
Pre	Post	Pre	Post
<input checked="" type="checkbox"/>	<u>15</u>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
<input checked="" type="checkbox"/>	<u>.010</u>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
cim	cim		

LEAK CHECK

SYSTEM		PITOT	
Pre	Post	Pre	Post
<input checked="" type="checkbox"/>	<u>15</u>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
<input checked="" type="checkbox"/>	<u>.008</u>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
cim	cim		

VOLUME OF LIQUID WATER COLLECTED

IMP. 1	IMP. 2	IMP. 3	IMP. 4
<u>166</u>	<u>100</u>	<u>0</u>	<u>1586.4</u>
<u>100</u>	<u>100</u>	<u>0</u>	<u>1576.0</u>
<u>66</u>	<u>0</u>	<u>0</u>	<u>10.4</u>
NET	NET	NET	NET
TOTAL			<u>76.4</u>

VOLUME OF LIQUID WATER COLLECTED

IMP. 1	IMP. 2	IMP. 3	IMP. 4
<u>153</u>	<u>100</u>	<u>0</u>	<u>1444.5</u>
<u>100</u>	<u>100</u>	<u>0</u>	<u>1435.0</u>
<u>53</u>	<u>0</u>	<u>0</u>	<u>9.5</u>
NET	NET	NET	NET
TOTAL			<u>62.5</u>

VOLUME OF LIQUID WATER COLLECTED

IMP. 1	IMP. 2	IMP. 3	IMP. 4
<u>156</u>	<u>100</u>	<u>0</u>	<u>1594.0</u>
<u>100</u>	<u>100</u>	<u>0</u>	<u>158.4</u>
<u>56</u>	<u>0</u>	<u>0</u>	<u>7.6</u>
NET	NET	NET	NET
TOTAL			<u>63.6</u>

GAS ANALYSIS

O <sub>2</sub> <u>4.8</u>	STATIC <u>4.3</u>
CO <sub>2</sub> <u>14.0</u>	BAROMETRIC <u>30.30</u>
CO	

GAS ANALYSIS

O <sub>2</sub> <u>4.9</u>	STATIC <u>4.3</u>
CO <sub>2</sub> <u>13.5</u>	BAROMETRIC <u>30.30</u>
CO	

GAS ANALYSIS

O <sub>2</sub> <u>4.8</u>	STATIC <u>4.3</u>
CO <sub>2</sub> <u>13.5</u>	BAROMETRIC <u>30.30</u>
CO	

PORT #	POINT #	TIME	GAS METER VOL. (cu. ft.)	VEL. HEAD ΔP in. H <sub>2</sub> O	ORIFICE HEAD ΔH in. H <sub>2</sub> O	TEMPERATURE °F				VAC. in. H <sub>g</sub>		
						STACK	PROBE	HOT BOX	IMP.		GAS METER	
										IN	OUT	
1-6	6	9:39	78.400	1.42	1.42	300			66	71	70	7
	5	9:41	79.500	1.52	1.19	310			✓	71	70	8
	4	9:43	80.800	1.52	1.19	310			✓	71	70	6
	3	9:45	81.900	3.70	2.43	311			✓	72	70	6
	2	9:47	83.200	2.22	1.74	324			✓	73	70	8
	1	9:49	84.700	3.30	2.59	350			✓	73	70	8 11
2-6	6	9:52	86.500	1.30	1.08	302			✓	74	71	7
	5	9:54	87.700	1.25	.98	310			✓	74	71	7
	4	9:56	88.800	1.12	.88	319			✓	76	71	6
	3	9:58	90.500	2.15	1.68	318			✓	76	71	9
	2	10:00	91.100	1.99	1.56	324			✓	76	72	9
	1	10:02	92.500	2.10	1.65	345			✓	76	72	9
3-6	6	10:05	93.800	.67	.53	300			54	76	72	6
	5	10:07	94.800	.96	.75	312			✓	77	73	6
	4	10:09	95.500	.93	.73	320			✓	77	73	6
	3	10:11	96.500	1.00	.79	319			✓	77	73	7
	2	10:13	97.500	1.35	1.06	336			✓	78	73	8
	1	10:15	98.500	1.90	1.49	349			✓	78	73	8
4-6	6	10:18	99.735	1.00	.84	304			56	78	73	8
	5	10:20	100.200	1.10	.92	310			✓	78	73	8
	4	10:22	101.200	.95	.74	321			✓	79	75	8
	3	10:24	102.700	1.08	.84	317			✓	79	75	8
	2	10:26	103.800	.70	.80	339			✓	79	75	8
	1	10:28	104.500	.68	.53	350			✓	80	75	7

CHECK INDICATES TEMPERATURES MEET REQUIRED LIMITS.

COMPANY G.H. Pao. Co DATE 12-7-94  
 SITE C-3 RUN # 1 PAGE 55 OF

PORT #	POINT #	TIME	GAS METER VOL. (cu. ft.)	VEL. HEAD ΔP in. H <sub>2</sub> O	ORIFICE HEAD ΔH in. H <sub>2</sub> O	TEMPERATURE °F				VAC. in. H <sub>g</sub>		
						STACK	PROBE	HOT BOX	IMP.		GAS METER	
										IN	OUT	
5-6		10:31	105.340	1.03	.81	305			58	79	76	8
	5	:33	106.200	1.06	.83	313			✓	79	76	8
	4	:35	107.350	.67	.53	320			✓	79	76	8
	3	:37	108.500	1.82	.64	316			✓	79	76	8
	2	:39	108.900	.60	.47	316			✓	79	76	8
	1	:41	109.100	.62	.49	345			✓	79	76	8
		:43	110.450									

1.1288    1.07    321.3    74.67

CHECK INDICATES TEMPERATURES MEET REQUIRED LIMITS.

COMPANY   G.H. Pene. Co.        DATE   12-7-54    
 SITE   Cn. 27 >        RUN #   1      PAGE      OF

PORT # POINT #	TIME	GAS METER VOL. (cu. ft.)	VEL. HEAD $\Delta P$ in. H <sub>2</sub> O	ORIFICE HEAD $\Delta H$ in. H <sub>2</sub> O	TEMPERATURE °F					VAC. in. H <sub>g</sub>		
					STACK	PROBE	HOT BOX	IMP.	GAS METER			
									IN		OUT	
1-6	11:18	11.400	1.58	<del>1.32</del> 1.28	308			66	80	79	8	
5	120	12.650	1.57	1.24	314			✓	80	79	7	
4	122	13.900	1.38	1.07	323			✓	81	79	7	
3	124	14.990	3.12	2.47	321			✓	81	80	10	
2	126	16.650	2.35	1.86	328			✓	81	80	9	
1	128	18.200	3.75	2.97	354			✓	82	80	12	
2-6	11:31	19.950	1.42	<del>1.13</del> 1.13	305			✓	50	82	80	7
5	133	21.000	1.32	1.05	313			✓	82	80	7	
4	135	22.150	1.13	.89	322			✓	83	80	7	
3	137	23.200	1.90	1.51	323			✓	83	80	7	
2	139	24.500	1.85	1.46	328			✓	83	80	9	
1	141	25.800	2.30	1.82	353			✓	84	80	10	
3-6	1:44	27.200	.60	.49	304			✓	51	84	80	5
5	146	27.900	.92	.73	314			✓	84	80	7	
4	148	28.900	.92	.73	323			✓	84	81	7	
3	150	29.900	.96	.76	323			✓	84	81	7	
2	152	30.900	1.38	1.07	346			✓	84	81	8	
1	154	31.900	1.92	1.52	355			✓	84	81	10	
2-6	11:57	33.110	1.06	.84	355			✓	84	81	10	
5	159	34.100	1.15	.91	319			✓	84	81	8	
4	1:01	35.350	1.02	.80	325			✓	84	81	8	
3	1:03	36.150	1.06	.84	323			✓	84	81	8	
2	1:05	37.100	.86	.68	335			✓	84	81	7	
1	1:07	38.070	.82	.65	354			✓	84	81	7	

CHECK INDICATES TEMPERATURES MEET REQUIRED LIMITS.

COMPANY G.H. Auer Co DATE 12-7-94  
 SITE Crist RUN # 2 PAGE 2 OF 2

PORT #	TIME	GAS METER VOL. (cu. ft.)	VEL. HEAD ΔP in. H <sub>2</sub> O	ORIFICE HEAD ΔH in. H <sub>2</sub> O	TEMPERATURE °F					VAC. in. H <sub>g</sub>	
					STACK	PROBE	HOT BOX	IMP.	GAS METER		
									IN		OUT
5-6	12:10	38.900	.96	.76	308			51	83	80	8
5	:12	39.800	1.04	.82	325			✓	83	80	8
4	:14	40.700	.80	.63	320			✓	83	80	8
3	:16	41.600	.82	.65	322			✓	83	80	8
2	:18	42.500	.67	.53	337			✓	83	80	8
1	:20	43.300	.63	.50	353			✓	83	80	8
	:22	44.140									

1.1213    1.041    322.7    81.57

CHECK INDICATES TEMPERATURES MEET REQUIRED LIMITS.

COMPANY Gulf Power Co      DATE 12-7-94  
 SITE Crist >      RUN # 2      PAGE      OF

PORT #	TIME	GAS METER VOL. (cu. ft.)	VEL. HEAD $\Delta P$ in. H <sub>2</sub> O	ORIFICE HEAD $\Delta H$ in. H <sub>2</sub> O	TEMPERATURE °F					VAC. in. H <sub>g</sub>	
					STACK	PROBE	HOT BOX	IMP.	GAS METER		
POINT #									IN	OUT	
1-6	12:38	45.550	1.50	1.32	305			62	81	80	8
5	:40	46.300	1.69	1.49	315			✓	81	80	8
4	:42	47.500	1.56	1.38	324			✓	82	80	8
3	:44	48.950	3.22	2.84	324			✓	82	80	8
2	:46	50.000	2.32	2.04	335			✓	83	80	10
1	:48	52.350	3.20	2.82	356			✓	82	80	12
2-6	:50	53.900	1.35	1.19	307			✓	80	80	8
5	:52	55.100	1.32	1.16	313			✓	83	80	8
4	:54	56.500	1.22	1.08	324			✓	83	80	8
3	:56	57.300	2.05	1.81	324			✓	83	80	9
2	:58	58.600	2.05	1.81	336			✓	83	80	9
1	13:00	60.500	2.22	1.95	356			✓	83	80	9
3-6	13:03	61.500	.66	.58	306			✓	83	80	6
5	:05	62.400	.92	.81	306			✓	83	80	6
4	:07	63.300	.82	.72	325			✓	83	80	7
3	:09	64.200	.92	.81	325			✓	83	80	7
2	:11	65.140	1.04	.92	340			✓	83	80	7
1	:13	65.900	1.9	1.68	350			✓	83	80	11
4-6	:18	67.400	1.06	.93	307			✓	83	80	8
5	:19	68.200	1.06	.93	320			✓	83	80	8
4	:21	69.500	.92	.81	328			✓	83	80	8
3	:23	70.300	.96	.84	326			✓	83	80	8
2	:25	71.300	.73	.64	326			✓	83	80	8
1	:27	72.200	.92	.81	356			✓	83	80	9

CHECK INDICATES TEMPERATURES MEET REQUIRED LIMITS.

COMPANY G.H. Buss Co. DATE 12-7-54  
 SITE Christ RUN # 3 PAGE      OF



3137

7848

3903

PORT # POINT #	TIME	GAS METER VOL. (cu. ft.)	VEL. HEAD ΔP in. H <sub>2</sub> O	ORIFICE HEAD ΔH in. H <sub>2</sub> O	TEMPERATURE °F					VAC. in. H <sub>g</sub>	
					STACK	PROBE	HOT BOX	IMP.	GAS METER		
									IN	OUT	
5-6	13:30	73.215	.97	.88	310			59	82	80	9
5	:32	74.150	.97	.88	323			✓	82	80	9
4	:34	75.350	.77	.68	327			✓	82	80	9
3	:36	76.250	.92	.72	325			✓	82	80	9
2	:38	77.000	.72	.63	340			✓	82	80	9
1	:40	77.950	.72	.63	353			✓	82	80	9
	:42	78.825									

1.1315 1.19 322.5

8125

CHECK INDICATES TEMPERATURES MEET REQUIRED LIMITS.

COMPANY E. G. H. Power Co DATE 12-7-94

SITE Crisfield RUN # 3 PAGE      OF

LABORATORY ANALYSIS & CHAIN OF CUSTODY

COMPANY/PLANT: GULF POWER CO.

UNIT #: 7 DATE OF TEST: 12-6-92 TYPE OF TEST:  M-5  M-17  OTHER \_\_\_\_\_

SAMPLE #	RELINQUISHED BY	RECEIVED BY	TIME	DATE	REASON FOR CHANGE
<del>3 FH - U7-S8</del>	<del>W</del>	<del>W</del>	<del>AM</del>	<del>12/3/92</del>	<del>Lab</del>
<del>3 W2-L U7-S5</del>	<del>W</del>	<del>W</del>	<del>AM</del>	<del>12/3/92</del>	<del>Lab</del>
<del>3 FH - U7-S8</del>	<del>W</del>	<del>W</del>	<del>AM</del>	<del>12/3/92</del>	<del>Lab</del>
<del>3 FH - U7-S8</del>	<del>W</del>	<del>W</del>	<del>AM</del>	<del>12/3/92</del>	<del>Lab</del>

UNIT # 7 Dec 6, 1992

UNIT # 7 Dec 7, 1992

RUN # <u>1</u>	FILTER # <u>1113</u>	BEAKER # <u>4</u> WASH (ML) <u>42</u>
FINAL WEIGHT	<u>155.1</u>	<u>68029.9</u>
INITIAL WEIGHT	<u>120.1</u>	<u>68020.0</u>
DIFFERENCE	<u>35.0</u>	<u>4.9</u>
CORRECTED TOTAL WEIGHT		<u>39.9</u>
RUN # <u>2</u>	FILTER # <u>1114</u>	BEAKER # <u>5</u> WASH (ML) <u>22</u>
FINAL WEIGHT	<u>142.1</u>	<u>64697.1</u>
INITIAL WEIGHT	<u>119.5</u>	<u>64692.8</u>
DIFFERENCE	<u>22.6</u>	<u>4.3</u>
CORRECTED TOTAL WEIGHT		<u>26.9</u>
RUN # <u>3</u>	FILTER # <u>1112</u>	BEAKER # <u>32</u> WASH (ML) <u>28</u>
FINAL WEIGHT	<u>143.6</u>	<u>64731.8</u>
INITIAL WEIGHT	<u>121.7</u>	<u>64724.1</u>
DIFFERENCE	<u>21.9</u>	<u>7.7</u>
CORRECTED TOTAL WEIGHT		<u>29.6</u>
RUN # _____	FILTER # _____	BEAKER # _____ WASH (ML) _____
FINAL WEIGHT		
INITIAL WEIGHT		
DIFFERENCE		
CORRECTED TOTAL WEIGHT		

RUN # <u>1</u>	FILTER # <u>1116</u>	BEAKER # <u>7</u> WASH (ML) <u>22</u>
FINAL WEIGHT	<u>168.4</u>	<u>62231.1</u>
INITIAL WEIGHT	<u>121.5</u>	<u>60923.3</u>
DIFFERENCE	<u>46.9</u>	<u>7.8</u>
CORRECTED TOTAL WEIGHT		<u>59.7</u>
RUN # <u>2</u>	FILTER # <u>1117</u>	BEAKER # <u>30</u> WASH (ML) <u>22</u>
FINAL WEIGHT	<u>149.7</u>	<u>67093.4</u>
INITIAL WEIGHT	<u>122.4</u>	<u>67079.5</u>
DIFFERENCE	<u>27.3</u>	<u>3.9</u>
CORRECTED TOTAL WEIGHT		<u>33.2</u>
RUN # <u>3</u>	FILTER # <u>1118</u>	BEAKER # <u>40</u> WASH (ML) <u>20</u>
FINAL WEIGHT	<u>155.5</u>	<u>67690.7</u>
INITIAL WEIGHT	<u>119.9</u>	<u>67689.2</u>
DIFFERENCE	<u>35.6</u>	<u>2.5</u>
CORRECTED TOTAL WEIGHT		<u>38.1</u>
WASH SOLVENT BLANK (ML)	<u>50</u>	BEAKER # <u>17</u> WASH (ML) <u>50</u>
FINAL WEIGHT		<u>68323.1</u>
INITIAL WEIGHT		<u>68324.1</u>
DIFFERENCE		<u>1.0</u>
CORRECTION FACTOR (MG/ML)		<u>40.00</u>

ALL WEIGHTS ARE IN MILLIGRAMS (MG)

**A P P E N D I X B EQUATIONS AND SAMPLE CALCULATIONS**

## EQUATIONS

$$1. \quad P_s = P_{\text{bar}} + \frac{P_g}{13.6}$$

$$2. \quad P_m = P_{\text{bar}} + \frac{\overline{\Delta H}}{13.6}$$

$$3. \quad V_s = K_p C_p \sqrt{\Delta P} \sqrt{\frac{\overline{T_s}}{M_s P_s}}$$

$$4. \quad V_{m(\text{Std})} = K_1 V_m Y \left[ \frac{P_{\text{bar}} + \frac{\overline{\Delta H}}{13.6}}{\overline{T_m}} \right]$$

$$5. \quad V_{w(\text{Std})} = 0.04707 V_{l c}$$

$$6. \quad B_{ws} = \frac{V_{w(\text{Std})}}{V_{m(\text{Std})} + V_{w(\text{Std})}}$$

$$7. \quad M_d = 0.44 (\%CO_2) + 0.32 (\%O_2) + 0.28 (\%N_2 + \%CO)$$

$$8. \quad M_s = M_d(1 - B_{ws}) + 18 (B_{ws})$$

$$9. \quad EA = \left[ \frac{(\%O_2 - 0.5 (\%CO))}{0.264 (\%N_2) - ((\%O_2) - 0.5 (\%CO))} \right] 100$$

$$10. \quad Q_a = (V_s) (A_s) (60)$$

$$11. \quad Q_s = Q_a (1 - B_{ws}) \frac{(528)}{\bar{T}_s} \frac{(P_s)}{29.92}$$

$$12. \quad E_H = \left( \frac{PMR}{H_1} \right)$$

$$13. \quad E = C_d F_{O_2} \left( \frac{20.9}{20.9 - \%O_2} \right)$$

$$14. \quad C_s = 0.0154 \frac{M_n}{V_{m(Std)}}$$

$$15. \quad C_{50} = \frac{21 C_s}{21 - [(1.5) (\%O_2) - 0.133 (N_2) - 0.75 (\%CO)]}$$

$$16. \quad C_{12} = \frac{C_s (12)}{\%CO_2}$$

$$17. \quad PMR = (C_s) (Q_s) \frac{(60)}{7000}$$

$$18. \quad V_n = \left[ (0.002669) (V_{1c}) + \frac{V_m Y}{\bar{T}_m} \left( p_{bar} + \frac{\bar{\Delta H}}{13.6} \right) \right] \frac{\bar{T}_s}{p_s}$$

$$19. \quad I = \frac{100 V_n}{(60) \emptyset V_s A_n}$$

## NOMENCLATURE

- $A_n$  = Cross-sectional area of nozzle, ft<sup>2</sup>
- $A_s$  = Cross sectional area of stack, ft<sup>2</sup>
- $B_{we}$  = Water vapor in the gas stream,  
proportion by volume (dimensionless)
- $C_p$  = Pitot tube coefficient (dimensionless) (0.84)
- $C_s$  = Particulate concentration, grains/SDCF
- $C_d$  = Particulate concentration, lbs/SDCF
- $C_{12}$  = Particulate concentration ( $C_s$  adjusted to 12% CO )  
grains/SDCF
- $C_{50}$  = Particulate concentration ( $C_s$  adjusted to 50% excess air)  
grains/SDCF
- EA = Excess air, %
- E = Emission in lb/mmBTU
- $E_H$  = Emission in lb/mmBTU, based on heat input
- $H_I$  = Total Heat Input, Million BTU per Hour (MMBTU/hr)
- I = Percent of isokinetic sampling
- $K_1$  = 17.64 °R/ inches Hg
- $K_p$  = Pitot tube constant,  
$$85.49 \text{ ft/sec} \left[ \frac{(\text{lb/lb-mole}) (\text{in. Hg})}{(^\circ\text{R}) (\text{inc. H}_2\text{O})} \right]^{\frac{1}{2}}$$
- $M_n$  = Total amount of particulate collected, mg
- $M_d$  = Molecular weight of stack gas; dry basis, lb/lb mole
- $M_s$  = Molecular weight of stack gas; wet basis, lb/lb mole
- $P_{bar}$  = Barometric pressure at the sampling site, in. Hg

## NOMENCLATURE (continued)

- $P_m$  = Meter pressure, in. Hg
- $P_s$  = Absolute stack pressure, in. Hg
- $P_g$  = Stack static pressure, in. H<sub>2</sub>O
- PMR = Particulate mass rate, lb/Hr
- $Q_a$  = Volumetric flow rate ACFM
- $Q_s$  = Volumetric flow rate SDCFM
- $V_s$  = Average stack gas velocity, ft/sec
- $V_{lc}$  = Total volume of liquid collected in impingers & silica gel, ml
- $V_m$  = Volume of gas sample as measured by dry gas meter, ACF
- $V_{m(std)}$  = Volume of gas sample measured by dry gas meter,  
corrected to standard conditions, SDCF
- $V_{w(std)}$  = Volume of water vapor in gas sample, corrected to standard  
conditions, SCF
- $V_n$  = Volume collected at stack conditions through nozzle, ACF
- Y = Dry gas meter calibration factor (dimensionless)
- $\Delta H$  = Average pressure difference of orifice, in. H<sub>2</sub>O
- $\Delta P$  = Velocity head of stack gas, in. H<sub>2</sub>O
- $\sqrt{\Delta P}$  = Average of square roots of the velocity pressure, in. H<sub>2</sub>O
- $\emptyset$  = Total sampling time, minutes
- %CO<sub>2</sub>, %O<sub>2</sub>, N<sub>2</sub>, %CO - Number % by volume, dry basis, from gas analysis
- $F_{O_2}$  = Oxygen based F factor (9820 SDCF/mmBTU for bituminous coal)
- $T_s$  = Temperature of the stack, °R (°F + 460)

**Input and Constants**

$$f := \frac{9820 \text{ ft}^3}{\text{mm btu}}$$

$$pg := 1.3 \text{ in. H}_2\text{O}$$

$$pbar := 30.3 \text{ in. Hg.}$$

$$\Delta h_{avg} := 1.066 \text{ in. H}_2\text{O}$$

$$y := 0.99$$

$$t_m := 77.9 \text{ }^\circ\text{F}$$

$$o_2 := 4.8$$

$$co_2 := 14.$$

$$v_m := 32.05 \text{ ft}^3$$

$$v_{lc} := 76.4 \text{ ml}$$

$$\theta := 60 \text{ min}$$

$$nozdia := 0.184 \text{ in.}$$

$$t_s := 321. \text{ }^\circ\text{F}$$

$$a_s := 375. \text{ ft}^2$$

$$m_n := 54.7 \text{ mg}$$

$$numberofpoints := 30$$

$$sqrt{\Delta p} := 1.129 \text{ in. H}_2\text{O}$$

$$kp := \frac{85.49 \text{ 1 ft}^1 \left( \frac{\text{lb in. Hg.}}{\text{lb-mole } ^\circ\text{R in. H}_2\text{O}} \right)^{0.5}}{1 \text{ sec}}$$

$$cp := 0.84$$

$$k_1 := \frac{17.64 \text{ }^\circ\text{R}}{\text{in. Hg.}}$$



$$t_s = \frac{(t_s + 460 \text{ } ^\circ\text{F}) \text{ } ^\circ\text{R}}{\text{ } ^\circ\text{F}}$$

781. °R

$$t_m = \frac{(t_m + 460 \text{ } ^\circ\text{F}) \text{ } ^\circ\text{R}}{\text{ } ^\circ\text{F}}$$

537.9 °R

$$n_2 = 100 - o_2 - co_2$$

81.2

$$a_n = \frac{\text{nozdia}^2 \text{ } 3.1416}{4 \left( \frac{12 \text{ in.}^2}{\text{ft}} \right)}$$

0.000184656 ft<sup>2</sup>

Calculations

Equation 1

$$p_s = p_{bar} + \frac{p_g}{13.6 \text{ in. H}_2\text{O}}$$

$$\frac{1 \text{ in. Hg.}}{13.6 \text{ in. H}_2\text{O}}$$

30.3956 in. Hg.

Equation 2

$$p_m = p_{bar} + \frac{\Delta h_{avg}}{13.6 \text{ in. H}_2\text{O}}$$

$$\frac{\text{in. Hg.}}{13.6 \text{ in. H}_2\text{O}}$$

30.3784 in. Hg.

Equation 3

$$k_1 v_m y \left( p_{bar} + \frac{\Delta h_{avg}}{13.6 \text{ in. H}_2\text{O}} \right)$$

$$\frac{\text{in. Hg.}}{13.6 \text{ in. H}_2\text{O}}$$

$$v_{mstd} = \frac{\text{-----}}{t_m}$$

<sup>3</sup>  
31.61 ft

Equation 4

$$v_{wstd} = \frac{0.04707 \text{ ft}^3 v_{lc}}{m_l}$$

<sup>3</sup>  
3.59615 ft

Equation 5

$$b_{ws} = \frac{v_{wstd}}{v_{mstd} + v_{wstd}}$$

0.102145

Equation 6

$$md = \frac{(0.44 \text{ co}_2 + 0.32 \text{ o}_2 + 0.28 \text{ n}_2) \text{ lb}}{\text{lb-mole}}$$

$$\frac{30.432 \text{ lb}}{\text{lb-mole}}$$

Equation 7

$$ms = md (1 - bws) + \frac{bws \text{ 18 lb}}{\text{lb-mole}}$$

$$\frac{29.1621 \text{ lb}}{\text{lb-mole}}$$

Equation 8

$$vs = kp \text{ cp } \sqrt{ts} \left( \frac{0.5}{ms \text{ ps}} \right)$$

$$\frac{76.1025 \text{ ft}}{\text{sec}}$$

Equation 9

$$qa = \frac{vs \text{ as } 60 \text{ sec}}{\text{min}}$$

$$\frac{1.71231 \text{ } 10^6 \text{ } 10^3 \text{ ft}}{\text{min}}$$

Equation 10

$$qs = \frac{qa (1 - bws) 528 \text{ } ^\circ\text{R ps}}{ts \text{ 29.92 in. Hg.}}$$

$$\frac{1.05589 \text{ } 10^6 \text{ } 10^3 \text{ ft}}{\text{min}}$$

Equation 11

$$cs = \frac{0.0154 \text{ gr mn}}{\text{mg vmstd}}$$

$$\frac{0.0266491 \text{ gr}}{\text{ft}^3}$$

Equation 12

$$pmr = \frac{cs \text{ qs } 60 \text{ min}}{\text{hour} \frac{7000 \text{ gr}}{\text{lb}}}$$

$$\frac{241.188 \text{ lb}}{\text{hour}}$$

Equation 13

$$e = \frac{cs \text{ f } 20.9 \text{ l lb}}{(20.9 - o_2) 7000 \text{ gr}}$$

$$\frac{0.0485307 \text{ lb}}{\text{mm btu}}$$

Equation 14

$$vn = \frac{0.002669 \text{ in. Hg. ft}^3 \text{ vlc} \text{ vm y pm}}{\text{ml } ^\circ\text{R} + \text{tm}}$$

$$51.2827 \text{ ft}^3$$

Equation 15

$$i = \frac{100 \text{ } \% \text{ } vn}{60 \text{ sec theta vs an}} \text{ min}$$

101.369 %

Equation 16

$$hi = \frac{pmr}{e} \text{ 4969.8 mm btu} \text{ hour}$$

**A P P E N D I X C QUALITY CONTROL**

**INITIAL  
METER CALIBRATION FORM - DGM**

DATE: 06-16-94                      Box No. S-100

Ref. DGM Ser. #	1044456	Calibrated By			JACK COVINGTON	
RUN #		1	2	3	4	5
DELTA H (DGM)		0.50	1.00	1.50	2.00	3.00
Y (Ref. DGM)		0.985	0.985	0.985	0.985	0.985
Reference DGM						
Gas Vol. Initial		198.000	205.700	214.200	225.700	236.500
Gas Vol. Final		205.300	213.600	223.000	235.600	242.700
Meter Box DGM						
Gas Vol. Initial		187.520	195.170	203.650	215.090	225.830
Gas Vol. Final		194.778	203.050	212.418	224.920	231.960
Reference DGM						
Temp.		Avg.	Avg.	Avg.	Avg.	Avg.
Deg F Initial		93	93	94	95	95
Deg F Final		93	94	95	95	94
Meter Box DGM						
Temp. Initial In		94	97	95	99	97
Temp. Initial Out		93	94	95	98	93
Temp. Final In		97	95	100	97	98
Temp. Final Out		94	95	96	93	93
P Bar IN. Hg		30.15	30.15	30.15	30.15	30.15
Time (sec.)		1044	832	756	737	380
Meter Calibration						
Factor (Y)		0.992	0.988	0.989	0.990	0.990
Qm (C.F.M.)		0.398	0.540	0.660	0.761	0.925
Km (Std Pressure)		0.707	0.678	0.677	0.676	0.673
DELTA Ha		1.70	1.85	1.85	1.85	1.89
Average Y (Meter Calibration Factor)					0.990	
Average Km (Standard Pressure)					0.682	
Average DELTA Ha of Orifice					1.825	

Y =  $\leq$  .03  
 Max & Min  $\leq$  .02 from Avg  
 Final Avg within 5% of Initial Avg  
 $\Delta$ Ha = Max & Min  $\leq$  .2 from Avg

**FINAL  
METER CALIBRATION FORM - DGM**

DATE:	12-10-94	Box No.	S-100
Ref. DGM Ser. #	1044456	Calibrated By	JACK COVINGTON
RUN #	1	2	3
DELTA H (DGM)	1.5	1.5	1.5
Y (Ref. DGM)	0.985	0.985	0.985
Reference DGM			
Gas Vol. Initial	38.900	45.300	52.900
Gas Vol. Final	45.300	52.900	60.700
Meter Box DGM			
Gas Vol. Initial	96.960	103.375	111.000
Gas Vol. Final	103.375	111.000	118.800
Reference DGM			
Temp.	Avg.	Avg.	Avg.
Deg F Initial	60	60	60
Deg F Final	62	63	63
Meter Box DGM			
Temp. Initial In	60	60	60
Temp. Initial Out	60	60	60
Temp. Final In	62	63	66
Temp. Final Out	62	63	64
P Bar IN. Hg	30.14	30.14	30.14
Time (sec.)	575	675	710
Meter Calibration			
Factor (Y)	0.979	0.978	0.983
Qm (C.F.M.)	0.672	0.679	0.662
Km (Std Pressure)	0.712	0.719	0.701
DELTA Ha	1.90	1.86	1.95
Average Y (Meter Calibration Factor)			0.980
Initial Y (Meter Calibration Factor)			0.990
Percent Error			1.01%
Average Km (Standard Pressure)			0.710
Average DELTA Ha of Orifice			1.90



# MAGEHELIC CALIBRATION

BOX	460	100	133	2879	173	175	S101	S-318
SER. NO.	91127W	91126A	R32D	R33C	R20208	R90125	R22D	R74D
	W137	M91			A617	MR6		
RANGE	0-2	0-2	0-2	0-2	0-2	0-2		0-5
REFERENCE READING	FIELD DEVICE READING							
0.000						0.00	0.0	
0.050								
0.150								
0.200								
0.250								
0.450								
0.50	0.50	0.50	0.48	0.52		0.50	0.5	
1.00	1.02	1.00	0.96	1.02		0.98	0.98	
1.30								
1.80	1.86	1.80	1.70	1.86		1.80	1.8	
2.50								
4.50								
5.0								
9.0								
13.0								
22.0								

SIGNATURE:

*Chun... [Signature]*

DATE:

*6/15/08*

**MAGEHELIC CALIBRATION**  
BOX #1

SER. NO.	10720-	R1061-	R5031-	R1062-	R1051-	R90124
	A868	3AG48	SE375	9JA82	3MR42	R1119
RANGE	0-0.25	0-0.50	0-2	0-5	0-10	0-25
REFERENCE READING	FIELD DEVICE READING					
0.000	0.000	0.000	0.00	0.00	0.0	0.0
0.050	0.050					
0.150	0.150	0.150				
0.200	0.200					
0.250		0.250				
0.450		0.450				
0.50			0.49			
1.00			0.99			
1.30				1.30		
1.80			1.80			
2.50				2.40	2.5	
4.50				4.50		
5.0					5.0	5.0
9.0					9	
13.0						13.0
22.0						22.0

SIGNATURE:

*Samuel Harris*

DATE:

6/16/91

**MAGEHELIC CALIBRATION**  
**BOX #2**

SER. NO.	10819- DF2	R1090- 2AG18	R50315- EB93	R1062- 9TA87	30830- AM79	R1072- 2MC5
RANGE	0-0.25	0-0.50	0-2	0-5	0-10	0-25
REFERENCE READING	FIELD DEVICE READING					
0.000	0.000					
0.050	0.051					
0.150	0.158	0.152				
0.200	0.206					
0.250		0.250				
0.450		0.456				
0.50			0.51			
1.00			1.01			
1.30				1.31		
1.80			1.83			
2.50				2.52	2.5	
4.50				4.50		
5.0					5.0	5.0
9.0					8.3	
13.0						12.6
22.0						21.5

SIGNATURE: \_\_\_\_\_

*[Handwritten Signature]*

DATE: \_\_\_\_\_

*[Handwritten Date]*

MAGEHELIC CALIBRATION  
BOX #3

SER. NO.	R900723MIR01126	R10608	
	RR LC2	CF20	
RANGE	0-0.50	0-2	0-10
REFERENCE READING	FIELD DEVICE READING		
0.000	0.00	0.00	0.0
0.050			
0.150	0.15		
0.200			
0.250	0.250		
0.450	0.45		
0.50		0.50	
1.00		1.00	
1.30			
1.80		1.80	
2.00			2.0
4.50			
5.0			5.0
9.0			9.0
13.0			
22.0			

SIGNATURE:

*Edward L. Harris*

DATE:

10/11/94


**Best Available Copy**

**MAGEHELIC CALIBRATION**

BOX #5

SER. NO.	R90072	R90100	R90111
	3MRR1	3CD87	3RR106
RANGE	0-0.50	0-5	0-25
REFERENCE READING	FIELD DEVICE READING		
0.000:	0.00	0.00	0.0
0.050:			
0.150:	0.153		
0.200:			
0.250:	0.254		
0.450:	0.458		
0.50:			
1.00:			
1.30:		1.32	
1.80:			
2.50:		2.51	
4.50:		4.56	
5.0:			5.0
9.0:			
13.0:			12.8
22.0:			21.8

SIGNATURE: \_\_\_\_\_




DATE:

TEMPERATURE CALIBRATIONS - DEGREES FAHRENHEIT

REFERENCE DEVICE READING*	0 DEG. F	210 DEG.	420 DEG.	630 DEG.	840 DEG.	1050 DEG.	1260 DEG.	1470 DEG.	1680 DEG.	1900 DEG.
2879	1	211	421	631	839	1050	1260	1470	1680	1900
METER BOX #1 C-133 11580	0	214	423	632	850	1060	1267	1479	1690	1910
METER BOX #3 C-173 S11-24										
METER BOX #2 C-175 15962	0	212	418	626	843	1058	1251	1470	1684	1909
METER BOX #4 D-460 15751	0	207	414	624	838	1055	1271	1484	1689	1898
METER BOX #5 S-100 15751	0	206	413	623	838	1055	1271	1484	1689	1899
METER BOX #6 S-101 15751	0	212	422	635	836	1056	1265	1471	1690	1909
METER BOX #7 S-318 15751										
PORTABLE THERMOCOUPLE # 2 (Blue)	2	210	416	625	839	1055	1270	1480	1684	1890
PORTABLE THERMOCOUPLE # 2 (Green)	2	210	417	626	840	1057	1272	1483	1687	1893
PINK T83658	1	210	418	629	844	1062	1278	1489	1695	1903

DATE: 6-16-44

SIGNATURE: 

\* Reference Device is an Omega Engineering CL505-A calibrated reference thermocouple-potentiometer system.






**SANDERS ENGINEERING & ANALYTICAL SERVICES, Inc.**

1688 Leroy Stevens Rd. Office: (206) 833-4120  
 Medina, Al. 98005 FAX: (206) 833-2285


The Pilot used was within the following geometric specifications:  
 $D_i$  between 0.48 and 0.96 cm (3/16 and 3/8 in.)  
 $G_p = 0.84$




**Notes:**

$1.05 D_i \leq 1.50 D_i$


$P_A = P_B$



Minimum pilot-sample probe separation needed to prevent interference



OR



Proper thermocouple placement to prevent interference.




**SANDERS ENGINEERING &  
ANALYTICAL SERVICES, Inc.**


1600 Jerry Bluvens Rd  
McCalla, Al. 36696

Office: (205) 833 4120  
FAX: (205) 833 2286

Proper pilot tube-sampling nozzle configuration to prevent aero-dynamic interference; bottomhook type nozzle; centers of nozzle and pilot opening aligned;  $D_1$  between 0.48 and 0.65 cm (3/16 and 3/8 in.)



Bottom view showing minimum pilot/nozzle separation



Side view; to prevent pilot tube from interfering with the gas flow streamlines approaching the nozzle, the impact pressure opening plane of the pilot tube shall be even with or above the nozzle entry plane.





Best Available Copy

**SANDERS ENGINEERING & ANALYTICAL SERVICES, Inc.**

1688 Leroy Stevens Rd. Office: (205) 833-1120  
 Mobile, AL 36606 FAX: (205) 833-2288

Types of face-opening misalignment that can result from field use or improper construction of type 'B' pilot tubes. These will not affect the baseline value of  $C_p(\theta)$  so long as  $\alpha_1$  and  $\alpha_2 \leq 10^\circ$ ,  $\theta_1$  and  $\theta_2 \leq 5^\circ$ , and  $w \leq 0.32$  cm (1/8 in.)



**A P P E N D I X D OPERATIONAL DATA**

**CRIST ELECTRIC GENERATING PLANT  
PARTICULATE COMPLIANCE TEST CHRONOLOGY  
UNIT # 7  
STEADY STATE CONDITIONS  
December 7, 1994**

RUN # 1	START	9:39 a.m.	No problems noted at beginning of run.
	STOP	10:43 a.m.	No problems noted at end of run.
RUN # 2	START	11:18 a.m.	No problems noted at beginning of run.
	STOP	12:22 p.m.	No problems noted at end of run.
RUN # 3	START	12:38 p.m.	No problems noted at beginning of run.
	STOP	1:42 p.m.	No problems noted at end of run.

**CRIST ELECTRIC GENERATING PLANT  
PARTICULATE COMPLIANCE TEST  
SIX - MINUTE OPACITY AVERAGES  
UNIT # 7  
STEADY STATE CONDITIONS  
December 7, 1994**

TIME OF 6 MIN. AVERAGE	OPACITY (%)
(RUN # 1: 9:39 - 10:43)	(RUN # 1)
9:37 - 9:42	11.3
9:43 - 9:48	12.5
9:49 - 9:54	12.8
9:55 - 10:00	13.3
10:01 - 10:06	12.0
10:07 - 10:12	13.2
10:13 - 10:18	12.9
10:19 - 10:24	12.2
10:25 - 10:30	12.3
10:31 - 10:36	13.2
10:37 - 10:42	13.6
10:43 - 10:48	13.0
(RUN # 2: 11:18 - 12:22)	(RUN # 2)
11:13 - 11:18	12.0
11:19 - 11:24	12.2
11:25 - 11:30	12.9
11:31 - 11:36	13.2
11:37 - 11:42	12.1
11:43 - 11:48	12.4
11:49 - 11:54	12.2
11:55 - 12:00	14.9
12:01 - 12:06	13.0
12:07 - 12:12	13.7
12:13 - 12:18	12.2
12:19 - 12:24	13.8

**CRIST ELECTRIC GENERATING PLANT  
PARTICULATE COMPLIANCE TEST  
SIX - MINUTE OPACITY AVERAGES  
UNIT # 7  
STEADY STATE CONDITIONS  
December 7, 1994**

<b>(RUN # 3: 12:38 - 1:42)</b>	<b>(RUN # 3)</b>
12:37 - 12:42	12.0
12:43 - 12:48	11.5
12:49 - 12:54	12.1
12:55 - 1:00	13.5
1:01 - 1:06	11.6
1:07 - 1:12	12.4
1:13 - 1:18	12.5
1:19 - 1:24	12.3
1:25 - 1:30	12.1
1:31 - 1:36	11.5
1:37 - 1:42	11.8

CRIST ELECTRIC GENERATING PLANT

PRECIPITATOR COMPLIANCE TEST READINGS

UNIT # 7  
 DATE 12/7/94  
 LOAD 495

STEAD STATE

RUN # 1  
 START TIME 0935  
 FINISH TIME 1043

A PRECIPITATOR		PRIMARY AMPS	PRIMARY VOLTS	SECONDARY AMPS	SECONDARY VOLTAGE
START	1A	40	360	260	
	1B	45	330	340	
	1C	70	400	700	
	1D	80	370	680	
	1E	90	340	700	
	1F	85	390	660	
	1G	98	375	800	
	1H	88	370	780	
	1J	110	450	1000	

FINISH	1A	30	360	220	
	1B	55	350	320	
	1C	55	370	560	
	1D	70	350	585	
	1E	80	350	585	
	1F	80	350	640	
	1G	90	350	375	
	1H	89	350	600	
	1J	100	425	900	

COMMENTS : \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

CRIST ELECTRIC GENERATING PLANT  
PRECIPITATOR COMPLIANCE TEST READINGS

UNIT # 7  
DATE 12/7/04  
LOAD \_\_\_\_\_

STEAD STATE

RUN # 1  
START TIME 0935  
FINISH TIME 1043

B PRECIPITATOR		PRIMARY AMPS	PRIMARY VOLTS	SECONDARY AMPS	SECONDARY VOLTAGE
START	2A	50	420	300	/
	2B	50	320	260	
	2C	35	250	190	
	2D	100	330	680	
	2E	85	400	700	
	2F	105	400	960	
	2G	98	372	800	
	2H	100	373	940	
	2J	100	385	900	

FINISH	2A	50	420	300	/
	2B	60	340	265	
	2C	80	360	530	
	2D	110	340	800	
	2E	70	380	900	
	2F	50	300	1230	
	2G	98	375	700	
	2H	100	375	920	
	2J	100	390	800	

COMMENTS : \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

CRIST ELECTRIC GENERATING PLANT  
 PRECIPITATOR COMPLIANCE TEST READINGS

JNIT # 7  
 DATE 12-7-94  
 LOAD 495

RUN # 2  
 START TIME 1118  
 FINISH TIME 1222

A PRECIPITATOR		PRIMARY AMPS	PRIMARY VOLTS	SECONDARY AMPS	SECONDARY VOLTAGE
START	1A	30	360	220	
	1B	55	350	320	
	1C	55	370	560	
	1D	70	350	585	
	1E	80	350	585	
	1F	80	350	640	
	1G	90	350	375	
	1H	89	350	600	
	1J	100	525	900	

FINISH	1A	35	340	200	
	1B	45	340	300	
	1C	50	340	280	
	1D	70	360	340	
	1E	90	340	600	
	1F	80	400	660	
	1G	90	375	760	
	1H	80	360	720	
	1J	95	425	900	

COMMENTS : \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_



CRIST ELECTRIC GENERATING PLANT  
 PRECIPITATOR COMPLIANCE TEST READINGS

UNIT # 7  
 DATE 12-7-94  
 LOAD 495

RUN # 2  
 START TIME 1118  
 FINISH TIME 1222

B PRECIPITATOR		PRIMARY AMPS	PRIMARY VOLTS	SECONDARY AMPS	SECONDARY VOLTAGE
START	2A	50	420	300	
	2B	60	340	265	
	2C	80	360	530	
	2D	110	340	800	
	2E	70	380	900	
	2F	50	300	1230	
	2G	98	375	700	
	2H	100	375	920	
	2J	100	390	800	

FINISH	2A	40	380	280	
	2B	40	270	220	
	2C	70	350	540	
	2D	100	340	800	
	2E	60	350	520	
	2F	100	400	900	
	2G	100	375	800	
	2H	100	375	940	
	2J	100	400	900	

COMMENTS : \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

CRIST ELECTRIC GENERATING PLANT  
 PRECIPITATOR COMPLIANCE TEST READINGS

UNIT # 7  
 DATE 12-7-94  
 LOAD 495

STEAD STATE

RUN # 3  
 START TIME 1238  
 FINISH TIME 1342

A PRECIPITATOR	PRIMARY AMPS	PRIMARY VOLTS	SECONDARY AMPS	SECONDARY VOLTAGE
START	1A	35	340	200
	1B	45	340	300
	1C	50	340	280
	1D	70	360	340
	1E	90	340	600
	1F	80	400	660
	1G	90	375	760
	1H	80	360	720
	1J	95	425	900

FINISH	1A	40	340	220
	1B	45	340	240
	1C	35	320	300
	1D	55	340	420
	1E	70	360	600
	1F	70	380	520
	1G	80	375	640
	1H	70	340	620
	1J	90	400	900

COMMENTS : \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

CRIST ELECTRIC GENERATING PLANT

PRECIPITATOR COMPLIANCE TEST READINGS

UNIT # 7  
 DATE 12-7-94  
 LOAD 495

STEAD STATE

RUN # 3  
 START TIME 1238  
 FINISH TIME 1342

B PRECIPITATOR	PRIMARY AMPS	PRIMARY VOLTS	SECONDARY AMPS	SECONDARY VOLTAGE
START	2A	40	380	280
	2B	40	270	220
	2C	70	350	540
	2D	100	340	800
	2E	60	350	520
	2F	100	400	900
	2G	100	375	800
	2H	100	375	940
	2J	100	400	900

FINISH	2A	40	400	340
	2B	40	290	300
	2C	70	300	220
	2D	65	280	520
	2E	60	350	500
	2F	70	340	600
	2G	60	300	400
	2H	90	375	900
	2J	100	400	900

COMMENTS : \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

SANDERS ENGINEERING & ANALYTICAL SERVICES, INC.

**PARTICULATE EMISSIONS TEST REPORT  
SOOT BLOWING OPERATIONS**

*FOR*

**GULF POWER COMPANY**  
*Plant Crist, Unit 7  
Pensacola, Florida*



*September 26, 1995*

1568 LEROY STEVENS ROAD

MOBILE, ALABAMA 36695 • 205/633-4120



SANDERS ENGINEERING & ANALYTICAL SERVICES, INC.

1568 LEROY STEVENS ROAD MOBILE, ALABAMA 36695 • OFFICE 334 / 633-4120  
FAX 334 / 633-2285


ENVIRONMENTAL ENGINEERING  
AIR & WATER QUALITY MODELING  
ENVIRONMENTAL ASSESSMENTS  
PSD ANALYSIS  
EMERGENCY RESPONSE MONITORING

AMBIENT AIR MONITORING  
CONTINUOUS IN-STOCK MONITORING  
SOURCE TESTING  
VISIBLE EMISSIONS TESTING  
CONSULTING SERVICES

### REPORT CERTIFICATION

The sampling and analysis for this report was carried out under my direction and supervision.

Date: 10-3-95

Signature:   
C. Jack Covington  
Senior Environmental Specialist

I have reviewed the testing details and results in this report and hereby certify that the test report is authentic and accurate to the best of my knowledge.

Date: 10-3-95


Signature:   
Joseph C. Sanders  
Manager

TABLE OF CONTENTS

INTRODUCTION ..... 1

SUMMARY AND DISCUSSION OF RESULTS ..... 2

PROCESS DESCRIPTION ..... 4

*Source Air Flow* ..... 5

*Operation During Testing* ..... 6

SAMPLE POINT LOCATION ..... 7

PARTICULATE SAMPLING PROCEDURE (EPA Method 17) ..... 8

*Particulate Sample Recovery* ..... 9

*Particulate Analytical Procedures* ..... 10

APPENDIX A EQUATIONS AND FIELD DATA SHEETS ..... 11

APPENDIX B SAMPLE CALCULATIONS ..... 12

APPENDIX C QUALITY CONTROL ..... 13

APPENDIX D OPERATIONAL DATA ..... 14

**LIST OF TABLES**

TABLE I. RESULTS AND COMPUTATIONS OF PARTICULATE TESTING ..... 3

**ILLUSTRATIONS**

FIGURE 1. AIR FLOW SCHEMATIC..... 5

FIGURE 2. SAMPLE POINT LOCATIONS..... 7

FIGURE 3. PARTICULATE SAMPLING TRAIN..... 8



## **1. INTRODUCTION**

Sanders Engineering & Analytical Services, Inc. (SEAS), performed particulate emissions testing at Gulf Power Company, Plant Crist, Unit 7, located in Pensacola, Florida. The test was conducted on September 26, 1995, during soot blowing operations. The testing was performed in accordance with the applicable U.S. EPA procedures specified at **40 CFR, Part 60, Appendix A, Methods 1, 2, 3, 4, and 17.**

The purpose of the test was to demonstrate compliance with the rules and regulations of the Florida Department of Environmental Protection, and to meet certain requirements contained in the permit to operate issued by the Florida Department of Environmental Protection.

The test was conducted by Mr. Jack Covington, Mr. Edward Harris, Mr. John Wilson, and Mr. Dean Holmes of Sanders Engineering & Analytical Services, Inc., and was coordinated with Mr. John McPherson of Gulf Power Company. Mr. Louis Nichols of the Florida Department of Environmental Protection was also present to observe the testing.

The test was conducted in accordance with the rules and regulations of the Florida Department of Environmental Protection. Further discussion of the test methods are included later in the report.

## **2. SUMMARY AND DISCUSSION OF RESULTS**

The results of the particulate emissions testing for the soot blowing runs, along with the results of the computations, are summarized in Table I. The equations used in the calculation of the results, along with the completed field data sheets, are presented in Appendix A. The sample calculations of the first run are presented in Appendix B. The quality control checks of the equipment used in the sampling program are included in Appendix C.

There were no problems encountered during the performance of the test. At the completion of each run, the filter and probe were removed to a clean, draft-free area for clean-up.

The results of the testing indicate the particulate emission rate during soot blowing for Plant Crist, Unit 7, is 0.027 LBS/MMBTU. The applicable Florida Department of Environmental Protection rules and regulations require an emission rate of no greater than 0.30 LBS/MMBTU. The results of the testing indicate that the unit is in compliance with the particulate emission condition of the permit to operate issued by the Florida Department of Environmental Protection.

**TABLE I. PARTICULATE EMISSIONS TEST RESULTS  
GULF POWER COMPANY  
PLANT CRIST, UNIT 7, SOOT BLOWING  
9/26/95**

Title of Run		<u>RUN 1</u>	<u>RUN 2</u>	<u>RUN 3</u>
Sampling Time -Start	Military	0909	1044	1333
Sampling Time -Stop	Military	1014	1144	1436
F Factor	SDCF/MMBTU	9820	9820	9820
Static Pressure	In. H2O	1.60	1.60	1.60
Barometric Pressure	In. Hg	29.92	29.92	29.92
Average dH	In. H2O	1.8	1.2	2.1
Meter correction		1.016	1.016	1.016
Avg. Meter Temp.	Deg. F	84.9	92.3	96.9
% O2	%	4.9	4.9	4.7
%CO2	%	12.0	12.0	12.0
Volume Metered	ACF	42.657	34.673	43.800
Volume Water	MI	77.500	65.000	100.0
Sampling Time	Minutes	60	60	60
Nozzle Diameter	Inches	0.216	0.190	0.213
Avg. Stack Temp.	Deg. F	328.6	332.7	334.8
Area of Stack	Sq. Feet	375.0000	375.0000	375.0000
Wt. of Part.	Mg.	47.6	30.7	36.4
Number of Points		30	30	30
Avg. Sqrt dP	In. H2O	1.1246	1.1522	1.1819

**RESULTS OF COMPUTATIONS**

		<u>RUN 1</u>	<u>RUN 2</u>	<u>RUN 3</u>	<u>Average</u>
Volume of Gas Sampled	SDCF	42.168	33.764	42.385	
H2O vapor in Gas Stream	PERCENT	8.0	8.3	10.0	8.8
Avg. Stack Gas Velocity	FT/SEC	76.6	78.8	81.2	78.9
Volumetric Flow Rate	SDCF/M	1,066,771	1,086,873	1,096,927	1,083,524
Volumetric Flow Rate	ACF/M	1,724,342	1,772,569	1,827,396	1,774,769
Particulate Conc.	Grs/SDCF	0.017	0.014	0.013	0.015
Particulate Conc.	Grs/ACF	0.011	0.009	0.008	0.009
Particulate Mass Rate	Lb/Hr	159.0	130.4	124.3	137.9
Particulate Mass Rate	Lb/MMBtu	0.032	0.026	0.024	0.027
Heat Input	F Factor MMBTU/Hr	4989.82	5083.84	5195.01	5089.56
Percent of Isokinetic	%	97.1	98.7	97.6	


### **3. PROCESS DESCRIPTION**

The process consists of a steam electric generating unit firing bituminous coal for the production of electric energy. The coal is received by either rail, truck, or barge, and loaded directly onto the conveyor feeding the plant, or onto the stockpile and later loaded onto the conveyor belt transporting the coal to the plant. The coal from the conveyor is loaded into bunkers capable of holding between 24 to 36 hours supply of coal. The coal is then fed to pulverizing mills before being fired in the unit through the burners. Upon combustion of the coal in the fire box, approximately 20 percent of the ash falls to the bottom of the boiler and is removed by the ash removal system. The remaining 80 percent exits with the flue gases through the heat exchange and economizer sections of the furnace, and is collected by electrostatic precipitators.

**3.1. Source Air Flow**

As shown in Figure 1, the flue gases exit the boiler and are separated into ducts A and B before entering air preheaters. They are then routed to a cold side ESP. The flue gases exiting the cold side ESP are exhausted through a stack into the atmosphere.

**Figure 1. Air Flow Schematic**





### ***3.2. Operation During Testing***

The approximate heat input average during soot blowing operation, as based on F-factor calculations, is 5089.56 million BTU per hour, resulting in the production of approximately 495 megawatts of electricity. Precipitator data supplied by Gulf Power personnel is given in Appendix D.

4. SAMPLE POINT LOCATION

The sample point locations and outlet duct schematic are presented in Figure 2. Method 1 was used for determination of the number and location of sampling points. The minimum number of points (25) required for rectangular stacks was met by sampling a total of 30 points.

Figure 2. Sample Point Locations




5. PARTICULATE SAMPLING PROCEDURE (EPA Method 17)

The sampling procedure utilized is that specified in 40 CFR, Part 60, Appendix A, Method 17. A brief description of this procedure is as follows:

The first impingers were partially filled with 100 milliliters of deionized water. The next impinger was left empty to act as a moisture trap.

Preweighed 6 to 16 mesh indication silica gel was added to the last impinger. The sampling equipment manufactured by Lear Siegler (Model 100) or Sanders Engineering (Model 200) was assembled as shown in the attached drawing. The system was leak checked by plugging the inlet to the nozzle and pulling a 15 inch mercury vacuum. A leakage rate not in excess of 0.02 cubic feet per minute was considered acceptable.

Figure 3. Particulate Sampling Train



The inside dimensions of the stack liner were measured and recorded. The required number of sampling points were marked on the probe for easy visibility. The range of velocity pressure, the percent moisture, and the temperature of the effluent



gases were determined. From this data, the correct nozzle size and the nomograph multiplication factor were determined.

Crushed ice was placed around the impingers. The nozzle was placed on the first traverse point with the tip pointing directly into the gas stream. The pump was started immediately and the flow was adjusted to isokinetic sampling conditions. After the required time interval had elapsed, the probe was repositioned to the next traverse point and isokinetic sampling was re-established. This was performed for each point until the run was completed. Readings were taken at each point and recorded on the field data sheet. At the conclusion of each run, the pump was turned off and the final readings were recorded.

### ***5.1. Particulate Sample Recovery***

Care was exercised in moving the collection train to the sample recovery area to minimize the loss of collected sample, or the gain of extraneous particulate matter. The volume of water in the impingers was measured, the silica gel impinger was weighed and recorded on the field data sheet. The nozzle, and all sample-exposed surfaces were washed with reagent grade acetone into a clean sample container. A brush was used to loosen any adhering particulate matter and subsequent washings were placed into the container. The filter was carefully removed from the fritted support and placed in a clean separate sample container. A sample of the acetone used in the washing was saved for a blank laboratory analysis.

## ***5.2. Particulate Analytical Procedures***

The filter and any loose particulate matter were transferred from the sample container to a clean, tared weighing dish. The filter was placed in a desiccator for at least 24 hours and then weighed to the nearest 0.1 milligram until a constant weight was obtained. The original weight of the filter was deducted, and the weight gain was recorded to the nearest 0.1 milligram.

The wash solution was transferred to a clean, tared beaker. The solution was evaporated to dryness, desiccated to a constant weight, and the weight gain was recorded to the nearest 0.1 milligram.

**APPENDIX A EQUATIONS AND FIELD DATA SHEETS**

## EQUATIONS

$$1. \quad P_s = P_{\text{bar}} + \frac{P_g}{13.6}$$

$$2. \quad P_m = P_{\text{bar}} + \frac{\overline{\Delta H}}{13.6}$$

$$3. \quad V_s = K_p C_p \sqrt{\Delta P} \sqrt{\frac{\overline{T_s}}{M_s P_s}}$$

$$4. \quad V_{m(\text{Std})} = K_1 V_m Y \left[ \frac{P_{\text{bar}} + \frac{\overline{\Delta H}}{13.6}}{\overline{T_m}} \right]$$

$$5. \quad V_{w(\text{Std})} = 0.04707 V_{1c}$$

$$6. \quad B_{ws} = \frac{V_{w(\text{Std})}}{V_{m(\text{Std})} + V_{w(\text{Std})}}$$

$$7. \quad M_d = 0.44 (\% \text{CO}_2) + 0.32 (\% \text{O}_2) + 0.28 (\% \text{N}_2 + \% \text{CO})$$

$$8. \quad M_s = M_d (1 - B_{ws}) + 18 (B_{ws})$$

$$9. \quad EA = \left[ \frac{(\% \text{O}_2 - 0.5 (\% \text{CO}))}{0.264 (\% \text{N}_2) - ((\% \text{O}_2) - 0.5 (\% \text{CO}))} \right] 100$$

$$10. \quad Q_a = (V_s) (A_s) (60)$$

$$11. \quad Q_s = Q_a (1 - B_{ws}) \frac{(528)}{\bar{T}_s} \frac{(P_s)}{29.92}$$

$$12. \quad E_H = \left( \frac{PMR}{H_l} \right)$$

$$13. \quad E = C_d F_{O_2} \left( \frac{20.9}{20.9 - \%O_2} \right)$$

$$14. \quad C_s = 0.0154 \frac{M_n}{V_{m(Std)}}$$

$$15. \quad C_{50} = \frac{21 C_s}{21 - [(1.5) (\%O_2) - 0.133 (N_2) - 0.75 (\%CO)]}$$

$$16. \quad C_{12} = \frac{C_s (12)}{\%CO_2}$$

$$17. \quad PMR = (C_s) (Q_s) \frac{(60)}{7000}$$

$$18. \quad V_n = \left[ (0.002669) (V_{1c}) + \frac{V_m Y}{T_m} \left( P_{bar} + \frac{\bar{\Delta H}}{13.6} \right) \right] \frac{\bar{T}_s}{P_s}$$

$$19. \quad I = \frac{100 V_n}{(60) \emptyset V_s A_n}$$

## NOMENCLATURE

- $A_n$  = Cross-sectional area of nozzle, ft<sup>2</sup>
- $A_s$  = Cross sectional area of stack, ft<sup>2</sup>
- $B_{ws}$  = Water vapor in the gas stream,  
proportion by volume (dimensionless)
- $C_p$  = Pitot tube coefficient (dimensionless) (0.84)
- $C_s$  = Particulate concentration, grains/SDCF
- $C_d$  = Particulate concentration, lbs/SDCF
- $C_{12}$  = Particulate concentration ( $C_s$  adjusted to 12% CO )  
grains/SDCF
- $C_{50}$  = Particulate concentration ( $C_s$  adjusted to 50% excess air)  
grains/SDCF
- EA = Excess air, %
- E = Emission in lb/mmBTU
- $E_H$  = Emission in lb/mmBTU, based on heat input
- $H_I$  = Total Heat Input, Million BTU per Hour (MMBTU/hr)
- I = Percent of isokinetic sampling
- $K_1$  = 17.64 °R/ inches Hg
- $K_p$  = Pitot tube constant,  
$$85.49 \text{ ft/sec} \left[ \frac{(\text{lb/lb-mole}) (\text{in. Hg})}{(^{\circ}\text{R}) (\text{inc. H}_2\text{O})} \right]^{\frac{1}{2}}$$
- $M_n$  = Total amount of particulate collected, mg
- $M_d$  = Molecular weight of stack gas; dry basis, lb/lb mole
- $M_s$  = Molecular weight of stack gas; wet basis, lb/lb mole
- $P_{bar}$  = Barometric pressure at the sampling site, in. Hg

## NOMENCLATURE (continued)

- $P_m$  = Meter pressure, in. Hg
- $P_s$  = Absolute stack pressure, in. Hg
- $P_g$  = Stack static pressure, in. H<sub>2</sub>O
- PMR** = Particulate mass rate, lb/Hr
- $Q_a$  = Volumetric flow rate ACFM
- $Q_s$  = Volumetric flow rate SDCFM
- $V_s$  = Average stack gas velocity, ft/sec
- $V_{lc}$  = Total volume of liquid collected in impingers & silica gel, ml
- $V_m$  = Volume of gas sample as measured by dry gas meter, ACF
- $V_{m(std)}$  = Volume of gas sample measured by dry gas meter,  
corrected to standard conditions, SDCF
- $V_{w(std)}$  = Volume of water vapor in gas sample, corrected to standard  
conditions, SCF
- $V_n$  = Volume collected at stack conditions through nozzle, ACF
- $Y$  = Dry gas meter calibration factor (dimensionless)
- $\Delta H$  = Average pressure difference of orifice, in. H<sub>2</sub>O
- $\Delta P$  = Velocity head of stack gas, in. H<sub>2</sub>O
- $\sqrt{\Delta P}$  = Average of square roots of the velocity pressure, in. H<sub>2</sub>O
- $\emptyset$  = Total sampling time, minutes
- $\%CO_2, \%O_2, N_2, \%CO$  - Number % by volume, dry basis, from gas analysis
- $F_{O_2}$  = Oxygen based F factor (9820 SDCF/mmBTU for bituminous coal)
- $T_s$  = Temperature of the stack, °R (° F + 460)



SANDERS ENGINEERING & ANALYTICAL SERVICES, Inc.

1568 Leroy Stevens Rd.  
Mobile, AL 36695

Office: (205) 633-4120  
FAX#: (205) 633-2285

FIELD DATA SHEET

COMPANY Gulf Power DATE 9-26-95 DGM# S-100  
 PLANT Crist OPERATOR JL ΔHa .25  
 UNIT 7 METHOD 17 PROBE N/A liner length 25'  
 cu. ft./min. 25'

RUN 1

NOZZLE CALIBRATION		FILTER NUMBER
PRE	POST	
.215	.215	1282
.218	.216	
.216	.216	
.216	.216	
AVERAGE	AVERAGE	

RUN 2

NOZZLE CALIBRATION		FILTER NUMBER
PRE	POST	
.190	.190	1278
.190	.190	
.190	.190	
.190	.190	
AVERAGE	AVERAGE	

RUN 3

NOZZLE CALIBRATION		FILTER NUMBER
PRE	POST	
.212	.212	1281
.213	.213	
.213	.213	
.213	.213	
AVERAGE	AVERAGE	

METER READING

120.457	FINAL
77.800	FINAL
42.657	INITIAL
	NET

METER READING

55.973	FINAL
21.300	FINAL
34.673	INITIAL
	NET

METER READING

102.000	FINAL
58.200	FINAL
43.800	INITIAL
	NET

LEAK CHECK

SYSTEM		PITOT	
Pre	Post	Pre	Post
✓	18	impact	impact
in. hg	in. hg	static	static
✓	.010	static	static
cm	cm		

LEAK CHECK

SYSTEM		PITOT	
Pre	Post	Pre	Post
✓	18	impact	impact
in. hg	in. hg	static	static
✓	.010	static	static
cm	cm		

LEAK CHECK

SYSTEM		PITOT	
Pre	Post	Pre	Post
✓	19	impact	impact
in. hg	in. hg	static	static
✓	.010	static	static
cm	cm		

VOLUME OF LIQUID WATER COLLECTED

IMP. 1	IMP. 2	IMP. 3	IMP. 4
168	100	0	1544.5
FINAL	FINAL	FINAL	FINAL
107	100	0	1535.0
INITIAL	INITIAL	INITIAL	INITIAL
68	0	0	9.5
NET	NET	NET	NET
TOTAL			77.5

VOLUME OF LIQUID WATER COLLECTED

IMP. 1	IMP. 2	IMP. 3	IMP. 4
160	100	0	1460.0
FINAL	FINAL	FINAL	FINAL
100	100	0	1455.0
INITIAL	INITIAL	INITIAL	INITIAL
60	0	0	5.0
NET	NET	NET	NET
TOTAL			65.0

VOLUME OF LIQUID WATER COLLECTED

IMP. 1	IMP. 2	IMP. 3	IMP. 4
180	100	0	1464.0
FINAL	FINAL	FINAL	FINAL
100	100	0	1444.0
INITIAL	INITIAL	INITIAL	INITIAL
80	0	0	20.0
NET	NET	NET	NET
TOTAL			100.0

GAS ANALYSIS

O <sub>2</sub> <u>4.9</u>	STATIC <u>1.60</u>
CO <sub>2</sub> <u>12.0</u>	BAROMETRIC <u>29.92</u>
CO	in. hg

GAS ANALYSIS

O <sub>2</sub> <u>4.9</u>	STATIC <u>1.6</u>
CO <sub>2</sub> <u>12.1</u>	BAROMETRIC <u>29.92</u>
CO	in. hg

GAS ANALYSIS

O <sub>2</sub> <u>4.7</u>	STATIC <u>1.6</u>
CO <sub>2</sub> <u>12.0</u>	BAROMETRIC <u>29.92</u>
CO	in. hg



SO 1159100

SO 1067304

Port #	Time	Gas Meter Vol. (cu. ft.)	Vel. Head ΔP in. H <sub>2</sub> O	Orifice Head ΔH in. H <sub>2</sub> O	Temperature (F)						Vac. in. H <sub>2</sub>
					Stack	Probe	Hot Box	Imp.	Gas Meter		
									In	Out	
1-1	9:09	72.500	2.60	5.377	350			66	81	80	14
2	11	79.800	2.40	3.18	350			-	81	80	14
3	13	82.400	2.1	4.1	323			✓	81	80	11
4	15	83.900	1.6	2.13	325			-	83	81	10
5	17	85.600	1.6	2.13	320			-	83	81	9
6	19	87.100	1.35	1.88	320			✓	83	81	9
2-1	9:23	88.600	2.00	2.79	355			✓	83	81	12
2	25	90.500	1.88	2.62	323			✓	83	81	12
3	27	92.100	1.90	2.65	325			✓	83	81	12
4	29	93.900	1.12	2.65	327			✓	83	80	9
5	31	95.200	1.15	1.60	316			✓	83	80	8
6	33	96.500	1.27	1.77	316			✓	83	83	8
3-1	9:35	97.700	1.50	2.08	331			✓	83	83	8
2	37	98.400	1.35	1.85	327			✓	83	83	9
3	39	101.300	1.08	1.50	327			✓	83	84	5
4	41	102.600	1.06	1.47	327			64	84	84	8
5	43	103.900	.83	1.15	320			✓	84	84	8
6	45	105.100	.70	.97	320			-	90	84	6
4-1	9:49	106.100	.63	.87	356			✓	90	84	6
2	51	107.300	.70	.98	327			✓	90	84	6
3	53	108.300	.96	1.33	325			✓	90	85	6
4	55	109.400	1.03	1.43	330			-	90	85	8
5	57	110.700	1.17	1.62	321			64	90	85	10
6	59	112.200	1.03	1.43	316			✓	90	85	10
5-1	10:02	113.400	.53	.74	355			✓	90	84	6
2	04	114.400	.74	1.03	330			✓	90	84	6
3	06	115.600	.93	1.30	323			✓	90	84	9
4	08	116.800	.80	1.14	330			✓	90	84	9
5	10	117.800	1.06	1.48	327			✓	90	84	10
6	12	119.300	1.03	1.43	320			✓	91	85	10
	10:14	120.450									
					328.4				84.8		

Check Indicates Temperatures Meet Required Limits.

1.1246

Company Earth Power Co

Date 9-21-91

Site C-58

Run # 1

Page

Of

1204  
1205

SW = 1,185, <sup>337</sup> ~~437~~

SD 1,086, 847

Port #	Time	Gas Meter Vol. (cu. ft.)	Vel. Head ΔP in. H <sub>2</sub> O	Orifice Head ΔH in. H <sub>2</sub> O	Temperature (F)						Vac. in. H <sub>g</sub>
					Stack	Probe	Hot Box	Imp.	Gas Meter		
									In	Out	
1-1	10:44	21.300	2.56	2.13	362			66	89	88	7
2	46	22.200	2.45	2.04	332			✓	89	88	7
3	48	24.300	4.00	3.30	332			✓	90	89	15
4	50	26.000	1.82	1.52	330			✓	90	89	12
5	52	28.000	1.73	1.44	320			✓	90	89	7
6	54	29.200	1.45	1.21	320			✓	90	89	7
2-1	10:56	30.300	1.95	1.62	361			✓	92	90	8
2	58	31.200	2.25	1.87	331			✓	92	90	8
3	11:00	32.200	2.10	1.75	330			✓	92	90	10
4	02	34.600	1.32	1.10	330			56	93	90	7
5	04	35.800	1.42	1.17	320			✓	93	91	7
6	06	36.900	1.32	1.10	320			✓	93	90	7
3-1	08	38.100	1.57	1.30	361			✓	94	90	7
2	10	39.300	1.42	1.18	334			✓	94	91	7
3	12	40.900	1.23	1.01	331			✓	94	90	7
4	14	42.100	.92	.76	333			✓	94	90	7
5	16	42.900	.96	.79	323			✓	94	90	6
6	18	43.800	.77	.64	320			✓	94	91	6
4-1	11:20	44.200	.75	.62	333			✓	94	90	5
2	22	45.700	.75	.61	330			✓	95	92	5
3	24	46.600	1.12	.93	330			✓	95	92	5
4	26	47.500	1.00	.83	334			✓	95	92	5
5	28	48.300	1.40	1.16	325			✓	95	92	5
6	30	49.500	1.03	.85	312			✓	95	93	7
5-1	11:32	50.800	.54	.45	361			✓	97	93	5
2	34	51.400	.69	.57	335			✓	97	97	5
3	36	52.200	.88	.73	330			✓	97	94	6
4	38	53.000	.75	.62	330			✓	97	94	6
5	40	54.000	1.02	.84	330			✓	97	94	6
6	42	55.000	.92	.76	320			✓	97	94	6
	44	55.973	.	.	320						
										92.3	

1.1522 1.16 332.7 Check Indicates Temperatures Meet Required Limits.

Company WISX 66th Power Date 9-26-95  
 Site CHS 7 Run # 2 Page      Of

SW = 1,219,001

SD 1,097,157

Port #	Time	Gas Meter Vol. (cu. ft.)	Vel. Head ΔP in. H <sub>2</sub> O	Orifice Head ΔH in. H <sub>2</sub> O	Temperature (F)					Vac. in. H <sub>2</sub>	
					Stack	Probe	Hot Box	Imp.	Gas Meter		
									In		Out
1-1	14:33	58.200	4.15	5.50	368			68	95	95	15
2	:35	60.200	2.75	3.64	334			66	95	95	15
3	:37	62.200	3.95	5.46	335			✓	95	95	15
4	:39	64.000	1.67	2.31	333			✓	95	95	15
5	:41	66.100	2.12	2.93	323			✓	95	95	15
6	:43	67.600	1.35	1.87	315			✓	95	95	10
2-1	13:46	69.200	2.10	2.91	315			64	95	95	10
2	:48	71.300	2.00	2.77	335			✓	95	95	10
3	:50	72.900	2.40	3.32	336			✓	96	95	10
4	:52	74.700	1.35	1.87	335			✓	98	95	12
5	:54	76.100	1.35	1.87	325			✓	98	95	12
6	:56	77.600	1.35	1.87	316			✓	98	95	10
3-1	13:59	79.200	1.42	1.96	366			68	98	95	10
2	14:01	80.700	1.56	2.16	339			✓	99	95	10
3	:03	82.100	1.12	1.55	337			✓	99	95	12
4	:05	83.800	1.00	1.38	336			✓	99	95	9
5	:07	85.100	.96	1.33	326			✓	99	95	9
6	:09	86.400	1.23	1.70	316			✓	99	95	9
4-1	14:12	87.600	.75	1.04	365			✓	99	95	8
2	:14	88.800	.87	1.20	339			✓	99	95	8
3	:16	89.900	1.02	1.41	335			✓	99	95	10
4	:18	91.300	1.12	1.55	335			✓	99	95	10
5	:20	92.400	1.23	1.70	328			✓	99	95	10
6	:22	94.000	1.32	1.82	315			✓	99	95	10
5-1	14:24	95.200	.54	.74	365			56	102	98	8
2	:26	96.200	.64	.89	338			✓	102	98	8
3	:28	97.200	.87	1.20	336			✓	102	98	8
4	:30	98.300	.67	.93	337			✓	102	98	8
5	:32	99.300	1.06	1.47	320			✓	102	98	8
6	:34	100.700	.88	1.22	320			✓	102	98	8
	14:36	102.000									

1.16192522 205 337.46 Check Indicates Temperatures Meet Required Limits. 96.93

Company Gulf Power Co Date 9-21-95

Site Crust > Run # 3 Page      Of

# LABORATORY ANALYSIS & CHAIN OF CUSTODY

COMPANY/PLANT: GPCO/Crist

UNIT #: 7 DATE OF TEST: 9-26-95 TYPE OF TEST:  M-5  M-17  OTHER \_\_\_\_\_

SAMPLE #	RELINQUISHED BY	RECEIVED BY	TIME	DATE	REASON FOR CHANGE
1282 : Wash	/	/	/	/	Analysis
1278 : Wash	/	/	/	/	
1281 : Wash	/	/	/	/	

UNIT # 7 ScotBlaw

RUN # <u>1</u>	FILTER # <u>1282</u>	BEAKER # <u>7</u>	WASH (ML) <u>35</u>
FINAL WEIGHT	<u>161.5 mg</u>	<u>69930.1 mg</u>	
INITIAL WEIGHT	<u>120.1 mg</u>	<u>69923.9 mg</u>	
DIFFERENCE	<u>41.4</u>	<u>6.2</u>	
CORRECTED TOTAL WEIGHT		<u>47.6</u>	
RUN # <u>2</u>	FILTER # <u>1278</u>	BEAKER # <u>8</u>	WASH (ML) <u>30</u>
FINAL WEIGHT	<u>151.7 mg</u>	<u>67106.0 mg</u>	
INITIAL WEIGHT	<u>123.8 mg</u>	<u>67003.2 mg</u>	
DIFFERENCE	<u>27.9</u>	<u>2.8</u>	
CORRECTED TOTAL WEIGHT		<u>30.7</u>	
RUN # <u>3</u>	FILTER # <u>1281</u>	BEAKER # <u>14</u>	WASH (ML) <u>20</u>
FINAL WEIGHT	<u>155.2 mg</u>	<u>65625.7 mg</u>	
INITIAL WEIGHT	<u>124.0 mg</u>	<u>65620.5 mg</u>	
DIFFERENCE	<u>31.2</u>	<u>5.2</u>	
CORRECTED TOTAL WEIGHT		<u>36.4</u>	
RUN # _____	FILTER # _____	BEAKER # _____	WASH (ML) _____
FINAL WEIGHT			
INITIAL WEIGHT			
DIFFERENCE			
CORRECTED TOTAL WEIGHT			

UNIT # \_\_\_\_\_

RUN # _____	FILTER # _____	BEAKER # _____	WASH (ML) _____
FINAL WEIGHT			
INITIAL WEIGHT			
DIFFERENCE			
CORRECTED TOTAL WEIGHT			
RUN # _____	FILTER # _____	BEAKER # _____	WASH (ML) _____
FINAL WEIGHT			
INITIAL WEIGHT			
DIFFERENCE			
CORRECTED TOTAL WEIGHT			
WASH SOLVENT BLANK (ML) _____		BEAKER # <u>10</u>	WASH (ML) <u>110</u>
FINAL WEIGHT		<u>63813.1 mg</u>	
INITIAL WEIGHT		<u>63813.1 mg</u>	
DIFFERENCE		<u>0.0</u>	
CORRECTION FACTOR (MG/ML)			

ALL WEIGHTS ARE IN MILLIGRAMS (MG)

**APPENDIX B SAMPLE CALCULATIONS**

**Input and Constants**

$$f := \frac{9820 \text{ ft}^3}{\text{mm btu}}$$

$$pg := 1.6 \text{ in. H}_2\text{O}$$

$$pbar := 29.92 \text{ in. Hg.}$$

$$\Delta h_{avg} := 1.8 \text{ in. H}_2\text{O}$$

$$y := 1.016$$

$$tm := 84.9 \text{ }^\circ\text{F}$$

$$o_2 := 4.9$$

$$co_2 := 12.$$
  

$$vm := 42.657 \text{ ft}^3$$

$$vlc := 77.5 \text{ ml}$$

$$\theta := 60 \text{ min}$$

$$nozdia := 0.216 \text{ in.}$$

$$ts := 328.6 \text{ }^\circ\text{F}$$
  

$$as := 375. \text{ ft}^2$$

$$mn := 47.6 \text{ mg}$$

$$\text{numberofpoints} := 30$$
  

$$\text{sqrt}A_p := 1.1246 \text{ in. H}_2\text{O}^{0.5}$$
  

$$kp := \frac{85.49 \text{ 1 ft 1 (} \frac{\text{lb in. Hg.}}{\text{lb-mole }^\circ\text{R in. H}_2\text{O}} \text{)}^{0.5}}{1 \text{ sec}}$$
  

$$cp := 0.84$$
  

$$k_1 := \frac{17.64 \text{ }^\circ\text{R}}{\text{in. Hg.}}$$

$$ts = \frac{(ts + 460 \text{ } ^\circ\text{F}) \text{ } ^\circ\text{R}}{\text{ } ^\circ\text{F}}$$

788.6 °R

$$tm = \frac{(tm + 460 \text{ } ^\circ\text{F}) \text{ } ^\circ\text{R}}{\text{ } ^\circ\text{F}}$$

544.9 °R

$$n2 = 100 - o2 - co2$$

83.1

$$an = \frac{\text{nozdia}^2 \cdot 3.1416}{4 \left( \frac{12 \text{ in.}^2}{\text{ft}} \right)}$$

0.00025447 ft<sup>2</sup>

**Calculations**

**Equation 1**

$$ps = pbar + \frac{pg}{\frac{13.6 \text{ in. H}_2\text{O}}{1 \text{ in. Hg.}}}$$

30.0376 in. Hg.

**Equation 2**

$$pm = pbar + \frac{\Delta havg}{\frac{13.6 \text{ in. H}_2\text{O}}{\text{in. Hg.}}}$$

30.0524 in. Hg.

**Equation 3**

$$k1 \text{ } \nu m \text{ } \gamma \left( pbar + \frac{\Delta havg}{\frac{13.6 \text{ in. H}_2\text{O}}{\text{in. Hg.}}} \right)$$

$$\nu mstd = \frac{\text{-----}}{tm}$$

42.1642 ft<sup>3</sup>

**Equation 4**

$$\nu wstd = \frac{0.04707 \text{ ft } \nu lc^3}{ml}$$

3.64793 ft<sup>3</sup>

**Equation 5**

$$bws = \frac{\nu wstd}{\nu mstd + \nu wstd}$$

0.0796279



**Equation 6**

$$md = \frac{(0.44 \text{ co}_2 + 0.32 \text{ o}_2 + 0.28 \text{ n}_2) \text{ lb}}{\text{lb-mole}}$$

$$\frac{30.116 \text{ lb}}{\text{lb-mole}}$$

**Equation 7**

$$ms = md (1 - bws) + \frac{bws \text{ 18 lb}}{\text{lb-mole}}$$

$$\frac{29.1512 \text{ lb}}{\text{lb-mole}}$$

**Equation 8**

$$vs = kp \text{ cp } \sqrt{\Delta p} \left( \frac{ts}{ms \text{ ps}} \right)^{0.5}$$

$$\frac{76.6407 \text{ ft}}{\text{sec}}$$

**Equation 9**

$$qa = \frac{vs \text{ as } 60 \text{ sec}}{\text{min}}$$

$$\frac{1.72442 \text{ } 10^6 \text{ } 10^3 \text{ ft}}{\text{min}}$$

**Equation 10**

$$qs = \frac{qa (1 - bws) 528 \text{ } ^\circ\text{R ps}}{ts \text{ 29.92 in. Hg.}}$$

$$\frac{1.06681 \text{ } 10^6 \text{ } 10^3 \text{ ft}}{\text{min}}$$

**Equation 11**

$$cs = \frac{0.0154 \text{ gr mn}}{mg \text{ vmstd}}$$

$$\frac{0.0173853 \text{ gr}}{\text{ft}^3}$$

**Equation 12**

$$pmr = \frac{cs \text{ qs } 60 \text{ min}}{\text{hour}}$$

$$\frac{7000 \text{ gr}}{\text{lb}}$$

$$158.973 \text{ lb}$$

$$\text{hour}$$

**Equation 13**

$$e = \frac{cs \text{ f } 20.9 \text{ } 1 \text{ lb}}{(20.9 - o_2) 7000 \text{ gr}}$$

$$0.0318583 \text{ lb}$$

$$\text{mm btu}$$

**Equation 14**

$$vn = \frac{0.002669 \text{ in. Hg. ft}^3 \text{ vlc} + \text{vm y pm}}{\text{ml } ^\circ\text{R} \text{ tm}}$$

$$68.1838 \text{ ft}^3$$

$$\text{ps}$$

Equation 15

$$i = \frac{100 \% \text{ vn}}{60 \text{ sec theta vs an}} \text{ min}$$

97.1143 %

Equation 16

$$hi = \frac{\text{pmr}}{e} \text{ hour}$$

4990. mm btu

**APPENDIX C QUALITY CONTROL**

**INITIAL  
METER CALIBRATION FORM - DGM**

DATE:	06-16-95	Box No.	S-100			
Ref. DGM Ser. #	1044456	Calibrated By	JACK COVINGTON			
RUN #		1	2	3	4	5
DELTA H (DGM)		0.50	1.00	1.50	2.00	2.50
Y (Ref. DGM)		0.995	0.995	0.995	0.995	0.995
Reference DGM						
Gas Vol. Initial		9.300	43.750	56.850	62.600	90.800
Gas Vol. Final		42.950	56.300	62.000	90.200	100.000
Meter Box DGM						
Gas Vol. Initial		5.140	39.370	52.360	58.000	85.750
Gas Vol. Final		38.580	51.800	57.400	85.720	94.785
Reference DGM						
Temp.		Avg.	Avg.	Avg.	Avg.	Avg.
Deg F Initial		79	78	76	76	76
Deg F Final		78	77	76	76	77
Meter Box DGM						
Temp. Initial In		80	82	84	85	87
Temp. Initial Out		80	79	79	79	80
Temp. Final In		82	84	85	87	87
Temp. Final Out		79	79	79	80	80
P Bar IN. Hg		30.11	30.11	30.11	30.11	30.11
Time (sec.)		4927	1308	448	2095	628
Meter Calibration						
Factor (Y)		1.008	1.014	1.029	1.003	1.025
Qm (C.F.M.)		0.404	0.569	0.684	0.784	0.871
Km (Std Pressure)		0.728	0.724	0.710	0.705	0.700
DELTA Ha		1.69	1.70	1.77	1.80	1.82
Average Y (Meter Calibration Factor)					1.016	
Average Km (Standard Pressure)					0.713	
Average DELTA Ha of Orifice					1.753	

$Y = \leq .03$   
 Max & Min  $\leq .02$  from Avg  
 Final Avg within 5% of Initial Avg  
 $\Delta H_a = \text{Max \& Min} \leq .2$  from Avg

### MAGEHELIC CALIBRATION

BOX	460	2879	S-100	C-133	175	S-318	S-101	S-110
SER. NO.	91127W W137		91126AM 91	9126A M91	R90125 MR6	R74D	R22D	R20208 A617
RANGE	0-2	0-2	0-2	0-2	0-2	0-5	0-2	0-2
REFERENCE READING	FIELD DEVICE READING							
0.000	0.00		0.02	0.00	0.00	0.00	0.00	0.00
0.050								
0.150								
0.200								
0.250								
0.450								
0.50	0.50	0.51	0.50	0.50	0.50	0.49	0.50	0.50
1.00	1.00	1.02	1.00	0.99	1.00	1.01	1.00	1.00
1.30								
1.80	1.77	1.82	1.78	1.78	1.80	1.80	1.80	1.80
2.50								
4.50								
5.0								
9.0								
13.0								
22.0								

SIGNATURE: Edward L. Harris

DATE: 6/23/95

FINAL  
METER CALIBRATION FORM - DGM

DATE:	09-29-95	Box No.	S-100
Ref. DGM Ser. #	1044456	Calibrated By	JACK COVINGTON
RUN #	1	2	3
DELTA H (DGM)	1.5	1.5	1.5
Y (Ref. DGM)	0.985	0.985	0.985
Reference DGM			
Gas Vol. Initial	25.400	32.500	40.200
Gas Vol. Final	32.500	40.200	46.600
Meter Box DGM			
Gas Vol. Initial	69.070	75.966	83.450
Gas Vol. Final	75.966	83.450	89.650
Reference DGM			
Temp.	Avg.	Avg.	Avg.
Deg F Initial	76	76	76
Deg F Final	77	77	78
Meter Box DGM			
Temp. Initial In	74	74	74
Temp. Initial Out	73	73	73
Temp. Final In	76	79	81
Temp. Final Out	76	79	79
P Bar IN. Hg	29.98	29.98	29.98
Time (sec.)	615	667	556
Meter Calibration			
Factor (Y)	1.007	1.009	1.013
Qm (C.F.M.)	0.673	0.673	0.670
Km (Std Pressure)	0.702	0.701	0.698
DELTA Ha	1.84	1.83	1.84
Average Y (Meter Calibration Factor)			1.010
Initial Y (Meter Calibration Factor)			1.016
Percent Error			0.59%
Average Km (Standard Pressure)			0.700
Average DELTA Ha of Orifice			1.84

MAGEHELIC CALIBRATION  
BOX #1

SER. NO.	10720- AB68	R1061- 6AG48	R5031- SEB76	R1062- 9JA82	R1051- 3MR42	R90124 RI119
RANGE	0-0.25	0-0.50	0-2	0-5	0-10	0-25
REFERENCE READING	FIELD DEVICE READING					
0.000	0.000	0.000	0.000	0.000	0.000	0.000
0.050	0.050					
0.150	0.150	0.140				
0.200	0.200					
0.250		0.250				
0.450		0.450				
0.50			0.51			
1.00			1.00			
1.30				1.30		
1.80			1.80			
2.50				2.49	2.5	
4.50				4.47		
5.0					5.0	5.0
9.0					9.1	
13.0						13.1
22.0						22.0

SIGNATURE:

DATE:


6/23/94  
Hain



MAGEHELIC CALIBRATION  
BOX #2

SER. NO.	10819-DR2	R1090-2AG18	R50315-EB93	R1062-9TA87	30830-AM79	R1072-2MC5
RANGE	0-0.25	0-0.50	0-2	0-5	0-10	0-25
REFERENCE READING	FIELD DEVICE READING					
0.000	-0.008	0.000	0.00	0.00	0.0	0.0
0.050	0.055					
0.150	0.160	0.145				
0.200	0.210					
0.250		0.250				
0.450		0.450				
0.50			0.50			
1.00			1.00			
1.30				1.26		
1.80			1.80			
2.50				2.52	2.4	
4.50				4.55		
5.0					4.9	5.0
9.0					9.0	
13.0						12.9
22.0						21.8

SIGNATURE:




DATE:

6-23-12

MAGEHELIC CALIBRATION  
BOX #3

SER. NO.	R10908AG71	R0112642	R10608CF20
	MRR1		CF20
RANGE	0-0.50	0-2.0	0-10
REFERENCE READING	FIELD DEVICE READING		
0.000	0.00	0.00	0.0
0.050			
0.150	0.15		
0.200			
0.250	0.245		
0.450	0.450		
0.50		0.50	
1.00		0.99	
1.50			
1.80		1.79	1.9
2.50			
4.50			
5.0			5.0
9.0			9.0
13.0			
22.0			

SIGNATURE:




DATE:

10/2/02

MAGEHELIC CALIBRATION  
BOX #4

SER. NO.	R22D	R90051	R90101
RANGE	0-0.50	0-5	0-25
REFERENCE READING	FIELD DEVICE READING		
0.000	-0.010	0.00	0.0
0.050			
0.150	0.151		
0.200			
0.250	0.252		
0.450	0.458		
0.50			
1.00			
1.30		1.31	
1.80			
2.50		2.55	
4.50		4.58	
5.0			5.0
9.0			
13.0			13.2
22.0			21.9

SIGNATURE:



DATE:

11-20-81

**TEMPERATURE CALIBRATIONS - DEGREES FAHRENHEIT**

REFERENCE DEVICE READING*	0 DEG. F	210 DEG.	420 DEG.	630 DEG.	840 DEG.	1050 DEG.	1260 DEG.	1470 DEG.	1680 DEG.	1900 DEG.
2879	0	211	421	630	840	1050	1260	1470	1680	1900
METER BOX #1 C-133 11580	0	210	419	629	840	1052	1267	1479	1687	1893
METER BOX #2 C-175 15962	1	212	417	633	839	1052	1262	1471	1683	1904
METER BOX #4 D-460 15751	0	209	420	631	838	1047	1265	1476	1683	1893
METER BOX #5 S-100 15751	0	208	416	626	841	1059	1276	1489	1696	1905
METER BOX #6 S-101 15751	0	210	420	627	838	1051	1263	1473	1679	1899
PORTABLE THERMOCOUPLE # 1 (Yellow) T105998	1	209	416	625	839	1055	1270	1480	1684	1890
PORTABLE THERMOCOUPLE # 2 (Blue)	1	209	419	625	838	1051	1265	1471	1686	1900
METER BOX #7 S-110 15751	0	212	421	630	842	1053	1264	1477	1683	1905
PINK T140293	0	209	416	630	840	1056	1271	1482	1686	1893

DATE: 6-20-95


SIGNATURE: *Edward L. Harris*

\* Reference Device is an Omega Engineering CL505-A calibrated reference thermocouple-potentiometer system.



**SANDERS ENGINEERING &  
ANALYTICAL SERVICES, Inc.**


1668 Leroy Stevens Rd. Office: (205) 833-4120  
Mobile, AL 36605 FAX#: (205) 833-2285




**Note:**

$$1.05 D_i \leq 1.50 D_i$$

$$P_A = P_B$$



OR




**Proper thermocouple placement to prevent interference.**

The Pilot used was within the following geometric specifications:

$D_i$  between 0.48 and 0.95 cm (3/16 and 3/8 in.)

$$C_p = 0.84$$




**Minimum pilot-sample probe separation needed to prevent interference**




**SANDERS ENGINEERING &  
ANALYTICAL SERVICES, Inc.**

1688 Leroy Stevens Rd. Office: (205) 633-4120  
Mobile, AL 36606 FAX: (205) 633-2286

Proper pilot tube-sampling nozzle configuration to prevent aero-dynamic interference; bottomhook type nozzle; centers of nozzle and pilot opening aligned;  $D_1$  between 0.48 and 0.85 cm (3/16 and 3/8 in.)



Bottom view showing minimum pilot/nozzle separation



Side view; to prevent pilot tube from interfering with the gas flow streamlines approaching the nozzle, the impact pressure opening plane of the pilot tube shall be even with or above the nozzle entry plane.







Best Available Copy



# SANDERS ENGINEERING & ANALYTICAL SERVICES, Inc.

1568 Leroy Stevens Rd. Office: (205) 833-4120  
Mobile, AL 36695 FAX#: (205) 833-2285

Types of face-opening misalignment that can result from field use or improper construction of type 'S' pilot tubes. These will not affect the baseline value of  $C_p(\theta)$  so long as  $\alpha_1$  and  $\alpha_2 \leq 10^\circ$ ,  $\theta_1$  and  $\theta_2 \leq 5^\circ$ , and  $d \leq 0.32$  cm (1/8 in.)



**APPENDIX D OPERATIONAL DATA**



**CRIST ELECTRIC GENERATING PLANT  
PARTICULATE COMPLIANCE TEST CHRONOLOGY  
UNIT 7  
SOOTBLOWING CONDITIONS  
SEPTEMBER 26,1995**

RUN #1	START	9:09 a.m.	No problems noted at beginning of run.
	STOP	10:14 a.m.	No problems noted at end of run.
RUN #2	START	10:44 a.m.	No problems noted at the beginning of run.
	STOP	11:44 a.m.	No problems noted at the end of the run.
RUN #3	START	13:33 p.m.	No problems noted at the beginning of run.
	STOP	14:36 p.m.	No problems noted at the end of run.

CRIST ELECTRIC GENERATING PLANT  
 PARTICULATE COMPLIANCE TEST  
 SIX - MINUTE OPACITY AVERAGES  
 UNIT #7  
 SOOTBLOWING CONDITIONS  
 SEPTEMBER 26, 1995

TIME OF 6 MIN. AVERAGE	OPACITY (%)
<b>RUN #1</b>	<b>RUN #1</b>
8:07 - 8:12	8.6
8:13 - 8:18	9.1
8:19 - 8:24	8.8
8:25 - 8:30	8.2
8:31 - 8:36	9
8:37 - 8:42	8.2
8:43 - 8:48	9.2
8:49 - 8:54	8.3
8:55 - 9:00	8.1
9:01 - 9:06	9.5
9:07 - 9:12	8.6
9:13 - 9:18	9.2
<b>RUN #2</b>	<b>RUN #2</b>
9:43 - 9:48	9.1
9:49 - 9:54	8.5
9:55 - 10:00	8.6
10:01 - 10:06	7.7
10:07 - 10:12	8.9
10:13 - 10:18	8.3
10:19 - 10:24	8
10:25 - 10:30	7.6
10:31 - 10:36	7.9
10:37 - 10:42	7.9
10:43 - 10:48	7.6
<b>RUN #3</b>	<b>RUN #3</b>
12:31 - 12:36	7.8
12:37 - 12:42	8.3
12:43 - 12:48	7.7
12:49 - 12:54	7.8
12:55 - 13:00	7.3
13:01 - 13:06	9.2
13:07 - 13:12	8.6
13:13 - 13:18	8.5
13:19 - 13:24	8.8
13:25 - 13:30	8.5
13:31 - 13:36	8.6

Particulate Compliance Test [CRIST UNIT 7]

Notes: STAT 909  
CEMS Time 909  
RUN #1  
 9-26-95  
 Sootblowing  
STOP 1014  
CEMS Time 914

@ Start: Coal scale Readings ✓ ✓ ✓  
 PRECIP READINGS ✓ ✓ ✓  
 Coal sample ✓ ✓ ✓  
 State called ✓

@ END: Coal scale Readings ✓  
 PRECIP READINGS ✓ ✓  
 Coal sample ✓ ✓

Call Jerry Pennington in Lab

→ FLY ASH SAMPLE ✓ ✓ ✓  
Comments:

9-26-95 RUN 2: START 10:44  
 Sootblowing CEMS Time 9:44  
 STOP 11:44  
 CEMS Time 10:44

9-26-95 Run 3 START 13:33  
 Sootblowing CEMS Time 12:33  
 STOP 14:36  
 CEMS Time 13:36

RUN # 1  
TYPE Start  
LOAD 645

DATA SHEET  
PASS \_\_\_\_\_ FAIL \_\_\_\_\_  
P.E.R. \_\_\_\_\_

DATE 9-2-85  
START TIME 11:19  
STOP TIME 10:14  
WEATHER cloudy  
AMBIENT TEMP \_\_\_\_\_

**✓ GAS TEMPERATURES (DEG. F)**

*Unit 6  
was off  
during test*

*#7 duct work  
upstream of test  
parts has a hole  
in it.*

PT.1	7A SAPH INLET AIR	238
PT.2	7B SAPH OUTLET AIR	238
PT.3	7B SAPH INLET AIR	238
PT.4	7B SAPH OUTLET AIR	238
PT.5	LH ECONO OUT GAS	238
PT.6	RH ECONO OUT GAS	238
PT.7	7A SAPH OUT GAS	238
PT.8	7B SAPH OUT GAS	332
PT.17	7A PAH INLET AIR	238
PT.18	7A PAH OUTLET AIR	332
PT.19	7B PAH INLET AIR	238
PT.20	7B PAH OUTLET AIR	332
PT.21	7A PAH INLET GAS	238
PT.22	7A PAH OUTLET GAS	238
PT.23	7B PAH INLET GAS	642
	7B PAH OUTLET GAS	332

**FAN AMPS**

7A F.D. FAN	110
7B F.D. FAN	110
7A I.D. FAN	370
7B I.D. FAN	370
7C I.D. FAN	370
7D I.D. FAN	340
7A P.A. FAN	150
7B P.A. FAN	175

**DAMPER POSITIONS (%)**

7A FDF INLET VANE	65
7B FDF INLET VANE	70
7A IDF INLET VANE	50
7B IDF INLET VANE	50
7C IDF INLET VANE	50
7D IDF INLET VANE	50
7A PAF INLET VANE	70
7B PAF INLET VANE	70
7A PAH GAS DAMPER	70
7B PAH GAS DAMPER	70
SH/RH DAMPERS	70/50
SAH STEAM COILS	70
PAH STEAM COILS	70
CONDENSER VAC HP	2600
CONDENSER VAC LP	2600
COND INLET H2O	7/100
COND OUTLET H2O	7/100
THROTTLE PSI	2400
SUPERHEAT TEMP	1700
REHEAT TEMP	230

7A FD DISCHARGE	238	(IN. OF H2O)
7B FD DISCHARGE	332	
FURNACE GAS	238	
ECON INLET	238	
ID DUCT SUCTION	17	
ECON OUTLET	238	
7A IDF SUCTION	4	
7B IDF SUCTION	105	
7C IDF SUCTION	135	
7D IDF SUCTION	18	
7A SAH GAS DIFF	77	
7B SAH GAS DIFF	72	
7A PAF DISCHARGE	238	
7B PAF DISCHARGE	238	
7A PAH GAS DIFF	12	
7B GAS DIFF	12	

MAIN STEAM FLOW 3.2  
 WATER FLOW 3.16  
 CONDENSATE FLOW 3.1

OPACITY 6 MIN AVG 15  
 OPACITY A INSTANT 15  
 OPACITY B INSTANT 14  
 7A O2 2.5  
 7B O2 2.5  
 STACK O2 2  
 SO2 1

PULVERIZER READINGS

	MILL AMPS	COAL FLOW	P.A. FLOW	MILL DIFF	MILL TEMP		
7A	50		105	8	150	57897	59521
7B	50	68	105	10	150	959083	959083
7C	50		105	9	150		
7D	50	72	105	10	150		
7E	50	70	105	7	162		112000
7F	50	70	142	8	150		

PULVERIZER DAMPER POSITIONS (%)

	HOT AIR	P.A. FLOW
7A		
7B		
7C		
7D		
7E		
7F		

AIR REGISTERS

	POSITIONER PERCENT
7A	54, 31, 33, 40
7B	50, 30, 30, 30
7C	45, 30, 30, 35
7D	45, 30, 30, 35
7E	44, 30, 30, 40
7F	55, 31, 31, 48

COMMENTS

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

CRIST ELECTRIC GENERATING PLANT  
UNIT 7 COMPLIANCE TEST  
PRECIPITATOR DATA SHEET

DATE \_\_\_\_\_  
MW LOAD \_\_\_\_\_  
WEATHER \_\_\_\_\_

RUN # 1  
START TIME 9:09  
STOP TIME 10:14

CABINET	START/STOP PRIMARY AMPS	START/STOP PRIMARY VOLTS	START/STOP SECONDARY AMPS	
1A	30			
1B	60			
1C	70			
1D	70	200	200	
1E	70			
1F	70			
1G	5			
1H	13			
1J	70	700	1.1	
2A	55	700	.41	
2B	34	300	.35	
2C	92	700	.72	
2D	63	700	.70	
2E	70	700	.74	
2F	70	700	.70	
2G	77	700	.70	
2H	70	700	.70	
2J	70	700	.85	

OPACITY START	
6 MIN AVG	8.5
7A INST.	
7B INST.	
SO2	

OPACITY STOP	
6 MIN AVG	9.6
7A INST.	14
7B INST.	14
SO2	1.5

COMMENTS \_\_\_\_\_

	START	STOP
PT. 7. 7A SAH OUTLET GAS TEMPERATURE	330	331
PT. 8. 7B SAH OUTLET GAS TEMPERATURE	312	315
PT. 22.7A PAH OUTLET GAS TEMPERATURE	330	340
PT. 24 7B PAH OUTLET GAS TEMPERATURE	332	336

T/R CONTROL PRECIPITATOR A

T/R	COMM LINK	T/R RATED KVA	T/R ACTUAL KVA	% MAX CURRENT		PRIMARY		SECONDARY	SPARKS per MINUTE	POR
				SET	OBS	VOLT	AMPS	MILLIAMPS		
7A-A	ON	90	90	100	13	357	30	186	18	OFF
7A-B	ON	90	90	100	19	365	47	270	30	OFF
7A-C	ON	90	90	100	33	352	61	466	33	OFF
7A-D	ON	90	90	100	56	394	90	793	3	OFF
7A-E	ON	90	90	100	40	327	85	560	6	OFF
7A-F	ON	90	90	100	42	361	74	597	0	OFF
7A-G	ON	90	90	100	40	348	73	560	0	OFF
7A-H	ON	90	90	100	50	369	84	700	9	OFF
7A-J	ON	90	90	100	73	457	104	1026	15	OFF

10:24:45 25-Sep-95

10:14

Run #1

STOP 10:14

T/R CONTROL PRECIPITATOR B

T/R	COMM LINK	T/R RATED KVA	T/R ACTUAL KVA	% MAX CURRENT		PRIMARY		SECONDARY	SPARKS per MINUTE	POR
				SET	OBS	VOLT	AMPS	MILLIAMPS		
7B-A	ON	90	90	100	23	411	50	326	24	OFF
7B-B	ON	90	90	100	38	365	76	532	0	OFF
7B-C	ON	90	90	100	57	382	86	802	9	OFF
7B-D	ON	90	90	100	76	361	130	1064	0	OFF
7B-E	ON	90	90	100	36	323	60	513	6	OFF
7B-F	ON	90	90	100	74	415	117	1045	3	OFF
7B-G	ON	90	90	100	54	336	94	765	0	OFF
7B-H	ON	90	90	100	62	348	100	877	0	OFF
7B-J	ON	90	90	100	68	378	96	952	0	OFF

10:25:09 25-Sep-95

10:14

Run# 1

STOP 10:14



WGR # 2  
TYPE ...  
LOAD 145

DATA SHEET  
PASS      FAIL       
P.E.R.     

DATE 9/26/95  
START TIME 10:00  
STOP TIME 11:00  
WEATHER clear  
AMBIENT TEMP     

/GAS TEMPERATURES (DEG. F)

PT.1	7A SAPH INLET AIR	<u>160</u>
PT.2	7B SAPH OUTLET AIR	<u>175</u>
PT.3	7B SAPH INLET AIR	<u>    </u>
PT.4	7B SAPH OUTLET AIR	<u>    </u>
PT.5	LH ECONO OUT GAS	<u>    </u>
PT.6	RH ECONO OUT GAS	<u>    </u>
PT.7	7A SAPH OUT GAS	<u>330</u>
PT.8	7B SAPH OUT GAS	<u>    </u>
PT.17	7A PAH INLET AIR	<u>132</u>
PT.18	7A PAH OUTLET AIR	<u>342</u>
PT.19	7B PAH INLET AIR	<u>134</u>
PT.20	7B PAH OUTLET AIR	<u>324</u>
PT.21	7A PAH INLET GAS	<u>203</u>
PT.22	7A PAH OUTLET GAS	<u>371</u>
PT.23	7B PAH INLET GAS	<u>357</u>
PT.24	7B PAH OUTLET GAS	<u>339</u>

Unit 6 was  
off line during  
test, fan off  
  
#7 ductwork  
upstream of test  
ports was a dble  
in

FAN AMPS

7A F.D. FAN	<u>180</u>
7B F.D. FAN	<u>170</u>
7A I.D. FAN	<u>    </u>
7B I.D. FAN	<u>    </u>
7C I.D. FAN	<u>365</u>
7D I.D. FAN	<u>    </u>
7A P.A. FAN	<u>172</u>
7B P.A. FAN	<u>175</u>

7A FD DISCHARGE	<u>22</u>	(IN. OF H2O)
7B FD DISCHARGE	<u>22</u>	
FURNACE GAS	<u>75</u>	
ECON INLET	<u>32</u>	
ID DUCT SUCTION	<u>17</u>	
ECON OUTLET	<u>6</u>	
7A IDF SUCTION	<u>18</u>	
7B IDF SUCTION	<u>18.5</u>	
7C IDF SUCTION	<u>18</u>	
7D IDF SUCTION	<u>18</u>	
7A SAH GAS DIFF	<u>27</u>	
7B SAH GAS DIFF	<u>28</u>	
7A PAF DISCHARGE	<u>73</u>	
7B PAF DISCHARGE	<u>70</u>	
7A PAH GAS DIFF	<u>12</u>	
7B PAH GAS DIFF	<u>11</u>	

DAMPER POSITIONS (%)

7A FDF INLET VANE	<u>65</u>
7B FDF INLET VANE	<u>70</u>
7A IDF INLET VANE	<u>50</u>
7B IDF INLET VANE	<u>54</u>
7C IDF INLET VANE	<u>50</u>
7D IDF INLET VANE	<u>50</u>
7A PAF INLET VANE	<u>72</u>
7B PAF INLET VANE	<u>70</u>
7A PAH GAS DAMPER	<u>40</u>
7B PAH GAS DAMPER	<u>50</u>
SH/RH DAMPERS	<u>60/40</u>
SAH STEAM COILS	<u>5</u>
PAH STEAM COILS	<u>5</u>
CONDENSER VAC HP	<u>2570</u>
CONDENSER VAC LP	<u>2570</u>
COND INLET H2O	<u>90/90</u>
COND OUTLET H2O	<u>123/123</u>
THROTTLE PSI	<u>2400</u>
SUPERHEAT TEMP	<u>1000</u>
REHEAT TEMP	<u>1000</u>

MAIN STEAM FLOW 4.0  
 FLOW 3.7  
 WATER FLOW 1.0  
 CONDENSATE FLOW 2.1

OPACITY 6 MIN AVG 11  
 OPACITY A INSTANT 10  
 OPACITY B INSTANT 14  
 7A O2 20.5  
 7B O2 20.5  
 STACK O2 5  
 SO2 1.4

PULVERIZER READINGS

	MILL AMPS	COAL FLOW	P.A. FLOW	MILL DIFF	MILL TEMP	Coal Scal es	
7A	50	70	105	7	153	531200	
7B	50	-	100	1	153	256280	
7C	50	20	3	2	153	999315	
7D	50	2	100	1	160	148530	
7E	50	-	5		170	113000	
7F	50	-	-	6	170	207006	508750

PULVERIZER DAMPER POSITIONS (%)

	HOT AIR	P.A. FLOW
7A	100	65
7B	100	50
7C	100	45
7D	100	75
7E	100	65
7F	100	70

AIR REGISTERS

	POSITIONER PERCENT			
7A	54	31	33	40
7B	56	31	30	50
7C	45	30	30	55
7D	50	30	31	45
7E	46	30	30	46
7F	55	31	31	45

COMMENTS

---



---



---



---



---

T/R CONTROL PRECIPITATOR A

T/R	COMM LINK	T/R RATED KVA	T/R ACTUAL KVA	% MAX CURRENT		PRIMARY		SECONDARY	SPARKS per MINUTE	POR
				SET	OBS	VOLT	AMPS	MILLIAMPS		
7A-A	ON	90	90	100	8	323	24	121	6	OFF
7A-B	ON	90	90	100	13	306	34	186	48	OFF
7A-C	ON	90	90	100	32	394	57	448	27	OFF
7A-D	ON	90	90	100	40	365	69	560	3	OFF
7A-E	ON	90	90	100	39	331	35	550	3	OFF
7A-F	ON	90	90	100	42	369	75	597	0	OFF
7A-G	ON	90	90	100	40	352	73	560	3	OFF
7A-H	ON	90	90	100	50	373	83	700	12	OFF
7A-J	ON	90	90	100	72	457	104	1017	18	OFF

10:56:13 25-Sep-95

10:46

Run # 2

START 10:44

T/R CONTROL PRECIPITATOR B

T/R	COMM LINK	T/R RATED KVA	T/R ACTUAL KVA	% MAX CURRENT		PRIMARY		SECONDARY	SPARKS	POR
				SET	OBS	VOLT	AMPS	MILLIAMPS	per MINUTE	
7B-A	ON	90	90	100	26	428	54	364	18	OFF
7B-B	ON	90	90	100	22	319	52	308	42	OFF
7B-C	ON	90	90	100	50	378	79	709	6	OFF
7B-D	ON	90	90	100	76	363	131	1064	0	OFF
7B-E	ON	90	90	100	36	327	59	504	39	OFF
7B-F	ON	90	90	100	58	386	97	821	3	OFF
7B-G	ON	90	90	100	54	340	94	765	0	OFF
7B-H	ON	90	90	100	62	352	101	877	0	OFF
7B-J	ON	90	90	100	68	382	96	952	0	OFF

10:56:32 25-Sep-95

10.46

Run # 2

STA. - 10.44

T/R CONTROL PRECIPITATOR A

T/R	COMM LINK	T/R RATED KVA	T/R ACTUAL KVA	% MAX CURRENT		PRIMARY		SECONDARY	SPARKS per MINUTE	POR
				SET	OBS	VOLT	AMPS	MILLIAMPS		
7A-A	ON	90	90	100	7	315	20	102	18	OFF
7A-B	ON	90	90	100	16	365	43	233	24	OFF
7A-C	ON	90	90	100	26	361	51	373	45	OFF
7A-D	ON	90	90	100	30	340	57	429	30	OFF
7A-E	ON	90	90	100	40	336	86	560	12	OFF
7A-E	ON	90	90	100	43	373	75	606	48	OFF
7A-G	ON	90	90	100	40	357	74	569	0	OFF
7A-H	ON	90	90	100	49	378	84	690	21	OFF
7A-J	ON	90	90	100	69	457	102	970	21	OFF

11:57:46 25-Sep-95

11:47

Run # 2

STOP 11:44

T/R CONTROL PRECIPITATOR B

T/R	COMM LINK	T/R RATED KVA	T/R ACTUAL KVA	% MAX CURRENT		PRIMARY		SECONDARY	SPARKS per MINUTE	POR
				SET	OBS	VOLT	AMPS	MILLIAMPS		
7B-A	ON	90	90	100	24	424	52	336	9	OFF
7B-B	ON	90	90	100	30	348	62	420	48	OFF
7B-C	ON	90	90	100	49	369	77	690	30	OFF
7B-D	ON	90	90	100	76	369	130	1064	12	OFF
7B-E	ON	90	90	100	36	331	60	513	15	OFF
7B-F	ON	90	90	100	71	415	113	998	0	OFF
7B-G	ON	90	90	100	54	340	95	765	0	OFF
7B-H	ON	90	90	100	63	357	101	886	3	OFF
7B-J	ON	90	90	100	68	382	96	961	0	OFF

11:58:06 25-Sep-95

11:47

Run # 2  
STOP 11:44

RUN # 3  
 TYPE Test  
 LOAD 495

DATA SHEET  
 PASS      FAIL       
 P.E.R.     

DATE 5/15  
 START TIME 1333  
 STOP TIME 1436  
 WEATHER Clear  
 AMBIENT TEMP     

/GAS TEMPERATURES (DEG. F)	
PT.1	7A SAPH INLET AIR <u>118</u>
PT.2	7B SAPH OUTLET AIR <u>717</u>
PT.3	7B SAPH INLET AIR <u>112</u>
PT.4	7B SAPH OUTLET AIR <u>~11</u>
PT.5	LH ECONO OUT GAS <u>    </u>
PT.6	RH ECONO OUT GAS <u>    </u>
PT.7	7A SAPH OUT GAS <u>387</u>
PT.8	7B SAPH OUT GAS <u>379</u>
PT.17	7A PAH INLET AIR <u>158</u>
PT.18	7A PAH OUTLET AIR <u>389</u>
PT.19	7B PAH INLET AIR <u>170</u>
PT.20	7B PAH OUTLET AIR <u>382</u>
PT.21	7A PAH INLET GAS <u>    </u>
PT.22	7A PAH OUTLET GAS <u>    </u>
PT.23	7B PAH INLET GAS <u>735</u>
PT.24	7B PAH OUTLET GAS <u>307</u>

*Unit 2 was off line during test. Fans off by shutdown upstream of test ports has a hole in it.*

FAN AMPS	
7A F.D. FAN	<u>410</u>
7B F.D. FAN	<u>410</u>
7A I.D. FAN	<u>    </u>
7B I.D. FAN	<u>    </u>
7C I.D. FAN	<u>    </u>
7D I.D. FAN	<u>    </u>
7A P.A. FAN	<u>175</u>
7B P.A. FAN	<u>    </u>

7A FDF DISCHARGE	<u>22.5</u> (IN. OF H2O)
7B FDF DISCHARGE	<u>22.5</u>
FURNACE GAS	<u>25</u>
ECON INLET	<u>3.5</u>
ID DUCT SUCTION	<u>17</u>
ECON OUTLET	<u>6</u>
7A IDF SUCTION	<u>18</u>
7B IDF SUCTION	<u>18.5</u>
7C IDF SUCTION	<u>18</u>
7D IDF SUCTION	<u>18</u>
7A SAH GAS DIFF	<u>25</u>
7B SAH GAS DIFF	<u>20</u>
7A PAF DISCHARGE	<u>20</u>
7B PAF DISCHARGE	<u>20</u>
7A PAH GAS DIFF	<u>11</u>
7B PAH GAS DIFF	<u>11</u>

DAMPER POSITIONS (%)	
7A FDF INLET VANE	<u>65</u>
7B FDF INLET VANE	<u>70</u>
7A IDF INLET VANE	<u>    </u>
7B IDF INLET VANE	<u>    </u>
7C IDF INLET VANE	<u>    </u>
7D IDF INLET VANE	<u>    </u>
7A PAF INLET VANE	<u>    </u>
7B PAF INLET VANE	<u>    </u>
7A PAH GAS DAMPER	<u>    </u>
7B PAH GAS DAMPER	<u>    </u>
SH/RH DAMPERS	<u>40/60</u>
SAH STEAM COILS	<u>    </u>
PAH STEAM COILS	<u>    </u>
CONDENSER VAC HP	<u>    </u>
CONDENSER VAC LP	<u>    </u>
COND INLET H2O	<u>    </u>
COND OUTLET H2O	<u>    </u>
THROTTLE PSI	<u>2400</u>
SUPERHEAT TEMP	<u>    </u>
REHEAT TEMP	<u>    </u>

MAIN STEAM FLOW 1.7  
 WATER FLOW 4.1  
 CONDENSATE FLOW 3.1

OPACITY 6 MIN AVG 5.0  
 OPACITY A INSTANT 1.2  
 OPACITY B INSTANT 1.2  
 7A 02 3.7  
 7B 02 3.7  
 STACK 02 1.1  
 S02 1.1 Max 2

PULVERIZER READINGS

	MILL AMPS	COAL FLOW	P.A. FLOW	MILL DIFF	MILL TEMP			
7A	56	70	115	8	160	533705	533702	697
7B	52	68	114	1	160	488703	988701	704
7C	50	66	112	2	155	001065	001061	661
7D	5	65	115	1	155	150304	150304	
7E	5	70	115	2	170	115608	115502	
7F	5	70	115	7	165	800003	800008	

PULVERIZER DAMPER POSITIONS (%)

	HOT AIR	P.A. FLOW
7A	100%	53%
7B	100%	50%
7C	100%	45%
7D	100%	45%
7E	100%	45%
7F	100%	70%

AIR REGISTERS

	POSITIONER PERCENT
7A	54, 31, 34, 47
7B	56, 31, 30, 52
7C	45, 30, 32, 58
7D	46, 30, 31, 52
7E	45, 30, 30, 45
7F	56, 31, 31, 48

COMMENTS

---



---



---



---



T/R CONTROL PRECIPITATOR A

T/R	COMM LINK	T/R RATED KVA	T/R ACTUAL KVA	% MAX CURRENT		PRIMARY		SECONDARY	SPARKS	POR
				SET	OBS	VOLT	AMPS	MILLIAMPS	per MINUTE	
7A-A	ON	90	90	100	4	331	19	74	6	OFF
7A-B	ON	90	90	100	15	369	40	214	30	OFF
7A-C	ON	90	90	100	18	348	39	261	24	OFF
7A-D	ON	90	90	100	43	386	74	606	12	OFF
7A-E	ON	90	90	100	39	344	85	550	12	OFF
7A-F	ON	90	90	100	42	373	75	597	6	OFF
7A-G	ON	90	90	100	40	357	74	569	0	OFF
7A-H	ON	90	90	100	46	369	78	644	24	OFF
7A-J	ON	90	90	100	65	449	95	905	18	OFF

~~13:45:33~~ 25-Sep-95

13:35

Run # 3

START 1333

T/R CONTROL PRECIPITATOR B

T/R	COMM LINK	T/R RATED KVA	T/R ACTUAL KVA	% MAX CURRENT		PRIMARY		SECONDARY	SPARKS per MINUTE	POR
				SET	OBS	VOLT	AMPS	MILLIAMPS		
7B-A	ON	90	90	100	20	403	44	270	33	OFF
7B-B	ON	90	90	100	32	365	66	457	12	OFF
7B-C	ON	90	90	100	40	357	66	569	42	OFF
7B-D	ON	90	90	100	66	344	118	933	51	OFF
7B-E	ON	90	90	100	36	336	60	513	0	OFF
7B-F	ON	90	90	100	60	403	99	849	0	OFF
7B-G	ON	90	90	100	54	348	95	765	9	OFF
7B-H	ON	90	90	100	63	361	101	886	0	OFF
7B-J	ON	90	90	100	68	386	96	961	0	OFF

Run # 3

START 13:33

13:45:15 25-Sep-95

13:35

T/R CONTROL PRECIPITATOR A

T/R	COMM LINK	T/R RATED KVA	T/R ACTUAL KVA	% MAX CURRENT		PRIMARY		SECONDARY	SPARKS	POR
				SET	OBS	VOLT	AMPS	MILLIAMPS	per MINUTE	
7A-A	ON	90	90	100	2	298	13	37	21	OFF
7A-B	ON	90	90	100	14	365	38	196	33	OFF
7A-C	ON	90	90	100	15	340	33	205	72	OFF
7A-D	ON	90	90	100	18	306	39	261	60	OFF
7A-E	ON	90	90	100	26	306	62	373	69	OFF
7A-F	ON	90	90	100	31	319	61	438	63	OFF
7A-G	ON	90	90	100	40	365	74	569	30	OFF
7A-H	ON	90	90	100	43	369	75	606	24	OFF
7A-J	ON	90	90	100	58	436	88	812	18	OFF

Run #3  
Stop 1436

14:48:48 25-Sep-95

14:50

T/R CONTROL PRECIPITATOR B

T/R	COMM LINK	T/R RATED KVA	T/R ACTUAL KVA	Z MAX CURRENT		PRIMARY		SECONDARY	SPARKS per MINUTE	POR
				SET	OBS	VOLT	AMPS	MILLIAMPS		
7B-A	ON	90	90	100	15	390	37	214	18	OFF
7B-B	ON	90	90	100	28	336	58	392	15	OFF
7B-C	ON	90	90	100	44	369	68	616	12	OFF
7B-D	ON	90	90	100	76	382	131	1073	3	OFF
7B-E	ON	90	90	100	36	344	60	513	6	OFF
7B-F	ON	90	90	100	68	428	109	961	9	OFF
7B-G	ON	90	90	100	54	352	95	765	0	OFF
7B-H	ON	90	90	100	63	365	101	886	0	OFF
7B-J	ON	90	90	100	68	386	96	961	0	OFF

Run #3  
STOP 1436

14:49:08 25-Sep-95

PERMIT#: A 7-234356

EPA

VISIBLE EMISSION OBSERVATION FORM 1

Method Used (Circle One)  
 Method 9 203A 203B Other \_\_\_\_\_

Company Name  
 Gulf Power Crist Electric GEN. PLANT  
 Facility Name  
 FLY ASH SILO "A"  
 Street Address  
 TEN MILE Rd.,  
 City PENSACOLA State FL Zip 32514


Process Unit # Operating Mode  
 FLY ASH Collection Syst. A NORMAL  
 Control Equipment Operating Mode  
 BAGHOUSE NORMAL

Describe Emission Point  
 Southeast (west-west) Green Vent  
 on Silo A  
 Height of Emis. Pt. Start ~230 End ~230  
 Height of Emis. Pt. Rel. to Observer Start ~75 End ~75  
 Distance to Emis. Pt. Start ~250 End ~250  
 Direction to Emis. Pt. (Degrees) Start 20° End 20°

Vertical Angle to Obs. Pt. Start 16.7° End 16.7°  
 Direction to Obs. Pt. (Degrees) Start 20° End 20°  
 Distance and Direction to Observation Point from Emission Point  
 Start Same End Same

Describe Emission:  
 Start Light periodic puff End Same  
 Emission Color Start Gray End Gray  
 Attached  Detached  None

Describe Plume Background:  
 Start Sky End SKY  
 Background Color: Start BLUE End BLUE  
 Sky Conditions Start CLEAR End CLEAR  
 Wind Speed Start 4-7 End 4-7 mph  
 Wind Direction Start NE End NE  
 Ambient Temp. Start 55°F End 50°F  
 Wet Bulb Temp. RH Percent



Additional Information  
 opacity readings: MAX: 5  
 MIN: 0

Form Number \_\_\_\_\_ Page 1 of 2  
 Continued on VEO Form Number \_\_\_\_\_

Observation Date	Time Zone	Start Time	End Time				
11/30/95	CST	1600	1700				
Sec	0	15	30	45	Comments		
1	0	0	0	0			
2	0	0	0	0			
3	0	0	0	0			
4	0	5	5	5	MAX READING: 5		
5	0	0	0	0	MIN READING: 0		
6	0	0	5	0	6 MIN. AVG.		
7	0	0	0	5	(HIGHEST 24		
8	5	0	0	0	CONSECUTIVE		
9	0	0	0	5	READINGS: 1.46		
10	0	0	0	0			
11	0	0	5	0			
12	0	5	0	5			
13	0	0	0	0			
14	0	0	0	5			
15	0	5	0	0			
16	0	0	0	0			
17	5	5	0	5			
18	0	0	0	0			
19	5	0	0	0			
20	0	0	0	0			
21	0	0	5	0			
22	0	0	0	0			
23	0	0	0	5			
24	0	0	5	0			
25	0	0	0	0			
26	0	0	0	0			
27	0	0	0	0			
28	0	0	0	0			
29	0	0	0	0			
30	5	0	0	0			

Observer's Name (Print)  
 JOHN M. McPHERSON  
 Observer's Signature  
 [Signature] Date 11/30/95  
 Organization  
 GULF POWER CO  
 Certified by  
 EASTERN TECHNICAL ASSOC. Date 11/15/95

FLY ASH  
SILO "A"  
(Nearest Vent)

EPA

VISIBLE EMISSION OBSERVATION FORM 1

Form Number    Page 2 of 2  
Continued on VEO Form Number   

Method Used (Circle One)  
Method 9  203A  203B  Other: \_\_\_\_\_

Company Name \_\_\_\_\_  
Facility Name \_\_\_\_\_  
Street Address \_\_\_\_\_  
City \_\_\_\_\_ State \_\_\_\_\_ Zip \_\_\_\_\_


Process \_\_\_\_\_ Unit # \_\_\_\_\_ Operating Mode \_\_\_\_\_  
Control Equipment \_\_\_\_\_ Operating Mode \_\_\_\_\_

Describe Emission Point \_\_\_\_\_  
Height of Emiss. Pt. \_\_\_\_\_ Height of Emiss. Pt. Rel. to Observer \_\_\_\_\_  
Start \_\_\_\_\_ End \_\_\_\_\_ Start \_\_\_\_\_ End \_\_\_\_\_  
Distance to Emiss. Pt. \_\_\_\_\_ Direction to Emiss. Pt. (Degrees) \_\_\_\_\_  
Start \_\_\_\_\_ End \_\_\_\_\_ Start \_\_\_\_\_ End \_\_\_\_\_

Vertical Angle to Obs. Pt. \_\_\_\_\_ Direction to Obs. Pt. (Degrees) \_\_\_\_\_  
Start \_\_\_\_\_ End \_\_\_\_\_ Start \_\_\_\_\_ End \_\_\_\_\_  
Distance and Direction to Observation Point from Emission Point \_\_\_\_\_  
Start \_\_\_\_\_ End \_\_\_\_\_

Describe Emissions \_\_\_\_\_  
Start \_\_\_\_\_ End \_\_\_\_\_  
Emission Color: \_\_\_\_\_ Water Droplet Plume \_\_\_\_\_  
Start \_\_\_\_\_ End \_\_\_\_\_ Attached  Detached  None

Describe Plume Background \_\_\_\_\_  
Start \_\_\_\_\_ End \_\_\_\_\_  
Background Color: \_\_\_\_\_ Sky Conditions \_\_\_\_\_  
Start \_\_\_\_\_ End \_\_\_\_\_ Start \_\_\_\_\_ End \_\_\_\_\_  
Wind Speed \_\_\_\_\_ Wind Direction \_\_\_\_\_  
Start \_\_\_\_\_ End \_\_\_\_\_ Start \_\_\_\_\_ End \_\_\_\_\_  
Ambient Temp. \_\_\_\_\_ Wet Bulb Temp. \_\_\_\_\_ RH Percent \_\_\_\_\_  
Start \_\_\_\_\_ End \_\_\_\_\_



Sec Min	Time Zone				Start Time	End Time	Comments
	0	15	30	45			
1	5	5	0	0			
2	0	0	0	0			
3	0	0	0	0			
4	0	0	0	0			
5	0	0	0	5			
6	0	0	0	0			
7	0	0	0	0			
8	0	0	0	0			
9	0	0	0	0			
10	0	5	0	0			
11	0	5	0	0			
12	0	0	0	0			
13	0	0	0	0			
14	0	5	0	0			
15	5	0	0	0			
16	0	0	5	0			
17	0	0	5	0			
18	0	0	0	0			
19	0	0	0	0			
20	0	0	0	0			
21	0	0	0	0			
22	0	0	0	0			
23	0	5	0	5			
24	0	0	0	0			
25	0	0	5	0			
26	0	0	0	0			
27	0	0	0	0			
28	0	0	0	0			
29	5	0	0	0			
30	0	5	0	0			

Observer's Name (Print) \_\_\_\_\_  
Observer's Signature \_\_\_\_\_ Date \_\_\_\_\_  
Organization \_\_\_\_\_  
Certified by \_\_\_\_\_ Date \_\_\_\_\_

Additional Information \_\_\_\_\_  
\_\_\_\_\_

EPA

VISIBLE EMISSION OBSERVATION FORM 1

Method Used (Circle One)  
 Method 9 203A 203B Other

Company Name: GULF POWER CRIST Electric GEN. Plant  
 Facility Name: FLY ASH SILO "A"  
 Street Address: Ten mile Rd.  
 City: PENSACOLA State: FL Zip: 32514


Process: FLY ASH Collection Syst. "A" Unit # \_\_\_\_\_ Operating Mode: NORMAL  
 Control Equipment: BAGHOUSE Operating Mode: NORMAL

Describe Emission Point:  
Farthest (East-most) GREEN VENT  
on SILO "A"  
 Height of Emiss. Pt. Start: ~230 End: ~230 Height of Emiss. Pt. Rel. to Observer Start: ~75' End: ~75'  
 Distance to Emiss. Pt. Start: ~250 End: ~250 Direction to Emiss. Pt. (Degrees) Start: 20° End: 20°

Vertical Angle to Obs. Pt. Start: 16.7° End: 16.7° Direction to Obs. Pt. (Degrees) Start: 20° End: 20°  
 Distance and Direction to Observation Point from Emission Point Start: Same End: Same

Describe Emissions:  
 Start: Light Periodic Puff End: Same  
 Emission Color: Start: Gray End: Gray  
 Water Droplet Plume: Attached  Detached  None

Describe Plume Background:  
 Start: SKY End: SKY  
 Background Color: Start: BLUE End: BLUE Sky Conditions: Start: CLEAR End: CLEAR  
 Wind Speed: Start: A-7 End: 4-7 Wind Direction: Start: NE End: NE  
 Ambient Temp.: Start: 55°F End: 50°F Wet Bulb Temp.: \_\_\_\_\_ RH Percent: \_\_\_\_\_



Longitude \_\_\_\_\_ Latitude \_\_\_\_\_ Declination \_\_\_\_\_

Additional Information  
 opacity Readings: MAX: 5 / MIN: 0  
 HIGHEST 24 consecutive: .63

Form Number \_\_\_\_\_ Page 1 of 2  
 Continued on VEO Form Number \_\_\_\_\_

Observation Date	Time Zone	Start Time	End Time					
11/30/95	CST	1600	1700					
Min	Sec				Comments			
	0	15	30	45				
1	0	0	0	0				
2	0	0	0	0				
3	0	0	0	0				
4	0	0	0	0				
5	0	0	0	0	MAX READING: 5			
6	0	5	0	0	MIN READING: 0			
7	0	0	5	0	HIGH 6 MIN.			
8	0	0	0	0	AVG (consecutive			
9	0	5	0	0	24 readings)			
10	0	0	0	0	= .63			
11	0	0	0	0				
12	0	0	0	0				
13	0	0	0	0				
14	0	0	0	0				
15	0	0	0	0				
16	0	5	0	0				
17	0	0	0	0				
18	0	0	0	0				
19	0	0	0	0				
20	0	0	0	0				
21	0	0	0	0				
22	0	0	0	0				
23	0	0	0	0				
24	0	0	5	0				
25	0	0	0	0				
26	0	0	0	0				
27	0	0	0	0				
28	0	0	0	0				
29	0	0	0	0				
30	0	0	0	0				

Observer's Name (Print): JOHN M. McPHERSON  
 Observer's Signature: [Signature] Date: 11/30/95  
 Organization: GULF POWER CO.  
 Certified By: EASTERN TECHNICAL ASSOC Date: 11/15/95

FLYING  
SILB...  
FARTHEST VENT

EPA

VISIBLE EMISSION OBSERVATION FORM 1

Method Used (Circle One)  
 Method 9    203A    203B    Other \_\_\_\_\_

Company Name \_\_\_\_\_  
 Facility Name \_\_\_\_\_  
 Street Address \_\_\_\_\_  
 City \_\_\_\_\_ State \_\_\_\_\_ Zip \_\_\_\_\_

Process \_\_\_\_\_ Unit # \_\_\_\_\_ Operating Mode \_\_\_\_\_  
 Control Equipment \_\_\_\_\_ Operating Mode \_\_\_\_\_


Describe Emission Point \_\_\_\_\_

Height of Emis. Pt. \_\_\_\_\_ Height of Emis. Pt. Rel. to Observer \_\_\_\_\_  
 Start \_\_\_\_\_ End \_\_\_\_\_ Start \_\_\_\_\_ End \_\_\_\_\_  
 Distance to Emis. Pt. \_\_\_\_\_ Direction to Emis. Pt. (Degrees) \_\_\_\_\_  
 Start \_\_\_\_\_ End \_\_\_\_\_ Start \_\_\_\_\_ End \_\_\_\_\_

Vertical Angle to Obs. Pt. \_\_\_\_\_ Direction to Obs. Pt. (Degrees) \_\_\_\_\_  
 Start \_\_\_\_\_ End \_\_\_\_\_ Start \_\_\_\_\_ End \_\_\_\_\_  
 Distance and Direction to Observation Point from Emission Point \_\_\_\_\_  
 Start \_\_\_\_\_ End \_\_\_\_\_

Describe Emissions \_\_\_\_\_  
 Start \_\_\_\_\_ End \_\_\_\_\_  
 Emission Color \_\_\_\_\_ Water Droplet Plume \_\_\_\_\_  
 Start \_\_\_\_\_ End \_\_\_\_\_ Attached  Detached  None

Describe Plume Background \_\_\_\_\_  
 Start \_\_\_\_\_ End \_\_\_\_\_  
 Background Color \_\_\_\_\_ Sky Conditions \_\_\_\_\_  
 Start \_\_\_\_\_ End \_\_\_\_\_ Start \_\_\_\_\_ End \_\_\_\_\_  
 Wind Speed \_\_\_\_\_ Wind Direction \_\_\_\_\_  
 Start \_\_\_\_\_ End \_\_\_\_\_ Start \_\_\_\_\_ End \_\_\_\_\_  
 Ambient Temp. \_\_\_\_\_ Wet Bulb Temp. \_\_\_\_\_ RH Percent \_\_\_\_\_  
 Start \_\_\_\_\_ End \_\_\_\_\_



Additional Information \_\_\_\_\_

Form Number \_\_\_\_\_ Page 2 of 2  
 Continued on VEO Form Number \_\_\_\_\_

Sec Min	Time Zone				Start Time	End Time	Comments
	0	15	30	45			
1	0	0	5	0			
2	0	0	0	0			
3	0	0	0	0			
4	0	0	0	0			
5	0	0	0	0			
6	0	0	5	0			
7	0	0	0	0			
8	0	0	0	0			
9	0	0	0	0			
10	0	0	0	0			
11	0	0	0	0			
12	0	0	0	0			
13	0	0	0	0			
14	0	0	0	0			
15	0	0	0	0			
16	0	0	0	0			
17	0	0	0	0			
18	0	5	0	0			
19	0	0	0	0			
20	0	0	0	0			
21	0	0	0	0			
22	0	0	0	0			
23	0	0	0	0			
24	0	0	0	5			
25	0	0	0	0			
26	0	0	0	0			
27	0	0	0	0			
28	0	0	0	0			
29	0	0	0	0			
30	0	0	0	0			

Observer's Name (Print) \_\_\_\_\_  
 Observer's Signature \_\_\_\_\_ Date \_\_\_\_\_  
 Organization \_\_\_\_\_  
 Certified by \_\_\_\_\_ Date \_\_\_\_\_



Permit = AC17-2 = 356

EPA

VISIBLE EMISSION OBSERVATION FORM 1

Method Used (Circle One) Method 9 203A 203B Other \_\_\_\_\_

Company Name Gulf Power Crist Electric Generating  
 Facility Name FLYASH SILO "B" PLANT  
 Street Address Ten mile Rd., Pensacola 32514  
 City Pensacola State FL Zip 32514


Process Fly Ash Collection System B Unit # \_\_\_\_\_ Operating Mode NORMAL  
 Control Equipment Baghouse Operating Mode NORMAL

Describe Emission Point  
Nearest (West-most) green vent on Silo "B"  
 Height of Emiss. Pt. Start ~230' End ~230' Height of Emiss. Pt. Rel. to Observer Start ~75' End ~75'  
 Distance to Emiss. Pt. Start 250' End 250' Direction to Emiss. Pt. (Degree) Start 2530° End 30°

Vertical Angle to Obs. Pt. Start 16.7° End 16.7° Direction to Obs. Pt. (Degree) Start 30° End 30°  
 Distance and Direction to Observation Point from Emission Point Start Same End Same

Describe Emissions  
 Start Light Periodic puff End Same  
 Emission Color Start Gray End Gray Water Droplet Plume Attached  Detached  None

Describe Plume Background  
 Start SKY End SKY  
 Background Color Start BLUE End BLUE Sky Conditions Start CLEAR End CLEAR  
 Wind Speed Start ~4-7 End 4-7 Wind Direction Start ENE End NE  
 Ambient Temp. Start ~60°F End ~60°F Wet Bulb Temp. \_\_\_\_\_ RH Percent \_\_\_\_\_



Additional Information  
opacity READINGS: MIN: 0 MAX: 5

Form Number \_\_\_\_\_ Page 1 of 2  
 Continued on VEO Form Number \_\_\_\_\_

Observation Date	Time Zone	Start Time	End Time	Comments	
11/30/95	CST	1400hr.	1500hr.		
Sec	0	15	30	45	Comments
Min	0	0	0	0	
1	0	0	0	0	
2	0	0	0	0	
3	0	0	5	5	
4	0	0	0	5	
5	0	0	5	5	
6	0	5	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	5	5	0	
10	0	0	5	5	MAX reading = 5
11	0	0	5	5	min. reading = 0
12	5	0	5	0	HIGHEST 6 min
13	5	5	5	0	Avg = 2.29%
14	0	0	0	0	"opacity"
15	0	5	5	0	
16	0	0	0	0	
17	0	0	5	5	
18	0	0	5	0	
19	5	0	0	0	
20	0	0	0	5	
21	0	0	0	0	
22	0	0	0	5	
23	0	0	0	5	
24	0	0	0	5	
25	0	0	5	5	
26	0	5	0	0	
27	0	0	5	0	
28	0	0	0	0	
29	5	5	5	5	
30	0	0	5	0	

Observer's Name (Print) JOHN M. McPherson  
 Observer's Signature John M. McPherson Date 11/30/95  
 Organization GULF POWER CO.  
 Certified By Eastern Technical Assoc. Date 11/15/95

6-17  
NEAREST VENT

EPA

VISIBLE EMISSION OBSERVATION FORM 1

Method Used (Circle One)  
 Method 9    203A    203B    Other: \_\_\_\_\_

Company Name \_\_\_\_\_  
 Facility Name \_\_\_\_\_  
 Street Address \_\_\_\_\_  
 City \_\_\_\_\_ State \_\_\_\_\_ Zip \_\_\_\_\_


Process \_\_\_\_\_ Unit # \_\_\_\_\_ Operating Mode \_\_\_\_\_  
 Control Equipment \_\_\_\_\_ Operating Mode \_\_\_\_\_

Describe Emission Point \_\_\_\_\_  
 \_\_\_\_\_  
 Height of Emiss. Pt. \_\_\_\_\_ Height of Emiss. Pt. Rel. to Observer \_\_\_\_\_  
 Start \_\_\_\_\_ End \_\_\_\_\_ Start \_\_\_\_\_ End \_\_\_\_\_  
 Distance to Emiss. Pt. \_\_\_\_\_ Direction to Emiss. Pt. (Degree) \_\_\_\_\_  
 Start \_\_\_\_\_ End \_\_\_\_\_ Start \_\_\_\_\_ End \_\_\_\_\_

Vertical Angle to Obs. Pt. \_\_\_\_\_ Direction to Obs. Pt. (Degree) \_\_\_\_\_  
 Start \_\_\_\_\_ End \_\_\_\_\_ Start \_\_\_\_\_ End \_\_\_\_\_  
 Distance and Direction to Observation Point from Emission Point \_\_\_\_\_  
 Start \_\_\_\_\_ End \_\_\_\_\_

Describe Emissions \_\_\_\_\_  
 Start \_\_\_\_\_ End \_\_\_\_\_  
 Emission Color \_\_\_\_\_ Water Droplet Plume \_\_\_\_\_  
 Start \_\_\_\_\_ End \_\_\_\_\_ Attached  Detached  None

Describe Plume Background \_\_\_\_\_  
 Start \_\_\_\_\_ End \_\_\_\_\_  
 Background Color \_\_\_\_\_ Sky Conditions \_\_\_\_\_  
 Start \_\_\_\_\_ End \_\_\_\_\_ Start \_\_\_\_\_ End \_\_\_\_\_  
 Wind Speed \_\_\_\_\_ Wind Direction \_\_\_\_\_  
 Start ~ End \_\_\_\_\_ Start \_\_\_\_\_ End \_\_\_\_\_  
 Ambient Temp. \_\_\_\_\_ Wet Bulb Temp. \_\_\_\_\_ RH Percent \_\_\_\_\_  
 Start \_\_\_\_\_ End \_\_\_\_\_



Additional Information \_\_\_\_\_  
 \_\_\_\_\_

Form Number \_\_\_\_\_ Page \_\_\_\_\_ of \_\_\_\_\_  
 Continued on VEO Form Number \_\_\_\_\_

Sec Min	Time Zone				Start Time	End Time	Comments
	0	15	30	45			
1	0	0	0	0			
2	0	5	0	0			
3	0	0	0	0			
4	0	0	0	0			
5	0	0	0	0			
6	0	0	0	0			
7	5	0	0	5			
8	0	0	0	0			
9	0	0	0	0			
10	0	5	0	5			
11	5	0	0	0			
12	0	0	0	0			
13	0	0	5	5			
14	5	0	0	0			
15	0	0	0	0			
16	0	0	0	5			
17	0	0	0	5			
18	0	0	0	5			
19	0	0	0	0			
20	0	0	0	0			
21	0	0	0	0			
22	0	0	0	0			
23	5	0	0	0			
24	0	0	0	0			
25	0	0	0	0			
26	0	0	0	0			
27	0	0	0	0			
28	0	0	0	0			
29	0	0	0	0			
30	0	0	0	0			

Observer's Name (Print) \_\_\_\_\_  
 Observer's Signature \_\_\_\_\_ Date \_\_\_\_\_  
 Organization \_\_\_\_\_  
 Certified By \_\_\_\_\_ Date \_\_\_\_\_

EPA

VISIBLE EMISSION OBSERVATION FORM 1

Form Number    Page 1 of 2  
Continued on VEO Form Number   

Method Used (Circle One)  
Method 9    203A    203B    Other \_\_\_\_\_

Company Name: Gulf Power Electric Generating  
Facility Name: FLY ASH SILO "B" PLANT  
Street Address: Ten Mile Rd, Pensacola 32514  
City: PENSACOLA State: FL Zip: 32514


Process: FLY ASH Collection System - B Unit #: \_\_\_\_\_ Operating Mode: NORMAL  
Control Equipment: BAGHOUSE Operating Mode: NORMAL

Describe Emission Point:  
Furthest (EAST-MOST) GREEN VENT ON SILO "B"  
Height of Emiss. Pt. Start: ~230' End: ~230' Height of Emiss. Pt. Rel. to Observer Start: ~75' End: ~75'  
Distance to Emiss. Pt. Start: 250' End: 250' Direction to Emiss. Pt. (Degrees) Start: 30° End: 30°

Vertical Angle to Obs. Pt. Start: 16.7° End: 16.7° Direction to Obs. Pt. (Degrees) Start: 30° End: 30°  
Distance and Direction to Observation Point from Emission Point Start: same End: same

Describe Emissions  
Start: Light Periodic puff End: same  
Emission Color: Start: gray End: gray Water Droplet Plume: Attached  Detached  None

Describe Plume Background  
Start: SKY End: SKY  
Background Color: Start: BLUE End: BLUE Sky Conditions: Start: CLEAR End: CLEAR  
Wind Speed: Start: ~4-7 End: 4-7 Wind Direction: Start: ENE End: NE  
Ambient Temp.: Start: ~60°F End: ~60°F Wet Bulb Temp.: \_\_\_\_\_ RH Percent: \_\_\_\_\_



Longitude \_\_\_\_\_ Latitude \_\_\_\_\_ Declination \_\_\_\_\_  
Additional Information \_\_\_\_\_

Observation Date	Time Zone	Start Time	End Time	Comments		
11/30/95	CST	1400	1500			
Sec	Min	0	15	30	45	Comments
1	0	0	0	0		
2	0	0	0	0		
3	0	0	0	0		
4	0	5	0	0		
5	0	0	0	0		
6	0	0	0	0		
7	0	0	0	0		
8	0	0	0	0		
9	0	0	5	5		
10	0	0	0	0		
11	0	5	0	0		
12	0	0	0	0		
13	0	0	0	0		
14	0	0	0	0		
15	0	0	0	0		MAX READING: 5
16	0	0	0	5		MIN READING: 0
17	0	5	5	0		HIGHEST 6 min.
18	0	0	0	0		Avg. (24 consecutive
19	0	5	0	0		READINGS) = .83
20	0	0	0	0		
21	0	0	0	0		
22	0	0	0	0		
23	0	0	0	0		
24	0	0	0	0		
25	0	0	0	0		
26	0	0	5	0		
27	0	0	0	0		
28	0	0	0	0		
29	0	0	5	0		
30	0	0	0	0		

Observer's Name (Print): JOHN McPERSON  
Observer's Signature: [Signature] Date: 11/30/95  
Organization: GULF POWER CO.  
Certified by: EASTERN TECHNICAL ASSOC Date: 11/15/95

EPA

1 EMISSION OBSERVATION FORM 1

3 (Circle One)  
 49 203A 203B Other

Name \_\_\_\_\_  
 Address \_\_\_\_\_  
 City \_\_\_\_\_ State \_\_\_\_\_ Zip \_\_\_\_\_

Unit # \_\_\_\_\_ Operating Mode \_\_\_\_\_  
 Equipment \_\_\_\_\_ Operating Mode \_\_\_\_\_


Describe Emission Point \_\_\_\_\_

Height of Emiss. Pt. Rel. to Observer  
 Start \_\_\_\_\_ End \_\_\_\_\_  
 Direction to Emiss. Pt. (Degrees)  
 Start \_\_\_\_\_ End \_\_\_\_\_

Direction to Obs. Pt. (Degrees)  
 Start \_\_\_\_\_ End \_\_\_\_\_  
 Distance and Direction to Observation Point from Emission Point  
 Start \_\_\_\_\_ End \_\_\_\_\_

Describe Emissions  
 Start \_\_\_\_\_ End \_\_\_\_\_  
 Emission Color \_\_\_\_\_  
 Attached  Detached  None

Describe Plume Background  
 Start \_\_\_\_\_ End \_\_\_\_\_  
 Background Color \_\_\_\_\_ Sky Conditions \_\_\_\_\_  
 Wind Speed \_\_\_\_\_ Wind Direction \_\_\_\_\_  
 Ambient Temp. \_\_\_\_\_ Wet Bulb Temp. \_\_\_\_\_ RH Percent \_\_\_\_\_



Form Number \_\_\_\_\_ Page \_\_\_\_\_ of \_\_\_\_\_  
 Continued on VEO Form Number \_\_\_\_\_

Observation Date		Time Zone		Start Time	End Time	Comments
11/30/95		CST		1400	1500	
Min	Sec	0	15	30	45	
1	0	0	0	0		
2	0	0	0	0		
3	0	0	0	0		
4	0	0	0	0		
5	0	0	0	0		
6	0	0	0	0		
7	0	0	0	0		
8	0	0	0	5		
9	0	0	0	0		
10	5	0	0	0		
11	0	0	0	0		
12	0	5	0	0		
13	0	0	0	0		
14	0	0	0	0		
15	0	0	0	0		
16	0	0	0	0		
17	0	0	0	0		
18	0	0	0	0		
19	0	0	0	0		
20	0	0	0	0		
21	0	0	0	0		
22	0	0	0	0		
23	0	5	0	0		
24	0	0	0	0		
25	0	0	0	0		
26	0	0	0	0		
27	0	0	0	0		
28	0	0	0	0		
29	0	0	0	0		
30	0	0	5	0		

Observer's Name (Print) \_\_\_\_\_  
 Observer's Signature \_\_\_\_\_ Date \_\_\_\_\_  
 Organization \_\_\_\_\_  
 Certified by \_\_\_\_\_ Date \_\_\_\_\_

EUS-6

### **Crist Plant Units 1, 2, & 3 Startup Procedure**

The steam generators for Crist Units 1, 2, & 3 are non-reheat, balanced draft, front wall fired boilers manufactured by Riley Stoker. Natural gas, #6 fuel oil, and distillate #2 fuel oil are all considered primary fuels. The normal startup procedures for Units 1, 2, & 3 are basically the same and are as follows:

Prior to startup, insure that all personnel and foreign material are out of the boiler and ductwork before the access and observation doors are closed and secured; this includes the Induced Draft (ID) fan and the Forced Draft (FD) fan and the pulverizers. Strictly follow the hold tag procedures to maintain the highest level of safety. Check the boiler valves to be in the startup position. Start the ID fan and the FD fan and establish an air flow of approximately two inches of water on the forced draft fan discharge. Engage the manual ignitors. Increase the fuel supply approximately 1/3 to 1/2 open. Insure that a stable flame has been established. As the firing process continues, the fuel is increased to continually raise the boiler steam pressure and temperature. When 600 psi steam pressure in the boiler is reached, and turbine conditions allow, start to roll and warm up the turbine and prepare to put the unit on-line. When the unit is on-line, which refers to the transmission of electrical power to the switchyard for power distribution, additional fuel guns are needed to maintain the proper steam flow to the turbine for minimum load. This process takes eight to twelve hours from the time when a fire is established in the boiler but is dictated directly by the ambient temperature, fuel quality, the number of equipment malfunctions encountered during startup, and the turbine warm-up conditions. Startup operations are complete when the plant laboratoryman checks the quality of the boiler water and its ancillary equipment and processes and releases the units for full boiler pressure operation and electrical generation.

## Shutdown Procedures

Shutdown operations can be separated into two categories: emergency shutdown or normal shutdown. An emergency shutdown occurs when a piece of equipment fails or an electrical fault occurs within the system and causes the unit to trip off-line.

At this point, all of the fuel is immediately taken out of the boiler. The unit is stabilized and, depending on what is at fault, the unit is either left down or the malfunction is corrected and the unit is brought back on-line. A normal controlled shutdown is usually brought about due to load demands within the Southern System and how the units are dispatched. When a unit is requested to shutdown by the Southern Company Central Dispatch Office, the fuel is slowly restricted to the boiler while the steam pressure is allowed to drop. When all of the fuel has been removed from the boiler, the ID and FD fans are left running to cool the boiler.

An emergency shutdown typically takes from a half hour to several hours, depending on the nature of the emergency and whether the unit is placed back "on-line" after correcting the equipment malfunction. A typical normal shutdown takes approximately ten to twelve hours to cool down the boiler and shut down the fans. This depends on the ambient temperature and the number of equipment malfunctions encountered during shutdown.

## **Crist Units 4 & 5 Startup Procedure**

The steam generators for Crist Units 4&5 are tangential fired, balanced draft, boilers manufactured by Combustion Engineering. The primary fuel is coal. Natural gas is a secondary fuel used for startup and can be used for load carrying capabilities. Distillate #2 fuel oil is also a secondary fuel used for startup and sometimes used for flame stabilization. The normal startup procedures for unit 4&5 are basically the same and are as follows:

Prior to startup, insure that all personnel and foreign materials are out of the boiler and ductwork before the access and observation doors are closed and secured; this includes the induced draft (ID) fan, the forced draft (F.) fan, and the pulverizers. Strictly follow the hold tag procedures to maintain the highest level of safety. Check that all boiler valves are in the startup position. Start the air preheaters. Set up the air heater sootblower steam header and blow the air heater sootblowers continuously while firing to maintain the cleanliness of the air heaters. Start the induced draft (ID) fan and the forced draft (FD) fan. Start the pilot oil torch blower. After the boiler is purged for 5 minutes, adjust air flow to approximately 25% of full load air flow. After the air flow has stabilized, the first oil guns or gas guns are placed into service. Establish a firing rate not to exceed 100 degrees rise per hour at the economizer outlet gas. Continue this for several hours until approximately 600 psi steam pressure in the boiler is achieved. At this point, the cold and hot precipitators are energized. At this point, if the turbine conditions allow, roll the turbine and start turbine warm-up sequence. Put in the pilot oil torches for the pulverizers you will need when you get on-line. Start the pulverizers and verify their operation. Continue to increase the boiler pressure and when turbine conditions allow, tie the unit on-line, which refers to the transmission of electrical power to the switchyard for power distribution. At this point, the coal pulverizers are placed in service and once the coal pulverizers are stable, the oil and/or gas is removed from service. The unit is slowly brought up to minimum load while increasing the coal firing rate. This process usually takes approximately eight to twelve hours from the time when a fire is established in the boiler but is dictated directly by the ambient temperature, fuel quality, the number of equipment malfunctions encountered during the startup, and the turbine warm-up conditions. Startup operations are complete when the plant laboratoryman checks the quality of the boiler water and its ancillary equipment and processes and releases the unit for full boiler pressure operation and electrical generation.

## Shutdown Procedures

Shutdown operations can be separated into two categories: emergency shutdown or normal shutdown. An emergency shutdown occurs when a piece of equipment fails or an electrical fault occurs within the system which causes the unit to trip off-line. At this point, all of the fuel is immediately taken out of the boiler. The unit is stabilized and depending on what is at fault, the unit is either left down or the malfunction is corrected and the unit is brought back on-line. A normal controlled shutdown is usually due to load demands within the Southern System and how the units are dispatched. When a unit is requested to shut down by the Southern Company Central Dispatch Office, the fuel is slowly restricted to the boiler while the steam pressure is allowed to drop. When all of the fuel has been removed from the boiler, the ID and FD fans are left running to cool the boiler. When the temperature drops to approximately 100 to 125 degrees, the fans are shut down and the precipitator is taken out of service.

An emergency shutdown typically takes from half an hour to several hours, depending on the nature of the emergency and whether the unit is placed back "on line" after correcting the equipment malfunction. A typical normal shutdown takes approximately ten to twelve hours to cool down the boiler and shut down the fans and precipitator. This time period depends on the ambient temperature and the number of equipment malfunctions encountered during shutdown.



## **Crist Plant Unit 6 Startup Procedure**

Crist Unit 6 steam generator is a front wall fired, balanced draft boiler manufactured by Foster Wheeler. The primary fuel is coal. The secondary fuel is natural gas and is used for startup and can be used for load carrying conditions. Distillate #2 fuel oil is also a secondary fuel for startup and sometimes used for flame stabilization. Normal startup procedure is as follows:

Prior to startup, insure that all personnel and foreign materials are out of the boiler and ductwork before the access and observation doors are closed and secured; this includes the induced draft (ID) fan, the forced draft (FD) fan, and the pulverizers. Strictly follow the hold tag procedures to maintain the highest level of safety. Check boiler valves to be in the startup position. Set superheat and reheat dampers at approximately 50% open position. Start the air preheaters. Start the induced draft (ID) fans and the forced draft (FD) fans and adjust air flow to a minimum of 25% of the full load air flow which is approximately 750,000 lbs./hr. Start the ignitor cooling air fan and the hot air recirculating fans. Set up the air heater sootblower steam header and blow air heaters continuously while firing to maintain the cleanliness of the air heaters. At this point, the superheat dampers are positioned at 100% open and the reheat dampers are closed. After the air flow has stabilized, the first oil guns or gas guns are placed in service. Establish a firing rate not to exceed 100 degrees F temperature rise per hour at the economizer outlet gas, and maintain during succeeding hours. At the end of the fifth hour, there will be approximately 400 psi of boiler pressure and it will be time to test the oil ignitors for the pulverizers that will be needed when the unit comes on-line to verify their operation. Once verified, the oil ignitors are removed from service and the cold precipitator is placed in service. When the boiler pressure reaches approximately 600 psi, start the first coal pulverizers and verify their operation. Continue to raise boiler steam pressure and temperature. When turbine conditions allow, tie the unit on-line, which refers to the transmission of electrical power to the switchyard for power distribution. At this point, the coal pulverizers are placed into service and once the coal pulverizers are stable, the oil and/or gas is removed from service. The unit is slowly brought to minimum load while increasing the coal firing rate. This process takes eight to twelve hours from the time when a fire is established in the boiler but is dictated directly by the ambient temperature, fuel quality, the number of equipment malfunctions encountered during startup, and the turbine warm up conditions. Startup operations are complete when the plant laboratoryman checks the quality of the boiler water and its ancillary equipment and processes and releases the unit for full boiler pressure operation and electrical generation.

## Shutdown Procedures

Shutdown operations can be separated into two categories: emergency shutdown or normal shutdown. An emergency shutdown occurs when a piece of equipment fails or an electrical fault occurs within the system which causes the unit to trip off-line. At this point, all of the fuel is immediately taken out of the boiler. The unit is stabilized and, depending on what is at fault, the unit is either left down or the malfunction is corrected and the unit is brought back on line. A normal controlled shutdown is usually due to load demands within the Southern System and how the units are dispatched. When a unit is requested to shutdown by the Southern Company Central Dispatch Office, the fuel is slowly restricted to the boiler while the steam pressure is allowed to drop. When all of the fuel has been removed from the boiler, the ID and FD fans are left running to cool the boiler. When the temperature drops to approximately 100 to 125 degrees, the fans are shut down and the precipitator is taken out of service.

An emergency shutdown typically takes from half an hour to several hours, depending on the nature of the emergency and whether the unit is placed back "on line" after correcting the equipment malfunction. A typical normal shutdown takes approximately 10 to 12 hours to cool down the boiler and shut down the fans and precipitator. This time period depends on the ambient temperature and the number of equipment malfunctions encountered during shutdown.

## **Crist Plant Unit 7 Start-up Procedures**

The steam generator for Crist Unit 7 is a front wall and rear wall fired, balanced draft boiler manufactured by Foster Wheeler. The primary fuel is coal. Natural gas is a secondary fuel used for startup and may also be used for load carrying capabilities. Distillate #2 fuel oil is also a secondary fuel used for startup and sometimes used for flame stabilization. The normal startup procedure is as follows:

Prior to startup, insure that all personnel and foreign materials are out of the boiler and ductwork before the access and observation doors are closed and secured; this includes the induced draft (ID) fan and the forced draft (FD) fan and the pulverizers. Strictly follow the hold tag procedures to maintain the highest level of safety. Check boiler valves to be in the startup position. Set the superheat and reheat dampers at 50% open position. Normally, start all four ID fans and both FD fans on low speed. Start the secondary air preheaters and one ignitor cooling air fan. Set up the air heater sootblowing steam header and blow the air heater sootblowers continuously while firing to maintain the cleanliness of the air heaters. Position the superheat damper open at 100% and the reheat damper closed. Adjust the air flow to about 25% of the total full load air flow that is approximately 1,200,000 lbs./hr. After the air flow has stabilized, the first oil guns or gas guns are placed into service. Establish a firing rate not to exceed 100 degrees F temperature rise per hour at the economizer outlet gas, and maintain during succeeding hours. At the end of the fifth hour, there will be approximately 400 psi of boiler pressure and it will be time to test the ignitors for the pulverizers that will be needed when the unit comes on-line to verify their operation. Once verified, the oil ignitors are taken out of service and the cold precipitator is placed in service. When the boiler pressure reaches approximately 600 psi, start the first coal pulverizers and verify their operation. Continue to raise boiler pressure and when turbine conditions allow, tie the unit on-line, which refers to the transmission of electrical power to the switchyard for power distribution. At this point, the coal pulverizers are placed in service and once the coal pulverizers are stable, the oil and/or gas is removed from service. The unit is slowly brought to minimum load while increasing the coal firing rate. This process takes eight to twelve hours from the time when a fire is established in the boiler but is dictated directly by the ambient temperature, fuel quality, the number of equipment malfunctions encountered during startup, and the turbine warm up conditions. Startup operations are considered complete when the plant laboratoryman checks the quality of the boiler water and its ancillary equipment, and processes and releases the unit for full boiler pressure operation and electrical generation.

## Shutdown Procedures

Shutdown operations can be separated into two categories: emergency shutdown or normal shutdown. An emergency shutdown occurs when a piece of equipment fails or an electrical fault occurs within the system that causes the unit to trip off-line, at which point all of the fuel is immediately taken out of the boiler. The unit is stabilized and, depending on what is at fault, the unit is either left down or the malfunction is corrected and the unit is brought back on-line. A normal controlled shutdown is usually due to load demands within the Southern System and how the units are dispatched. When a unit is requested to shutdown by the Southern Company Central Dispatch Office, the fuel is slowly restricted to the boiler while the steam pressure is allowed to drop. When all of the fuel has been removed from the boiler, the ID and FD fans are left running to cool the boiler. When the temperature drops to approximately 100 to 125 degrees, the fans are shut down and the precipitator is taken out of service.

An emergency shutdown typically takes from half an hour to several hours, depending on the nature of the emergency and whether the unit is placed back "on line" after correcting the equipment malfunction. A typical normal shutdown takes approximately ten to twelve hours to cool down the boiler and shut down the fans and precipitator. This time period depends on the ambient temperature and the number of equipment malfunctions encountered during shutdown.

EUS-10

Crist123EUS123-10 (Alternative Methods of Operation)

## **ALTERNATIVE METHODS OF OPERATION CRIST UNIT 1-2-3**

- 1. Unit is operated under normal conditions utilizing natural gas as the primary fuel with supplemental firing of "on specification" used oil at a rate to minimize emissions less than the applicable opacity standard. The amount of used oil to be consumed by the unit is estimated to be less than 10,000 gallons per year.**
- 2. Unit is operated under normal conditions utilizing #2 fuel oil as the primary fuel with supplemental firing of "on specification" used oil at a rate to minimize emissions less than the applicable opacity standard. The amount of used oil to be consumed by the unit is estimated to be less than 10,000 gallons per year.**
- 3. Unit is operated under normal conditions utilizing #6 fuel oil as the primary fuel with supplemental firing of "on specification" used oil at a rate to minimize emissions less than the applicable opacity standard. The amount of used oil to be consumed by the unit is estimated to be less than 10,000 gallons per year.**
- 4. Unit is operated under normal conditions utilizing natural gas as the primary fuel with supplemental firing of any combination of the following fuels; #2 oil, #6 oil, as dictated by market and fuel availability demands.**
- 5. Unit is operated under normal conditions utilizing #2 oil as the primary fuel.**
- 6. Unit is operated under normal conditions utilizing #6 oil as the primary fuel.**
- 7. Unit is operated under normal conditions utilizing natural gas as the primary fuel.**

## **ALTERNATIVE METHODS OF OPERATION CRIST UNIT 4**

- 1. Unit is operated under normal conditions utilizing coal as the primary fuel with supplemental firing of “on specification” used oil at a rate to minimize emissions less than the applicable opacity standard. The amount of used oil to be consumed by the unit is estimated to be less than 50,000 gallons per year.**
- 2. Unit is operated under normal conditions utilizing coal as the primary fuel with supplemental firing of “boiler chemical cleaning waste” at a rate of less than 50 gallons per minute to minimize emissions less than the applicable opacity standard.**
- 3. Unit is operated under normal conditions utilizing coal as the primary fuel with supplemental firing of “oil contaminated soil” for energy recovery at a rate to minimize emissions less than the applicable opacity standard. The amount of “oil contaminated soil” is estimated to be less than 2500 cubic yards of soil per year.**
- 4. Unit is operated under normal conditions utilizing coal as the primary fuel with supplemental firing of any combination of the following fuels; #2 oil, natural gas as dictated by market and fuel availability demands.**
- 5. Unit is operated under normal conditions utilizing #2 oil as the primary fuel.**
- 6. Unit is operated under normal conditions utilizing natural gas as the primary fuel.**
- 7. Unit is operated under normal conditions utilizing subbituminous coal as the primary fuel.**
- 8. Unit is operated under normal conditions utilizing bituminous coal as the primary fuel.**

## **ALTERNATIVE METHODS OF OPERATION CRIST UNIT 5**

- 1. Unit is operated under normal conditions utilizing coal as the primary fuel with supplemental firing of "on specification" used oil at a rate to minimize emissions less than the applicable opacity standard. The amount of used oil to be consumed by the unit is estimated to be less than 50,000 gallons per year.**
- 2. Unit is operated under normal conditions utilizing coal as the primary fuel with supplemental firing of "boiler chemical cleaning waste" at a rate of less than 50 gallons per minute to minimize emissions less than the applicable opacity standard.**
- 3. Unit is operated under normal conditions utilizing coal as the primary fuel with supplemental firing of "oil contaminated soil" for energy recovery at a rate to minimize emissions less than the applicable opacity standard. The amount of "oil contaminated soil" is estimated to be less than 2500 cubic yards of soil per year.**
- 4. Unit is operated under normal conditions utilizing coal as the primary fuel with supplemental firing of any combination of the following fuels; #2 oil, natural gas as dictated by market and fuel availability demands.**
- 5. Unit is operated under normal conditions utilizing #2 oil as the primary fuel.**
- 6. Unit is operated under normal conditions utilizing natural gas as the primary fuel.**
- 7. Unit is operated under normal conditions utilizing subbituminous coal as the primary fuel.**
- 8. Unit is operated under normal conditions utilizing bituminous coal as the primary fuel.**

## **ALTERNATIVE METHODS OF OPERATION CRIST UNIT 6**

- 1. Unit is operated under normal conditions utilizing coal as the primary fuel with supplemental firing of "on specification" used oil at a rate to minimize emissions less than the applicable opacity standard. The amount of used oil to be consumed by the unit is estimated to be less than 50,000 gallons per year.**
- 2. Unit is operated under normal conditions utilizing coal as the primary fuel with supplemental firing of "boiler chemical cleaning waste" at a rate of less than 50 gallons per minute to minimize emissions less than the applicable opacity standard.**
- 3. Unit is operated under normal conditions utilizing coal as the primary fuel with supplemental firing of "oil contaminated soil" for energy recovery at a rate to minimize emissions less than the applicable opacity standard. The amount of "oil contaminated soil" is estimated to be less than 2500 cubic yards of soil per year.**
- 4. Unit is operated under normal conditions utilizing coal as the primary fuel with supplemental firing of any combination of the following fuels; #2 oil, natural gas as dictated by market and fuel availability demands.**
- 5. Unit is operated under normal conditions utilizing #2 oil as the primary fuel.**
- 6. Unit is operated under normal conditions utilizing natural gas as the primary fuel.**
- 7. Unit is operated under normal conditions utilizing subbituminous coal as the primary fuel.**
- 8. Unit is operated under normal conditions utilizing bituminous coal as the primary fuel.**



## **ALTERNATIVE METHODS OF OPERATION CRIST UNIT 7**

- 1. Unit is operated under normal conditions utilizing coal as the primary fuel with supplemental firing of "on specification" used oil at a rate to minimize emissions less than the applicable opacity standard. The amount of used oil to be consumed by the unit is estimated to be less than 50,000 gallons per year.**
- 2. Unit is operated under normal conditions utilizing coal as the primary fuel with supplemental firing of "boiler chemical cleaning waste" at a rate of less than 50 gallons per minute to minimize emissions less than the applicable opacity standard.**
- 3. Unit is operated under normal conditions utilizing coal as the primary fuel with supplemental firing of "oil contaminated soil" for energy recovery at a rate to minimize emissions less than the applicable opacity standard. The amount of "oil contaminated soil" is estimated to be less than 2500 cubic yards of soil per year.**
- 4. Unit is operated under normal conditions utilizing coal as the primary fuel with supplemental firing of any combination of the following fuels; #2 oil, natural gas as dictated by market and fuel availability demands.**
- 5. Unit is operated under normal conditions utilizing #2 oil as the primary fuel.**
- 6. Unit is operated under normal conditions utilizing natural gas as the primary fuel.**
- 7. Unit is operated under normal conditions utilizing subbituminous coal as the primary fuel.**
- 8. Unit is operated under normal conditions utilizing bituminous coal as the primary fuel.**
- 9. Unit is operated under normal conditions utilizing coal as the primary fuel with supplemental injection of ammonia at a rate of 25 to 40 pounds per hour as necessary to minimize emissions less than the applicable opacity standard.**
- 10. Unit is operated under normal conditions utilizing coal as the primary fuel with supplemental injection of sulfur trioxide at a rate of 4 to 20 ppm as necessary to minimize emissions less than the applicable opacity standard.**



Lawton Chiles  
Governor

Florida Department of **EUS-12**  
**Environmental Protection**

Northwest District  
160 Governmental Center  
Pensacola, Florida 32501-5794

Virginia B. Wetherell  
Secretary

**PERMITTEE:**

**Gulf Power Company**

I.D. Number: 10PEN17004501,02,03  
Permit/Certification Number: AO17-249656  
Date of Issue: May 19, 1994  
Expiration Date: January 15, 1996  
County: Escambia  
Latitude/Longitude: 33°32'58"N/87°13'44"W  
Project: Crist Boilers 1, 2, 3

This permit is issued under the provisions of Section 403.087, Florida Statutes, and Florida Administrative Code Rules 17-296, 17-297 and 17-4. The above named applicant, hereinafter called Permittee, is hereby authorized to perform the work or operate the facility shown on the application and approved drawing(s), plans, and other documents attached hereto or on file with the Department and made a part hereof and specifically described as follows:

Operation of Boilers 1, 2, and 3 with maximum rated heat inputs of 320, 320, and 550 MMBtu/hour, respectively. These boilers are primarily fueled with natural gas, with fuel oil as a standby fuel. Emissions are generally controlled by proper combustion; when operating with fuel oil, SO<sub>2</sub> emissions are controlled by the sulfur content of the fuel oil.

Operation of this source shall be consistent with the operation permit application dated April 15, 1994.

Located at the Crist Plant, Governor's Bayou, north of Pensacola.

Specific Condition No. 2 establishes maximum allowable operating and testing rates.

Specific Condition No. 6 establishes emission limits.

Specific Condition No. 7 establishes compliance testing requirements.

Specific Condition No. 9 requires submission of an annual operation report.

Specific Condition No. 10 requires submission of a Major Air Pollution Source Annual Operation Fee Form.

Specific Condition No. 11 requires submission of a Title V renewal application.

PERMITTEE:  
Gulf Power Company.

I.D. Number: 10PEN17004501,02,03  
Permit/Certification Number: AO17-249656  
Date of Issue: May 19, 1994  
Expiration Date: January 15, 1996

**SPECIFIC CONDITIONS:**

General

1. The attached General Conditions are part of this permit. (FAC Rule 17-4.160)

Operation

2. The maximum allowable operating rates are 320, 320, and 550 MMBtu heat input per hour for Boiler 1, 2, and 3, respectively. These are the operating rates at which compliance with standards shall be demonstrated. Testing of emissions shall be conducted with the sources operating at capacity. Capacity is defined as 90 to 100% of rated capacity. If it is impracticable to test at capacity, then sources may be tested at less than capacity; if the sources are tested at less than capacity, subsequent source operation is limited to 110% of the test load until a new test is conducted. Once a unit is so limited, then operation at higher capacity is allowed for no more than fifteen days for purposes of additional compliance testing to regain the rated capacity in the permit, with prior notification to the Department. (FAC Rule 17-4.070)

3. The maximum hours of operation are 24 hours/day, 7 days/week, and 52 weeks/year. The Permittee shall maintain an operation log available for Department inspection certifying the total hours of operation annually. (Application dated April 15, 1994)

4. The maximum sulfur content of the back up fuel oil is limited to that percentage necessary to meet the SO<sub>2</sub> emission limit of 1.98 lbs/MMBtu heat input. The Permittee shall maintain a log available for Department inspection of the fuel oil sulfur content. (FAC Rule 17-4.070)

5. Satisfactory ladders, platforms, and other safety devices as well as necessary parts shall be provided, maintained, and made available as necessary to facilitate compliance inspections. (FAC Rule 17-297.345)

Emissions

6. The maximum allowable emission limit for each pollutant is as follows:

<u>Pollutant</u>	<u>FAC Rule</u>	<u>Allowable Emissions</u>
VE	17-296.405	20% opacity *
PM	17-296.405	0.1 lb/MMBtu heat input
SO <sub>2</sub>	17-296.405	1.98 lbs/MMBtu heat input

\* except for one two-minute period/hour of up to 40% percent opacity

PERMITTEE:

Gulf Power Company

I.D. Number: 10PEN17004501,02,03

Permit/Certification Number: AO17-249656

Date of Issue: May 19, 1994

Expiration Date: January 15, 1996

**SPECIFIC CONDITIONS:**

Testing

7. Emissions tests for the following pollutants shall be performed between October 1 and November 30, in accordance with the test methods and frequency indicated, with notification to the Department 15 days prior to testing. The test results must provide reasonable assurance that the source is capable of compliance at the permitted maximum operating rate. For good cause, the Permittee may request an extension of a compliance test due date. However, inadequate planning of testing does not constitute good cause for an extension of the compliance test due date. The test report documentation must be submitted to the Department within 45 days after completion of testing.

<u>Pollutant</u>	<u>Frequency</u>	<u>Test Method</u>	<u>Reference</u>
VE	annually	DEP No. 9	FAC Rule 17-296.405
	annually during excess emissions when applicable	DEP No. 9	
PM	annually	EPA No. 5	FAC Rule 17-296.405
	annually during excess emissions when applicable	EPA No. 5	FAC Rule 17-296.405

No particulate emissions test is required in any year during which the specific source did not burn fuel oil for more than 400 hours other than during startup.

The VE test shall be for a duration of sixty minutes and shall be conducted during one of the P.M. test runs if a P.M. test is conducted. Test reports shall comply with F.A.C. Rule 17-297.570, Test Reports. The Department can require special compliance tests in accordance with F.A.C. Rule 17-297.340(2).

Administrative

8. Boilers 1, 2, 3, 4 and 5 use a common stack. Visible emissions violations from this stack shall be attributed to all boilers unless the opacity meter results identify the specific boiler causing the excess visible emissions.

9. An annual operation report [DEP Form 17-210.900(4) attached] shall be submitted by March 1 each year. The attached form shall be reproduced by the Permittee and used for future annual submittals. (FAC Rule 17-210.370)

PERMITTEE:

Gulf Power Company

I.D. Number: 10PEN17004501,02,03  
Permit/Certification Number: AO17-249656  
Date of Issue: May 19, 1994  
Expiration Date: January 15, 1996

SPECIFIC CONDITIONS:

10. In accordance with F.A.C. Rule 17-213, a Major Air Pollution Source Annual Operation Fee Form (DEP Form 17-213.900(11) attached) must be completed and submitted with appropriate fee between January 15 and March 1 of each year. If the Department has not received the fee payment by March 1, the Department shall impose, in addition to the fee, a penalty of 50 percent of the amount of the fee, plus interest on such amount computed in accordance with s.220.807, Florida Statutes. The Department may revoke any major air pollution source operation permit if it finds that the permit holder has failed to pay timely and required annual operation license fee, penalty or interest. The attached form shall be reproduced by the Permittee and used for future annual submittals. The completed form and appropriate fees must be submitted to the Department of Environmental Protection, Title V (Facility I.D. Number), 2600 Blair Stone Road, Tallahassee, Florida 32399-2400.

11. An application to renew this permit shall be submitted as required for a Title V permit. (FAC Rule 17-210)

12. The permanent source identification numbers for these point sources are:

10PEN17004501 - Boiler 1  
10PEN16004502 - Boiler 2  
10PEN17004503 - Boiler 3

Please cite these numbers on all test reports and other correspondence specific to these permitted point sources. (FAC Rule 17-297.570)

13. The Department telephone number for reporting problems, malfunctions or exceedances under this permit is (904) 444-8300, day or night, and for emergencies involving a significant threat to human health or the environment is (904) 488-1320. For routine business, use telephone number (904) 444-8300 during normal working hours. (FAC Rule 17-210.700)

Expiration Date:

Issued this 19<sup>th</sup> day of May  
1994.

January 15, 1996

STATE OF FLORIDA DEPARTMENT  
OF ENVIRONMENTAL PROTECTION

  
BOBBY A. COOLEY  
District Director

PERMITTEE:  
Gulf Power Company.

I.D. Number: 10PEN17004501,02,03  
Permit/Certification Number: AO17-249656  
Expiration Date: January 15, 1996

**GENERAL CONDITIONS:**

1. The terms, conditions, requirements, limitations, and restrictions set forth in this permit are "permit conditions", and are binding and enforceable pursuant to Sections 403.141, 403.727, or 403.859 through 403.861, Florida Statutes. The Permittee is placed on notice that the Department will review this permit periodically and may initiate enforcement action for any violation of these conditions.

2. This permit is valid only for the specific processes and operations applied for and indicated in the approved drawings or exhibits. Any unauthorized deviation from the approved drawings, exhibits, specifications, or conditions of this permit may constitute grounds for revocation and enforcement action by the Department.

3. As provided in Subsections 403.087(6) and 403.722(5), Florida Statutes, the issuance of this permit does not convey any vested rights or any exclusive privileges. Nor does it authorize any injury to public or private property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations. This permit does not constitute a waiver of or approval of any other Department permit that may be required for other aspects of the total project which are not addressed in the permit.

4. This permit conveys no title to land or water, does not constitute state recognition or acknowledgment of title, and does not constitute authority for the use of submerged lands unless herein provided and the necessary title or leasehold interests have been obtained from the state. Only the Trustees of the Internal Improvement Trust Fund may express state opinion as to title.

5. This permit does not relieve the Permittee from liability for harm or injury to human health or welfare, animal, or plant life, or property caused by the construction or operation of this permitted source, or from penalties therefore; nor does it allow the Permittee to cause pollution in contravention of Florida Statutes and Department rules, unless specifically authorized by an order from the Department.

6. The Permittee shall properly operate and maintain the facility and systems of treatment and control (and related appurtenances) that are installed and used by the Permittee to achieve compliance with the conditions of this permit, are required by Department rules. This provision includes the operation of backup or auxiliary facilities or similar systems when necessary to achieve compliance with the conditions of the permit and when required by Department rules.

7. The Permittee, by accepting this permit, specifically agrees to allow authorized Department personnel, upon presentation of credentials or other documents as may be required by law, access to the premises, at reasonable times, where the permitted activity is located or conducted for the purpose of:

a. Having access to and copying any records that must be kept under the conditions of this permit;

b. Inspecting the facility, equipment, practices, or operations regulated or required under this permit; and,

PERMITTEE:  
Gulf Power Company.

I.D. Number: 10PEN17004501,02,03  
Permit/Certification Number: AO17-249656  
Expiration Date: January 15, 1996

**GENERAL CONDITIONS:**

c. Sampling or monitoring any substances or parameters at any location reasonably necessary to assure compliance with this permit or Department rules.

Reasonable time may depend on the nature of the concern being investigated.

8. If, for any reason, the Permittee does not comply with or will be unable to comply with any condition or limitation specified in this permit, the Permittee shall immediately provide the Department with the following information:

a. A description of and cause of noncompliance; and

b. The period of noncompliance, including exact dates and times; or, if not corrected, the anticipated time the noncompliance is expected to continue, and steps being taken to reduce, eliminate, and prevent recurrence of the noncompliance. The Permittee shall be responsible for any and all damages which may result and may be subject to enforcement action by the Department for penalties or for revocation of this permit.

9. In accepting this permit, the Permittee understands and agrees that all records, notes, monitoring data and other information relating to the construction or operation of this permitted source which are submitted to the Department may be used by the Department as evidence in any enforcement case involving the permitted source arising under the Florida Statutes or Department rules, except where such use is proscribed by Sections 403.73 and 403.111, Florida Statutes. Such evidence shall only be used to the extent it is consistent with Florida Rules of Civil Procedure and appropriate evidentiary rules.

10. The Permittee agrees to comply with changes in Department rules and Florida Statutes after a reasonable time for compliance, provided however, the Permittee does not waive any other rights granted by Florida Statutes or Department rules.

11. This permit is transferable only upon Department approval in accordance with Florida Administrative Code Rules 17-4.120 and 17-730.300, as applicable. The Permittee shall be liable for any noncompliance of the permitted activity until the transfer is approved by the Department.

12. This permit is required to be kept at the work site of the permitted activity during the entire period of construction or operation.

13. The Permittee shall comply with the following:

a. Upon request, the Permittee shall furnish all records and plans required under Department rules. During enforcement actions, the retention period for all records will be extended automatically unless otherwise stipulated by the Department.

b. The Permittee shall hold at the facility or other location designated by this permit records of all monitoring information (including all calibration and maintenance records and all original strip chart recordings for continuous

PERMITTEE:  
Gulf Power Company

I.D. Number: 10PEN17004501,02,03  
Permit/Certification Number: AO17-249656  
Expiration Date: January 15, 1996

**GENERAL CONDITIONS:**

monitoring instrumentation) required by the permit, copies of all reports required by this permit, and records of all data used to complete the application for this permit. These materials shall be retained at least three years from the date of the sample, measurement, report or application unless otherwise specified by Department rule.

**c. Records of monitoring information shall include:**

- the date, exact place, and time of sampling or measurement;
- the person responsible for performing the sampling or measurement;
- the date(s) analyses were performed;
- the person responsible for performing the analyses;
- the analytical techniques or methods used; and
- the results of such analyses.

14. When requested by the Department, the Permittee shall within a reasonable time furnish any information required by law which is needed to determine compliance with the permit. If the Permittee becomes aware the relevant facts were not submitted or were incorrect in the permit application or in any report to the Department, such facts or information shall be corrected promptly.



STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
NOTICE OF PERMIT ISSUANCE

CERTIFIED MAIL

In the matter of an  
Application for Permit

DEP File No. AO17-249656  
Escambia County

By:  
M. L. Gilchrist  
Manager of Fuel & Environmental Affairs  
Gulf Power Company  
Post Office Box 1151  
Pensacola, Florida 32520-0328

Enclosed is Permit Number AO17-249656 to operate Crist Boiler Units 1, 2 and 3, issued pursuant to Section 403.087, Florida Statutes.

A person whose substantial interests are affected by this permit may petition for an administrative proceeding (hearing) in accordance with Section 120.57, Florida Statutes. The petition must contain the information set forth below and must be filed (received) in the Office of General Counsel of the Department at 2600 Blair Stone Road, Tallahassee 32399-2400, within 14 days of receipt of this Permit. Petitioner shall mail a copy of the petition to the applicant at the address indicated above at the time of filing. Failure to file a petition within this time period shall constitute a waiver of any right such person may have to request an administrative determination (hearing) under Section 120.57, Florida Statutes.

The Petition shall contain the following information;

(a) The name, address, and telephone number of each petitioner, the applicant's name and address, the Department Permit File Number and the county in which the project is proposed;

(b) A statement of how and when each petitioner received notice of the Department's action or proposed action;

(c) A statement of how each petitioner's substantial interests are affected by the Department's action or proposed action;

(d) A statement of the material facts disputed by petitioner, if any;

(e) A statement of facts which petitioner contends warrant reversal or modification of the Department's action or proposed action;

(f) A statement of which rules or statutes petitioner contends require reversal or modification of the Department's action or proposed action; and

(g) A statement of the relief sought by petitioner, stating precisely the action petitioner wants the Department to take with respect to the Department's action or proposed action.

If a petition is filed, the administrative hearing process is designed to formulate agency action. Accordingly, the Department's final action may be different from the position taken by it in this permit. Persons whose

substantial interests will be affected by any decision of the Department with regard to the application have the right to petition to become a party to the proceeding. The petition must conform to the requirements specified above and be filed (received) within 21 days of receipt of this notice in the Office of General Counsel at the above address of the Department. Failure to petition within the allowed time frame constitutes a waiver of any right such person has to request a hearing under Section 120.57, Florida Statutes, and to participate as a party to this proceeding. Any subsequent intervention will only be at the approval of the presiding officer upon motion filed pursuant to Rule 28-5.207, F.A.C.

This permit is final and effective on the date filed with the Clerk of the Department unless a petition is filed in accordance with the above paragraphs or unless a request for extension of time in which to file a petition is filed within the time specified for filing a petition and conforms to Rule 17-103.070, F.A.C. Upon timely filing of a petition or a request for an extension of time this permit will not be effective until further Order of the Department.

When the Order (Permit) is final, any party to the Order has the right to seek judicial review of the Order pursuant to Section 120.68, Florida Statutes, by the filing of a Notice of Appeal pursuant to Rule 9.110, Florida Rules of Appellate Procedure, with the Clerk of the Department in the Office of General Counsel, 2600 Blair Stone Road, Tallahassee, Florida 32399-2400; and by filing a copy of the Notice of Appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal. The Notice of Appeal must be filed within 30 days from the date the Final Order is filed with the Clerk of the Department.

Executed in Pensacola, Florida.

State of Florida Department  
of Environmental Protection

  
BOBBY A. COOLEY  
District Director


160 Governmental Center  
Pensacola, Florida 32501-5794  
(904) 444-8300

#### CERTIFICATE OF SERVICE

The undersigned duly designated deputy agency clerk hereby certifies that this NOTICE OF PERMIT ISSUANCE and all copies were mailed by certified mail before the close of business on MAY 20, 1994 to the listed persons.

FILING AND ACKNOWLEDGMENT FILED,  
on this date, pursuant to §120.52(9),  
Florida Statutes, with the designated  
Department clerk, receipt of which is  
hereby acknowledged.

  
Clerk  
5/20/94  
Date



**STATE OF FLORIDA  
DEPARTMENT OF  
ENVIRONMENTAL REGULATION**

GULF POWER COMPANY  
BOILER #1 - CRIST  
ESCAMBIA COUNTY

**OPERATION  
PERMIT**


**NO.** A017-91467

**DATE OF ISSUANCE**

October 5, 1984

**DATE OF EXPIRATION**

September 1, 1989



Robert V. Kriegel  
District Manager

STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL REGULATION



**ORTHWEST DISTRICT**

160 GOVERNMENTAL CENTER  
PENSACOLA, FLORIDA 32501-5794

BOB GRAHAM  
GOVERNOR

VICTORIA J. TSCHINKEL  
SECRETARY

ROBERT V. KRIEDEL  
DISTRICT MANAGER

**PERMITTEE:**

Gulf Power Company

I.D. Number: 10/17/0045/01

Permit/Certification Number: A017-91467

Date of Issue: October 5, 1984

Expiration Date: September 1, 1989

County: Escambia

Latitude/Longitude: 33°33'58"N/87°13'44"W

Section/Township/Range: 25/1N/30W

Project: Boiler #1 - Crist

This permit is issued under the provisions of Chapter 403, Florida Statutes, and Florida Administrative Code Rules 17-2 and 17-4. The above named applicant, hereinafter called Permittee, is hereby authorized to perform the work or operate the facility shown on the application and approved drawing(s), plans, and other documents attached hereto or on file with the department and made a part hereof and specifically described as follows:

Operation of Boiler #1. Fueled with natural gas, with #6 fuel oil as a standby fuel. Maximum heat input is 320 million BTU/hour. Emits through a 450 foot high stack used in common by Boilers #1 through #5.

Located: Crist Plant, Governor's Bayou, Pensacola

PERMITTEE:  
Gulf Power Company

I.D. Number: 10/17/0045/01  
Permit/Certification Number: A017-91467  
Date of Issue: October 5, 1984

Expiration Date: September 1, 1989

GENERAL CONDITIONS:

7. The permittee, by accepting this permit, specifically agrees to allow authorized department personnel, upon presentation of credentials or other documents as may be required by law, access to the premises, at reasonable times, where the permitted activity is located or conducted for the purpose of:

- a. Having access to and copying any records that must be kept under the conditions of the permit;
- b. Inspecting the facility, equipment, practices, or operations regulated or required under this permit; and
- c. Sampling or monitoring any substances or parameters at any location reasonably necessary to assure compliance with this permit or department rules.

Reasonable time may depend on the nature of the concern being investigated.

8. If, for any reason, the permittee does not comply with or will be unable to comply with any condition or limitation specified in this permit, the permittee shall immediately notify and provide the department with the following information:

- a. A description of and cause of noncompliance; and
- b. The period of noncompliance, including exact dates and times; or, if not corrected, the anticipated time the noncompliance is expected to continue, and steps being taken to reduce, eliminate, and prevent recurrence of the noncompliance.

The permittee shall be responsible for any and all damages which may result and may be subject to enforcement action by the department for penalties or revocation of this permit.

9. In accepting this permit, the permittee understands and agrees that all records, notes, monitoring data and other information relating to the construction or operation of this permitted source, which are submitted to the department, may be used by the department as evidence in any enforcement case arising under the Florida Statutes or department rules, except where such use is proscribed by Sections 403.73 and 403.111, Florida Statutes.

PERMITTEE:  
Gulf Power Company

I.D. Number: 10/17/0045/01  
Permit/Certification Number: A017-91467  
Date of Issue: October 5, 1984

Expiration Date: September 1, 1989

GENERAL CONDITIONS:

14. When requested by the department, the permittee shall within a reasonable time furnish any information required by law which is needed to determine compliance with the permit. If the permittee becomes aware that relevant facts were not submitted or were incorrect in the permit application or in any report to the department, such facts or information shall be submitted or corrected promptly.

SPECIFIC CONDITIONS:

15. The maximum allowable heat input is 320 million BTU per hour. This is the heat input at which compliance with standards shall be demonstrated.

16. Particulates emissions shall be no greater than 0.1 pounds per million BTU of heat input. Sulfur oxide emissions shall be no greater than 1.88 pounds per million BTU of heat input. Visible emissions shall be no greater than 20% opacity except that 40% opacity shall be permissible for not more than two minutes in any one hour.

17. A particulates test is required to show continuing compliance with the standards of the Department. The test results shall show compliance at the permitted operating rate. Such test results shall be obtained once per year in accordance with Condition 18 and shall be submitted to: Department of Environmental Regulation, 160 Governmental Center, Pensacola, Florida 32501-5794. The Department shall be notified prior to testing to allow witnessing.

18. Stack testing is waived as long as fuel oil constitutes less than 10% of the annual heat input, and that continuous monitoring data show testing to be unnecessary.

19. Boilers #1, #2, #3, #4 and #5 use a common stack. Visible emission violations from this stack shall be attributed to all boilers unless opacity meter results show the specific boiler causing the violation.

20. The following continuous monitoring record keeping and reporting is required:

A. A log shall be maintained showing daily entries (including "none" or "zero") of:

PERMITTEE:  
Gulf Power Company

I.D. Number: 10/17/0045/01  
Permit/Certification Number: A017-91467  
Date of Issue: October 5, 1984

Expiration Date: September 1, 1989


SPECIFIC CONDITIONS:

Expiration Date:



September 1, 1989

Issued this 5th day of Oct,  
1984.

STATE OF FLORIDA DEPARTMENT  
OF ENVIRONMENTAL REGULATION

  
ROBERT V. KRIEGEL  
District Manager

Crist  
2



STATE OF FLORIDA  
DEPARTMENT OF  
ENVIRONMENTAL REGULATION

GULF POWER COMPANY  
BOILER #2 - CRIST  
ESCAMBIA COUNTY

OPERATION  
PERMIT

NO. AO17-91469

DATE OF ISSUANCE

October 4, 1984

DATE OF EXPIRATION

September 1, 1989

Robert V. Kriegel  
District Manager



STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL REGULATION

ORTHWEST DISTRICT

160 GOVERNMENTAL CENTER  
PENSACOLA, FLORIDA 32501-5794



BOB GRAHAM  
GOVERNOR

VICTORIA J. TSCHINKEL  
SECRETARY

ROBERT V. KRIEGLER  
DISTRICT MANAGER

PERMITTEE:

Gulf Power Company

I.D. Number: 10/17/0045/02

Permit/Certification Number: A017-91469

Date of Issue: October 4, 1984

Expiration Date: September 1, 1989

County: Escambia

Latitude/Longitude: 33°33'58"N/87°13'44"W

Section/Township/Range: 25/1N/30W

Project: Boiler #2 - Crist

This permit is issued under the provisions of Chapter 403, Florida Statutes, and Florida Administrative Code Rules 17-2 and 17-4. The above named applicant, hereinafter called Permittee, is hereby authorized to perform the work or operate the facility shown on the application and approved drawing(s), plans, and other documents attached hereto or on file with the department and made a part hereof and specifically described as follows:

Operation of Boiler #2. Fueled with natural gas, with #6 fuel oil as a standby fuel. Maximum heat input is 320 million BTU/hour. Emits through a 450 foot high stack used in common by Boilers #1 through #5.

Located: Crist Plant, Governor's Bayou, Pensacola

PERMITTEE:  
Gulf Power Company

I.D. Number: 10/17/0045/02  
Permit/Certification Number: A017-91469  
Date of Issue: October 4, 1984

Expiration Date: September 1, 1989

GENERAL CONDITIONS:

7. The permittee, by accepting this permit, specifically agrees to allow authorized department personnel, upon presentation of credentials or other documents as may be required by law, access to the premises, at reasonable times, where the permitted activity is located or conducted for the purpose of:

- a. Having access to and copying any records that must be kept under the conditions of the permit;
- b. Inspecting the facility, equipment, practices, or operations regulated or required under this permit; and
- c. Sampling or monitoring any substances or parameters at any location reasonably necessary to assure compliance with this permit or department rules.

Reasonable time may depend on the nature of the concern being investigated.

8. If, for any reason, the permittee does not comply with or will be unable to comply with any condition or limitation specified in this permit, the permittee shall immediately notify and provide the department with the following information:

- a. A description of and cause of noncompliance; and
- b. The period of noncompliance, including exact dates and times; or, if not corrected, the anticipated time the noncompliance is expected to continue, and steps being taken to reduce, eliminate, and prevent recurrence of the noncompliance.

The permittee shall be responsible for any and all damages which may result and may be subject to enforcement action by the department for penalties or revocation of this permit.

9. In accepting this permit, the permittee understands and agrees that all records, notes, monitoring data and other information relating to the construction or operation of this permitted source, which are submitted to the department, may be used by the department as evidence in any enforcement case arising under the Florida Statutes or department rules, except where such use is proscribed by Sections 403.73 and 403.111, Florida Statutes.

## CRIST # 2

PERMITTEE:  
Gulf Power Company

I.D. Number: 10/17/0045/02  
Permit/Certification Number: A017-91469  
Date of Issue: October 4, 1984

Expiration Date: September 1, 1989

### GENERAL CONDITIONS:

14. When requested by the department, the permittee shall within a reasonable time furnish any information required by law which is needed to determine compliance with the permit. If the permittee becomes aware that relevant facts were not submitted or were incorrect in the permit application or in any report to the department, such facts or information shall be submitted or corrected promptly.

### SPECIFIC CONDITIONS:

15. The maximum allowable heat input is 320 million BTU per hour. This is the heat input at which compliance with standards shall be demonstrated.

16. Particulates emissions shall be no greater than 0.1 pounds per million BTU of heat input. Sulfur oxide emissions shall be no greater than 1.88 pounds per million BTU of heat input. Visible emissions shall be no greater than 20% opacity except that 40% opacity shall be permissible for not more than two minutes in any one hour.

17. A particulates test is required to show continuing compliance with the standards of the Department. The test results shall show compliance at the permitted operating rate. Such test results shall be obtained once per year in accordance with Condition 18 and shall be submitted to: Department of Environmental Regulation, 160 Governmental Center, Pensacola, Florida 32501-5794. The Department shall be notified prior to testing to allow witnessing.

18. Stack testing is waived as long as fuel oil constitutes less than 10% of the annual heat input, and that continuous monitoring data show testing to be unnecessary.

19. Boilers #1, #2, #3, #4 and #5 use a common stack. Visible emission violations from this stack shall be attributed to all boilers unless opacity meter results show the specific boiler causing the violation.

20. The following continuous monitoring record keeping and reporting is required:

A. A log shall be maintained showing daily entries (including "none" or "zero") of:

PERMITTEE:  
Gulf Power Company

I.D. Number: 10/17/0045/02  
Permit/Certification Number: A017-91469  
Date of Issue: October 4, 1984

Expiration Date: September 1, 1989


SPECIFIC CONDITIONS:

Expiration Date:



September 1, 1989

Issued this 4th day of Oct,  
1984.

STATE OF FLORIDA DEPARTMENT  
OF ENVIRONMENTAL REGULATION

  
ROBERT V. KRIEDEL  
District Manager

**CRIST**  
**3**



**STATE OF FLORIDA**  
**DEPARTMENT OF**  
**ENVIRONMENTAL REGULATION**

GULF POWER COMPANY  
BOILER #3 - CRIST  
ESCAMBIA COUNTY

**OPERATION**  
**PERMIT**

**NO.** A017-91470

**DATE OF ISSUANCE**


October 4, 1984

**DATE OF EXPIRATION**

September 1, 1989

Robert V. Kriegel  
District Manager

STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL REGULATION



BOB GRAHAM  
GOVERNOR  
VICTORIA J. TSCHINKEL  
SECRETARY  
ROBERT V. KRIEGLER  
DISTRICT MANAGER

**NORTHWEST DISTRICT**

160 GOVERNMENTAL CENTER  
PENSACOLA, FLORIDA 32501-5794

**PERMITTEE:**

Gulf Power Company

I.D. Number: 10/17/0045/03  
Permit/Certification Number: A017-91470  
Date of Issue: October 4, 1984

Expiration Date: September 1, 1989  
County: Escambia  
Latitude/Longitude: 33°33'58"N/87°13'44"W  
Section/Township/Range: 25/1N/30W  
Project: Boiler #3 - Crist

This permit is issued under the provisions of Chapter 403, Florida Statutes, and Florida Administrative Code Rules 17-2 and 17-4. The above named applicant, hereinafter called Permittee, is hereby authorized to perform the work or operate the facility shown on the application and approved drawing(s), plans, and other documents attached hereto or on file with the department and made a part hereof and specifically described as follows:

Operation of Boiler #3. Fueled with natural gas, with #6 fuel oil as a standby fuel. Maximum heat input is 550 million BTU/hour. Emits through a 450 foot high stack used in common by Boilers #1 through #5.

Located: Crist Plant, Governor's Bayou, Pensacola

PERMITTEE:  
Gulf Power Company

I.D. Number: 10/17/0045/03  
Permit/Certification Number: A017-91470  
Date of Issue: October 4, 1984

Expiration Date: September 1, 1989

GENERAL CONDITIONS:

7. The permittee, by accepting this permit, specifically agrees to allow authorized department personnel, upon presentation of credentials or other documents as may be required by law, access to the premises, at reasonable times, where the permitted activity is located or conducted for the purpose of:

- a. Having access to and copying any records that must be kept under the conditions of the permit;
- b. Inspecting the facility, equipment, practices, or operations regulated or required under this permit; and
- c. Sampling or monitoring any substances or parameters at any location reasonably necessary to assure compliance with this permit or department rules.

Reasonable time may depend on the nature of the concern being investigated.

8. If, for any reason, the permittee does not comply with or will be unable to comply with any condition or limitation specified in this permit, the permittee shall immediately notify and provide the department with the following information:

- a. A description of and cause of noncompliance; and
- b. The period of noncompliance, including exact dates and times; or, if not corrected, the anticipated time the noncompliance is expected to continue, and steps being taken to reduce, eliminate, and prevent recurrence of the noncompliance.

The permittee shall be responsible for any and all damages which may result and may be subject to enforcement action by the department for penalties or revocation of this permit.

9. In accepting this permit, the permittee understands and agrees that all records, notes, monitoring data and other information relating to the construction or operation of this permitted source, which are submitted to the department, may be used by the department as evidence in any enforcement case arising under the Florida Statutes or department rules, except where such use is proscribed by Sections 403.73 and 403.111, Florida Statutes.

PERMITTEE:  
Gulf Power Company

I.D. Number: 10/17/0045/03  
Permit/Certification Number: AO17-91470  
Date of Issue: October 4, 1984

Expiration Date: September 1, 1989

GENERAL CONDITIONS:

14. When requested by the department, the permittee shall within a reasonable time furnish any information required by law which is needed to determine compliance with the permit. If the permittee becomes aware that relevant facts were not submitted or were incorrect in the permit application or in any report to the department, such facts or information shall be submitted or corrected promptly.

SPECIFIC CONDITIONS:

15. The maximum allowable heat input is 550 million BTU per hour. This is the heat input at which compliance with standards shall be demonstrated.

16. Particulates emissions shall be no greater than 0.1 pounds per million BTU of heat input. Sulfur oxide emissions shall be no greater than 1.88 pounds per million BTU of heat input. Visible emissions shall be no greater than 20% opacity except that 40% opacity shall be permissible for not more than two minutes in any one hour.

17. A particulates test is required to show continuing compliance with the standards of the Department. The test results shall show compliance at the permitted operating rate. Such test results shall be obtained once per year in accordance with Condition 18 and shall be submitted to: Department of Environmental Regulation, 160 Governmental Center, Pensacola, Florida 32501-5794. The Department shall be notified prior to testing to allow witnessing.

18. Stack testing is waived as long as fuel oil constitutes less than 10% of the annual heat input, and that continuous monitoring data show testing to be unnecessary.

19. Boilers #1, #2, #3, #4 and #5 use a common stack. Visible emission violations from this stack shall be attributed to all boilers unless opacity meter results show the specific boiler causing the violation.

20. The following continuous monitoring record keeping and reporting is required:

A. A log shall be maintained showing daily entries (including "none" or "zero") of:



PERMITTEE:  
Gulf Power Company

I.D. Number: 10/17/0045/03  
Permit/Certification Number: A017-91470  
Date of Issue: October 4, 1984


Expiration Date: September 1, 1989


SPECIFIC CONDITIONS:

Expiration Date:  
September 1, 1989

Issued this 4th day of Oct,  
1984.

STATE OF FLORIDA DEPARTMENT  
OF ENVIRONMENTAL REGULATION

  
\_\_\_\_\_  
ROBERT V. KRIEDEL  
District Manager



# Florida Department of Environmental Regulation

Northwest District • 160 Governmental Center • Pensacola, Florida 32501-5794

Lawton Chiles, Governor

Carol M. Browner, Secretary

**PERMITTEE:**

Gulf Power Company

I.D. Number: 10PEN17004504 and 05  
Permit/Certification Number: A017-211303  
Date of Issue: April 17, 1992

Expiration Date: April 1, 1997  
County: Escambia  
Latitude/Longitude: 30°33'57"N/87°13'29.5"W  
Section/Township/Range: 25/1N/30W  
Project: Crist Units No. 4 and No. 5  
Coal Fired Boilers

This permit is issued under the provisions of Section 403.087, Florida Statutes, and Florida Administrative Code Rules 17-2 and 17-4. The above named applicant, hereinafter called Permittee, is hereby authorized to perform the work or operate the facility shown on the application and approved drawing(s), plans, and other documents attached hereto or on file with the Department and made a part hereof and specifically described as follows:

Operation of Crist Units No. 4 and No. 5, both coal fired boilers, generating 91 megawatts of electricity each. Particulate emissions from each Unit are controlled by hot side electrostatic precipitators manufactured by Buell Model BAL .2X34N333-4-3P followed by cold side electrostatic precipitators manufactured by Buell Model 1.1X48K33-1P. Sulfur dioxide emissions are controlled by the sulfur content of the coal used as fuel. Sulfur dioxide, nitrogen dioxide, oxygen and opacity are monitored by continuous emission monitors on each Unit.

Located at the east end of Pate Road, off Ten Mile Road, two miles east of State Road 292, north of Pensacola.

Specific Condition No. 7 requires logging excess emissions.  
Specific Condition No. 8 requires keeping a maintenance log.  
Specific Condition No. 9 requires submitting quarterly excess emissions reports.  
Specific Condition No. 11 requires annual particulate emissions tests due before the end of September.  
Specific Condition No. 12 requires maintenance of a QC program.  
Specific Condition No. 14 requires reporting of excess emissions as soon as possible.  
Specific Condition No. 15 requires actions taken upon particulate test failures.  
Specific Condition No. 18 requires submittal of permit renewal application by February 1, 1997.

PERMITTEE:  
Gulf Power Company

I.D. Number: 10PEN17004504 and 05  
Permit/Certification Number: A017-211303  
Date of Issue: April 17, 1992

Expiration Date: April 1, 1997

SPECIFIC CONDITIONS:

1. The attached General Conditions are part of this permit.
2. The maximum allowable heat inputs are those heat inputs necessary to maintain electrical load output at 110% of the level at which the most recent successful particulate emissions compliance test was conducted for each unit. If the test was conducted at less than 90% of rated capacity of the unit, permittee may operate the unit at loads up to the rated capacity (91 megawatts for each unit) for purposes of preparation for testing for up to ten calendar days. The Department shall be advised in writing prior to each testing.
3. Particulate emissions shall not exceed 0.1 pounds per million Btu heat input.
4. Sulfur dioxide emissions shall not exceed 5.90 pounds per million Btu heat input.
5. Visible emissions shall not exceed 40% opacity.
6. Excess emissions are defined as:
  - A. Any six-minute average for opacity which exceeds the standard.
  - B. Any 24-hour average for sulfur dioxide which exceeds the standard.
7. A log shall be maintained showing the:
  - A. Duration of excess visible emissions and their causes.
  - B. Duration of excess SO<sub>2</sub> emissions.
8. A maintenance log of the continuous monitoring system shall be kept showing:
  - A. Time out of service.
  - B. Calibrations and adjustments.
9. A quarterly report of excess emissions shall be submitted within 30 days following the end of each calendar quarter. The report shall consist of each individual exceedance of opacity or SO<sub>2</sub> emissions (Specific Conditions 6 and 7) with duration, magnitude and cause. Any exceedance that is beyond the allowances of FAC Rule 17-2.250 shall be highlighted with note indicating compliance with Specific Condition 14 below.
10. Units 4 and 5 use a common stack (along with Units 1, 2 and 3). Visible emission violations from this stack shall be attributed to both Units unless opacity meter results show the specific Unit causing the violation.

PERMITTEE:  
Gulf Power Company

I.D. Number: 10PEN17004504 and 05  
Permit/Certification Number: A017-211303  
Date of Issue: April 17, 1992

Expiration Date: April 1, 1997

SPECIFIC CONDITIONS:

11. Particulate emissions tests are required to show continuing compliance with the standards of the Department. The test results must provide reasonable assurance that the source is capable of compliance at the permitted maximum operating rate. Tests shall be conducted in accordance with EPA methods 1, 2, 3 and 17. Such tests shall be conducted once per year before the end of September. Results shall be submitted to the Department within 45 days after testing. The Department shall be notified at least 15 days prior to testing to allow witnessing.

12. Continuous SO<sub>2</sub> emission monitoring 24-hour averages are required to demonstrate compliance with the standard of the Department (Specific Condition 4). A valid 24-hour average shall consist of no less than 18 hours of valid data capture per calendar day. In the event that valid data capture is not available, the permittee shall initiate as-fired fuel sampling to demonstrate compliance with the SO<sub>2</sub> emission standard. The as-fired fuel sampling shall be initiated no later than 36 hours after the permittee has verified the problem or no later than 36 hours after the end of the affected calendar day. Fuel sampling shall continue until such time as the valid data capture is restored. In lieu of as-fired fuel sampling the permittee may elect to demonstrate SO<sub>2</sub> emission compliance by the temporary use of a spare SO<sub>2</sub> emission monitor. The spare SO<sub>2</sub> emissions monitor must be installed and collecting data in the same time frame as required above for as-fired fuel sampling.

Maintain a QC program. As a minimum the QC program must include written procedures which should describe in detail complete, step-by-step procedures and operations for each of the following activities:

1. Calibration of CEMS.
2. CD determination and adjustment of CEMS.
3. Preventative maintenance of CEMS (including spare parts inventory).
4. Data recording, calculations and reporting.
5. Accuracy audit procedures including sampling and analysis methods.
6. Program of corrective action for malfunctioning CEMS.

13. Excess emissions as stated in Florida Administrative Code Rule 17-2.250 shall be allowed.

14. The Department shall be notified as soon as possible (by telephone) of excess emissions that are beyond the allowances of FAC Rule 17-2.250, such as:

A. Any soot blowing or load changes that cause excess visible emissions for a period longer than three hours, or that exceed 60% opacity (six minute average) more than four times in any one day.

B. Any malfunction that causes visible emissions for a period longer than two hour in any one day.

C. A 24-hour average of SO<sub>2</sub> emissions measured by the continuous monitor that exceeds the standard, or daily average SO<sub>2</sub> emissions measured by coal analysis (in the event the permittee chooses) that exceeds the standard.

Immediately upon notification of excess emissions that are beyond the allowances, the permittee shall take the necessary steps to determine the cause and arrange a meeting with the Department within 72 hours to discuss a settlement of the violation with corrective action to avoid recurrence.

PERMITTEE:  
Gulf Power Company

I.D. Number: 10PEN17004504 and 05  
Permit/Certification Number: AO17-211303  
Date of Issue: April 17, 1992

Expiration Date: April 1, 1997

SPECIFIC CONDITIONS:

15. Immediately upon notification of a particulate test report that fails to demonstrate compliance with the particulate emission limit of 0.1 pounds per million Btu heat input, the permittee shall take necessary steps to determine the cause of the test failure and arrange a meeting with the Department within 72 hours to discuss a settlement of the violation and a schedule for retesting when the cause of the test failure has been determined and corrected.

16. An annual operation report (DER Form 17-1.202(6) attached) shall be submitted by March 1 each year. The attached form shall be reproduced by the permittee and used for future annual submittals.

17. An application to renew this permit shall be submitted prior to February 1, 1997.

18. The permanent source identification numbers for these point sources are:  
10PEN17004504 Crist Unit No. 4, and  
10PEN17004505 Crist Unit No. 5.

Please cite the appropriate number on all test reports and other correspondence specific to a permitted point source.


19. The Department telephone number for reporting problems, malfunctions or exceedances under this permit is (904) 436-8300, day or night, and for emergencies involving a significant threat to human health or the environment is (904) 488-1320. For routine business, telephone (904) 436-8364 during normal working hours.

Expiration date:

April 1, 1997

Issued this 17th day of April,  
1992.

STATE OF FLORIDA DEPARTMENT  
OF ENVIRONMENTAL REGULATION

  
ROBERT V. KRIEGEL  
District Director

PERMITTEE:

Gulf Power Company

I.D. Number: 10PEN17004504 and 05

Permit/Certification Number: A017-211303

Date of Issue: April 17, 1992

Expiration Date: April 1, 1997

GENERAL CONDITIONS:

1. The terms, conditions, requirements, limitations, and restrictions set forth in this permit are "permit conditions", and are binding and enforceable pursuant to Sections 403.141, 403.727, or 403.859 through 403.861, Florida Statutes. The permittee is placed on notice that the Department will review this permit periodically and may initiate enforcement action for any violation of these conditions.
2. This permit is valid only for the specific processes and operations applied for and indicated in the approved drawings or exhibits. Any unauthorized deviation from the approved drawings, exhibits, specifications, or conditions of this permit may constitute grounds for revocation and enforcement action by the Department.
3. As provided in Subsections 403.087(6) and 403.722(5), Florida Statutes, the issuance of this permit does not convey any vested rights or any exclusive privileges. Nor does it authorize any injury to public or private property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations. This permit does not constitute a waiver of or approval of any other Department permit that may be required for other aspects of the total project which are not addressed in the permit.
4. This permit conveys no title to land or water, does not constitute state recognition or acknowledgement of title, and does not constitute authority for the use of submerged lands unless herein provided and the necessary title or leasehold interests have been obtained from the state. Only the Trustees of the Internal Improvement Trust Fund may express state opinion as to title.
5. This permit does not relieve the permittee from liability for harm or injury to human health or welfare, animal, or plant life, or property caused by the construction or operation of this permitted source, or from penalties therefore; nor does it allow the permittee to cause pollution in contravention of Florida Statutes and Department rules, unless specifically authorized by an order from the Department.
6. The permittee shall properly operate and maintain the facility and systems of treatment and control (and related appurtenances) that are installed and used by the permittee to achieve compliance with the conditions of this permit, are required by Department rules. This provision includes the operation of backup or auxiliary facilities or similar systems when necessary to achieve compliance with the conditions of the permit and when required by Department rules.

PERMITTEE:

Gulf Power Company

I.D. Number: 10PEN17004504 and 05

Permit/Certification Number: A017-211303

Date of Issue: April 17, 1992

Expiration Date: April 1, 1997

GENERAL CONDITIONS:

7. The permittee, by accepting this permit, specifically agrees to allow authorized Department personnel, upon presentation of credentials or other documents as may be required by law, access to the premises, at reasonable times, where the permitted activity is located or conducted for the purpose of:

- a. Having access to and copying any records that must be kept under the conditions of this permit;
- b. Inspecting the facility, equipment, practices, or operations regulated or required under this permit; and,
- c. Sampling or monitoring any substances or parameters at any location reasonably necessary to assure compliance with this permit or Department rules.

Reasonable time may depend on the nature of the concern being investigated.

8. If, for any reason, the permittee does not comply with or will be unable to comply with any condition or limitation specified in this permit, the permittee shall immediately provide the Department with the following information:

- a. A description of and cause of noncompliance; and
- b. The period of noncompliance, including exact dates and times; or, if not corrected, the anticipated time the noncompliance is expected to continue, and steps being taken to reduce, eliminate, and prevent recurrence of the noncompliance. The permittee shall be responsible for any and all damages which may result and may be subject to enforcement action by the Department for penalties or for revocation of this permit.

9. In accepting this permit, the permittee understands and agrees that all records, notes, monitoring data and other information relating to the construction or operation of this permitted source which are submitted to the Department may be used by the Department as evidence in any enforcement case involving the permitted source arising under the Florida Statutes or Department rules, except where such use is proscribed by Sections 403.73 and 403.111, Florida Statutes. Such evidence shall only be used to the extent it is consistent with Florida Rules of Civil Procedure and appropriate evidentiary rules.

PERMITTEE:  
Gulf Power Company

I.D. Number: 10PEN17004504 and 05  
Permit/Certification Number: A017-211303  
Date of Issue: April 17, 1992

Expiration Date: April 1, 1997

GENERAL CONDITIONS:

10. The permittee agrees to comply with changes in Department rules and Florida Statutes after a reasonable time for compliance, provided however, the permittee does not waive any other rights granted by Florida Statutes or Department rules.

11. This permit is transferable only upon Department approval in accordance with Florida Administrative Code Rules 17-4.120 and 17-730.300, as applicable. The permittee shall be liable for any noncompliance of the permitted activity until the transfer is approved by the Department.

12. This permit is required to be kept at the work site of the permitted activity during the entire period of construction or operation.

13. The permittee shall comply with the following:


- a. Upon request, the permittee shall furnish all records and plans required under Department rules. During enforcement actions, the retention period for all records will be extended automatically unless otherwise stipulated by the Department.
- b. The permittee shall hold at the facility or other location designated by this permit records of all monitoring information (including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation) required by the permit, copies of all reports required by this permit, and records of all data used to complete the application for this permit. These materials shall be retained at least three years from the date of the sample, measurement, report or application unless otherwise specified by Department rule.
- c. Records of monitoring information shall include:
  - the date, exact place, and time of sampling or measurement;
  - the person responsible for performing the sampling or measurement;
  - the date(s) analyses were performed;
  - the person responsible for performing the analyses;
  - the analytical techniques or methods used; and
  - the results of such analyses.

14. When requested by the Department, the permittee shall within a reasonable time furnish any information required by law which is needed to determine compliance with the permit. If the permittee becomes aware the relevant facts were not submitted or were incorrect in the permit application or in any report to the Department, such facts or information shall be corrected promptly.



STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL REGULATION

NORTHWEST DISTRICT  
160 GOVERNMENTAL CENTER  
PENSACOLA, FLORIDA 32501-5794



ANNUAL OPERATION REPORT FORM FOR AIR EMISSIONS SOURCES

For each permitted emission point, please submit a separate report for calendar year 19\_\_\_\_  
prior to March 1st of the following year.

I GENERAL INFORMATION

1. Source Name: \_\_\_\_\_
2. Permit Number: \_\_\_\_\_
3. Source Address: \_\_\_\_\_  
\_\_\_\_\_
4. Description of Source: \_\_\_\_\_  
\_\_\_\_\_

II ACTUAL OPERATING HOURS: \_\_\_\_\_ hrs/day \_\_\_\_\_ days/wk \_\_\_\_\_ wks/yr

III RAW MATERIAL INPUT PROCESS WEIGHT: (List separately all materials put into process  
and specify applicable units if other than tons/yr)

Raw Material	Input Process Weight
_____	_____ tons/yr
_____	_____ tons/yr
_____	_____ tons/yr
_____	_____ tons/yr
_____	_____ tons/yr

IV PRODUCT OUTPUT (Specify applicable units)

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL REGULATION

NORTHWEST DISTRICT  
160 GOVERNMENTAL CENTER  
PENSACOLA, FLORIDA 32501-5794



APPLICATION FOR RENEWAL OF  
PERMIT TO OPERATE AIR POLLUTION SOURCE(S)

If major alterations have occurred, the applicant should complete the Standard Air Permit Application Form.

Source Type: \_\_\_\_\_ Renewal of DER Permit No. \_\_\_\_\_

Company Name: \_\_\_\_\_ County: \_\_\_\_\_

Identify the specific emission point source(s) addressed in this application (i.e., Lime Kiln No. 4 with Venturi Scrubber; Peaking Unit No. 2, Gas Fired):

Source Location: Street: \_\_\_\_\_ City: \_\_\_\_\_

UTM: East \_\_\_\_\_ North \_\_\_\_\_

Latitude: \_\_\_ ° \_\_\_ ' \_\_\_ "N. Longitude: \_\_\_ ° \_\_\_ ' \_\_\_ "W.

1. Attach a check made payable to the Department of Environmental Regulation in accordance with operation permit fee schedule set forth in Florida Administrative Code Rule 17-4.05.
2. Have there been any alterations to the plant since last permitted?  Yes  No  
If minor alterations have occurred, describe on a separate sheet and attach.
3. Attach the last compliance test report required per permit conditions if not submitted previously.
4. Have previous permit conditions been adhered to?  Yes  No If no, explain on a separate sheet and attach.
5. Has there been any malfunction of the pollution control equipment during tenure of current permit?  Yes  No If yes, and not previously reported, give brief details and what action was taken on a separate sheet and attach.
6. Has the pollution control equipment been maintained to preserve the collection efficiency last permitted by the Department?  Yes  No
7. Has the annual operating report for the last calendar year been submitted?  Yes  No If no, please attach.

Gulf Power Company  
500 Bayfront Parkway  
Post Office Box 1151  
Pensacola, FL 32520-1151  
Telephone 904 444-6111



*The southern electric system*

March 30, 1992

Mr. Ed K. Middleswart, P.E.  
Florida Department of Environmental Regulation  
Northwest District  
160 Governmental Center  
Pensacola, Florida 32501-5794

Dear Mr. Middleswart:

Please find enclosed three (3) copies of the renewal applications for the following Air Operating Permits:

Crist Unit 4 - AO17-134882  
Crist Unit 5 - AO17-134883  
Smith Unit 1 - AOO3-134885  
Smith Unit 2 - AOO3-134887  
Scholz Unit 1 - AO32-134888  
Scholz Unit 2 - AO32-134889

As you may recall, on November 19, 1990 the Department granted a modification to the existing Crist Unit 4 and 5 Air Operating Permits to include new specific language for Conditions 17, 19, 22, 27, 28, 29, 30 and 31. These provisions were necessary from our agreement regarding the use of continuous emission monitoring for determination of SO<sub>2</sub> compliance at Plant Crist. At that time, it was discussed that these provisions would be available for Gulf's other coal-fired units should Gulf Power wish to pursue this option. Gulf Power hereby requests the same provisions be adopted for the Smith Electric Generating Plant and the Scholz Electric Generating Plant.

Additionally, Gulf Power wishes to apply for a reduction in permit application fees under Section 17-4.050(4)(a)3. Similar Source Fee for each facility referenced above. This provision allows for an applicant to apply for an operation permit for a group of similar air sources at the same facility, under the same application if each source utilize the same air emissions testing or monitoring requirements. The application fee under this provision require submittal of \$2000 per facility for each permit renewal. Please find enclosed a check for a total of \$6,000 for the above referenced facilities.

Mr. Ed K. Middleswart, P.E.  
March 30, 1992  
Page Two

If you have any questions or need further information,  
please call me at (904) 444-6527.

Sincerely,



G. Dwain Waters  
Senior Environmental Affairs Specialist

Enclosures

cc: Mr. J. A. Babbitt  
Mr. M. L. Gilchrist  
Mr. C. R. Lee  
Mr. W. T. Lyford, III  
Mr. P. Parker  
Mr. J. O. Vick

received  
10/8 Re

STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
NOTICE OF PERMIT

Unit 6  
Construction  
Permit

In the matter of an  
Application for Permit  
By:  
M. L. Gilchrist  
Manager of Fuel and Environmental Affairs  
Gulf Power Company  
Post Office Box 1151  
Pensacola, Florida 32520-0328

DEP File No. AC17-23401  
Escambia County

Enclosed is Permit Number AC17-234016 to construct a replacement electrostatic precipitator for Crist Unit 6, issued pursuant to Section 403.087, Florida Statutes.

Any party to this Order (permit) has the right to seek judicial review of the permit pursuant to Section 120.68, Florida Statutes, by the filing of a Notice of Appeal pursuant to Rule 9.110, Florida Rules of Appellate Procedure, with the Clerk of the Department in the Office of General Counsel, 2600 Blair Stone Road, Tallahassee, Florida 32399-2400, and by filing a copy of the Notice of Appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal. The Notice of Appeal must be filed within 30 days from the date this Notice is filed with the Clerk of the Department.

Executed in Pensacola, Florida.

State of Florida Department  
of Environmental Protection

  
BOBBY A. COOLEY  
District Director

160 Governmental Center  
Pensacola, Florida 32501-5794  
(904) 436-8300

**CERTIFICATE OF SERVICE**

The undersigned duly designated deputy agency clerk hereby certifies that this NOTICE OF PERMIT and all copies were mailed before the close of business on October 7, 1993 to the listed persons.

FILING AND ACKNOWLEDGMENT FILED,  
on this date, pursuant to §120.52(11),  
Florida Statutes, with the designated  
Department clerk, receipt of which is  
hereby acknowledged.

  
Clerk \_\_\_\_\_ Date 10/7/93



Lawton Chiles  
Governor

# Florida Department of Environmental Protection

Northwest District  
160 Governmental Center  
Pensacola, Florida 32501-5794

Virginia B. Wetherell  
Secretary

**PERMITTEE:**

**Gulf Power Company**

I.D. Number: 10PEN17004506  
Permit/Certification Number: AC17-234016  
Date of Issue: October 7, 1993  
Expiration Date: December 1, 1994  
County: Escambia  
Latitude/Longitude: 30°33'57"N/87°13'29.5"W  
Project: Electrostatic Precipitator, Crist 6

This permit is issued under the provisions of Section 403.087, Florida Statutes, and Florida Administrative Code Rules 17-296, 17-297 and 17-4. The above named applicant, hereinafter called Permittee, is hereby authorized to perform the work or operate the facility shown on the application and approved drawing(s), plans, and other documents attached hereto or on file with the Department and made a part hereof and specifically described as follows:

Construction of a replacement Electrostatic Precipitator (ESP), for Crist Unit No. 6. The new ESP will reduce PM emissions by 922 T/yr. The coal-fired power boiler (Crist No. 6) is used to supply steam for the generation of 320 MW of electricity.

Emissions of particulates will be controlled by the ESP, Wheelabrator model HaRDE. The ESP has a PM removal efficiency of 99.6% at full load flow conditions of 1,325,820 ACFM. Emissions of sulfur dioxide are controlled by the sulfur content of the coal. Continuous emissions monitoring systems for opacity, sulfur dioxide, nitrogen oxides and oxygen are installed. Collected fly ash and bottom ash generated by the combustion of fossil fuels are to be disposed of in an on-site permitted landfill.

Located: Gulf Power Crist Plant, Ten Mile Road, on Governor's Bayou, north of Pensacola.

Specific Condition No. 2 requires notification upon commencement of construction. Projects beyond one year require annual status reports.

Specific Condition No. 2 also requires notification and prior approval of any changes or revisions made during construction.

Specific Condition No. 18 requires submittal of certificate of completion of construction with appropriate fee within 75 days after completion of construction.

Specific Condition No. 18 also requires obtaining an operating permit before the expiration date (December 1, 1994) of this construction permit for continued operation.

PERMITTEE:  
Gulf Power Company

I.D. Number: 10PEN17004506  
Permit/Certification Number: AC17-234016  
Date of Issue: October 7, 1993  
Expiration Date: December 1, 1994

**SPECIFIC CONDITIONS:**

1. The attached General Conditions are part of this permit.
2. The Department shall be notified upon commencement of construction. The Department shall be notified and prior approval shall be obtained of any substantial changes or revisions made during construction. Projects beyond one year require annual status reports.
3. The nameplate capacity is 320 MW net output of electricity based on the maximum fuel consumption of 3368 MBtu/hr input as measured by average fuel heating values. This is the operating rate at which compliance with standards shall be demonstrated. The maximum allowable heat input is that heat input necessary to maintain electrical load output at 110 percent of nameplate capacity or the level at which the most recent successful emissions compliance test was conducted. If the test was conducted at less than 90 percent of nameplate capacity of the unit, permittee may operate the unit at loads up to the nameplate capacity for purposes of preparation for testing for up to ten calendar days. The Department shall be advised in writing prior to each testing.
4. The Electrostatic Precipitator, and Crist Unit 6 may operate continuously, i.e., 8760 hrs/yr.
5. The manner, nature, volume and frequency of permitted emissions, applicable emissions limiting standards, if any, and allowable emissions are listed as per FAC Rule 17-210.300(2)(a):

<u>Airborne Contaminant Emitted</u>	<u>FAC Rule</u>	<u>Allowable Emissions T/yr</u>
PM	17-296.405(1)(b)	1475 <sup>1</sup>
SO <sub>2</sub>	17-296.405(1)(c)2c	87035 <sup>2</sup>
Objectionable Odors	17-296.320(2)	None allowed off plant property <sup>3</sup>
VE	17-296.405(1)(a)	40% opacity <sup>3</sup>

- 1 Based on steady-state operating parameters, application to construct and rule:  
PM emissions shall not exceed 0.1 pounds per million Btu heat input.
  - 2 Based on steady-state operating parameters, application to construct and rule:  
SO<sub>2</sub> emissions shall not exceed 5.90 pounds per million Btu heat input.
  - 3 Department order dated May 12, 1988.
6. Excess emissions as stated in FAC Rule 17-210.700 shall be allowed. The steady-state hourly emission rate allowable for PM listed in Specific Condition #5 shall not apply during soot-blowing or load changes. However, PM emissions shall not exceed an average of 0.3 lb/MMBtu heat input (equivalent to 1011 lb/hr allowable emissions - steady state) during the 3 hour excess emissions period allowed by 17-210.700 ( ref. FAC rule 17-210.700(3) ).

PERMITTEE:  
Gulf Power Company

I.D. Number: 10PEN17004506  
Permit/Certification Number: AC17-234016  
Date of Issue: October 7, 1993  
Expiration Date: December 1, 1994

**SPECIFIC CONDITIONS:**

7. Excess emissions are defined as:

- A. Any six-minute average for opacity which exceeds the standard.
- B. Any 24-hour average for sulfur dioxide which exceeds the standard.

8. The Department shall be notified as soon as possible (by telephone) of excess emissions that are beyond the allowances of FAC Rule 17-210.700, such as:

- A. Any soot blowing or load changes that cause excess visible emissions for a period longer than three hours, or that exceed 60 percent opacity (six minute average) more than four times in any one day.
- B. Any malfunction that causes excess visible emissions for a period longer than two hours in any one day.
- C. A 24-hour average of SO<sub>2</sub> emissions measured by the continuous monitor that exceeds the standard, or daily average SO<sub>2</sub> emissions measured by coal analysis (in the event the permittee chooses) that exceeds the standard.

Immediately upon notification of excess emissions that are beyond the allowances, the permittee shall take the necessary steps to determine the cause and arrange a meeting with the Department within 72 hours to discuss a settlement of the violation with corrective action to avoid recurrence.

9. A log shall be maintained showing the duration, magnitude and cause of excess visible emissions, and of excess SO<sub>2</sub> emissions.

10. A quarterly report of excess emissions shall be submitted within 30 days following the end of each calendar quarter. The report shall consist of each individual exceedance of opacity or SO<sub>2</sub> emissions (specific Conditions 7 and 8) with duration, magnitude and cause. Any exceedance that is beyond the allowances of FAC Rule 17-210.700 shall be highlighted with note indicating compliance with specific condition 8. A continuous emissions monitor quarterly summary report shall be submitted for each CEM.

11. A maintenance log of the continuous monitoring system shall be kept showing time out of service, and calibrations and adjustments.



**PERMITTEE:**

Gulf Power Company

I.D. Number: 10PEN17004506  
Permit/Certification Number: AC17-234016  
Date of Issue: October 7, 1993  
Expiration Date: December 1, 1994

**SPECIFIC CONDITIONS:**

12. Emissions tests are required to show compliance with the standards of the Department. The test results must provide reasonable assurance that the source is capable of compliance at the permitted maximum operating rate. Tests shall be conducted in accordance with the table below. Such tests shall be scheduled within 30 days after construction is completed. The Department shall be notified at least 15 days prior to testing to allow witnessing. Results shall be submitted to the Department within 45 days after testing.

<u>Pollutant</u>	<u>Test Method</u>
PM	DEP method 1, 2, 3, and 17
VE	DEP method 9

The VE test shall be conducted during one of the PM test runs. Test reports shall comply with F.A.C. Rule 17-297.570, Test Reports. The Department can require special compliance tests in accordance with F.A.C. Rule 17-297.340(2). Other test methods and alternate compliance procedures may be used only after prior Departmental approval has been obtained in writing.

13. Immediately upon notification of a particulate test report that fails to demonstrate compliance with the particulate emission limit of 0.1 pounds per million Btu heat input, the permittee shall take necessary steps to determine the cause of the test failure and arrange a meeting with the Department within 72 hours to discuss a settlement of the violation and a schedule for retesting when the cause of the test failure has been determined and corrected.

14. Boilers No. 6 and 7 use a common stack. Visible emission violations from this stack shall be attributed to both boilers unless opacity meter results show the specific boiler causing the violation.

15. Continuous SO<sub>2</sub> emission monitoring 24-hour averages are required to demonstrate compliance with the standard of the Department (specific condition 5). A valid 24-hour average shall consist of no less than 18 hours of valid data capture per calendar day. In the event that valid data capture is not available, the permittee shall initiate as-fired fuel sampling to demonstrate compliance with the SO<sub>2</sub> emission standard. The as-fired fuel sampling shall be initiated no later than 36 hours after the permittee has verified the problem or no later than 36 hours after the end of the affected calendar day. Fuel sampling shall continue until such time as the valid data capture is restored. In lieu of as-fired fuel sampling the permittee may elect to demonstrate SO<sub>2</sub> emission compliance by the temporary use of a spare SO<sub>2</sub> emission monitor. The spare SO<sub>2</sub> emission monitor must be installed and collecting data in the same time frame as required above for as-fired fuel sampling.

**PERMITTEE:**

Gulf Power Company

I.D. Number: 10PEN17004506  
Permit/Certification Number: AC17-234016  
Date of Issue: October 7, 1993  
Expiration Date: December 1, 1994

**SPECIFIC CONDITIONS:**

16. The permittee shall develop and implement a QC program. As a minimum, the QC program must include written procedures which should describe in detail complete, step-by-step procedures and operations for each of the following activities:

1. Calibration of CEMS.
2. Calibration Drift determination and adjustment of CEMS.
3. Preventive maintenance of CEMS (including spare parts inventory).
4. Data recording, calculations and reporting.
5. Accuracy audit procedures including sampling and analysis methods.
6. Program of corrective action for malfunctioning CEMS.

17. The applicant shall retain a Professional Engineer, registered in the State of Florida, for the inspection of the construction of this project. Upon completion the engineer shall inspect for conformity to the permit application and associated documents. A Certificate of Completion [Form DEP 17-1.202(3) attached] shall be submitted with the compliance test results and appropriate fee as application for an operation permit. These are to be submitted within 75 days after completion of construction. The permittee shall obtain an operating permit for this source before the expiration of this construction permit if the permittee desires to continue operation.

18. All fugitive dust generated at this site shall be adequately controlled.

19. The permanent source identification number for this point source is 10PEN17004506. Please cite this number on all test reports and other correspondence specific to this permitted point source.

20. The Department telephone number for reporting problems, malfunctions or exceedances under this permit is (904) 436-8300, day or night, and for emergencies involving a significant threat to human health or the environment is (904) 488-1320. For routine business, telephone (904) 436-8364 during normal working hours.

Expiration Date:

December 1, 1994

Issued this 7<sup>th</sup> day of October,  
1993.

STATE OF FLORIDA DEPARTMENT  
OF ENVIRONMENTAL PROTECTION

  
BOBBY A. COOLEY  
District Director

**PERMITTEE:**

**Gulf Power Company**

**I.D. Number: 10PEN17004506**

**Permit/Certification Number: AC17-234016**

**Date of Issue: October 7, 1993**

**Expiration Date: December 1, 1994**

**GENERAL CONDITIONS:**

1. The terms, conditions, requirements, limitations, and restrictions set forth in this permit are "permit conditions", and are binding and enforceable pursuant to Sections 403.141, 403.727, or 403.859 through 403.861, Florida Statutes. The permittee is placed on notice that the Department will review this permit periodically and may initiate enforcement action for any violation of these conditions.

2. This permit is valid only for the specific processes and operations applied for and indicated in the approved drawings or exhibits. Any unauthorized deviation from the approved drawings, exhibits, specifications, or conditions of this permit may constitute grounds for revocation and enforcement action by the Department.

3. As provided in Subsections 403.087(6) and 403.722(5), Florida Statutes, the issuance of this permit does not convey any vested rights or any exclusive privileges. Nor does it authorize any injury to public or private property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations. This permit does not constitute a waiver of or approval of any other Department permit that may be required for other aspects of the total project which are not addressed in the permit.

4. This permit conveys no title to land or water, does not constitute state recognition or acknowledgment of title, and does not constitute authority for the use of submerged lands unless herein provided and the necessary title or leasehold interests have been obtained from the state. Only the Trustees of the Internal Improvement Trust Fund may express state opinion as to title.

5. This permit does not relieve the permittee from liability for harm or injury to human health or welfare, animal, or plant life, or property caused by the construction or operation of this permitted source, or from penalties therefore; nor does it allow the permittee to cause pollution in contravention of Florida Statutes and Department rules, unless specifically authorized by an order from the Department.

6. The permittee shall properly operate and maintain the facility and systems of treatment and control (and related appurtenances) that are installed and used by the permittee to achieve compliance with the conditions of this permit, are required by Department rules. This provision includes the operation of backup or auxiliary facilities or similar systems when necessary to achieve compliance with the conditions of the permit and when required by Department rules.

7. The permittee, by accepting this permit, specifically agrees to allow authorized Department personnel, upon presentation of credentials or other documents as may be required by law, access to the premises, at reasonable times, where the permitted activity is located or conducted for the purpose of:

a. Having access to and copying any records that must be kept under the conditions of this permit;

b. Inspecting the facility, equipment, practices, or operations regulated or required under this permit; and,

**PERMITTEE:**

Gulf Power Company

I.D. Number: 10PEN17004506

Permit/Certification Number: AC17-234016

Date of Issue: October 7, 1993

Expiration Date: December 1, 1994

**GENERAL CONDITIONS:**

c. Sampling or monitoring any substances or parameters at any location reasonably necessary to assure compliance with this permit or Department rules.

Reasonable time may depend on the nature of the concern being investigated.

8. If, for any reason, the permittee does not comply with or will be unable to comply with any condition or limitation specified in this permit, the permittee shall immediately provide the Department with the following information:

a. A description of and cause of noncompliance; and

b. The period of noncompliance, including exact dates and times; or, if not corrected, the anticipated time the noncompliance is expected to continue, and steps being taken to reduce, eliminate, and prevent recurrence of the noncompliance. The permittee shall be responsible for any and all damages which may result and may be subject to enforcement action by the Department for penalties or for revocation of this permit.

9. In accepting this permit, the permittee understands and agrees that all records, notes, monitoring data and other information relating to the construction or operation of this permitted source which are submitted to the Department may be used by the Department as evidence in any enforcement case involving the permitted source arising under the Florida Statutes or Department rules, except where such use is proscribed by Sections 403.73 and 403.111, Florida Statutes. Such evidence shall only be used to the extent it is consistent with Florida Rules of Civil Procedure and appropriate evidentiary rules.

10. The permittee agrees to comply with changes in Department rules and Florida Statutes after a reasonable time for compliance, provided however, the permittee does not waive any other rights granted by Florida Statutes or Department rules.

11. This permit is transferable only upon Department approval in accordance with Florida Administrative Code Rules 17-4.120 and 17-730.300, as applicable. The permittee shall be liable for any noncompliance of the permitted activity until the transfer is approved by the Department.

12. This permit is required to be kept at the work site of the permitted activity during the entire period of construction or operation.

13. The permittee shall comply with the following:

a. Upon request, the permittee shall furnish all records and plans required under Department rules. During enforcement actions, the retention period for all records will be extended automatically unless otherwise stipulated by the Department.

b. The permittee shall hold at the facility or other location designated by this permit records of all monitoring information (including all calibration and maintenance records and all original strip chart recordings for continuous

**PERMITTEE:**

**Gulf Power Company**

**I.D. Number: 10PEN17004506**

**Permit/Certification Number: AC17-234016**

**Date of Issue: October 7, 1993**

**Expiration Date: December 1, 1994**

**GENERAL CONDITIONS:**

monitoring instrumentation) required by the permit, copies of all reports required by this permit, and records of all data used to complete the application for this permit. These materials shall be retained at least three years from the date of the sample, measurement, report or application unless otherwise specified by Department rule.

**c. Records of monitoring information shall include:**

- the date, exact place, and time of sampling or measurement;
- the person responsible for performing the sampling or measurement;
- the date(s) analyses were performed;
- the person responsible for performing the analyses;
- the analytical techniques or methods used; and
- the results of such analyses.

**14. When requested by the Department, the permittee shall within a reasonable time furnish any information required by law which is needed to determine compliance with the permit. If the permittee becomes aware the relevant facts were not submitted or were incorrect in the permit application or in any report to the Department, such facts or information shall be corrected promptly.**

# Visible Emissions Observation Form

Source/Process Information				Opacity Readings								
FACILITY NAME				OBSERVATION DATE		START TIME		STOP TIME				
SOURCE NAME		PERMIT NO		SEC	0	15	30	45	SEC	0	15	30
LOCATION/ADDRESS				MIN					MIN			
CONTACT				PHONE NO		1			31			
PROCESS/PRODUCTION RATE				2					32			
CONTROL EQUIPMENT				OPERATING MODE		3			33			
FUEL TYPE/RATE		MATERIAL TYPE/RATE		PERMITTED RATE		4			34			
DESCRIBE EMISSION POINT				5					35			
HEIGHT ABOVE GROUND LEVEL		HEIGHT RELATIVE TO OBSERVER		6					36			
Emissions Description				7					37			
DESCRIBE EMISSIONS				8					38			
START		END		9					39			
PLUME COLOR		PLUME TYPE		10					40			
WATER DROPLETS PRESENT?		IF YES, IS PLUME		11					41			
YES <input type="checkbox"/> NO <input type="checkbox"/>		ATTACHED <input type="checkbox"/> DETACHED <input type="checkbox"/>		12					42			
Meteorological Information				13					43			
BACKGROUND		BACKGROUND COLOR		14					44			
START		END		15					45			
SKY CONDITIONS/CLCUD COVER		AMBIENT TEMP		16					46			
START		END		17					47			
WIND SPEED		WIND DIRECTION		18					48			
START		END		19					49			
Observation Data, Site Diagram				20					50			
<div style="display: flex; justify-content: space-between;"> <div style="width: 45%;"> <p>Stack with Plume </p> <p>Sun </p> <p>Wind </p> </div> <div style="width: 45%; text-align: center;"> <p>Draw North Arrow </p> </div> </div> <div style="text-align: center; margin-top: 20px;"> <p style="text-align: center;">X Emission Point</p> <p style="text-align: center;">Observer's Position</p> <p style="text-align: center;">Sun Location Line</p> <p style="text-align: center;">140°</p> </div>				21					51			
				22					52			
				23					53			
				24					54			
				25					55			
				26					56			
				27					57			
				28					58			
				29					59			
				30					60			
				Compliance Information				Certification Data, Signatures				
RANGE OF OPACITY READINGS		MIN		MAX		OBSERVERS NAME						
AVERAGE OF HIGHEST 24 CONSECUTIVE READINGS				OBSERVERS SIGNATURE				DATE				
SHORT TERM AVERAGE DATA				ORGANIZATION								
AVERAGING PERIOD		MINUTES		ACTUAL AVERAGE		CERTIFIED BY		DATE				
COMMENTS:				I HAVE RECEIVED A COPY OF THESE OBSERVATIONS. SIGNATURE				DATE				
				APS NUMBER:								



STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL REGULATION  
AIR POLLUTION SOURCES  
CERTIFICATE OF COMPLETION OF CONSTRUCTION\*

PERMIT NO. \_\_\_\_\_ DATE: \_\_\_\_\_

Company Name: \_\_\_\_\_ County: \_\_\_\_\_

Source Identification(s): \_\_\_\_\_

Actual costs of serving pollution control purpose: \$ \_\_\_\_\_

Operating Rates: \_\_\_\_\_ Design Capacity: \_\_\_\_\_

Expected Normal \_\_\_\_\_ During Compliance Test \_\_\_\_\_

Date of Compliance Test: \_\_\_\_\_ (Attach detailed test report)

Test Results:	Pollutant	Actual Discharge	Allowed Discharge
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

Date plant placed in operation: \_\_\_\_\_

This is to certify that, with the exception of deviations noted\*\*, the construction of the project has been completed in accordance with the application to construct and Construction Permit No. \_\_\_\_\_ dated \_\_\_\_\_.

**A. Applicant:**

\_\_\_\_\_  
Name of Person Signing (Type) \_\_\_\_\_ Signature of Owner or Authorized Representative and Title

Date: \_\_\_\_\_ Telephone: \_\_\_\_\_

**B. Professional Engineer:**

\_\_\_\_\_  
Name of Person Signing (Type) \_\_\_\_\_ Signature of Professional Engineer

\_\_\_\_\_  
Company Name \_\_\_\_\_ Florida Registration No. \_\_\_\_\_

Date: \_\_\_\_\_


(Seal)

\_\_\_\_\_  
Mailing Address

\_\_\_\_\_  
Telephone Number

\*This form, satisfactorily completed, submitted in conjunction with an existing application to construct permit and payment of application processing fee will be accepted in lieu of an application to operate.

\*\*As built, if not built as indicated include process flow sketch, plot plan sketch, and updates of applicable pages of application form.



# Florida Department of Environmental Regulation

Northwest District • 160 Governmental Center • Pensacola, Florida 32501-5794 • 904-436-8300

Bob Martinez, Governor

Dale Twachtmann, Secretary

John Shearer, Assistant Secretary  
Robert Kriegel, Deputy Assistant Secretary

**PERMITTEE:**

Gulf Power Company

I.D. Number: 10PEN17004507

Permit/Certification Number: AO17-171806

Date of Issue: JUN 6 1990

Expiration Date: March 1, 1995

County: Escambia

Latitude/Longitude: 30°33'57"N/87°13'29.5"W

Section/Township/Range: 25/1N/30W

Project: Crist Boiler #7

This permit is issued under the provisions of Section 403.087, Florida Statutes, and Florida Administrative Code Rules 17-2 and 17-4. The above named applicant, hereinafter called Permittee, is hereby authorized to perform the work or operate the facility shown on the application and approved drawing(s), plans, and other documents attached hereto or on file with the Department and made a part hereof and specifically described as follows:

Operation of utility boiler (Crist #7) to supply steam for generation of 500 MW of electricity. This boiler is fueled with coal.

Emissions of particulates are controlled by an electro-static precipitator. Emissions of sulfur dioxide are controlled by the sulfur content of the coal. Continuous emissions monitoring system for opacity, sulfur dioxide, nitrogen oxides and oxygen is installed.

Located at Crist Plant, Governors Bayou, north of Pensacola.

The following specific conditions require timely action by the permittee during the life of this permit:

- Condition 20 Logging excess emissions (each occurrence)
- 21 Logging CEM maintenance (each occurrence)
- 22 Excess emissions report (quarterly)
- 24 Annual particulates test (prior to end of September)
- 25 QC Program (within 90 days after permit issuance)
- 27 Report of excess emissions, not allowed (each occurrence)
- 28 Report of particulate stack test exceedence (each occurrence)
- 30 Apply for permit renewal (prior to January 1, 1995)



PERMITTEE:

Gulf Power Company

I.D. Number: 10PEN17004507

Permit/Certification Number: A017--171806

Date of Issue: JUN 6 1990

Expiration Date: March 1, 1995

GENERAL CONDITIONS:

1. The terms, conditions, requirements, limitations, and restrictions set forth in this permit are "permit conditions", and are binding and enforceable pursuant to Sections 403.141, 403.727, or 403.859 through 403.861, Florida Statutes. The permittee is placed on notice that the Department will review this permit periodically and may initiate enforcement action for any violation of these conditions.
2. This permit is valid only for the specific processes and operations applied for and indicated in the approved drawings or exhibits. Any unauthorized deviation from the approved drawings, exhibits, specifications, or conditions of this permit may constitute grounds for revocation and enforcement action by the Department.
3. As provided in Subsections 403.087(6) and 403.722(5), Florida Statutes, the issuance of this permit does not convey any vested rights or any exclusive privileges. Nor does it authorize any injury to public or private property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations. This permit does not constitute a waiver of or approval of any other Department permit that may be required for other aspects of the total project which are not addressed in the permit.
4. This permit conveys no title to land or water, does not constitute state recognition or acknowledgement of title, and does not constitute authority for the use of submerged lands unless herein provided and the necessary title or leasehold interests have been obtained from the state. Only the Trustees of the Internal Improvement Trust Fund may express state opinion as to title.
5. This permit does not relieve the permittee from liability for harm or injury to human health or welfare, animal, or plant life, or property caused by the construction or operation of this permitted source, or from penalties therefore; nor does it allow the permittee to cause pollution in contravention of Florida Statutes and Department rules, unless specifically authorized by an order from the Department.
6. The permittee shall properly operate and maintain the facility and systems of treatment and control (and related appurtenances) that are installed and used by the permittee to achieve compliance with the conditions of this permit, are required by Department rules. This provision includes the operation of backup or auxiliary facilities or similar systems when necessary to achieve compliance with the conditions of the permit and when required by Department rules.

PERMITTEE:

Gulf Power Company

I.D. Number: 10PEN17004507

Permit/Certification Number: A017-171806

Date of Issue: JUN 6 1990

Expiration Date: March 1, 1995

GENERAL CONDITIONS:

7. The permittee, by accepting this permit, specifically agrees to allow authorized Department personnel, upon presentation of credentials or other documents as may be required by law, access to the premises, at reasonable times, where the permitted activity is located or conducted for the purpose of:

- a. Having access to and copying any records that must be kept under the conditions of this permit;
- b. Inspecting the facility, equipment, practices, or operations regulated or required under this permit; and,
- c. Sampling or monitoring any substances or parameters at any location reasonably necessary to assure compliance with this permit or Department rules.

Reasonable time may depend on the nature of the concern being investigated.

8. If, for any reason, the permittee does not comply with or will be unable to comply with any condition or limitation specified in this permit, the permittee shall immediately provide the Department with the following information:

- a. A description of and cause of noncompliance; and
- b. The period of noncompliance, including exact dates and times; or, if not corrected, the anticipated time the noncompliance is expected to continue, and steps being taken to reduce, eliminate, and prevent recurrence of the noncompliance. The permittee shall be responsible for any and all damages which may result and may be subject to enforcement action by the Department for penalties or for revocation of this permit.

9. In accepting this permit, the permittee understands and agrees that all records, notes, monitoring data and other information relating to the construction or operation of this permitted source which are submitted to the Department may be used by the Department as evidence in any enforcement case involving the permitted source arising under the Florida Statutes or Department rules, except where such use is proscribed by Sections 403.73 and 403.111, Florida Statutes. Such evidence shall only be used to the extent it is consistent with Florida Rules of Civil Procedure and appropriate evidentiary rules.

PERMITTEE:

Gulf Power Company

I.D. Number: 10PEN17004507

Permit/Certification Number: AO17-171806

Date of Issue: JUN 6 1990

Expiration Date: March 1, 1995

GENERAL CONDITIONS:

10. The permittee agrees to comply with changes in Department rules and Florida Statutes after a reasonable time for compliance, provided however, the permittee does not waive any other rights granted by Florida Statutes or Department rules.

11. This permit is transferable only upon Department approval in accordance with Florida Administrative Code Rules 17-4.12 and 17-730.300, as applicable. The permittee shall be liable for any noncompliance of the permitted activity until the transfer is approved by the Department.

12. This permit is required to be kept at the work site of the permitted activity during the entire period of construction or operation.

13. The permittee shall comply with the following:

- a. Upon request, the permittee shall furnish all records and plans required under Department rules. During enforcement actions, the retention period for all records will be extended automatically unless otherwise stipulated by the Department.
- b. The permittee shall hold at the facility or other location designated by this permit records of all monitoring information (including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation) required by the permit, copies of all reports required by this permit, and records of all data used to complete the application for this permit. These materials shall be retained at least three years from the date of the sample, measurement, report or application unless otherwise specified by Department rule.
- c. Records of monitoring information shall include:
  - the date, exact place, and time of sampling or measurement;
  - the person responsible for performing the sampling or measurement;
  - the date(s) analyses were performed;
  - the person responsible for performing the analyses;
  - the analytical techniques or methods used; and
  - the results of such analyses.

PERMITTEE:  
Gulf Power Company

I.D. Number: 10PEN17004507  
Permit/Certification Number: A017-171806  
Date of Issue: JUN 6 1990

Expiration Date: March 1, 1995

GENERAL CONDITIONS:

14. When requested by the Department, the permittee shall within a reasonable time furnish any information required by law which is needed to determine compliance with the permit. If the permittee becomes aware the relevant facts were not submitted or were incorrect in the permit application or in any report to the Department, such facts or information shall be corrected promptly.

SPECIFIC CONDITIONS:

15. The maximum allowable heat input is that heat input necessary to maintain electrical load output at 110 percent of the level at which the most recent successful particulate emissions compliance test was conducted. If the test was conducted at less than 90 percent of rated capacity of the unit, permittee may operate the unit at loads up to the rated capacity (500 megawatts) for purposes of preparation for testing for up to ten calendar days. The Department shall be advised in writing prior to each testing.

16. Particulate emissions shall not exceed 0.1 pounds per million Btu heat input.

17. Sulfur dioxide emissions shall not exceed 5.90 pounds per million Btu heat input.

18. Visible emissions shall not exceed 40 percent opacity.

19. Excess emissions are defined as:

A. Any six minute average for opacity which exceeds the standard.

B. Any 24 hour average for sulfur dioxide which exceeds the standard.

20. A log shall be maintained showing the:

A. Duration of excess visible emissions and their causes.

B. Duration of excess SO<sub>2</sub> emissions.

21. A maintenance log of the continuous monitoring system shall be kept showing:

A. Time out of service.

B. Calibrations and adjustments.

PERMITTEE:

Gulf Power Company

I.D. Number: 10PEN17004507

Permit/Certification Number: A017-171806

Date of Issue: JUN 6 1990

Expiration Date: March 1, 1995

SPECIFIC CONDITIONS:

22. A quarterly report of excess emissions shall be submitted within 30 days following the end of each calendar quarter. The report shall consist of each individual exceedance of opacity or SO<sub>2</sub> emissions (Specific Conditions 19 and 20) with duration, magnitude and cause. Any exceedance that is beyond the allowances of FAC Rule 17-2.250 shall be highlighted with note indicating compliance with Specific Condition 27 below.

A continuous emission monitor quarterly summary report shall be submitted for each CEM.

23. Boilers #6 and #7 use a common stack. Visible emission violations from this stack shall be attributed to both boilers unless opacity meter results show the specific boiler causing the violation.

24. Particulate tests are required to show continuing compliance with the standards of the Department. The test results must provide reasonable assurance that the source is capable of compliance at the permitted maximum operating rate. Tests shall be conducted in accordance with EPA methods 1, 2, 3 and 17. Such tests shall be conducted once per year before the end of September. Results shall be submitted to the Department within 45 days after testing. The Department shall be notified at least 15 days prior to testing to allow witnessing.

25. Continuous SO<sub>2</sub> emission monitoring 24-hour averages are required to demonstrate compliance with the standard of the Department (Specific Condition 17). A valid 24-hour average shall consist of no less than 18 hours of valid data capture per calendar day. In the event that valid data capture is not available, the permittee shall initiate as-fired fuel sampling to demonstrate compliance with the SO<sub>2</sub> emission standard. The as-fired fuel sampling shall be initiated no later than 36 hours after the permittee has verified the problem or no later than 36 hours after the end of the affected calendar day. Fuel sampling shall continue until such time as the valid data capture is restored. In lieu of as-fired fuel sampling the permittee may elect to demonstrate SO<sub>2</sub> emission compliance by the temporary use of a spare SO<sub>2</sub> emission monitor. The spare SO<sub>2</sub> emission monitor must be installed and collecting data in the same time frame as required above for as-fired fuel sampling.

Develop and implement a QC program. As a minimum the QC program must include written procedures which should describe in detail, complete, step-by-step procedures and operations for each of the following activities:

1. Calibration of CEMS.
2. CD determination and adjustment of CEMS.
3. Preventive maintenance of CEMS (including spare parts inventory).

PERMITTEE:

Gulf Power Company

I.D. Number: 10PEN17004507

Permit/Certification Number: AO17-171806

Date of Issue: JUN 6 1990

Expiration Date: March 1, 1995

SPECIFIC CONDITIONS:

4. Data recording, calculations and reporting.
  5. Accuracy audit procedures including sampling and analysis methods.
  6. Program of corrective action for malfunctioning CEMS.
26. Excess emissions as stated in Florida Administrative Code Rule 17-2.250 shall be allowed.
27. The Department shall be notified as soon as possible (by telephone) of excess emissions that are beyond the allowances of FAC Rule 17-2.250, such as:
- A. Any soot blowing or load changes that cause excess visible emissions for a period longer than three hours, or that exceed 60 percent opacity (six minute average) more than four times in any one day.
  - B. Any malfunction that causes excess visible emissions for a period longer than two hours in any one day.
  - C. A 24-hour average of SO<sub>2</sub> emissions measured by the continuous monitor that exceeds the standard, or daily average SO<sub>2</sub> emissions measured by coal analysis (in the event the permittee chooses) that exceeds the standard.
- Immediately upon notification of excess emissions that are beyond the allowances, the permittee shall take the necessary steps to determine the cause and arrange a meeting with the Department within 72 hours to discuss a settlement of the violation with corrective action to avoid recurrence.
28. Immediately upon notification of a particulate test report that fails to demonstrate compliance with the particulate emission limit of 0.1 pounds per million Btu heat input, the permittee shall take necessary steps to determine the cause of the test failure and arrange a meeting with the Department within 72 hours to discuss a settlement of the violation and a schedule for retesting when the cause of the test failure has been determined and corrected.
29. An annual operation report (DER Form 17-1.202(6) attached) shall be submitted by March 1 each year. The attached form shall be reproduced by the permittee and used for future annual submittals.
30. The permanent source identification number for this point source is 10PEN17004507. Please cite this number on all test reports and other correspondence specific to this permitted point source.
31. An application to renew this permit shall be submitted prior to January 1, 1995.

PERMITTEE:

Gulf Power Company

I.D. Number: 10PEN17004507

Permit/Certification Number: A017-171806

Date of Issue: JUN 6 1990

Expiration Date: March 1, 1995

SPECIFIC CONDITIONS:


32. The Department telephone number for reporting problems, malfunctions or exceedances under this permit is (904) 436-8300, day or night, and for emergencies involving a significant threat to human health or the environment is (904) 488-1320. For routine business, telephone (904) 436-8364 during normal working hours.

Expiration date:

March 1, 1995

Issued this 5th day of June,  
1990.

STATE OF FLORIDA DEPARTMENT  
OF ENVIRONMENTAL REGULATION

  
ROBERT V. KRIEDEL  
Deputy Assistant Secretary

STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
NOTICE OF PERMIT ISSUANCE

CERTIFIED MAIL

In the matter of an  
Application for Permit

DEP File No. AO17-234356  
Escambia County

By:  
M. L. Gilchrist  
Manager of Fuel & Environmental Affairs  
Gulf Power Company  
Post Office Box 1151  
Pensacola, Florida 32520-0328

---

Enclosed is Permit Number AO17-234356 to operate fly ash storage silos, pursuant to Section 403.087, Florida Statutes.

A person whose substantial interests are affected by this permit may petition for an administrative proceeding (hearing) in accordance with Section 120.57, Florida Statutes. The petition must contain the information set forth below and must be filed (received) in the Office of General Counsel of the Department at 2600 Blair Stone Road, Tallahassee 32399-2400, within 14 days of receipt of this Permit. Petitioner shall mail a copy of the petition to the applicant at the address indicated above at the time of filing. Failure to file a petition within this time period shall constitute a waiver of any right such person may have to request an administrative determination (hearing) under Section 120.57, Florida Statutes.

The Petition shall contain the following information;

(a) The name, address, and telephone number of each petitioner, the applicant's name and address, the Department Permit File Number and the county in which the project is proposed;

(b) A statement of how and when each petitioner received notice of the Department's action or proposed action;

(c) A statement of how each petitioner's substantial interests are affected by the Department's action or proposed action;

(d) A statement of the material facts disputed by petitioner, if any;

(e) A statement of facts which petitioner contends warrant reversal or modification of the Department's action or proposed action;

(f) A statement of which rules or statutes petitioner contends require reversal or modification of the Department's action or proposed action; and

(g) A statement of the relief sought by petitioner, stating precisely the action petitioner wants the Department to take with respect to the Department's action or proposed action.



If a petition is filed, the administrative hearing process is designed to formulate agency action. Accordingly, the Department's final action may be different from the position taken by it in this permit. Persons whose substantial interests will be affected by any decision of the Department with regard to the application have the right to petition to become a party to the proceeding. The petition must conform to the requirements specified above and be filed (received) within 14 days of receipt of this notice in the Office of General Counsel at the above address of the Department. Failure to petition within the allowed time frame constitutes a waiver of any right such person has to request a hearing under Section 120.57, Florida Statutes, and to participate as a party to this proceeding. Any subsequent intervention will only be at the approval of the presiding officer upon motion filed pursuant to Rule 28-5.207, F.A.C.

This permit is final and effective on the date filed with the Clerk of the Department unless a petition is filed in accordance with the above paragraphs or unless a request for extension of time in which to file a petition is filed within the time specified for filing a petition and conforms to Rule 17-103.070, F.A.C. Upon timely filing of a petition or a request for an extension of time this permit will not be effective until further Order of the Department.

When the Order (Permit) is final, any party to the Order has the right to seek judicial review of the Order pursuant to Section 120.68, Florida Statutes, by the filing of a Notice of Appeal pursuant to Rule 9.110, Florida Rules of Appellate Procedure, with the Clerk of the Department in the Office of General Counsel, 2600 Blair Stone Road, Tallahassee, Florida 32399-2400; and by filing a copy of the Notice of Appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal. The Notice of Appeal must be filed within 30 days from the date the Final Order is filed with the Clerk of the Department.

Executed in Pensacola, Florida.

State of Florida Department  
of Environmental Protection

  
BOBBY A. COOLEY  
District Director

160 Governmental Center  
Pensacola, Florida 32501-5794  
(904) 436-8300

CERTIFICATE OF SERVICE

The undersigned duly designated deputy agency clerk hereby certifies that this NOTICE OF PERMIT ISSUANCE and all copies were mailed by certified mail before the close of business on August 2, 1993 to the listed persons.

FILING AND ACKNOWLEDGMENT FILED,  
on this date, pursuant to §120.52(9),  
Florida Statutes, with the designated  
Department clerk, receipt of which is  
hereby acknowledged.



Clerk



Date



Lawton Chiles  
Governor

# Florida Department of Environmental Protection

Northwest District  
160 Governmental Center  
Pensacola, Florida 32501-5794

Virginia B. Wetherell  
Secretary

**PERMITTEE:**

Gulf Power Company

I.D. Number: 10PEN17004508  
Permit/Certification Number: AO17-234356  
Date of Issue: July 30, 1993  
Expiration Date: July 1, 1998  
County: Escambia  
Latitude/Longitude: 30°33'54.5"N/87°13'41.5"W  
Project: Fly Ash Storage Silos

This permit is issued under the provisions of Section 403.087, Florida Statutes, and Florida Administrative Code Rules 17-296, 17-297 and 17-4. The above named applicant, hereinafter called Permittee, is hereby authorized to perform the work or operate the facility shown on the application and approved drawing(s), plans, and other documents attached hereto or on file with the Department and made a part hereof and specifically described as follows:

Operation of two fly ash silos. Fly ash collection systems from precipitators on Boilers 4, 5, 6 & 7 to three transfer tanks are totally enclosed with no emission points. Three blowers pneumatically convey dry fly ash to two silos at a maximum solids rate of 150 tons per hour to either or both silos. A majority of the solids (99.4%) settle by gravity upon entering the silo(s). The residual particulate emissions are controlled by a baghouse on each silo. Each baghouse is a Pulse Jet Fabric Filter, model #100-WMWC-420 (IIG) manufactured by Flex-Kleen. Dry fly ash will be transported in closed tanker trucks away from the site or conditioned (12-15% water added) fly ash will be transported to an approved landfill area on company property.

Located: Approximately 3 miles northeast of SR 292 and Ten Mile Road intersection, north of Pensacola.

Specific Condition No. 4 requires annual visible emissions (VE) testing due before the end of March.

Specific Condition No. 7 require submittal of annual operation reports.

Specific Condition No. 8 requires submittal of annual operation fee.

Specific Condition No. 9 requires submittal of permit renewal application by May 1, 1998.

**PERMITTEE:**

Gulf Power Company

I.D. Number: 10PEN17004508

Permit/Certification Number: AO17-234356

Date of Issue: July 30, 1993

Expiration Date: July 1, 1998

**SPECIFIC CONDITIONS:**

1. The attached General Conditions are part of this permit.
2. The maximum allowable operating rate is 150 tons of fly ash transported per hour. Compliance shall be demonstrated at an operating rate which typifies normal operation of the fly ash system. This operating rate may be lower than the maximum allowable operating rate. The Department may request that a special compliance test be conducted should test results not provide reasonable assurance that the source is in compliance.
3. Visible emissions shall not exceed 5% opacity.
4. Visible emissions tests are required to show continuing compliance with the Department. The test results must provide reasonable assurance that the source is capable of compliance at the permitted maximum operating rate. Tests shall be conducted in accordance with DEP method 9 (on each baghouse, on each vent ; 2 vents per baghouse). Such tests shall be conducted annually at 12-month intervals ( $\pm$  two months) before the end of March. Results shall be submitted to the Department within 45 days after testing. The Department shall be notified at least 15 days prior to testing to allow witnessing.
5. All fugitive dust generated at this site shall be adequately controlled.
6. This permit prohibits the discharge of liquid effluents or contaminated run-off from holding ponds or from your facility unless appropriately permitted or exempted in accordance with State rules and regulations.
7. An annual operation report (DEP Form 17-210.900(4) attached ) shall be submitted by March 1 each year. The attached form shall be reproduced by the permittee and used for future annual submittals.
8. In accordance with F.A.C. Rule 17-213, a Major Air Pollution Source Annual Operation Fee Form [DEP Form 17-213.900(11) attached] must be completed and submitted with appropriate fee between January 15 and March 1 of each year. If the Department has not received the fee payment by March 1, the Department shall impose, in addition to the fee, a penalty of 50 percent of the amount of the fee, plus interest on such amount computed in accordance with s.220.807, Florida Statutes. The Department may revoke any major air pollution source operation permit if it finds that the permit holder has failed to pay timely and required annual operation license fee, penalty or interest. The attached form shall be reproduced by the permittee and used for future annual submittals. The completed form and appropriate fees must be submitted to the Department of Environmental Protection, Title V (Facility I.D. Number), 2600 Blair Stone Road, Tallahassee, Florida 32399-2400.
9. An application to renew this permit shall be submitted prior to May 1, 1998.

PERMITTEE:

Gulf Power Company

I.D. Number: 10PEN17004508

Permit/Certification Number: AO17-234356

Date of Issue: July 30, 1993

Expiration Date: July 1, 1998

SPECIFIC CONDITIONS:

10. The permanent source identification number for this point source is 10PEN17004508. Please cite this number on all test reports and other correspondence specific to the permitted point source.

11. The Department telephone number for reporting problems, malfunctions or exceedances under this permit is (904) 436-8300, day or night, and for emergencies involving a significant threat to human health or the environment is (904) 488-1320. For routine business, telephone (904) 436-8364 during normal working hours.

Expiration Date:

July 1, 1998

Issued this 30<sup>th</sup> day of July,  
1993.

STATE OF FLORIDA DEPARTMENT  
OF ENVIRONMENTAL PROTECTION

  
BOBBY A. COOLEY  
District Director

PERMITTEE:

Gulf Power Company

I.D. Number: 10PEN17004508

Permit/Certification Number: AO17-234356

Date of Issue: July 30, 1993

Expiration Date: July 1, 1998

**GENERAL CONDITIONS:**

1. The terms, conditions, requirements, limitations, and restrictions set forth in this permit are "permit conditions", and are binding and enforceable pursuant to Sections 403.141, 403.727, or 403.859 through 403.861, Florida Statutes. The permittee is placed on notice that the Department will review this permit periodically and may initiate enforcement action for any violation of these conditions.

2. This permit is valid only for the specific processes and operations applied for and indicated in the approved drawings or exhibits. Any unauthorized deviation from the approved drawings, exhibits, specifications, or conditions of this permit may constitute grounds for revocation and enforcement action by the Department.

3. As provided in Subsections 403.087(6) and 403.722(5), Florida Statutes, the issuance of this permit does not convey any vested rights or any exclusive privileges. Nor does it authorize any injury to public or private property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations. This permit does not constitute a waiver of or approval of any other Department permit that may be required for other aspects of the total project which are not addressed in the permit.

4. This permit conveys no title to land or water, does not constitute state recognition or acknowledgment of title, and does not constitute authority for the use of submerged lands unless herein provided and the necessary title or leasehold interests have been obtained from the state. Only the Trustees of the Internal Improvement Trust Fund may express state opinion as to title.

5. This permit does not relieve the permittee from liability for harm or injury to human health or welfare, animal, or plant life, or property caused by the construction or operation of this permitted source, or from penalties therefore; nor does it allow the permittee to cause pollution in contravention of Florida Statutes and Department rules, unless specifically authorized by an order from the Department.

6. The permittee shall properly operate and maintain the facility and systems of treatment and control (and related appurtenances) that are installed and used by the permittee to achieve compliance with the conditions of this permit, are required by Department rules. This provision includes the operation of backup or auxiliary facilities or similar systems when necessary to achieve compliance with the conditions of the permit and when required by Department rules.

7. The permittee, by accepting this permit, specifically agrees to allow authorized Department personnel, upon presentation of credentials or other documents as may be required by law, access to the premises, at reasonable times, where the permitted activity is located or conducted for the purpose of:

a. Having access to and copying any records that must be kept under the conditions of this permit;

b. Inspecting the facility, equipment, practices, or operations regulated or required under this permit; and,

PERMITTEE:

Gulf Power Company

I.D. Number: 10PEN17004508

Permit/Certification Number: AO17-234356

Date of Issue: July 30, 1993

Expiration Date: July 1, 1998

**GENERAL CONDITIONS:**

c. Sampling or monitoring any substances or parameters at any location reasonably necessary to assure compliance with this permit or Department rules.

Reasonable time may depend on the nature of the concern being investigated.

8. If, for any reason, the permittee does not comply with or will be unable to comply with any condition or limitation specified in this permit, the permittee shall immediately provide the Department with the following information:

a. A description of and cause of noncompliance; and

b. The period of noncompliance, including exact dates and times; or, if not corrected, the anticipated time the noncompliance is expected to continue, and steps being taken to reduce, eliminate, and prevent recurrence of the noncompliance. The permittee shall be responsible for any and all damages which may result and may be subject to enforcement action by the Department for penalties or for revocation of this permit.

9. In accepting this permit, the permittee understands and agrees that all records, notes, monitoring data and other information relating to the construction or operation of this permitted source which are submitted to the Department may be used by the Department as evidence in any enforcement case involving the permitted source arising under the Florida Statutes or Department rules, except where such use is proscribed by Sections 403.73 and 403.111, Florida Statutes. Such evidence shall only be used to the extent it is consistent with Florida Rules of Civil Procedure and appropriate evidentiary rules.

10. The permittee agrees to comply with changes in Department rules and Florida Statutes after a reasonable time for compliance, provided however, the permittee does not waive any other rights granted by Florida Statutes or Department rules.

11. This permit is transferable only upon Department approval in accordance with Florida Administrative Code Rules 17-4.120 and 17-730.300, as applicable. The permittee shall be liable for any noncompliance of the permitted activity until the transfer is approved by the Department.

12. This permit is required to be kept at the work site of the permitted activity during the entire period of construction or operation.

13. The permittee shall comply with the following:

a. Upon request, the permittee shall furnish all records and plans required under Department rules. During enforcement actions, the retention period for all records will be extended automatically unless otherwise stipulated by the Department.

b. The permittee shall hold at the facility or other location designated by this permit records of all monitoring information (including all calibration and maintenance records and all original strip chart recordings for continuous

**PERMITTEE:**

Gulf Power Company

I.D. Number: 10PEN17004508

Permit/Certification Number: AO17-234356

Date of Issue: July 30, 1993

Expiration Date: July 1, 1998

**GENERAL CONDITIONS:**

monitoring instrumentation) required by the permit, copies of all reports required by this permit, and records of all data used to complete the application for this permit. These materials shall be retained at least three years from the date of the sample, measurement, report or application unless otherwise specified by Department rule.


**c. Records of monitoring information shall include:**

- the date, exact place, and time of sampling or measurement;
- the person responsible for performing the sampling or measurement;
- the date(s) analyses were performed;
- the person responsible for performing the analyses;
- the analytical techniques or methods used; and
- the results of such analyses.

14. When requested by the Department, the permittee shall within a reasonable time furnish any information required by law which is needed to determine compliance with the permit. If the permittee becomes aware the relevant facts were not submitted or were incorrect in the permit application or in any report to the Department, such facts or information shall be corrected promptly.



DEPARTMENT OF ENVIRONMENTAL REGULATION



BOB GRAHAM  
GOVERNOR

VICTORIA J. TSCHINKEL  
SECRETARY

ROBERT V. KRIEDEL  
DISTRICT MANAGER

OCT 27 1981

NORTHWEST DISTRICT  
60 GOVERNMENTAL CENTER  
PENSACOLA, FLORIDA 32531

Mr. George O. Layman  
Director of Power Supply  
Gulf Power Company  
P. O. Box 1151  
Pensacola, Florida 32520

Dear Mr. Layman:

Enclosed is Permit Number AC17-47675, dated OCT 27 1981, to construct a fly ash storage silo, issued pursuant to Section 403.087, Florida Statutes.

Should you object to this permit, including any and all of the conditions contained therein, you may file an appropriate petition for administrative hearing. This petition must be filed within 14 days of the receipt of this letter. Further, the petition must conform to the requirements of Section 28-5.201, Florida Administrative Code (see reverse). The petition must be filed with the Office of General Counsel, Department of Environmental Regulation, Twin Towers Office Building, 2600 Blair Stone Road, Tallahassee, Florida 32301.

If no petition is filed within the prescribed time, you will be deemed to have accepted this permit and waived your right to request an administrative hearing on this matter.

Acceptance of the permit constitutes notice and agreement that the Department will periodically review this permit for compliance, including site inspections where applicable, and may initiate enforcement action for violation of the conditions and requirements thereof.

Sincerely,


Thomas W. Moody, P.E.  
Special Programs Supervisor

TWM:d  
Enclosure

STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL REGULATION

NORTHWEST DISTRICT

60 GOVERNMENTAL CENTER  
PENSACOLA, FLORIDA 32501



BOB GRAHAM  
GOVERNOR

VICTORIA J. TSCHINKEL  
SECRETARY

ROBERT V. KRIEDEL  
DISTRICT MANAGER

APPLICANT:

Gulf Power Company

CONSTRUCTION  
PERMIT/CERTIFICATION  
NO. AC17-47675

COUNTY: Escambia

PROJECT:  
Fly Ash Storage Silo

This permit is issued under the provisions of Chapter 403, Florida Statutes, and Chapter 17-4, Florida Administrative Code. The above named applicant, hereinafter called Permittee, is hereby authorized to perform the work or operate the facility shown on the approved drawing(s), plans, documents, and specifications attached hereto and made a part hereof and specifically described as follows:

To construct two Fly Ash Storage Silos. Fly ash collection systems from precipitators on boilers numbers 4, 5, 6 & 7 to three transfer tanks are totally enclosed with no emission points. Three blowers pneumatically convey dry fly ash to 2 silos at a maximum solids rate of 150 tons per hour to either silo or to both. The majority of the solids (99.4%) settles by gravity upon entering the silo, the residual particulates are controlled by a baghouse on each silo. Each baghouse is a Pulse Jet Fabric Filter - Model #100 - WWC-420 (IIG) manufactured by Flex-Kleen. Dry fly ash will be transported in closed tanker trucks away from the site or conditioned (12-15% water added) fly ash will be transported to an approved landfill area on the site.

Location: Approximately 3 miles northeast of the intersection of SR 292 and 10 Mile Road north of Pensacola

Latitude: 30° 33' 54 1/2"N

Longitude: 87° 13' 41 1/2"W

PERMIT NO.: AC17-47675  
APPLICANT: Gulf Power Company

SPECIFIC CONDITIONS:

13. The Department shall be notified within 15 days after initial startup of this source and prior to testing to allow witnessing of tests.
14. The Department shall be notified and prior approval shall be obtained of any changes or revisions made during construction.
15. The maximum allowable operating rate is 150 tons of fly ash transported per hour. This is the operating rate at which compliance with standards shall be demonstrated.
16. Visible emissions shall not exceed 5% opacity under normal operating conditions.
17. Visible emissions tests are required to show compliance with the standards of the Department. The test results must provide reasonable assurance that the source is capable of compliance at the permitted maximum operating rate. Tests shall be conducted in accordance with EPA Method 9. Such tests shall be scheduled within 30 days after construction is completed. Observations shall be made on both emission points of each silo while the specific silo is receiving the maximum loading rate, and each tested silo shall be at least 1/2 full at the time of compliance testing. The loading rate and silo level data shall be made a part of the test report.
18. The applicant shall retain the engineer of record for the inspection of the construction of this project. Upon completion the engineer shall inspect for conformity to the permit application and associated documents. A Certificate of Completion (Form DER 17-1.122(20) attached) shall be submitted with the compliance test results and a fee of \$20 as an application for an operation permit. These are to be submitted within 75 days after completion of construction.
19. All fugitive dust generated at this site shall be adequately controlled.
20. This permit does not authorize any discharges of liquid effluents or contaminated runoff from this source.


PERMIT NO.: AC17-47675  
APPLICANT: Gulf Power Company

Expiration Date:

February 1, 1983

Issued this 27th day of October,  
1981.

STATE OF FLORIDA DEPARTMENT  
OF ENVIRONMENTAL REGULATION



ROBERT V. KRIEGEL  
District Manager

BEST AVAILABLE COPY

Post Office Box 1151  
Pensacola, FL 32520  
Telephone 904 444-6111

MCC  
JAT  
Gulf Power

August 24, 1993

Mr. Ed K. Middleswart, P.E.  
Florida Department of Environmental Protection  
Northwest District  
160 Governmental Center  
Pensacola, Florida 32501-5794

Dear Mr. Middleswart:

**OIL CONTAMINATED MATERIALS**

On August 18, 1993, Andy Allen of your staff and I discussed current regulations covering energy recovery of oil contaminated soils. Pursuant to those discussions, I agreed to document to the department Gulf's current understanding of recycling requirements and overview our present practices.

Recently, Gulf Power has made several notifications to the waste and air sections of FDEP regarding energy recovery operations concerning oil contaminated soils at Plants Smith and Scholz. Florida regulations currently exempt operations of this type for electric utility sources as long as the material is considered non-hazardous and the material is handled in a responsible manner. In lieu of continuing the process of making courteous notifications, the Department and Gulf have reached an agreement that no further notification is needed for small de-minus operations. Operations involving major cleanup operations will continue to be noticed by Gulf for monitoring purposes. For example, Gulf Power is preparing a Contamination Assessment Report (CAR) for a situation at Plant Smith. Energy recovery of this type of material will be managed on a case by case basis as part of an approved cleanup plan.

If you have any questions or need further information, please call me at (904) 444-6527.

Sincerely,

  
G. Dwain Waters

Senior Environmental Affairs Specialist

cc: Florida Department of Environmental Protection  
Mike Kennedy

Gulf Power Company

M. L. Gilchrist  
J. A. Tucker  
J. O. Vick

"Our business is customer satisfaction"



EUS-14

UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

REGION 4

246 DOLYBELL STREET, N.E.  
ATLANTA, GEORGIA 30345

## PHASE I ACID RAIN PERMIT

Issued to: Gulf Power Company-Crist  
Operated by: Gulf Power Company  
Effective: January 1, 1995 to December 31, 1999

### Summary of Previous Actions

This page will be replaced to document new EPA actions each time a new action is taken by the Agency. The following actions have been taken:

1. Draft permit, including SO<sub>2</sub> compliance plan,  
issued for public comment  
(See page 1) July 16, 1993
2. SO<sub>2</sub> portion of permit finalized and issued September 3, 1993
3. Permit revised to include a draft nitrogen oxides  
Compliance Plan for Units 6 and 7, issued for  
public comment on the NO<sub>x</sub> portion only.  
(see page 4(a) and 5(a) and the NO<sub>x</sub> compliance plan forms) August 24, 1994
4. NO<sub>x</sub> portion of permit finalized and issued October 19, 1994
5. Permit revised to include a draft SO<sub>2</sub> Substitution Plan,  
issued for public comment on the proposed revision only  
(See page 5, 6, and 7) November 4, 1994
6. SO<sub>2</sub> portion of permit revision finalized and issued December 27, 1994



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

REGION 4

345 COURTLAND STREET, N.E.  
ATLANTA, GEORGIA 30365

Plant Name: Crist  
State: Florida  
ORIS Code: 0641

7. Permit revised to activate the conditional SO<sub>2</sub> Substitution Plan for Units 4, 5, and 7, issued as an administrative amendment (See page 5, 6, and 7) February 14, 1995
8. Permit administratively amended to change compliance dates for nitrogen oxides compliance plans [and to change requirements in NO<sub>x</sub> averaging plans] consistent with 40 CFR part 76 (as promulgated on April 13, 1995) June 22, 1995
9. Permit revised to include a draft nitrogen oxides Emissions Averaging Plan for Units 4, 5, and 6, issued for public comment on the NO<sub>x</sub> portion only, consistent with 40 CFR part 76 (as promulgated on April 13, 1995) (see page 4(a), 6(a), and 7(a) and the NO<sub>x</sub> compliance plan) September 21, 1995

**Present Action**

10. NO<sub>x</sub> portion of permit revised to reflect changes in the draft NO<sub>x</sub> averaging plan for Units 4, 5, and 6, issued as a permit modification (see page 4(a), 6(a), and 7(a) and the NO<sub>x</sub> compliance plan)
11. Permit revised to include a SO<sub>2</sub> reduced utilization plan for Units 4, 5, 6, and 7, issued as an administrative amendment (See page 3, 4, 5, 6, and 7 and the SO<sub>2</sub> compliance plan)

Bruce R. Miller for

12/14/95

Signature

Date

Winston A. Smith  
Director, Air, Pesticides and Toxics Management Division  
U.S. Environmental Protection Agency, Region 4  
345 Courtland Street, N.E.  
Atlanta, Georgia 30365  
Telephone: (404) 347-3043 Facsimile: (404) 347-5207

Statement of Basis. Part B

Plant Name: Crist Electric Generating Plant
State: Florida
ORIS Code: 0641
Boiler ID#: 0006

Phase I SO2 Allowance Allocation

Table with 6 columns (Year) and 5 rows (Table 1, Phase I Extension, Substitution, Reduced Utilization) showing allowance values for 1995-1999.

Comments, notes and justifications regarding permit decisions, and changes made to the permit application forms during the review process:

See changes made to the Permit Application form on Statement of Basis, page 2.

Pursuant to 40 CFR 72.42 and the ranking of Phase I Extension Early Ranking applications determined by lottery on March 31, 1993, the Phase I Extension plan for Indianapolis Power and Light Company-Petersburg, naming this unit as a transfer unit, has not been approved.

\* If Phase I Extension reserve allowances become available in the future, this application is eligible to receive the allocations specified above by administrative amendment to this permit if the Phase I Extension plan continues to meet the requirements of 40 CFR 72.42.

\* If Phase I Extension allowances became available for this unit prior to January 1, 1995, this unit will also receive an extension of the deadline for compliance with regulations implementing Section 407 of the Clean Air Act (nitrogen oxides).

R. SCOTT DAVIS
Permit Reviewer

R. Scott Davis
Signature

12-11-95
Date



Plant Name: Crist Electric Generating Plant  
State: Florida  
ORIS Code: 0641  
Boiler ID#: 0006

**Comments, notes and justifications regarding permit decisions, and changes made to the permit application forms during the review process:**

Consistent with the Partial Settlement Agreement in Environmental Defense Fund v. Carol M. Browner, No. 93-1203 (executed on May 4, 1994):

1. EPA approves a reduced utilization plan for this unit for 1995 that designates these Southern Company units (see attachments to plan dated October 16, 1995) as compensating units or sulfur free generators. This plan results in the use of improved unit efficiency measures or the shifting of electrical generation to account for underutilization of this unit. There is no allowance allocation for the use of this compliance measure.

R. SCOTT DAVIS

Permit Reviewer

R. Scott Davis

Signature

12-11-95

Date

**Statement of Basis. Part B**

Page 4(a)

Plant Name: Crist  
State: Florida  
ORIS Code: 0641  
Boiler ID#: 0006

**NO<sub>x</sub> Compliance Plan**

EPA approves a nitrogen oxides emissions averaging plan for this unit for 1996-1999. For each year under the plan, this unit's actual annual average emission rate for NO<sub>x</sub> shall not exceed the alternative contemporaneous annual emission limitation of 0.60 lbs/mmBtu, and this unit's actual annual heat input shall not be greater than the annual heat input limit of 13,451,097 mmBtu.

The other units designated in the plan are Crist Unit 4 and Unit 5, Scholz Unit 1 and Unit 2, Watson Unit 4 and Unit 5, and Daniel Unit 1 and Unit 2. Under the plan, the actual Btu-weighted annual average emission rate for the units in the plan shall be less than or equal to the Btu-weighted annual average rate for the same units had they each been operated, during the same period of time, in compliance with the applicable emission limitation in 40 CFR 76.5. If the designated representative demonstrates that the requirement of the prior sentence (as set forth in 40 CFR 76.11(d)(1)(ii)(A)) is met for a year under the plan, then this unit shall be deemed to be in compliance for that year with its alternative contemporaneous annual emission limitation and annual heat input limit.

R. SCOTT DAVIS  
Permit Reviewer

R. Scott Davis  
Signature

12-11-95  
Date

Plant Name: Crist Electric Generating Plant  
 State: Florida  
 ORIS Code: 0641  
 Boiler ID#: 0007

**Phase I SO<sub>2</sub> Allowance Allocation**

	1995	1996	1997	1998	1999
Table 1 40 CFR 73.10	30,846	30,846	30,846	30,846	30,846
Phase I Extension 40 CFR 72.42	19,857	19,857	0	0	0
Substitution 40 CFR 72.41	0	0	0	0	0
Reduced Utilization 40 CFR 72.43	0	N/A	N/A	N/A	N/A

**Comments, notes and justifications regarding permit decisions, and changes made to the permit application forms during the review process:**

See changes made to the Permit Application form on Statement of Basis, page 2.

Pursuant to 40 CFR 72.42 and the ranking of Phase I Extension Early Ranking applications determined by lottery on March 31, 1993, the Phase I Extension plan for Virginia Electric & Power Company-Mount Storm, naming this unit as a transfer unit, has been approved. Pursuant to 40 CFR 72.42 and the attached Phase I Extension Early Ranking application forms, this unit has an Acid Rain emissions reduction requirement limiting SO<sub>2</sub> emissions to a maximum of 48,702 tons per year for 1997, 1998, and 1999. The Phase I Extension Early Ranking forms were modified to correct rounding errors at steps 35, 38, and 41 pursuant to a letter from the designated representative, dated March 11, 1993. This unit has also been granted an extension, until January 1, 1997, of the deadline for compliance with regulations implementing Section 407 of the Clean Air Act (nitrogen oxides).

Consistent with the Partial Settlement Agreement in Environmental Defense Fund v. Carol M. Browner, No. 93-1203 (executed on May 4, 1994):

1. EPA approves a substitution plan for this unit for 1995-1999 that designates Gulf Power Company-Scholz Unit 1 and Unit 2; Crist Unit 4 and Unit 5, and Lansing Smith Unit 1 and Unit 2 as substitution units.
2. EPA approves a reduced utilization plan for this unit for 1995 that designates these Southern Company units (see attachments to plan dated October 16, 1995) as compensating units or sulfur free generators. This plan results in the use of improved unit efficiency measures or the shifting of electrical generation to account for underutilization of this unit. There is no allowance allocation for the use of this compliance measure.

R. SCOTT DAVIS  
 Permit Reviewer

*R. Scott Davis*  
 Signature

12-11-95  
 Date

Statement of Basis. Part B

Plant Name: Crist  
 State: Florida  
 ORIS Code: 0641  
 Boiler ID#: 0004

Phase I SO<sub>2</sub> Allowance Allocation

	1995	1996	1997	1998	1999
Table 1 40 CFR 73.10	N/A	N/A	N/A	N/A	N/A
Phase I Extension 40 CFR 72.42	N/A	N/A	N/A	N/A	N/A
Substitution 40 CFR 72.41	9,953	9,953	9,953	9,953	9,953
Reduced Utilization 40 CFR 72.43	0	N/A	N/A	N/A	N/A

Comments, notes and justifications regarding permit decisions, and changes made to the permit application forms during the review process:

See changes made to the Permit Application form on Statement of Basis, page 2.

Consistent with the Partial Settlement Agreement in Environmental Defense Fund v. Carol M. Browner, No. 93-1203 (executed on May 4, 1994):

1. EPA approves a substitution plan for this unit for 1995-1999 in which it is designated as a substitution unit for Gulf Power Company-Crist Unit 7, a Phase I unit. This substitution unit will receive the allowances indicated above. In this plan, Crist Unit 5, Scholz Unit 1 and Unit 2, and Lansing Smith Unit 1 and Unit 2 are also designated as substitution units by the Phase I unit.
2. The value in step 3, column g, of the substitution plan for this unit reflects the lesser of (i) the unit's 1985 actual emission rate from NADB, (ii) the unit's 1985 allowable emission rate from NADB, (iii) the greater of the unit's 1989 or 1990 actual emissions rate, or (iv) the unit's most stringent federally enforceable or state enforceable emissions limitation for Phase I as of November 15, 1990.
3. EPA approves a reduced utilization plan for this unit for 1995 that designates these Southern Company units (see attachments to plan dated October 16, 1995) as compensating units or sulfur free generators. This plan results in the use of improved unit efficiency measures or the shifting of electrical generation to account for underutilization of this unit. There is no allowance allocation for the use of this compliance measure.

R. SCOTT DAVIS  
 Permit Reviewer

*R. Scott Davis*  
 Signature

12-11-95  
 Date

**Statement of Basis. Part B**

Plant Name: Crist  
State: Florida  
ORIS Code: 0641  
Boiler ID#: 0004

**NO<sub>x</sub> Compliance Plan**

EPA approves a nitrogen oxides emissions averaging plan for this unit for 1996-1999. For each year under the plan, this unit's actual annual average emission rate for NO<sub>x</sub> shall not exceed the alternative contemporaneous annual emission limitation of 0.60 lbs/mmBtu, and this unit's actual annual heat input shall not be greater than the annual heat input limit of 4,330,920 mmBtu. 494.4

The other units designated in the plan are Crist Unit 5 and Unit 6, Scholz Unit 1 and Unit 2, Watson Unit 4 and Unit 5, and Daniel Unit 1 and Unit 2. Under the plan, the actual Btu-weighted annual average emission rate for the units in the plan shall be less than or equal to the Btu-weighted annual average rate for the same units had they each been operated, during the same period of time, in compliance with the applicable emission limitation in 40 CFR 76.5. If the designated representative demonstrates that the requirement of the prior sentence (as set forth in 40 CFR 76.11(d)(1)(ii)(A)) is met for a year under the plan, then this unit shall be deemed to be in compliance for that year with its alternative contemporaneous annual emission limitation and annual heat input limit.

R. SCOTT DAVIS  
Permit Reviewer

R. Scott Davis  
Signature

12-11-95  
Date

Plant Name: Crist  
 State: Florida  
 ORIS Code: 0641  
 Boiler ID#: 0005

**Phase I SO<sub>2</sub> Allowance Allocation**

	1995	1996	1997	1998	1999
Table 1 40 CFR 73.10	N/A	N/A	N/A	N/A	N/A
Phase I Extension 40 CFR 72.42	N/A	N/A	N/A	N/A	N/A
Substitution 40 CFR 72.41	9,374	9,374	9,374	9,374	9,374
Reduced Utilization 40 CFR 72.43	0	N/A	N/A	N/A	N/A

**Comments, notes and justifications regarding permit decisions, and changes made to the permit application forms during the review process:**

See changes made to the Permit Application form on Statement of Basis, page 2.

Consistent with the Partial Settlement Agreement in Environmental Defense Fund v. Carol M. Browner, No. 93-1203 (executed on May 4, 1994):

1. EPA approves a substitution plan for this unit for 1995-1999 in which it is designated as a **substitution unit for Gulf Power Company-Crist Unit 7, a Phase I unit**. This substitution unit will receive the allowances indicated above. In this plan, Crist Unit 4, Scholz Unit 1 and Unit 2, and Lansing Smith Unit 1 and Unit 2 are also designated as substitution units by the Phase I unit.
2. The value in step 3, column h, of the substitution plan for this unit reflects the lesser of (i) the unit's 1985 actual emission rate from NADB, (ii) the unit's 1985 allowable emission rate from NADB, (iii) the greater of the unit's 1989 or 1990 actual emissions rate, or (iv) the unit's most stringent federally enforceable or state enforceable emissions limitation for Phase I as of November 15, 1990.
3. EPA approves a reduced utilization plan for this unit for 1995 that designates these Southern Company units (see attachments to plan dated October 16, 1995) as compensating units or sulfur free generators. This plan results in the use of improved unit efficiency measures or the shifting of electrical generation to account for underutilization of this unit. There is no allowance allocation for the use of this compliance measure.

R. SCOTT DAVIS  
 Permit Reviewer

R. Scott Davis  
 Signature

12-11-95  
 Date

Plant Name: Crist  
State: Florida  
ORIS Code: 0641  
Boiler ID#: 0005

**NO<sub>x</sub> Compliance Plan**

EPA approves a nitrogen oxides emissions averaging plan for this unit for 1996-1999. For each year under the plan, this unit's actual annual average emission rate for NO<sub>x</sub> shall not exceed the alternative contemporaneous annual emission limitation of 0.60 lbs/mmBtu, and this unit's actual annual heat input shall not be greater than the annual heat input limit of 3,518,988 mmBtu.

The other units designated in the plan are Crist Unit 4 and Unit 6, Scholz Unit 1 and Unit 2, Watson Unit 4 and Unit 5, and Daniel Unit 1 and Unit 2. Under the plan, the actual Btu-weighted annual average emission rate for the units in the plan shall be less than or equal to the Btu-weighted annual average rate for the same units had they each been operated, during the same period of time, in compliance with the applicable emission limitation in 40 CFR 76.5. If the designated representative demonstrates that the requirement of the prior sentence (as set forth in 40 CFR 76.11(d)(1)(ii)(A)) is met for a year under the plan, then this unit shall be deemed to be in compliance for that year with its alternative contemporaneous annual emission limitation and annual heat input limit.

R. SCOTT DAVIS  
Permit Reviewer

R. Scott Davis  
Signature

12-11-95  
Date



# NO<sub>x</sub> Averaging Plan

**RECEIVED**  
12-11-95

For more information, see instructions and refer to 40 CFR 76.11

This submission is:  New  Revised

**STEP 1**

Identify the units participating in this averaging plan by plant name, State, and boiler ID# from NADB. In column (a), fill in each unit's applicable emission limitation from 40 CFR 76.5, 76.6, or 76.7. In column (b), assign an alternative contemporaneous annual emissions limitation in lb/mmBtu to each unit. In column (c), assign an annual heat input limitation in mmBtu to each unit. Continue on page 3 if necessary

Plant Name	State	ID#	(a) Emission Limitation	(b) Alt. Contemp. Emission Limitation	(c) Annual Heat Input Limit
Watson	MS	4	.50	.57	12086872
Watson	MS	5	.50	.57	20127887
Daniel	MS	1	.45	.35	21244417
Daniel	MS	2	.45	.35	29987051
Crist	FL	4	.45	.60	4330920
Crist	FL	5	.45	.60	3518988
Crist	FL	6	.50	.60	13451097
Scholz	FL	1	.50	.70	723608
Scholz	FL	2	.50	.75	731528

**STEP 2**

Use the formula to enter the Btu-weighted annual emission rate averaged over the units if they are operated in accordance with the proposed averaging plan and the Btu-weighted annual average emission rate for the same units if they are operated in compliance with 40 CFR 76.5, 76.6, or 76.7. The former must be less than or equal to the latter

Btu-weighted annual emission rate averaged over the units if they are operated in accordance with the proposed averaging plan

.4720

≤

Btu-weighted annual average emission rate for same units operated in compliance with 40 CFR 76.5, 76.6 or 76.7

.4722

$$\frac{\sum_{i=1}^n (R_{Li} \times HI_i)}{\sum_{i=1}^n HI_i}$$

≤

$$\frac{\sum_{i=1}^n (R_{ii} \times HI_i)}{\sum_{i=1}^n HI_i}$$

Where:

- $R_{Li}$  = Alternative contemporaneous annual emission limitation for unit i, in lb. mmBtu, as specified in column (b) of Step 1;
- $R_{ii}$  = Applicable emission limitation for unit i, in lb. mmBtu, as specified in column (a) of Step 1;
- $HI_i$  = Annual heat input for unit i, in mmBtu, as specified in column (c) of Step 1;
- $n$  = Number of units in the averaging plan



# Phase II Permit Application

For more information, see instructions and refer to 40 CFR 72.30 and 72.31 and Chapter 62-214, F.A.C.

This submission is:  New  Revised

**STEP 1**  
Identify the source by plant name, State, and ORIS code from NADB

Plant Name	Crist	FL State	641 ORIS Code
------------	-------	----------	---------------

**STEP 2**  
Enter the boiler ID# from NADB for each affected unit, and indicate whether a repowering plan is being submitted for the unit by entering "yes" or "no" at column c. For new units, enter the requested information in columns d and e

Compliance Plan				
a	b	c	d	e
Boiler ID#	Unit Will Hold Allowances in Accordance with 40 CFR 72.9(c)(1)	Repowering Plan	New Units  Commence Operation Date	New Units  Monitor Certification Deadline
1	Yes	No		
2	Yes	No		
3	Yes	No		
4	Yes	No		
5	Yes	No		
6	Yes	No		
7	Yes	No		
	Yes			
	Yes			
	Yes			
	Yes			
	Yes			

For each unit that will be repowered, the Repowering Extension Plan form is included and the Repowering Technology Petition form has been submitted or will be submitted by June 1, 1997.

**STEP 3**  
Check the box if the response in column c of Step 2 is "Yes" for any unit

P. Name (from Step 1)

**STEP 4**

Read the standard requirements and certification, enter the name of the designated representative, and sign and date

**Standard Requirements****Permit Requirements.**

- (1) The designated representative of each Acid Rain source and each Acid Rain unit at the source shall:
  - (i) Submit a complete Acid Rain part application (including a compliance plan) under 40 CFR part 72, Rules 62-214.320 and 330, F.A.C. in accordance with the deadlines specified in Rule 62-214.320, F.A.C.; and
  - (ii) Submit in a timely manner any supplemental information that the permitting authority determines is necessary in order to review an Acid Rain part application and issue or deny an Acid Rain permit.
- (2) The owners and operators of each Acid Rain source and each Acid Rain unit at the source shall:
  - (i) Operate the unit in compliance with a complete Acid Rain part application or a superseding Acid Rain part issued by the permitting authority; and
  - (ii) Have an Acid Rain Part.

**Monitoring Requirements.**

- (1) The owners and operators and, to the extent applicable, designated representative of each Acid Rain source and each Acid Rain unit at the source shall comply with the monitoring requirements as provided in 40 CFR part 75, and Rule 62-214.420, F.A.C.
- (2) The emissions measurements recorded and reported in accordance with 40 CFR part 75 shall be used to determine compliance by the unit with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program.
- (3) The requirements of 40 CFR part 75 shall not affect the responsibility of the owners and operators to monitor emissions of other pollutants or other emissions characteristics at the unit under other applicable requirements of the Act and other provisions of the operating permit for the source.

**Sulfur Dioxide Requirements.**

- (1) The owners and operators of each source and each Acid Rain unit at the source shall:
  - (i) Hold allowances, as of the allowance transfer deadline, in the unit's compliance subaccount (after deductions under 40 CFR 73.34(c)) not less than the total annual emissions of sulfur dioxide for the previous calendar year from the unit; and
  - (ii) Comply with the applicable Acid Rain emissions limitations for sulfur dioxide.
- (2) Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act.
- (3) An Acid Rain unit shall be subject to the requirements under paragraph (1) of the sulfur dioxide requirements as follows:
  - (i) Starting January 1, 2000, an Acid Rain unit under 40 CFR 72.6(a)(2); or
  - (ii) Starting on the later of January 1, 2000 or the deadline for monitor certification under 40 CFR part 75, an Acid Rain unit under 40 CFR 72.6(a)(3).
- (4) Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program.
- (5) An allowance shall not be deducted in order to comply with the requirements under paragraph (1)(i) of the sulfur dioxide requirements prior to the calendar year for which the allowance was allocated.
- (6) An allowance allocated by the Administrator under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the Acid Rain permit application, the Acid Rain permit, or the written exemption under 40 CFR 72.7 and 72.8 and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization.
- (7) An allowance allocated by the Administrator under the Acid Rain Program does not constitute a property right.

**Nitrogen Oxides Requirements.** The owners and operators of the source and each Acid Rain unit at the source shall comply with the applicable Acid Rain emissions limitation for nitrogen oxides.

**Excess Emissions Requirements.**

- (1) The designated representative of an Acid Rain unit that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR part 77.
- (2) The owners and operators of an Acid Rain unit that has excess emissions in any calendar year shall:
  - (i) Pay without demand the penalty required, and pay upon demand the interest on that penalty, as required by 40 CFR part 77; and
  - (ii) Comply with the terms of an approved offset plan, as required by 40 CFR part 77.

**Recordkeeping and Reporting Requirements.**

- (1) Unless otherwise provided, the owners and operators of the source and each Acid Rain unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time prior to the end of 5 years, in writing by the Administrator or permitting authority:
  - (i) The certificate of representation for the designated representative for the source and each Acid Rain unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with Rule 62-214.350, F.A.C.; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation changing the designated representative;
  - (ii) All emissions monitoring information, in accordance with 40 CFR part 75;
  - (iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the Acid Rain Program; and,

Plant Name (from Step 1)

Recordkeeping and Reporting Requirements (cont.)

- (iv) Copies of all documents used to complete an Acid Rain part application and any other submission under the Acid Rain Program or to demonstrate compliance with the requirements of the Acid Rain Program.
- (2) The designated representative of an Acid Rain source and each Acid Rain unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR part 72 subpart I and 40 CFR part 75.

Liability.


- (1) Any person who knowingly violates any requirement or prohibition of the Acid Rain Program, a complete Acid Rain part application, an Acid Rain part, or a written exemption under 40 CFR 72.7 or 72.8, including any requirement for the payment of any penalty owed to the United States, shall be subject to enforcement pursuant to section 113(c) of the Act.
- (2) Any person who knowingly makes a false, material statement in any record, submission, or report under the Acid Rain Program shall be subject to criminal enforcement pursuant to section 113(c) of the Act and 18 U.S.C. 1001.
- (3) No permit revision shall excuse any violation of the requirements of the Acid Rain Program that occurs prior to the date that the revision takes effect.
- (4) Each Acid Rain source and each Acid Rain unit shall meet the requirements of the Acid Rain Program.
- (5) Any provision of the Acid Rain Program that applies to an Acid Rain source (including a provision applicable to the designated representative of an Acid Rain source) shall also apply to the owners and operators of such source and of the Acid Rain units at the source.
- (6) Any provision of the Acid Rain Program that applies to an Acid Rain unit (including a provision applicable to the designated representative of an Acid Rain unit) shall also apply to the owners and operators of such unit. Except as provided under 40 CFR 72.44 (Phase II repowering extension plans), and except with regard to the requirements applicable to units with a common stack under 40 CFR part 75 (including 40 CFR 75.16, 75.17, and 75.18), the owners and operators and the designated representative of one Acid Rain unit shall not be liable for any violation by any other Acid Rain unit of which they are not owners or operators or the designated representative and that is located at a source of which they are not owners or operators or the designated representative.
- (7) Each violation of a provision of 40 CFR parts 72, 73, 75, 77, and 78 by an Acid Rain source or Acid Rain unit, or by an owner or operator or designated representative of such source or unit, shall be a separate violation of the Act.

Effect on Other Authorities. No provision of the Acid Rain Program, an Acid Rain part application, an Acid Rain part, or a written exemption under 40 CFR 72.7 or 72.8 shall be construed as:

- (1) Except as expressly provided in title IV of the Act, exempting or excluding the owners and operators and, to the extent applicable, the designated representative of an Acid Rain source or Acid Rain unit from compliance with any other provision of the Act, including the provisions of title I of the Act relating to applicable National Ambient Air Quality Standards or State Implementation Plans;
- (2) Limiting the number of allowances a unit can hold; provided, that the number of allowances held by the unit shall not affect the source's obligation to comply with any other provisions of the Act;
- (3) Requiring a change of any kind in any State law regulating electric utility rates and charges, affecting any State law regarding such State regulation, or limiting such State regulation, including any prudence review requirements under such State law;
- (4) Modifying the Federal Power Act or affecting the authority of the Federal Energy Regulatory Commission under the Federal Power Act; or,
- (5) Interfering with or impairing any program for competitive bidding for power supply in a State in which such program is established.

Certification

I am authorized to make this submission on behalf of the owners and operators of the Acid Rain source or Acid Rain units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fines or imprisonment.

Name	M. L. Gilchrist	
Signature		Date 12/8/95

STEP 5 (optional)  
Enter the source AIRS  
and FINDS identification  
numbers, if known

S
FINDS

United States  
Environmental Protection Agency  
Acid Rain Program

EPA Form 346  
Expires 6/30/93



# Certificate of Representation

For more information, see instructions and refer to 40 CFR 72.24

This submission is:  New  Revised

**STEP 1**  
Identify the source by  
plant name, State, and  
ORIS code from NADB

Plant Name **Crist Electric Generating Plant**

State **FL** ORIS **541-0000**

**STEP 2**  
Enter requested  
information for the  
designated  
representative

Name **Frederick D. Kuester**

Address  
**2992 West Beach Boulevard  
P. O. Box 4079  
Gulfport, MS 39502**

Phone Number **(601) 865-5964**

Fax Number **(601) 865-5873**

**STEP 3**  
Enter requested  
information for the  
alternate designated  
representative  
(optional)

Name **M. L. Gilchrist**

Address  
**Gulf Power Company  
P. O. Box 1151  
Pensacola, FL 32520-0328**

Phone Number **(904) 444-6236**

Fax Number **(904) 444-6705**

**STEP 4**  
Complete Step 5, read  
the certifications and  
sign and date

I certify that I was selected as the designated representative or alternate designated representative, as applicable, by an agreement binding on the owners and operators of the affected source and each affected unit at the source.

I certify that I have given notice of the agreement, selecting me as the designated representative or alternate designated representative, as applicable for the affected source and each affected unit at the source identified in this certificate of representation, daily for a period of one week in a newspaper of general circulation in the area where the source is located or in a State publication designed to give general public notice.

I certify that I have all necessary authority to carry out my duties and responsibilities under the Acid Rain Program on behalf of the owners and operators of the affected source and of each affected unit at the source and that each such owner and operator shall be fully bound by my actions, inactions, or submissions.

I certify that I shall abide by any fiduciary responsibilities imposed by the agreement by which I was selected as designated representative or alternate designated representative, as applicable.

I certify that the owners and operators of the affected source and of each affected unit at the source shall be bound by any order issued to me by the Administrator, the permitting authority, or a court regarding the source or unit.

Where there are multiple holders of a legal or equitable title to, or a leasehold interest in, an affected unit where a utility or industrial customer purchases power from an affected unit under life-of-the-unit, firm or contractual arrangements, I certify that:

I have given a written notice of my selection as the designated representative or alternate designated representative, as applicable, and of the agreement by which I was selected to each owner and operator of the affected source and of each affected unit at the source; and

Allowances and the proceeds of transactions involving allowances will be deemed to be held or distributed in proportion to each holder's legal, equitable, leasehold, or contractual reservation or entitlement or, if such multiple holders have expressly provided for a different distribution of allowances under contract, that allowances and the proceeds of transactions involving allowances will be deemed to be held or distributed in accordance with the contract.

The agreement by which I was selected as the alternate designated representative includes a procedure for the resolution of disputes between the designated representative and the alternate designated representative.

Crist Electric Generating Plant  
Plant Name (from Step 1)

Certification

I am authorized to make this submission on behalf of the owners and operators of the affected source or affected units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Signature (designated representative) *Frederick D. Kuster* Date 12/21/94  
Signature (alternate) *[Signature]* Date 12/21/94

**STEP 5**  
Provide the name of every owner and operator of the source and each affected unit at the source. Identify the units they own and/or operate by boiler ID# from NADS. For owners only, identify each state or local utility regulatory authority with jurisdiction over each owner

Name Gulf Power Company						<input checked="" type="checkbox"/> Owner	<input checked="" type="checkbox"/> Operator
ID# 1	ID# 2	ID# 3	ID# 4	ID# 5	ID# 6	ID# 7	
ID#	ID#	ID#	ID#	ID#	ID#	ID#	
Regulatory Authorities Florida Public Service Commission							

Name						<input type="checkbox"/> Owner	<input type="checkbox"/> Operator
ID#	ID#	ID#	ID#	ID#	ID#	ID#	
ID#	ID#	ID#	ID#	ID#	ID#	ID#	
Regulatory Authorities							

Name						<input type="checkbox"/> Owner	<input type="checkbox"/> Operator
ID#	ID#	ID#	ID#	ID#	ID#	ID#	
ID#	ID#	ID#	ID#	ID#	ID#	ID#	
Regulatory Authorities							

Name						<input type="checkbox"/> Owner	<input type="checkbox"/> Operator
ID#	ID#	ID#	ID#	ID#	ID#	ID#	
ID#	ID#	ID#	ID#	ID#	ID#	ID#	
Regulatory Authorities							