**From:** Waters, G. Dwain
**To:** Attalla, Yousry
**Cc:** Terry, Greg N.
**Subject:** Crist CEMS
**Date:** Wednesday, January 02, 2013 9:02:19 AM

---

Got your phone message with questions regarding the SO2 CEMS systems at Plant Crist. Plant Crist has 4 SO2 monitoring CEM systems. Of these, 3 are certified under the Acid Rain/CAIR Part 75 protocols and are located on the exit of the Common Unit 4-7 scrubber stack and in each of the 2 bypass exit stacks (Unit 4&5, Unit 6&7). The uncertified SO2 system is located on the inlet of the scrubber and is used for an operational tool for scrubber operation. Hope this helps. Please let me know if you have additional questions. Thanks, Dwain

G. Dwain Waters, Q.E.P.
Special Projects and Environmental Assets Coordinator
Gulf Power Company
One Energy Place
Pensacola, Florida 32520-0328
Phone: (850) 444-6527
Cell: (850) 336-6527
Fax: (850) 444-6080
gdwaters@southernco.com<mailto:gdwaters@southernco.com>