



HARDEE POWER PARTNERS

RECEIVED

MAR 29 2002

DIVISION OF AIR RESOURCES MANAGEMENT

March 28, 2002

Via Federal Express

Mr. Howard Rhodes
Florida Department of
Environmental Protection
Division of Air Resources
Management
Bureau of Air Regulation
Twin Towers Office Building
2600 Blair Stone Rd.
Tallahassee, FL 32399-2400

Via Federal Express

Florida Department of
Environmental Protection
Southwest District Office
3804 Coconut Palm Drive
Tampa, FL 33619

RECEIVED

MAR 29 2002

BUREAU OF AIR REGULATION

Re: Hardee Power Partners (HPP)
Hardee Power Station (HPS)
Conditions of Certification PA 89-25
Title V Air Operations Permit No. 0490015-001-AV
2001 Annual Average Capacity Factor and
Cumulative Lifetime Average Capacity Factor Report

To Whom It May Concern:

Pursuant to Special Condition S.1 of Title V Air Operations Permit No. 0490015-001-AV and Condition II.A.1 of Conditions of Certification PA 89-25, Hardee Power Partners hereby submits the enclosed report providing calculations of the 2001 annual average capacity factor and cumulative lifetime average capacity factor for Hardee Power Station Units 1A, 1B, 2A, and the Steam Turbine.

Please feel free to call me at (813) 228-1000, or Frank Sarduy at (813) 228-1228, if you have any questions regarding this information.

Sincerely,

William F. O'Brien
General Manager - Operations

**ANNUAL CUMULATIVE LIFETIME CAPACITY FACTOR
FOR HARDEE POWER STATION UNITS 1A, 1B, ST, 2A
FOR THE CALENDAR YEAR 2001**

UNIT	UNIT CAPABILITY (MW)	2001 ANNUAL		CUMULATIVE LIFETIME	
		MWH	CAPACITY FACTOR	MWH	CAPACITY FACTOR
CT 1A	86	331,123	43.95%	1,981,892	29.23%
CT 1B	86	293,501	38.96%	1,952,707	28.80%
Steam Turbine	81	317,701	44.77%	1,954,146	30.60%
Total CC	253	942,325	42.52%	5,888,745	29.52%
CT 2A	87	120,928	15.87%	568,837	8.29%
Total	340	1,063,253	35.70%	6,457,582	24.09%

Note: Commercial operation began January 1, 1993.