

**HARDEE POWER  
PARTNERS LIMITED**

Invenergy

May 4, 2012

Ms. Danielle Henry  
Florida Department of Environmental Protection  
Southwest District Office  
13051 North Telecom Parkway  
Temple Terrace, FL 33637-0926

**RECEIVED**

MAY 07 2012

**DIVISION OF AIR  
RESOURCE MANAGEMENT**

Re: Hardee Power Partners Limited  
Hardee Power Station  
Conditions of Certification PA 89-25  
Title V Air Operations Permit No. 0490015-013-AV  
2011 Annual Average Capacity Factor Report Resubmit

Dear Ms. Henry,

On March 27, 2012, pursuant to the requirements of Specific Conditions A.20 and A.22 of Title V Air Operations Permit No. 0490015-013-AV, Hardee Power Partners Limited submitted the annual average capacity factor report and cumulative lifetime average capacity factor for Hardee Power Station Units 1A, 1B, 2A, and the Steam Turbine. During a review of this report, we detected an error in the cumulative lifetime average. The 2011 MWH totals were added to the 2009 cumulative MWH totals, rather than the 2010 totals. The corrected report is attached.

We hope this does not cause any inconvenience for you.

Please feel free to contact Matt Drennan at (863) 375-3266 ext. 227 if you have any questions regarding this information.

*I certify that, based on the information and belief formed after reasonable inquiry, the statements and information in the documents are true, accurate, and complete.*

Sincerely,



Tim Frost  
Plant Manager

Attachment

cc: Florida Department of Environmental Protection  
Division of Air Resource Management  
Bureau of Air Regulation  
Title V Section  
2600 Blair Stone Rd., Mail Station #5505  
Tallahassee, FL 32399-2400

**ANNUAL CUMULATIVE LIFETIME CAPACITY FACTOR  
FOR HARDEE POWER STATION UNITS 1A, 1B, ST, 2A  
FOR THE CALENDAR YEAR 2011**

UNIT	UNIT CAPABILITY (MW)	2011 ANNUAL		CUMULATIVE LIFETIME	
		MWH	CAPACITY FACTOR	MWH	CAPACITY FACTOR
CT 1A	86	62,056	8.24%	3,770,417	26.34%
CT 1B	86	37,181	4.94%	3,765,056	26.30%
Steam Turbine	81	49,080	6.92%	3,809,741	28.26%
<b>Total CC</b>	<b>253</b>	<b>148,317</b>	<b>6.69%</b>	<b>11,345,214</b>	<b>26.94%</b>
CT 2A	87	1,465	0.19%	858,853	5.93%
<b>Total</b>	<b>340</b>	<b>149,782</b>	<b>5.03%</b>	<b>12,204,067</b>	<b>21.57%</b>

Note: Commercial operation began January 1, 1993.