

**HARDEE POWER
PARTNERS LIMITED**

Invenergy

Via Federal Express

March 24, 2011

Via FedEx

Ms. Danielle Henry
Florida Department of Environmental Protection
Southwest District Office
13051 North Telecom Parkway
Temple Terrace, FL 33637-0926

RECEIVED
MAR 28 2011
BUREAU OF
AIR REGULATION

Re: Hardee Power Partners Limited
Hardee Power Station
Conditions of Certification PA 89-25
Title V Air Operations Permit No. 0490015-013-AV
2010 Annual Average Capacity Factor Report


Dear Ms. Henry,

Pursuant to the requirements of Specific Conditions A.20 and A.22 of Title V Air Operations Permit No. 0490015-013-AV, Hardee Power Partners Limited hereby submits the enclosed report providing calculations of the 2010 annual average capacity factor and cumulative lifetime average capacity factor for Hardee Power Station Units 1A, 1B, 2A, and the Steam Turbine.

Please feel free to contact Dennis Powell at (863) 375-3266 if you have any questions regarding this information.

I certify that, based on the information and belief formed after reasonable inquiry, the statements and information in the documents are true, accurate, and complete.

Sincerely,



Ralph E. Randall
Plant Manager

Attachment

cc: Florida Department of Environmental Protection
Division of Air Resource Management
Bureau of Air Regulation
Title V Section
2600 Blair Stone Rd., Mail Station #5505
Tallahassee, FL 32399-2400

**ANNUAL CUMULATIVE LIFETIME CAPACITY FACTOR
FOR HARDEE POWER STATION UNITS 1A, 1B, ST, 2A
FOR THE CALENDAR YEAR 2010**

UNIT	UNIT CAPABILITY (MW)	2010 ANNUAL		CUMULATIVE LIFETIME	
		MWH	CAPACITY FACTOR	MWH	CAPACITY FACTOR
CT 1A	86	188,281	24.99%	3,708,361	27.35%
CT 1B	86	178,559	23.70%	3,727,875	27.49%
Steam Turbine	81	188,657	26.59%	3,760,661	29.44%
Total CC	253	555,497	25.06%	11,196,897	28.07%
CT 2A	87	12,805	1.68%	857,388	6.25%
Total	340	568,302	19.08%	12,054,285	22.48%

Note: Commercial operation began January 1, 1993.