From:	Drennan, Matt
To:	Linero, Alvaro
Cc:	Frost, Tim; Frank Sarduy
Subject:	RE: CT2B - Comments on Draft FDEP Permit Documents
Date:	Thursday, September 20, 2012 6:44:49 AM

Thank you very much Al. This will be good for everyone. Best Regards.

Matt Drennan
Operations Superintendent
Hardee Power Station
863.375.3266 x227
mdrennan@invenergyllc.com

This electronic message and all contents contain information which may be privileged, confidential or otherwise protected from disclosure. The information is intended to be for the addressee(s) only. If you are not an addressee, any disclosure, copy, distribution or use of the contents of this message is prohibited. If you have received this electronic message in error, please notify the sender by reply e-mail and destroy the original message and all copies.

From: Linero, Alvaro [mailto:Alvaro.Linero@dep.state.fl.us]
Sent: Wednesday, September 19, 2012 4:04 PM
To: Drennan, Matt
Cc: Frost, Tim; Frank Sarduy
Subject: RE: CT2B - Comments on Draft FDEP Permit Documents

Hey Matt: Thanks for the helpful input.

Here is the email that was sent today to Mr. Randall and Tom Davis.

It provides links to the posted documents.

Let us know if a WORD version of the Public Notice would be helpful in publishing.

Call with any questions.

Sincerely,

Al Linero.

_____
From: Friday, Barbara
Sent: Wednesday, September 19, 2012 3:18 PM
To: 'rrandall@invenergyllc.com'
Cc: 'tdavis@ectinc.com'; Mulkey, Cindy; 'abrams.heather@epa.gov'; 'oquendo.ana@epa.gov'; Friday, Barbara; Scearce, Lynn; Arif, Syed; Linero, Alvaro; Holtom, Jonathan
Subject: 0490015-015-AC (PSD-FL-140D) - 0490015-016-AV, Hardee Power Partners, Hardee Power Station, Notice of Draft Permit and Draft/Proposed Permit

Dear Mr. Randall:
Attached is the official **Notice of Draft/Proposed Permit** for the project referenced below. Click on the link displayed below to access the permit project documents and send a "reply" message verifying receipt of the document(s) provided in the link; this may be done by selecting "Reply" on the menu bar of your e-mail software, noting that you can view the documents, and then selecting "Send".

***Please notice your permit is electronically signed and is also PDF searchable.*

Note: We must receive verification that you are able to access the documents. Your immediate reply will preclude subsequent e-mail transmissions to verify accessibility of the document(s).

Attention: Al Linero

Owner/Company Name: HARDEE POWER PARTNERS LIMITED
Facility Name: HARDEE POWER STATION
Project Number: 0490015-015-AC (PSD-FL-140D)/0490015-016-AV
Permit Status: DRAFT/DRAFT-PROPOSED
Permit Activity: CONSTRUCTION/TITLE V REVISION
Facility County: HARDEE

Click on the following link to access the permit project documents:
http://ARM-PERMIT2K.dep.state.fl.us/adh/prod/pdf_permit_zip_files/0490015.015.AC.D_pdf.zip

Click on the following link to access the permit project documents:
http://ARM-PERMIT2K.dep.state.fl.us/adh/prod/pdf_permit_zip_files/0490015.016.AV.D_pdf.zip

The Office of Permitting and Compliance is issuing electronic documents for permits, notices and other correspondence in lieu of hard copies through the United States Postal System, to provide greater service to the applicant and the engineering community. Access these documents by clicking on the link provided above, or search for other project documents using the "*Air Permit Documents Search*" website at http://www.dep.state.fl.us/air/emission/apds/default.asp.

Permit project documents addressed in this email may require immediate action within a specified time frame. Please open and review the document(s) as soon as possible, and verify that they are accessible. Please advise this office of any changes to your e-mail address or that of the Engineer-of-Record. If you have any problems opening the documents or would like further information, please contact the Florida Department of Environmental Protection, Office of Permitting and Compliance.

Barbara Friday
Office of Permitting and Compliance (OPC)
Division of Air Resource Management - DEP
2600 Blair Stone Road, Mail Stop 5505
Phone: 850-717-9095

A. A. Linero, P.E.
Florida Department of Environmental Protection
Office of Permitting and Compliance
850-717-9076

From: Drennan, Matt [mailto:MDrennan@invenergyllc.com]
Sent: Tuesday, September 18, 2012 5:17 PM
To: Linero, Alvaro
Cc: Frost, Tim; Frank Sarduy
Subject: RE: CT2B - Comments on Draft FDEP Permit Documents

Correct. We would only test on a fuel if we fired that fuel for more than 400 hours during the previous federal fiscal year. So, if we fired more than 400 hours on gas during the previous year, we would test on gas. If we fired more than 400 hours on oil, we would test on oil. If we did not fire either fuel for more than 400 hours, no testing would be required.

Matt Drennan
Operations Superintendent
Hardee Power Station
863.375.3266 x227
mdrennan@invenergyllc.com

This electronic message and all contents contain information which may be privileged, confidential or otherwise protected from disclosure. The information is intended to be for the addressee(s) only. If you are not an addressee, any disclosure, copy, distribution or use of the contents of this message is prohibited. If you have received this electronic message in error, please notify the sender by reply e-mail and destroy the original message and all copies.

From: Linero, Alvaro [mailto:Alvaro.Linero@dep.state.fl.us]
Sent: Tuesday, September 18, 2012 4:07 PM
To: Drennan, Matt
Subject: RE: CT2B - Comments on Draft FDEP Permit Documents

Thanks Matt:

Does it sound like you would test on distillate if you burn more than 400 hours of distillate?

Does it sound like you wouldn't test on natural gas if you burned less than 400 hours on natural gas.

I know we have the permit ready to go, but I'm explaining this as clearly as I can to the person signing off.

Thanks again.

Al.

A. A. Linero, P.E.
Florida Department of Environmental Protection
Office of Permitting and Compliance
850-717-9076

From: Drennan, Matt [mailto:MDrennan@invenergyllc.com]
Sent: Tuesday, September 18, 2012 4:02 PM
To: Linero, Alvaro

Cc: tdavis@ectinc.com; Frank Sarduy; Frost, Tim
Subject: RE: CT2B - Comments on Draft FDEP Permit Documents

We do maintain oil burning capability on CT2B. The permit limits us to 876 hours in any consecutive 12 month period. We can burn over 400 hours on fuel oil. The short answer is yes, yes.

The cost of fuel oil has been out of the market for a long time now. We typically only run on fuel oil to exercise the equipment. It is possible that we would burn more than 400 hours on oil if there were ever an interruption of the gas supply or a drastic change to fuel market conditions. It is unlikely.

Matt Drennan
Operations Superintendent
Hardee Power Station
863.375.3266 x227
mdrennan@invenergyllc.com

This electronic message and all contents contain information which may be privileged, confidential or otherwise protected from disclosure. The information is intended to be for the addressee(s) only. If you are not an addressee, any disclosure, copy, distribution or use of the contents of this message is prohibited. If you have received this electronic message in error, please notify the sender by reply e-mail and destroy the original message and all copies.

From: Linero, Alvaro [mailto:Alvaro.Linero@dep.state.fl.us]
Sent: Tuesday, September 18, 2012 3:46 PM
To: Drennan, Matt
Cc: tdavis@ectinc.com; Frank Sarduy; Frost, Tim
Subject: RE: CT2B - Comments on Draft FDEP Permit Documents

Hey Matt.

We are almost done.

Do you maintain distillate oil burning capability at all on Unit CT-2B.

If so, can you fire more than 400 hours/year.

A. A. Linero, P.E.
Florida Department of Environmental Protection
Office of Permitting and Compliance
850-717-9076

Please take a few minutes to share your comments on the service you received from the department by clicking on this link DEP Customer Survey.
From: Drennan, Matt [mailto:MDrennan@invenergyllc.com]
Sent: Monday, September 10, 2012 10:22 AM
To: Linero, Alvaro
Cc: tdavis@ectinc.com; Frank Sarduy; Frost, Tim

Subject: FW: CT2B - Comments on Draft FDEP Permit Documents

Good morning Alvaro,

Please see our comments below. Let us know if you have any questions or comments.

Thanks,

Matt Drennan
Operations Superintendent
Hardee Power Station
863.375.3266 x227
mdrennan@invenergyllc.com