From: Linero, Alvaro
To: Arif, Syed
Subject: Hardee Package ready to go
Date: Tuesday, September 18, 2012 9:01:00 AM

To: Syed Arif

From: Al Linero, P.E., OPC

Date: September 18, 2012

Subject: Draft Air Construction Permit No. 0490015-015-AC
Draft/Proposed Title V Operation Permit No. 0490015-016-AV
Hardee Power Station
Testing and Tuning Conditions on Combustion Turbine CT-2B

We are ready to distribute the public notice package for the Hardee Power Station. The facility is located at 6695 North County Road 663 in Bowling Green, Hardee County.

The requested revision to the permits is to reduce annual carbon monoxide (CO) and visible emissions compliance testing requirements for Unit CT2-B when operating less than 400 hours on natural gas and to allow excess emissions related to tuning of the DLN combustors.

The files are available at:

O:\OPC\LINERO\Electrical\Hardee\0490015 Unit CT2-B Permit Revisions

We received the application on August 17, 2012 and we sent the applicant a preliminary version of the package on August 30. We received the applicant's few corrections on September 10. That makes it feasible to issue a Draft/Proposed version of the Title V permit.

It effort involved minimal AC and Title V changes to a permit that Jeff/Christy prepared in 2009. Ed Svec took an early look at it and I understand he commented that it looks O.K.

Day 90 is November 15. From initial receipt to draft permit issuance will be 33 days if we distribute tomorrow (Wednesday September 19).

I recommend distribution issuance of the package.

Al Linero