From:	Drennan, Matt
To:	Linero, Alvaro
Cc:	tdavis@ectinc.com; Frank Sarduy; Frost, Tim
Subject:	FW: CT2B - Comments on Draft FDEP Permit Documents
Date:	Monday, September 10, 2012 10:22:50 AM

Good morning Alvaro,

Please see our comments below. Let us know if you have any questions or comments.

Thanks,

Matt Drennan
Operations Superintendent
Hardee Power Station
863.375.3266 x227
mdrennan@invenergyllc.com

This electronic message and all contents contain information which may be privileged, confidential or otherwise protected from disclosure. The information is intended to be for the addressee(s) only. If you are not an addressee, any disclosure, copy, distribution or use of the contents of this message is prohibited. If you have received this electronic message in error, please notify the sender by reply e-mail and destroy the original message and all copies.

From: Tom Davis [mailto:tdavis@ectinc.com]
Sent: Monday, September 10, 2012 9:57 AM
To: Drennan, Matt
Cc: Frank O. Sarduy (FSarduy@SouthshoreEnv.com)
Subject: CT2B - Comments on Draft FDEP Permit Documents

Matt,

My minor comments on the draft FDEP permit documents for CT2B are as follows:

Hardee Power Station
Comments on Draft FDEP Permits
TV Permit No. 0490015-015-AV
Air Permit No. 0490015-015-AC (PSD-FL-140C)

A. Statement of Basis

Page 2 of 3

Second sentence of Condition B.12.c. should read as follows: "Excess emissions shall not exceed a total of 15 hours per tuning session."

B. Technical Evaluation and Preliminary Determination

Page 4 of 6, Table 1.

SER for SO_2 is 40 tons/year.

Page 5 of 6, Condition 20.(b)

Second sentence should read as follows: "Excess emissions shall not exceed a total of 15 hours per tuning session."

C. TV Permit No. 0490015-015-AV

Page 3 State Rule Citations

EU IDs 001, 002, and 003 are not subject to the Acid Rain Program and therefore Rule 62-213.413 (Fast-Track Revisions of Acid Rain Parts) does not apply to these emission units.

Page 12 Condition B.12.c.

Second sentence should read as follows: "Excess emissions shall not exceed a total of 15 hours per tuning session."

D. Air Permit No. 0490015-015-AC (PSD-FL-140C)

Page 4 of 4, Section III Condition No. 20.(b)

Second sentence should read as follows: "Excess emissions shall not exceed a total of 15 hours per tuning session."

Pls contact me if you have any questions or comments.

Thanks.

Tom Davis, P.E.
Environmental Consulting & Technology, Inc.
3701 NW 98th Street
Gainesville, FL 32606

Voice: 352.248.3351
Fax: 352.332.6722

IF YOU RECEIVED THIS EMAIL BY ERROR, PLEASE DELETE IT AND NOTIFY THE SENDER.