From: Linero, Alvaro
To: Koerner, Jeff
Subject: RE: Hardee Power Partners - Final Air Construction Permit No. 0490015-015-AC
Date: Wednesday, October 10, 2012 12:22:00 PM

To: Jeff Koerner

From: Al Linero

Date: October 10, 2012

Subject: Draft Air Construction Permit No. 0490015-015-AC
Hardee Power Station
Testing and Tuning Conditions on Combustion Turbine CT-2B

We are ready to issue the final air construction permit revision for the Hardee Power Station. The facility is located at 6695 North County Road 663 in Bowling Green, Hardee County.

The requested revision is to reduce annual CO and visible emissions compliance testing requirements for Unit CT2-B when operating less than 400 hours on natural gas and to allow excess emissions related to tuning of the DLN combustors.

The attached Final Determination summarizes the publication and comment process. There are no pending petitions for administrative hearings or extensions of time in which to file a petition for an administrative hearing.

A concurrent Title V permit revision that implements the same changes will be issued after expiration of the 45 day EPA review period that began September 27, 2012.

Assuming we issue this air construction permit on Friday, October 12, the total time from application to final issuance is 56 days.

I recommend your approval of the attached final air construction permit for this project.