

STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
NOTICE OF FINAL PERMIT MODIFICATION

In the Matter of an
Application for Permit Modification


Mr. Michael P. Opalinski
Seminole Electric Cooperative Incorporated
Post Office Box 272000
Tampa, Florida 33688-2000

Permit: PSD-FL-214A / PA-89-25SA

Enclosed is the FINAL Permit Modification which reflects the use of SCR and oxidation catalyst control systems at the Payne Creek generating Station in Hardee County. This permit is issued pursuant to Chapter 403, Florida Statutes and 62-4 through 297, F.A.C and 40 CFR 52.21 - Prevention of Significant Deterioration(PSD).

Any party to this order (permit) has the right to seek judicial review of the permit pursuant to Section 120.68, F.S., by the filing of a Notice of Appeal pursuant to Rule 9.110, Florida Rules of Appellate Procedure, with the Clerk of the Department in the Legal Office; and by filing a copy of the Notice of Appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal. The Notice of Appeal must be filed within 30 (thirty) days from the date this Notice is filed with the Clerk of the Department.

Executed in Tallahassee, Florida.


C.H. Fancy, P.E. Chief
Bureau of Air Regulation


CERTIFICATE OF SERVICE

The undersigned duly designated deputy agency clerk hereby certifies that this NOTICE OF FINAL PERMIT (including the FINAL permit) was sent by certified mail (*) and copies were mailed by U.S. Mail before the close of business on 7-23-99 to the person(s) listed:

Mr. Michael P. Opalinski, SECI *
Mr. Gregg Worley, EPA
Mr. John Bunyak, NPS
Mr. Bill Thomas, DEP SWD
Mr. Hamilton S. Oven, DEP PPS

Clerk Stamp

FILING AND ACKNOWLEDGMENT FILED, on this date, pursuant to §120.52, Florida Statutes, with the designated Department Clerk, receipt of which is hereby acknowledged.


Kim Joben 7-23-99
(Clerk) (Date)

FINAL DETERMINATION

Seminole Electric Cooperative, Incorporated (SECI) Hardee Power Station Unit 3 (Payne Creek Generating Station) Permit No. PSD-FL-214A / PA-89-25SA

An Intent to Issue a PSD Permit Modification for SECI, Hardee Power Station Unit 3 (Payne Creek Generating Station), located near Bowling Green, Hardee County, Florida, was distributed on May 6, 1999. The Public Notice of Intent to Issue PSD Permit Modification was published in the Herald-Advocate on May 20, 1999. Copies of the draft permit modification were available for public inspection at the Department offices in Tampa and Tallahassee.

The National Park Service, the U.S. Environmental Protection Agency or the public submitted no comments. Several editorial comments on the proposed permit modification were submitted by the applicant in response to the public notice. The Department will make changes based on those comments. Additionally, the applicant wanted to change the expiration date of the permit to March 4, 2002.

A summary of the comments received and the Department's responses to those comments are provided in the following paragraphs:

Comment 1: SECI submitted a comment requesting that the word "revised" be inserted before permit in Specific Condition H.3. The change will give SECI 18 months period from the issuance of the revised permit for the initiation of BACT on the units on which construction has not commenced.

Response: The Department will incorporate the source obligation conditions from 40 CFR 52.21 (r)(2). SECI has agreed that construction (delayed since 1995) will commence by June 2000. Specific Condition H.3 will be replaced by the following:

Approval to construct shall become invalid if construction is not commenced by June, 2000, if construction is discontinued for a period of 18 months or more, or if construction is not completed by March 4, 2002. The Department may extend the 18-month period upon a satisfactory showing that an extension is justified. [40 CFR 52.21(r)(2)].

Comment 2: SECI submitted comments on May 26 and June 4, 1999, requesting extension of the expiration date of the permit to March 4, 2002. During 1995, SECI received a proposal from Florida Power Corporation to supply SECI with approximately 450 MW of firm capacity for three years and 150 MW of system intermediate capacity for the period of 1999 through 2013. Through subsequent negotiations, SECI found that this arrangement would result in significant savings to its Member Systems when compared to this project, and thus decided to delay the project.

Response: The Department will set June 2000 as the date by which construction must commence, and March 4, 2002, as the "reasonable time" by which construction must be completed. The extension moots the conditions related to installation by November 1, 2000 of DLN burners capable of achieving 9-12 ppm. SECI may install either DLN or SCR systems to meet a NO_x limit of 9 ppmvd @ 15% O₂.

The final action of the Department is to issue the permit with the changes noted above.

Is your RETURN ADDRESS completed on the reverse side?

<p>SENDER:</p> <ul style="list-style-type: none"> ■ Complete items 1 and/or 2 for additional services. ■ Complete items 3, 4a, and 4b. ■ Print your name and address on the reverse of this form so that we can return this card to you. ■ Attach this form to the front of the mailpiece, or on the back if space does not permit. ■ Write "Return Receipt Requested" on the mailpiece below the article number. ■ The Return Receipt will show to whom the article was delivered and the date delivered. 	<p>I also wish to receive the following services (for an extra fee):</p> <p>1. <input type="checkbox"/> Addressee's Address</p> <p>2. <input type="checkbox"/> Restricted Delivery</p> <p>Consult postmaster for fee.</p>
<p>3. Article Addressed to:</p> <p>Mr. Michael Opalinski Seminole Electric Coop P O Box 272000 Tampa, FL 33688-2000</p>	<p>4a. Article Number 2 333 618 114</p> <p>4b. Service Type</p> <p><input type="checkbox"/> Registered <input checked="" type="checkbox"/> Certified</p> <p><input type="checkbox"/> Express Mail <input type="checkbox"/> Insured</p> <p><input type="checkbox"/> Return Receipt for Merchandise <input type="checkbox"/> COD</p> <p>7. Date of Delivery 7-27-99</p>
<p>5. Received By: (Print Name) William RSHY</p>	<p>8. Addressee's Address (Only if requested and fee is paid)</p>
<p>6. Signature: (Addressee or Agent) X <i>William RSHY</i></p>	


Thank you for using Return Receipt Service.

Z 333 618 114

US Postal Service
Receipt for Certified Mail
 No Insurance Coverage Provided.
 Do not use for International Mail (See reverse)

Sender <i>Michael Opalinski</i>	
Street & Number <i>Seminole Electric</i>	
Post Office, State, & ZIP Code <i>Tampa FL</i>	
Postage	\$
Certified Fee	
Special Delivery Fee	
Restricted Delivery Fee	
Return Receipt Showing to Whom & Date Delivered	
Return Receipt Showing to Whom, Date, & Addressee's Address	
TOTAL Postage & Fees	\$
Postmark or Date PSO-FI-214A 7-23-99 PA 89-255A	

PS Form 3800, April 1995



Department of Environmental Protection

Jeb Bush
Governor

Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

David B. Struhs
Secretary

PERMITTEE:
Seminole Electric Cooperative
Incorporated
P.O. Box 272000
Tampa, FL 33688-2000

Permit Number: PSD-FL-214A/PA-89-25SA
Issued: 9/28/95 Revised: 7/21/99
County: Polk & Hardee
Latitude/Longitude: 27°38'30"N
81°57'45"W
Project: 488 MW Combined Cycle
Power Plant

This permit is issued under the provisions of Chapter 403, Florida Statutes, and Florida Administrative Code Chapters 62-212 and 62-4. The above named permittee is hereby authorized to perform the work or operate the facility shown on the application and approved drawings, plans, and other documents attached hereto or on file with the Department and specifically described as follows:

For a 488 MW (nominal) combined cycle power plant consisting of two 157.5 MW (nominal) combustion turbines (CTs), two heat recovery steam generators (HRSGs), a 173 MW (nominal) steam turbine generator and a 4.4 million gallon fuel oil storage tank. The maximum heat input at 32°F is 1962 MMBtu/hr/CT (natural gas) and 1888 MMBtu/hr/CT (oil). The plant will be located at the Polk and Hardee County site near Bowling Green, Florida which is also the site of a 295 MW power plant which is operated by Hardee Power Partners Limited (HPPL). The combustion turbines are to be Westinghouse Model 501F (D) or equivalent and equipped with dry low NO_x combustors and a Selective Catalytic Reduction (SCR) system for natural gas firing and wet injection for fuel oil firing. The CT will be fired with natural gas and No. 2 low sulfur fuel oil with a sulfur content limit not to exceed 0.05 percent, by weight, as a back-up only. Each CT will also be equipped with a carbon monoxide oxidation catalyst control system.

The source shall be constructed in accordance with the permit application, plans, documents, amendments and drawings, except as otherwise noted in the General and Specific Conditions.

Howard L. Rhodes, Director
Division of Air Resources
Management

"Protect, Conserve and Manage Florida's Environment and Natural Resources"

PERMITTEE:
Seminole Electric Cooperative Inc.

Permit Number: PSD-FL-214A
(PA-89-25SA)

Attachments are listed below:

1. Seminole Electric Cooperative Incorporated's (SECI) application received May 9, 1994.
2. Department's letters dated June 27, September 21, and November 16, 1994.
3. SECI's letters dated August 26, October 6, and November 23, 1994.
4. SECI's letter dated February 9, 1995.
5. SECI's letters dated December 1 and December 21, 1998; January 29 and February 11, 1999.

GENERAL CONDITIONS:

1. The terms, conditions, requirements, limitations, and restrictions set forth in this permit are "Permit Conditions" and are binding and enforceable pursuant to Sections 403.161, 403.727, or 403.859 through 403.861, F.S. The permittee is placed on notice that the Department will review this permit periodically and may initiate enforcement action for any violation of these conditions.
2. This permit is valid only for the specific processes and operations applied for and indicated in the approved drawings or exhibits. Any unauthorized deviation from the approved drawings, exhibits, specifications, or conditions of this permit may constitute grounds for revocation and enforcement action by the Department.
3. As provided in Subsections 403.087(6) and 403.722(5), F.S., the issuance of this permit does not convey any vested rights or any exclusive privileges. Neither does it authorize any injury to public or private property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations. This permit is not a waiver of or approval of any other Department permit that may be required for other aspects of the total project which are not addressed in the permit.
4. This permit conveys no title to land or water, does not constitute State recognition or acknowledgment of title, and does not constitute authority for the use of submerged lands unless herein provided and the necessary title or leasehold interests have been obtained from the State. Only the Trustees of the Internal Improvement Trust Fund may express State opinion as to title.
5. This permit does not relieve the permittee from liability for harm or injury to human health or welfare, animal, or plant life, or property caused by the construction or operation of this permitted source, or from penalties therefore; nor does it allow the permittee to cause pollution in contravention of F.S. and Department rules, unless specifically authorized by an order from the Department.
6. The permittee shall properly operate and maintain the facility and systems of treatment and control (and related appurtenances) that are installed or used by the permittee to achieve compliance with the conditions of this permit, as required by Department rules. This provision includes the operation of backup or auxiliary facilities or similar systems when necessary

PERMITTEE:
Seminole Electric Cooperative Inc.

Permit Number: PSD-FL-214A
(PA-89-25SA)

to achieve compliance with the conditions of the permit and when required by Department rules.

7. The permittee, by accepting this permit, specifically agrees to allow authorized Department personnel, upon presentation of credentials or other documents as may be required by law and at a reasonable time, access to the premises, where the permitted activity is located or conducted to:

- a. Have access to and copy any records that must be kept under the conditions of the permit;
- b. Inspect the facility, equipment, practices, or operations regulated or required under this permit; and,
- c. Sample or monitor any substances or parameters at any location reasonably necessary to assure compliance with this permit or Department rules.

Reasonable time may depend on the nature of the concern being investigated.

8. If, for any reason, the permittee does not comply with or will be unable to comply with any condition or limitation specified in this permit, the permittee shall immediately provide the Department with the following information:

- a. A description of and cause of non-compliance; and,
- b. The period of noncompliance, including dates and times; or, if not corrected, the anticipated time the non-compliance is expected to continue, and steps being taken to reduce, eliminate, and prevent recurrence of the non-compliance.

The permittee shall be responsible for any and all damages which may result and may be subject to enforcement action by the Department for penalties or for revocation of this permit.

9. In accepting this permit, the permittee understands and agrees that all records, notes, monitoring data and other information relating to the construction or operation of this permitted source which are submitted to the Department may be used by the Department as evidence in any enforcement case involving the permitted source arising under the F.S. or Department rules, except where such use is prescribed by Sections 403.73 and 403.111, F.S. Such evidence shall only be used to the extent it is consistent with the Florida Rules of Civil Procedure and appropriate evidentiary rules.

10. The permittee agrees to comply with changes in Department rules and F.S. after a reasonable time for compliance, provided, however, the permittee does not waive any other rights granted by F.S. or Department rules.

11. This permit is transferable only upon Department approval in accordance with Rules 62-4.120 and 62-730.300, F.A.C., as applicable. The permittee shall be liable for any non-compliance of the permitted activity until the transfer is approved by the Department.

12. This permit or a copy thereof shall be kept at the work site of the permitted activity.

PERMITTEE:
Seminole Electric Cooperative Inc.

Permit Number: PSD-FL-214A
(PA-89-25SA)

13. This permit also constitutes:

- (X) Determination of Best Available Control Technology (BACT)
- (X) Determination of Prevention of Significant Deterioration (PSD)
- (X) Compliance with New Source Performance Standards (NSPS)

14. The permittee shall comply with the following:

a. Upon request, the permittee shall furnish all records and plans required under Department rules. During enforcement actions, the retention period for all records will be extended automatically unless otherwise stipulated by the Department.

b. The permittee shall hold at the facility or other location designated by this permit records of all monitoring information (including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation) required by the permit, copies of all reports required by this permit, and records of all data used to complete the application for this permit. These materials shall be retained at least three years from the date of the sample, measurement, report, or application unless otherwise specified by Department rule.

c. Records of monitoring information shall include:

- the date, exact place, and time of sampling or measurements;
- the person responsible for performing the sampling or measurements;
- the dates analyses were performed;
- the person responsible for performing the analyses;
- the analytical techniques or methods used; and,
- the results of such analyses.

15. When requested by the Department, the permittee shall within a reasonable time furnish any information required by law which is needed to determine compliance with the permit. If the permittee becomes aware that relevant facts were not submitted or were incorrect in the permit application or in any report to the Department, such facts or information shall be corrected promptly.

16. Circumvention. No person shall circumvent any air pollution control device, or allow the emission of air pollutants without the applicable air pollution control device operating properly pursuant to Rule 62-210.650 F.A.C.

SPECIFIC CONDITIONS:

The construction and operation of the project shall be in accordance with all applicable provisions of Chapters 62-210 through 62-297 and 62-4, Florida Administrative Code (F.A.C.), and 40 CFR 60, Subpart GG, Appendix A, Appendix B, and Appendix F (1994 version). The following emission limitations and conditions reflect the BACT determinations for the 315 megawatts (nominal) (MW; two 157.5 MW (nominal) combined cycle combustion turbines) of generating

PERMITTEE:
Seminole Electric Cooperative Inc.

Permit Number: PSD-FL-214A
(PA-89-25SA)

capacity. Each combustion turbine (CT) will be connected to a heat recovery steam generator (HRSG), which will recover the waste heat to produce steam for utilization in a single 173 MW (nominal) steam turbine. There is no fuel firing in the associated HRSG. The facility will have a total nominal generating capacity of 488 MW (nominal). In addition to the foregoing, the project shall comply with the following Specific Conditions:

A. General Requirements

1. Pursuant to Rule 62-212.200(56), F.A.C., Potential to Emit (PTE), the maximum heat input to each Westinghouse 501F (D) CT, or equivalent, at an ambient temperature of 32°F, shall neither exceed 1,962 MMBtu/hr while firing natural gas nor 1,888 MMBtu/hr while firing fuel oil.
2. Pursuant to Rule 62-212.200(56), F.A.C., PTE, the CTs may operate continuously, i.e., 8,760 hrs/year.
3. Pursuant to Rule 62-212.200(56), F.A.C., PTE, only natural gas or No. 2 fuel oil is allowed to be fired in the CTs. The maximum sulfur content limit of the No. 2 fuel oil shall not exceed 0.05 percent, by weight.
4. Pursuant to Rule 62-212.200(56), F.A.C., PTE, the maximum No. 2 fuel oil consumption allowed to be burned is 41,751,000 gallons per year, which is equivalent to 1500 hours per CT per year of operation at full load (not to exceed 3,000 hrs/yr between the two CTs). The No. 2 fuel oil is to be used as a back-up fuel only.
5. Pursuant to Rule 62-296.310(3), F.A.C., Unconfined Emissions of Particulate Matter (PM), the emissions of unconfined PM shall be minimized during the construction period by covering or watering dust generating areas.

B. Emission Limits

1. Pursuant to Rule 62-212.410, F.A.C., BACT, the maximum allowable emission limitations from two CTs, when firing natural gas or No. 2 fuel oil, shall not exceed the following:

PERMITTEE:
Seminole Electric Cooperative Inc.

Permit Number: PSD-FL-214A
(PA-89-25SA)

MAXIMUM ALLOWABLE EMISSION LIMITATIONS

<u>POLLUTANT</u>	<u>FUEL</u>	<u>CONCENTRATION</u>	<u>lbs/hr(a)</u>	<u>TPY(b)</u>	<u>TPY(TOTAL)^c</u>
NO _x	Gas	9 ppmvd(d)	68	596	906
	Oil	42 ppmvd(e)	336	504	
CO	Gas	20 ppmvd	71	622	618
	Oil	25 ppmvd	91	136	
PM/PM ₁₀	Gas		7	65	147
	Oil		67	100	
SO ₂	Gas		5	47	182
	Oil		101	152	
VOC	Gas	5 ppmvd	10	88	99
	Oil	10 ppmvd	21	31	
Sulfuric Acid Mist	Gas		1	6	39
	Oil		22	34	
Beryllium	Oil		0.0049	0.007	0.007
Arsenic	Oil		0.0097	0.014	0.014
Visible Emissions	Gas		≤ 10 percent opacity		
	Oil		≤ 10 percent opacity		

(a) The emission limitations in lbs/hr/CT are a 1-hour average as determined pursuant to the Performance Testing conducted pursuant to Condition C.1 below.

(b) The annual emission limitations (TPY) for natural gas are based on two CTs operating at full load for 8,760 hours per year. The annual emission limitations (TPY) for fuel oil are based on the equivalent of full-load operation for a maximum of 1500 hours per year for each of the two CTs (not to exceed 3,000 hrs/yr between the two CTs). The emission calculations are also based at a worst case ambient temperature of 32°F.

(c) Maximum allowable emissions from two CTs if any fuel oil is burned at the facility during the year. The emission calculations are also based at an ambient temperature of 59°F.

(d) The natural gas NO_x allowable emission limitation of 9 ppmvd is corrected to 15 percent O₂. An interim limit of 12 ppmvd (91 lb/hr/CT, 797 TPY) corrected to 15 percent O₂ shall be allowed for a period of one year from the startup date. Compliance shall be determined through the initial and annual compliance tests.

(e) The fuel oil NO_x allowable emission limitation of 42 ppmvd is corrected to 15 percent oxygen. Compliance shall be determined through the initial and annual compliance tests. The annual compliance test will be required if the fuel oil is fired for more than 400 hours in the preceding 12-months.

PERMITTEE:
Seminole Electric Cooperative Inc.

Permit Number: PSD-FL-214A
(PA-89-25SA)

For fuel oil firing, NO_x emissions of 42 ppmvd @ 15 percent O₂ are based on fuel bound nitrogen (FBN) content of 0.015 percent by weight or less. When FBN levels are above this percentage, the CTs may produce higher NO_x concentrations due to increased fuel NO_x formation. When FBN levels are above 0.015 percent, the operator shall employ all reasonable measures to maintain the NO_x concentrations below 42 ppmvd. However, NO_x emissions (ppmvd and lb/hr), as calculated from the formula below, shall be allowed if the permittee submits data (FBN levels from most recent fuel shipment or as fired fuel sampling and hourly averages of: fuel rate, heat rate, ambient conditions, and NO_x control system parameters) which demonstrates that emissions (hourly averages) above 42 ppmvd are due solely to FBN levels above 0.015 percent.

The emission level for NO_x is adjusted for higher fuel nitrogen contents up to a maximum of 0.030 percent by weight as follows:

FUEL BOUND NITROGEN (% by weight)	NO _x LEVELS (ppmvd @ 15% O ₂)	NO _x EMISSIONS (lb/hr/CT) ¹	NO _x EMISSIONS INCREASE (TPY) ¹
0.015 or less	42	336.2	0
0.020	44	352.1	0
0.025	46	368.2	0
0.030	48	384.2	0

1 - From 336.2 lb/hr/CT at 32⁰F basis.

For intermediate values of FBN use the formula:

$$STD = 0.0042 + F$$

where,

STD = allowable NO_x emissions (ppmvd @ 15% O₂)

F = NO_x emission allowance for fuel bound nitrogen

and

N (fuel bound nitrogen), is defined as follows:

N (% by weight)	F (NO _x % by volume)
0 < N ≤ 0.015	0
0.015 < N ≤ 0.030	0.04 (N - 0.015)
0.030 < N	0.0006

2. The following estimated CT emissions are tabulated for PSD tracking purposes only:

ESTIMATED EMISSIONS

<u>POLLUTANT</u>	<u>FUEL</u>	<u>TPY</u>
Lead	Oil(a,b)	0.16
Fluoride	Oil(a,b)	0.090
Mercury	Gas(c)	0.0003
	Oil(a,b)	0.024

PERMITTEE:
Seminole Electric Cooperative Inc.

Permit Number: PSD-FL-214A
(PA-89-25SA)

(a) The annual emission limitations (TPY) for fuel oil are based on full-load operation for a total of 3,000 hours per year between the two CTs at an ambient temperature of 59°F.

(b) The No. 2 fuel oil shall have a maximum sulfur content limit of 0.05 percent, by weight.

(c) The annual emission limitation (TPY) for natural gas is based on two CTs operating at full-load for 8,760 hours per year at an ambient temperature of 59°F.

3. The permittee will install a dry low-NO_x (DLN) combustor or an SCR system on each CT. Ammonia slip from the SCR system shall not exceed 10 ppm. The permittee shall make every practicable effort to achieve the lowest possible NO_x emission rate, but must not exceed 12 ppmvd at 15 percent O₂ per CT on a continuous basis when firing natural gas during the first year of operation. The final limit for NO_x one year after startup will be 9 ppmvd at 15% O₂.

4. Excess emissions from a turbine resulting from start up, shutdown, malfunction, fuel switch or load change shall be reported in accordance with 40 CFR 60.334(c) and accepted providing (1) best operational practices to minimize emissions are adhered to and (2) the duration of excess emissions shall be minimized, but in no case exceed two hours in any 24-hour period unless specifically authorized by the Department for a longer duration. The permittee shall provide a general description of the procedures to be followed during periods of start up, shutdown, malfunction, fuel switch or load change to ensure that the best operational practices to minimize emissions will be adhered to and the duration of any excess emissions will be minimized. The description should be submitted to the Department along with the initial compliance test data. The description may be updated as needed by submitting such update to the Department within thirty (30) days of implementation.

5. Excess emissions from fuel switching shall not exceed 15 minutes.

6. Excess emissions due to fuel bound nitrogen levels above 0.015 percent are allowed pursuant to Condition B.1 foot note (e) of the emission limitation table.

C. Performance Testing

1. Initial (I) compliance tests shall be performed on each CT using both fuels. Testing of emissions shall be conducted at 95-100% of the manufacturer's rated heat input based on the average ambient air temperature for the CT during the test. Annual (A) compliance tests shall be performed on the CT with the fuel(s) used for more than 400 hours in the preceding 12-month period. Tests at permit renewal shall also be performed on the non-PSD pollutants. Tests and procedures shall be in accordance with 40 CFR 60.335. Tests shall be conducted using EPA reference methods in accordance with 40 CFR 60, Appendix A, as adopted by reference in Chapter 62-297, F.A.C, and follows:

a. Reference Method 5B for PM (I, A: for oil only; assumption is that all PM is PM₁₀).

b. Reference Method 9 for VE (I, A).

- c. Reference Method 10 for CO (I, A).
- d. Reference Method 20 for NO_x (I, A) or Method 7E if sampling downstream of the heat recovery steam generator.
- e. Reference Method 18 or 25A for VOC (I, A).
- f. Reference Method 8 for H₂SO₄ Mist (I, A).
- g. Trace elements of Beryllium (Be) and Arsenic (As) shall be tested (I, for oil only) using EMTIC Interim Test Methods. As an alternative, EPA Method 104 for Be may be used; or, Be and As may be determined from fuel analysis using either Method 7090 or 7091 and sample extraction using Method 3040, as described in the EPA solid waste regulations SW 846.
- h. ASTM D4294 (or equivalent) for sulfur content of distillate oil (I and A), which can be used for determining SO₂ emissions annually.
- i. ASTM D1072-80, D3031-81, D4084-82, or D3246-81 (or equivalent) for sulfur content of natural gas (I; and, A if deemed necessary by the Department).
- j. Other USEPA or DEP approved test methods for the permitted facilities may be used for compliance testing after departmental approval. Unless the permittee requests to modify a reference method, or to use a method for which a method was not designed, such approval shall not constitute an alternative test procedure under Section 62-297.620, F.A.C., or otherwise require modification of the permit.

2. The maximum sulfur content of the fuel oil shall not exceed 0.05 percent, by weight. Compliance shall be demonstrated in accordance with the requirements of 40 CFR 60.334(b).

3. As an alternative to Condition C.1.i above, natural gas supplier data for sulfur content may be submitted. However, the applicant is responsible for ensuring that the procedures above are used for determination of fuel sulfur content. Analysis may be performed by the owner or operator, a service contractor retained by the owner or operator, the fuel vendor, or any other qualified agency pursuant to 40 CFR 60.335(e) (1993 version). Any request for a future custom monitoring schedule shall be made in writing to the Department's Bureau of Air Regulation. Any custom schedule approved by the USEPA pursuant to 40 CFR 60.334(b) (1993 version) will be recognized as enforceable provisions of the permit.

D. Monitoring Requirements

Monitoring of operations shall be in accordance with 40 CFR 60.334. Also, and for each CT, the permittee shall install, operate, and maintain a continuous emission monitoring system (CEMS) to monitor nitrogen oxides in accordance with 40 CFR 60, Appendix F, and, if necessary, a diluent gas (CO₂ or O₂). The Federal Acid Rain Program requirements of 40 CFR 75 shall apply.

1. Each CEMS shall meet performance specifications of 40 CFR 60, Appendix B.

PERMITTEE:
Seminole Electric Cooperative Inc.

Permit Number: PSD-FL-214A
(PA-89-25SA)

2. CEMS data shall be recorded and reported in accordance with Rule 62-297.500, F.A.C.; 40 CFR 60; and, 40 CFR 75, if it becomes applicable. The record shall include periods of start up, shutdown, load change, fuel switch, high fuel bound nitrogen, and malfunction.

3. A malfunction means any sudden and unavoidable failure of air pollution control equipment or process equipment to operate in a normal or usual manner. Failures that are caused entirely or in part by poor maintenance, careless operation or any other preventable upset condition or preventable equipment breakdown shall not be considered malfunctions.

4. The procedures under 40 CFR 60.13 shall be followed for installation, evaluation, and operation of all CEMS. In addition, 40 CFR 75 shall apply (Federal Acid Rain Program).

5. For purposes of the reports required under this permit, excess emissions, as determined pursuant to Condition B.6 herein, are defined as any calculated average emission rate which exceeds the applicable emission limitation in Condition B.1.

E. Notification, Reporting and Recordkeeping

1. To determine compliance with the natural gas and fuel oil firing heat input limitation, the permittee shall maintain daily records of natural gas and fuel oil consumption for each turbine, and provide the heating value for each fuel during the compliance test. All records shall be maintained for a minimum of three years after the date of each record and shall be made available to representatives of the Department upon request.

2. The project shall comply with all the applicable requirements of Chapters 62-210 through 62-297 and 62-4, F.A.C., and 40 CFR 60, Subparts A and GG. The requirements shall include:

- a. 40 CFR 60.7(a)(1) - By postmarking or delivering notification of the start of construction no more than 30 days after such date.
- b. 40 CFR 60.7(a)(2) - By postmarking or delivering notification of the anticipated date of the initial start up of each CT not less than 30 days prior to such date.
- c. 40 CFR 60.7(a)(3) - By postmarking or delivering notification of the actual start up of each turbine within 15 days after such date.
- d. 40 CFR 60.7(a)(5) - By postmarking or delivering notification of the date for demonstrating the CEMS performance, no less than 30 days prior to such date.
- e. 40 CFR 60.7(a)(6) - By postmarking or delivering notification of the anticipated date for conducting the opacity observations no less than 30 days prior to such date.
- f. 40 CFR 60.7(b) - By initiating a recordkeeping system to record the occurrence and duration of any start up, shutdown, load change, fuel switch, high fuel bound

PERMITTEE:
Seminole Electric Cooperative Inc.

Permit Number: PSD-FL-214A
(PA-89-25SA)

nitrogen, and malfunction of a turbine, malfunction of the air pollution control equipment, and the periods when the CEMS is inoperable.

- g. 40 CFR 60.7(c) - By postmarking or delivering a quarterly excess emissions and monitoring system performance report within 30 days after the end of each calendar quarter. This report shall contain the information specified in 40 CFR 60.7(c) and (d).
- h. 40 CFR 60.8(a) - By conducting all performance tests within 60 days after achieving the maximum turbine and boiler firing rates, but not more than 180 days after the initial start up of each CT.
- i. 40 CFR 60.8(d) - By postmarking or delivering notification of the date of each performance test required by this permit at least 30 days prior to the test date; and,
- j. Rule 62-297.345 - By providing stack sampling facilities for each turbine.
- k. All notifications and reports required by this specific condition shall be submitted to the Department's Southwest District office. Performance test results shall be submitted within 45 days of completion of such test.

3. The following information shall be submitted to the Department's Bureau of Air Regulation within 90 days after the permittee has made the selection of the following:

a. Description of the final selection of the turbines, SCR and CO oxidation catalyst control systems. The descriptions shall include the specific make and model numbers and any changes in the proposed method of operation, fuels, emissions or equipment.

b. Description of the CEMS selected. The description shall include the type of sensors and the manufacturer and model numbers of the equipment.

4. The following protocols shall be submitted to the Department's Southwest District office for approval:

a. CEMS Protocol - Within 120 days after selection of the CEMS, but 180 days prior to the initial startup, a CEMS protocol describing the system, its installation, operating and maintenance characteristics and requirements. The protocol shall meet the requirements of 40 CFR 60.13, Appendix B and Appendix F or 40 CFR 75, and be approved within 60 days.

b. Performance Test Protocol - At least 90 days prior to conducting the initial performance tests required by this permit, the permittee shall submit to the Department's Southwest District office a protocol outlining the procedures to be followed, the test methods and any differences between the reference methods and the test methods proposed to be used to verify compliance with the conditions of this permit. The Department shall approve the testing protocol within 60 days provided that it meets the requirements of this permit.

PERMITTEE:
Seminole Electric Cooperative Inc.

Permit Number: PSD-FL-214A
(PA-89-25SA)

c. Heat Input Curves - Within 120 days after final selection of the turbine, but 180 days prior to initial startup of the turbine, manufacturer's curves or equations of heat input and NOx emission rate (lbs/hr) corrections to other temperatures shall be provided to the Department.

d. Subject to the approval by the Department for technical validity while applying sound engineering principles, the manufacturer's curves shall be used to establish the heat input rates over a range of temperatures for the purposes of compliance determination.

F. Modifications

The permittee shall give written notification to the Department when there is any modification to this facility pursuant to Rule 62-212.200, F.A.C., Definitions - Modifications. This notice shall be submitted sufficiently in advance of any critical date involved to allow sufficient time for review, discussion, and revision of plans, if necessary. Such notice shall include, but not be limited to, information describing the precise nature of the change; modifications to any emission control system; production capacity of the facility before and after the change; and, the anticipated completion date of the change.

G. No. 2 Fuel Oil Storage Tank

The permittee shall be in compliance with the monitoring requirements of 40 CFR 60.116b(a) and (b).

H. Additional General Conditions

1. Pursuant to Rule 62-4.090, F.A.C., the permittee, for good cause, may request that this construction permit be extended. Such a request shall be submitted to the Department's Bureau of Air Regulation prior to 60 days before the expiration of the permit.

2. An application for an operation permit pursuant to Rule 62-4.220, F.A.C., is not required if the facility is also certified under the Power Plant Siting Act, Chapter 403, Part II, F.S. That certification serves as the operation permit also. The permittee must submit an application for an operation permit for a major source of pollution pursuant to Chapter 62-213, F.A.C.

3. Approval to construct shall become invalid if construction is not commenced by June, 2000, if construction is discontinued for a period of 18 months or more, or if construction is not completed by March 4, 2002. The Department may extend the 18-month period upon a satisfactory showing that an extension is justified. [40 CFR 52.21(r)(2)].

Florida Department of
Environmental Protection

Memorandum

BAR

TO: Howard L. Rhodes
THRU: Clair Fancy *CAF*
Al Linero *AL* 7/19
FROM: Syed Arif *Syed Arif*
DATE: July 13, 1999

SUBJECT Seminole Electric Cooperative Incorporated
: PSD-FL-214A Combined Cycle Facility

Attached for your approval and signature is the final amendment for the above referenced permit. A Technical Evaluation and Preliminary Determination was issued, and the facility was required to do a public notice.

The facility was originally permitted in 1995 as a 440 MW power plant. They have not even started construction and the permit would have expired in 2000. They have decided to proceed with the project and requested an extension of their permit to March 2002. The units to be delivered will actually produce 488 MW and will be equipped with SCR systems instead of DLN. They will have oxidation catalyst for CO control.

The DLN units required by the original permit were to achieve 15 ppm. The facility has agreed to meet a revised emission limit of 9 ppmvd for NO_x. The revised permit gives allows them to operate at 12 ppm for one year, after which they must meet 9 ppm by SCR. We provided for the long-shot possibility that Westinghouse will develop a DLN combustor that will meet the same 9 ppm requirements as SCR by the same date.

We added language based on the Federal rules (applicable to PPSA projects) that will give us greater authority if they defer construction again. There were no comments from EPA or USFWS. The Site Certification contains automatic update language based on PSD and NPDES permit revisions. Therefore this permit may be issued without a concurrent Certification Modification.

I recommend your approval and signature.