



RECEIVED

FEB 10 2009

BUREAU OF AIR REGULATION

February 5, 2009

Mr. Jeff Koerner
Bureau of Air Regulation – New Source Review Section
Florida Department of Environmental Protection
Division of Air Resource Management
2600 Blair Stone Road, MS5505
Tallahassee, FL 32399-2400

**Re: Midulla Generating Station (0490340-011 -AV) and (0490340-010-AC)
Proof of Public Notice for the Revision of a Title V Air Permit and Air
Construction Permit.**

Dear Mr. Koerner:

Enclosed you will find the required proof of public notice for the incorporation of the permit changes to the Midulla Generating Station's Title V permit and Air Construction Permit.

If you have any questions or need additional information, please contact me at (813) 739-1219.

Sincerely,

Juan Ramirez
Senior Environmental Engineer

Enclosures: Public Notice from the Wauchula Herald-Advocate

AFFIDAVIT OF PUBLICATION

The Herald-Advocate

Published Weekly at Wauchula, Florida

STATE OF FLORIDA,
COUNTY OF HARDEE

Before the undersigned authority personally appeared Kim Beas
who on oath says he is the Secretary of The Herald-Advocate, a
newspaper published at Wauchula, in Hardee County, Florida; that the attached copy of advertise-
ment, being a Public Notice
in the matter of Intent to issue Air permits
in the _____ Court, was published in said newspaper in the issues
of Jan. 29, 2009


Affiant further says that the said Herald-Advocate is a newspaper published at Wauchula, in
said Hardee County, Florida, and that the said newspaper has heretofore been continuously published
in said Hardee County, Florida, each week and has been entered as second class mail matter at the
post office in Wauchula, in said Hardee County, Florida, for a period of one year next preceding the
publication of the attached copy of advertisement; and affiant further says that he has neither paid nor
promised any person, firm or corporation any discount, rebate, commission or refund for the purpose
of securing this advertisement for publication in the said newspaper.

[Signature]

Sworn to and subscribed before me this 30th day of January
A.D. 20 09

Nancy P. Davis
Notary Public

My Commission Expires May 26, 20 12



PUBLIC NOTICE OF INTENT TO ISSUE AIR PERMITS

Florida Department of Environmental Protection

Notice of Intent to Issue Air Permits Seminole Electric Cooperative, Inc., Midulla Generating Station

Draft/Proposed Permit No. 0490340-011-AV, Title V Air Permit Revisions
Draft Permit No. 0490340-010-AC, Air Construction Permit Revisions

Applicant: The applicant for this project is Seminole Electric Cooperative, Inc. The applicant's responsible official is Mr. Mike Roddy, the Manager of Environmental Affairs for Seminole Electric Cooperative, Inc. The applicant's mailing address is P.O. Box 272000, Tampa, Florida 33688-2000.

Facility Location: Seminole Electric Cooperative, Inc. operates the Midulla Generating Station, which is an existing electrical generating plant located in Hardee County at 6695 County Road 663 in Bowling Green, Florida. This station was formerly known as the Payne Creek Generating Station.

Project: Project No. 0490340-010-AC (PSD-FL-214E and PSD-FL-344B) will revise original air construction permit PSD-FL-214 for the existing two combined cycle combustion turbines (Units 1 and 2) and revise original air construction permit PSD-FL-344 for the existing five sets of simple cycle combustion turbines (CT-4A to CT-8B). These projects were subject to preconstruction review in accordance with Rule 62-212.400 of the Florida Administrative Code (F.A.C.) for the Prevention of Significant Deterioration (PSD) of Air Quality. Original air construction Permit No. PSD-FL-214 (Units 1 and 2) will be revised to: replace the current sulfuric acid mist emission limits with a fuel sulfur limitation; and establish the carbon monoxide emissions standard as a surrogate for volatile organic compounds. Original air construction Permit No. PSD-FL-344 (CT-4A to CT-8B) will be revised to: increase the maximum heat input rate when firing natural gas from 55.8 to 676.2 MMBtu/hour; increase the maximum heat input rate when firing distillate oil from 576.8 to 606.8 MMBtu/hour; and establish the carbon monoxide emissions standard as a surrogate for volatile organic compounds. The changes in maximum heat input rates are to reflect the actual installed capabilities of the equipment as documented by the manufacturer, Pratt & Whitney.

Project No. 0490340-011-AV will revise existing Title V air operation Permit No. 0490340-006-AV to incorporate the changes proposed in Project No. 0490340-010-AC. In addition, Project No. 0490340-011-AV will incorporate the final changes made in previously issued final Permit No. 0490340-012-AC for the existing five Twin Pac simple cycle combustion turbines. That final project replaced the requirement to conduct annual compliance tests for carbon monoxide upstream of the oxidation catalyst systems with a requirement to conduct periodic tests to determine the reactivity of the oxidation catalyst.

Details of the projects are provided in the attached documents.

Permitting Authority: Applications for air construction permits are subject to review in accordance with the provisions of Chapter 403, Florida Statutes (F.S.) and Chapters 62-4, 62-210 and 62-212, F.A.C. Applications for Title V air operation permits are subject to review in accordance with the provisions of Chapter 403, F.S. and Chapters 62-4, 62-210 and 62-213, F.A.C. The projects are not exempt from the permitting procedures for air construction permits and Title V air operation permits. The Permitting Authority responsible for making a permit determination for this project is the Bureau of Air Regulation in the Florida Department of Environmental Protection's Division of Air Resource Management. The Bureau of Air Regulation's physical address is 111 South Magnolia Drive, Suite 4, Tallahassee, Florida 32301 and the mailing address is 2600 Blair Stone Road, MS #5505, Tallahassee, Florida 32399-2400. The Bureau of Air Regulation's phone number is 850/488-0114.

Project File: A complete project file is available for public inspection during the normal business hours of 8:00 a.m. to 5:00 p.m., Monday through Friday (except legal holidays), at address indicated above for the Permitting Authority. The complete project file includes the draft and draft/proposed permits, the Statement of Basis, the Technical Evaluation and Preliminary Determination, the application, and the additional information submitted by the applicant, exclusive of confidential records under Section 403.111, F.S. Interested persons may contact the Permitting Authority's project review engineer for additional information at the address and phone number listed above. The draft/proposed permit documents can be viewed at: <http://www.dep.state.fl.us/air/eproducts/apds/default.asp>.

Notice of Intent to Issue Permits with Parallel Review by EPA: The Permitting Authority gives notice of its intent to issue a draft air construction permit revision and a concurrent draft/proposed Title V air operation permit revision for the projects described above. The applicant has provided reasonable assurance that operation of the facility will not adversely impact air quality and that the project will comply with all applicable provisions of Chapters 62-4, 62-204, 62-210, 62-212, 62-213, 62-214, 62-296 and 62-297, F.A.C. The Permitting Authority will issue final permits in accordance with the conditions of the draft/proposed Permits unless a timely petition for an administrative hearing is filed under Sections 120.569 and 120.57, F.S. or unless public comment received in accordance with this notice results in a different decision or a significant change of terms or conditions.

The EPA has agreed to treat the draft Title V air operation permit as a Proposed Title V air operation permit and to perform its 45-day review provided by the law and regulations concurrently with the public comment period (parallel review). Although EPA's 45-day review period will be performed concurrently with the public comment period, the deadline for submitting a citizen petition to object to the EPA Administrator will be determined as if EPA's 45-day review period is performed after the public comment period has ended. The Final Title V Air Operation Permit will be issued after the conclusion of the 45-day EPA review period so long as no adverse comments are received that result in a different decision or significant change of terms or conditions. The status regarding EPA's 45-day review of this project and the deadline for submitting a citizen petition can be found at the following link: <http://www.dep.state.fl.us/air/eproducts/apds/default.asp>.