From: Tom Davis
To: Heron, Teresa
Cc: JRamirez@seminole-electric.com
Subject: Seminole Electric - Midulla Generating Station TV Permit Renewal; Diesel Engine Descriptions
Date: Thursday, August 09, 2012 5:06:28 PM

Teresa,

In response to your request, suggested engine description language for the Seminole Midulla Generating Station TV permit is as follows:

E.U. ID No.	Brief Description of Emissions Units and/or Activity
-003	265 HP Clark Model JDFP-06WA 265 diesel engine used to drive an emergency fire water pump. Engine was manufactured prior to April 6, 2006 and therefore is not subject to NSPS 40 CFR Part 60 Subpart IIII. Engine is subject to the applicable provisions of NESHAPS 40 CFR Part 63 Subpart ZZZZ for existing emergency engines located at area HAP sources.
-004	1,528 HP Mitsubishi Heavy Industries (MHI) Model 512H-Y1PTA-3 diesel engine used to drive a generator. Engine was manufactured prior to April 6, 2006 and therefore is not subject to NSPS 40 CFR Part 60 Subpart IIII. Engine is subject to the applicable provisions of NESHAPS 40 CFR Part 63 Subpart ZZZZ for existing non-emergency engines greater than 500 HP located at area HAP sources.

Pls contact me if you need any additional information.

Thanks.

Tom Davis, P.E.
Environmental Consulting & Technology, Inc.
3701 NW 98th Street
Gainesville, FL 32606

Voice: 352.248.3351
Fax: 352.332.6722

IF YOU RECEIVED THIS EMAIL BY ERROR, PLEASE DELETE IT AND NOTIFY THE SENDER.