From: Juan Ramirez
To: Heron, Teresa
Cc: tdavis@ectinc.com
Subject: RE: Title V Application Renewal Seminole Electric - Review
Date: Wednesday, July 18, 2012 10:21:49 AM

Teresa,

I'm asking our system operations. We are discussing what we are going to do.

Juan

>>> "Heron, Teresa" <Teresa.Heron@dep.state.fl.us> 7/17/2012 10:25 AM >>>
Hi Juan:

RE: Regarding the two emergency engines.

Below are the descriptions that these engines currently have in the Appendix for Unregulated units.

Now that there are regulated since they have to comply with Subpart ZZZZ, we would like to have a better description to their use to write in the permit.

E.U. ID No.	Brief Description of Emissions Units and/or Activity
-003	One or more emergency generators which are not subject to the Acid Rain Program and have a total fuel consumption, in the aggregate, of 32,000 gallons per year or less of diesel fuel, 4,000 gallons per year or less of gasoline, 4.4 million cubic feet per year or less of natural gas or propane, or an equivalent prorated amount if multiple fuels are used.
-004	One or more heating units and general purpose internal combustion engines which are not subject to the Acid Rain Program and have a total fuel consumption, in the aggregate, of 32,000 gallons per year or less of diesel fuel, 4,000 gallons per year or less of gasoline, 4.4 million cubic feet per year or less of natural gas or propane, or an equivalent prorated amount if multiple fuels are used.

I would appreciate your cooperation,

Thanks you,

Teresa Heron
850-717-9082

Please take a few minutes to share your comments on the service you received from the department by clicking on this link DEP Customer Survey.

From: Juan Ramirez [mailto:JRamirez@seminole-electric.com]
Sent: Friday, July 06, 2012 4:50 PM
To: Holtom, Jonathan; Heron, Teresa; Mike Roddy
Cc: tdavis@ectinc.com
Subject: Re: Title V Application Renewal Seminole Electric - Review

Mr. Holtom,

Attached please find Seminole Electric's response to your department's request for additional information on the Midulla Generating Station's Title V permit renewal application.
If you should have any questions please feel free to call me at the number below.

Sincerely,

Juan Ramirez
Senior Environmental Engineer
Seminole Electric Cooperative Inc.
16313 N. Dale Mabry
Tampa, FL 33618
813-739-1219 Office
813-610-4748 Mobile
813-264-7906 Fax