From: Heron, Teresa
To: Holtom, Jonathan
Subject: DRAFT Title V Application Renewal Seminole Electric - Review
Date: Thursday, May 24, 2012 1:31:00 PM
Attachments: Preapplication Engine Reminder.docx

FYI before sending it.

Dear Mr. Roddy:

A brief review of your Title V Renewal application shows the following:

- Current Title V permit has 2 Unregulated emission units (EU 003 and 004) which are emergency generators/internal combustion engines. These units may be regulated now under NSPS Subpart IIII and/or NESHAP Subpart ZZZZ. Please refer to attached questionnaire and respond the questions regarding these engines. Please consult the regulations for applicability and submit an updated information.
- Current Title V permit Appendix I, Insignificant Emissions Units, has engines that may also be now subject to NSPS Subpart IIII and/or NESHAP Subpart ZZZZ. Please refer to attached questionnaire and respond the questions regarding these engines. Please consult the regulations for applicability and submit an updated information.
- On Attachment 5 of your application submittal (Page 5-5, Section C), there is a reference to a water pump diesel engines subject to Subpart ZZZZ and IIII. However, it refer to another facility: Santa Rosa Energy Center. Please correct this and let us know of any unit at your facility that are subject to these regulations.
- If any unit is subject to the above regulations, please include the appropriate application form pages for these units with enough information for our database.
- Your application list that your facility has one or more emissions units subject to NEHSAP. However, the application does not identify any specific unit. Please explain.
- The Appendix CS. NOX Compliance Spreadsheet for Twin Pac Systems was not included in the application. Is there any changes to this Appendix?
- Please submit the date that the Five Twin Pac simple cycle sets began commercial operation. Our description of these units is missing this date.

Please refer to the attached document that was originally sent on March.

Thanks, Teresa

From: Heron, Teresa
Sent: Wednesday, March 14, 2012 12:11 PM
To: 'wmroddy@seminole-electric.com''
Subject: Before submission of the Title V Application Renewal

RE: Seminole Electric Cooperative, Inc.

Dear Mr. Roddy:

I have been assigned as the contact/processor for your facility Title V renewal permit.

We encourage you to schedule a pre-application meeting with us (teleconference is fine), if you need to do any revisions, additions, etc or are in need of clarification. We would be reformatting your old permit into a new style format.

Attached, please find the list of questions that you need to respond if you have engines at your facility.

Should you have any questions, please feel free to contact me.

Thanks,
Teresa Heron, Engineer
Power Plant Group
Permitting and Compliance Section
Division of Air Resource Management - DEP
Florida Department of Environmental Protection
Phone 850/717-9082
teresa.heron@dep.state.fl.us