

**RECEIVED**

APR 20 2010

BUREAU OF  
AIR REGULATION

**PRELIMINARY TRIAL BURN REPORT**

**NITROGEN OXIDE, SULFUR DIOXIDE AND  
OPACITY VIA CONTINUOUS MONITORING  
SYSTEMS**

**PARTICULATE MATTER AND  
CARBON MONOXIDE VIA  
EMISSION MEASUREMENTS**

**AND**

**OPERATIONS PARAMETRIC DATA**


**Power Plant**

**CENTRAL POWER AND LIME, INC.  
Brooksville, Florida**

Permit No.: 0530021-023-AC

Test Dates: January 5-22, 2010  
Report Date: April 14, 2010

308-09-08



**KOOGLER & ASSOCIATES, INC.**  
*ENVIRONMENTAL SERVICES*

4014 NW 13th STREET  
GAINESVILLE, FL 32609-1923  
352/377-5822 ■ FAX/377-7158

RECEIVED

APR 20 2010

BUREAU OF  
AIR REGULATION

PRELIMINARY TRIAL BURN REPORT

NITROGEN OXIDE, SULFUR DIOXIDE AND OPACITY  
VIA CONTINUOUS MONITORING SYSTEMS

PARTICULATE MATTER AND  
CARBON MONOXIDE  
VIA EMISSION MEASUREMENTS

AND

OPERATIONS PARAMETRIC DATA

**Power Plant**

**CENTRAL POWER AND LIME, INC.**  
Brooksville, Florida

Permit No. 0530021-023-AC

Test Dates: January 5-22, 2010  
Report Date: April 13, 2010

*Koogler and Associates, Inc.*  
4014 N.W. 13th Street  
Gainesville, FL 32609-1923  
(352) 377-5822

308-09-08



PRELIMINARY TRIAL BURN REPORT  
NITROGEN OXIDE, SULFUR DIOXIDE AND  
OPACITY VIA CONTINUOUS MONITORING SYSTEMS  
PARTICULATE MATTER AND CARBON MONOXIDE  
VIA EMISSION MEASUREMENTS  
AND  
OPERATIONS PARAMETRIC DATA

Power Plant

CENTRAL POWER AND LIME, INC.  
Brooksville, Florida


Permit No. 0530021-023-AC

Test Dates: January 5-22, 2010  
Report Date: April 14, 2010

**Responsible Official Certification:**

I certify that, based upon information and belief formed after reasonable inquiry, the statements and information in the attached documents are true, accurate and complete.

Terry Woodard  
Manager, Power Plant



Signature

Date:

4-19-10

308-09-08



To the best of my knowledge, all applicable field and analytical procedures comply with the Florida Department of Environmental Protection requirements and all test data and plant operating data are true and correct.




Max Lee, Ph.D., P.E.

State of Florida  
License No. 58091

4/14/10

Date



## Table of Contents

1.0	INTRODUCTION .....	1
2.0	PROCESS DESCRIPTION.....	3
3.0	LOCATION OF SAMPLING PORTS .....	3
4.0	TEST METHODS .....	10
5.0	SUMMARY OF RESULTS .....	11

Appendix

## 1.0 INTRODUCTION

Central Power and Lime, Inc. (CPL) owns a 150-MW coal-fired electric generating unit (EGU) at a co-generation facility that also includes a cement plant complex that is owned and operated by Cemex Construction Materials Florida, L.L.C. (CEMEX) in Hernando County, northwest of Brooksville, Florida. Air Construction Permit No. 0530021-023-AC allows CPL to conduct a temporary trial burn of commercially manufactured wood pellets to supplement the primary fuel of coal in the power plant boiler. The purpose of this project is to examine the feasibility of receiving, storing, handling, and firing the commercial-grade wood pellets. The project affects only the Power Plant Boiler, having a maximum heat input of 1850 mmBtu/hr (EU 018).

The purpose of this report is to provide a summary report as required under permit condition A.3 of the following:

- fuel firing rates of each fuel (tons/hour);
- heat input rates from firing each fuel (MMBtu/hour);
- power generated (MW);
- steam generating rates (lb/hour);
- total flue gas flow rate;
- flue gas oxygen content;
- temperature at the baghouse inlet;
- whether or not the cement plant was operating;
- problems with receiving, storing, handling and firing the commercial wood pellets;
- overall operational feasibility of commercial wood pellets as an alternative fuel;
- performance of the fuel feed system
- performance of the bottom ash and fly ash removal systems;
- results of the ultimate,
- proximate and heat content analyses;
- comparison of emissions between firing only coal with co-firing commercial wood pellets with coal.

Emissions data includes nitrogen oxides (CEMS-power plant duct), sulfur dioxide (CEMS-main stack), opacity, particulate matter (Method 5), and carbon monoxide (Method 10) at baseline (coal fueled only) and three levels of supplemental wood pellet input fired in the boiler. For comparison, process monitor CO data is also provided in Table 1 results. The cement kiln No. 1 shares a common stack with the power boiler and was not online during all emission measurements testing.

Prior to the test dates, the Southwest District FDEP office in Temple Terrace, Florida was notified of the test schedule.

Tests were conducted as follows:

Baseline: January 5, 2010

Low-level: (6.1 percent of heat input): January 19, 2010

Mid-level: (11.4 percent of heat input): January 21, 2010

High-level: (16.2 percent of heat input): January 22, 2010 (partially completed)

Particulate matter and carbon monoxide emissions measurements were conducted by Koogler and Associates, Inc. of Gainesville, Florida. Nitrogen oxides, sulfur dioxide and opacity were monitored by certified continuous emission rate monitors. Particulate matter emission measurements were conducted in accordance with EPA Method 5 and the carbon monoxide emission measurements were conducted in

accordance with EPA Method 10. All test methods are described in 40 CFR 60, Appendix A.

The power plant is permitted to operate at a generating rate of 150 megawatts with a heat input rate not to exceed 1850 mmBTU/hr.

## **2.0 PROCESS DESCRIPTION**

The CPL power facility is a cogenerating facility including power plant. The power plant is permitted for a generating rate of 150 megawatts. The plant is normally fired with low-sulfur coal with a maximum permitted heat input rate of 1850 mmBTU per hour; however, commercially manufactured wood pellets to supplement the coal is allowed for the temporary trial burn.




## **3.0 LOCATION OF SAMPLING PORTS – PM AND CO TESTING**

The locations of the sampling points used for the particulate matter and volumetric stack gas flow rate sampling are shown in Figure 1. The main stack gas flow rate and particulate matter measurements for the power plant emissions were made through four sampling ports located at the 194-foot level of the stack (see Figure 1). The sampling ports are located at 90 degrees to one another in the 18.65-foot diameter stack; 155 feet above the point where the stack gases are introduced to



the stack and 126 feet below the top of the stack. A total of 16 sampling points were used for the velocity and sampling traverses. The sampling points were located in accordance with criteria established by EPA Test Method 1 (40 CFR 60, Appendix A).

Measurements of the carbon monoxide concentrations in the exhaust gas from the power plant were made at a single point near the center of a 11.75 foot by 11.75 foot duct exhausting the power plant prior to the point where the power plant and cement plant exhaust gases are combined. This location is shown in Figure 2.




**FIGURE 1**

**Fan Inlet/Outlet Duct  
Dimensions and  
Stack Dimensions**

**CEMEX, INC./DELTA POWER**

**Brooksville, Florida**



Duct Measurements	
Duct Depth (ft)	11.18
Duct Width (ft)	11.18
Duct Cross Sectional Area (sq ft)	125.86

CAIR CEM MONITORING at DELTA POWER aka CENTRAL POWER AND LINE

#### 4.0 TEST METHODS

The particulate matter measurements were conducted in accordance with EPA Method 5. These samples were collected at the 194-foot level of the stack. The particulate matter emission rate are representative of baseline power plant emissions. Moisture, stack gas flow rate, oxygen and CO<sub>2</sub> were measured in accordance with EPA Methods 2, 3 and 4.

Carbon monoxide emission measurements were conducted in accordance with EPA Method 10 (40 CFR 60, Appendix A). The main stack gas flow measurements used to determine CO emission rates were conducted using EPA Method 1-3 and dry bulb/wet bulb temperature measurements and psychometric tables were used to determine the stack gas moisture content.

All referenced test methods are described in 40 CFR 60, Appendix A.

The nitrogen oxides CMS is operated in accordance 40 CFR Part 75 and the sulfur dioxide and opacity CMS are operated in accordance with the provisions of 40 CFR 60, Appendix F and B.

## 5.0 SUMMARY OF RESULTS

The purpose of this report is to provide a summary report as required under permit condition A.3 of the following:

- fuel firing rates of each fuel (tons/hour);
- heat input rates from firing each fuel (MMBtu/hour);
- power generated (MW);
- steam generating rates (lb/hour);
- total flue gas flow rate;
- flue gas oxygen content;
- temperature at the baghouse inlet;
- comparison of emissions between firing only coal with co-firing commercial wood pellets with coal.

*These items are summarized in Table 1.*

- problems with receiving, storing, handling and firing the commercial wood pellets;
- overall operational feasibility of commercial wood pellets as an alternative fuel;
- performance of the fuel feed system
- performance of the bottom ash and fly ash removal systems;
- results of the ultimate,
- proximate and heat content analyses;

*These items are summarized in Sections 5.2.*

- whether or not the cement plant was operating;

The cement plant was not operating at all times during testing.

### 5.1 Baseline Emission Summary

The results of the baseline emissions data for January 5, 2010 are summarized in Table 1. During the particulate matter and carbon monoxide baseline emission test period for the power plant on January 5, 2010, the power plant was operating at a generating rate of 144.3 megawatts with an average coal feed rate of 108.6 tons per hour (or 1412 mmBTU per hour at 13,000 BTU per pound of coal).

The test results showed the baseline emissions from the power plant alone to be:

- a. The particulate matter emissions rate averaged 11.5 pounds per hour and 0.008 pounds per mmBTU.
- b. The carbon monoxide emissions rate averaged 542 pounds per hour and 0.384 pounds per mmBTU.
- c. The nitrogen oxide emission rate averaged 482 pounds per hour and 0.30 pounds per mmBTU.
- d. The sulfur dioxide emission rate averaged 640 pounds per hour and 0.34 pounds per mmBTU.

## **5.2 Supplemental Fuel Trial Summary**

The trial burn tests with wood pellets were conducted on January 19, 21 and 22, 2010 by Koogler and Associates, Inc.. The particulate matter emission measurements were only required to be performed during the highest level of supplementary fuel use which was on January 22, 2010. However, due to the inclement weather the PM measurements were not completed. For comparison, process monitor CO data is also provided in Table 1 results.

The test results showed the supplemental fuel trial emissions to be:

### Low-Level (6.1% heat replacement)

- a. The carbon monoxide emissions rate averaged 414 pounds per hour and 0.341 pounds per mmBTU (EPA Method 10).

- b. The nitrogen oxide emission rate averaged 421 pounds per hour and 0.285 pounds per mmBTU.
- c. The sulfur dioxide emission rate averaged 696 pounds per hour and 0.370 pounds per mmBTU.

Mid-Level (11.4% heat replacement)

- a. The carbon monoxide emissions rate averaged 677 pounds per hour and 0.487 pounds per mmBTU (EPA Method 10).
- b. The nitrogen oxide emission rate averaged 450 pounds per hour and 0.288 pounds per mmBTU.
- c. The sulfur dioxide emission rate averaged 677 pounds per hour and 0.366 pounds per mmBTU.

High-Level (16.2% heat replacement)

- a. The particulate matter emissions rate averaged 10.4 pounds per hour and 0.007 pounds per mmBTU.
- b. The carbon monoxide emissions rate averaged 1020 pounds per hour and 0.759 pounds per mmBTU (EPA Method 10).
- c. The nitrogen oxide emission rate averaged 633 pounds per hour and 0.416 pounds per mmBTU.
- d. The sulfur dioxide emission rate averaged 668 pounds per hour and 0.562 pounds per mmBTU.

Calculations, field and analytical data sheets, plant information, equipment calibration data and a list of the project participants are included in the Appendix of this report.

### **Summary Discussion of Wood Pellets as an Alternative Fuel**

- **problems with receiving, storing, handling and firing the commercial wood pellets;**

The shipment of 250 tons of wood pellets arrived by train and was stored in covered rail cars. Rain conditions on January 20, 21, and 22 limited handling to certain times of those days as the pellets quickly absorb a significant amount of moisture which drastically changes the handling characteristics. If the pellets are wet, the normally dry, hard pellets soften, expand and break apart and thus do not transfer as easily from conveyors and hoppers.

- **overall operational feasibility of commercial wood pellets as an alternative fuel;**

Wood pellets were shown to be a viable alternative fuel to coal. The most significant problems are prevention of moisture, blending of coal and wood pellets, and segregation between loading and entering the feed system. However, the boiler operators considered the trial period too short to adjust the factors that appeared to impact emissions and boiler performance.

The goal of future trial burns:

- 1) Evaluate the handling conditions to control and predict pellet properties (e.g., control moisture content and hardness of pellets).
- 2) Evaluate methods to increase the blending ratio of wood pellets with coal.



- 3) Improve the grinding efficiency of the mill which will allow a greater percentage of wood pellets to be ground thus improving the grinding process in the coal mill after recent maintenance, replacing grinding rings, and balls.
- 4) Conduct longer trial burns to give more ability to adjust operation conditions to improve the boiler operations.

- **performance of the fuel feed system**

Changes due to moisture content from rain water and a lesser extent changes in humidity result in changes of the pellet composition. The primary concern for wood pellet fuel is the change of bulk heat content. Also, it was noted by operators that the pellets segregated when transferred from the coal yard to the coal bin and Merrick feeder. If the pellets properties change from the time of analysis to input to the boiler, the heat content, moisture, and general heat properties become unknown variables.

The operators realized such problems as controlling the heat distribution and needed temperatures were affected by pellets composition changes and pellets segregation resulting in plugs of wood pellets into the boiler. This plug flow causing inferior boiler operation is suspected given the change in CO emissions.

- **performance of the bottom ash and fly ash removal systems;**

The bottom and fly ash operations were not observed to be impacted by the input of wood pellets.

- **results of the ultimate, proximate and heat content analyses;**

Results of analyses are attached.

**Table 1**

**Wood Pellets Trial Burn, AC Permit 0530021-023-AC**  
 Summary of NOx, SO2, PM, and CO Emissions Test Data

CEMEX / CPL Co-located Facility															
Brooksville, Florida															
Central Power and Lime, Inc. (CPL)															
Brooksville, Florida															
Power Boiler Operational Data															
Run No.	Date	Sample Start Time (hh:mm)	Sample End Time (hh:mm)	Generator Rate (MW)	Steam Rate (1000lb/hr)	Economizer Oxygen (%)	Baghouse Inlet Temp. (°F)	Coal Feed (tons/hr)	Wood Pellet Feed (tons/hr)	Coal Input (1) (MMBtu/hr)	Wood Input (1) (MMBtu/hr)	Total Input (1) (MMBtu/hr)	Stack Gas Parameters		
													Flow (dscfm)	Temp. (F)	Moisture (%)
1	5-Jan	12:25	13:46	143.8	951.5	5.39	260.8	54.1	0	1406	0	1406	484321	274	5.3
2	5-Jan	14:12	15:23	143.7	951.0	5.44	260.9	54.2	0	1409	0	1409	475865	275	5.7
3	5-Jan	15:41	16:52	145.4	957.9	5.43	268.7	54.6	0	1420	0	1420	482930	281	5.3
Ave.>				144.3	953.5	5.42	263.5	54.3	0	1412	0	1412	481039	277	5.4
Pellet Fuel Trials															
1	19-Jan	12:52	15:08	122.7	826.1	6.61	300.5	43.8	4.4	1139	74	1213	431848	295	6.8
1	21-Jan	11:49	14:04	139.9	951.7	5.00	323.6	47.3	9.5	1231	159	1390	420619	311	8.1
1	22-Jan	16:30	17:39	134.0	922.5	5.99	310.3	43.3	13.0	1125	218	1343	426062	306	7.6
<b>(1) Coal Heating Value = 13000 Btu/lb; Wood Pellet Heating Value = 8400 Btu/lb</b>															
<b>Calculated Btu value</b>															
Central Power and Lime, Inc. (CPL)															
Brooksville, Florida															
Power Boiler Emission Data															
Run No.	Pellet % Heat Input (%)	Opacity (%)	Power Duct CEMS Nitrogen Oxides		Stack CEMS Sulfur Dioxide		Process Monitor Carbon Monoxide		Stack Test Emission Data						
			(lb/hr)	(lb/MMBtu)	(lb/hr)	(lb/MMBtu)	(lb/hr)	(lb/MMBtu)	Carbon Monoxide		Particulate Matter				
			(lb/hr)	(lb/MMBtu)	(lb/hr)	(lb/MMBtu)	(lb/hr)	(lb/MMBtu)	(lb/hr)	(lb/MMBtu)	(gr/dscf)	(lb/hr)	(lb/MMBtu)		
Baseline															
1	Baseline	3.4	475	0.294	680	0.338	535	0.380	444	0.316	0.0025	10.5	0.007		
2	Baseline	2.3	477	0.295	621	0.339	550	0.391	468	0.332	0.0029	11.9	0.008		
3	Baseline	2.4	493	0.310	618	0.347	726	0.511	714	0.503	0.0029	12.1	0.008		
Ave.>		2.7	482	0.300	640	0.341	604	0.427	542	0.384	0.0028	11.5	0.008		
Pellet Fuel Trials															
9%wood	6.1	3.4	421	0.285	696	0.370	587	0.484	414	0.341	NA	NA	NA		
17% wood	11.4	3.5	450	0.288	677	0.366	828	0.596	677	0.487	NA	NA	NA		
23%wood	16.2	2.6	633	0.416	668	0.562	1066	0.793	1020	0.759	0.0028	10.4	0.007		

NOTES: SO2, CO, and PM emission rate of lb/mmbtu is calculated from 1) measured lb/hr and 2) calculated mmbtu/hr based on fuel input amounts.

## Appendix

### Particulate Matter Emission Measurements (Jan. 5)

Calculations

Field and Analytical Data Sheets

### Carbon monoxide Emission Measurements (Jan. 5)

Calibration Calculations and Concentrations

Field Data Sheets

### Particulate Matter Emission Measurements (Jan. 22)

Calculations

Field and Analytical Data Sheets

### Carbon monoxide Emission Measurements (Jan. 19, 21 and 22)

Calibration Calculations and Concentrations

Field Data Sheets

### Particulate Matter Equipment Calibrations and

Calibration Gas Certifications

Plant Operating Data

Project Participants

Particulate Matter Emission Measurements (Jan. 5)

Calculations

SUMMARY OF PARTICULATE MATTER EMISSION TEST DATA

CENTRAL POWER & LIME, INC. (CPL)					
EU 018: POWER PLANT COAL BASELINE					
JANUARY 05, 2010					
Run No.	Stack Gas Flow Rate (SCFMD)	Stack Gas Temperature (F)	Stack Gas Moisture (%)	Particulate Matter	
				Conc. (gr/dscf)	Emission Rate (Lbs/Hr)
1	484,321	274	5.3	0.0025	10.52
2	475,865	275	5.7	0.0029	11.95
3	482,930	281	5.3	0.0029	12.06
Avg.	481,039	277	5.4	0.0028	11.51

GENERAL DATA

Plant : CENTRAL POWER & LIME, INC. (CPL)  
 Source/Unit : EU 018: POWER PLANT COAL BASELINE  
 Date : JANUARY 05, 2010 Cp : 0.840  
 Stack dia. : 223.80 inch OR : Duct Length : 0.00 inch  
 Oxygen Corr.: 0.0 percent Duct Width : 0.00 inch  
 CO2 Corr. : 0.0 percent Std. Temp. : 68 F

FUEL ANALYSIS DATA, (By F Factor or Fuel Use)

F Factor = F, Fuel Use = U f Process Wt.

Hydrogen, wt% : 0.00 Run 1 : 0 Tons/hr  
 Carbon, wt% : 0.00 Run 2 : 0  
 Sulfur, wt% : 0.00 Run 3 : 0  
 Nitrogen, wt% : 0.00  
 Oxygen, wt% : 0.00  
 Btu/lb : 0

Type of Flow Meter : (1=Meter Box 2=Mass Flow Meter) 1

F-Factor : dscf/MMBtu;

<u>FIELD DATA</u>	METHOD 5	RUN 1	RUN 2	RUN 3
Meter Temp., Tm (F) .....		63	66	66
Stack Temp., Ts (F) .....		274	275	281
Sq.Rt. dP .....		0.66	0.65	0.66
dH (in. H2O) .....		1.31	1.31	1.35
Meter Vol., Vm (ft3) .....		43.175	44.311	45.064
Vol. H2O, Vlc (ml) .....		52.0	58.0	54.0
Meter Y .....		0.996	0.996	0.996
Bar. Press., Pb (in.Hg.) .....		30.12	30.12	30.12
Static Press., Ps (in.H2O) .....		-0.83	-0.83	-0.83
Test Time (min.) .....		64.0	64.0	64.0
Nozzle Dia., Dn (in.) .....		0.266	0.266	0.266
Oxygen, O2 (%) .....		13.0	12.0	13.0
Carbon Dioxide, CO2 (%) .....		9.0	9.0	8.5
Carbon Monoxide, CO (%) .....		0.0	0.0	0.0
Report Emission Criteria in ? l = lb/hr g = gr/dscf :				grains
Process Rate Units ? T = Ton/hr, L = Lbs/hr, C = Cans/min:				T
Allowable Particulate Matter Concentration .....				0

<u>LABORATORY RESULTS</u>	RUN 1	RUN 2	RUN 3
	grams	grams	grams
<u>GRAVIMETRIC ANALYSIS METHOD 5 :</u>			
Front Half Wash (FWW) .....	0.00410	0.00680	0.00540
Filterable Sample (MF) .....	0.00310	0.00170	0.00320
Condensable Sample (BHW) .....	0.00000	0.00000	0.00000

## A. FIELD DATA SUMMARY

---

Plant: CENTRAL POWER & LIME, INC. (CPL)  
 Source/Unit: EU 018: POWER PLANT COAL BASELINE  
 Date: JANUARY 05, 2010

	RUN 1	RUN 2	RUN 3
Vlc = Vol water collected in train, ml	52.0	58.0	54.0
Vm = Sample gas vol, meter cond., acf	43.175	44.311	45.064
Y = Meter calibration factor	0.9960	0.9960	0.9960
Pbar = Barometric pressure, in. Hg	30.12	30.12	30.12
Pstatic = Stack static pressure, in. H2O	-0.83	-0.83	-0.83
dH = Avg meter pressure diff, in. H2O	1.31	1.31	1.35
Tm = Absolute meter temp., degrees R	522.9	525.5	525.5
Vm(std) = Sample gas vol, Std. cond., dscf	43.854	44.783	45.548
Bws = Water vapor in gas stream, fraction	0.053	0.057	0.053
MF = Moisture factor ( 1 - Bws)	0.947	0.943	0.947
CO2 = Carbon Dioxide, dry, volume %	9.00	9.00	8.50
O2 = Oxygen, dry, volume %	13.00	12.00	13.00
N2 = Nitrogen, dry volume %	78.00	79.00	78.50
Md = Molecular weight of stack gas, dry	29.96	29.92	29.88
Ms = Molecular weight of stack gas, wet	29.33	29.24	29.25
Cp = Pitot tube coefficient	0.84	0.84	0.84
Sq.Rt. dP = Avg. square root of each dP	0.6589	0.6500	0.6590
Ts = Absolute stack temp., degrees R	734.3	735.4	740.6
A = Area of stack, ft2	273.18	273.18	273.18
Qstd = Volumetric flowrate, dscfm	484,321	475,865	482,930
An = Nozzle area, ft2	3.86E-04	3.86E-04	3.86E-04
t = Sample time, minutes	64.00	64.00	64.00
%I = Isokinetic variation, percent	100.15	104.09	104.32

B. PARTICULATE DATA SUMMARY

---

Plant: CENTRAL POWER & LIME, INC. (CPL)  
 Source/Unit: EU 018: POWER PLANT COAL BASELINE  
 Date: JANUARY 05, 2010

	RUN 1	RUN 2	RUN 3
Sample Weight (FHW + MF + BHW), mg .....	7.20	8.50	8.60
Meter Volume, standard cond., Vm(std) .....	43.854	44.783	45.548
Carbon Dioxide, percent .....	9.00	9.00	8.50
Oxygen, percent .....	13.00	12.00	13.00
Sample Concentration :			
gr/scf .....	0.0024	0.0028	0.0028
gr/dscf .....	0.0025	0.0029	0.0029
gr/dscf @ 0 % CO2 .....	0.0034	0.0039	0.0041
gr/dscf @ 0 % O2 .....	0.0067	0.0069	0.0077
ppm * MW (dry gas).....	139.4	161.1	160.3
ppm * MW @ 0% CO2 .....	0.0	0.0	0.0
ppm * MW @ 0% O2 .....	368.7	378.3	424.0



**EMISSION RATE CALCULATIONS**

Plant : CENTRAL POWER & LIME, INC. (CPL)  
 Source/Unit : EU 018: POWER PLANT COAL BASELINE  
 Date: JANUARY 05, 2010 RUN N 1  
 STANDARD TEMP. : 68 F

Front Half Wash (FHW)	0.00410 grams	Vm(st	43.854 ft3
Mass Filter (MF)	0.00310 grams	Vw(st	2.448 ft3
Back Half Wash (BHW)	0.00000 grams	Qs(st	484,321 dscfm
Vm(std) SO2	dscf	Bws	0.053
CO2 CORF 0.0 %		CO2	9.00 %
O2 CORR. 0.0 %		O2	13.00 %

**F-FACTOR**

$10E6 \times [3.64(\%H) + 1.53(\%C) + 0.57(\%S) + 0.14(\%N) - 0.46(\%O2)] / (Btu/lb) \times [(Tstd + 460)/528]$  ..... dscf/MMBtu  
 FUEL USE

Use Rate (gal/ton) \* Process Wt. (ton/hr) ..... gal/hr  
 Heat Input = (Process Weight (ton/hr) x Heating Value (Btu/gal) x Fuel Use Rate (gal/ton) / 1E6 .... MMBtu/hr

**TOTAL PARTICULATE**

$15.432 \times (FHW + MF + BHW) / [(Vm(std) + Vw(std))]$  ... 0.0024 gr/scf  
 $15.432 \times (FHW + MF + BHW) / (Vm(std))$  ..... 0.0025 gr/dscf  
 gr/dscf x (12 / %CO2) ..... 0.0034 @ 0% CO2  
 gr/dscf x [(20.9 - Oxygen corr.) / (20.9 - %O2)] ..... 0.0067 @ 0% O2  
 0.00857 x Qs(std) x gr/dscf ..... 10.52 lb/hr  
 F-Fac x  $1.4286E-4 \times [20.9 / (20.9 - \%O2)] \times$  gr/dscf .. lb/MMBtu  
 Particulate (lb/hr) / Heat Input (MMBtu/hr) ..... lb/MMBtu

**TOTAL ACID MIST**

$[1.0811E-4 \times (Vt - Vtb) \times N \times Vsol] / Vol(aloq)$  .. lb Acid Mist  
 [Acid Mist (lb) / Vm std (ft^3)] x Qs std x 60 ... lb/hr  
 [Acid Mist (lb) / Vm std (ft^3)] x F-Factor ..... lb/MMBtu

**SULFUR DIOXIDE (SO2)**

$[7.061E-5 \times (Vt - Vtb) \times N \times Vsol] / Vol(aloq)$  .. lb SO2  
 [SO2 (lb) / Vm std (ft^3)] x Qs std (ft^3/min) x 60 ... lb/hr  
 [SO2 (lb) / Vm std (ft^3)] x F ..... lb/MMBtu  
 [Mass SO2 (lb) x 385 / 64E+6 (ft^3/lb)] / Vm (std) ppm  
 ppm x 0.0 % Corr. / 9.0 % CO2 in Stack ..... ppm @ 0% CO2  
 ppm x (20.9% - 0.0% O2 Corr)/(20.9% - 13.0% O2 Stack) ppm @ 0% O2  
 SO2 (lb/hr / Heat Input) ..... lb/MMBtu

**HYDROGEN CHLORIDE DATA SUMMARY**

[Mass HCl(mg) x 385 x 1E6] / [453600 x 36.5 x Vm(std)].. ppm  
 ppm x 0.0 % Corr. / 9.0 % CO2 in Stack ..... ppm @ 0% CO2  
 ppm x (20.9% - 0.0% O2 Corr)/(20.9% - 9.0% O2 Stack) ppm @ 0% O2  
 [Mass HCl(mg) x 60 x Qs / (Vm(std) x 453,600)]..... lb/hr

**EMISSION RATE CALCULATIONS**

Plant : CENTRAL POWER & LIME, INC. (CPL)  
 Source/Unit : EU 018: POWER PLANT COAL BASELINE  
 Date: JANUARY 05, 2010 RUN N 2  
 STANDARD TEMP. : 68 F

Front Half Wash (FHW)	0.00680 grams	Vm(st	44.783 ft3
Mass Filter (MF)	0.00170 grams	Vw(st	2.730 ft3
Back Half Wash (BHW)	0.00000 grams	Qs(st	475,865 dscfm
Vm(std) SO2	dscf	Bws	0.057
CO2 CORF 0.0 %		CO2	9.00 %
O2 CORR. 0.0 %		O2	12.00 %

F-FACTOR

$10E6 \times [3.64(\%H) + 1.53(\%C) + 0.57(\%S) + 0.14(\%N) - 0.46(\%O2)] / (Btu/lb) \times [(Tstd + 460)/528]$  ..... dscf/MMBtu

FUEL USE

-  
 Use Rate (gal/ton) \* Process Wt. (ton/hr) ..... gal/hr  
 Heat Input = (Process Weight (ton/hr) x Heating Value (Btu/gal) x Fuel Use Rate (gal/ton) / 1E6) ..... MMBtu/hr

TOTAL PARTICULATE

$15.432 \times (FHW + MF + BHW) / [(Vm(std) + Vw(std))]$  ... 0.0028 gr/scf  
 $15.432 \times (FHW + MF + BHW) / (Vm(std))$  ..... 0.0029 gr/dscf  
 gr/dscf x (12 / %CO2) ..... 0.0039 @ 0% CO2  
 gr/dscf x [(20.9 - Oxygen corr.) / (20.9 - %O2)] ..... 0.0069 @ 0% O2  
 0.00857 x Qs(std) x gr/dscf ..... 11.95 lb/hr  
 F-Fac x  $1.4286E-4 \times [20.9 / (20.9 - \%O2)] \times$  gr/dscf .. lb/MMBtu  
 Particulate (lb/hr) / Heat Input (MMBtu/hr) ..... lb/MMBtu

TOTAL ACID MIST

$[1.0811E-4 \times (Vt - Vtb) \times N \times Vsol] / Vol(aloq)$  . lb Acid Mist  
 [Acid Mist (lb) / Vm std (ft^3)] x Qs std x 60 ... lb/hr  
 [Acid Mist (lb) / Vm std (ft^3)] x F-Factor ..... lb/MMBtu

SULFUR DIOXIDE (SO2)

$[7.061E-5 \times (Vt - Vtb) \times N \times Vsol] / Vol(aloq)$  . lb SO2  
 [SO2 (lb) / Vm std (ft^3)] x Qs std (ft^3/min) x 60 ... lb/hr  
 [SO2 (lb) / Vm std (ft^3)] x F ..... lb/MMBtu  
 [ Mass SO2 (lb) x 385 / 64E+6 (ft^3/lb) ] / Vm (std) ppm  
 ppm x 0.0 % Corr. / 9.0 % CO2 in Stack ..... ppm @ 0% CO2  
 ppm x (20.9% - 0.0% O2 Corr)/(20.9% - 9.0% O2 Stack) ppm @ 0% O2  
 SO2 (lb/hr / Heat Input) ..... lb/MMBtu

HYDROGEN CHLORIDE DATA SUMMARY

[Mass HCl(mg) x 385 x 1E6] / [453600 x 36.5 x Vm(std)].. ppm  
 ppm x 0.0 % Corr. / 9.0 % CO2 in Stack ..... ppm @ 0% CO2  
 ppm x (20.9% - 0.0% O2 Corr)/(20.9% - 9.0% O2 Stack) ppm @ 0% O2  
 [ Mass HCl(mg) x 60 x Qs / ( Vm(std) x 453,600 )]..... lb/hr

**EMISSION RATE CALCULATIONS**

Plant : CENTRAL POWER & LIME, INC. (CPL)  
 Source/Unit : EU 018: POWER PLANT COAL BASELINE  
 Date: JANUARY 05, 2010 RUN N 3  
 STANDARD TEMP. : 68 F

Front Half Wash (FHW)	0.00540 grams	Vm(st)	45.548 ft3
Mass Filter (MF)	0.00320 grams	Vw(st)	2.542 ft3
Back Half Wash (BHW)	0.00000 grams	Qs(st)	482,930 dscfm
Vm(std) SO2	dscf	Bws	0.053
CO2 CORF 0.0 %		CO2	8.50 %
O2 CORR. 0.0 %		O2	13.00 %

F-FACTOR

$10E6 \times [3.64(\%H) + 1.53(\%C) + 0.57(\%S) + 0.14(\%N) - 0.46(\%O2)] / (Btu/lb) \times [(Tstd + 460)/528]$  ..... dscf/MMBtu  
 FUEL USE

Use Rate (gal/ton) \* Process Wt. (ton/hr) ..... gal/hr  
 Heat Input = (Process Weight (ton/hr) x Heating .... MMBtu/hr  
 Value (Btu/gal) x Fuel Use Rate (gal/ton) / 1E6  
TOTAL PARTICULATE

$15.432 \times (FHW + MF + BHW) / [(Vm(std) + Vw(std)]$  ... 0.0028 gr/scf  
 $15.432 \times (FHW + MF + BHW) / (Vm(std) \dots\dots\dots$  0.0029 gr/dscf  
 gr/dscf x (12 / %CO2) ..... 0.0041 @ 0% CO2  
 gr/dscf x [(20.9 - Oxygen corr.) / (20.9 - %O2)] ..... 0.0077 @ 0% O2  
 $0.00857 \times Qs(std) \times gr/dscf \dots\dots\dots$  12.06 lb/hr  
 F-Fac x  $1.4286E-4 \times [20.9 / (20.9 - \%O2)] \times gr/dscf \dots$  lb/MMBtu  
 Particulate (lb/hr) / Heat Input (MMBtu/hr) ..... lb/MMBtu  
TOTAL ACID MIST

$[1.0811E-4 \times (Vt - Vtb) \times N \times Vsol] / Vol(aloq) \dots$  lb Acid Mist  
 [Acid Mist (lb) / Vm std (ft^3)] x Qs std x 60 ... lb/hr  
 [Acid Mist (lb) / Vm std (ft^3)] x F-Factor ..... lb/MMBtu  
SULFUR DIOXIDE (SO2)

$[7.061E-5 \times (Vt - Vtb) \times N \times Vsol] / Vol(aloq) \dots$  lb SO2  
 [SO2 (lb) / Vm std (ft^3)] x Qs std (ft^3/min) x 60 ... lb/hr  
 [SO2 (lb) / Vm std (ft^3)] x F ..... lb/MMBtu  
 [ Mass SO2 (lb) x 385 / 64E+6 (ft^3/lb) ] / Vm (std) ppm  
 ppm x 0.0 % Corr. / 9.0 % CO2 in Stack ..... ppm @ 0% CO2  
 ppm x (20.9% - 0.0% O2 Corr)/(20.9% - 9.0% O2 Stack) ppm @ 0% O2  
 SO2 (lb/hr / Heat Input) ..... lb/MMBtu

HYDROGEN CHLORIDE DATA SUMMARY

[Mass HCl(mg) x 385 x 1E6] / [453600 x 36.5 x Vm(std)].. ppm  
 ppm x 0.0 % Corr. / 8.5 % CO2 in Stack ..... ppm @ 0% CO2  
 ppm x (20.9% - 0.0% O2 Corr)/(20.9% - 8.5% O2 Stack) ppm @ 0% O2  
 [ Mass HCl(mg) x 60 x Qs / ( Vm(std) x 453,600 )]..... lb/hr

SOURCE TEST CALCULATIONS

---

Plant : CENTRAL POWER & LIME, INC. (CPL)  
 Source/Unit : EU 018: POWER PLANT COAL BASELINE  
 Date: JANUARY 05, 2010

RUN NO.: 1

STD. TEMP, Tstd =	68 F	STATIC PRESS., Ps =	-0.83 in. H2O
METER TEMP, Tm =	62.875 F	PITOT COFF., Cp =	0.840
STACK TEMP, Ts =	274.3 F	STACK I.D. =	223.80 inch
AVG. VEL. HEAD, dP =	0.434 in. H2O	DUCT LENGTH =	inch
METER ORIFICE, dH =	1.31 in. H2O	DUCT WIDTH =	inch
METER VOL., Vm =	43.175 Cu.Ft.	STACK AREA, As =	273.179 Sq.Ft.
METER COFF., Y =	0.996	TEST TIME =	64.00 min.
BAR. PRESS., Pb =	30.12 in.Hg	NOZZLE DIA. =	0.266 inch
COND. (Vlc) =	52.0 ml	NOZZLE DIA., An =	3.9E-04 Sq.Ft.
GAS ANALYSIS =	13.00 % O2	0.00 % CO	
	9.00 % CO2	78.00 % N2	

---

$$\begin{aligned}
 Vm(std) &= [ ( T(std) + 460 ) / 29.92 ] \times Vm \times Y \times \\
 &\quad ( Pb + (dH / 13.6) ) / (Tm + 460) \dots\dots = 43.854 \text{ dscf} \\
 Vw(std) &= (8.9148 \times 10e-5) \times (Tstd + 460) \times Vlc = 2.448 \text{ scf} \\
 Bws &= Vw(std) / (Vm(std) + Vw(std)) \dots\dots\dots = 0.053 \text{ | Lower} \\
 &\quad \text{| Bws} \\
 Bws @ \text{ Saturated Conditions} &= \text{Vapor Press. of H2O} \\
 @ \text{ Dew Point Temp. / (Ps, in.Hg.)} \dots\dots\dots &= 1.000 \text{ | value} \\
 &\quad \text{| used.} \\
 \%EA &= (\%O2 - 0.5\%CO) / (0.264\%N2 - (\%O2 - 0.5\%CO)) \times 100 = 171.23 \\
 Md &= (.44 \times \%CO2) + (.32 \times \%O2) + [.28 \times (\%N2 + \%CO)] = 29.96 \\
 Ms &= (Md \times (1 - Bws)) + (18.0 \times Bws) \dots\dots\dots = 29.33 \\
 P(stack) &= Pbar + (Ps / 13.6) \dots\dots\dots = 30.06 \text{ in. Hg} \\
 vs &= 85.49 \times CP \times (Sq.Rt.dP) \times [Sq.Rt.(Ts + 460) \\
 &\quad / (Ms \times P(stack))] \dots\dots\dots = 43.18 \text{ ft/sec} \\
 Qs &= vs \times As \times 60 \dots\dots\dots = 707,813 \text{ acf/min} \\
 Qs(std) &= Qs \times (1 - Bws) \times ((Tstd + 460) / (Ts + 460)) \\
 &\quad \times (P(stack) / 29.92) \dots\dots\dots = 484,321 \text{ dscf/min} \\
 I &= (Ts + 460) \times [(0.002669 \times Vlc) + (Vm(std) / \\
 &\quad (T(std) + 460) / 29.92] \times 100 / [ \text{Time} \times \\
 &\quad P(stack) \times An \times vs \times 60] \dots\dots\dots = 100.15 \%
 \end{aligned}$$

SOURCE TEST CALCULATIONS

---

Plant : CENTRAL POWER & LIME, INC. (CPL)  
 Source/Unit : EU 018: POWER PLANT COAL BASELINE  
 Date : JANUARY 05, 2010

RUN NO.: 2

STD.TEMP, Tstd =	68 F	STATIC PRESS.,Ps =	-0.83 in. H2O
METER TEMP, Tm =	65.50 F	PITOT COFF., Cp =	0.840
STACK TEMP, Ts =	275.4 F	STACK I.D. =	223.80 inch
AVG.VEL.HEAD,dP =	0.423 in. H2O	DUCT LENGTH =	inch
METER ORIFICE,dH=	1.31 in. H2O	DUCT WIDTH =	inch
METER VOL., Vm =	44.311 Cu.Ft.	STACK AREA, As =	273.179 Sq.Ft.
METER COFF., Y =	0.996	TEST TIME =	64.00 min.
BAR. PRESS., Pb =	30.12 in.Hg	NOZZLE DIA. =	0.266 inch
COND.(Vlc) =	58.0 ml	NOZZLE DIA., An =	3.9E-04 Sq.Ft.

GAS ANALYSIS =	12.00 % O2	0.00 % CO	
	9.00 % CO2	79.00 % N2	

---

Vm(std) = [ ( T(std) + 460 ) / 29.92 ] x Vm x Y x (Pb + (dH / 13.6)) / (Tm + 460).....	=	44.783 dscf
Vw(std) = (8.9148 x 10e-5) x (Tstd + 460) x Vlc	=	2.730 scf
Bws = Vw(std) / (Vm(std) + Vw(std)).....	=	0.057   Lower   Bws   value   used.
Bws @ Saturated Conditions = Vapor Press. of H2O @ Dew Point Temp. / (Ps, in.Hg.) .....	=	1.000
%EA = (%O2 - 0.5%CO)/(0.264%N2 - (%O2-0.5%CO)) x 100 =	=	135.50
Md = (.44 x %CO2)+(.32 x %O2)+[.28 x (%N2 + %CO)] =	=	29.92
Ms = (Md x (1-Bws)) + (18.0 x Bws).....	=	29.24
P(stack) = Pbar + (Ps / 13.6) .....	=	30.06 in. Hg
vs = 85.49 x CP x (Sq.Rt.dP) x [Sq.Rt.(Ts + 460) / (Ms x P(stack))] .....	=	42.70 ft/sec
Qs = vs x As x 60 .....	=	699,915 acf/min
Qs(std) = Qs x (1-Bws)x((Tstd + 460)/(Ts + 460)) x (P(stack)/29.92) .....	=	475,865 dscf/min
I = (Ts+460) x [(0.002669 x Vlc) + (Vm(std) / (T(std) + 460) / 29.92] x 100 / [ Time x P(stack) x An x vs x 60] .....	=	104.09 %

SOURCE TEST CALCULATIONS

---

Plant : CENTRAL POWER & LIME, INC. (CPL)  
 Source/Unit : EU 018: POWER PLANT COAL BASELINE  
 Date : JANUARY 05, 2010

RUN NO.: 3

STD.TEMP, Tstd =	68 F	STATIC PRESS., Ps =	-0.83 in. H2O
METER TEMP, Tm =	65.50 F	PITOT COFF., Cp =	0.840
STACK TEMP, Ts =	280.6 F	STACK I.D. =	223.80 inch
AVG.VEL.HEAD,dP =	0.434 in. H2O	DUCT LENGTH =	inch
METER ORIFICE,dH=	1.35 in. H2O	DUCT WIDTH =	inch
METER VOL., Vm =	45.064 Cu.Ft.	STACK AREA, As =	273.179 Sq.Ft.
METER COFF., Y =	0.996	TEST TIME =	64.00 min.
BAR. PRESS., Pb =	30.12 in.Hg	NOZZLE DIA. =	0.266 inch
COND.(Vlc) =	54.0 ml	NOZZLE DIA., An =	3.9E-04 Sq.Ft.

GAS ANALYSIS =	13.00 % O2	0.00 % CO	
	8.50 % CO2	78.50 % N2	

---


$Vm(std) = [ ( T(std) + 460 ) / 29.92 ] \times Vm \times Y \times (Pb + (dH / 13.6)) / (Tm + 460).....$	=	45.548 dscf
$Vw(std) = (8.9148 \times 10e-5) \times (Tstd + 460) \times Vlc$	=	2.542 scf
$Bws = Vw(std) / (Vm(std) + Vw(std)).....$	=	0.053   Lower   Bws   value   used.
$Bws @ \text{Saturated Conditions} = \text{Vapor Press. of H2O @ Dew Point Temp.} / (Ps, \text{in.Hg.}) .....$	=	1.000
$\%EA = (\%O2 - 0.5\%CO) / (0.264\%N2 - (\%O2 - 0.5\%CO)) \times 100 =$		168.31
$Md = (.44 \times \%CO2) + (.32 \times \%O2) + [.28 \times (\%N2 + \%CO)] =$		29.88
$Ms = (Md \times (1 - Bws)) + (18.0 \times Bws).....$	=	29.25
$P(stack) = Pbar + (Ps / 13.6) .....$	=	30.06 in. Hg
$vs = 85.49 \times CP \times (Sq.Rt.dP) \times [Sq.Rt.(Ts + 460) / (Ms \times P(stack))] .....$	=	43.43 ft/sec
$Qs = vs \times As \times 60 .....$	=	711,841 acf/min
$Qs(std) = Qs \times (1 - Bws) \times ((Tstd + 460) / (Ts + 460)) \times (P(stack) / 29.92) .....$	=	482,930 dscf/min
$I = (Ts + 460) \times [(0.002669 \times Vlc) + (Vm(std) / (T(std) + 460) / 29.92) \times 100 / [Time \times P(stack) \times An \times vs \times 60] .....$	=	104.32 %

Particulate Matter Emission Measurements (Jan. 5)

Field and Analytical Data Sheets

## Multiple Methods Data Sheet

Plant: CPZ - Power Plant - Brooksville  
 Sample Location: Main Stack  
 Control Type: Baghouse  
 Sample Type: Port  
 Date: 1-5-10 Run No.: 1  
 Time Start: 1225 Time End: 1346  
 Sample Time: 4 min/point 64 Total Mins.  
 Dry Bulb: °F Wet Bulb: °F VP@DP:  
 Bar. Pres: 30.12 "Hg Stack Pres: 30.06 "Hg Ps: -0.83 "H<sub>2</sub>O  
 Moisture: 8 % FDA: Gas Density Factor:  
 Temp: 45 °F Wind Direction: Var Wind Speed: 2-3  
 Weather: Clear Thermocouple Readout: KAK-7  
 Sample Box No.: KAV-7 Meter Box No.: KAK-7  
 Meter Y: 0.996 @ Delta H: 1.54 Pitot Corr.: 0.84  
 Nozzle Diameter: 0.266 inches Probe Length: 10.11 feet  
 Probe Heater Setting: 242 Nomograph Cf: 3.0  
 Stack Dimensions: 223.8 inches  
 Stack Area: 27318 ft<sup>2</sup>  
 Effective Stack Area: 27318 ft<sup>2</sup>  
 Stack Height: \_\_\_\_\_ ft



Material Processing Rate:  
 Final Gas Meter Reading: 331,475 ft<sup>3</sup>  
 Initial Gas Meter Reading: 288,300 ft<sup>3</sup>  
 Total Metered Gas Volume: 43,175 ft<sup>3</sup>  
 Condensate Gain in Impingers: 44 mL  
 Weight Gain in Silica Gel: 3.0 g  
 Total Moisture Gain: 52 mL  
 Silica Gel Container No.: 16  
 Filter Number: I

Leak Check - Meter Box:  
 Initial: 0.009 cfm @ 10 inches Hg  
 Final: 0.000 cfm @ 5 inches Hg

Leak Check - Pitot Tubes:  
 Impact 3 "H<sub>2</sub>O for 15 sec: Stable Leak  
 Static 3 "H<sub>2</sub>O for 15 sec: Stable Leak

Test Conducted By: R Paul - J Langston  
 O<sub>2</sub>: 13.0 % CO<sub>2</sub>: 9.0 %  
 Stack Test Observers: \_\_\_\_\_

Port and Traverse Point No.	Distance from Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft <sup>3</sup> )	Stack Velocity Head (H <sub>2</sub> O)	Meter Orifice Pressure Difference (H <sub>2</sub> O)		Stack Gas Temp (°F)	Sample Box Temp (°F)	Last Impinger Temp (°F)	Meter Temp (°F)	Vacuum on Sample Train ("Hg)	Oxygen Meter Reading (%O <sub>2</sub> )
					Calculated	Actual						
1-1			88.3	0.53	1.59	1.59	273	248	47	57	2	
2			91.2	0.50	1.5	1.5	274	250	41	58	2	
3			94.0	0.50	1.5	1.5	273	249	40	59	2	
4			96.8	0.41	1.23	1.23	271	247	40	60	2	
2-1			99.3	0.43	1.36	1.36	273	252	46	61	2	
2			302.0	0.43	1.36	1.36	274	243	39	62	2	
3			4.6	0.40	1.27	1.27	274	250	39	63	2	
4			7.2	0.36	1.14	1.14	273	248	39	63	2	






Port and Traverse Point No.	Distance from Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft <sup>3</sup> )	Stack Velocity Head (H <sub>2</sub> O)	Meter Orifice Pressure Difference (H <sub>2</sub> O)		Stack Gas Temp (°F)	Sample Box Temp (°F)	Last Impinger Temp (°F)	Meter Temp (°F)	Vacuum on Sample Train ("Hg)	Oxygen Meter Reading (%O <sub>2</sub> )
					Calculated	Actual						
3-1			9.7	0.43	1.36	1.36	273	237	37	64	2	
2			12.4	0.40	1.27	1.27	275	239	36	64	2	
3			15.0	0.37	1.17	1.17	275	259	38	65	2	
4			17.5	0.37	1.17	1.17	273	243	36	65	2	
4-1			20.0	0.50	1.59	1.59	276	260	38	66	2	
2			23.0	0.48	1.52	1.52	278	253	38	66	2	
3			25.9	0.43	1.36	1.36	277	256	38	67	2	
4			28.7	0.43	1.36	1.36	276	261	39	66	2	



# Multiple Methods Data Sheet

Plant: CPZ - Brooksville  
 Sample Location: Power Plant  
 Control Type: Baghouse  
 Sample Type: Dust  
 Date: 1-5-10 Run No.: 2  
 Time Start: 1412 Time End: 1523  
 Sample Time: 4x4x4 min/point 64 Total Mins.  
 Dry Bulb: °F Wet Bulb: °F VP@DP:  
 Bar. Pres: 30.12 "Hg Stack Pres: 30.00 "Hg Ps: -0.83 "H<sub>2</sub>O  
 Moisture: 4.5 % FDA: Gas Density Factor:  
 Temp: 45 °F Wind Direction: Var Wind Speed: 2-3  
 Weather: Clear Thermocouple Readout: KAU-7  
 Sample Box No. KAU-7 Meter Box No.: KAU-7  
 Meter Y: 0.996 @ Delta H: 1.54 Pitot Corr.: 0.84  
 Nozzle Diameter: 0.26 inches Probe Length: 10.22 feet  
 Probe Heater Setting: 242 Nomograph Cf: 3.1  
 Stack Dimensions: 223.8 inches  
 Stack Area: 27318 ft<sup>2</sup>  
 Effective Stack Area: 27318 ft<sup>2</sup>  
 Stack Height: \_\_\_\_\_ ft



Material Processing Rate:  
 Final Gas Meter Reading: 376.011 ft<sup>3</sup>  
 Initial Gas Meter Reading: 331.700 ft<sup>3</sup>  
 Total Metered Gas Volume: 44.311 ft<sup>3</sup>  
 Condensate Gain in Impingers: 50 mL  
 Weight Gain in Silica Gel: 8 g  
 Total Moisture Gain: 58 mL  
 Silica Gel Container No.: 14  
 Filter Number: II

**Leak Check - Meter Box:**  
 Initial: 0.000 cfm @ 10 inches Hg  
 Final: 0.004 cfm @ 5 inches Hg

**Leak Check - Pitot Tubes:**  
 Impact 3 "H<sub>2</sub>O for 15 sec: Stable, Leak  
 Static 3 "H<sub>2</sub>O for 15 sec: Stable, Leak

Umbilical: KAU-KK1<sup>RP</sup>  
 Thermocouple: \_\_\_\_\_  
 Probe No.: KAU-110  
 Pitot Tube: KAU-SS1  
 Test Conducted By: R Paul J Langston  
 O<sub>2</sub>: 12.0 % CO<sub>2</sub>: 8.0 %  
 Stack Test Observers: \_\_\_\_\_

Port and Traverse Point No.	Distance from Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft <sup>3</sup> )	Stack Velocity Head (H <sub>2</sub> O)	Meter Orifice Pressure Difference (H <sub>2</sub> O)		Stack Gas Temp (°F)	Sample Box Temp (°F)	Last Impinger Temp (°F)	Meter Temp (°F)	Vacuum on Sample Train ("Hg)	Oxygen Meter Reading (%O <sub>2</sub> )
					Calculated	Actual						
1-1			31.7	0.51	1.58	1.58	276	232	44	63	3	
2			34.7	0.45	1.4	1.4	278	250	42	63	3	
3			37.6	0.45	1.4	1.4	276	236	41	64	3	
4			40.4	0.40	1.24	1.24	276	259	41	64	3	
2-1			43.0	0.42	1.3	1.3	273	242	40	65	3	
2			45.7	0.40	1.24	1.24	277	246	40	65	3	
3			48.5	0.40	1.24	1.24	275	244	38	66	3	
4			51.1	0.33	1.02	1.02	277	254	39	65	2	




Port and Traverse Point No.	Distance from Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft <sup>3</sup> )	Stack Velocity Head (H <sub>2</sub> O)	Meter Orifice Pressure Difference (H <sub>2</sub> O)		Stack Gas Temp (°F)	Sample Box Temp (°F)	Last Impinger Temp (°F)	Meter Temp (°F)	Vacuum on Sample Train ("Hg)	Oxygen Meter Reading (%O <sub>2</sub> )
					Calculated	Actual						
3-1			53.5	0.45	1.4	1.4	274	260	39	66	3	
2			56.3	0.40	1.24	1.24	275	261	39	65	3	
3			59.1	0.40	1.24	1.24	275	265	39	67	3	
4			61.7	0.36	1.11	1.11	275	262	39	66	3	
4-1			64.3	0.47	1.46	1.46	272	262	40	67	4	
2			67.2	0.47	1.46	1.46	276	256	39	66	3	
3			70.2	0.47	1.46	1.46	276	258	40	68	3	
4			73.3	0.40	1.24	1.24	275	265	40	68	3	



## Multiple Methods Data Sheet

Plant: CPZ - Brooksville  
 Sample Location: Power Plant  
 Control Type: Baghouse  
 Sample Type: Part  
 Date: 1-5-10 Run No.: 3  
 Time Start: 1541 Time End: 1652  
 Sample Time: 4x4x4 min/point 164 Total Mins.  
 Dry Bulb: °F Wet Bulb: °F VP@DP:  
 Bar. Pres: 30.12 "Hg Stack Pres: 30.06 "Hg Ps: -0.43 "H<sub>2</sub>O  
 Moisture: 6 % FDA: Gas Density Factor:  
 Temp: 45 °F Wind Direction: Var Wind Speed: 2-3  
 Weather: Clear Thermocouple Readout: KAK-7  
 Sample Box No. KAU-7 Meter Box No.: KAU-7  
 Meter Y: 0.996@ Delta H: 1.54 Pitot Corr.: 0.84  
 Nozzle Diameter: 0.266 inches Probe Length: 10.22 feet  
 Probe Heater Setting: 242 Nomograph Cf: 3.1  
 Stack Dimensions: 223.8 inches  
 Stack Area: 273.18 ft<sup>2</sup>  
 Effective Stack Area: 273.18 ft<sup>2</sup>  
 Stack Height: \_\_\_\_\_ ft



Material Processing Rate:  
 Final Gas Meter Reading: 421.265 ft<sup>3</sup>  
 Initial Gas Meter Reading: 376.201 ft<sup>3</sup>  
 Total Metered Gas Volume: 45.064 ft<sup>3</sup>  
 Condensate Gain in Impingers: 44 mL  
 Weight Gain in Silica Gel: 10 g  
 Total Moisture Gain: 54 mL  
 Silica Gel Container No.: 1  
 Filter Number: III

Leak Check - Meter Box:  
 Initial: 0.008 fm @ 10 inches Hg  
 Final: 0.006 fm @ 5 inches Hg

Leak Check - Pitot Tubes:  
 Impact 3 "H<sub>2</sub>O for 15 sec: Stable Leak  
 Static 3 "H<sub>2</sub>O for 15 sec: Stable Leak

Test Conducted By: R Paul - J Janyston  
 O<sub>2</sub>: 13.0 % CO<sub>2</sub>: 8.3 %  
 Stack Test Observers:

Umbilical: KAK-100  
 Thermocouple  
 Probe No. KAK-110  
 Pitot Tube: KA-55T

Port and Traverse Point No.	Distance from Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft <sup>3</sup> )	Stack Velocity Head (H <sub>2</sub> O)	Meter Orifice Pressure Difference (H <sub>2</sub> O)		Stack Gas Temp (°F)	Sample Box Temp (°F)	Last Impinger Temp (°F)	Meter Temp (°F)	Vacuum on Sample Train ("Hg)	Oxygen Meter Reading (%O <sub>2</sub> )
					Calculated	Actual						
1-1			76.2	0.50	1.55	1.55	279	234	47	65	3	
2			79.2	0.50	1.55	1.55	279	243	44	64	3	
3			82.1	0.48	1.49	1.49	279	241	44	65	3	
4			85.1	0.41	1.27	1.27	280	261	44	65	3	
2-1			87.8	0.45	1.4	1.4	280	265	44	66	3	
2			90.7	0.45	1.4	1.4	283	262	42	65	2	
3			93.5	0.39	1.21	1.21	281	251	42	66	2	
4			96.2	0.35	1.09	1.09	281	266	41	66	2	



Port and Traverse Point No.	Distance from Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft <sup>3</sup> )	Stack Velocity Head (H <sub>2</sub> O)	Meter Orifice Pressure Difference (H <sub>2</sub> O)		Stack Gas Temp (°F)	Sample Box Temp (°F)	Last Impinger Temp (°F)	Meter Temp (°F)	Vacuum on Sample Train ("Hg)	Oxygen Meter Reading (%O <sub>2</sub> )
					Calculated	Actual						
3-1			98.6	0.46	1.43	1.43	280	233	40	66	3	
2			401.7	0.40	1.24	1.24	283	247	40	65	3	
3			4.4	0.40	1.24	1.24	282	256	40	66	2	
4			7.2	0.37	1.15	1.15	279	242	38	66	2	
4-1			9.7	0.53	1.64	1.64	280	250	40	66	3	
2			62.8	0.42	1.3	1.3	280	263	37	66	3	
3			15.6	0.45	1.4	1.4	281	258	41	66	3	
4			18.5	0.41	1.27	1.27	282	256	41	65	3	



**SAMPLING RATE CALCULATIONS**

Plant Name: CPY - Power Plant Date: 1-5-10

Location: Brooksville Source: Main Stack

1) Calculate the optimum Cf:

$$\frac{\Delta H @}{\Delta P_{avg}} = Cf$$

DH	/DP <sub>avg</sub>	= Cf

2) Calculate the optimum nozzle size:

Record Values		
R1	R2	R3
65	68	
0.07	0.06	
28.3	28.4	
270	275	
1.54	1.54	
0.266		

0.04  
286

- Tm = Meter Temperature (°F) (Add 5 °F for initial temp.)
- Bw = Moisture Fraction
- Ms = Wet Molecular Weight of Stack Gas (from Table)
- Ts = Stack Temperature (°F)
- ΔH@ = Meter Box Constant (box front)
- ΔP = Average Pitot Reading (Inches H2O)
- Dn = Nozzle Diameter (Inches) measured

Moisture Fraction	MS
0	29
0.05	28.5
0.1	27.9
0.15	27.4
0.2	26.8
0.25	26.2
0.3	25.7
0.35	25.2
0.4	24.6

$$Dn = \left[ \frac{Cf}{\left( \frac{Tm+460}{Ms(Ts+460)} \right) * \left( 1 - \frac{Bw}{100} \right)^2 * (\Delta H @) * (1774)} \right]^{0.25}$$

1-0.55  
2-0.53  
3-0.50  
4-0.40  
TS-270

3) Calculate the correction factor Cf. Cf times the stack ΔP will determine the manometer setting ΔH:

$$Cf = \left[ \frac{Tm+460}{Ms*(Ts+460)} \right] * (1-Bw)^2 * \Delta H @ * Dn^4 * 1774 \quad Cf * \Delta P = \Delta H$$

Calculation	Run No. 1	Run No. 2	Run No. 3
Tm + 460 =	525	525	528
1/[MS*(Ts+460)] =	20659	20878	20874
* (1 - Bw) <sup>2</sup> =	0.8649	0.9216	0.8836
* ΔH@ =	1.54	1.54	1.54
* (Dn) <sup>4</sup> =	0.00501	0.00501	0.00501
* 1774 = Cf	3.0	3.17	3.1

6005



# Chain of Custody

Plant Name: CPJ

Project Number: 308-09-08

Location: Brooksville

Source: Power Plant

Sample Identification	Remarks	
1-CPJ-P	Probe Wash R-1	
2-CPJ-P	} } }	
3-CPJ-P		2
		3
I	Filter Holder R-1	
II	} } }	
III		2
		3
16	Silica Gel R-1	
14	} } }	
		2
		3
1		

Sampled by: RPaul                      1-5-10                      See data  
Signature                      Date                      Time

Relinquished by: \_\_\_\_\_  
Signature                      Date                      Time

Received by: \_\_\_\_\_  
Signature                      Date                      Time

Relinquished by: \_\_\_\_\_  
Signature                      Date                      Time

Laboratory:  
 Received by: RPaul                      1-6-10                      1500  
Signature                      Date                      Time

Sample Shipped Via:                       UPS     Federal Express                       Other

Shipping Bill Number: \_\_\_\_\_



# Particulate Lab Data Sheet

Test Date: 1-5-10  
 Plant Name: CPZ-Brooksville  
 Source: Power Plant

	Run No. 1	Run No. 2	Run No. 3	Blank
Container No.	Z	425	10	391
Total Volume (ml)	105	120	135	100
Aliquot Evaporated (ml)	105	120	135	100
Final Weight (g)	113.8773	113.2528	116.6993	112.8331
Tare Weight (g)	113.8732	113.2460	116.6939	112.8328
Gross Weight Gained (g)	0.0041	0.0068	0.0054	0.0003
Average Blank (g)	—	—	—	
Net Weight (g)	0.0041	0.0068	0.0054	
Aliquot Factor	x 1.0	x 1.0	x 1.0	x
Total Net Weight (mg)	4.1	6.8	5.4	

Container No.	1-F	2-F	3-F	BL-A
Filter No.	5331	5332	5333	5341
Final Weight (g)	0.4358	0.4349	0.4334	0.4316
Tare Weight (g)	0.4327	0.4332	0.4302	0.4316
Gross Weight Gained	0.0031	0.0017	0.0032	0.0000
Average Blank (g)	—	—	—	
Total Net Weight (mg)	3.1	1.7	3.2	

**Tare Balance Check**

0.0  10.0   
 1.0  50.0   
 5.0  100.0   
 T/H 68/38

R Paul  
 Signature

1-7-10  
 Date

**Final Balance Check**

0.0  10.0   
 1.0  50.0   
 5.0  100.0   
 T/H 67/39

R Paul  
 Signature

1-8-10  
 Date





Carbon Monoxide Emission Measurements (Jan. 5)

Calibration Calculations and Concentrations

## Analyzer Calibration Calculations Summary Method 10

Cal. Gas ppm	% of Span
201.4	39.3
512.9	100.0

Span is Equal to: 512.9  
(M7E Sec. 3.4)

*Method 7E Calibration Specifications*

Mid (Down scale) (40-60%Span); High(Upscale) (100%Span) (M7E-Sec.3.3.2+3.3.3)

EPA Protocol Gas Analyzer Calibration Data					
Analyzer Calibration Error					
Instrument Range Setting (ppmv) 0 to 1000					
Calibration Gas	Conc. (ppmv)	Run No.	Date / Time	Response Instrument Direct (ppmv)	Accuracy Diff. from Actual (% of Span)(1)
Zero	0.00	R1-Pre	1/5/2010 11:51	0.63	0.12
CO	201.4	R1-Pre	1/5/2010 12:03	197	-0.87
CO	512.9	R1-Pre	1/5/2010 11:59	508	-0.98

*Method 7E Calibration Specifications*

(1) Analyzer Calibration Error + 2% of Span (Section 12.2,Equation 7E-1)

EPA Protocol Gas Analyzer Calibration Data						
System Bias Check						
Instrument Range Setting (ppmv) 0 to 1000						
Calibration Gas	Conc. (ppmv)	Run No.	Date / Time	Response through Train System Loop (ppmv)	5% Max System Bias (% of Span)(2)	3% Max Drift(3)
Zero	0.00	R1-Pre	1/5/2010 12:20	-0.50	-0.22	
Zero	0.00	R1-Post	1/5/2010 13:54	-0.50	-0.22	0.00
CO	201.4	R1-Pre	1/5/2010 12:14	192.0	-0.96	
CO	201.4	R1-Post	1/5/2010 13:58	192.3	-0.90	0.06
Zero	0.00	R2-Pre	1/5/2010 13:54	-0.50	-0.22	
Zero	0.00	R2-Post	1/5/2010 15:30	-0.50	-0.22	0.00
CO	201.4	R2-Pre	1/5/2010 13:58	192.3	-0.90	
CO	201.4	R2-Post	1/5/2010 15:25	189.4	-1.46	0.56
Zero	0.00	R3-Pre	1/5/2010 15:30	-0.50	-0.22	
Zero	0.00	R3-Post	1/5/2010 17:00	-0.50	-0.22	0.00
CO	201.4	R3-Pre	1/5/2010 15:25	189.4	-1.46	
CO	201.4	R3-Post	1/5/2010 16:56	187.5	-1.83	0.37

*Method 7E Calibration Specifications*

(2) Section 12.3, Equation 7E-2

(3) Section 12.4, Equation 7E-4

Central Power & Lime Co.  
 Brooksville Cement and Power Plant Complex  
 Brooksville, Florida

Wood Pellet Fuel Trials (Baseline PM/CO Emission Data)

Date	Time	CO ppmv		
1/5/2010	11:45	20.3		
1/5/2010	11:46	16.8		
1/5/2010	11:47	16.3		
1/5/2010	11:48	16.8		
1/5/2010	11:49	16.3		
1/5/2010	11:50	15.8		
1/5/2010	11:51	5.3	<< Nitrogen Direct	
1/5/2010	11:52	0.8	CO	
1/5/2010	11:53	0.5	0.63	<average
1/5/2010	11:54	6.8		
1/5/2010	11:55	303.2		
1/5/2010	11:56	491.5		
1/5/2010	11:57	501.3		
1/5/2010	11:58	490.0		
1/5/2010	11:59	492.7	<< 512.9 ppmv CO Direct	
1/5/2010	12:00	509.0	CO	
1/5/2010	12:01	506.8	507.89	<average
1/5/2010	12:02	507.8		
1/5/2010	12:03	345.5	<< 201.4 ppmv CO Direct	
1/5/2010	12:04	199.0	CO	
1/5/2010	12:05	194.8	196.92	<average
1/5/2010	12:06	194.5		
1/5/2010	12:07	187.0		
1/5/2010	12:08	32.8		
1/5/2010	12:09	-0.5	<< Nitrogen Direct	
1/5/2010	12:10	-0.3	CO	
1/5/2010	12:11	-0.3	-0.25	<average
1/5/2010	12:12	59.8		
1/5/2010	12:13	136.7		
1/5/2010	12:14	208.1	<< 201.4.9 ppmv CO System	
1/5/2010	12:15	193.8	CO	
1/5/2010	12:16	192.5	193.17	<average
1/5/2010	12:17	193.3		
1/5/2010	12:18	142.2		
1/5/2010	12:19	5.3		
1/5/2010	12:20	-0.5	<< Nitrogen System	
1/5/2010	12:21	-0.5	CO	
1/5/2010	12:22	-0.5	-0.50	<average
1/5/2010	12:23	34.3		
1/5/2010	12:25	102.4	<< START RUN #1	
1/5/2010	12:26	111.9		
1/5/2010	12:27	114.4		
1/5/2010	12:28	120.2		
1/5/2010	12:29	164.2		
1/5/2010	12:30	192.5		
1/5/2010	12:31	144.5		
1/5/2010	12:32	162.5		
1/5/2010	12:33	228.3		
1/5/2010	12:34	179.0		
1/5/2010	12:35	151.7		
1/5/2010	12:36	143.2		
1/5/2010	12:37	140.7		
1/5/2010	12:38	160.2		
1/5/2010	12:39	154.0		
1/5/2010	12:40	160.0		
1/5/2010	12:41	269.7		
1/5/2010	12:42	291.2		
1/5/2010	12:43	198.5		
1/5/2010	12:44	129.7		
1/5/2010	12:45	206.3		
1/5/2010	12:46	263.1		
1/5/2010	12:47	217.6		
1/5/2010	12:48	178.3		
1/5/2010	12:49	227.6		
1/5/2010	12:50	204.6		
1/5/2010	12:51	203.1		
1/5/2010	12:52	192.3		
1/5/2010	12:53	207.8		

1/5/2010 12:54 201.3  
 1/5/2010 12:55 227.1  
 1/5/2010 12:56 202.1  
 1/5/2010 12:57 197.5  
 1/5/2010 12:58 229.6  
 1/5/2010 12:59 235.1  
 1/5/2010 13:00 274.2  
 1/5/2010 13:01 282.4  
 1/5/2010 13:02 205.6  
 1/5/2010 13:03 198.3  
 1/5/2010 13:04 246.1  
 1/5/2010 13:05 189.0  
 1/5/2010 13:06 264.1  
 1/5/2010 13:07 270.4  
 1/5/2010 13:08 230.6  
 1/5/2010 13:09 303.0  
 1/5/2010 13:10 245.9  
 1/5/2010 13:11 279.4  
 1/5/2010 13:12 233.1  
 1/5/2010 13:13 196.5  
 1/5/2010 13:14 244.1  
 1/5/2010 13:15 270.7  
 1/5/2010 13:16 235.9  
 1/5/2010 13:17 202.6  
 1/5/2010 13:18 227.8  
 1/5/2010 13:19 245.1  
 1/5/2010 13:20 223.8  
 1/5/2010 13:21 255.1  
 1/5/2010 13:22 243.9  
 1/5/2010 13:23 244.6  
 1/5/2010 13:24 226.6  
 1/5/2010 13:25 212.6  
 1/5/2010 13:26 189.0  
 1/5/2010 13:27 211.8  
 1/5/2010 13:28 197.5  
 1/5/2010 13:29 214.6  
 1/5/2010 13:30 188.0  
 1/5/2010 13:31 162.5  
 1/5/2010 13:32 176.0  
 1/5/2010 13:33 197.3  
 1/5/2010 13:34 168.5  
 1/5/2010 13:35 156.7  
 1/5/2010 13:36 184.0  
 1/5/2010 13:37 173.5  
 1/5/2010 13:38 175.0  
 1/5/2010 13:39 164.0  
 1/5/2010 13:40 149.2  
 1/5/2010 13:41 197.3  
 1/5/2010 13:42 187.3  
 1/5/2010 13:43 161.7  
 1/5/2010 13:44 159.2  
 1/5/2010 13:45 153.7  
 1/5/2010 13:46 167.8  
 1/5/2010 13:47 148.2  
 1/5/2010 13:48 154.2  
 1/5/2010 13:49 162.7  
 1/5/2010 13:50 164.5  
 1/5/2010 13:51 118.2  
 1/5/2010 13:52 115.7  
 1/5/2010 13:53 58.3  
 1/5/2010 13:54 0.0  
 1/5/2010 13:55 -0.5  
 1/5/2010 13:56 -0.5  
 1/5/2010 13:57 63.3  
 1/5/2010 13:58 183.0  
 1/5/2010 13:59 192.5  
 1/5/2010 14:00 192.0  
 1/5/2010 14:01 191.0  
 1/5/2010 14:02 193.0

<< END RUN #1

<< Nitrogen System			
		CO	
		-0.50	<average

<< 201.4.9 ppmv CO System			
		CO	
		192.29	<average

RUN (1)	ANALYZER RESPONSE TO STACK GAS ppmv	ZERO BIAS ppmv	ACTUAL CAL. GAS VALUE ppmv	ANALYZER RESPONSE TO CAL. GAS ppmv	CORRECTED STACK GAS CONC. ppmv
CO	201.2	-0.50	201.4	192.73	210.2

Central Power & Lime Co.  
Brooksville Cement and Power Plant Complex  
Brooksville, Florida

Wood Pellet Fuel Trials (Baseline PM/CO Emission Data)

Date	Time	CO ppmv
1/5/2010	14:10	262.1
1/5/2010	14:11	237.4
1/5/2010	14:12	246.6
1/5/2010	14:13	237.4
1/5/2010	14:14	254.1
1/5/2010	14:15	248.1
1/5/2010	14:16	253.4
1/5/2010	14:17	221.1
1/5/2010	14:18	202.6
1/5/2010	14:19	283.9
1/5/2010	14:20	304.0
1/5/2010	14:21	285.4
1/5/2010	14:22	236.9
1/5/2010	14:23	211.1
1/5/2010	14:24	182.0
1/5/2010	14:25	176.8
1/5/2010	14:26	160.0
1/5/2010	14:27	151.7
1/5/2010	14:28	161.5
1/5/2010	14:29	173.0
1/5/2010	14:30	190.5
1/5/2010	14:31	178.0
1/5/2010	14:32	223.6
1/5/2010	14:33	257.6
1/5/2010	14:34	218.6
1/5/2010	14:35	153.0
1/5/2010	14:36	135.0
1/5/2010	14:37	128.7
1/5/2010	14:38	188.5
1/5/2010	14:39	156.7
1/5/2010	14:40	111.4
1/5/2010	14:41	146.5
1/5/2010	14:42	132.4
1/5/2010	14:43	134.0
1/5/2010	14:44	163.2
1/5/2010	14:45	237.4
1/5/2010	14:46	252.4
1/5/2010	14:47	145.0
1/5/2010	14:48	136.2
1/5/2010	14:49	149.5
1/5/2010	14:50	159.7
1/5/2010	14:51	227.6
1/5/2010	14:52	259.6
1/5/2010	14:53	175.8

<< START RUN #2

1/5/2010 14:54 131.7  
 1/5/2010 14:55 159.2  
 1/5/2010 14:56 157.7  
 1/5/2010 14:57 161.0  
 1/5/2010 14:58 180.0  
 1/5/2010 14:59 235.1  
 1/5/2010 15:00 262.9  
 1/5/2010 15:01 246.1  
 1/5/2010 15:02 287.9  
 1/5/2010 15:03 409.6  
 1/5/2010 15:04 324.2  
 1/5/2010 15:05 218.6  
 1/5/2010 15:06 196.3  
 1/5/2010 15:07 188.8  
 1/5/2010 15:08 220.8  
 1/5/2010 15:09 177.8  
 1/5/2010 15:10 185.5  
 1/5/2010 15:11 216.8  
 1/5/2010 15:12 295.2  
 1/5/2010 15:13 316.0  
 1/5/2010 15:14 216.6  
 1/5/2010 15:15 215.6  
 1/5/2010 15:16 322.7  
 1/5/2010 15:17 259.4  
 1/5/2010 15:18 220.3  
 1/5/2010 15:19 227.1  
 1/5/2010 15:20 255.6  
 1/5/2010 15:21 285.4  
 1/5/2010 15:22 332.5  
 1/5/2010 15:23 230.6  
 1/5/2010 15:24 268.2  
 1/5/2010 15:25 210.6  
 1/5/2010 15:26 190.0  
 1/5/2010 15:27 188.8  
 1/5/2010 15:28 188.5  
 1/5/2010 15:29 129.4  
 1/5/2010 15:30 2.8  
 1/5/2010 15:31 -0.5  
 1/5/2010 15:32 -0.5

<< END RUN #2

<< 201.4.9 ppmv CO System		
	CO	
	189.41	<average

<< Nitrogen System		
	CO	
	-0.50	<average

RUN (2)	ANALYZER RESPONSE TO STACK GAS ppmv	ZERO BIAS ppmv	ACTUAL CAL. GAS VALUE ppmv	ANALYZER RESPONSE TO CAL. GAS ppmv	CORRECTED STACK GAS CONC. ppmv
CO	213.7	-0.50	201.4	190.85	225.5

Central Power & Lime Co.  
Brooksville Cement and Power Plant Complex  
Brooksville, Florida

Wood Pellet Fuel Trials (Baseline PM/CO Emission Data)

Date Time	CO ppmv
1/5/2010 15:40	362.8
1/5/2010 15:41	316.2
1/5/2010 15:42	270.7
1/5/2010 15:43	376.1
1/5/2010 15:44	456.9
1/5/2010 15:45	374.3
1/5/2010 15:46	487.0
1/5/2010 15:47	511.0
1/5/2010 15:48	628.9
1/5/2010 15:49	429.4
1/5/2010 15:50	434.9
1/5/2010 15:51	318.2
1/5/2010 15:52	423.1
1/5/2010 15:53	514.8
1/5/2010 15:54	453.9
1/5/2010 15:55	342.5
1/5/2010 15:56	304.2
1/5/2010 15:57	354.0
1/5/2010 15:58	389.3
1/5/2010 15:59	521.0
1/5/2010 16:00	419.6
1/5/2010 16:01	321.5
1/5/2010 16:02	352.8
1/5/2010 16:03	346.5
1/5/2010 16:04	379.8
1/5/2010 16:05	382.1
1/5/2010 16:06	362.5
1/5/2010 16:07	284.9
1/5/2010 16:08	282.4
1/5/2010 16:09	285.4
1/5/2010 16:10	306.2
1/5/2010 16:11	338.3
1/5/2010 16:12	344.3
1/5/2010 16:13	296.4
1/5/2010 16:14	349.5
1/5/2010 16:15	344.8
1/5/2010 16:16	303.5
1/5/2010 16:17	320.5
1/5/2010 16:18	338.3
1/5/2010 16:19	338.5
1/5/2010 16:20	328.2
1/5/2010 16:21	277.2
1/5/2010 16:22	210.6
1/5/2010 16:23	244.6

<< START RUN #3

1/5/2010 16:24 288.2  
 1/5/2010 16:25 274.9  
 1/5/2010 16:26 309.5  
 1/5/2010 16:27 236.6  
 1/5/2010 16:28 365.8  
 1/5/2010 16:29 318.0  
 1/5/2010 16:30 349.5  
 1/5/2010 16:31 282.9  
 1/5/2010 16:32 262.1  
 1/5/2010 16:33 244.9  
 1/5/2010 16:34 254.4  
 1/5/2010 16:35 245.4  
 1/5/2010 16:36 269.2  
 1/5/2010 16:37 239.9  
 1/5/2010 16:38 283.9  
 1/5/2010 16:39 235.4  
 1/5/2010 16:40 234.9  
 1/5/2010 16:41 185.3  
 1/5/2010 16:42 182.3  
 1/5/2010 16:43 195.8  
 1/5/2010 16:44 285.4  
 1/5/2010 16:45 242.1  
 1/5/2010 16:46 248.4  
 1/5/2010 16:47 236.9  
 1/5/2010 16:48 206.3  
 1/5/2010 16:49 178.3  
 1/5/2010 16:50 173.0  
 1/5/2010 16:51 185.8  
 1/5/2010 16:52 152.0  
 1/5/2010 16:53 157.0  
 1/5/2010 16:54 164.0  
 1/5/2010 16:55 182.5  
 1/5/2010 16:56 187.0  
 1/5/2010 16:57 187.0  
 1/5/2010 16:58 188.0  
 1/5/2010 16:59 129.9  
 1/5/2010 17:00 2.5  
 1/5/2010 17:01 -0.5  
 1/5/2010 17:02 -0.5

<< END RUN #3
---------------

<< 201.4.9 ppmv CO System
---------------------------

187.0	CO	
188.0	187.53	<average

<< Nitrogen System
--------------------

-0.5	CO	
-0.5	-0.50	<average

RUN (3)	ANALYZER RESPONSE TO STACK GAS ppmv	ZERO BIAS ppmv	ACTUAL CAL. GAS VALUE ppmv	ANALYZER RESPONSE TO CAL. GAS ppmv	CORRECTED STACK GAS CONC. ppmv
CO	317.1	-0.50	201.4	188.47	338.5



Carbon Monoxide Emission Measurements (Jan. 5)

Field Data Sheets

BF: 30.12

U = 20.04ppm  
Fscale = SM12.755

KOGLER AND ASSOCIATES, INC.  
INSTRUMENTAL GAS SAMPLING FIELD DATA RECORD

PLANT <i>CEMEX/CPL</i>				DATE <i>01-05-10</i>			
LOCATION <i>Bradenville FL</i>				EMISSION UNIT <i>Kiln#1 Power Plant</i>			
TEST(s) <i>CO, Pm</i>				SYSTEM LEAK CHECK (Limit 1 inHg/2min)			
				Init. VAC inHg <i>1.5</i>		Final VAC inHg	
INSTRUMENT RANGE (R) (0-XXX)				Calibration Gas Certified Concentration Value			
Instrument	Available R	Selected R	Teloger Vdc	Test	mid-gas	mid-gas	high-gas(span)
NOx (M7E)				NOx (M7E)			
SO2 (M6C)				SO2 (M6C)			
CO (M10)				CO (M10)	<i>Zero Air</i>	<i>201.4</i>	<i>512.9</i>
THC (M25A)				THC (M25A)			
NMHC				NMHC			
TIME	Action Comment			TIME	Action Comment		
<i>11:42</i>	<i>Zero Air on</i>			<i>15:32</i>	<i>Zero Air off / Stack Gas</i>		
<i>11:54</i>	<i>Zero Air off / 512.9 on</i>			<i>15:41</i>	<i>Start Run #3</i>		
<i>12:00</i>	<i>512.9 CO = 510.015</i>			<i>16:52</i>	<i>END Run #3</i>		
<i>12:02</i>	<i>512.9 CO off / 201.4 CO on</i>			<i>16:52</i>	<i>Zero 201.4 CO ON</i>		
<i>12:05</i>	<i>201.4 CO = 194.7</i>			<i>16:56</i>	<i>201.4 CO = 196.78</i>		
<i>12:07</i>	<i>201.4 CO off / Zero on</i>			<i>16:58</i>	<i>201.4 CO off / Zero Air on</i>		
<i>12:09</i>	<i>Zero = -0.5</i>			<i>17:00</i>	<i>Zero Air = 7.5</i>		
<i>12:11</i>	<i>Zero off</i>			<i>17:02</i>	<i>Zero Air off</i>		
<i>12:13</i>	<i>201.4 CO on</i>						
<i>12:15</i>	<i>201.4 CO = 194</i>						
<i>12:17</i>	<i>201.4 CO off / Zero Air on</i>						
<i>12:20</i>	<i>Zero Air = -0.5</i>						
<i>12:22</i>	<i>Zero Air off / Stack Gas</i>						
<i>12:25</i>	<i>Start Run 1 Pm / CO Run</i>						
<i>13:46</i>	<i><del>Start CO Run</del> END Pm Run #1</i>						
	<i>Start Pm Run #2</i>						
	<i>END CO Run #1</i>						
<i>13:52</i>	<i>Zero Air on</i>						
<i>13:54</i>	<i>Zero Air = 5.2</i>						
<i>13:56</i>	<i>Zero Air off / 201.4 CO on</i>						
<i>13:59</i>	<i>201.4 CO = 192.78</i>						
<i>14:01</i>	<i>201.4 CO off / Stack Gas</i>						
<i>14:12</i>	<i>Start Run #2</i>						
<i>15:23</i>	<i>END Run #2</i>						
<i>15:24</i>	<i>204.1 CO on</i>						
<i>15:26</i>	<i>204.1 CO = 196.5</i>						
<i>15:28</i>	<i>204.1 CO off / Zero Air on</i>						
<i>15:30</i>	<i>Zero Air = 1.002</i>						

Run #1 O<sub>2</sub> = 13.0 Pm CO<sub>2</sub> = 9.0  
Run #2 O<sub>2</sub> = 12.0 Pm CO<sub>2</sub> = 9.0  
Run #3 Pm O<sub>2</sub> = 13.0 CO<sub>2</sub> = 8.5

Start 11:49  
Loop

Particulate Matter Emission Measurements (Jan. 22)

Calculations

SUMMARY OF PARTICULATE MATTER EMISSION TEST DATA

CENTRAL POWER AND LIME, INC. Brooksville					
EU 018: POWER PLANT (23 % Wood Fuel)					
JANUARY 22, 2010					
Run No.	Stack Gas Flow Rate (SCFMD)	Stack Gas Temperature (F)	Stack Gas Moisture (%)	Particulate Matter	
				Conc. (gr/dscf)	Emission Rate (Lbs/Hr)
1	426,062	306	7.6	0.0028	10.39

GENERAL DATA

Plant : CENTRAL BROOKSVILLE, FL  
 Source/Unit : EU 018: POWER PLANT (23 % Wood Fuel)  
 Date : JANUARY 22, 2010 Cp : 0.840  
 Stack dia. : 223.80 inch OR : Duct Length : 0.00 inch  
 Oxygen Corr.: 0.0 percent Duct Width : 0.00 inch  
 CO2 Corr. : 0.0 percent Std. Temp. : 68 F

FUEL ANALYSIS DATA, (By F Factor or Fuel Use)

F Factor = F, Fuel Use = U £ Process Wt.

Hydrogen, wt% : 0.00 Run 1 : 0 Tons/hr  
 Carbon, wt% : 0.00 Run 2 : 0  
 Sulfur, wt% : 0.00 Run 3 : 0  
 Nitrogen, wt% : 0.00  
 Oxygen, wt% : 0.00  
 Btu/lb : 0

Type of Flow Meter : (1=Meter Box 2=Mass Flow Meter) 1

F-Factor : dscf/MMBtu;

<u>FIELD DATA</u>	METHOD 5	RUN	RUN	RUN
		1	2	3
Meter Temp., Tm (F) .....		73	0	0
Stack Temp., Ts (F) .....		306	0	0
Sq.Rt. dP .....		0.61	0.00	0.00
dH (in. H2O) .....		2.11	0.00	0.00
Meter Vol., Vm (ft3) .....		53.438	0.000	0.000
Vol. H2O, Vlc (ml) .....		93.0	0.0	0.0
Meter Y .....		1.004	1.004	1.004
Bar. Press., Pb (in. Hg.) .....		29.78	29.78	29.78
Static Press., Ps (in. H2O) .....		-0.59	-0.59	-0.59
Test Time (min.) .....		64.0	64.0	64.0
Nozzle Dia., Dn (in.) .....		0.306	0.306	0.306
Oxygen, O2 (%) .....		19.0	0.0	0.0
Carbon Dioxide, CO2 (%) .....		10.0	0.0	0.0
Carbon Monoxide, CO (%) .....		0.0	0.0	0.0
Report Emission Criteria in ? I = lb/hr g = gr/dscf :				grains
Process Rate Units ? T = Ton/hr, L = Lbs/hr, C = Cans/min:				T
Allowable Particulate Matter Concentration .....				0

<u>LABORATORY RESULTS</u>	RUN	RUN	RUN
	1	2	3
	grams	grams	grams
GRAVIMETRIC ANALYSIS METHOD 5 :			
Front Half Wash (FHW) .....	0.00670	0.00000	0.00000
Filterable Sample (MF) .....	0.00310	0.00000	0.00000
Condensable Sample (BHW) .....	0.00000	0.00000	0.00000

## A. FIELD DATA SUMMARY

---

Plant: CENTRAL POWER AND LIME, INC. Brooksville  
Source/Unit: EU 018: POWER PLANT (23 % Wood Fuel)  
Date: JANUARY 22, 2010

	RUN
	1
Vlc = Vol water collected in train, ml	93.0
Vm = Sample gas vol, meter cond., acf	53.438
Y = Meter calibration factor	1.0040
Pbar = Barometric pressure, in. Hg	29.78
Pstatic = Stack static pressure, in. H2O	-0.59
dH = Avg meter pressure diff, in. H2O	2.11
Tm = Absolute meter temp., degrees R	533.3
Vm(std) = Sample gas vol, Std. cond., dscf	53.145
Bws = Water vapor in gas stream, fraction	0.076
MF = Moisture factor ( 1 - Bws)	0.924
CO2 = Carbon Dioxide, dry, volume %	10.00
O2 = Oxygen, dry, volume %	19.00
N2 = Nitrogen, dry volume %	71.00
Md = Molecular weight of stack gas, dry	30.36
Ms = Molecular weight of stack gas, wet	29.42
Cp = Pitot tube coefficient	0.84
Sq.Rt. dP = Avg. square root of each dP	0.6113
Ts = Absolute stack temp., degrees R	766.3
A = Area of stack, ft2	273.18
Qstd = Volumetric flowrate, dscfm	426,062
An = Nozzle area, ft2	5.11E-04
0 = Sample time, minutes	64.00
%I = Isokinetic variation, percent	104.26

B. PARTICULATE DATA SUMMARY

---

Plant: CENTRAL POWER AND LIME, INC. Brooksville  
Source/Unit: EU 018: POWER PLANT (23 % Wood Fuel)  
Date: JANUARY 22, 2010

	RUN
	1
Sample Weight (FHW + MF + BHW), mg .....	9.80
Meter Volume, standard cond., Vm(std) .....	53.145
Carbon Dioxide, percent .....	10.00
Oxygen, percent .....	19.00
Sample Concentration :	
gr/scf .....	0.0026
gr/dscf .....	0.0028
gr/dscf @ 0 % CO2 .....	0.0034
gr/dscf @ 0 % O2 .....	0.0313
ppm * MW (dry gas).....	156.5
ppm * MW @ 0% CO2 .....	0.0
ppm * MW @ 0% O2 .....	1721.7

**EMISSION RATE CALCULATIONS**

Plant : CENTRAL POWER AND LIME, INC. Brooksville  
 Source/Unit : EU 018: POWER PLANT (23 % Wood Fuel)  
 Date: JANUARY 22, 2010 RUN N 1  
 STANDARD TEMP. : 68 F

Front Half Wash (FHW)	0.00670 grams	Vm(st	53.145 ft3
Mass Filter (MF)	0.00310 grams	Vw(st	4.378 ft3
Back Half Wash (BHW)	0.00000 grams	Qs(st	426,062 dscfm
Vm(std) SO2	dscf	Bws	0.076
CO2 CORF 0.0 %		CO2	10.00 %
O2 CORR. 0.0 %		O2	19.00 %

F-FACTOR

$10E6 \times [3.64(\%H) + 1.53(\%C) + 0.57(\%S) + 0.14(\%N) - 0.46(\%O2)] / (Btu/lb) \times [(Tstd + 460)/528]$  ..... dscf/MMBtu  
 FUEL USE

Use Rate (gal/ton) \* Process Wt. (ton/hr) ..... gal/hr  
 Heat Input = (Process Weight (ton/hr) x Heating Value (Btu/gal) x Fuel Use Rate (gal/ton) / 1E6 .... MMBtu/hr  
TOTAL PARTICULATE

$15.432 \times (FHW + MF + BHW) / [(Vm(std) + Vw(std)]$  ... 0.0026 gr/scf  
 $15.432 \times (FHW + MF + BHW) / (Vm(std)$  ..... 0.0028 gr/dscf  
 gr/dscf x (12 / %CO2) ..... 0.0034 @ 0% CO2  
 gr/dscf x [(20.9 - Oxygen corr.) / (20.9 - %O2)] ..... 0.0313 @ 0% O2  
 0.00857 x Qs(std) x gr/dscf ..... 10.39 lb/hr  
 F-Fac x  $1.4286E-4 \times [20.9 / (20.9 - \%O2)] \times$  gr/dscf .. lb/MMBtu  
 Particulate (lb/hr) / Heat Input (MMBtu/hr) ..... lb/MMBtu

TOTAL ACID MIST

$[1.0811E-4 \times (Vt - Vtb) \times N \times Vsol] / Vol(aloq)$  . lb Acid Mist  
 [Acid Mist (lb) / Vm std (ft^3)] x Qs std x 60 ... lb/hr  
 [Acid Mist (lb) / Vm std (ft^3)] x F-Factor ..... lb/MMBtu  
SULFUR DIOXIDE (SO2)

$[7.061E-5 \times (Vt - Vtb) \times N \times Vsol] / Vol(aloq)$  lb SO2  
 [SO2 (lb) / Vm std (ft^3)] x Qs std (ft^3/min) x 60 ... lb/hr  
 [SO2 (lb) / Vm std (ft^3)] x F ..... lb/MMBtu  
 [ Mass SO2 (lb) x 385 / 64E+6 (ft^3/lb)] / Vm (std) ppm  
 ppm x 0.0 % Corr. / 10.0 % CO2 in Stack ..... ppm @ 0% CO2  
 ppm x (20.9% - 0.0% O2 Corr)/(20.9% - 19.0% O2 Stack) ppm @ 0% O2  
 SO2 (lb/hr / Heat Input) ..... lb/MMBtu

HYDROGEN CHLORIDE DATA SUMMARY

[Mass HCl(mg) x 385 x 1E6] / [453600 x 36.5 x Vm(std)].. ppm  
 ppm x 0.0 % Corr. / 10.0 % CO2 in Stack ..... ppm @ 0% CO2  
 ppm x (20.9% - 0.0% O2 Corr)/(20.9% - 10.0% O2 Stack) ppm @ 0% O2  
 [ Mass HCl(mg) x 60 x Qs / ( Vm(std) x 453,600 )]..... lb/hr



**EMISSION RATE CALCULATIONS**

Plant : CENTRAL POWER AND LIME, INC. Brooksville  
 Source/Unit : EU 018: POWER PLANT (23 % Wood Fuel)  
 Date: JANUARY 22, 2010 RUN N 2  
 STANDARD TEMP. : 68 F

Front Half Wash (FHW)	0.00000	grams	Vm(st	ft3
Mass Filter (MF)	0.00000	grams	Vw(st	ft3
Back Half Wash (BHW)	0.00000	grams	Qs(st	dscfm
Vm(std) SO2		dscf	Bws	
CO2 CORF	0.0 %		CO2	%
O2 CORR.	0.0 %		O2	%

F-FACTOR

$10E6 \times [3.64(\%H) + 1.53(\%C) + 0.57(\%S) + 0.14(\%N) - 0.46(\%O2)] / (Btu/lb) \times [(Tstd + 460)/528]$  ..... dscf/MMBtu

FUEL USE

-  
 Use Rate (gal/ton) \* Process Wt. (ton/hr) ..... gal/hr  
 Heat Input = (Process Weight (ton/hr) x Heating .... MMBtu/hr  
 Value (Btu/gal) x Fuel Use Rate (gal/ton) / 1E6

TOTAL PARTICULATE

$15.432 \times (FHW + MF + BHW) / [(Vm(std) + Vw(std))]$  ... gr/scf  
 $15.432 \times (FHW + MF + BHW) / (Vm(std))$  ..... gr/dscf  
 gr/dscf x (12 / %CO2) ..... @ 0% CO2  
 gr/dscf x [(20.9 - Oxygen corr.) / (20.9 - %O2)] ..... @ 0% O2  
 0.00857 x Qs(std) x gr/dscf ..... lb/hr  
 F-Fac x  $1.4286E-4 \times [20.9 / (20.9 - \%O2)] \times$  gr/dscf .. lb/MMBtu  
 Particulate (lb/hr) / Heat Input (MMBtu/hr) ..... lb/MMBtu

TOTAL ACID MIST

$[1.0811E-4 \times (Vt - Vtb) \times N \times Vsol] / Vol(aloq)$  . lb Acid Mist  
 [Acid Mist (lb) / Vm std (ft^3)] x Qs std x 60 ... lb/hr  
 [Acid Mist (lb) / Vm std (ft^3)] x F-Factor ..... lb/MMBtu

SULFUR DIOXIDE (SO2)

$[7.061E-5 \times (Vt - Vtb) \times N \times Vsol] / Vol(aloq)$  . lb SO2  
 [SO2 (lb) / Vm std (ft^3)] x Qs std (ft^3/min) x 60 ... lb/hr  
 [SO2 (lb) / Vm std (ft^3)] x F ..... lb/MMBtu  
 [Mass SO2 (lb) x 385 / 64E+6 (ft^3/lb)] / Vm (std) ppm  
 ppm x 0.0 % Corr. / 10.0 % CO2 in Stack ..... ppm @ 0% CO2  
 ppm x (20.9% - 0.0% O2 Corr)/(20.9% - 10.0% O2 Stack) ppm @ 0% O2  
 SO2 (lb/hr / Heat Input) ..... lb/MMBtu

HYDROGEN CHLORIDE DATA SUMMARY

[Mass HCl(mg) x 385 x 1E6] / [453600 x 36.5 x Vm(std)].. ppm  
 ppm x 0.0 % Corr. / 0.0 % CO2 in Stack ..... ppm @ 0% CO2  
 ppm x (20.9% - 0.0% O2 Corr)/(20.9% - 0.0% O2 Stack) ppm @ 0% O2  
 [Mass HCl(mg) x 60 x Qs / (Vm(std) x 453,600)]..... lb/hr

**EMISSION RATE CALCULATIONS**

Plant : CENTRAL POWER AND LIME, INC. Brooksville  
 Source/Unit : EU 018: POWER PLANT (23 % Wood Fuel)  
 Date: JANUARY 22, 2010 RUN N 3  
 STANDARD TEMP. : 68 F

Front Half Wash (FHW)	0.00000 grams	Vm(st	ft3
Mass Filter (MF)	0.00000 grams	Vw(st	ft3
Back Half Wash (BHW)	0.00000 grams	Qs(st	dscfm
Vm(std) SO2	dscf	Bws	
CO2 CORF 0.0 %		CO2	%
O2 CORR. 0.0 %		O2	%

**F-FACTOR**

$10E6 \times [3.64(\%H) + 1.53(\%C) + 0.57(\%S) + 0.14(\%N) - 0.46(\%O2)] / (Btu/lb) \times [(Tstd + 460)/528]$  ..... dscf/MMBtu  
 FUEL USE

Use Rate (gal/ton) \* Process Wt. (ton/hr) ..... gal/hr  
 Heat Input = (Process Weight (ton/hr) x Heating .... MMBtu/hr  
 Value (Btu/gal) x Fuel Use Rate (gal/ton) / 1E6  
**TOTAL PARTICULATE**

$15.432 \times (FHW + MF + BHW) / [(Vm(std) + Vw(std))]$  ... gr/scf  
 $15.432 \times (FHW + MF + BHW) / (Vm(std))$  ..... gr/dscf  
 gr/dscf x (12 / %CO2) ..... @ 0% CO2  
 gr/dscf x [(20.9 - Oxygen corr.) / (20.9 - %O2)] ..... @ 0% O2  
 0.00857 x Qs(std) x gr/dscf ..... lb/hr  
 F-Fac x  $1.4286E-4 \times [20.9 / (20.9 - \%O2)] \times$  gr/dscf .. lb/MMBtu  
 Particulate (lb/hr) / Heat Input (MMBtu/hr) ..... lb/MMBtu  
**TOTAL ACID MIST**

$[1.0811E-4 \times (Vt - Vtb) \times N \times Vsol] / Vol(aloq)$  . lb Acid Mist  
 [Acid Mist (lb) / Vm std (ft^3)] x Qs std x 60 ... lb/hr  
 [Acid Mist (lb) / Vm std (ft^3)] x F-Factor ..... lb/MMBtu  
**SULFUR DIOXIDE (SO2)**

$[7.061E-5 \times (Vt - Vtb) \times N \times Vsol] / Vol(aloq)$  . lb SO2  
 [SO2 (lb) / Vm std (ft^3)] x Qs std (ft^3/min) x 60 ... lb/hr  
 [SO2 (lb) / Vm std (ft^3)] x F ..... lb/MMBtu  
 [ Mass SO2 (lb) x 385 / 64E+6 (ft^3/lb)] / Vm (std) ppm  
 ppm x 0.0 % Corr. / 10.0 % CO2 in Stack ..... ppm @ 0% CO2  
 ppm x (20.9% - 0.0% O2 Corr)/(20.9% - 10.0% O2 Stack) ppm @ 0% O2  
 SO2 (lb/hr / Heat Input) ..... lb/MMBtu

**HYDROGEN CHLORIDE DATA SUMMARY**

[Mass HCl(mg) x 385 x 1E6] / [453600 x 36.5 x Vm(std)].. ppm  
 ppm x 0.0 % Corr. / 0.0 % CO2 in Stack ..... ppm @ 0% CO2  
 ppm x (20.9% - 0.0% O2 Corr)/(20.9% - 0.0% O2 Stack) ppm @ 0% O2  
 [ Mass HCl(mg) x 60 x Qs / ( Vm(std) x 453,600 )]..... lb/hr

SOURCE TEST CALCULATIONS

Plant : CENTRAL POWER AND LIME, INC. Brooksville  
 Source/Unit : EU 018: POWER PLANT (23 % Wood Fuel)  
 Date: JANUARY 22, 2010

RUN NO.: 1

STD. TEMP, Tstd =	68 F	STATIC PRESS., Ps =	-0.59 in. H2O
METER TEMP, Tm =	73.3125 F	PITOT COFF., Cp =	0.840
STACK TEMP, Ts =	306.3 F	STACK I.D. =	223.80 inch
AVG. VEL. HEAD, dP =	0.374 in. H2O	DUCT LENGTH =	inch
METER ORIFICE, dH =	2.11 in. H2O	DUCT WIDTH =	inch
METER VOL., Vm =	53.438 Cu.Ft.	STACK AREA, As =	273.179 Sq.Ft.
METER COFF., Y =	1.004	TEST TIME =	64.00 min.
BAR. PRESS., Pb =	29.78 in. Hg	NOZZLE DIA. =	0.306 inch
COND.(Vlc) =	93.0 ml	NOZZLE DIA., An =	5.1E-04 Sq.Ft.
GAS ANALYSIS =	19.00 % O2	0.00 % CO	
	10.00 % CO2	71.00 % N2	

$$Vm(std) = [ ( T(std) + 460 ) / 29.92 ] \times Vm \times Y \times (Pb + (dH / 13.6)) / (Tm + 460) \dots = 53.145 \text{ dscf}$$

$$Vw(std) = (8.9148 \times 10e-5) \times (Tstd + 460) \times Vlc = 4.378 \text{ scf}$$

$$Bws = Vw(std) / (Vm(std) + Vw(std)) \dots = 0.076 \text{ | Lower Bws value used.}$$

$$Bws @ \text{ Saturated Conditions} = \text{Vapor Press. of H2O @ Dew Point Temp. / (Ps, in. Hg.)} \dots = 1.000$$

$$\%EA = (\%O2 - 0.5\%CO) / (0.264\%N2 - (\%O2 - 0.5\%CO)) \times 100 = -7421.87$$

$$Md = (.44 \times \%CO2) + (.32 \times \%O2) + [.28 \times (\%N2 + \%CO)] = 30.36$$

$$Ms = (Md \times (1 - Bws)) + (18.0 \times Bws) \dots = 29.42$$

$$P(stack) = Pbar + (Ps / 13.6) \dots = 29.74 \text{ in. Hg}$$

$$vs = 85.49 \times CP \times (Sq.Rt.dP) \times [Sq.Rt.(Ts + 460) / (Ms \times P(stack))] \dots = 41.09 \text{ ft/sec}$$

$$Qs = vs \times As \times 60 \dots = 673,428 \text{ acf/min}$$

$$Qs(std) = Qs \times (1 - Bws) \times ((Tstd + 460) / (Ts + 460)) \times (P(stack) / 29.92) \dots = 426,062 \text{ dscf/min}$$

$$I = (Ts + 460) \times [(0.002669 \times Vlc) + (Vm(std) / (T(std) + 460) / 29.92) \times 100 / [Time \times P(stack) \times An \times vs \times 60]] \dots = 104.26 \%$$

Particulate Matter Emission Measurements (Jan. 22)

Field and Analytical Data Sheets

# Multiple Methods Data Sheet

Plant: CPL

Sample Location: Rilm

Control Type: B.H

Sample Type: PM Method 5

Date: 1/22/10 Run No.: 1

Time Start: 16:30 Time End: 17:39

Sample Time: 64 min @ 4 min min/point 4 Total Mins. 64

Dry Bulb: 9 °F Wet Bulb: 9 °F VP@DP: 9 °F

Bar. Pres: 29.78 "Hg Stack Pres: - "Hg Ps: -0.59 "H<sub>2</sub>O

Moisture: 9 % FDA: 9 Gas Density Factor: 9

Temp: 70 °F Wind Direction: NW Wind Speed: 10+

Weather: P.C. Thermocouple Readout: KA-8

Sample Box No.: KA-8 Meter Box No.: KA-8

Meter Y: 1.024 @ Delta H: 1.73 Pitot Corr.: .84

Nozzle Diameter: 306 inches Probe Length: 10 S.S. feet

Probe Heater Setting: 250 Nomograph Cf: 5.56

Stack Dimensions: \_\_\_\_\_ inches

Stack Area: \_\_\_\_\_ ft<sup>2</sup>

Effective Stack Area: \_\_\_\_\_ ft<sup>2</sup>

Stack Height: \_\_\_\_\_ ft

38% wood pellets

CPE @ 7:55  
S61 CPE @ 7:50

Material Processing Rate:

Final Gas Meter Reading: 372.735 ft<sup>3</sup>

Initial Gas Meter Reading: 319.297 ft<sup>3</sup>

Total Metered Gas Volume: 53.438 ft<sup>3</sup>

Condensate Gain in Impingers: 80 mL

Weight Gain in Silica Gel: 13 g

Total Moisture Gain: 93 mL

Silica Gel Container No.: 18

Filter Number: \_\_\_\_\_

Leak Check - Meter Box:

Initial: .007 cfm @ 9 inches Hg

Final: .002 cfm @ 6 inches Hg

Leak Check - Pitot Tubes:

Impact 3 "H<sub>2</sub>O for 15 sec: Stable, Leak

Static 3 "H<sub>2</sub>O for 15 sec: Stable, Leak

Umbilical: KA-60

Thermocouple \_\_\_\_\_

Probe No. KAK-110

Pitot Tube: SS III

Test Conducted By: J. Langston A. West

O<sub>2</sub>: 9 % CO<sub>2</sub>: 10 %

Stack Test Observers: \_\_\_\_\_

Port and Traverse Point No.	Distance from Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft <sup>3</sup> )	Stack Velocity Head (H <sub>2</sub> O)	Meter Orifice Pressure Difference (H <sub>2</sub> O)		Stack Gas Temp (°F)	Sample Box Temp (°F)	Last Impinger Temp (°F)	Meter Temp (°F)	Vacuum on Sample Train ("Hg)	Oxygen Meter Reading (%O <sub>2</sub> )
					Calculated	Actual						
1-1		0	319.297	.41	2.23	2.23	305	248	67	73	3	
2		4	22.6	.39	2.17	2.17	308	256	63	72	3	
3		8	26.1	.39	2.17	2.17	311	247	59	72	3	
4		12		.38	2.17	2.17	305	250	58	71	3	
2-1		16	32.6	.45	2.50	2.50	307	252	57	72	3	
2		20	36.1	.38	2.11	2.11	307	248	56	72	3	
3		24	39.5	.36	2.00	2.00	304	246	57	73	3	
4		28	42.4	.34	1.89	1.89	304	247	55	74	3	



Port and Traverse Point No.	Distance from Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft³)	Stack Velocity Head (H₂O)	Meter Orifice Pressure Difference (H₂O)		Stack Gas Temp (°F)	Sample Box Temp (°F)	Last Impinger Temp (°F)	Meter Temp (°F)	Vacuum on Sample Train ("Hg)	Oxygen Meter Reading (%O₂)
					Calculated	Actual						
3-1		32	45.6	.43	2.39	2.39	306	257	57	74	3	
2		36	49.0	.38	2.11	2.11	308	258	55	74	3	
3		40	52.3	.41	2.28	2.28	306	250	54	74	3	
4		44	55.6	.41	2.28	2.28	306	246	55	74	3	
4-1		48	59.0	.44	2.45	2.45	306	248	55	74	3	
2		52	62.6	.43	2.39	2.39	307	249	55	74	3	
3		56	66.1	.40	2.22	2.22	306	347	55	75	3	
4		60	69.4	.38	2.11	2.11	305	350	55	75	3	
	END	64										

$P_s = .59$

10 CO₂ 9 O₂



### SAMPLING RATE CALCULATIONS

Plant Name: CPL Date: 1/22/10  
 Location: Brooksville FL Source: Kiln

1) Calculate the optimum Cf:  $\Delta H @ / \Delta P_{avg} = Cf$

ΔH	/ ΔP <sub>avg</sub>	= Cf
		<u>4.8</u>

2) Calculate the optimum nozzle size:

Record Values		
R1	R2	R3
<u>85</u>		
<u>89</u>		
<u>28.0</u>		
<u>320</u>		
<u>1.73</u>		
<u>.36</u>		
<u>306</u>		

- Tm = Meter Temperature ( °F ) (Add 5 °F for initial temp.)
- Bw = Moisture Fraction
- Ms = Wet Molecular Weight of Stack Gas (from Table)
- Ts = Stack Temperature ( °F )
- ΔH@ = Meter Box Constant (box front)
- ΔP = Average Pitot Reading (Inches H2O)
- Dn = Nozzle Diameter (Inches) measured

Moisture Fraction	MS
0	29
0.05	28.5
0.1	27.9
0.15	27.4
0.2	26.8
0.25	26.2
0.3	25.7
0.35	25.2
0.4	24.6

= 295

$$Dn = \left[ \frac{Cf}{\left( \frac{Tm + 460}{Ms * (Ts + 460)} \right)^2 * (1 - Bw)^2 * (\Delta H @) * 17741} \right]^{0.25}$$

$\left( \frac{545}{21840} \right)^2 * (.8281) * (1.73) * (17741)$   
634.236

3) Calculate the correction factor Cf. Cf times the stack ΔP will determine the manometer setting ΔH:

$$Cf = \left[ \frac{Tm + 460}{Ms * (Ts + 460)} \right]^2 * (1 - Bw)^2 * \Delta H @ * Dn^4 * 17741$$

$Cf * \Delta P = \Delta H$

Calculation	Run No. 1	Run No. 2	Run No. 3
Tm + 460 =	<u>545</u>		
1/[MS*(Ts+460)] =	<u>21840</u>		
* (1 - Bw) <sup>2</sup> =	<u>.8281</u>		
* ΔH@ =	<u>1.73</u>		
* (Dn) <sup>4</sup> =	<u>.008760</u>		
* 17741 = Cf			

5.56

628.41726

# Chain of Custody

Plant Name: CPL

Project Number: 308-09-08

Location: K. In no. Brooksville, FL

Source: K. In

Sample Identification	Remarks
<u>RI PM F</u>	<u>Run 1 P.M. Filter</u>
<u>RI PM P.R.</u>	<u>Run 1 P.M. Probe Rinse - acetone</u>
<u>RI Silica</u>	<u>Run 1 Silica Gel</u>

Sampled by: [Signature] 1/22/10 See Lab Sheets  
Signature Date Time

Relinquished by: \_\_\_\_\_  
Signature Date Time

Received by: \_\_\_\_\_  
Signature Date Time

Relinquished by: \_\_\_\_\_  
Signature Date Time

Laboratory:  
Received by: [Signature] 1/22/10 2030  
Signature Date Time

Sample Shipped Via:  UPS  Federal Express  Other

Shipping Bill Number: \_\_\_\_\_





# Particulate Lab Data Sheet

Test Date: 1/22/10  
 Plant Name: CPL  
 Source: Power Plant

	Run No. 1	Run No. 2	Run No. 3	Blank
Container No.	713	717	204	7211
Total Volume (ml)	200			150
Aliquot Evaporated (ml)	200			
Final Weight (g)	112.4848			110.5214
Tare Weight (g)	112.4781	111.1596	98.9357	110.5211
Gross Weight Gained (g)	.0067			.0003
Average Blank (g)	0	0	0	0
Net Weight (g)	.0067			.0003
Aliquot Factor	x 1.0	x	x	x 1.0
Total Net Weight (mg)	6.7 <sup>50L</sup>			3

Container No.	1 B			BL
Filter No.	005346			5308
Final Weight (g)	0.4369			0.4162
Tare Weight (g)	0.4336			0.4162
Gross Weight Gained	0.0031			—
Average Blank (g)	—			—
Total Net Weight (mg)	3.1			0.0

**Tare Balance Check**

0.0 0.0000    10.0 10.0002  
 1.0 0.9999    50.0 50.0004  
 5.0 5.0001    100.0 100.0004  
 T/H 10/47

Signature

Date

[Signature]  
1/21/10

**Final Balance Check**

0.0 0.0000    10.0 9.997  
 1.0 0.9996    50.0 49.9997  
 5.0 4.9998    100.0 100.0001  
 T/H 70/40

Signature

Date

[Signature]  
1/28/10



Carbon Monoxide Emission Measurements (Jan. 19, 21 and 22)  
Calibration Calculations and Concentrations

**Analyzer Calibration Calculations Summary  
Method 10**

Cylinder ID #	Cal. Gas ppm	% of Span
CC-115823	512.9	51.2
CC-251816	1002.1	100.0

Span is Equal to: 1002.1  
(M7E Sec. 3.4)

*Method 7E Calibration Specifications*  
Mid (Down scale) (40-60%Span); High(Upscale) (100%Span) (M7E-Sec.3.3.2+3.3.3)

EPA Protocol Gas Analyzer Calibration Data Analyzer Calibration Error Instrument Range Setting (ppmv) 0 to 2000						
Cylinder ID #	Calibration Gas	Conc. (ppmv)	Run No.	Date / Time	Response Instrument Direct ppmv	Accuracy Diff. from Actual (% of Span)(1)
ABS981	Zero	0.00	R1-Pre	1/19/2010 12:18	-1.00	-0.10
CC-115823	CO	512.9	R1-Pre	1/19/2010 12:29	502	-1.06
CC-251816	CO	1002.1	R1-Pre	1/19/2010 12:24	1008	0.61

*Method 7E Calibration Specifications*  
(1) Analyzer Calibration Error + 2% of Span (Section 12.2,Equation 7E-1)

EPA Protocol Gas Analyzer Calibration Data System Bias Check Instrument Range Setting (ppmv) 0 to 2000							
Cylinder ID #	Calibration Gas	Conc. (ppmv)	Run No.	Date / Time	Response through Train System Loop ppmv	5% Max System Bias (% of Span)(2)	3% Max Drift(3)
ABS981	Zero	0.00	R1-Pre	1/19/2010 12:44	-1.00	0.00	
ABS981	Zero	0.00	R1-Post	1/19/2010 15:09	-1.00	0.00	0.00
CC-115823	CO	512.9	R1-Pre	1/19/2010 12:39	496.7	-0.55	
CC-115823	CO	512.9	R1-Post	1/19/2010 15:13	483.5	-1.87	1.32

*Method 7E Calibration Specifications*  
(2) Section 12.3, Equation 7E-2  
(3) Section 12.4, Equation 7E-4

Central Power & Lime Co.  
 Brooksville Cement and Power Plant Complex  
 Brooksville, Florida

Wood Pellet Fuel Trials  
 10% Wood Pellet

Date	Time	CO ppmv		
1/19/2010	12:15	21.5		
1/19/2010	12:16	126.2		
1/19/2010	12:17	6.5		
1/19/2010	12:18	-1.0	<< Nitrogen Direct	
1/19/2010	12:19	-1.0	CO	
1/19/2010	12:20	24.0	-1.00	<average
1/19/2010	12:21	710.6		
1/19/2010	12:22	1010.5		
1/19/2010	12:23	985.5		
1/19/2010	12:24	1006.5	<< 1002.1 ppmv CO Direct	
1/19/2010	12:25	1010.0	CO	
1/19/2010	12:26	1008.0	1008.26	<average
1/19/2010	12:27	991.5		
1/19/2010	12:28	627.9		
1/19/2010	12:29	503.3	<< 512.9 ppmv CO Direct	
1/19/2010	12:30	501.3	CO	
1/19/2010	12:31	494.7	502.25	<average
1/19/2010	12:32	135.7		
1/19/2010	12:33	-1.0	<< Nitrogen Direct	
1/19/2010	12:34	-1.0	CO	
1/19/2010	12:35	1.5	-1.00	<average
1/19/2010	12:36	181.8		
1/19/2010	12:37	293.4		
1/19/2010	12:38	458.2		
1/19/2010	12:39	496.2	<< 512.9 ppmv CO System	
1/19/2010	12:40	497.2	CO	
1/19/2010	12:41	496.2	496.75	<average
1/19/2010	12:42	414.1		
1/19/2010	12:43	39.6		
1/19/2010	12:44	-1.0	<< Nitrogen System	
1/19/2010	12:45	-1.0	CO	
1/19/2010	12:46	-1.0	-1.00	<average
1/19/2010	12:47	33.6		
1/19/2010	12:48	188.3		
1/19/2010	12:49	227.8		
1/19/2010	12:50	226.8		
1/19/2010	12:51	185.8		
1/19/2010	12:52	186.8	<< START RUN #1	
1/19/2010	12:53	204.3		
1/19/2010	12:54	171.3		
1/19/2010	12:55	180.8		
1/19/2010	12:56	227.8		
1/19/2010	12:57	247.9		
1/19/2010	12:58	206.8		
1/19/2010	12:59	257.4		
1/19/2010	13:00	224.3		
1/19/2010	13:01	243.4		
1/19/2010	13:02	256.4		
1/19/2010	13:03	235.9		
1/19/2010	13:04	239.9		
1/19/2010	13:05	219.8		
1/19/2010	13:06	245.9		
1/19/2010	13:07	220.8		
1/19/2010	13:08	334.0		
1/19/2010	13:09	838.8		
1/19/2010	13:10	578.9		
1/19/2010	13:11	206.8		
1/19/2010	13:12	209.8		

1/19/2010 13:13	223.3
1/19/2010 13:14	250.4
1/19/2010 13:15	245.4
1/19/2010 13:16	225.8
1/19/2010 13:17	264.4
1/19/2010 13:18	239.4
1/19/2010 13:19	230.8
1/19/2010 13:20	285.9
1/19/2010 13:21	308.0
1/19/2010 13:22	367.1
1/19/2010 13:23	354.0
1/19/2010 13:24	337.5
1/19/2010 13:25	298.9
1/19/2010 13:26	320.5
1/19/2010 13:27	776.7
1/19/2010 13:28	779.2
1/19/2010 13:29	444.2
1/19/2010 13:30	272.4
1/19/2010 13:31	256.4
1/19/2010 13:32	209.3
1/19/2010 13:33	193.3
1/19/2010 13:34	183.3
1/19/2010 13:35	205.3
1/19/2010 13:36	205.3
1/19/2010 13:37	210.3
1/19/2010 13:38	214.3
1/19/2010 13:39	272.9
1/19/2010 13:40	275.4
1/19/2010 13:41	224.8
1/19/2010 13:42	242.4
1/19/2010 13:43	310.0
1/19/2010 13:44	284.4
1/19/2010 13:45	262.9
1/19/2010 13:46	243.4
1/19/2010 13:47	213.8
1/19/2010 13:48	237.9
1/19/2010 13:49	254.9
1/19/2010 13:50	204.8
1/19/2010 13:51	217.3
1/19/2010 13:52	497.7
1/19/2010 13:53	439.7
1/19/2010 13:54	311.0
1/19/2010 13:55	210.3
1/19/2010 13:56	176.8
1/19/2010 13:57	164.7
1/19/2010 13:58	197.8
1/19/2010 13:59	243.4
1/19/2010 14:00	252.4
1/19/2010 14:01	243.4
1/19/2010 14:02	262.9
1/19/2010 14:03	222.8
1/19/2010 14:04	209.8
1/19/2010 14:05	251.4
1/19/2010 14:06	404.6
1/19/2010 14:07	375.1
1/19/2010 14:08	344.5
1/19/2010 14:09	211.8
1/19/2010 14:10	159.2
1/19/2010 14:11	168.3
1/19/2010 14:12	162.7
1/19/2010 14:13	172.3
1/19/2010 14:14	208.3
1/19/2010 14:15	195.3
1/19/2010 14:16	193.3
1/19/2010 14:17	169.8
1/19/2010 14:18	185.8

1/19/2010 14:19 164.2  
 1/19/2010 14:20 144.2  
 1/19/2010 14:21 127.2  
 1/19/2010 14:22 120.2  
 1/19/2010 14:23 120.2  
 1/19/2010 14:24 116.2  
 1/19/2010 14:25 105.2  
 1/19/2010 14:26 99.6  
 1/19/2010 14:27 91.6  
 1/19/2010 14:28 94.6  
 1/19/2010 14:29 116.2  
 1/19/2010 14:30 116.2  
 1/19/2010 14:31 109.2  
 1/19/2010 14:32 104.7  
 1/19/2010 14:33 102.7  
 1/19/2010 14:34 97.1  
 1/19/2010 14:35 106.2  
 1/19/2010 14:36 107.2  
 1/19/2010 14:37 102.2  
 1/19/2010 14:38 92.1  
 1/19/2010 14:39 93.1  
 1/19/2010 14:40 100.7  
 1/19/2010 14:41 101.2  
 1/19/2010 14:42 91.1  
 1/19/2010 14:43 104.2  
 1/19/2010 14:44 99.6  
 1/19/2010 14:45 93.6  
 1/19/2010 14:46 91.6  
 1/19/2010 14:47 82.1  
 1/19/2010 14:48 82.1  
 1/19/2010 14:49 90.1  
 1/19/2010 14:50 88.1  
 1/19/2010 14:51 89.1  
 1/19/2010 14:52 87.1  
 1/19/2010 14:53 86.1  
 1/19/2010 14:54 96.1  
 1/19/2010 14:55 95.6  
 1/19/2010 14:56 81.6  
 1/19/2010 14:57 81.1  
 1/19/2010 14:58 96.1  
 1/19/2010 14:59 90.6  
 1/19/2010 15:00 85.1  
 1/19/2010 15:01 85.1  
 1/19/2010 15:02 81.1  
 1/19/2010 15:03 80.1  
 1/19/2010 15:04 76.6  
 1/19/2010 15:05 76.6  
 1/19/2010 15:06 85.6  
 1/19/2010 15:07 87.6  
 1/19/2010 15:08 28.5

<< END RUN #1

1/19/2010 15:09	-1.0	<< Nitrogen System		
1/19/2010 15:10	-1.0		CO	
1/19/2010 15:11	-1.0		-1.00	<average
1/19/2010 15:12	134.2			
1/19/2010 15:13	451.7	<< 512.9 ppmv CO System		
1/19/2010 15:14	483.2		CO	
1/19/2010 15:15	483.7		483.48	<average

RUN (1)	ANALYZER RESPONSE TO STACK GAS ppmv	ZERO BIAS ppmv	ACTUAL CAL. GAS VALUE ppmv	ANALYZER RESPONSE TO CAL. GAS ppmv	CORRECTED STACK GAS CONC. ppmv
CO	209.2	-1.00	512.9	490.11	219.6

SUMMARY OF MOISTURE EMISSION TEST DATA

CPL BROOKSVILLE FL KILN #1 JANUARY 19, 2010			
Run No.	Stack Gas Flow Rate (SCFMD)	Stack Gas Temperature (F)	Stack Gas Moisture (%)
1	431,848	295	6.8

GENERAL DATA

Plant : CPL BROOKSVILLE FL  
 Source/Unit : KILN #1  
 Date : JANUARY 19, 2010 Cp : 0.840  
 Stack dia. : 223.80 inch OR : Duct Length : 0.00 inch  
 Oxygen Corr.: 0.0 percent Duct Width : 0.00 inch  
 CO2 Corr. : 0.0 percent Std. Temp. : 68 F

FUEL ANALYSIS DATA, (By F Factor or Fuel Use)

F Factor = F, Fuel Use = U f Process Wt.

Hydrogen, wt% : 0.00 Run 1 : 0 Tons/hr  
 Carbon, wt% : 0.00 Run 2 : 0  
 Sulfur, wt% : 0.00 Run 3 : 0  
 Nitrogen, wt% : 0.00  
 Oxygen, wt% : 0.00  
 Btu/lb : 0

Type of Flow Meter : (1=Meter Box 2=Mass Flow Meter) 1

F-Factor : dscf/MMBtu;

<u>FIELD DATA</u>	METHOD 5	RUN 1	RUN 2	RUN 3
Meter Temp., Tm (F) .....		74	0	0
Stack Temp., Ts (F) .....		295	0	0
Sq.Rt. dP .....		0.60	0.00	0.00
dH (in. H2O) .....		0.00	0.00	0.00
Meter Vol., Vm (ft3) .....		95.033	0.000	0.000
Vol. H2O, Vlc (ml) .....		146.0	0.0	0.0
Meter Y .....		1.004	0.000	0.000
Bar. Press., Pb (in.Hg.) .....		30.00	0.00	0.00
Static Press., Ps (in.H2O) .....		0.00	0.00	0.00
Test Time (min.) .....		128.0	0.0	0.0
Nozzle Dia., Dn (in.) .....		0.000	0.000	0.000
Oxygen, O2 (%) .....		13.5	0.0	0.0
Carbon Dioxide, CO2 (%) .....		7.0	0.0	0.0
Carbon Monoxide, CO (%) .....		0.0	0.0	0.0

Report Emission Criteria in ? l = lb/hr g = gr/dscf : grains

Process Rate Units ? T = Ton/hr, L = Lbs/hr, C = Cans/min: T

Allowable Particulate Matter Concentration .....: 0

<u>LABORATORY RESULTS</u>	RUN 1	RUN 2	RUN 3
	grams	grams	grams

GRAVIMETRIC ANALYSIS METHOD 5 :

Front Half Wash (FHW) .....	0.00000	0.00000	0.00000
Filterable Sample (MF) .....	0.00000	0.00000	0.00000
Condensable Sample (BHW) .....	0.00000	0.00000	0.00000



A. FIELD DATA SUMMARY

---

Plant: CPL BROOKSVILLE FL  
 Source/Unit: KILN #1  
 Date: JANUARY 19, 2010

	RUN 1
Vlc = Vol water collected in train, ml	146.0
Vm = Sample gas vol, meter cond., acf	95.033
Y = Meter calibration factor	1.0040
Pbar = Barometric pressure, in. Hg	30.00
Pstatic = Stack static pressure, in. H2O	0.00
dH = Avg meter pressure diff, in. H2O	0.00
Tm = Absolute meter temp., degrees R	534.3
Vm(std) = Sample gas vol, Std. cond., dscf	94.549
Bws = Water vapor in gas stream, fraction	0.068
MF = Moisture factor ( 1 - Bws)	0.932
CO2 = Carbon Dioxide, dry, volume %	7.00
O2 = Oxygen, dry, volume %	13.50
N2 = Nitrogen, dry volume %	79.50
Md = Molecular weight of stack gas, dry	29.66
Ms = Molecular weight of stack gas, wet	28.87
Cp = Pitot tube coefficient	0.84
Sq.Rt. dP = Avg. square root of each dP	0.6010
Ts = Absolute stack temp., degrees R	754.8
A = Area of stack, ft2	273.18
Qstd = Volumetric flowrate, dscfm	431,848
An = Nozzle area, ft2	
0 = Sample time, minutes	128.00
%I = Isokinetic variation, percent	

SOURCE TEST CALCULATIONS

---

Plant : CPL BROOKSVILLE FL  
 Source/Unit : KILN #1  
 Date: JANUARY 19, 2010

RUN NO.: 1

STD.TEMP, Tstd =	68 F	STATIC PRESS., Ps =	0.00 in. H2O
METER TEMP, Tm =	74.25 F	PITOT COFF., Cp =	0.840
STACK TEMP, Ts =	294.8 F	STACK I.D. =	223.80 inch
AVG.VEL.HEAD,dP =	0.361 in. H2O	DUCT LENGTH =	inch
METER ORIFICE,dH=	0.00 in. H2O	DUCT WIDTH =	inch
METER VOL., Vm =	95.033 Cu.Ft.	STACK AREA, As =	273.179 Sq.Ft.
METER COFF., Y =	1.004	TEST TIME =	128.00 min.
BAR. PRESS., Pb =	30.00 in.Hg	NOZZLE DIA. =	inch
COND.(Vlc) =	146.0 ml	NOZZLE DIA., An =	Sq.Ft.
GAS ANALYSIS =	13.50 % O2	0.00 % CO	
	7.00 % CO2	79.50 % N2	

---

Vm(std) = [ ( T(std) + 460 ) / 29.92 ] x Vm x Y x (Pb + (dH / 13.6)) / (Tm + 460).....	=	94.549 dscf
Vw(std) = (8.9148 x 10e-5) x (Tstd + 460) x Vlc	=	6.872 scf
Bws = Vw(std) / (Vm(std) + Vw(std)).....	=	0.068   Lower   Bws   value
Bws @ Saturated Conditions = Vapor Press. of H2O @ Dew Point Temp. / (Ps, in.Hg.) .....	=	1.000   used.
%EA = (%O2 - 0.5%CO) / (0.264%N2 - (%O2 - 0.5%CO)) x 100 =		180.29
Md = (.44 x %CO2) + (.32 x %O2) + [.28 x (%N2 + %CO)] =		29.66
Ms = (Md x (1-Bws)) + (18.0 x Bws).....	=	28.87
P(stack) = Pbar + (Ps / 13.6) .....	=	30.00 in. Hg
vs = 85.49 x CP x (Sq.Rt.dP) x [Sq.Rt.(Ts + 460) / (Ms x P(stack))] .....	=	40.29 ft/sec
Qs = vs x As x 60 .....	=	660,408 acf/min
Qs(std) = Qs x (1-Bws) x ((Tstd + 460) / (Ts + 460)) x (P(stack) / 29.92) .....	=	431,848 dscf/min
I = (Ts+460) x [(0.002669 x Vlc) + (Vm(std) / (T(std) + 460) / 29.92] x 100 / [ Time x P(stack) x An x vs x 60] .....	=	%

**Analyzer Calibration Calculations Summary  
Method 10**

Cylinder ID #	Cal. Gas ppm	% of Span
CC-115823	512.9	51.2
CC-251816	1002.1	100.0

Span is Equal to: 1002.1  
(M7E Sec. 3.4)

*Method 7E Calibration Specifications*

Mid (Down scale) (40-60%Span); High(Upscale) (100%Span) (M7E-Sec.3.3.2+3.3.3)

EPA Protocol Gas Analyzer Calibration Data Analyzer Calibration Error Instrument Range Setting (ppmv) 0 to 2000						
---	--	--	--	--	--	--

Cylinder ID #	Calibration Gas	Conc. (ppmv)	Run No.	Date / Time	Response Instrument Direct ppmv	Accuracy Diff. from Actual (% of Span)(1)
ABS981	Zero	0.00	R1-Pre	1/21/2010 9:20	3.76	0.37
CC-115823	CO	512.9	R1-Pre	1/21/2010 9:30	508	-0.46
CC-251816	CO	1002.1	R1-Pre	1/21/2010 9:26	1007	0.49

*Method 7E Calibration Specifications*

(1) Analyzer Calibration Error + 2% of Span (Section 12.2,Equation 7E-1)

EPA Protocol Gas Analyzer Calibration Data System Bias Check Instrument Range Setting (ppmv) 0 to 2000							
--	--	--	--	--	--	--	--

Cylinder ID #	Calibration Gas	Conc. (ppmv)	Run No.	Date / Time	Response through Train System Loop ppmv	5% Max System Bias (% of Span)(2)	3% Max Drift(3)
ABS981	Zero	0.00	R1-Pre	1/21/2010 9:52	4.26	0.05	
ABS981	Zero	0.00	R1-Post	1/21/2010 14:12	0.50	-0.32	0.37
CC-115823	CO	512.9	R1-Pre	1/21/2010 9:48	502.5	-0.57	
CC-115823	CO	512.9	R1-Post	1/21/2010 14:08	496.0	-1.22	0.65

*Method 7E Calibration Specifications*

(2) Section 12.3, Equation 7E-2

(3) Section 12.4, Equation 7E-4

Central Power & Lime Co.  
 Brooksville Cement and Power Plant Complex  
 Brooksville, Florida

Wood Pellet Fuel Trials  
**20% Wood Pellet**

Date	Time	CO ppmv		
1/21/2010	9:15	482.2		
1/21/2010	9:16	317.0		
1/21/2010	9:17	48.6		
1/21/2010	9:18	30.5		
1/21/2010	9:19	26.0		
1/21/2010	9:20	10.0	<< Nitrogen Direct	
1/21/2010	9:21	4.0		CO
1/21/2010	9:22	3.5		3.76 <average
1/21/2010	9:23	53.1		
1/21/2010	9:24	740.6		
1/21/2010	9:25	999.0		
1/21/2010	9:26	1006.5	<< 1002.1 ppmv CO Direct	
1/21/2010	9:27	1006.5		CO
1/21/2010	9:28	1007.5		1007.01 <average
1/21/2010	9:29	984.5		
1/21/2010	9:30	624.4	<< 512.9 ppmv CO Direct	
1/21/2010	9:31	509.8		CO
1/21/2010	9:32	506.8		508.26 <average
1/21/2010	9:33	481.2		
1/21/2010	9:34	90.1		
1/21/2010	9:35	4.0	<< Nitrogen Direct	
1/21/2010	9:36	3.5		CO
1/21/2010	9:37	4.5		4.01 <average
1/21/2010	9:38	50.1		
1/21/2010	9:39	145.2		
1/21/2010	9:40	146.2		
1/21/2010	9:41	320.5		
1/21/2010	9:42	886.3		
1/21/2010	9:43	996.0	<< 1002.1 ppmv CO System	
1/21/2010	9:44	1000.0		CO
1/21/2010	9:45	1001.0		1000.50 <average
1/21/2010	9:46	913.4		
1/21/2010	9:47	563.3		
1/21/2010	9:48	504.3	<< 512.9 ppmv CO System	
1/21/2010	9:49	502.3		CO
1/21/2010	9:50	502.8		502.50 <average
1/21/2010	9:51	442.7		
1/21/2010	9:52	69.6	<< Nitrogen System	
1/21/2010	9:53	5.5		CO
1/21/2010	9:54	3.0		4.26 <average
1/21/2010	11:45	200.3		
1/21/2010	11:46	185.3		
1/21/2010	11:47	207.3		

1/21/2010 11:48	208.3
1/21/2010 11:49	222.8
1/21/2010 11:50	236.4
1/21/2010 11:51	234.4
1/21/2010 11:52	227.3
1/21/2010 11:53	212.3
1/21/2010 11:54	234.9
1/21/2010 11:55	261.4
1/21/2010 11:56	230.3
1/21/2010 11:57	251.4
1/21/2010 11:58	287.4
1/21/2010 11:59	291.4
1/21/2010 12:00	324.0
1/21/2010 12:01	316.5
1/21/2010 12:02	279.9
1/21/2010 12:03	281.4
1/21/2010 12:04	258.9
1/21/2010 12:05	219.8
1/21/2010 12:06	272.4
1/21/2010 12:07	257.9
1/21/2010 12:08	299.4
1/21/2010 12:09	278.4
1/21/2010 12:10	235.9
1/21/2010 12:11	220.8
1/21/2010 12:12	257.9
1/21/2010 12:13	280.4
1/21/2010 12:14	277.9
1/21/2010 12:15	297.9
1/21/2010 12:16	300.5
1/21/2010 12:17	286.9
1/21/2010 12:18	265.9
1/21/2010 12:19	295.9
1/21/2010 12:20	306.0
1/21/2010 12:21	302.0
1/21/2010 12:22	297.4
1/21/2010 12:23	266.9
1/21/2010 12:24	293.9
1/21/2010 12:25	298.4
1/21/2010 12:26	356.5
1/21/2010 12:27	399.6
1/21/2010 12:28	377.6
1/21/2010 12:29	356.5
1/21/2010 12:30	349.0
1/21/2010 12:31	320.5
1/21/2010 12:32	394.6
1/21/2010 12:33	393.6
1/21/2010 12:34	364.0
1/21/2010 12:35	347.0
1/21/2010 12:36	370.6
1/21/2010 12:37	419.6
1/21/2010 12:38	435.2
1/21/2010 12:39	456.7

<< START RUN #1

1/21/2010 12:40	504.3
1/21/2010 12:41	437.7
1/21/2010 12:42	495.2
1/21/2010 12:43	499.8
1/21/2010 12:44	397.6
1/21/2010 12:45	373.1
1/21/2010 12:46	461.7
1/21/2010 12:47	452.2
1/21/2010 12:48	377.6
1/21/2010 12:49	419.1
1/21/2010 12:50	499.2
1/21/2010 12:51	573.9
1/21/2010 12:52	540.3
1/21/2010 12:53	517.8
1/21/2010 12:54	550.3
1/21/2010 12:55	555.8
1/21/2010 12:56	528.3
1/21/2010 12:57	503.3
1/21/2010 12:58	514.8
1/21/2010 12:59	518.8
1/21/2010 13:00	524.3
1/21/2010 13:01	513.3
1/21/2010 13:02	534.3
1/21/2010 13:03	491.2
1/21/2010 13:04	421.1
1/21/2010 13:05	512.3
1/21/2010 13:06	597.4
1/21/2010 13:07	484.7
1/21/2010 13:08	469.2
1/21/2010 13:09	462.7
1/21/2010 13:10	444.7
1/21/2010 13:11	438.2
1/21/2010 13:12	498.7
1/21/2010 13:13	554.3
1/21/2010 13:14	475.2
1/21/2010 13:15	538.3
1/21/2010 13:16	533.8
1/21/2010 13:17	613.4
1/21/2010 13:18	595.4
1/21/2010 13:19	540.3
1/21/2010 13:20	429.6
1/21/2010 13:21	365.0
1/21/2010 13:22	362.0
1/21/2010 13:23	412.6
1/21/2010 13:24	420.6
1/21/2010 13:25	376.6
1/21/2010 13:26	392.6
1/21/2010 13:27	360.5
1/21/2010 13:28	389.1
1/21/2010 13:29	346.5
1/21/2010 13:30	400.1
1/21/2010 13:31	425.6

1/21/2010 13:32 389.1  
 1/21/2010 13:33 349.5  
 1/21/2010 13:34 362.5  
 1/21/2010 13:35 355.0  
 1/21/2010 13:36 364.5  
 1/21/2010 13:37 303.0  
 1/21/2010 13:38 334.0  
 1/21/2010 13:39 291.4  
 1/21/2010 13:40 275.4  
 1/21/2010 13:41 290.4  
 1/21/2010 13:42 280.4  
 1/21/2010 13:43 254.4  
 1/21/2010 13:44 247.9  
 1/21/2010 13:45 275.9  
 1/21/2010 13:46 262.4  
 1/21/2010 13:47 268.9  
 1/21/2010 13:48 248.9  
 1/21/2010 13:49 242.9  
 1/21/2010 13:50 308.0  
 1/21/2010 13:51 279.9  
 1/21/2010 13:52 305.5  
 1/21/2010 13:53 258.9  
 1/21/2010 13:54 222.3  
 1/21/2010 13:55 221.8  
 1/21/2010 13:56 209.8  
 1/21/2010 13:57 185.8  
 1/21/2010 13:58 200.3  
 1/21/2010 13:59 215.3  
 1/21/2010 14:00 215.3  
 1/21/2010 14:01 212.8  
 1/21/2010 14:02 254.9  
 1/21/2010 14:03 242.4  
 1/21/2010 14:04 198.8  
 1/21/2010 14:05 240.4  
 1/21/2010 14:06 298.9  
 1/21/2010 14:07 471.2  
 1/21/2010 14:08 496.2  
 1/21/2010 14:09 495.2  
 1/21/2010 14:10 496.7  
 1/21/2010 14:11 354.0  
 1/21/2010 14:12 22.0  
 1/21/2010 14:13 1.0  
 1/21/2010 14:14 0.0

<< END RUN #1

<< 512.9 ppmv CO System

CO	
495.99	<average

<< Nitrogen System

CO	
0.50	<average

RUN (1)	ANALYZER RESPONSE TO STACK GAS ppmv	ZERO BIAS ppmv	ACTUAL CAL. GAS VALUE ppmv	ANALYZER RESPONSE TO CAL. GAS ppmv	CORRECTED STACK GAS CONC. ppmv
CO	359.4	2.38	512.9	499.25	368.5

SUMMARY OF MOISTURE EMISSION TEST DATA

CPL, BROOKSVILLE FL KILN #1 JANUARY 21, 2010			
Run No.	Stack Gas Flow Rate (SCFMD)	Stack Gas Temperature (F)	Stack Gas Moisture (%)
1	420,619	311	8.1



GENERAL DATA

Plant : CPL, BROOKSVILLE FL  
 Source/Unit : KILN #1  
 Date : JANUARY 21, 2010 Cp : 0.840  
 Stack dia. : 223.80 inch OR : Duct Length : 0.00 inch  
 Oxygen Corr.: 0.0 percent Duct Width : 0.00 inch  
 CO2 Corr. : 0.0 percent Std. Temp. : 68 F

FUEL ANALYSIS DATA, (By F Factor or Fuel Use)

F Factor = F, Fuel Use = U f Process Wt.

Hydrogen, wt% : 0.00 Run 1 : 0 Tons/hr  
 Carbon, wt% : 0.00 Run 2 : 0  
 Sulfur, wt% : 0.00 Run 3 : 0  
 Nitrogen, wt% : 0.00  
 Oxygen, wt% : 0.00  
 Btu/lb : 0

Type of Flow Meter : (1=Meter Box 2=Mass Flow Meter) 1

F-Factor : dscf/MMBtu;

FIELD DATA METHOD 5 RUN RUN RUN  
1 2 3

Meter Temp., Tm (F) .....	81	0	0
Stack Temp., Ts (F) .....	311	0	0
Sq.Rt. dP .....	0.60	0.00	0.00
dH (in. H2O) .....	0.00	0.00	0.00
Meter Vol., Vm (ft3) .....	95.874	0.000	0.000
Vol. H2O, Vlc (ml) .....	176.0	0.0	0.0
Meter Y .....	1.004	1.004	1.004
Bar. Press., Pb (in.Hg.) .....	29.89	29.89	29.89
Static Press., Ps (in.H2O) .....	-0.51	-0.51	-0.51
Test Time (min.) .....	128.0	128.0	128.0
Nozzle Dia., Dn (in.) .....	0.000	0.000	0.000
Oxygen, O2 (%) .....	10.5	0.0	0.0
Carbon Dioxide, CO2 (%) .....	9.0	0.0	0.0
Carbon Monoxide, CO (%) .....	0.0	0.0	0.0

Report Emission Criteria in ? l = lb/hr g = gr/dscf : grains

Process Rate Units ? T = Ton/hr, L = Lbs/hr, C = Cans/min: T

Allowable Particulate Matter Concentration .....

LABORATORY RESULTS RUN RUN RUN  
1 2 3  
grams grams grams

GRAVIMETRIC ANALYSIS METHOD 5 :

Front Half Wash (FWW) .....	0.00000	0.00000	0.00000
Filterable Sample (MF) .....	0.00000	0.00000	0.00000
Condensable Sample (BHW) .....	0.00000	0.00000	0.00000

A. FIELD DATA SUMMARY

---

Plant: CPL, BROOKSVILLE FL  
 Source/Unit: KILN #1  
 Date: JANUARY 21, 2010

	RUN 1
Vlc = Vol water collected in train, ml	176.0
Vm = Sample gas vol, meter cond., acf	95.874
Y = Meter calibration factor	1.0040
Pbar = Barometric pressure, in. Hg	29.89
Pstatic = Stack static pressure, in. H2O	-0.51
dH = Avg meter pressure diff, in. H2O	0.00
Tm = Absolute meter temp., degrees R	541.0
Vm(std) = Sample gas vol, Std. cond., dscf	93.850
Bws = Water vapor in gas stream, fraction	0.081
MF = Moisture factor ( 1 - Bws)	0.919
CO2 = Carbon Dioxide, dry, volume %	9.00
O2 = Oxygen, dry, volume %	10.50
N2 = Nitrogen, dry volume %	80.50
Md = Molecular weight of stack gas, dry	29.86
Ms = Molecular weight of stack gas, wet	28.90
Cp = Pitot tube coefficient	0.84
Sq.Rt. dP = Avg. square root of each dP	0.6019
Ts = Absolute stack temp., degrees R	770.5
A = Area of stack, ft2	273.18
Qstd = Volumetric flowrate, dscfm	420,619
An = Nozzle area, ft2	
t = Sample time, minutes	128.00
%I = Isokinetic variation, percent	

SOURCE TEST CALCULATIONS

---

Plant : CPL, BROOKSVILLE FL  
 Source/Unit : KILN #1  
 Date: JANUARY 21, 2010

RUN NO.: 1

STD. TEMP, Tstd =	68 F	STATIC PRESS., Ps =	-0.51 in. H2O
METER TEMP, Tm =	81 F	PITOT COFF., Cp =	0.840
STACK TEMP, Ts =	310.5 F	STACK I.D. =	223.80 inch
AVG. VEL. HEAD, dP =	0.362 in. H2O	DUCT LENGTH =	inch
METER ORIFICE, dH =	0.00 in. H2O	DUCT WIDTH =	inch
METER VOL., Vm =	95.874 Cu.Ft.	STACK AREA, As =	273.179 Sq.Ft.
METER COFF., Y =	1.004	TEST TIME =	128.00 min.
BAR. PRESS., Pb =	29.89 in.Hg	NOZZLE DIA. =	inch
COND.(Vlc) =	176.0 ml	NOZZLE DIA., An =	Sq.Ft.
GAS ANALYSIS =	10.50 % O2	0.00 % CO	
	9.00 % CO2	80.50 % N2	

---

$$\begin{aligned}
 Vm(std) &= [ ( T(std) + 460 ) / 29.92 ] \times Vm \times Y \times \\
 &\quad ( Pb + (dH / 13.6) ) / ( Tm + 460 ) \dots\dots = 93.850 \text{ dscf} \\
 Vw(std) &= ( 8.9148 \times 10e-5 ) \times ( Tstd + 460 ) \times Vlc = 8.284 \text{ scf} \\
 Bws &= Vw(std) / ( Vm(std) + Vw(std) ) \dots\dots\dots = 0.081 \text{ | Lower} \\
 &\quad \text{| Bws} \\
 &\quad \text{| value} \\
 Bws @ \text{ Saturated Conditions} &= \text{Vapor Press. of H2O} \\
 @ \text{ Dew Point Temp. / (Ps, in.Hg.)} \dots\dots\dots &= 1.000 \text{ | used.} \\
 \%EA &= ( \%O2 - 0.5\%CO ) / ( 0.264\%N2 - ( \%O2 - 0.5\%CO ) ) \times 100 = 97.66 \\
 Md &= ( .44 \times \%CO2 ) + ( .32 \times \%O2 ) + [ .28 \times ( \%N2 + \%CO ) ] = 29.86 \\
 Ms &= ( Md \times ( 1 - Bws ) ) + ( 18.0 \times Bws ) \dots\dots\dots = 28.90 \\
 P(stack) &= Pbar + ( Ps / 13.6 ) \dots\dots\dots = 29.85 \text{ in. Hg} \\
 vs &= 85.49 \times CP \times ( Sq.Rt.dP ) \times ( Sq.Rt.( Ts + 460 ) \\
 &\quad / ( Ms \times P(stack) ) ] \dots\dots\dots = 40.85 \text{ ft/sec} \\
 Qs &= vs \times As \times 60 \dots\dots\dots = 669,493 \text{ acf/min} \\
 Qs(std) &= Qs \times ( 1 - Bws ) \times ( ( Tstd + 460 ) / ( Ts + 460 ) ) \\
 &\quad \times ( P(stack) / 29.92 ) \dots\dots\dots = 420,619 \text{ dscf/min} \\
 I &= ( Ts + 460 ) \times [ ( 0.002669 \times Vlc ) + ( Vm(std) / \\
 &\quad ( T(std) + 460 ) / 29.92 ] \times 100 / [ \text{Time} \times \\
 &\quad P(stack) \times An \times vs \times 60 ] \dots\dots\dots = \%
 \end{aligned}$$

**Analyzer Calibration Calculations Summary  
Method 10**

Cylinder ID #	Cal. Gas ppm	% of Span
CC-251816	512.9	34.0
CC-251876	1000.2	66.2

Span is Equal to: 1510.0  
(M7E Sec. 3.4)

*Method 7E Calibration Specifications*

Mid (Down scale) (40-60%Span); High(Upscale) (100%Span) (M7E-Sec.3.3.2+3.3.3)

EPA Protocol Gas Analyzer Calibration Data Analyzer Calibration Error Instrument Range Setting (ppmv) 0 to 2000						
Cylinder ID #	Calibration Gas	Conc. (ppmv)	Run No.	Date / Time	Response Instrument Direct ppmv	Accuracy Diff. from Actual (% of Span)(1)
ABS981	Zero	0.00	R1-Pre	1/22/2010 11:30	-0.75	-0.05
CC-251876	CO	512.9	R1-Pre	1/22/2010 11:26	493.7	-1.27
CC-251816	CO	1000.2	R1-Pre	1/22/2010 11:22	1007.0	0.45
CC-251950	CO	1510.0	R1-Pre	1/22/2010 11:18	1512.5	0.17

*Method 7E Calibration Specifications*

(1) Analyzer Calibration Error + 2% of Span (Section 12.2,Equation 7E-1)

EPA Protocol Gas Analyzer Calibration Data System Bias Check Instrument Range Setting (ppmv) 0 to 2000							
Cylinder ID #	Calibration Gas	Conc. (ppmv)	Run No.	Date / Time	Response through Train System Loop ppmv	5% Max System Bias (% of Span)(2)	3% Max Drift(3)
ABS981	Zero	0.00	R1-Pre	1/22/2010 11:52	-0.50	0.02	
ABS981	Zero	0.00	R1-Post	1/22/2010 17:50	-1.00	-0.02	0.03
CC-251816	CO	512.9	R1-Pre	1/22/2010 11:48	491.2	-0.17	
CC-251816	CO	512.9	R1-Post	1/22/2010 17:49	486.5	-0.48	0.32

*Method 7E Calibration Specifications*

(2) Section 12.3, Equation 7E-2

(3) Section 12.4, Equation 7E-4

Central Power & Lime Co.  
 Brooksville Cement and Power Plant Complex  
 Brooksville, Florida

Wood Pellet Fuel Trials  
 30 % Pellets

Date	Time	CO ppmv			
1/22/2010	11:05	-1.0			
1/22/2010	11:06	-0.5			
1/22/2010	11:07	147.7			
1/22/2010	11:08	169.8			
1/22/2010	11:09	59.6			
1/22/2010	11:10	3.0			
1/22/2010	11:11	-1.0	<< Nitrogen Direct		
1/22/2010	11:12	-1.0		CO	
1/22/2010	11:13	76.6		-1.00	<average
1/22/2010	11:14	1136.2			
1/22/2010	11:15	1514.8			
1/22/2010	11:16	1515.3	<< 1510 ppmv CO Direct		
1/22/2010	11:17	1514.8		CO	
1/22/2010	11:18	1510.3		1512.5	<average
1/22/2010	11:19	1467.2			
1/22/2010	11:20	1076.1	<< 1002. ppmv CO Direct		
1/22/2010	11:21	983.0		CO	
1/22/2010	11:22	981.5		982.2	<average
1/22/2010	11:23	947.4			
1/22/2010	11:24	593.9			
1/22/2010	11:25	495.2	<< 512.9 ppmv CO Direct		
1/22/2010	11:26	492.2		CO	
1/22/2010	11:27	461.7		493.7	<average
1/22/2010	11:28	79.1			
1/22/2010	11:29	-0.5	<< Nitrogen Direct		
1/22/2010	11:30	-1.0		CO	
1/22/2010	11:31	9.0		-0.75	<average
1/22/2010	11:32	118.7			
1/22/2010	11:33	132.7			
1/22/2010	11:34	426.6			
1/22/2010	11:35	1379.1			
1/22/2010	11:36	1499.8			
1/22/2010	11:37	1502.3	<< 1510 ppmv CO System		
1/22/2010	11:38	1501.3		CO	
1/22/2010	11:39	1323.5		1501.75	<average
1/22/2010	11:40	1004.0			
1/22/2010	11:41	977.5			
1/22/2010	11:42	974.0	<< 1002.1 ppmv CO System		
1/22/2010	11:43	975.5		CO	
1/22/2010	11:44	813.7		974.71	<average
1/22/2010	11:45	519.8			
1/22/2010	11:46	492.2			
1/22/2010	11:47	491.2	<< 512.9 ppmv CO System		
1/22/2010	11:48	491.2		CO	
1/22/2010	11:49	339.0		491.24	<average
1/22/2010	11:50	19.5			
1/22/2010	11:51	-0.5	<< Nitrogen System		
1/22/2010	11:52	-0.5		CO	
				-0.50	<average

Central Power & Lime Co.  
Brooksville Cement and Power Plant Complex  
Brooksville, Florida

Wood Pellet Fuel Trials  
30 % Pellets

Date Time CO ppmv

1/22/2010 16:30	662.5
1/22/2010 16:31	640.0
1/22/2010 16:32	613.4
1/22/2010 16:33	677.5
1/22/2010 16:34	695.5
1/22/2010 16:35	672.0
1/22/2010 16:36	541.8
1/22/2010 16:37	556.8
1/22/2010 16:38	578.4
1/22/2010 16:39	540.3
1/22/2010 16:40	555.8
1/22/2010 16:41	589.9
1/22/2010 16:42	549.8
1/22/2010 16:43	574.9
1/22/2010 16:44	572.9
1/22/2010 16:45	540.3
1/22/2010 16:46	509.8
1/22/2010 16:47	504.3
1/22/2010 16:48	600.4
1/22/2010 16:49	574.4
1/22/2010 16:50	465.2
1/22/2010 16:51	442.2
1/22/2010 16:52	510.3
1/22/2010 16:53	553.3
1/22/2010 16:54	463.2
1/22/2010 16:55	470.2
1/22/2010 16:56	497.2
1/22/2010 16:57	361.0
1/22/2010 16:58	423.6
1/22/2010 16:59	455.7
1/22/2010 17:00	454.2
1/22/2010 17:01	416.1
1/22/2010 17:02	409.6
1/22/2010 17:03	373.1
1/22/2010 17:04	438.2
1/22/2010 17:05	536.3
1/22/2010 17:06	472.2
1/22/2010 17:07	459.7
1/22/2010 17:08	555.3
1/22/2010 17:09	532.3
1/22/2010 17:10	500.3
1/22/2010 17:11	621.9
1/22/2010 17:12	550.8
1/22/2010 17:13	587.9
1/22/2010 17:14	586.4
1/22/2010 17:15	589.4
1/22/2010 17:16	513.3
1/22/2010 17:17	410.1

<<Start CO Run 1

Central Power & Lime Co.  
 Brooksville Cement and Power Plant Complex  
 Brooksville, Florida

Wood Pellet Fuel Trials  
 30 % Pellets

Date	Time	CO ppmv
1/22/2010	17:18	449.2
1/22/2010	17:19	573.4
1/22/2010	17:20	658.5
1/22/2010	17:21	617.4
1/22/2010	17:22	497.2
1/22/2010	17:23	585.9
1/22/2010	17:24	515.8
1/22/2010	17:25	400.6
1/22/2010	17:26	375.6
1/22/2010	17:27	366.0
1/22/2010	17:28	457.2
1/22/2010	17:29	503.8
1/22/2010	17:30	478.7
1/22/2010	17:31	451.2
1/22/2010	17:32	427.1
1/22/2010	17:33	385.6
1/22/2010	17:34	337.0
1/22/2010	17:35	376.6
1/22/2010	17:36	375.1
1/22/2010	17:37	412.6
1/22/2010	17:38	387.6
1/22/2010	17:39	270.9
1/22/2010	17:40	261.4
1/22/2010	17:41	372.6
1/22/2010	17:42	480.2
1/22/2010	17:43	485.7
1/22/2010	17:44	486.7
1/22/2010	17:45	486.2
1/22/2010	17:46	347.5
1/22/2010	17:47	19.5
1/22/2010	17:48	-1.0
1/22/2010	17:49	-1.0
1/22/2010	17:50	-1.0

<<END CO Run 1

1/22/2010 17:44	486.7	<< 512.9 ppmv CO System	
1/22/2010 17:45	486.2	CO	
1/22/2010 17:46	347.5	486.48	<average
1/22/2010 17:47	19.5		
1/22/2010 17:48	-1.0	<< Nitrogen System	
1/22/2010 17:49	-1.0	CO	
1/22/2010 17:50	-1.0	-1.00	<average

RUN (1)	ANALYZER RESPONSE TO STACK GAS ppmv	ZERO BIAS ppmv	ACTUAL CAL.GAS VALUE ppmv	ANALYZER RESPONSE TO CAL. GAS ppmv	CORRECTED STACK GAS CONC. ppmv
CO	522.6	-0.75	512.9	488.86	548.3

Carbon Monoxide Emission Measurements (Jan. 19, 21 and 22)

Field Data Sheets



**KOGLER AND ASSOCIATES, INC.**  
**INSTRUMENTAL GAS SAMPLING FIELD DATA RECORD**

PLANT <i>CDL Branksville FL</i>				DATE <i>01-19-10</i>			
LOCATION <i># Kiln #1</i>				EMISSION UNIT <i>1 kiln #1</i>			
TEST(s) <i>CO + Moisture &amp; Flows</i> <i>10% wood Pellets</i>				SYSTEM LEAK CHECK (Limit 1 inHg/2min)			
				Init. VAC inHg <i>15</i>		Final VAC inHg <i>15</i>	
INSTRUMENT RANGE (R) (0-XXX)				Calibration Gas Certified Concentration Value			
Instrument	Available R	Selected R	Teloger Vdc	Test	mid-gas	mid-gas	high-gas(span)
NOx (M7E)				NOx (M7E)			
SO2 (M6C)				SO2 (M6C)			
CO (M10)				CO (M10)	<i>Zero Air</i>	<i>201.4</i>	<i>1003.1</i>
THC (M25A)				THC (M25A)			
NMHC				NMHC			
TIME	Action Comment			TIME	Action Comment		
<del>11:37</del>	<del>Zero Air on</del>			<i>15:14</i>	<i>512.9 CO = 482.2</i>		
<del>11:40</del>	<del>Zero Air = 1.002</del>			<i>15:16</i>	<i>512.9 CO off</i>		
<del>11:42</del>	<del>Zero Air off / 512.9 CO on</del>						
<del>11:47</del>	<del>512.9 CO = 511.768</del>						
<del>11:49</del>	<del>512.9 CO off / 201.4 CO on</del>						
<del>11:51</del>	<del>201.4 CO = 202.3</del>						
<del>11:53</del>	<del>201.4 CO off / Zero Air on</del>						
<del>11:55</del>	<del>Zero Air = 2.2003</del>						
<del>11:57</del>	<del>Zero Air off</del>						
<i>12:16</i>	<i>Zero Air on</i>						
<i>12:18</i>	<i>Zero Air = -.5</i>						
<i>12:20</i>	<i>Zero Air off / 1003.1 CO on</i>						
<i>12:25</i>	<i>1003.1 CO = 1005.5</i>						
<i>12:27</i>	<i>1003.1 CO off / 512.9 CO on</i>						
<i>12:29</i>	<i>512.9 CO = 511.267</i>						
<i>12:31</i>	<i>512.9 CO off / Zero Air</i>						
<i>12:33</i>	<i>Zero Air = 0.5</i>						
<i>12:35</i>	<i>Zero Air off</i>						
<i>12:36</i>	<i>512.9 CO on</i>						
<i>12:39</i>	<i>512.9 CO = 495.2</i>						
<i>12:41</i>	<i>512.9 CO off / Zero Air on</i>						
<i>12:44</i>	<i>Zero Air = 0.3</i>						
<i>12:46</i>	<i>Zero Air off / Stack Gas</i>						
<i>12:52</i>	<i>Start Run 10% Wood Pellets</i>						
<i>13:06</i>	<i>End Run 10% Wood Pellets</i>						
<i>13:07</i>	<i>Zero Air on</i>						
<i>13:09</i>	<i>Zero Air = 1.0</i>						
<i>13:11</i>	<i>Zero Air off / 512.9 CO on</i>						

Direct

System

Direct

System

~~13:11~~  
 13:11 - 13:26 - ~~13:11~~

PS 15 min

13:52 - 14:05 -

## Multiple Methods Data Sheet

Plant: CPL Brooksville, FL

Sample Location: K-1

Control Type: Bayhouse

Sample Type: Method 4 Moisture

Date: 1/19/10 Run No.: 1

Time Start: 1252 Time End: 13:06

Sample Time: 120 min min/point Total Mins. 128

Dry Bulb: °F Wet Bulb: °F VP@DP: °F

Bar. Pres: 30.00 "Hg Stack Pres: "Hg Ps: -.51 "H<sub>2</sub>O

Moisture: 6 % FDA: Gas Density Factor:

Temp: 72 °F Wind Direction: VAR Wind Speed: 3-5

Weather: Clear Thermocouple Readout: KA-8

Sample Box No.: KA-8 Meter Box No.: KA-8

Meter Y: L004 @ Delta H: 1.73 Pitot Corr.: .84

Nozzle Diameter: - inches Probe Length: 10 S.S. feet


Probe Heater Setting: 250 Nomograph Cf: -

Stack Dimensions: \_\_\_\_\_ inches

Stack Area: \_\_\_\_\_ ft<sup>2</sup>

Effective Stack Area: \_\_\_\_\_ ft<sup>2</sup>

Stack Height: \_\_\_\_\_ ft



Material Processing Rate:

Final Gas Meter Reading: 223.034 ft<sup>3</sup>

Initial Gas Meter Reading: 128.001 ft<sup>3</sup>

Total Metered Gas Volume: 95.033 ft<sup>3</sup>

Condensate Gain in Impingers: 128 mL

Weight Gain in Silica Gel: 18 g

Total Moisture Gain: 146 mL

Silica Gel Container No.: 10

Filter Number: \_\_\_\_\_

Leak Check - Meter Box:

Initial: 001 cfm @ 7 inches Hg

Final: 1002 cfm @ 5 inches Hg

Leak Check - Pitot Tubes:

Impact 3 "H<sub>2</sub>O for 15 sec: Stable Leak

Static 3 "H<sub>2</sub>O for 15 sec: Stable Leak

Test Conducted By: J. Langston A West.

O<sub>2</sub>: 13.5 % CO<sub>2</sub>: 7.0 %

Stack Test Observers: \_\_\_\_\_

Port and Traverse Point No.	Distance from Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft <sup>3</sup> )	Stack Velocity Head (H <sub>2</sub> O)	Meter Orifice Pressure Difference (H <sub>2</sub> O)		Stack Gas Temp (°F)	Sample Box Temp (°F)	Last Impinger Temp (°F)	Meter Temp (°F)	Vacuum on Sample Train ("Hg)	Oxygen Meter Reading (%O <sub>2</sub> )
					Calculated	Actual						
1-1-1		0	128.0	.34	1.73	1.73	297	248	57	70	2	
2		84	30.8	.36			297	264	52	70	2	
2-2		108	33.8	.36			296	265	50	70	2	
2		1512	36.7	.36			294	264	50	70	2	
3-1		16	39.6	.32			300	264	50	70	2	
2		20	42.6	.35			291	239	49	73	2	
4-1		24	45.6	.30			291	240	49	72	2	
2		28	48.5	.37			292	249	49	74	2	



Port and Traverse Point No.	Distance from Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft <sup>3</sup> )	Stack Velocity Head (H <sub>2</sub> O)	Meter Orifice Pressure Difference (H <sub>2</sub> O)		Stack Gas Temp (°F)	Sample Box Temp (°F)	Last Impinger Temp (°F)	Meter Temp (°F)	Vacuum on Sample Train ("Hg)	Oxygen Meter Reading (%O <sub>2</sub> )
					Calculated	Actual						
2-1-1		32	51.4	.37	1.73	1.73	290	232	53	74	2	
2		36	54.4	.37			298	242	50	74	2	
2-1		40	57.4	.35			297	250	50	74	2	
2		44	60.3	.36			295	234	49	74	2	
3-1		48	63.3	.35			295	232	49	74	2	
"		52	66.0	.32			294	240	49	75	2	
4-1		56	69.1	.30			281	237	49	74	2	
2		60	72.1	.32			293	222	48	74	2	
3-1-1		64	75.0	.42			286		50	74	2	
1		68	78.0	.39			299		50	74	2	
2-1		72	80.9	.39			299		49	75	2	
2		76	83.8	.39			299		50	75	2	
3-1		80	86.8	.42			298		50	75	2	
2		84	89.8	.39			297		49	75	2	
4-1		88	92.7	.34			296		50	76	2	
2		92	95.7	.36			296		51	77	2	
4-1-1		96	98.6	.41			291		53	76	2	
3		100	201.7	.39			298		51	77	2	
2-1		104	84.7	.39			298		50	77	2	
2		108	87.9	.35			296	247	50	76	2	
3-1		112	11.0	.37			296	252	50	76	2	
2		116	14.4	.37	1.73	1.73	295	254	50	77	2	
4-1		120	17.2	.35	1.73	1.73	294	232	50	77	2	
2		124	220.1	.35	1.73	1.73	293	245	50	77	2	
		12K	run									

← look for heat but no filter



KOOGLER AND ASSOCIATES, INC.  
INSTRUMENTAL GAS SAMPLING FIELD DATA RECORD

PLANT <u>CPL</u>				DATE <u>01-21-10</u>			
LOCATION <u>Brooksville FL</u>				EMISSION UNIT <u>Kiln #1</u>			
TEST(s) <u>CO + moisture &amp; Flows</u> <u>20% wood pellets 2 coal mills</u>				SYSTEM LEAK CHECK (Limit 1 inHg/2min)			
				Init. VAC inHg <u>15</u>		Final VAC inHg <u>15</u>	
INSTRUMENT RANGE (R) (0-XXX)				Calibration Gas Certified Concentration Value			
Instrument	Available R	Selected R	Teloger Vdc	Test	mid-gas	mid-gas	high-gas(span)
NOx (M7E)				NOx (M7E)			
SO2 (M6C)				SO2 (M6C)			
CO (M10)				CO (M10)	<u>Zero Air</u>	<u>512.9</u>	<u>1002.1</u>
THC (M25A)				THC (M25A)			
NMHC				NMHC			
TIME	Action Comment			TIME	Action Comment		
09:19	<u>Zero Air on</u>						
09:21	<u>Zero Air = 5.5</u>						
09:23	<u>Zero Air off / 1002.1 CO on</u>						
09:27	<u>1002.1 CO = 1006.009</u>						
09:29	<u>1002.1 CO off / 512.9 CO on</u>						
09:31	<u>512.9 CO = 517.777</u>						
09:33	<u>512.9 CO off / <del>Zero Air on</del></u>						
09:35	<u>Zero Air = 5.508</u>						
09:37	<u>Zero Air off</u>						
09:40	<u>1002.1 CO on</u>						
09:43	<u>1002.1 CO = 982.975</u>						
09:45	<u>1002.1 CO off / 512.9 CO on</u>						
09:48	<u>512.9 CO = 503.264</u>						
09:50	<u>512.9 CO off / Zero Air on</u>						
09:53	<u>Zero Air = 9.514</u>						
09:55	<u>Zero Air off</u>						
11:49	<u>Start 20% wood Pellet trial Run #1</u>						
14:04	<u>END 20% wood Pellet Trial Run #1</u>						
14:05	<u>to 512.9 CO on</u>						
14:08	<u>512.9 CO off / Zero Air on</u>						
14:08	<u>to 512.9 = 491.738</u>						
14:10	<u>512.9 off / Zero Air on</u>						
14:13	<u>Zero Air = 3.012</u>						
14:15	<u>Zero Air off</u>						

Direct

System



# Multiple Methods Data Sheet

Plant: CPL

Sample Location: Kiln

Control Type: B.H.

Sample Type: Method 4, moisture

Date: 1/20/00 Run No.: 1

Time Start: 11:49 Time End: 14:04

Sample Time: 129 min/point 8 Total Mins. 128

Dry Bulb: 29.49 °F Wet Bulb: — °F VP@DP: —

Bar. Pres: 29.49 "Hg Stack Pres: — "Hg Ps: -.51 "H<sub>2</sub>O

Moisture: — % FDA: — Gas Density Factor: —

Temp: 83 °F Wind Direction: VAR Wind Speed: 3-5

Weather: PC Thermocouple Readout: KA-8

Sample Box No.: KA-8 Meter Box No.: KA-8

Meter Y: 1.004 @ Delta H: 1.73 Pitot Corr.: .84

Nozzle Diameter: — inches Probe Length: 10 S.S. feet

Probe Heater Setting: 250 Nomograph Cf: —

Stack Dimensions: — inches

Stack Area: — ft<sup>2</sup>

Effective Stack Area: — ft<sup>2</sup>

Stack Height: — ft

20%  
Wood pellets

Material Processing Rate:

Final Gas Meter Reading: 319.083 ft<sup>3</sup>

Initial Gas Meter Reading: 223.209 ft<sup>3</sup>

Total Metered Gas Volume: 95.874 ft<sup>3</sup>

Condensate Gain in Impingers: 156 mL

Weight Gain in Silica Gel: 20 g

Total Moisture Gain: 176 mL

Silica Gel Container No.: 3

Filter Number: —

**Leak Check - Meter Box:**

Initial: 000 cfm @ 6 inches Hg

Final: 000 cfm @ 5 inches Hg

**Leak Check - Pitot Tubes:**

Impact 3 "H<sub>2</sub>O for 15 sec: Stable, Leak

Static 3 "H<sub>2</sub>O for 15 sec: Stable, Leak

Umbilical: KAK-100

Thermocouple: —

Probe No.: KAK-110

Pitot Tube: SS III

Test Conducted By: J Langston A. West

O<sub>2</sub>: 10.5 % CO<sub>2</sub>: 9.0 %

Stack Test Observers: —

Port and Traverse Point No.	Distance from Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft <sup>3</sup> )	Stack Velocity Head (H <sub>2</sub> O)	Meter Orifice Pressure Difference (H <sub>2</sub> O)		Stack Gas Temp (°F)	Sample Box Temp (°F)	Last Impinger Temp (°F)	Meter Temp (°F)	Vacuum on Sample Train ("Hg)	Oxygen Meter Reading (%O <sub>2</sub> )
					Calculated	Actual						
1-1		0	223.2	.41	1.73	1.73	302	7	74	78	2	
2		4	26.0	.40	↓	↓	304		64	79	2	
2-1		8	28.9	.41			304		63	79	2	
2		12	31.9	.41			305		62	79	2	
3-1		16	34.8	.39			307		63	79	2	
2		20	37.9	.42			305		63	79	2	
4-1		24	41.0	.37			306		63	80	2	
2		28	44.0	.36			305		63	80	2	



Port and Traverse Point No.	Distance from Inside Stack Wall (in.)	Clock Time	Gas Meter Reading (ft³)	Stack Velocity Head (H₂O)	Meter Orifice Pressure Difference (H₂O)		Stack Gas Temp (°F)	Sample Box Temp (°F)	Last Impinger Temp (°F)	Meter Temp (°F)	Vacuum on Sample Train ("Hg)	Oxygen Meter Reading (%O₂)
					Calculated	Actual						
2-1		32	46.9	.39	1.73	1.73	307		64	81	2	
2		36	49.9	.39			310		60	81	2	
2-1		40	52.9	.41			311		62	82	2	
2		44	55.9	.37			311		62	82	2	
3-1		48	58.8	.33			314		62	82	2	
2		52	61.8	.35			310		61	82	2	
4-1		56	64.8	.37			311		61	82	2	
2		60	67.7	.38			311		61	82	2	
3-1-1		64	70.6	.36			310		64	83	2	
2		68	74.6	.33			313		58	83	2	
2-1		72	76.7	.31			314		58	83	2	
2		76	79.6	.30			314		59	83	2	
3-1		80	82.7	.35			314		59	83	2	
2		84	85.6	.32			314		59	83	2	
4-1		88	88.6	.34			312		59	83	2	
2		92	91.6	.29			312		59	83	2	
4-1-1		96	94.5	.35			311		63	83	2	
2		100	97.5	.35			314		62	83	2	
2-1		104	100.7	.34			315		62	83	2	
2		108	103.7	.39			314		63	83	2	
3-1		112	106.9	.39			314		63	83	2	
2		116	110.0	.35			314		64	83	2	
4-1		120	113.0	.33			314		64	83	2	
2		124	116.0	.33	1.73	1.73	314		64	83	2	
		128	119.1	.33								



**KOGLER AND ASSOCIATES, INC.**  
**INSTRUMENTAL GAS SAMPLING FIELD DATA RECORD**

PLANT <b>CPL</b>				DATE <b>01-22-10</b>			
LOCATION <b>Brooksville FL</b>				EMISSION UNIT <b>Kiln #1</b>			
TEST(s) <b>CO + PM</b>				SYSTEM LEAK CHECK (Limit 1 inHg/2min)			
				Init. VAC inHg <b>15</b>		Final VAC inHg <b>15</b>	
INSTRUMENT RANGE (R) (0-XXX)				Calibration Gas Certified Concentration Value			
Instrument	Available R	Selected R	Teloger Vdc	Test	mid-gas	mid-gas	high-gas(span)
NOx (M7E)				NOx (M7E)			
SO2 (M6C)				SO2 (M6C)	<b>66-251876</b>	<b>66-251816</b>	<b>66-117907</b>
CO (M10)				CO (M10)	<b>512.9</b>	<b>1002.1</b>	<b>1510</b>
THC (M25A)				THC (M25A)			
NMHC				NMHC			
TIME	Action Comment			TIME	Action Comment		
11:09	Zero Air on			14:59	Zero Air off / Stack Gas		
11:11	Zero Air = 1.0			16:30	Start Run #1 30% wood pellets		
11:13	Zero Air off / 1510 CO on			17:39	END Run #1		
11:17	1510 CO = 1513.777			17:40	512.9 CO on		
11:19	1510 CO off / 1002.1 CO on			17:43	512.9 CO = 481.228		
11:21	1002.1 CO = 991.487			17:45	512.9 CO off / Zero Air on		
11:23	1002.1 CO off / 512.9 CO on			17:48	Zero Air = 3.5		
11:25	512.9 CO = 502.754			17:50	Zero Air off		
11:27	512.9 CO off / Zero Air on						
11:29	Zero Air = 3.505						
11:31	Zero Air off						
11:33	1510 CO on						
11:36	1510 CO = 1490.736						
11:38	1510 CO off / 1002.1 CO on						
11:40	1002.1 CO = 1016						
11:43	1002.1 CO off / 512.9 CO on						
11:46	512.9 CO = 495.243						
11:48	512.9 CO off / Zero Air on						
11:51	Zero Air = 2.003						
11:53	Zero Air off / Stack Gas						
	to start Run #1 30% wood pellets						
	End Run #1 30% wood pellets						
14:43	1002.1 CO on						
14:46	1002.1 CO = 972.964						
14:48	1002.1 CO off / 512.9 CO on						
14:51	512.9 CO = 496.482						
14:53	512.9 CO off / Zero Air on						
14:57	Zero Air = 2.003						

Direct  
 ↓  
 System

Particulate Matter Equipment Calibrations and  
Calibration Gas Certifications



# Nozzle Calibration

Date: 1-5-10


Plant Name: CPZ-Power Plant

Location: Brooksville

Source: Main Stack

Measurement Number	Inside Diameter (inches)
1	0.265
2	0.267
3	0.266
Average	0.266
Area of Nozzle	<u>38.6<sup>-5</sup></u> Ft. <sup>2</sup>

Calibrated by: R Powell



Nozzle X-Section

# Pitot Tube Calibration Measurements

Pitot Tube Identification Number: SSI

Date Calibrated: 10-8-09

Pitot Tube Assembly Level: Yes  No

Pitot Tube Openings Damaged: Yes  No  If yes, please explain: \_\_\_\_\_

$D_{tA} = \underline{0.370}$  in. ( $D_{tA} = 0.1875 - 0.3750$  in.)

$D_{tB} = \underline{0.370}$  in. ( $D_{tB} = 0.1875 - 0.3750$  in.)

$\alpha_A = \underline{3.0}^\circ (<10^\circ)$      $\alpha_B = \underline{2.5}^\circ (<10^\circ)$

$\beta_A = \underline{2.0}^\circ (<5^\circ)$      $\beta_B = \underline{2.0}^\circ (<5^\circ)$

$\gamma = \underline{0.5}^\circ$ ,     $\theta = \underline{0.5}^\circ$


$P_A = \underline{0.466}$  ( $P_A = 1.05 Dt$  to  $1.50 Dt$ )

$P_B = \underline{0.466}$  ( $P_B = 1.05 Dt$  to  $1.50 Dt$ )

$P_A + P_B = A = \underline{0.932}$  [ $A = 2x(1.05 Dt$  to  $1.50 Dt)$ ]

$Z = A \sin \gamma = \underline{<0.0}$  in. ( $<0.125$  in.)

$W = A \sin \theta = \underline{<0.0}$  in. ( $<0.031$  in.)



Comments: Pitot tubes soaked OK day of test

Calibration required? Yes  No

Calibrated by: Rodney Paul

# Post Test Thermocouple Calibration

Date: 1-5-10  
Plant Name: CP1  
Location: Brooksville  
Source: Power Plant

Thermocouple Readout No.	KAK-7
Umbilical Cord No.	KAK-100
Switch Box No.	KAK-7
Thermocouple No.	KAK-110
Average Stack Temperature °F	277
* Observed Mercury in Glass (ASTM) °F	277
Observed Thermocouple Reading °F	277

\* Per Alternative Method 2 Thermocouple Calibration Procedure (ALT-011)

Percent Difference  $\frac{(ASTM + 460) - (Thermo + 460)}{(ASTM + 460)} \times 100 =$  0.0%

Tolerance  $\pm 2$  °F

Signature: RPaul

**FIELD DATA SHEET: POST-TEST DRY GAS METER CALIBRATION  
USING CRITICAL ORIFICES**

**Koogler & Associates  
Environmental Services**

- 1) Select one critical orifice to calibrate the dry gas meter which approximates the test average delta H range.
- 2) Record barometric pressure before and after calibration procedure.
- 3) Run at tested vacuum (from Orifice Calibration Report), for a period of time necessary to achieve a minimum total volume of 5 cubic feet.
- 4) Record readings in outlined boxes below.

COMPANY: CPA - Brooksville  
 SOURCE: main stack  
 TEST DATE: 1-5-10  
 METER Y: 0.996  
 AVG. DELTA H: 1.3

METER SERIAL #: KH-7  
 CRITICAL ORIFICE SERIAL #: 1376  
 INITIAL FINAL  
 BAROMETRIC PRESSURE (in Hg): 30.13 30.13

RUN	ORIFICE NO.	K' FACTOR (AVG)	TESTED VACUUM (in Hg)	DGM READINGS (FT <sup>3</sup> )		TEMPERATURES °F		ELAPSED TIME (MIN)	DGM ΔH (in H <sub>2</sub> O)	
				INITIAL	FINAL	ORIFICE	DGM INITIAL			DGM FINAL
				1	22	0.5836	18			428.700
2	S		S	434.212	442.148	67	71	74	10.0	1.6
3	S		S	442.148	448.120	67	74	76	7.5	1.6

Test Conducted by: ROC  
 Signature: Rodney Paul  
 Date: 1-7-10



POST-TEST DRY GAS METER CALIBRATION USING CRITICAL ORIFICES

**Koogler & Associates**  
**Environmental Services**

- 1) Select one critical orifice to calibrate the dry gas meter which represents the observed operating range.
- 2) Record barometric pressure before and after calibration procedure.
- 3) Run at tested vacuum (from Orifice Calibration Report), for a period of time necessary to achieve a minimum total volume of 5 cubic feet.
- 4) Record readings in outlined boxes below, other columns are automatically calculated.

COMPANY: CPL - BROOKSVILLE, FL.

SOURCE: MAIN STACK

DATE: JANUARY 5, 2010

PRETEST Y: 0.996

METER SERIAL #: **KAK-7**

BAROMETRIC PRESSURE (in Hg):

INITIAL	FINAL	AVG (P <sub>bar</sub> )
30.13	30.13	30.13

CRITICAL ORIFICE SERIAL #: **1376**

RUN NO.	ORIFICE NO.	K' FACTOR (AVG)	TESTED VACUUM (in Hg)	DGM READINGS (FT <sup>3</sup> )			TEMPERATURES °F				ELAPSED TIME (MIN)	DGM ΔH (in H <sub>2</sub> O)	(1) V <sub>m</sub> (STD)	(2) V <sub>cr</sub> (STD)	(3) Y	(4) ΔH <sub>@</sub>
				INITIAL	FINAL	NET (V <sub>m</sub> )	ORIFICE	INITIAL	FINAL	DGM AVG						
1	22	0.5836	18	428.700	434.212	5.512	67	69	71	70	7.0	1.6	5.55	5.36	0.966	1.533
2	22	0.5836	18	434.212	442.148	7.936	67	71	74	73	10.0	1.6	7.96	7.66	0.963	1.533
3	22	0.5836	18	442.148	448.120	5.972	67	74	76	75	7.5	1.6	5.96	5.75	0.964	1.533
															AVG =	0.964

USING THE CRITICAL ORIFICES AS CALIBRATION STANDARDS:

The following equations are used to calculate the standard volumes of air passed through the DGM, V<sub>m</sub> (std), and the critical orifice, V<sub>cr</sub> (std), and the DGM calibration factor, Y. These equations are automatically calculated in the spreadsheet above.

AVERAGE DRY GAS METER CALIBRATION FACTOR, Y = 0.964

AVERAGE DELTA Y = -0.032

DELTA Y LIMIT = 0.05

IS TEST WITHIN 5%? YES

$$(1) V_m(std) = K_1 V_m Y \left[ \frac{P_{bar} + (\Delta H / 136)}{T_m} \right]$$

V<sub>m</sub>(std) = Net volume of gas sample passed through DGM, corrected to standard conditions.

K<sub>1</sub> = 17.64 °R/in. Hg

Y = DGM calibration factor

V<sub>cr</sub>(std) = Volume of gas sample passed through the critical orifice, corrected to standard conditions.

P<sub>bar</sub> = Barometric pressure at the sampling site (in. Hg).

ΔH = Orifice pressure differential (in. H<sub>2</sub>O).

θ = Total sampling time (min.)

T<sub>m</sub> = Absolute DGM avg. temperature °R

T<sub>amb</sub> = Absolute ambient temperature °R

K' = Average K' factor from Critical Orifice Calibration

$$(2) V_{cr}(std) = K \left[ \frac{P_{bar} \theta}{\sqrt{T_{amb}}} \right]$$

$$(3) Y = \frac{V_{cr}(std)}{V_m(std)}$$

$$(4) \Delta H_{@} = \left( \frac{0.75 * \theta}{V_{CR}(std)} \right)^2 * \Delta H$$

**METHOD 5 DRY GAS METER CALIBRATION USING CRITICAL ORIFICES**

- 1) Select three critical orifices to calibrate the dry gas meter which bracket the expected operating range.
- 2) Record barometric pressure before and after calibration procedure.
- 3) Run at tested vacuum (from Orifice Calibration Report), for a period of time necessary to achieve a minimum total volume of 5 cubic feet.
- 4) Record data and information in the GREEN cells, YELLOW cells are calculated.

**Koogler & Associates  
Environmental Services**

DATE: 1/31/2010 METER SERIAL #: KAK-7 BAROMETRIC PRESSURE (In Hg): INITIAL 30.06 FINAL 30.06 AVG (P<sub>bar</sub>) 30.06  
 METER PART #: KAK-7 CRITICAL ORIFICE SET SERIAL #: 1375 IF Y VARIATION EXCEEDS 2.00%, ORIFICE SHOULD BE RECALIBRATED

ORIFICE #	RUN #	K' FACTOR (AVG)	TESTED VACUUM (in Hg)	DGM READINGS (FT <sup>3</sup> )			TEMPERATURES °F				ELAPSED TIME (MIN) θ	DGM ΔH (in H <sub>2</sub> O)	(1) V <sub>m</sub> (STD)	(2) V <sub>cr</sub> (STD)	(3) Y	Y VARIATION (%)	ΔH <sub>g</sub>		
				INITIAL	FINAL	NET (V <sub>m</sub> )	Orifice	DGM INITIAL	DGM FINAL	DGM AVG									
26	1	0.7005	18	501.505	510.736	9.231	67	73	76	74.5	10.00	2.25	9.2157	9.1753	0.996		1.57		
	2	0.7005	18	510.736	519.549	8.813	67	76	78	77	9.60	2.35	8.7574	8.7165	0.995		1.56		
	3	0.7005	18	519.549	527.011	7.462	67	78	80	79	8.00	2.35	7.3874	7.3402	0.994		1.55		
															AVG =	0.995	-0.84		
22	1	0.5836	18	495.50	490.825	5.325	67	71	73	72	7.00	1.6	5.3314	5.3509	1.004		1.54		
	2	0.5836	18	490.825	496.165	5.340	67	72	73	72.5	7.00	1.6	5.3414	5.3509	1.002		1.54		
	3	0.5836	18	496.165	501.505	5.340	67	73	75	74	7.00	1.6	5.3264	5.3509	1.005		1.54		
															AVG =	1.003	0.01		
17	1	0.4452	18	527.011	534.005	6.994	67	76	78	78	12.00	0.91	6.9127	6.9976	1.012		1.49		
	2	0.4452	18	534.005	542.170	8.165	67	78	78	78	14.00	0.91	8.0701	8.1638	1.012		1.49		
	3	0.4452	18	542.170	549.759	7.589	67	78	78	78	13.00	0.91	7.5008	7.5807	1.011		1.49		
															AVG =	1.012	0.83		

**USING THE CRITICAL ORIFICES AS CALIBRATION STANDARDS:**

The following equations are used to calculate the standard volumes of air passed through the DGM, V<sub>m</sub> (std), and the critical orifice, V<sub>cr</sub> (std), and the DGM calibration factor, Y. These equations are automatically calculated in the spreadsheet above.

**AVERAGE DRY GAS METER CALIBRATION FACTOR, Y = 1.003**

**AVERAGE ΔH<sub>g</sub> = 1.53**

(1)  $V_{m(std)} = K_1 * V_m * \frac{P_{bar} + (\Delta H / 13.6)}{T_m}$

= Net volume of gas sample passed through DGM, corrected to standard conditions  
 K<sub>1</sub> = 17.64 °R/in. Hg (English), 0.3858 °K/mm Hg (Metric)  
 T<sub>m</sub> = Absolute DGM avg. temperature (°R - English, °K - Metric)

(2)  $V_{cr(std)} = K' * \frac{P_{bar} * \Theta}{\sqrt{T_{amb}}}$

= Volume of gas sample passed through the critical orifice, corrected to standard conditions  
 T<sub>amb</sub> = Absolute ambient temperature (°R - English, °K - Metric)

(3)  $Y = \frac{V_{cr(std)}}{V_{m(std)}}$

K' = Average K' factor from Critical Orifice Calibration  
 = DGM calibration factor


$\Delta H_g = \left( \frac{0.75 \theta}{V_{cr(std)}} \right) \Delta H \left( \frac{V_{m(std)}}{V_m} \right)$

# Nozzle Calibration

Date: 1/22/10  
Plant Name: CPL  
Location: Brooksville FL  
Source: Kiln

Measurement Number	Inside Diameter (inches)
1	.307
2	.305
3	.306
Average	.306
Area of Nozzle	$5.10705 \times 10^{-4}$ Ft. <sup>2</sup>

Calibrated by: Jane D Langston



Nozzle X-Section

# Post Test Thermocouple Calibration

Date: 1-19-10  
Plant Name: Central Power & Light  
Location: Brookville, FL  
Source: Kiln

Thermocouple Readout No.	KA-8
Umbilical Cord No.	KAK-100
Switch Box No.	KA-9
Thermocouple No.	KAK-110
Average Stack Temperature °F	300
* Observed Mercury in Glass (ASTM) °F	401
Observed Thermocouple Reading °F	403

\* Per Alternative Method 2 Thermocouple Calibration Procedure (ALT-011)

Percent Difference  $\frac{(ASTM + 460) - (Thermo + 460)}{(ASTM + 460)} \times 100 =$  -0.5

Tolerance  $\pm 2$  °F

Signature: \_\_\_\_\_







# Pitot Tube Calibration Measurements

Pitot Tube Identification Number: KA-SSIII

Date Calibrated: 4/1/09

Pitot Tube Assembly Level: Yes  No

Pitot Tube Openings Damaged: Yes  No  If yes, please explain: \_\_\_\_\_

$D_{tA} = 0.374$  in. ( $D_{tA} = 0.1875 - 0.3750$  in.)

$D_{tB} = 0.374$  in. ( $D_{tB} = 0.1875 - 0.3750$  in.)

$\alpha_A = 4^\circ (<10^\circ)$      $\alpha_B = 6^\circ (<10^\circ)$

$\beta_A = 2^\circ (<5^\circ)$      $\beta_B = 2^\circ (<5^\circ)$

$\gamma = 1.0^\circ$ ,     $\theta = 1.0^\circ$




$P_A = 0.496$  ( $P_A = 1.05 Dt$  to  $1.50 Dt$ )

$P_B = 0.496$  ( $P_B = 1.05 Dt$  to  $1.50 Dt$ )

$P_A + P_B = A = 0.992$  [ $A = 2x(1.05 Dt$  to  $1.50 Dt)$ ]

$Z = A \sin \gamma = 0.015$  in. ( $<0.125$  in.)

$W = A \sin \theta = 0.015$  in. ( $<0.031$  in.)



Comments: Measurements o.k.  
Day of test  
James D. Layton

Calibration required? Yes  No

Calibrated by: James D. Layton

**FIELD DATA SHEET: POST-TEST DRY GAS METER CALIBRATION  
USING CRITICAL ORIFICES**

**Koogler & Associates  
Environmental Services**

- 1) Select one critical orifice to calibrate the dry gas meter which approximates the test average delta H range.
- 2) Record barometric pressure before and after calibration procedure.
- 3) Run at tested vacuum (from Orifice Calibration Report), for a period of time necessary to achieve a minimum total volume of 5 cubic feet.
- 4) Record readings in outlined boxes below.

COMPANY: CPL  
 SOURCE: Kilo #1  
 TEST DATE: 01-25-10  
 METER Y: 1.004  
 AVG. DELTA H: 25

METER SERIAL #: 1CA.8  
 CRITICAL ORIFICE SERIAL #: 1376  
 INITIAL FINAL  
 BAROMETRIC PRESSURE (in Hg): 29.83 29.83

RUN	ORIFICE NO.	K' FACTOR (AVG)	TESTED VACUUM (in Hg)	DGM READINGS (FT <sup>3</sup> )		TEMPERATURES °F			ELAPSED TIME (MIN)	DGM ΔH (in H <sub>2</sub> O)
				INITIAL	FINAL	ORIFICE	DGM INITIAL	DGM FINAL		
1	26	0.7005	18	<del>396.553</del> 396.351	402.851	70	71	71	7.0	2.6
2	26	0.7005	18	402.851	409.166	70	71	71	9.0	2.6
3	26	0.7005	18	409.166	415.499	70	71	71		2.6

Test Conducted by: C. EDWARDS  
 Signature: [Signature]  
 Date: 01-25-10



POST-TEST DRY GAS METER CALIBRATION USING CRITICAL ORIFICES

**Koogler & Associates**  
**Environmental Services**

- 1) Select one critical orifice to calibrate the dry gas meter which represents the observed operating range.
- 2) Record barometric pressure before and after calibration procedure.
- 3) Run at tested vacuum (from Orifice Calibration Report), for a period of time necessary to achieve a minimum total volume of 5 cubic feet.
- 4) Record readings in outlined boxes below, other columns are automatically calculated.

COMPANY: CPL

SOURCE: KILN#1

DATE: 1/25/10

PRETEST Y: 1.004

METER SERIAL #: KA-8  
CRITICAL ORIFICE SERIAL #: 1376

BAROMETRIC PRESSURE (in Hg): INITIAL 29.83 # FINAL 29.83 AVG (P<sub>bar</sub>) 29.83

RUN NO.	ORIFICE NO.	K' FACTOR (AVG)	TESTED VACUUM (in Hg)	DGM READINGS (FT <sup>3</sup> )			TEMPERATURES °F				ELAPSED TIME (MIN)	DGM ΔH (in H <sub>2</sub> O)	(1) V <sub>m</sub> (STD)	(2) V <sub>cr</sub> (STD)	(3) Y	(4) ΔH <sub>@</sub>
				INITIAL	FINAL	NET (V <sub>m</sub> )	ORIFICE	DGM INITIAL	DGM FINAL	DGM AVG						
1	26	0.7005	18	396.553	402.851	6.298	71	70	70	70	7.0	2.6	6.30	6.35	1.008	1.778
2	26	0.7005	18	402.851	409.166	6.315	71	70	70	70	7.0	2.6	6.31	6.35	1.006	1.778
3	26	0.7005	18	409.166	415.499	6.333	71	70	70	70	7.0	2.6	6.33	6.35	1.003	1.778
													AVG =		1.006	

USING THE CRITICAL ORIFICES AS CALIBRATION STANDARDS:

The following equations are used to calculate the standard volumes of air passed through the DGM, V<sub>m</sub> (std), and the critical orifice, V<sub>cr</sub> (std), and the DGM calibration factor, Y. These equations are automatically calculated in the spreadsheet above.

AVERAGE DRY GAS METER CALIBRATION FACTOR, Y = 1.006

$$(1) V_m(std) = K_1 V_m Y \left[ \frac{P_{bar} + (\Delta H / 136)}{T_m} \right]$$

V<sub>m</sub>(std) = Net volume of gas sample passed through DGM, corrected to standard conditions.

AVERAGE DELTA Y = 0.002

K<sub>1</sub> = 17.64 °R/in. Hg

Y = DGM calibration factor

DELTA Y LIMIT = 0.05

V<sub>cr</sub>(std) = Volume of gas sample passed through the critical orifice, corrected to standard conditions.

IS TEST WITHIN 5%? YES

P<sub>bar</sub> = Barometric pressure at the sampling site (in. Hg).

ΔH = Orifice pressure differential (in. H<sub>2</sub>O).

θ = Total sampling time (min.)

T<sub>m</sub> = Absolute DGM avg. temperature °R

T<sub>amb</sub> = Absolute ambient temperature °R

K' = Average K' factor from Critical Orifice Calibration

$$(2) V_{cr}(std) = K' \left[ \frac{P_{bar} \theta}{\sqrt{T_{amb}}} \right]$$

$$(3) Y = \frac{V_{cr}(std)}{V_m(std)}$$

$$(4) \Delta H_{@} = \left( \frac{0.75 * \theta}{V_{CR}(std)} \right)^2 * \Delta H$$

**METHOD 5 DRY GAS METER CALIBRATION USING CRITICAL ORIFICES**

- 1) Select three critical orifices to calibrate the dry gas meter which bracket the expected operating range.
- 2) Record barometric pressure before and after calibration procedure.
- 3) Run at tested vacuum (from Orifice Calibration Report), for a period of time necessary to achieve a minimum total volume of 5 cubic feet.
- 4) Record data and information in the GREEN cells, YELLOW cells are calculated.

**Koogler & Associates**  
**Environmental Services**

DATE:	11/15/2009	METER SERIAL #:	KA-8	BAROMETRIC PRESSURE (In Hg):	INITIAL 29.82	FINAL 29.82	AVG (P <sub>bar</sub> )	29.82	IF Y VARIATION EXCEEDS 2.00%, ORIFICE SHOULD BE RECALIBRATED									
METER PART #:	KA-8	CRITICAL ORIFICE SET SERIAL #:	1378															
ORIFICE #	RUN #	K' FACTOR (AVG)	TESTED VACUUM (In Hg)	DGM READINGS (FT <sup>3</sup> )			TEMPERATURES °F				ELAPSED TIME (MIN) θ	DGM ΔH (In H <sub>2</sub> O)	(1) V <sub>m</sub> (STD)	(2) V <sub>cr</sub> (STD)	(3) Y	Y VARIATION (%)	ΔH <sub>e</sub>	
				INITIAL	FINAL	NET (V <sub>m</sub> )	AMBIENT	DGM INLET INITIAL FINAL	DGM OUTLET INITIAL FINAL	DGM AVG								
17	1	0.4452	18	579.862	585.113	5.251	77	79	79	80	80	79.5	9.00	1	5.1354	5.1576	1.004	1.68
	2	0.4452	18	585.113	590.343	5.230	77	79	79	80	81	79.76	9.00	1	5.1125	5.1576	1.009	1.67
	3	0.4452	18	590.343	595.560	5.217	78	79	80	81	81	80.25	9.00	1	5.0951	5.1528	1.011	1.68
												AVG =		1.008	0.40			
22	1	0.5836	18	563.779	569.144	5.365	77	79	79	80	80	79.5	7.00	1.8	5.2572	5.2585	1.000	1.78
	2	0.5836	18	569.144	574.504	5.360	77	79	79	80	80	78.5	7.00	1.8	5.2523	5.2585	1.001	1.76
	3	0.5836	18	574.504	579.862	5.358	77	79	79	80	80	79.5	7.00	1.8	5.2504	5.2585	1.002	1.76
												AVG =		1.001	-0.32			
26	1	0.7005	18	595.560	602.881	7.321	78	80	80	81	81	80.5	8.00	2.6	7.1747	7.2088	1.004	1.77
	2	0.7005	18	602.881	608.384	5.503	78	80	80	81	81	80.5	6.00	2.6	5.3931	5.4051	1.002	1.77
	3	0.7005	18	608.384	613.880	5.496	78	80	80	81	81	80.5	6.00	2.6	5.3862	5.4051	1.004	1.77
												AVG =		1.003	-0.08			

**USING THE CRITICAL ORIFICES AS CALIBRATION STANDARDS:**

The following equations are used to calculate the standard volumes of air passed through the DGM, V<sub>m</sub> (std), and the critical orifice, V<sub>cr</sub> (std), and the DGM calibration factor, Y. These equations are automatically calculated in the spreadsheet above.

(1) 
$$Vm_{(std)} = K_1 * Vm * \frac{Pbar + (\Delta H / 13.6)}{Tm}$$
 = Net volume of gas sample passed through DGM, corrected to standard conditions  
 K<sub>1</sub> = 17.64 °R/in. Hg (English), 0.3858 °K/mm Hg (Metric)  
 T<sub>m</sub> = Absolute DGM avg. temperature (°R - English, °K - Metric)

(2) 
$$Vcr_{(std)} = K' * \frac{Pbar * \Theta}{\sqrt{Tamb}}$$
 = Volume of gas sample passed through the critical orifice, corrected to standard conditions  
 T<sub>amb</sub> = Absolute ambient temperature (°R - English, °K - Metric)

(3) 
$$Y = \frac{Vcr_{(std)}}{Vm_{(std)}}$$
 = Average K' factor from Critical Orifice Calibration  
 = DGM calibration factor

AVERAGE DRY GAS METER CALIBRATION FACTOR, Y = **1.004**

AVERAGE ΔH<sub>e</sub> = **1.73**

$$\Delta H_e = \left( \frac{0.75 \theta}{V_{cr}(std)} \right) \Delta H \left( \frac{V_m(std)}{V_m} \right)$$

**KOGLER & ASSOCIATES, Inc.**  
**THERMOCOUPLE CALIBRATION**

"K" TYPE										Average % Δ	Average Δ (F°)
Probe ID	Ice			Ambient			Hot Oil				
	NIST (F°)	Probe (F°)	% Δ	NIST (F°)	Probe (F°)	% Δ	NIST (F°)	Probe (F°)	% Δ		
KAK-5	36	37	-2.8	74	73	1.4	406	404	0.5	-0.3	-0.3
KAK-8	38	39	-2.6	74	74	0.0	405	406	-0.2	-1.0	-1.0
KAK-9	36	37	-2.8	74	73	1.4	406	408	-0.5	-0.6	-0.6
KAK-10	36	36	0.0	92	91	1.1	405	407	-0.5	0.2	0.2
KAK-11	33	32	3.0	92	91	1.1	402	402	0.0	1.4	1.4
KAK-14	34	34	0.0	85	84	1.2	395	395	0.0	0.4	0.4
KAK-20	34	34	0.0	85	84	1.2	399	400	-0.3	0.3	0.3
KAK-35	36	36	0.0	74	74	0.0	401	401	0.0	0.0	0.0
KAK-36	34	36	-5.9	86	84	2.3	402	406	-1.0	-1.5	-1.5
KAK-50	36	37	-2.8	86	86	0.0	401	401	0.0	-0.9	-0.9
KAK-51	36	37	-2.8	74	72	2.7	403	404	-0.2	-0.1	-0.1
KAK-52	35	37	-5.7	86	85	1.2	401	400	0.2	-1.4	-1.4
KAK-60	36	36	0.0	86	85	1.2	404	404	0.0	0.4	0.4
KAK-61	36	37	-2.8	86	85	1.2	399	401	-0.5	-0.7	-0.7
KAK-62	34	35	-2.9	86	85	1.2	400	402	-0.5	-0.8	-0.8
KAK-63A	36	37	-2.8	85	84	1.2	398	398	0.0	-0.5	-0.5
KAK-63	36	36	0.0	84	84	0.0	401	402	-0.2	-0.1	-0.1
KAK-64	36	37	-2.8	85	84	1.2	400	401	-0.3	-0.6	-0.6
KAK-65	36	34	5.6	86	86	0.0	397	399	-0.5	1.7	1.7
KAK-70	36	36	0.0	85	85	0.0	400	401	-0.3	-0.1	-0.1
KAK-71	36	37	-2.8	84	84	0.0	394	395	-0.3	-1.0	-1.0
KAK-72A	34	34	0.0	86	85	1.2	394	393	0.3	0.5	0.5
KAK-72	34	33	2.9	86	85	1.2	393	393	0.0	1.4	1.4
KAK-75	34	34	0.0	86	85	1.2	400	401	-0.3	0.3	0.3
KAK-78	36	36	0.0	86	86	0.0	396	397	-0.3	-0.1	-0.1
KAK-80	36	36	0.0	86	85	1.2	396	396	0.0	0.4	0.4
KAK-111	36	36	0.0	84	83	1.2	397	398	-0.3	0.3	0.3
KAK-110	34	33	2.9	85	84	1.2	401	403	-0.5	1.2	1.2
KAK-112	36	37	-2.8	85	85	0.0	397	398	-0.3	-1.0	-1.0
Secondary Standard Thermocouple with Hand Held OMEGA (HH 509 R) s/n 51001062											
KAK # 1	35	37	-5.7	84	83	1.2	406	408	-0.5	-1.7	-1.7
KAK # 2	36	36	0.0	84	84	0.0	402	402	0.0	0.0	0.0

DATE: 6/23-24/2009  
 TESTER: J. Langston, C. Enwall

# Liquid Technology Corporation

Industry Leader in Specialty Gases, Equipment and Service

## Certificate of Analysis - EPA PROTOCOL GAS -

Customer Koogler & Associates (Gainesville, Florida)  
Date October 30, 2008  
Delivery Receipt DR-22922  
Gas Standard 500.0 ppm Propane, 500.0 ppm CO/Nitrogen - EPA PROTOCOL  
Final Analysis Date October 30, 2008  
Expiration Date October 30, 2011

Component Propane, Carbon Monoxide  
Balance Gas Nitrogen

Analytical Data: DO NOT USE BELOW 150 psig  
EPA Protocol, Section No. 2.2, Procedure G-1

### Reported Concentrations

**Propane: 520.2 ppm +/- 5.2 ppm**  
**Carbon Monoxide: 512.9 ppm +/- 5.1 ppm**  
**Nitrogen: Balance**

### Reference Standards:

SRM/GMIS:	GMIS/GMIS	GMIS/GMIS
Cylinder Number:	CC-166431/CC-231417	CC-166528/CC-115896
Concentration:	494.8 ppm C3H8/1003.9 ppm C3H8.	496.3 ppm CO/755.8 ppm CO
Expiration Date:	05/02/12 - 04/07/10	04/06/09 - 08/11/09

### Certification Instrumentation

Component:	Propane	Carbon Monoxide
Make/Model:	HP5890-II	Nicolet - NEXUS 470
Serial Number:	3336A59393	AEP99000154
Principal of Measurement:	GC-FID	FTIR
Last Calibration:	October 02, 2008	October 23, 2008

### Cylinder Data

Cylinder Serial Number: CC-251876      Cylinder Outlet: CGA 350  
Cylinder Volume: 140 Cubic Feet      Cylinder Pressure: 2000 psig, 70°F  
Analytical Uncertainty and NIST Traceability are in compliance with EPA-600/R-97/121.

Certified by:  
Date:

  
October 30, 2008

**Unmatched Excellence**

# Liquid Technology Corporation

Industry Leader in Specialty Gases, Equipment and Service

## Certificate of Analysis

### - EPA PROTOCOL GAS -

Customer Koogler & Associates (Gainesville, Florida)  
Date October 30, 2008  
Delivery Receipt DR-22922  
Gas Standard 1000 ppm Propane, 1000 ppm CO/Nitrogen - EPA PROTOCOL  
Final Analysis Date October 30, 2008  
Expiration Date October 30, 2011

Component Propane, Carbon Monoxide  
Balance Gas Nitrogen

Analytical Data: **DO NOT USE BELOW 150 psig**  
EPA Protocol, Section No. 2.2, Procedure G-1

#### Reported Concentrations

**Propane: 1017.0 ppm +/- 10 ppm**  
**Carbon Monoxide: 1002.1 ppm +/- 10 ppm**  
**Nitrogen: Balance**

#### Reference Standards:

SRM/GMIS:	GMIS	GMIS
Cylinder Number:	CC-231417	CC-159055
Concentration:	1003.9 ppm C3H8/Nitrogen	999.5 ppm CO/Nitrogen
Expiration Date:	04/07/10	08/18/09

#### Certification Instrumentation


Component:	Propane	Carbon Monoxide
Make/Model:	HP5890-II	Nicolet - NEXUS 470
Serial Number:	3336A59393	AEP99000154
Principal of Measurement:	GC-FID	FTIR
Last Calibration:	October 02, 2008	October 23, 2008

#### Cylinder Data

Cylinder Serial Number: CC-251816      Cylinder Outlet: CGA 350  
Cylinder Volume: 140 Cubic Feet      Cylinder Pressure: 2000 psig, 70°F  
Analytical Uncertainty and NIST Traceability are in compliance with EPA-600/R-97/121.

Certified by:

Date:

  
October 30, 2008

**Unmatched Excellence**

# Liquid Technology Corporation

Industry Leader in Specialty Gases, Equipment and Service

## Certificate of Analysis - EPA PROTOCOL GAS -

Customer Koogler & Associates (Gainesville, Florida)  
Date August 31, 2007  
Delivery Receipt DR-19963  
Gas Standard 1500 ppm CO, 3000 ppm Propane/Nitrogen-EPA PROTOCOL  
Final Analysis Date August 31, 2007  
Expiration Date August 31, 2010

Components Carbon Monoxide, Propane  
Balance Gas Nitrogen

Analytical Data: **DO NOT USE BELOW 150 psig**  
EPA Protocol, Section No. 2.2, Procedure G-1

Replicate Concentrations  
**Carbon Monoxide: 1510.0 ppm +/- 15 ppm**  
**Propane: 2895.3 ppm +/- 28 ppm**  
**Nitrogen: Balance**

### Reference Standards:

SRM/GMIS:	GMIS	GMIS
Cylinder Number:	CC-158957	CC-125482
Concentration:	1505.7 ppm CO/Nitrogen	2865.1 ppm Propane/Nitrogen
Expiration Date	08/08/09	11/04/09

### Certification Instrumentation

Component:	Carbon Monoxide	Propane
Make/Model:	Nicolet - NEXUS 470	HP5890 -II
Serial Number:	AEP99000154	3336A59393
Principal of Measurement:	FTIR	GC (FID)
Last Calibration:	August 01, 2007	August 01, 2007

### Cylinder Data

Cylinder Serial Number:	CC-251950	Cylinder Outlet:	CGA 350
Cylinder Volume:	140 Cubic Feet	Cylinder Pressure:	2000 psig, 70 F

Analytical Uncertainty and NIST Traceability are in compliance with EPA-600/R-97/121.


Certified by:   
Date: August 31, 2007

*Unmatched Excellence*



Plant Operating Data

Electrabel  
Regentlaan 8  
1000 Brussels  
Belgium

  
Celebrating 125 years  
**Alfred H Knight**

Page 1 of 1

**CERTIFICATE OF ANALYSIS**

**CERTIFICATE NUMBER** : 45978  
**DATE OF ISSUE** : 27th March 2009  
**OUR REFERENCE** : 290147.E  
**MATERIAL** : Woodpellets  
**VESSEL** : SAGA EXPLORER  
**ELECTRABEL LOT** : 0902005 A  
**SUPPLIER CODE** : USA05  
**SAMPLED** : On Discharge  
**DATE SAMPLED** : 20th-21st March 2009  
**PORT** : Vlissingen Ovet Terminal, Netherlands  
**DESTINATION** : Antwerpen Kaai 95  
**WEIGHT** : 4425.572 Mt

**Report of Analysis**

PARAMETER	UNIT	AS FOUND	AS FOUND	AS FOUND	TEST METHOD
TOTAL MOISTURE	%	4,2	-	-	CEN/TS 14774
ASH CONTENT	%	0,5	-	-	CEN/TS 14775
VOLATILES	%	80,2	84,1	84,1	CEN/TS 15148
FIXED CARBON	%	15,1	15,9	15,9	By Difference
TOTAL SULPHUR	%	0,02	0,02	0,02	CEN/TS 15289
CHLORINE	ppm	67	70	70	CEN/TS 15289
FLUORINE	ppm	34	35	35	ASTM D3761
ARSENIC	ppm	0,2	0,2	0,2	ICP/OES
CARBON	%	49,6	52,0	52,0	CEN/TS 15104
HYDROGEN	%	5,92	6,18	6,21	CEN/TS 15104
NITROGEN	%	0,10	0,10	0,10	CEN/TS 15104
OXYGEN	%	39,7	41,5	41,7	By Difference
GROSS CALORIFIC VALUE	KCal/Kg	4704	4942	4935	CEN/TS 14918
NET CALORIFIC VALUE	MJ/Kg	19,694	20,564	20,563	CEN/TS 14918
NET CALORIFIC VALUE	MJ/Kg	4389	-	-	CEN/TS 14918
NET CALORIFIC VALUE	MJ/Kg	18,377	-	-	CEN/TS 14918
SiO2 IN ASH	%	-	21,04	-	ASTM D4326
EMISSION FACTOR**	(CO2/TJ)	99	-	-	2003/87/EN

\* Net Calorific Value @ Constant Volume


\*\* Emission Factor as per European Parliament Directive 2003/87/EN

For and on behalf of  
**KNIGHT ENERGY SERVICES LIMITED**



**KNIGHT ENERGY SERVICES LIMITED**  
De Hoogens 36, 4254 XW Sleenwijk, The Netherlands  
Tel : (31) 183307050 Fax : (31) 183304502  
Email : arno.kant@hna-xrf.nl

Electrabel  
Regentlaan 8  
1000 Brussels  
Belgium

  
Celebrating 125 years  
**Alfred H Knight**

**CERTIFICATE OF ANALYSIS**

CERTIFICATE NUMBER : 45979  
DATE OF ISSUE : 27th March 2009  
OUR REFERENCE : 290147 F  
MATERIAL : Woodpellets  
VESSEL : SAGA EXPLORER  
ELECTRABEL LOT : 0902002 A  
SUPPLIER CODE : USA05  
SAMPLED : On Discharge  
DATE SAMPLED : 20th-21st March 2009  
PORT : Vlissingen Ovet Terminal, Netherlands  
DESTINATION : Rodenhuize Power Plant  
WEIGHT : 40198.889 Mt

**Report of Analysis**

PARAMETER	UNIT	AS	BS	TEST METHOD
TOTAL MEQ	%	4,2	-	CEN/TS 14774
ASH CONTENT	%	0,5	-	CEN/TS 14775
VOLATILES	%	80,5	84,4	CEN/TS 15148
FIXED CARBON	%	14,9	15,6	By Difference
TOTAL SULPHUR	%	0,03	0,03	CEN/TS 15289
CHLORINE	ppm	67	70	CEN/TS 15289
FLUORINE	ppm	29	30	ASTM D3761
ARSENIC	ppm	0,2	0,2	ICP/OES
CARBON	%	49,8	52,3	CEN/TS 15104
HYDROGEN	%	5,98	6,27	CEN/TS 15104
NITROGEN	%	0,10	0,10	CEN/TS 15104
OXYGEN	%	39,4	41,1	By Difference
GROSS CALORIFIC VALUE	KCal/Kg	4723	4928	CEN/TS 14918
NET CALORIFIC VALUE	MJ/Kg	19,775	20,831	CEN/TS 14918
"	KCal/Kg	4406	-	CEN/TS 14918
"	MJ/Kg	18,447	-	CEN/TS 14918
SO2 IN ASH	%	-	21,14	ASTM D4326
EMISSION FACTOR	tCO2/tJ	99	-	2003/87/EN

\* Net Calorific Value @ Constant Volume

\*\* Emission Factor as per European Parliament Directive 2003/87/EN

For and on behalf of  
**KNIGHT ENERGY SERVICES LIMITED**



**KNIGHT ENERGY SERVICES LIMITED**  
De Hoogens 36, 4254 XW Sleeuwijk, The Netherlands  
Tel : (31) 183307050 Fax : (31) 183304502  
Email : arno.kant@lms-xrf.nl

Bankwerkerstraat 16  
 3077 MB Rotterdam  
 P.O. Box 91244  
 3007 ME Rotterdam  
 The Netherlands  
 T. +31 (0)10-28 23 292  
 F. +31 (0)10-28 23 273  
 e-mail: info@tlr.nl  
 website: www.tlr.nl



**Analytical Report**

To whom it may concern

Reportnr.	: 182737 version 2	Disponent Number	: 41153
Product recognized as	: Hout/Wood/Bois/Holz/Madera	Sampling Date	: 21-Apr-2009
Product Specification	: Wood Fuel Pellets (White)	Sample size (kg)	: 3,051
Reference		Sealed / Seal Code	: No /
AYWB / BarCode	: 6164	Sample Arrival Date	: 21-Apr-2009 13:41
Packing	: Plastic	ReportDate Version	: 27-Apr-2009 17:17
Sample Type	: BIS		
Seller/Unloader	: Green Circle Bio Energy Inc.	TonnageEx Lot (mt)	: 11148,000
Ex	: Star Fuji / Star Fraser	Lot/Colli Number	: 1
Hold/Batch Number	: 99190000	Destination	: ESSENT GTB
Buyer	: Essent Trading International S.A. (ETISA)		
Disp. SampleType	: Loadport		
Disp. Remark	: Pre-shipment sample Green Circle		

**Preparation**

**Common**

**Parameter**

Amount (a.r.)	Amount (o.d.)	Amount (as det.)
---------------	---------------	------------------

Preparation sample

Biomass preparation according CEN14780&CEN14418

Q

**Composition Determination**

**Common**

**Parameter**

Amount (a.r.)	Amount (o.d.)	Amount (as det.)
---------------	---------------	------------------

AFT (oxid) DT

1180

gr.C

Q

AFT (oxid) ST

1180

gr.C

Q

AFT (oxid) HT

1180

gr.C

Q

AFT (oxid) FT

1220

gr.C

Q

particles >4 mm

0,88

%

particles >2 - <4 mm

10,03

%

particles 1> - <2 mm

37,88

%

particles >0,5 - <1 mm

28,02

%

particles >0,213 - <0,5 mm

14,01

%

particles >0,1 - <0,212mm

6,60

%

particles <0,1mm

2,47

%

**Metal and other elements**

**Parameter**

Amount (a.r.)	Amount (o.d.)	Amount (as det.)
---------------	---------------	------------------

Cl (Chlorine)

< 0,010

%

Q

**Ash Determination**

**Common**

**Parameter**

Amount (a.r.)	Amount (o.d.)	Amount (as det.)
---------------	---------------	------------------


Demanded 21-Apr-2009 by PBL

Analyses according to annex

Drs. ing. H. Janssens Technical Director TLR International Laboratories



AGB Amro Bank Rotterdam; Account no. 44-11-1111 BTW nr. / VAT no. NL000000001  
 All our services are subjected to General conditions applicable as deposited at the Chamber of Commerce Rotterdam (no. 24130490) and at the registry of the District Court of Rotterdam. Those conditions are available to you on request.  
 TLR, Technisch Laboratorium Rotterdam B.V. is also registered at the register of Laboratories recognised test laboratories under no. LCH10  
 Findings are based on the sample as submitted. TLR does not assume responsibility for selection, representativity and identifications such as codes, markings or product names.





Bankwerkerstraat 16  
3077 MB Rotterdam  
P.O. Box 81244  
3007 ME Rotterdam  
The Netherlands  
T. +31 (0)10-28 23 292  
F. +31 (0)10-28 23 273  
e-mail: info@tlr.nl  
website: www.tlr.nl



## Analytical Report

Reportnr.	: 182737 version 2	Disponent Number	: 41153
Product recognized as	: Hout/Wood/Bois/Holz/Madera	Sampling Date	: 21-Apr-2009
Product Specification	: Wood Fuel Pellets (White)	Samplesize (kg)	: 3,051
Reference		Sealed / Seal Code	: No /
AWB / BarCode	: 6164	Sample Arrival Date	: 21-Apr-2009 13:41
Packing	: Plastic	ReportDate Version	: 27-Apr-2009 17:17
Sample Type	: BIS		

Q - Analysis accredited by RvA

This is version number 2 of the certificate. It cancels and replaces version number 1.



Demanded 21-Apr-2009 by PBL

Analyses according to annex

Drs. ing. H. Janssens Technical Director TLR International Laboratories

Page 3 of 4

**FOSFA** Gafta  
INTERNATIONAL



ABN Amro Bank Rotterdam, account no. 440749 551 0111, NL 200400 880 801  
All our services are subject to the General Conditions applicable to the Chamber of Commerce Rotterdam (no 24120480)  
and at the registry of the District Court of Rotterdam. These conditions will be sent to you upon your request.  
T.L.R. Technisch Laboratorium Rotterdam B.V. is also registered in the register of Labcode recognised test laboratories' under no.  
LC/18  
Findings are based on the sample as submitted. TLR does not assume responsibility for selection, representativity and identifications  
such as codes, markings or product names.



Bankwerkerstraat 16  
 3077 MB Rotterdam  
 P.O. Box 91244  
 3007 ME Rotterdam  
 The Netherlands  
 T. +31 (0)10-26 23 292  
 F. +31 (0)10-28 23 273  
 e-mail: info@tlr.nl  
 website: www.tlr.nl

**Analytical Report**

Reportnr.	: 182737 version 2	Disponent Number	: 41153
Product recognized as	: Hout/Wood/Bois/Holz/Madera	Sampling Date	: 21-Apr-2009
Product Specification	: Wood Fuel Pellets (White)	Samplesize (kg)	: 3,051
Reference		Sealed / Seal Code	: No /
AWB / BarCode	: 6164	Sample Arrival Date	: 21-Apr-2009 13:41
Packing	: Plastic	ReportDate Version	: 27-Apr-2009 17:17
Sample Type	: BIS		

**ANNEX**

**Method Descriptions**

**Composition Determination**

**Common**

**Method Description**

Determination of fusibility of ash; temperature-tube method

**Metal and other elements**

**Method Description**

Determination of fluoride (F); IC method

**Contaminations:**

**Metal and other elements**

**Method Description**

Determination of arsenic (As); hydrid-AAS, Destruction :NEN-EN 14084 ; analysis: draft NEN-EN 14546/(14627)

Determination of Chromium (Cr);AAS.

Determination of cobalt (Co); AAS

Determination of copper (Cu); AAS, Equivalent to NEN-EN-ISO 6869

Wood: own method

Determination of fluoride (F); IC method

Determination of lead (Pb); grafit AAS, Destruction :NEN-EN 14084 ; analysis: NEN-EN 14083

Determination of manganese (Mn); AAS. Equivalent to NEN-EN-ISO 6869

Wood: own method

Determination of mercury (Hg); AAS, Destruction :NEN-EN 14084 ; analysis: NEN-EN 13806

Determination of selen (Se); AAS

Determination of vanadium (V); AAS

Determination of zinc (Zn); AAS, Eq. to NEN-EN-ISO 6869

Wood: own method

50

Method Code  
 NEN-EN 14084  
 Own method

Method Code  
 Own method

Method Code  
 Own method

Method Code  
 Own method

Method Code  
 Own method

Method Code  
 Own method

Method Code  
 Own method

Method Code  
 Own method

Method Code  
 Own method

Method Code  
 Own method

Method Code  
 Own method

Method Code  
 Own method

Method Code  
 Own method

Method Code  
 Own method

Method Code  
 Own method

Method Code  
 Own method

Demand 21-Apr-2009 by PBL  
 Analyses according to annex  
 Drs. ing. H. Janssens Technical Director TLR International Laboratories



ABN Nieuw Bank Rotterdam, Account no. 4100 49 91 10000000000000000001  
 All our services are subjected to technical Control Requests by the Chamber of Commerce Rotterdam (no 24130-00) and all the registry of the District Court of Rotterdam. Those conditions will be sent to you upon your request.  
 T.L.R. Technisch Laboratorium Rotterdam B.V. is also registered in the register of 'Laboratory recognised test laboratories' under no. LE210  
 Findings are based on the sample as submitted. TLR does not assume responsibility for selection, representativity and identifications such as codes, markings or product names.





STANDARD LABORATORIES INC.  
NORTHERN DIVISION  
P.O. BOX 214  
CRESSON, PA 16630  
(814) 886-7400  
STANDARD LABORATORIES, INC.

DATE: 8-4-2009  
SAMPLE NO. 1005096

RILEY POWER, INC.  
5 NEPONSET ST.  
P.O. BOX 15040  
WORCESTER,, MA. 01615-0040

SAMPLE ID: WOOD PELLETS #53258

OPERATING CO.:  
SAMPLED BY: CUSTOMER PROVIDED  
MINE:  
LOCATION:

DATE SAMPLED: 7/30/09  
WEATHER:  
GROSS WEIGHT:

DATE RECEIVED: 7/30/09

OTHER ID:

CERTIFICATE OF ANALYSIS

	ASTM METHOD	AS RECEIVED	DRY BASIS
MOISTURE	D2961 D3302 D3173	6.45%	
VOLATILE	D3175M	79.47%	84.95%
FIXED CARBON	D3172	13.44%	14.37%
ASH	D3174	0.64%	0.68%
SULFUR	D4239 METHOD B	0.12%	0.12%
CARBON	D3178 D5373	47.49%	50.76%
HYDROGEN	D3178 D5373	5.81%	6.21%
NITROGEN	D3179 D5373	0.15%	0.16%
OXYGEN	D3176	39.34%	42.07%
BTU/LB	D5865	8417	8998
MAF BTU/LB			9059
LBS OF SO2 PER MILLION BTU			0.27
LBS OF SULFUR PER MILLION BTU		0.143	
CHLORINE	D4208	153ppm	163ppm

APPROVED BY 

APPROVED BY 

Page 1 of 3  
370

BLACK SEAL ANALYSIS

FOR YOUR PROTECTION THIS DOCUMENT HAS  
BEEN PRINTED ON CONTROLLED PAPER STOCK.  
NOT VALID IF ALTERED.





STANDARD LABORATORIES INC.  
NORTHERN DIVISION  
P. O. BOX 214  
CRESSON, PA 16630  
(814) 886-7400

STANDARD LABORATORIES, INC.

DATE: 8- 4-2009  
SAMPLE NO. 1005096

RILEY POWER, INC.  
5 NEPONSET ST.  
P.O. BOX 15040  
WORCESTER,, MA. 01615-0040

SAMPLE ID: WOOD PELLETS #53258

OPERATING CO. :  
SAMPLED BY: CUSTOMER PROVIDED  
MINE:  
LOCATION:

DATE SAMPLED: 7/30/09  
WEATHER:  
GROSS WEIGHT:

DATE RECEIVED: 7/30/09

OTHER ID:

CERTIFICATE OF ANALYSIS

ASH FUSION TEMPERATURE(S)

	D1857	REDUCING ATMOSPHERE	
INITIAL DEFORMATION			2185
SOFTENING TEMPERATURE			2190
HEMISPHERICAL TEMPERATURE			2200
FLUID TEMPERATURE			2210

	D1857	OXIDIZING ATMOSPHERE	
INITIAL DEFORMATION			2190
SOFTENING TEMPERATURE			2200
HEMISPHERICAL TEMPERATURE			2210
FLUID TEMPERATURE			2220

APPROVED BY

APPROVED BY

BLACK SEAL ANALYSIS

FOR YOUR PROTECTION THIS DOCUMENT HAS  
BEEN PRINTED ON CONTROLLED PAPER STOCK.  
NOT VALID IF ALTERED.



STANDARD LABORATORIES INC.  
NORTHERN DIVISION  
P.O. BOX 214  
CRESSON, PA 16630  
(814) 886-7400

STANDARD LABORATORIES, INC.

DATE: 8-4-2009  
SAMPLE NO. 1005096

RILEY POWER, INC.  
5 NEPONSET ST.  
P.O. BOX 15040  
WORCESTER,, MA. 01615-0040

SAMPLE ID: WOOD PELLETS #53258

OPERATING CO. :  
SAMPLED BY: CUSTOMER PROVIDED  
MINE:  
LOCATION:

DATE SAMPLED: 7/30/09  
WEATHER:  
GROSS WEIGHT:

DATE RECEIVED: 7/30/09

OTHER ID:

CERTIFICATE OF ANALYSIS

ASH MINERAL  
D2795 D3682

SILICON DIOXIDE	30.07 %
ALUMINUM OXIDE	7.04 %
FERRIC OXIDE	5.27 %
TITANIUM DIOXIDE	0.45 %
PHOSPHOROUS PENTOXIDE	1.00 %
CALCIUM OXIDE	23.10 %
MAGNESIUM OXIDE	8.99 %
SODIUM OXIDE	2.19 %
POTASSIUM OXIDE	7.51 %
SULFUR TRIOXIDE	14.18 %

APPROVED BY

APPROVED BY

BLACK SEAL ANALYSIS

FOR YOUR PROTECTION THIS DOCUMENT HAS  
BEEN PRINTED ON CONTROLLED PAPER STOCK.  
NOT VALID IF ALTERED.

Project Participants

## PROJECT PARTICIPANTS

### Koogler and Associates, Inc.

John B. Koogler, Ph.D., P.E. .... Project Advisor  
Max Lee, Ph.D., P.E. .... Senior Project Engineer  
Steven L. Cloutier ..... Technical Manager  
Veronica Sgro ..... Project Engineer  
Chris Enwall ..... Field Technician  
James Langston ..... Field Technician  
Adam West ..... Field Technician  
Glen Haven ..... Field Technician  
Rodney Paul ..... Field Technician

### CEMEX Construction Materials Florida, LLC/Central Power and Lime, Inc.

Larry Roberts ..... Power Plant Operations Manager  
Rick Pelage ..... Power Plant Technical Supervisor

