

# Sebring Utilities Commission

JIM FULTON  
CHAIRMAN  
JAMES F. HOLSONBACK  
VICE CHAIRMAN  
TED SHOEMAKER  
SECRETARY

368 South Commerce Avenue  
P. O. Box 971  
SEBRING, FLORIDA 33870  
PHONE 385-0191

EDWARD D. KOCH, JR.  
ASSISTANT SECRETARY  
ANDREW B. JACKSON  
COMMISSIONER  
J. H. PHILLIPS  
GENERAL MANAGER

April 9, 1982

Mirza Baig  
Department of Environmental Regulation  
2269 Bay Street  
Ft. Myers, Florida 33901

Re: Sebring Utilities Commission  
Slow Speed Diesel #1 AC28-7377 and Slow Speed Diesel  
#2 AC28-7291  
Specific Condition 12f, Page 4a of 4

Dear Mr. Baig:

Specific Condition 12f of the above mentioned permits states "The following parameters are to be monitored on a daily basis; appropriate records shall be maintained on site for Department inspection: (f) Gross heat of combustion valve and percent sulfur content by weight for each fresh supply of fuel added to the fuel storage facilities."

Based on our conversation on April 9, it is the Commission's proposal to meet the intent of this permit condition by the following method:

(1) At the beginning of commercial operation of the first unit (approximately March 1983), we will test for sulfur content and BTU value of the fuel daily until the unit is tested for permit compliance for NO<sub>x</sub>, CO and particulate (approximately 30 days).

(2) After compliance tests for NO<sub>x</sub>, CO and particulate are successfully completed the Commission will test for sulfur and BTU content weekly for six months.

(3) After the six months, assuming no violations have occurred, we will test a composite of 4 weekly samples once a month for sulfur content and BTU value.

*Progress Through Service*

Page -2-

Your help in clarifying this permit condition and your response to this letter will be greatly appreciated.

Sincerely,

*Howard Short*

Howard Short

HS:jlf

cc: J.H. Phillips  
Joe E. Calhoun