

Jeb Bush  
Governor

# Department of Environmental Protection

Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

David B. Struhs  
Secretary

August 13, 2002

CERTIFIED MAIL - RETURN RECEIPT REQUESTED

Ms. Laura R. Crouch  
Manager – Air Programs  
Tampa Electric Company  
Post Office Box 111  
Tampa, Florida 33601-0111

Re: DEP File No. 0570038-004-AC  
Hookers Point Station

Dear Ms. Crouch:

Enclosed is one copy of the Draft Air Construction Permit Modification for the Hookers Point Station located in Hillsborough County. The Department's Intent to Issue Air Construction Permit Modification and the "PUBLIC NOTICE OF INTENT TO ISSUE AIR CONSTRUCTION PERMIT MODIFICATION" are also included.

The "PUBLIC NOTICE OF INTENT TO ISSUE AIR CONSTRUCTION PERMIT MODIFICATION" must be published in a newspaper of general circulation in Hillsborough County. Proof of publication, i.e., newspaper affidavit, must be provided to the Department's Bureau of Air Regulation office within seven (7) days of publication. Failure to publish the notice and provide proof of publication within the allotted time may result in the denial of the permit modification.

Please submit any written comments you wish to have considered concerning the Department's proposed action to A. A. Linero, P.E., Administrator, New Source Review Section at the above letterhead address. If you have any other questions, please call Mr. Syed Arif at 850/921-9528.

Sincerely,

  
for C. H. Fancy, P.E., Chief  
Bureau of Air Regulation

CHF/sa

Enclosures

"More Protection, Less Process"

Printed on recycled paper.

In the Matter of an  
Application for Permit Modification by:

Ms. Laura R. Crouch  
Manager – Air Programs  
Tampa Electric Company  
Post Office Box 111  
Tampa, Florida 33601-0111

DEP File No. 0570038-004-AC  
Hookers Point Station  
Hillsborough County

### **INTENT TO ISSUE AIR CONSTRUCTION PERMIT MODIFICATION**

The Department of Environmental Protection (Department) gives notice of its intent to issue a permit modification (copy of DRAFT Permit Modification attached) for the proposed action, as detailed in the application specified above, for the reasons stated below.

The applicant, Tampa Electric Company applied on April 1, 2002 to the Department for a permit modification to allow for continued operation of the thirty internal combustion engines at the existing Hookers Point Station in Hillsborough County.

The Department has permitting jurisdiction under the provisions of Chapter 403, Florida Statutes (F.S.), and Florida Administrative Code (F.A.C.) Chapters 62-4, 62-210, and 62-212. The above actions are not exempt from permitting procedures. The Department has determined that a construction permit modification is required.

The Department intends to issue this air construction permit based on the belief that reasonable assurances have been provided to indicate that operation of these emission units will not adversely impact air quality, and the emission units will comply with all appropriate provisions of Chapters 62-4, 62-204, 62-210, 62-212, 62-296, and 62-297, F.A.C.

Pursuant to Section 403.815, F.S., and Rule 62-110.106(7)(a)1., F.A.C., you (the applicant) are required to publish at your own expense the enclosed Public Notice of Intent to Issue Air Construction Permit. The notice shall be published one time only in the legal advertisement section of a newspaper of general circulation in the area affected. Rule 62-110.106(7)(b), F.A.C., requires that the applicant cause the notice to be published as soon as possible after notification by the Department of its intended action. For the purpose of these rules, "publication in a newspaper of general circulation in the area affected" means publication in a newspaper meeting the requirements of Sections 50.011 and 50.031, F.S., in the county where the activity is to take place. If you are uncertain that a newspaper meets these requirements, please contact the Department at the address or telephone number listed below. The applicant shall provide proof of publication to the Department's Bureau of Air Regulation, at 2600 Blair Stone Road, Mail Station #5505, Tallahassee, Florida 32399-2400 (Telephone: 850/488-0114; Fax 850/ 922-6979). You must provide proof of publication within seven days of publication, pursuant to Rule 62-110.106(5), F.A.C. No permitting action for which published notice is required shall be granted until proof of publication of notice is made by furnishing a uniform affidavit in substantially the form prescribed in section 50.051, F.S. to the office of the Department issuing the permit. Failure to publish the notice and provide proof of publication may result in the denial of the permit pursuant to Rules 62-110.106(9) & (11), F.A.C.

The Department will issue the final permit with the attached conditions unless a response received in accordance with the following procedures results in a different decision or significant change of terms or conditions.

The Department will accept written comments concerning the proposed permit issuance action for a period of 14 (fourteen) days from the date of publication of Public Notice of Intent to Issue Air Permit. Written comments should be provided to the Department's Bureau of Air Regulation at 2600 Blair Stone Road, Mail Station #5505, Tallahassee, FL 32399-2400. Any written comments filed shall be made available for public inspection. If written comments received result in a significant change in the proposed agency action, the Department shall revise the proposed permit and require, if applicable, another Public Notice.

The Department will issue the permit with the attached conditions unless a timely petition for an administrative hearing is filed pursuant to sections 120.569 and 120.57 F.S., before the deadline for filing a petition. The procedures for petitioning for a hearing are set forth below.

A person whose substantial interests are affected by the proposed permitting decision may petition for an administrative proceeding (hearing) under sections 120.569 and 120.57 of the Florida Statutes. The petition must

contain the information set forth below and must be filed (received) in the Office of General Counsel of the Department at 3900 Commonwealth Boulevard, Mail Station #35, Tallahassee, Florida, 32399-3000. Petitions filed by the permit applicant or any of the parties listed below must be filed within fourteen days of receipt of this notice of intent. Petitions filed by any persons other than those entitled to written notice under section 120.60(3) of the Florida Statutes must be filed within fourteen days of publication of the public notice or within fourteen days of receipt of this notice of intent, whichever occurs first. Under section 120.60(3), however, any person who asked the Department for notice of agency action may file a petition within fourteen days of receipt of that notice, regardless of the date of publication. A petitioner shall mail a copy of the petition to the applicant at the address indicated above at the time of filing. The failure of any person to file a petition within the appropriate time period shall constitute a waiver of that person's right to request an administrative determination (hearing) under sections 120.569 and 120.57 F.S., or to intervene in this proceeding and participate as a party to it. Any subsequent intervention will be only at the approval of the presiding officer upon the filing of a motion in compliance with Rule 28-106.205 of the Florida Administrative Code.

A petition that disputes the material facts on which the Department's action is based must contain the following information: (a) The name and address of each agency affected and each agency's file or identification number, if known; (b) The name, address, and telephone number of the petitioner, the name, address, and telephone number of the petitioner's representative, if any, which shall be the address for service purposes during the course of the proceeding; and an explanation of how the petitioner's substantial interests will be affected by the agency determination; (c) A statement of how and when petitioner received notice of the agency action or proposed action; (d) A statement of all disputed issues of material fact. If there are none, the petition must so indicate; (e) A concise statement of the ultimate facts alleged, including the specific facts the petitioner contends warrant reversal or modification of the agency's proposed action; (f) A statement of the specific rules or statutes the petitioner contends require reversal or modification of the agency's proposed action; and (g) A statement of the relief sought by the petitioner, stating precisely the action petitioner wishes the agency to take with respect to the agency's proposed action.

A petition that does not dispute the material facts upon which the Department's action is based shall state that no such facts are in dispute and otherwise shall contain the same information as set forth above, as required by Rule 28-106.301.

Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the Department's final action may be different from the position taken by it in this notice. Persons whose substantial interests will be affected by any such final decision of the Department on the application have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.

Mediation is not available in this proceeding.


In addition to the above, a person subject to regulation has a right to apply for a variance from or waiver of the requirements of particular rules, on certain conditions, under Section 120.542 F.S. The relief provided by this state statute applies only to state rules, not statutes, and not to any federal regulatory requirements. Applying for a variance or waiver does not substitute or extend the time for filing a petition for an administrative hearing or exercising any other right that a person may have in relation to the action proposed in this notice of intent.

The application for a variance or waiver is made by filing a petition with the Office of General Counsel of the Department, 3900 Commonwealth Boulevard, Mail Station #35, Tallahassee, Florida 32399-3000. The petition must specify the following information: (a) The name, address, and telephone number of the petitioner; (b) The name, address, and telephone number of the attorney or qualified representative of the petitioner, if any; (c) Each rule or portion of a rule from which a variance or waiver is requested; (d) The citation to the statute underlying (implemented by) the rule identified in (c) above; (e) The type of action requested; (f) The specific facts that would justify a variance or waiver for the petitioner; (g) The reason why the variance or waiver would serve the purposes of the underlying statute (implemented by the rule); and (h) A statement whether the variance or waiver is permanent or temporary and, if temporary, a statement of the dates showing the duration of the variance or waiver requested.

The Department will grant a variance or waiver when the petition demonstrates both that the application of the rule would create a substantial hardship or violate principles of fairness, as each of those terms is defined in Section 120.542(2) F.S., and that the purpose of the underlying statute will be or has been achieved by other means by the petitioner.

Persons subject to regulation pursuant to any federally delegated or approved air program should be aware that Florida is specifically not authorized to issue variances or waivers from any requirements of any such federally delegated or approved program. The requirements of the program remain fully enforceable by the Administrator of the EPA and by any person under the Clean Air Act unless and until the Administrator separately approves any variance or waiver in accordance with the procedures of the federal program.

Executed in Tallahassee, Florida.

  
C. H. Fancy, P.E., Chief  
Bureau of Air Regulation


**CERTIFICATE OF SERVICE**

The undersigned duly designated deputy agency clerk hereby certifies that this Intent to Issue Air Construction Permit Modification (including the Public Notice of Intent to Issue Air Construction Permit Modification, and the Draft permit) was sent by certified mail (\*) and copies were mailed by U.S. Mail before the close of business on 8/15/02 to the person(s) listed:

Ms. Laura R. Crouch, Tampa Electric Company\*  
Mr. J. Kissel, DEP-SWD  
Mr. J. Campbell, EPCHC

Clerk Stamp

FILING AND ACKNOWLEDGMENT FILED, on this date, pursuant to §120.52, Florida Statutes, with the designated Department Clerk, receipt of which is hereby acknowledged.

 August 15, 2002  
(Clerk) (Date)

**PUBLIC NOTICE OF INTENT TO ISSUE AIR CONSTRUCTION PERMIT MODIFICATION**

STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION

DEP File No. 0570038-004-AC

Hookers Point Station  
Tampa Electric Company  
Hillsborough County

The Department of Environmental Protection (Department) gives notice of its intent to issue an air construction permit modification to Tampa Electric Company (TEC) for the Hookers Point Station located in Hillsborough County. An air construction permit was issued to TEC in April 2001 for installation of 30 (thirty) internal combustion (IC) diesel engines. This permit modification allows for continued operation of the 30 IC engines following June 2003 and permanent shutdown of Boilers 1 through 6 by January 1, 2003. A Best Available Control Technology (BACT) determination was not required pursuant to Rule 62-212.400, F.A.C. and 40 CFR 52.21, Prevention of Significant Deterioration (PSD). The applicant's mailing address is: Tampa Electric Company, Post Office Box 111, Tampa, Florida 33601-0111.

During the original permitting in 2001, the Department applied an emissions cap on the existing boilers 1-6 to insure permanent and enforceable reductions of actual emissions. This allowed the installation of IC engines to "net out" of PSD review. The reduction in emissions from Boilers 1-6 will be greater than previously estimated due to their permanent shutdown. The installation of the IC units will become permanent. Boilers 1-6 were fired on residual fuel oil. The IC engines are restricted to 0.05 percent sulfur diesel fuel.

The Department will issue the Final permit modification with the attached conditions unless a response received in accordance with the following procedures results in a different decision or significant change of terms or conditions.

The Department will accept written comments concerning the proposed permit modification issuance action for a period of 14 (fourteen) days from the date of publication of this Public Notice of Intent to Issue PSD permit modification. Written comments should be provided to the Department's Bureau of Air Regulation at 2600 Blair Stone Road, Mail Station #5505, Tallahassee, FL 32399-2400. Any written comments filed shall be made available for public inspection. If written comments received result in a significant change in the proposed agency action, the Department shall revise the proposed permit modification and require, if applicable, another Public Notice.

The Department will issue the permit modification with the attached conditions unless a timely petition for an administrative hearing is filed pursuant to sections 120.569 and 120.57 F.S., before the deadline for filing a petition. The procedures for petitioning for a hearing are set forth below. Mediation is not available in this proceeding.

A person whose substantial interests are affected by the proposed permitting decision may petition for an administrative proceeding (hearing) under sections 120.569 and 120.57 of the Florida Statutes. The petition must contain the information set forth below and must be filed (received) in the Office of General Counsel of the Department at 3900 Commonwealth Boulevard, Mail Station #35, Tallahassee, Florida, 32399-3000. Petitions filed by the permit applicant or any of the parties listed below must be filed within fourteen days of receipt of this notice of intent. Petitions filed by any persons other than those entitled to written notice under section 120.60(3) of the Florida Statutes must be filed within fourteen days of publication of the public notice

**NOTICE TO BE PUBLISHED IN THE NEWSPAPER**

or within fourteen days of receipt of this notice of intent, whichever occurs first. Under section 120.60(3), however, any person who asked the Department for notice of agency action may file a petition within fourteen days of receipt of that notice, regardless of the date of publication. A petitioner shall mail a copy of the petition to the applicant at the address indicated above at the time of filing. The failure of any person to file a petition within the appropriate time period shall constitute a waiver of that person's right to request an administrative determination (hearing) under sections 120.569 and 120.57 F.S., or to intervene in this proceeding and participate as a party to it. Any subsequent intervention will be only at the approval of the presiding officer upon the filing of a motion in compliance with Rule 28-106.205 of the Florida Administrative Code.

A petition that disputes the material facts on which the Department's action is based must contain the following information: (a) The name and address of each agency affected and each agency's file or identification number, if known; (b) The name, address, and telephone number of the petitioner, the name, address, and telephone number of the petitioner's representative, if any, which shall be the address for service purposes during the course of the proceeding; and an explanation of how the petitioner's substantial interests will be affected by the agency determination; (c) A statement of how and when petitioner received notice of the agency action or proposed action; (d) A statement of all disputed issues of material fact. If there are none, the petition must so indicate; (e) A concise statement of the ultimate facts alleged, including the specific facts the petitioner contends warrant reversal or modification of the agency's proposed action; (f) A statement of the specific rules or statutes the petitioner contends require reversal or modification of the agency's proposed action; and (g) A statement of the relief sought by the petitioner, stating precisely the action petitioner wishes the agency to take with respect to the agency's proposed action.

A petition that does not dispute the material facts upon which the Department's action is based shall state that no such facts are in dispute and otherwise shall contain the same information as set forth above, as required by Rule 28-106.301

Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the Department's final action may be different from the position taken by it in this notice. Persons whose substantial interests will be affected by any such final decision of the Department on the application have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.

A complete project file is available for public inspection during normal business hours, 8:00 a.m. to 5:00 p.m., Monday through Friday, except legal holidays, at:

Dept. of Environmental Protection  
Bureau of Air Regulation  
Suite 4, 111 S. Magnolia Drive  
Tallahassee, Florida, 32301  
Telephone: 850/488-0114  
Fax: 850/922-6979

Dept. of Environmental Protection  
Southwest District  
3804 Coconut Palm Drive  
Tampa, Florida 33619-8218  
Telephone: 813/744-6100  
Fax: 813/744-6084

Hillsborough County Environmental  
Protection Commission  
1900 Ninth Avenue  
Tampa, Florida 33605  
Telephone: 813/272-5960  
Fax: 813/272-5157

The complete project file includes the application, Draft permit modification, and the information submitted by the responsible official, exclusive of confidential records under Section 403.111, F.S. Interested persons may contact the Administrator, New Source Review Section, at 111 South Magnolia Drive, Suite 4, Tallahassee, Florida 32301, or call 850/488-0114, for additional information.

NOTICE TO BE PUBLISHED IN THE NEWSPAPER

# DRAFT

## PERMITTEE:

Tampa Electric Company  
Hookers Point Station  
1700 Hemlock Street  
Tampa, Florida 33605-6660

### *Authorized Representative:*

Ms. Laura R. Crouch  
Manager – Air Program

**ARMS Permit No.** 0570038-004-AC

**Facility ID No.** 0570038

**SIC No.** 4911

**Expires:** February 1, 2003

## PROJECT AND LOCATION

This air construction permit describes the existing facility that was approved in April 2001 and its current modifications of allowing the thirty diesel engines to operate permanently and the permanent shutdown of Boilers 1-6. The diesel engine emissions unit number will be changed to 008-037.

The units are located in Hillsborough County at 1700 Hemlock Street, Tampa. The UTM coordinates are Zone 17, 358 km E, 3091 km N.

## STATEMENT OF BASIS

This air pollution construction permit is issued under the provisions of Chapter 403 of the Florida Statutes (F.S.), and Chapters 62-4, 62-204, 62-210, 62-212, 62-296, and 62-297 of the Florida Administrative Code (F.A.C.). The permittee is authorized to install the proposed equipment in accordance with the conditions of this permit and as described in the application, approved drawings, plans, and other documents on file with the Department.

## APPENDICES

The following Appendices are attached as part of this permit.

0570038-002-AC Original Air Construction Permit  
Appendix GC Construction Permit General Conditions

---

Howard L. Rhodes, Director  
Division of Air Resources Management

## ADMINISTRATIVE REQUIREMENTS

---

### FACILITY DESCRIPTION

The existing facility consists of six oil-fired steam boilers (Units Nos. 1 through 6) and thirty internal combustion diesel engines at the Hookers Point Station located at 1700 Hemlock Street, Tampa, Hillsborough County. All the boilers are fired using No. 6 fuel oil and the diesel engines are fired with 0.05 percent diesel fuel oil. The boilers may also fire a limited quantity of on-specification used oil. The total generating capacity at this facility is 227 megawatts. Also located at this facility are miscellaneous unregulated/insignificant emissions units and/or activities. The thirty internal combustion engines with generators are capable of providing a nominal 54.75 MW of electrical power.

### REGULATORY CLASSIFICATION

Acid Rain: This facility is subject to the acid rain provisions of the Clean Air Act (Title IV).

Title V Major Source: This facility is a Title V major source of air pollution.

PSD Major Source: Each pollutant with potential emissions greater than the Significant Emissions Rates specified in Table 62-212.400-2, F.A.C. requires a PSD review and Best Available Control Technology (BACT) determination. For this project, emissions of no pollutant are significant or subject to BACT standards, provided that the Emission Unit is operated as specified in this permit. However, the existing facility is classified as a PSD Major Source.

### PERMIT SCHEDULE

- 04-01-02: Date of Receipt of Permit Application
- 07-02-02: Application deemed complete
- 08-xx-02: Intent issued
- 08-xx-02: Notice published in \_\_\_\_\_

### RELEVANT DOCUMENTS

The documents listed form the basis of the permit. They are specifically related to this permitting action. These documents are on file with the Department.

- Application received 4-01-02
- Department letter dated 5-02-02
- Company letter receive date 7-02-02
- Intent issue date 8-xx-02



**APPENDIX SC**  
**SPECIFIC CONDITIONS**

1. This permit, 0570038-004-AC, supersedes original permit 0570038-002-AC issued on April 20, 2001.
2. The provisions of air construction permit 0570038-002-AC are attached and incorporated into this air construction permit except for the following changes:

**SECTION III. EMISSIONS UNIT SPECIFIC CONDITIONS**

This permit addresses the following emissions units.

<b>EU ID No.</b>	<b>EMISSIONS UNIT DESCRIPTION</b>
001 – 006 <sup>#</sup>	Six boilers that are fired using No. 6 fuel oil.
<del>007008–</del> <del>036*037*</del>	30 Caterpillar XQ2000 Power Modules. Each Power Module consists of one Caterpillar 3516B 16-cylinder, 4-stroke cycle diesel internal combustion (IC) engine and one Caterpillar SR4B generator. The Caterpillar 3516B IC engine has a power rating of 2,593 brake horsepower (bhp) at 100 percent load. The Caterpillar SR4B generator has a power output rating of 1,825 kilowatts (kW) at 100 percent load. The IC engines will be fired exclusively with low-sulfur (maximum of 0.05 weight percent sulfur) diesel fuel oil.

# Existing Emission units

\* New Emission units

12. Fuel Oil Consumption: The maximum No. 2 fuel oil allowed to be burned in thirty internal combustion engines combined is ~~2,743,880~~ 2,828,800 gallons per year, which is equivalent to 22,100 engine-hours per year at 100% load. [Rule 62-210.200, F.A.C. (Definitions – PTE)]
15. Operational Period: The thirty internal combustion engines ~~shall cease operation in~~ can operate beyond June 2003. [Applicant Request]

**The following Specific Conditions apply to the existing emission units 001-006:**

4. The existing emission units ~~may operate with a NO<sub>x</sub> emissions cap of 100 tpy after the internal combustion engines ceases operation in June 2003~~ shall be permanently retired as of January 1, 2003. [Applicant Request]



Jeb Bush  
Governor

# Department of Environmental Protection

Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

David B. Struhs  
Secretary

## PERMITTEE:

Tampa Electric Company  
Hookers Point Station  
1700 Hemlock Street  
Tampa, Florida 33605-6660

ARMS Permit No. 0570038-002-AC

Facility ID No. 0570038

SIC No. 4911

Expires: December 1, 2001

## Authorized Representative:

Mr. Darryl Scott  
General Manager

## PROJECT AND LOCATION

The proposed project authorizes the installation of thirty internal combustion engines with electrical generator sets. The thirty engines are capable of producing a nominal 54.75 MW of electricity.

The project will be located in Hillsborough County at 1700 Hemlock Street, Tampa. The UTM coordinates are Zone 17, 358 km E, 3091 km N.

## STATEMENT OF BASIS

This air pollution construction permit is issued under the provisions of Chapter 403 of the Florida Statutes (F.S.), and Chapters 62-4, 62-204, 62-210, 62-212, 62-296, and 62-297 of the Florida Administrative Code (F.A.C.). The permittee is authorized to install the proposed equipment in accordance with the conditions of this permit and as described in the application, approved drawings, plans, and other documents on file with the Department.

## APPENDICES

The following Appendices are attached as part of this permit.

Appendix GC - Construction Permit General Conditions

---

Howard L. Rhodes, Director  
Division of Air Resources Management

"More Protection, Less Process"

Printed on recycled paper.

## SECTION II. ADMINISTRATIVE REQUIREMENTS

---

### FACILITY DESCRIPTION

The existing facility consists of six oil-fired steam boilers (Units Nos. 1 through 6) at the Hookers Point Station located at 1700 Hemlock Street, Tampa, Hillsborough County. All the boilers are fired using No. 6 fuel oil. The boilers may also fire a limited quantity of on-specification used oil. The total generating capacity at this facility is 227 megawatts. Also located at this facility are miscellaneous unregulated/insignificant emissions units and/or activities. Title V Final Permit No. 0570038-001-AV currently authorizes operation of the existing steam boilers. Final Title V Permit was issued with an effective date of January 1, 1998 and expires on January 1, 2002. Completion of this project will result in the installation of thirty internal combustion engines with generators capable of providing a nominal 54.75 MW of electrical power.

### REGULATORY CLASSIFICATION

Acid Rain: This facility is subject to the acid rain provisions of the Clean Air Act (Title IV).

Title V Major Source: This facility is a Title V major source of air pollution.

PSD Major Source: Each pollutant with potential emissions greater than the Significant Emissions Rates specified in Table 62-212.400-2, F.A.C. requires a PSD review and Best Available Control Technology (BACT) determination. For this project, emissions of no pollutant are significant or subject to BACT standards, provided that the Emission Unit is operated as specified in this permit. However, the existing facility is classified as a PSD Major Source.

### PERMIT SCHEDULE

- 01-23-01: Date of Receipt of Permit Application
- 02-07-01: Application deemed complete
- 03-30-01: Intent issued
- 04-04-01: Notice published in the Tampa Tribune

### RELEVANT DOCUMENTS

The documents listed form the basis of the permit. They are specifically related to this permitting action. These documents are on file with the Department.

- Application received 1-23-01
- Department letter dated 1-30-01
- Company letters dated 2-06-01 and 2-15-01
- Technical Evaluation and Preliminary Determination dated 3-21-01
- EPA's letter dated April 17, 2001

## SECTION II. ADMINISTRATIVE REQUIREMENTS

---

### GENERAL AND ADMINISTRATIVE REQUIREMENTS

1. Permitting Authority: All documents related to applications for permits to construct, operate or modify an emissions unit should be submitted to the Bureau of Air Regulation (BAR), Florida Department of Environmental Protection (DEP), at 2600 Blair Stone Road, Tallahassee, Florida 32399-2400 and phone number 850/488-0114.
2. Compliance Authority: All documents related compliance activities such as reports, tests, and notifications should be submitted to the Air Management Division, Hillsborough County Environmental Protection Commission, 1900 Ninth Avenue, Tampa, Florida 33605. The phone number is 813/272-5960 and the fax number is 813/272-5157.
3. Terminology: The terms used in this permit have specific meanings as defined in the applicable chapters of the Florida Administrative Code.
4. General Conditions: The owner and operator are subject to, and shall operate under, the attached General Conditions listed in *Appendix GC* of this permit. General Conditions are binding and enforceable pursuant to Chapter 403 of the Florida Statutes. [Rule 62-4.160, F.A.C.]
5. Applicable Regulations, Forms and Application Procedures: Unless otherwise indicated in this permit, the construction and operation of the subject emissions unit shall be in accordance with the capacities and specifications stated in the application. The facility is subject to all applicable provisions of Chapter 403, F.S. and Florida Administrative Code Chapters 62-4, 62-110, 62-204, 62-212, 62-213, 62-296, 62-297 and the Code of Federal Regulations Title 40, Part 60, adopted by reference in the Florida Administrative Code (F.A.C.) regulations. The permittee shall use the applicable forms listed in Rule 62-210.900, F.A.C. and follow the application procedures in Chapter 62-4, F.A.C. Issuance of this permit does not relieve the facility owner or operator from compliance with any applicable federal, state, or local permitting or regulations. [Rules 62-204.800, 62-210.300 and 62-210.900, F.A.C.]
6. New or Additional Conditions: For good cause shown and after notice and an administrative hearing, if requested, the Department may require the permittee to conform to new or additional conditions. The Department shall allow the permittee a reasonable time to conform to the new or additional conditions, and on application of the permittee, the Department may grant additional time. [Rule 62-4.080, F.A.C.]
7. Modifications: No emissions unit or facility subject to this permit shall be constructed or modified without obtaining an air construction permit from the Department. Such permit shall be obtained prior to beginning construction or modification. [Rules 62-210.300(1) and 62-212.300(1)(a), F.A.C.]
8. Expiration: This air construction permit shall expire on **December 1, 2001**. The permittee, for good cause, may request that this construction permit be extended. Such a request shall be submitted to the Department's Bureau of Air Regulation prior to 60 days before the expiration of the permit. [Rules 62-210.300(1), 62-4.070(4) 62-4.080, and 62-4.210, F.A.C.]
9. Title V Permit: This permit authorizes construction and/or installation of the permitted emissions unit and initial operation to determine compliance with Department rules. A Title V operation permit is required for regular operation of the permitted emissions unit. The owner or operator shall apply for a Title V operation permit at least ninety days prior to expiration of this permit, but no later than 180 days after commencing operation. To apply for a Title V operation permit, the applicant shall submit the appropriate application form, compliance test results, and such additional information as the Department may by law require. The

## SECTION II. ADMINISTRATIVE REQUIREMENTS

application shall be submitted to the Department's Bureau of Air Regulation, and a copy sent to the Department's Southwest District office. [Rules 62-4.030, 62-4.050, 62-4.220, and 62-213.420, F.A.C.]

This permit addresses the following emissions units.

EU ID No.	EMISSIONS UNIT DESCRIPTION
001 – 006 <sup>#</sup>	Six boilers that are fired using No. 6 fuel oil.
007 – 036 <sup>*</sup>	30 Caterpillar XQ2000 Power Modules. Each Power Module consists of one Caterpillar 3516B 16-cylinder, 4-stroke cycle diesel internal combustion (IC) engine and one Caterpillar SR4B generator. The Caterpillar 3516B IC engine has a power rating of 2,593 brake horsepower (bhp) at 100 percent load. The Caterpillar SR4B generator has a power output rating of 1,825 kilowatts (kW) at 100 percent load. The IC engines will be fired exclusively with low-sulfur (maximum of 0.05 weight percent sulfur) diesel fuel oil.

# Existing Emission units

\* New Emission units

**The following Specific Conditions apply to the new emission units 007-036:**

### PERFORMANCE RESTRICTIONS

1. **Internal Combustion Engines:** The permittee is authorized to install, tune, operate and maintain thirty new internal combustion engines with electrical generator sets (Caterpillar XQ2000 Power modules). The thirty generators are designed to produce a maximum 54.75 MW of electrical power. **[Applicant Request]**
2. **Future PSD Review:** The internal combustion engines shall not exceed the permitted hours of operation, nor the permitted NO<sub>x</sub> emission limits allowed by this permit. This restriction is based on the permittee's request, which formed the basis of the PSD non-applicability determination and resulted in the emission standards specified in this permit. For any request to modify this emission unit in any way (whether a physical or operational modification, including a change in the allowable hours of operation or heat input) the permittee shall submit a full PSD permit application. **[Rules 62-212.400(2)(g) and 62-212.400(6)(b), F.A.C.]**
3. **Allowable Fuel:** The internal combustion engine shall be fired primarily with No. 2 fuel oil. The permittee shall demonstrate compliance with the fuel sulfur limit by keeping the records specified in this permit. **[Applicant Request, Rule 62-210.200, F.A.C. (Definition - PTE)]**
4. **Plant Operation - Problems:** If temporarily unable to comply with any of the conditions of the permit due to breakdown of equipment or destruction by fire, wind or other cause, the permittee shall notify the Compliance Authority as soon as possible, but at least within one working day, excluding weekends and holidays. The notification shall include: pertinent information as to the cause of the problem; steps being taken to correct the problem and prevent future recurrence; and, where applicable, the owner's intent toward reconstruction of destroyed facilities. Such notification does not release the permittee from any liability for failure to comply with the conditions of this permit or the regulations. **[Rule 62-4.130, F.A.C.]**

### SECTION III. EMISSIONS UNIT SPECIFIC CONDITIONS

---

5. Noise Nuisance: The permittee shall comply with the noise nuisance ordinances as outlined in Chapter 1-10 of the Rules of Environmental Protection Commission of Hillsborough County. **[Rule 1-10.01(B)(9) and Rule 1-10.03, EPCHC]**

#### EMISSIONS CONTROLS

6. Unconfined Emissions of Particulate Matter: **[Rule 62-296.320(4)(c), F.A.C.]**
- (a) No person shall cause, let, permit, suffer or allow the emissions of unconfined particulate matter from any activity, including vehicular movement; transportation of materials; construction, alteration, demolition or wrecking; or industrially related activities such as loading, unloading, storing or handling; without taking reasonable precautions to prevent such emissions.
- (b) Any permit issued to a facility with emissions of unconfined particulate matter shall specify the reasonable precautions to be taken by that facility to control the emissions of unconfined particulate matter.
- (c) Reasonable precautions include the following:
- Paving and maintenance of roads, parking areas and yards.
  - Application of water or chemicals to control emissions from such activities as demolition of buildings, grading roads, construction, and land clearing.
  - Application of asphalt, water, oil, chemicals or other dust suppressants to unpaved roads, yards, open stock piles and similar activities.
  - Removal of particulate matter from roads and other paved areas under the control of the owner or operator of the facility to prevent re-entrainment, and from buildings or work areas to prevent particulate from becoming airborne.
  - Landscaping or planting of vegetation.
  - Use of hoods, fans, filters, and similar equipment to contain, capture and/or vent particulate matter.
  - Confining abrasive blasting where possible.
  - Enclosure or covering of conveyor systems.
- (d) In determining what constitutes reasonable precautions for a particular source, the Department shall consider the cost of the control technique or work practice, the environmental impacts of the technique or practice, and the degree of reduction of emissions expected from a particular technique or practice.

#### EMISSION STANDARDS

7. Nitrogen Oxides (NO<sub>x</sub>):

NO<sub>x</sub> emissions from each internal combustion engine shall not exceed 53 lb/hr. Additionally, annual emissions of NO<sub>x</sub> in tpy from these emission units shall be calculated by using the NO<sub>x</sub> emission rate of 53 lb/hr multiplied by the total operating hours for the thirty engines divided by 2000. This NO<sub>x</sub> emission in tpy when combined with the NO<sub>x</sub> emissions for the existing emission units (EU001-EU006) in tpy shall not exceed 682 TPY, based upon a consecutive 12-month period. This facility-wide annual emissions cap shall become effective on the fifth day of the month following the start-up of the first internal combustion engine, and compliance shall begin based upon the first twelve months of operation thereafter. NO<sub>x</sub> emissions from the existing emission units (EU001-EU006) shall not exceed 100 TPY. NO<sub>x</sub> emissions from the existing emission units shall be determined using CEM's and converted to tpy.

**[Rule 62-212.400, F.A.C. (PSD avoidance)]**

### SECTION III. EMISSIONS UNIT SPECIFIC CONDITIONS

---

#### 8. General Visible Emissions Standard:

Except for emissions units that are subject to a particulate matter or opacity limit set forth or established by rule and reflected by conditions in this permit, no person shall cause, let, permit, suffer, or allow to be discharged into the atmosphere the emissions of air pollutants from any activity, the density of which is equal to or greater than that designated as Number 1 on the Ringelmann Chart (20% opacity). The test method for visible emissions shall be EPA Method 9, incorporated and adopted by reference in Chapter 62-297, F.A.C. Test procedures shall meet all applicable requirements of Chapter 62-297, F.A.C. [Rule 62-296.320(4)(b)1, F.A.C.]

#### EXCESS EMISSIONS

9. Excess Emissions Prohibited: Excess emissions caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure that may reasonably be prevented during startup, shutdown or malfunction, shall be prohibited. [Rule 62-210.700(4), F.A.C.]
10. Excess Emissions Allowed: Providing the permittee adheres to best operational practices to minimize the amount and duration of excess emissions, the following conditions shall apply:
- (a) During startup and shutdown, visible emissions shall not exceed 27% opacity for up to 2 hours in any 24-hour period. [Design; Rule 62-210.700(1), F.A.C.]

#### OPERATIONAL LIMITATIONS

11. Fuel Oil Specification: Only No. 2 fuel oil can be fired in the internal combustion engines. The maximum sulfur content of the No. 2 fuel oil shall not exceed 0.05 percent, by weight. [Rule 62-210.200, F.A.C. (Definitions – PTE)]
12. Fuel Oil Consumption: The maximum No. 2 fuel oil allowed to be burned in thirty internal combustion engines combined is 2,713,880 gallons per year, which is equivalent to 22,100 engine-hours per year at 100% load. [Rule 62-210.200, F.A.C. (Definitions – PTE)]
13. Permitted Capacity: The heat input to each internal combustion engine from firing No. 2 fuel oil shall not exceed 17 MMBtu per hour at 100% load. [Design, Rule 62-210.200, F.A.C. (Definition - PTE)]
14. Hours of Operation: The thirty internal combustion engines shall operate no more than 22,100 engine-hours during any consecutive 12-month period. The permittee shall install, calibrate, operate and maintain a monitoring system to measure the hours of operation on each internal combustion engine. [Rule 62-210.200, F.A.C. (Definitions - PTE)]
15. Operational Period: The thirty internal combustion engines shall cease operation in June 2003. [Applicant Request]

#### EMISSIONS PERFORMANCE TESTING

16. Sampling Facilities: The permittee shall design the internal combustion engine stack to accommodate adequate testing and sampling locations in order to determine compliance with the applicable emission limits specified by this permit. [Rule 62-297.310(6), F.A.C.]
17. Performance Test Methods: Initial (I) and Annual (A) compliance tests shall be performed in accordance with the following reference methods as described in 40 CFR 60, Appendix A, and adopted by reference in Chapter 62-204.800, F.A.C.
- (a) EPA Method 7 or 7E – Determination of Nitrogen Oxide Emissions from Stationary Sources (I, A);

### SECTION III. EMISSIONS UNIT SPECIFIC CONDITIONS

(b) EPA Method 9 - Visual Determination of the Opacity of Emissions from Stationary Sources (I, A);

No other test methods may be used for compliance testing unless prior DEP approval is received, in writing, from the DEP Emissions Monitoring Section Administrator.

18. Fuel Oil Monitoring: The fuel shall be monitored initially and annually for the sulfur content using ASTM D4294 Method (or equivalent). The permittee shall also maintain daily records of fuel oil consumption for the emission units. [Rule 62-297.440, F.A.C., and 62-210.200, F.A.C.]
19. Test Notification: The permittee shall notify the Compliance Authority in writing at least 15 days prior to the date on which each formal compliance test is to begin, of the date, time, and place of each such test, and the test contact person who will be responsible for coordinating and having such test conducted for the owner or operator. [Rule 62-297.310(7)(a)9., F.A.C.]
20. Initial Tests Required: Initial performance tests to demonstrate compliance with the emission standards specified in this permit shall be conducted within 60 days after achieving at least 90% of permitted capacity, but not later than 180 days after initial operation of the emissions unit. Initial performance tests shall be conducted for NO<sub>x</sub> and visible emissions on a sample of 5 (five) randomly picked internal combustion engines for the first year. A different set of randomly picked five engines from the remaining 25 (twenty five) internal combustion engines will be tested during the second year of operation. [Rule 62-297.310(7)(a)1., and 62-297.310(7)(c), F.A.C.]
21. Annual Performance Tests: To demonstrate compliance with the emission standards specified in this permit, the permittee shall conduct annual performance tests for NO<sub>x</sub> and visible emissions on the emission units that operated for more than 3,700 hours in the preceding 12-month period. Tests required on an annual basis shall be conducted at least once during each federal fiscal year (October 1<sup>st</sup> to September 30<sup>th</sup>). [Rule 62-297.310(7)(a)4., and 62-297.310(7)(c), F.A.C.]
22. Tests Prior to Permit Renewal: Prior to renewing the air operation permit, the permittee shall conduct performance tests for NO<sub>x</sub> and visible emissions on one of the internal combustion engines. These tests shall be conducted within the 12-month period prior to renewing the air operation permit. For pollutants required to be tested annually, the permittee may submit the most recent annual compliance test to satisfy the requirements of this provision. [Rule 62-297.310(7)(a)3., F.A.C.]
23. Internal Combustion Engine Testing Capacity: Performance tests for compliance with standards specified in this permit shall be conducted with the emission unit operating at permitted capacity. Permitted capacity is defined as 90-100 percent of the maximum heat input rate allowed by the permit. If it is impracticable to test at permitted capacity, the source may be tested at less than permitted capacity. However, subsequent operation is limited to 110 percent of the value reached during the test until a new test is conducted. Once the unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purposes of additional compliance testing to regain the permitted capacity. Emissions performance tests shall meet all applicable requirements of Chapters 62-204 and 62-297, F.A.C. [Rule 62-297.310(2), F.A.C.]
24. Calculation of Emission Rate: For each emissions performance test, the indicated emission rate or concentration shall be the arithmetic average of the emission rate or concentration determined by each of the three separate test runs unless otherwise specified in a particular test method or applicable rule. [Rule 62-297.310(3), F.A.C.]
25. Applicable Test Procedures
  - (a) Required Sampling Time.



### SECTION III. EMISSIONS UNIT SPECIFIC CONDITIONS

---

1. Unless otherwise specified in the applicable rule, the required sampling time for each test run shall be no less than one hour and no greater than four hours, and the sampling time at each sampling point shall be of equal intervals of at least two minutes. [Rule 62-297.310(4)(a)1., F.A.C.]
2. The minimum observation period for a visible emissions compliance test shall be thirty (30) minutes. The observation period shall include the period during which the highest opacity can reasonably be expected to occur. [Rule 62-297.310(4)(a)2., F.A.C.]
- (b) Minimum Sample Volume. Unless otherwise specified in the applicable rule or test method, the minimum sample volume per run shall be 25 dry standard cubic feet. [Rule 62-297.310(4)(b), F.A.C.]
- (c) Calibration of Sampling Equipment. Calibration of the sampling train equipment shall be conducted in accordance with the schedule shown in Table 297.310-1, F.A.C. [Rule 62-297.310(4)(d), F.A.C.]

#### 26. Determination of Process Variables

- (a) Required Equipment. The owner or operator of an emissions unit for which compliance tests are required shall install, operate, and maintain equipment or instruments necessary to determine process variables, such as process weight input or heat input, when such data are needed in conjunction with emissions data to determine the compliance of the emissions unit with applicable emission limiting standards. [Rule 62-297.310(5)(a), F.A.C.]
  - (b) Accuracy of Equipment. Equipment or instruments used to directly or indirectly determine process variables, including devices such as belt scales, weight hoppers, flow meters, and tank scales, shall be calibrated and adjusted to indicate the true value of the parameter being measured with sufficient accuracy to allow the applicable process variable to be determined within 10% of its true value. [Rule 62-297.310(5)(b), F.A.C.]
27. Special Compliance Tests: When the Department, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it shall require the owner or operator of the emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department. [Rule 62-297.310(7)(b), F.A.C.]

### RECORDKEEPING AND REPORTING REQUIREMENTS

28. Records Retention: All measurements, records, and other data required by this permit shall be documented in a permanent, legible format and retained for at least five (5) years following the date on which such measurements, records, or data are recorded. Records shall be made available to the Department upon request. [Rules 62-4.160(14) and 62-213.440(1)(b)2., F.A.C.]
29. Emissions Performance Test Reports: A report indicating the results of any required emissions performance test shall be submitted to the Compliance Authority no later than 45 days after completion of the last test run. The test report shall provide sufficient detail on the tested emission unit and the procedures used to allow the Department to determine if the test was properly conducted and if the test results were properly computed. At a minimum, the test report shall provide the applicable information listed in Rule 62-297.310(8)(c), F.A.C. [Rule 62-297.310(8), F.A.C.]
30. Monthly Operations Summary: By the fifth calendar day of each month, the permittee shall record the 12-month hours of operation of the internal combustion engines, 12-month emission totals for NO<sub>x</sub> and amount of the No. 2 fuel oil fired for the internal combustion engines. The information shall be recorded in

### SECTION III. EMISSIONS UNIT SPECIFIC CONDITIONS

---

a written or electronic log and shall be available for inspection and/or printing within at least one day of a request from the Compliance Authority. [Rule 62-4.160(15), F.A.C.]

31. **Annual Operating Report:** The permittee shall submit an annual report that summarizes the actual operating rates and emissions from this facility. Annual operating reports shall be submitted to the Compliance Authority by March 1st of each year. [Rule 62-210.370(2), F.A.C.]

**The following Specific Conditions apply to the existing emission units 001-006:**

1. The existing emission units shall comply with all the requirements of 0570038-001-AV with the exceptions listed below in conditions 2 through 4. [Title V Permit Requirements]
2. For each 12-month period that the thirty internal combustion engines (EU007-EU036) operate below 22,100 engine-hours, the existing emission units 001 through 006 may operate to reach the facility-wide NO<sub>x</sub> cap of 682 tpy. NO<sub>x</sub> emissions from the existing emission units (EU001-EU006) shall not exceed 100 tpy. The existing emission units shall use the CEM system to demonstrate compliance with the emission limits for NO<sub>x</sub>. [Rule 62-212.400, F.A.C. (PSD avoidance)]
3. The existing emission units may not operate simultaneously with the internal combustion engines unless the facility must do so to avoid interrupting customers. In the event that the facility does operate the two sources together, upon request from the Department, shall provide the necessary documentation to show the necessity of operating the two sources simultaneously. [Applicant Request]
4. The existing emission units may operate with a NO<sub>x</sub> emissions cap of 100 tpy after the internal combustion engines ceases operation in June 2003. [Applicant Request]

**APPENDIX GC**  
**GENERAL PERMIT CONDITIONS [F.A.C. 62-4.160]**

---

- G.1 The terms, conditions, requirements, limitations, and restrictions set forth in this permit are "Permit Conditions" and are binding and enforceable pursuant to Sections 403.161, 403.727, or 403.859 through 403.861, Florida Statutes. The permittee is placed on notice that the Department will review this permit periodically and may initiate enforcement action for any violation of these conditions.
- G.2 This permit is valid only for the specific processes and operations applied for and indicated in the approved drawings or exhibits. Any unauthorized deviation from the approved drawings or exhibits, specifications, or conditions of this permit may constitute grounds for revocation and enforcement action by the Department.
- G.3 As provided in Subsections 403.087(6) and 403.722(5), Florida Statutes, the issuance of this permit does not convey and vested rights or any exclusive privileges. Neither does it authorize any injury to public or private property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations. This permit is not a waiver or approval of any other Department permit that may be required for other aspects of the total project which are not addressed in the permit.
- G.4 This permit conveys no title to land or water, does not constitute State recognition or acknowledgment of title, and does not constitute authority for the use of submerged lands unless herein provided and the necessary title or leasehold interests have been obtained from the State. Only the Trustees of the Internal Improvement Trust Fund may express State opinion as to title.
- G.5 This permit does not relieve the permittee from liability for harm or injury to human health or welfare, animal, or plant life, or property caused by the construction or operation of this permitted source, or from penalties therefore; nor does it allow the permittee to cause pollution in contravention of Florida Statutes and Department rules, unless specifically authorized by an order from the Department.
- G.6 The permittee shall properly operate and maintain the facility and systems of treatment and control (and related appurtenances) that are installed or used by the permittee to achieve compliance with the conditions of this permit, as required by Department rules. This provision includes the operation of backup or auxiliary facilities or similar systems when necessary to achieve compliance with the conditions of the permit and when required by Department rules.
- G.7 The permittee, by accepting this permit, specifically agrees to allow authorized Department personnel, upon presentation of credentials or other documents as may be required by law and at a reasonable time, access to the premises, where the permitted activity is located or conducted to:
- a) Have access to and copy and records that must be kept under the conditions of the permit;
  - b) Inspect the facility, equipment, practices, or operations regulated or required under this permit, and,
  - c) Sample or monitor any substances or parameters at any location reasonably necessary to assure compliance with this permit or Department rules.
- Reasonable time may depend on the nature of the concern being investigated.
- G.8 If, for any reason, the permittee does not comply with or will be unable to comply with any condition or limitation specified in this permit, the permittee shall immediately provide the Department with the following information:
- a) A description of and cause of non-compliance; and
  - b) The period of noncompliance, including dates and times; or, if not corrected, the anticipated time the non-compliance is expected to continue, and steps being taken to reduce, eliminate, and prevent recurrence of the non-compliance.

**APPENDIX GC**  
**GENERAL PERMIT CONDITIONS [F.A.C. 62-4.160]**

---

The permittee shall be responsible for any and all damages, which may result and may be subject to enforcement action by the Department for penalties or for revocation of this permit.

- G.9 In accepting this permit, the permittee understands and agrees that all records, notes, monitoring data and other information relating to the construction or operation of this permitted source which are submitted to the Department may be used by the Department as evidence in any enforcement case involving the permitted source arising under the Florida Statutes or Department rules, except where such use is prescribed by Sections 403.73 and 403.111, Florida Statutes. Such evidence shall only be used to the extent it is consistent with the Florida Rules of Civil Procedure and appropriate evidentiary rules.
- G.10 The permittee agrees to comply with changes in Department rules and Florida Statutes after a reasonable time for compliance, provided, however, the permittee does not waive any other rights granted by Florida Statutes or Department rules.
- G.11 This permit is transferable only upon Department approval in accordance with Florida Administrative Code Rules 62-4.120 and 62-730.300, F.A.C., as applicable. The permittee shall be liable for any non-compliance of the permitted activity until the transfer is approved by the Department.
- G.12 This permit or a copy thereof shall be kept at the work site of the permitted activity.
- G.13 This permit also constitutes:
- a) Determination of Best Available Control Technology ( )
  - b) Determination of Prevention of Significant Deterioration ( ); and
  - c) Compliance with New Source Performance Standards ( ).
- G.14 The permittee shall comply with the following:
- a) Upon request, the permittee shall furnish all records and plans required under Department rules. During enforcement actions, the retention period for all records will be extended automatically unless otherwise stipulated by the Department.
  - b) The permittee shall hold at the facility or other location designated by this permit records of all monitoring information (including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation) required by the permit, copies of all reports required by this permit, and records of all data used to complete the application or this permit. These materials shall be retained at least three years from the date of the sample, measurement, report, or application unless otherwise specified by Department rule.
  - c) Records of monitoring information shall include:
    - 1. The date, exact place, and time of sampling or measurements;
    - 2. The person responsible for performing the sampling or measurements;
    - 3. The dates analyses were performed;
    - 4. The person responsible for performing the analyses;
    - 5. The analytical techniques or methods used; and
    - 6. The results of such analyses.
- G.15 When requested by the Department, the permittee shall within a reasonable time furnish any information required by law, which is needed to determine compliance with the permit. If the permittee becomes aware that relevant facts were not submitted or were incorrect in the permit application or in any report to the Department, such facts or information shall be corrected promptly.

## Memorandum

## Florida Department of Environmental Protection

---

TO: Clair Fancy

THRU: Al Linero

FROM: Syed Arif *Syed Arif 8/13*

DATE: August 13, 2002

SUBJECT: Tampa Electric Company – Hookers Point Station

Attached for approval and signature is a construction permit modification to Tampa Electric Company for the Hookers Point Station located in Hillsborough County. A construction permit was issued to TEC in April 2001 for installation of 30 (thirty) internal combustion (IC) diesel engines. The original permit restricted the operation of these diesel engines until June 2003. This permit modification allows TEC for continued operation of the 30 IC engines following June 2003. The modification also requires the oil-fired Boilers 1 through 6 to be permanently retired no later than January 1, 2003.

I recommend your approval and signature.

August 13, 2002 is day 42 of the 90-day timeclock.

Attachments

/sa

**SENDER: COMPLETE THIS SECTION**

- Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:

Ms. Laura R. Crouch  
Manager - Air Programs  
Tampa Electric Company  
P. O. Box 111  
Tampa, FL 33601-0111

**COMPLETE THIS SECTION ON DELIVERY**

A. Receiver's City (Please Print Clearly) **B. Rhind** B. Date of Delivery **8-20-02**

C. Signature **x B. Rhind** ☒ Agent ☒ Addressee

D. Is delivery address different from item 1? ☐ Yes  
If YES, enter delivery address below: ☐ No

3. Service Type  
☒ Certified Mail ☐ Express Mail  
☐ Registered ☐ Return Receipt for Merchandise  
☐ Insured Mail ☐ C.O.D.

4. Restricted Delivery? (Extra Fee) ☐ Yes

<sup>2</sup> 7001 0320 0001 3692 8055

PS Form 3811, July 1999

Domestic Return Receipt

102595-00-M-0952

**U.S. Postal Service**  
**CERTIFIED MAIL RECEIPT**  
(Domestic Mail Only; No Insurance Coverage Provided)

**OFFICIAL USE**

Postage	\$
Certified Fee	
Return Receipt Fee (Endorsement Required)	
Restricted Delivery Fee (Endorsement Required)	
<b>Total Postage &amp; Fees</b>	<b>\$</b>

Postmark  
Here

Sent To **Laura R. Crouch**  
Street, Apt. No.,  
or P.O. Box **111**  
City, State, ZIP+4  
**Tampa, FL 33601-0111**

PS Form 3800, January 2001

See Reverse for Instructions

5508 2692 1000 0320 0001 3692 8055