

# Florida Department of Environmental Regulation

Southwest District

4520 Oak Fair Boulevard

Tampa, Florida 33610-7347

Lawton Chiles, Governor

813-623-5561

Carol M. Browner, Secretary

## STATE OF FLORIDA DEPARTMENT OF ENVIRONMENTAL REGULATION NOTICE OF PERMIT ISSUANCE

### CERTIFIED MAIL

Mr. Lynn F. Robinson  
Environmental Planning  
Tampa Electric Company  
Post Office Box 111  
Tampa, FL 33601-0111

DER File No.: A029-203002  
County: Hillsborough

Enclosed is Permit Number A029-203002 to operate a 778 MMBTU/hr. steam generator designated as Unit #6, issued pursuant to Section 403.087, Florida Statutes.

A person whose substantial interests are affected by this permit may petition for an administrative proceeding (hearing) in accordance with Section 120.57, Florida Statutes. The petition must contain the information set forth below and must be filed (received) in the Office of General Counsel of the Department at 2600 Blair Stone Road, Tallahassee 32399-2400, within fourteen (14) days of receipt of this permit. Petitioner shall mail a copy of the petition to the applicant at the address indicated above at the time of filing. Failure to file a petition within this time period shall constitute a waiver of any right such person may have to request an administrative determination (hearing) under Section 120.57, Florida Statutes.

The Petition shall contain the following information:

- (a) The name, address, and telephone number of each petitioner, the applicant's name and address, the Department Permit File Number and the county in which the project is proposed;
- (b) A statement of how and when each petitioner received notice of the Department's action or proposed action;
- (c) A statement of how each petitioner's substantial interests are affected by the Department's action or proposed action;
- (d) A statement of the material facts disputed by petitioner, if any;
- (e) A statement of facts which petitioner contends warrant reversal or modification of the Department's action or proposed action;

P 149 931 638

RECEIPT FOR CERTIFIED MAIL

INSURANCE COVERAGE PROVIDED  
NOT FOR INTERNATIONAL MAIL

(See Reverse)

MR MARK J HORNICK  
TAMPA ELECTRIC CO  
PO BOX 111  
TAMPA FL 33601 0111

Certified Fee	
Special Delivery Fee	
Restricted Delivery Fee	
Return Receipt showing to whom and Date Delivered	
Return Receipt showing to whom, Date, and Address of Delivery	
TOTAL Postage and Fees	\$
Postmark or Date	
TECO A029-202997	
"	" - 202998
"	" - 202999
"	" - 203000

PS Form 3800, June 1985

A029-203001  
" - 203002

**SENDER:** Complete items 1 and 2 when additional services are desired, and complete items 3 and 4.  
Put your address in the "RETURN TO" Space on the reverse side. Failure to do this will prevent this card from being returned to you. The return receipt fee will provide you the name of the person delivered to and the date of delivery. For additional fees the following services are available. Consult postmaster for fees and check box(es) for additional service(s) requested.

1. ☐ Show to whom delivered, date, and addressee's address. (Extra charge) 2. ☐ Restricted Delivery (Extra charge)

3. Article Addressed to: A029-202997 HK  
(6) A029-203002

MR MARK J HORNICK  
TAMPA ELECTRIC CO  
PO BOX 111  
TAMPA FL 33601 0111

4. Article Number  
P 149 931 638

Type of Service:  
☒ Registered ☐ Insured  
☒ Certified ☐ COD  
☐ Express Mail ☐ Return Receipt for Merchandise

Always obtain signature of addressee or agent and DATE DELIVERED.

5. Signature - Addressee  
X

6. Signature - Agent  
X

7. Date of Delivery  
DEC 23 1991

8. Addressee's Address (ONLY if requested and fee paid)  
DEC 26 1991  
SOUTHWEST DISTRICT  
TAMPA

(f) A statement of which rules or statutes petitioner contends required reversal or modification of the Department's action or proposed action; and

(g) A statement of the relief sought by petitioner, stating precisely the action petitioner wants the Department to take with respect to the Department's action or proposed action.

If a petition is filed, the administrative hearing process is designed to formulate agency action. Accordingly, the Department's final action may be different from the position taken by it in this permit. Persons whose substantial interests will be affected by any decision of the Department with regard to the application have the right to petition to become a party to the proceeding. The petition must conform to the requirements specified above and be filed (received) within 14 days of receipt of this notice, in the Office of General Counsel at the above address of the Department. Failure to petition within the allotted time frame constitutes a waiver of any right such person has to request a hearing under Section 120.57, F.S., and to participate as a party to this proceeding. Any subsequent intervention will only be at the approval of the presiding officer upon motion filed pursuant to Rule 28-5.207, F.A.C.

This permit is final and effective on the date filed with the Clerk of the Department unless a petition is filed in accordance with the above paragraphs or unless a request for extension of time in which to file a petition is filed within the time specified for filing a petition and conforms to Rule 17-103.070, F.A.C. Upon timely filing of a petition or a request for an extension of time this permit will not be effective until further Order of the Department.

When the Order (Permit) is final, any party to the Order has the right to seek judicial review of the Order pursuant to Section 120.68, Florida Statutes, by the filing of a Notice of Appeal pursuant to Rule 9.110, Florida Rules of Appellate Procedure, with the Clerk of the Department in the Office of General Counsel, 2600 Blair Stone Road, Tallahassee, Florida 32399-2400; and by filing a copy of the Notice of Appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal. The Notice of Appeal must be filed within 30 days from the date the Final Order is filed with the Clerk of the Department.

P 149 931 637

RECEIPT FOR CERTIFIED MAIL

U.S. MAIL SERVICE  
INTERNATIONAL MAIL

(See Reverse)

MR LYNN F ROBINSON  
MANAGER ENV PLANNING  
TAMPA ELECTRIC CO  
PO BOX 111  
TAMPA FL 33601 0111

PS Form 3800, June 1985

Certified Fee	
Special Delivery Fee	
Restricted Delivery Fee	
Return Receipt showing to whom and Date Delivered	
Return Receipt showing to whom Date and Address of Delivery	
TOTAL Postage and Fees	\$
TECO A029-202997	
Postmark or Date	1 - 202998
"	" - 202999
"	" - 203000
"	" - 203001
"	" - 203002

**SENDER:** Complete items 1 and 2 when additional services are desired, and complete items 3 and 4.  
Put your address in the "RETURN TO" Space on the reverse side. Failure to do this will prevent this card from being returned to you. The return receipt fee will provide you the name of the person delivered to and the date of delivery. Additional fees for the following services are available. Consult postmaster for fees and check box(es) for additional service(s) requested.

1. ☐ Show to whom delivered, date, and addressee's address. (Extra charge) 2. ☐ Restricted Delivery (Extra charge)


3. Article Addressed to: A029-202997 HK (6) A029-203002  MR LYNN F ROBINSON MANAGER ENV PLANNING TAMPA ELECTRIC CO PO BOX 111 TAMPA FL 33601 0111	4. Article Number P 149 931 637  Type of Service: <input type="checkbox"/> Registered <input type="checkbox"/> Insured <input checked="" type="checkbox"/> Certified <input type="checkbox"/> COD <input type="checkbox"/> Express Mail <input type="checkbox"/> Return Receipt for Merchandise  Always obtain signature of addressee or agent and DATE DELIVERED.
5. Signature - Addressee X	8. Addressee's Address (ONLY if requested and fee paid)
6. Signature - Agent X	
7. Date of Delivery DEC 23 1991	

Tampa Electric Company  
Tampa, FL 33601-0111

Page Three

Executed in Tampa, Florida

Sincerely,

  
J. Harry Kerns, P.E.  
District Air Engineer

JHK/SKW/bm

Attachment:

cc: Environmental Protection Commission  
of Hillsborough County  
Mark J. Hornick, P.E., Tampa Electric Company


CERTIFICATE OF SERVICE

This is to certify that this NOTICE OF PERMIT ISSUANCE and all  
copies were mailed by certified mail before the close of business on  
DEC 19 1991 to the listed persons.

FILING AND ACKNOWLEDGEMENT FILED, on this  
date, pursuant to Section 120.52(11),  
Florida Statutes, with the designated  
Department Clerk, receipt of which is  
hereby acknowledged.

  
Clerk

DEC 19 1991  
Date



# Florida Department of Environmental Regulation

Southwest District

4520 Oak Fair Boulevard

Tampa, Florida 33610-7347

Lawton Chiles, Governor

813-623-5561

Carol M. Browner, Secretary

## PERMITTEE:

Tampa Electric Company  
Post Office Box 111  
Tampa, FL 33601-0111

## PERMIT/CERTIFICATION

Permit No: A029-203002  
County: Hillsborough  
Expiration Date: 12/01/96  
Project: Hooker's Point  
Station Unit #6

This permit is issued under the provisions of Chapter 403, Florida Statutes, and Florida Administrative Code Rules 17-2 and 17-4. The above named permittee is hereby authorized to perform the work or operate the facility shown on the application and approved drawing(s), plans and other documents, attached hereto or on file with the department and made a part of hereof and specifically described as follows:

For the operation of a 778 MMBTU/hr. steam generator designated as Unit #6. This tangential firing type boiler was manufactured by Combustion Engineering Corporation and is fired on No. 6 fuel oil. The unit has no add-on pollution control equipment. Air pollutant emissions are controlled by efficient combustion of the fuel. Unit No. 6 vents to stack #4, the northern most stack on the west side of the building.

Location: At the foot of Hemlock Street, Tampa

UTM: 17-358.0 E 3091.0 N NEDS NO: 0038 Point ID: 06

Replaces Permit No.: A029-125691

PERMITTEE:  
Tampa Electric Company

PERMIT/CERTIFICATION NO.: AO29-203002  
PROJECT: Hooker's Point Station  
Unit #6

SPECIFIC CONDITIONS:

1. A part of this permit is the attached 15 General Conditions.
2. Except as provided in Specific Condition No. 5, the maximum allowable particulate matter emission rate from this source shall not exceed 0.1 pounds per MMBtu heat input over a two (2) hour average. [Rule 17-2.650(2)(c)2.b.(i), F.A.C.]
3. Except as provided in Specific Condition No. 5, visible emissions shall not exceed 20% opacity except for one two-minute period per hour during which opacity shall not exceed 40%. [Rules 17-2.650(2)(c)2.b.(ii) and 17-2.600(5)(a)1., F.A.C.]
4. The maximum allowable sulfur dioxide emission rate from this source shall not exceed 1.1 pounds per MMBtu heat input. [Rule 17-2.600(5)(a)3.a.(v), F.A.C.]
5. Excess Emissions:
  - A. Excess emissions from existing fossil fuel steam generators resulting from startup or shutdown are permitted provided that best operational practices to minimize emissions are adhered to and the duration of excess emissions are minimized. [Rule 17-2.250(2), F.A.C.]
  - B. Excess emissions resulting from boiler cleaning (sootblowing) and load change are permitted provided that the duration of such excess emissions shall not exceed 3 hours in any 24-hour period and visible emissions shall not exceed 60% opacity, and providing (a) best operational practices to minimize emissions are adhered to and (b) the duration of the excess emissions are minimized. Particulate matter emissions shall not exceed an average of 0.3 pounds per MMBtu heat input during the 3-hour period of excess emissions allowed by part B. of this specific condition. [Rule 17-2.250(3), F.A.C.]
  - C. Excess emissions resulting from malfunctions\* are permitted provided (a) best operational practices to minimize emissions are adhered to and (b) the duration of excess emissions are minimized but in no case exceed two hours in any 24-hour period unless specifically authorized by the Department of Environmental Regulation for longer duration. [Rule 17-2.250(1), F.A.C.]
  - D. Excess emissions which are caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure which may reasonably be prevented during startup, shutdown, or malfunction is prohibited. [Rule 17-2.250(4), F.A.C.]

PERMITTEE:  
Tampa Electric Company

PERMIT/CERTIFICATION NO.: AO29-203002  
PROJECT: Hooker's Point Station  
Unit #6

SPECIFIC CONDITIONS: (continued)

\* In case of excess emissions resulting from malfunctions, Tampa Electric Company shall notify the Environmental Protection Commission of Hillsborough County in accordance with Rule 17-4.130, F.A.C. A full written report on the malfunctions shall be submitted in a quarterly report, if requested. [Rule 17-2.250(6), F.A.C.]

6. Test the emissions for the following pollutant(s) at intervals of 12 months from May 10, 1991 ( $\pm$  90 days) and submit 2 copies of test data to the Air Section of the Environmental Protection Commission of Hillsborough County office and the Florida Department of Environmental Regulation within forty-five days of such testing. Testing procedures shall be consistent with the requirements of Rule 17-2.700, F.A.C.:

(X) Particulates\*\*  
(X) Opacity\*\*

(X) Sulfur Dioxide\*

\* Compliance with the sulfur dioxide emission limits may be demonstrated by calculating SO<sub>2</sub> emissions based on the sulfur content of the fuel in lieu of stack sampling as provided in Rule 17-2.700, F.A.C. An analysis of the fuel oil shall be submitted with the stack test report. The analysis shall be in accordance with ASTM D4239-85 to determine sulfur content and contain as a minimum the Btu content (Btu/gal.), the density (lbs./gal.) and the sulfur content (% by weight).

\*\* Compliance with the particulate matter and opacity limits shall be demonstrated under both sootblowing and non-sootblowing operating conditions. A test under sootblowing conditions which demonstrates compliance with a non-sootblowing emission limitation will be accepted as proof of compliance with that non-sootblowing emission limitation.

7. Approved compliance testing of emissions must be conducted within  $\pm$  10% of the maximum permitted heat input rate (778 MMBtu/hr.), when practicable. Testing may be conducted at less than 90% of the maximum permitted heat input rate; however, if so, the maximum permitted heat input rate is automatically amended to be equal to the test heat input rate. If the maximum permitted heat input rate for this source is exceeded by more than 10%, compliance testing shall be performed within 60 days of initiation of the higher rate and the results of the tests shall be submitted to the Department of Environmental Regulation and the Environmental Protection Commission of Hillsborough County. The Environmental Protection Commission of Hillsborough County may, for good cause shown, grant an extension of the 60-day time limit on a case by case basis. Acceptance of said test will automatically amend the maximum permitted heat input rate to be equal to the test heat input rate. The actual heat input rate shall be specified in each test



PERMITTEE:  
Tampa Electric Company

PERMIT/CERTIFICATION NO.: AO29-203002  
PROJECT: Hooker's Point Station  
Unit #6

SPECIFIC CONDITIONS: (continued)

report. Failure to submit the actual heat input rate, or operation at conditions during testing which do not reflect normal operating conditions may invalidate the test and fail to provide reasonable assurance of compliance. [Rule 17-4.070(3), F.A.C.]

8. Compliance with the emission limitations of Specific Condition Nos. 2, 3, 4 and 5B (sootblowing) shall be determined using EPA Methods contained in 40 CFR 60, Appendix A and adopted by reference in Rule 17-2.700, F.A.C. in accordance with Table 700-1 and DER Method 9 contained in Rule 17-2.700, F.A.C. The Method 9 observation period shall be at least 60 minutes and concurrent with one stack test run for sootblowing and non-sootblowing conditions. The minimum requirements for stack sampling facilities, source sampling and reporting, shall be in accordance with Rule 17-2.700, F.A.C. and 40 CFR 60, Appendix A.

9. Submit for this facility, each calendar year, on or before March 1, an emission report for the preceding calendar year containing the following information pursuant to Subsection 403.061(13), Florida Statutes:

- (A) Annual amount of materials and/or fuels utilized.
- (B) Annual emissions (note calculation basis).
- (C) Any changes in the information contained in the permit application.

Duplicate copies of all reports shall be submitted to the Environmental Protection Commission of Hillsborough County and the Florida Department of Environmental Regulation.

10. Operation and Maintenance Plan. [Rule 17-2.650(2)(g), F.A.C.]

A. Process System Performance Parameters:

- 1) Source Designator: Hooker's Point Unit #6
- 2) Design Fuel Consumption Rate: 126 barrels per hour
- 3) Steam Flow: 625,000 pounds per hour
- 4) Operating Temperature: 950° F.
- 5) Operating Pressure: 1450 psi

B. The following observations, checks, and operations apply to this source while in operation and shall be conducted on the schedule specified:

Continuously Monitored and Recorded

Steam Flow  
Steam Temperature  
Steam Pressure  
Excess Air

PERMITTEE:  
Tampa Electric Company

PERMIT/CERTIFICATION NO.: AO29-203002  
PROJECT: Hooker's Point Station  
Unit #6

SPECIFIC CONDITIONS: (continued)

Daily

Check visible emissions  
Sample fuel oil for monthly composite analysis  
Maintain optimum flame pattern for efficient fuel combustion

Monthly

Monitor and back calculate fuel input rate

During Major Outages

Inspect boiler, controls, auxiliaries, and ductwork and repair as necessary.

Prior to Startup

Inspect burners and clean as necessary.  
Inspect burner tips and replace as necessary.

- C. Records of inspection, maintenance, and performance parameters shall be retained for a minimum of two years and shall be made available to the Department or the Environmental Protection Commission of Hillsborough County upon request. [Rule 17-2.650(2)(g)5., F.A.C.]

11. The Environmental Protection Commission of Hillsborough County shall be notified in writing 15 days in advance of any compliance test to be conducted on this source. [Rules 17-2.700(2)(a)9. and 17-2.820(5), F.A.C.]

12. An application for renewal of permit to operate this source, completed in quadruplicate, shall be submitted to the Environmental Protection Commission of Hillsborough County at least 60 days prior to its expiration date. [Rule 17-4.090, F.A.C.]

STATE OF FLORIDA DEPARTMENT OF  
ENVIRONMENTAL REGULATION

  
\_\_\_\_\_  
Richard Garrity, Ph.D.  
Director of District Management

ATTACHMENT - GENERAL CONDITIONS:

1. The terms, conditions, requirements, limitations and restrictions set forth in this permit, are "permit conditions" and are binding and enforceable pursuant to Sections 403.141, 403.161, 403.727, or 403.859 through 403.861, Florida Statutes. The permittee is placed on notice that the Department will review this permit periodically and may initiate enforcement action for any violation of these conditions.
2. This permit is valid only for the specific processes and operations applied for and indicated in the approved drawings or exhibits. Any unauthorized deviation from the approved drawings, exhibits, specifications, or conditions of this permit may constitute grounds for revocation and enforcement action by the Department.
3. As provided in subsections 403.087(6) and 403.722(5), F.S., the issuance of this permit does not convey any vested rights or any exclusive privileges. Neither does it authorize any injury to public or private property or any invasion of personal rights, nor any infringement of federal, State, or local laws or regulations. This permit is not a waiver of or approval of any other Department permit that may be required for other aspects of the total project which are not addressed in this permit.
4. This permit conveys no title to land or water, does not constitute State recognition or acknowledgement of title, and does not constitute authority for the use of submerged lands unless herein provided and the necessary title or leasehold interests have been obtained from the State. Only the Trustees of the Internal Improvement Trust Fund may express State opinion as to title.
5. This permit does not relieve the permittee from liability for harm or injury to human health or welfare, animal, or plant life, or property caused by the construction or operation of this permitted source, or from penalties therefore; nor does it allow the permittee to cause pollution in contravention of Florida Statutes and Department rules, unless specifically authorized by an order from the Department.
6. The permittee shall properly operate and maintain the facility and systems of treatment and control (and related appurtenances) that are installed and used by the permittee to achieve compliance with the conditions of this permit, are required by Department rules. This provision includes the operation of backup or auxiliary facilities or similar systems when necessary to achieve compliance with the conditions of the permit and when required by Department rules.
7. The permittee, by accepting this permit, specifically agrees to allow authorized Department personnel, upon presentation of credentials or other documents as may be required by law and at reasonable times, access to the premises where the permitted activity is located or conducted to:
  - (a) Have access to and copy any records that must be kept under conditions of the permit;
  - (b) Inspect the facility, equipment, practices, or operations regulated or required under this permit; and

- (c) Sample or monitor any substances or parameters at any location reasonably necessary to assure compliance with this permit or Department rules.

Reasonable time may depend on the nature of the concern being investigated.

8. If, for any reason, the permittee does not comply with or will be unable to comply with any condition or limitation specified in this permit, the permittee shall immediately provide the Department with the following information:

- (a) A description of and cause of noncompliance; and
- (b) The period of noncompliance, including dates and times; or, if not corrected, the anticipated time the noncompliance is expected to continue, and steps being taken to reduce, eliminate, and prevent recurrence of the noncompliance.

The permittee shall be responsible for any and all damages which may result and may be subject to enforcement action by the Department for penalties or for revocation of this permit.

9. In accepting this permit, the permittee understands and agrees that all records, notes, monitoring data and other information relating to the construction or operation of this permitted source which are submitted to the Department may be used by the Department as evidence in any enforcement case involving the permitted source arising under the Florida Statutes or Department rules, except where such use is prescribed by Sections 403.111 and 403.73, F.S. Such evidence shall only be used to the extent it is consistent with the Florida Rules of Civil Procedure and appropriate evidentiary rules.

10. The permittee agrees to comply with changes in Department rules and Florida Statutes after a reasonable time for compliance; provided, however, the permittee does not waive any other rights granted by Florida Statutes or Department rules.

11. This permit is transferable only upon Department approval in accordance with Rule 17-4.120 and 17-730.300, Florida Administrative Code, as applicable. The permittee shall be liable for any non-compliance of the permitted activity until the transfer is approved by the Department.

12. This permit or a copy thereof shall be kept at the work site of the permitted activity.

13. This permit also constitutes:

- ( ) Determination of Best Available Control Technology (BACT)
- ( ) Determination of Prevention of Significant Deterioration (PSD)
- ( ) Certification of compliance with State Water Quality Standards (Section 401, PL 92-500)
- ( ) Compliance with New Source Performance Standards

14. The permittee shall comply with the following:

- (a) Upon request, the permittee shall furnish all records and plans required under Department rules. During enforcement actions, the retention period for all records will be extended automatically unless otherwise stipulated by the Department.
- (b) The permittee shall hold at the facility or other location designated by this permit records of all monitoring information (including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation) required by the permit, copies of all reports required by this permit, and records of all data used to complete the application for this permit. These materials shall be retained at least three years from the date of the sample, measurement, report, or application unless otherwise specified by Department rule.
- (c) Records of monitoring information shall include:
  - 1. the date, exact place, and time of sampling or measurements;
  - 2. the person responsible for performing the sampling or measurements;
  - 3. the dates analyses were performed;
  - 4. the person responsible for performing the analyses;
  - 5. the analytical techniques or methods used;
  - 6. the results of such analyses.

15. When requested by the Department, the permittee shall within a reasonable time furnish any information required by law which is needed to determine compliance with the permit. If the permittee becomes aware the relevant facts were not submitted or were incorrect in the permit application or in any report to the Department, such facts or information shall be corrected promptly.

STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL REGULATION

TWIN TOWERS OFFICE BUILDING  
2800 BLAIR STONE ROAD  
TALLAHASSEE, FLORIDA 32301



BOB GRAHAM  
GOVERNOR

VICTORIA J. TECHINKEL  
SECRETARY

REC'D

SEP 23 1991

APPLICATION FOR RENEWAL OF  
PERMIT TO OPERATE AIR POLLUTION SOURCE(S)

A029-26382

ENV. PROT. COMM.  
CF H.C.

If major alterations have occurred, the applicant should complete the Standard Air Permit Application Form.

Source Type: Air Pollution Renewal of DER Permit No. A029-125691

Company Name: Tampa Electric Company County: Hillshorough

Identify the specific emission point source(s) addressed in this application (i.e., Line Kiln No. 4 with Venturi Scrubber; Peaking Unit No. 2, Gas Fired):

Hookers Point Station Boiler 6

Source Location: Street: Foot of Hemlock City: Tampa

UTM: East 358,000 North 3,091,000

Latitude: 27° 56' 20" N. Longitude: 82° 26' 34" W.

1. Attach a check made payable to the Department of Environmental Regulation in accordance with operation permit fee schedule set forth in Florida Administrative Code Rule 17-4.05. Enclosed.
2. Have there been any alterations to the plant since last permitted? ☐ Yes ☒ No  
If minor alterations have occurred, describe on a separate sheet and attach.
3. Attach the last compliance test report required per permit conditions if not submitted previously. Submitted 5/30/91
4. Have previous permit conditions been adhered to? ☒ Yes ☐ No If no, explain on a separate sheet and attach.
5. Has there been any malfunction of the pollution control equipment during tenure of current permit? ☐ Yes ☒ No If yes, and not previously reported, give brief details and what action was taken on a separate sheet and attach.
6. Has the pollution control equipment been maintained to preserve the collection efficiency last permitted by the Department? ☒ Yes ☐ No
7. Has the annual operating report for the last calendar year been submitted? ☒ Yes ☐ No If no, please attach.

1. Please provide the following information if applicable:

A. Raw Materials and Chemicals Used in Your Process: Not Applicable

Description	Contaminant		Utilization	
	Type	Conc	Rate	lbs/hr

B. Product Weight (lbs/hr): Not Applicable

C. Fuels

Type (Be Specific)	Consumption*		Maximum Heat Input (MMBTU/hr)
	Avg/hr*	Max/hr**	
Fuel Oil	77.6*	126.0	778

D. Normal Equipment Operating Time: hrs/day 24; days/wk 7; wks/yr 52;  
hrs/yr (power plants only) 8760; if seasonal, describe \_\_\_\_\_

\* Average value, 1984 and 1984 emissions inventories

The undersigned owner or authorized representative\*\*\* of Tampa Electric Company is fully aware that the statements made in this application for a renewal of a permit to operate an air pollution source are true, correct and complete to the best of his knowledge and belief. Further, the undersigned agrees to maintain and operate the pollution source and pollution control facilities in such a manner as to comply with the provisions of Chapter 403, Florida Statutes, and all the rules and regulations of the Department. He also understands that a permit, if granted by the Department, will be non-transferable and he will promptly notify the Department upon sale or legal transfer of the permitted facility.

\*During actual time of operation.

\*\*Units: Natural Gas-MMCF/hr;  
Fuel Oils-barrels/hr; Coal-lbs/hr.

\*\*\*Attach letter of authorization if not previously submitted

Lynn F. Robinson  
Signature, Owner or Authorized Representative  
(Notarization is mandatory)  
Lynn F. Robinson, Manager, Environmental Planning  
Typed Name and Title  
P.O. Box 111  
Address  
Tampa FL 33601-0111  
City State Zip  
9/20/91 228-4836  
Date Telephone No.

ER Form 17-1.202(4)  
Effective November 30, 1982

STATE OF FLORIDA  
COUNTY OF HILLSBOROUGH

Sworn to and subscribed before me this 20th  
day of September, 1991.



Diana R. Hofer  
Notary Public  
Commission Expires:

NOTARY PUBLIC STATE OF FLORIDA  
MY COMMISSION EXP. DEC. 4, 1993  
BONDED THRU GENERAL INS. UND.

Professional Engineer in Florida (as required by Subsection 17-4.05(3), F.A.C.)

This is to certify that the engineering features of this air pollution control project have been ~~Designed~~/examined\* by me and found to be in conformity with modern engineering principles applicable to the treatment and disposal of pollutants characterized in the permit application. There is reasonable assurance, in my professional judgement, that the pollution control facilities, when properly maintained and operated, will discharge an effluent that complies with all applicable statutes of the State of Florida and the rules and the regulations of the department. It is also agreed that the undersigned will furnish, if authorized by the owner, the applicant a set of instructions for the proper maintenance and operation of the pollution control facilities\*and, if applicable, pollution sources.

Signed Mark J. Hornick

Date: 7/13/71 Telephone No. 228-4111

Mark J. Hornick

Name (Please type)

Tampa Electric Company

Company Name (Please type)

P.O. Box 111, Tampa, FL 33601-0111

Mailing Address (Please Type)

Florida Registration No. 38663



\* This unit's air emissions are controlled by fuel quality and efficient combustion of fuel.



## HOOKERS POINT STATION - BOILERS 1 THROUGH 6

### OPERATION AND MAINTENANCE PLAN

#### Introduction

Hookers Point Station is owned and operated by Tampa Electric Company. The plant is located on the shore of Hillsborough Bay off Sparkman Channel. The plant consists of six boilers and five turbine generator units. Boilers 1 through 5 are connected to a header system which supplies steam to four turbine generators. Boiler 6 supplies steam to turbine generator number 5.

The Hookers Point boilers burn No. 6 fuel oil. The boiler manufacturers, types and in-service dates are listed below:

<u>Boiler</u>	<u>Service Date</u>	<u>Manufacturer</u>	<u>Type</u>
1	1948	Babcock and Wilcox	Front Firing
2	1948	Babcock and Wilcox	Front Firing
3	1950	Babcock and Wilcox	Front Firing
4	1950	Babcock and Wilcox	Front Firing
5	1953	Babcock and Wilcox	Front Firing
6	1955	Combustion Engineering	Tangential Firing

The boilers exhaust gases through stacks at an elevation of 280 feet.

#### Process System Performance Parameters

Boilers 1 through 6 burn low sulfur No. 6 fuel oil. Fuel oil quality is monitored upon delivery. In addition, daily samples are taken for a monthly composite analysis. The design fuel consumption, steam flow rates, operating temperatures and operating pressures are listed below.

<u>Boiler</u>	<u>Fuel Consumption (bbls/hr)</u>	<u>Steam Flow (lbs/hr)</u>	<u>Operating Temperature (°F)</u>	<u>Operating Pressure (psi)</u>
1	43.0	220,000	900	960
2	43.0	220,000	900	960
3	59.4	303,000	900	960
4	59.4	303,000	900	960
5	86.2	440,000	900	975
6	126.0	625,000	950	1450

Actual fuel input to the boilers is back calculated from monthly fuel tank drawdown and boiler efficiencies. Steam flow, temperature and pressure are continuously monitored and recorded on control room charts. Fuel oil temperature and pressure are maintained at optimum levels. Excess air is continuously monitored, recorded and maintained at levels to produce efficient fuel combustion.

### Maintenance Inspection

All generating units of the Tampa Electric Company system are regularly scheduled for periodic maintenance. The schedule for planned maintenance outages is affected by system load and forced outage requirements. Typically, planned outages are scheduled during non-peak load periods such as the spring or fall.

During major outages, the boilers, controls, auxiliaries and duct work are inspected and repaired as necessary. Ongoing procedures include burner inspections and cleanings, burner tip replacements and maintenance of optimum flame patterns to achieve efficient fuel combustion. All repair information is stored for future reference.

### Plant Status

Hookers Point Station was brought back into service in late 1990. The plant was previously on long-term reserve standby status since April 1986. All required start-up stack testing has been done.



TO WHOM IT MAY CONCERN:

Please be advised that Lynn F. Robinson, Manager, Environmental Planning, is the authorized representative of Tampa Electric Company concerning matters with which this permit application deals.

Very Truly Yours,

William N. Cantrell  
Vice President  
Energy Resources Planning

sn/GG398

STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL REGULATION



SOUTHWEST DISTRICT

7601 HIGHWAY 301 NORTH  
TAMPA, FLORIDA 33610

813-985-7402  
SunCom - 570-8000

BOB GRAHAM  
GOVERNOR

VICTORIA J. TSCHINKEL  
SECRETARY

DR. RICHARD D. GARRITY  
DISTRICT MANAGER

January 14, 1987

Mr. A. Spencer Autry, Manager  
Environmental Planning  
Tampa Electric Company  
Post Office Box 111  
Tampa, FL 33601-0111

Dear Mr. Autry:

RE: Hillsborough County - AP  
Permit Nos. AO29-125685, 86, 87, 89,  
90 and 91.

Enclosed are amended permits No. AO29-125685, 86, 87, 89, 90  
and 91 to operate the facilities at Hooker's Point Unit Nos. 1,  
2, 3, 4, 5, and 6 respectively.

These amendments have been made in accordance with the requests  
of your staff during the meeting January 8, 1987, at the  
District Office, with Hillsborough County Environmental  
Protection Commission in attendance.

If you have any questions please call Mr. Tom John at (813)  
985-7402.

Sincerely,

W. C. Thomas, P.E.  
District Air Engineer

cc: HCEPC  
file

STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL REGULATION



SOUTHWEST DISTRICT

7601 HIGHWAY 301 NORTH  
TAMPA, FLORIDA 33610

813-985-7402  
SunCom - 570-8000

BOB GRAHAM  
GOVERNOR

VICTORIA J. TSCHINKEL  
SECRETARY

DR. RICHARD D. GARRITY  
DISTRICT MANAGER

PERMITTEE:

Mr. A. Spencer Autry, Manager  
Environmental Planning  
Tampa Electric Company  
P.O. Box 111  
Tampa, FL 33601-0111

PERMIT/CERTIFICATION

Permit No.: AO29-125691  
County: Hillsborough  
Issuance Date: 12-29-86  
Amended Date: 1-14-87  
Expiration Date: 12-22-91  
Project: Hooker's Point  
Station Unit # 6

This permit is issued under the provisions of Chapter 403, Florida Statutes, and Florida Administrative Code Rules 17-2 & 17-4. The above named permittee is hereby authorized to perform the work or operate the facility shown on the application and approved drawing(s), plans, and other documents, attached hereto or on file with the department and made a part hereof and specifically described as follows:

For the operation of a 778 MMBTU/hr steam generator designated as Unit #6. This front firing type boiler was manufactured by Babcock and Wilcox Corporation and is fired on No. 6 fuel oil. The unit has no pollution control equipment. Air pollutant emissions are controlled by efficient combustion of the fuel. Unit Nos. 6 has its own stack exhaust.

Location: At the foot of Hemlock Street, Tampa.

UTM: 17-358.0E 3091.0N NEDS NO: 0038 Point ID: 06

Replaces Permit No.: AO29-47721

PERMITTEE  
Tampa Electric Company

Permit No.: AO29-125691  
Project: Hooker's Point  
Station Unit No.6

GENERAL CONDITIONS:

1. The terms, conditions, requirements, limitations, and restrictions set forth herein are "Permit Conditions" and as such are binding upon the permittee and enforceable pursuant to the authority of Sections 403.161, 403.727, or 403.859 through 403.861, Florida Statutes. The permittee is hereby placed on notice that the department will review this permit periodically and may initiate the enforcement action for any violation of the "Permit Conditions" by the permittee, its agent, employees, servants or representatives.

2. This permit is valid only for the specific processes and operations applied for and indicated in the approved drawings or exhibits. Any unauthorized deviation from the approved drawings, exhibits, specifications, or conditions of this permit may constitute grounds for revocation and enforcement action by the department.

3. As provided in Subsections 403.087(6) and 403.712(5), Florida Statutes, the issuance of this permit does not convey any vested rights or any exclusive privileges. Nor does it authorize any injury to public or private property or any invasion of personal rights, nor infringement of federal, state or local laws or regulations. This permit does not constitute a waiver of or approval of any other department permit that may be required for other aspects of the total project which are not addressed in the permit.

4. This permit conveys no title to land or water, does not constitute state recognition or acknowledgement of title, and does not constitute authority for the use of submerged lands unless herein provided and the necessary title or leasehold interests have been obtained from the state. Only the Trustees of the Internal Improvement Trust Fund may express state opinion as to title.

5. This permit does not relieve the permittee from liability for harm or injury to human health or welfare, animal, plant or aquatic life or property and penalties therefore caused by the construction or operation of this permitted source, nor does it allow the permittee to cause pollution in contravention of Florida Statutes and department rules, unless specifically authorized by any order from the department.

PERMITTEE  
Tampa Electric Company

Permit No.: AO29-125691  
Project: Hooker's Point  
Station Unit No.6

6. The permittee shall at all times properly operate and maintain the facility and systems of treatment and control (and related appurtenances) that are installed or used by the permittee to achieve compliance with the conditions of this permit, as required by department rules. This provision includes the operation of backup or auxiliary facilities or similar systems when necessary to achieve compliance with the conditions of the permit and when required by department rules.

7. The permittee, by accepting this permit, specifically agrees to allow authorized department personnel, upon presentation of credentials or other documents as maybe required by law, access to the premises, at reasonable times, where the permitted activity is located or conducted for the purposes of;

a. Having access to and copying any records that must be kept under the conditions of the permit:

b. Inspecting the facility, equipment, practices, or operations regulated or required under this permit; and

c. Sampling or monitoring any substances or parameters at any location reasonably necessary to assure compliance with this permit or department rules.

Reasonable time may depend on the nature of the concern being investigated.

8. If, for any reason, the permittee does not comply with or will be unable to comply with any condition or limitation specified in this permit, the permittee shall immediately notify and provide the department with the following information:

(a) a description of and cause of non-compliance; and

(b) the period of non-compliance, including exact dates and times; or, if not corrected, the anticipated time the non-compliance is expected to continue, and steps being taken to reduce, eliminate, and prevent recurrence of the non-compliance.

The permittee shall be responsible for any and all damages which may result and may be subject to enforcement action by the department for penalties or revocation of this permit.

PERMITTEE  
Tampa Electric Company

Permit No.: AO29-125691  
Project: Hooker's Point  
Station Unit No.6

9. In accepting this permit, the permittee understands and agrees that all records, notes, monitoring data and other information relating to the construction or operation of this permitted source, which are submitted to the department, may be used by the department as evidence in any enforcement case arising under the Florida Statutes or department rules, except where such use is proscribed by Section 403.73 and 403.111, Florida Statutes.

10. The permittee agrees to comply with changes in department rules and Florida Statutes after a reasonable time for compliance, provided, however, the permittee does not waive any other rights granted by Florida Statutes or department rules.

11. This permit is transferable only upon department approval in accordance with Florida Administrative Code Rules 17-4.12 and 17-30.30, as applicable. The permittee shall be liable for any non-compliance of the permitted activity until the transfer is approved by the department.

12. This permit is required to be kept at the work site of the permitted activity during the entire period of construction or operation.

13. This permit also constitutes:

- ( ) Determination of Best Available Control Technology (BACT)
- ( ) Determination of Prevention of Significant Deterioration (PSD)
- ( ) Certification of Compliance with State Water Quality Standards (Section 401. PL 92-500)
- ( ) Compliance with New Source Performance Standards

14. The permittee shall comply with the following monitoring and record keeping requirements:

a. Upon request, the permittee shall furnish all records and plans required under department rules. The retention period for all records will be extended automatically, unless otherwise stipulated by the department, during the course of any unresolved enforcement action.



PERMITTEE  
Tampa Electric Company

Permit No.: AO29-125691  
Project: Hooker's Point  
Station Unit No.6

14. (con't)

b. The permittee shall retain at the facility or other location designated by this permit records of all monitoring information (including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation), copies of all reports required by this permit, and records of all data used to complete the application for this permit. The time period of retention shall be at least three years from the date of the sample, measurement, report or application unless otherwise specified by department rule.

c. Records of monitoring information shall include:

- the date, exact place, and time of sampling or measurements;
- the person responsible for performing the sampling or measurements;
- the date(s) analyses were performed;
- the person responsible for performing the analyses;
- the analytical techniques or methods used; and
- the results of such analyses.

15. When requested by the department, the permittee shall within a reasonable time furnish any information required by law which is needed to determine compliance with the permit. If the permittee becomes aware that relevant facts were not submitted or were incorrect in the permit application or in any report to the department, such facts or information shall be submitted or corrected promptly.

SPECIFIC CONDITIONS:

1. The maximum allowable particulate emission rate from this source shall be 0.1 pounds per MMBTU heat input over a two hour average [Section 17-2.650(2)(c)2.b.(i), F.A.C.], except for any 3 hours during a 24 hour period in which the boiler is being cleaned by soot blowing or experiencing a load change. Under these operating conditions, the maximum allowable particulate emission rate shall be 0.3 pounds per MMBTU heat input, providing best operational practices to minimize emissions are adhered to and the duration of excess emissions are minimized [Section 17-2.250(3), F.A.C.].

2. The maximum opacity from this source shall be 20 percent [Section 17-2.650(2)(c)2.b.(ii), F.A.C.] except for any 2 minutes during a 60 minute period in which the opacity shall not exceed 40 percent [Section 17-2.600(5), F.A.C.]; any 3

PERMITTEE  
Tampa Electric Company

Permit No.: AO29-125691  
Project: Hooker's Point  
Station Unit No.6

hours during a 24 hour period of excess emissions in which the boiler is being cleaned by soot blowing or experiencing a load change the opacity shall not exceed 60%; and excess emissions otherwise allowed under Sections 17-2.250(1) through (3), F.A.C.

3. The maximum allowable SO<sub>2</sub> emission rate from this unit shall be 1.1 pounds of SO<sub>2</sub> per MMBTU heat input [Subsection 17-2.600(5)(b)3.a.(v), F.A.C.].

4. Within 60 days after achieving 90% of the maximum rated capacity but not more than 180 days from startup, and annually thereafter, or within a ninety (90) day period prior to the next annual due date, this unit shall be tested for particulate matter [under both sootblowing and non-sootblowing operating conditions], sulfur dioxide, and visible emissions. The Method 9 test interval on this source shall be sixty (60) minutes. Testing procedures shall be consistent with the requirements of Section 17-2.700, F.A.C. One copy of test data shall be submitted to the Air Section of the Hillsborough County Environmental Protection Commission and one copy to the Southwest District Department of Environmental Regulation within 45 days of testing.

5. Compliance with the SO<sub>2</sub> emission standard may be demonstrated by calculating SO<sub>2</sub> emissions based on the sulfur content of the fuel in lieu of stack sampling as provided in Section 17-2.700, F.A.C. An analysis of the fuel oil shall be submitted with the stack test report.

6. Submit for this facility, each calendar year, on or before March 1, an emission report for the preceding calendar year containing the following information as per Section 17-4.14, F.A.C.

- (A) Annual amount of materials and/or fuels utilized.
- (B) Annual emissions (note calculation basis).
- (C) Any changes in the information contained in the permit application.

A copy of this report shall be submitted to the Southwest District Department of Environmental Regulation, and a copy to the Air Section, Hillsborough County Environmental Protection Commission.

PERMITTEE  
Tampa Electric Company

Permit No.: AO29-125691  
Project: Hooker's Point  
Station Unit No.6

7. Operation and Maintenance Plan [Section 17-2.650(2),  
F.A.C.].

A. Process System Performance Parameters:

- (1) Source Designator: Hooker's Point Unit No. 6
- (2) Design Fuel Consumption Rate: 126 barrels per hour
- (3) Steam Flow: 625,000 pounds per hour
- (4) Operating Temperature: 950 degrees F
- (5) Operating Pressure: 1450 psi

B. The following observations, checks, and operations apply to this source while in operation and shall be conducted on the schedule specified:

Continuously Monitored and Recorded

Steam Flow  
Steam Temperature  
Steam Pressure  
Excess Air

Daily

Check visible emissions  
Sample fuel oil for monthly composite analysis  
Maintain optimum flame pattern for efficient fuel combustion

Monthly

Monitor and back calculate fuel input rate

During Major Outages

Inspect boiler, controls, auxiliaries, and ductwork and repair as necessary.

Prior to Start-up

Inspect burners and clean as necessary.  
Inspect burner tips and replace as necessary.

C. Records of inspection, maintenance, and performance parameters shall be retained for a minimum of two years and shall be made available to the Department or Hillsborough County Environmental Protection Commission upon request [Subsection 17-2.650(2)(g)5., F.A.C.].

PERMITTEE  
Tampa Electric Company


Permit No.: AO29-125691  
Project: Hooker's Point  
Station Unit No.6

8. An original application to renew this operating permit and three (3) copies, with original seals and signatures, shall be submitted to the Hillsborough County Environmental Protection Commission, at least 60 days prior to the expiration date of this permit.

Issued: December 29, 1986

Amended this 14 day of Jan  
1987.

STATE OF FLORIDA DEPARTMENT OF  
ENVIRONMENTAL REGULATION

  
\_\_\_\_\_  
Richard D. Garrity, Ph.D.  
District Manager

STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL REGULATION



SOUTHWEST DISTRICT

7601 HIGHWAY 301 NORTH  
TAMPA, FLORIDA 33610

813-985-7402  
SunCom - 570-8000

BOB GRAHAM  
GOVERNOR

VICTORIA J. TSCHINKEL  
SECRETARY

DR. RICHARD D. GARRITY  
DISTRICT MANAGER

December 22, 1986

NOTICE OF PERMIT

Mr. A. Spencer Autry, Manager  
Environmental Planning  
Tampa Electric Company  
Post Office Box 111  
Tampa, FL 33601-0111

Dear Mr. Autry:

Re: Hillsborough County - AP  
Hooker's Point Station Unit #6

Enclosed is Permit Number AO29-125691 to operate a 778 MMBTU/hr steam generator designated as Unit #6, issued pursuant to Section 403.087, Florida Statutes.

Persons whose substantial interests are affected by this permit have a right, pursuant to Section 120.57, Florida Statutes, to petition for an administrative determination (hearing) on it. The petition must conform to the requirements of Chapters 17-103 and 28-5.201, FAC, and must be filed (received) in the Department's Office of General Counsel, 2600 Blair Stone Road, Tallahassee Florida 32301, within fourteen (14) days of receipt of this notice. Failure to file a petition within the fourteen (14) days constitutes a waiver of any right such person has to an administrative determination (hearing) pursuant to Section 120.57, Florida Statutes. This permit is final and effective on the date filed with the Clerk of the Department unless a petition is filed in accordance with this paragraph or unless a request for extension of time in which to file a petition is filed within the time specified for filing a petition and conforms to Rule 17-103.070, FAC. Upon timely filing of a petition or a request for an extension of time, this permit will not be effective until further Order of the Department.

Mr. A. Spencer Autry  
December 22, 1986

Page Two

When the Order (Permit) is final, any party to the Order has the right to seek judicial review of the Order pursuant to Section 120.68, Florida Statutes, by the filing of a Notice of Appeal pursuant to Rule 9.110, Florida Rules of Appellate Procedure, with the Clerk of the Department in the Office of General Counsel, 2600 Blair Stone Road, Tallahassee, Florida 32301; and by filing a copy of the Notice of Appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal. The Notice of Appeal must be filed within 30 days from the date the Final Order is filed with the Clerk of the Department.

Executed in Tampa, Florida.

Sincerely,



Tom John, P.E.  
Permitting Engineer

TJ/dtw


Attachment: as stated

cc: HCEPC

CERTIFICATE OF SERVICE

This is to certify that this NOTICE OF PERMIT and all copies were mailed before the close of business on 12/29/86 to the listed persons.

FILING AND ACKNOWLEDGEMENT  
FILED, on this date, pursuant  
to §120.52(10), Florida  
Statutes, with the designated  
Department Clerk, receipt of  
which is hereby acknowledged.

  
Clerk

12/29/86  
Date

STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL REGULATION



SOUTHWEST DISTRICT

7601 HIGHWAY 301 NORTH  
TAMPA, FLORIDA 33610

813-985-7402  
SunCom - 570-8000

BOB GRAHAM  
GOVERNOR

VICTORIA J. TSCHINKEL  
SECRETARY

DR. RICHARD D. GARRITY  
DISTRICT MANAGER

PERMITTEE:

Mr. A. Spencer Autry, Manager  
Environmental Planning  
Tampa Electric Company  
Post Office Box 111  
Tampa, FL 33601-0111

PERMIT/CERTIFICATION

Permit No.: AO29-125691  
County: Hillsborough  
Expiration Date: 12-22-91  
Project: Hooker's Point  
Station Unit #6

This permit is issued under the provisions of Chapter 403, Florida Statutes, and Florida Administrative Code Rules 17-2 & 17-4. The above named permittee is hereby authorized to perform the work or operate the facility shown on the application and approved drawing(s), plans, and other documents, attached hereto or on file with the department and made a part hereof and specifically described as follows:

For the operation of a 778 MMBTU/hr steam generator designated as Unit #6. This front firing type boiler was manufactured by Babcock and Wilcox Corporation and is fired on No. 6 fuel oil. The unit has no pollution control equipment. Air pollutant emissions are controlled by efficient combustion of the fuel. Unit Nos. 6 has its own stack exhaust.

Location: At the foot of Hemlock Street, Tampa.

UTM: 17-358.OE 3091.ON NEDS NO: 0038 Point ID: 06

Replaces Permit No.: AO29-47721

PERMITTEE  
Tampa Electric Company

Permit No.: AO29-125691  
Project: Hooker's Point  
Station Unit No.6

GENERAL CONDITIONS:

1. The terms, conditions, requirements, limitations, and restrictions set forth herein are "Permit Conditions" and as such are binding upon the permittee and enforceable pursuant to the authority of Sections 403.161, 403.727, or 403.859 through 403.861, Florida Statutes. The permittee is hereby placed on notice that the department will review this permit periodically and may initiate the enforcement action for any violation of the "Permit Conditions" by the permittee, its agent, employees, servants or representatives.
2. This permit is valid only for the specific processes and operations applied for and indicated in the approved drawings or exhibits. Any unauthorized deviation from the approved drawings, exhibits, specifications, or conditions of this permit may constitute grounds for revocation and enforcement action by the department.
3. As provided in Subsections 403.087(6) and 403.712(5), Florida Statutes, the issuance of this permit does not convey any vested rights or any exclusive privileges. Nor does it authorize any injury to public or private property or any invasion of personal rights, nor infringement of federal, state or local laws or regulations. This permit does not constitute a waiver of or approval of any other department permit that may be required for other aspects of the total project which are not addressed in the permit.
4. This permit conveys no title to land or water, does not constitute state recognition or acknowledgement of title, and does not constitute authority for the use of submerged lands unless herein provided and the necessary title or leasehold interests have been obtained from the state. Only the Trustees of the Internal Improvement Trust Fund may express state opinion as to title.
5. This permit does not relieve the permittee from liability for harm or injury to human health or welfare, animal, plant or aquatic life or property and penalties therefore caused by the construction or operation of this permitted source, nor does it allow the permittee to cause pollution in contravention of Florida Statutes and department rules, unless specifically authorized by any order from the department.



PERMITTEE  
Tampa Electric Company

Permit No.: AO29-125691  
Project: Hooker's Point  
Station Unit No.6

6. The permittee shall at all times properly operate and maintain the facility and systems of treatment and control (and related appurtenances) that are installed or used by the permittee to achieve compliance with the conditions of this permit, as required by department rules. This provision includes the operation of backup or auxiliary facilities or similar systems when necessary to achieve compliance with the conditions of the permit and when required by department rules.

7. The permittee, by accepting this permit, specifically agrees to allow authorized department personnel, upon presentation of credentials or other documents as maybe required by law, access to the premises, at reasonable times, where the permitted activity is located or conducted for the purposes of:

a. Having access to and copying any records that must be kept under the conditions of the permit:

b. Inspecting the facility, equipment, practices, or operations regulated or required under this permit; and

c. Sampling or monitoring any substances or parameters at any location reasonably necessary to assure compliance with this permit or department rules.

Reasonable time may depend on the nature of the concern being investigated.

8. If, for any reason, the permittee does not comply with or will be unable to comply with any condition or limitation specified in this permit, the permittee shall immediately notify and provide the department with the following information:

(a) a description of and cause of non-compliance; and

(b) the period of non-compliance, including exact dates and times; or, if not corrected, the anticipated time the non-compliance is expected to continue, and steps being taken to reduce, eliminate, and prevent recurrence of the non-compliance.

The permittee shall be responsible for any and all damages which may result and may be subject to enforcement action by the department for penalties or revocation of this permit.

PERMITTEE  
Tampa Electric Company

Permit No.: AO29-125691  
Project: Hooker's Point  
Station Unit No.6

9. In accepting this permit, the permittee understands and agrees that all records, notes, monitoring data and other information relating to the construction or operation of this permitted source, which are submitted to the department, may be used by the department as evidence in any enforcement case arising under the Florida Statutes or department rules, except where such use is proscribed by Section 403.73 and 403.111, Florida Statutes.

10. The permittee agrees to comply with changes in department rules and Florida Statutes after a reasonable time for compliance, provided, however, the permittee does not waive any other rights granted by Florida Statutes or department rules.

11. This permit is transferable only upon department approval in accordance with Florida Administrative Code Rules 17-4.12 and 17-30.30, as applicable. The permittee shall be liable for any non-compliance of the permitted activity until the transfer is approved by the department.

12. This permit is required to be kept at the work site of the permitted activity during the entire period of construction or operation.

13. This permit also constitutes:

- ( ) Determination of Best Available Control Technology (BACT)
- ( ) Determination of Prevention of Significant Deterioration (PSD)
- ( ) Certification of Compliance with State Water Quality Standards (Section 401. PL 92-500)
- ( ) Compliance with New Source Performance Standards

14. The permittee shall comply with the following monitoring and record keeping requirements:

a. Upon request, the permittee shall furnish all records and plans required under department rules. The retention period for all records will be extended automatically, unless otherwise stipulated by the department, during the course of any unresolved enforcement action.

PERMITTEE  
Tampa Electric Company

Permit No.: AO29-125691  
Project: Hooker's Point  
Station Unit No.6

14. (con't)

b. The permittee shall retain at the facility or other location designated by this permit records of all monitoring information (including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation), copies of all reports required by this permit, and records of all data used to complete the application for this permit. The time period of retention shall be at least three years from the date of the sample, measurement, report or application unless otherwise specified by department rule.

c. Records of monitoring information shall include:

- the date, exact place, and time of sampling or measurements;
- the person responsible for performing the sampling or measurements;
- the date(s) analyses were performed;
- the person responsible for performing the analyses;
- the analytical techniques or methods used; and
- the results of such analyses.

15. When requested by the department, the permittee shall within a reasonable time furnish any information required by law which is needed to determine compliance with the permit. If the permittee becomes aware that relevant facts were not submitted or were incorrect in the permit application or in any report to the department, such facts or information shall be submitted or corrected promptly.

#### SPECIFIC CONDITIONS:

1. The maximum allowable particulate emission rate from this source shall be 0.1 pounds per MMBTU heat input over a two hour average [Section 17-2.650(2)(c)2.b.(i), F.A.C.], except for any 3 hours during a 24 hour period in which the boiler is being cleaned by soot blowing or experiencing a load change. Under these operating conditions, the maximum allowable particulate emission rate shall be 0.3 pounds per MMBTU heat input, providing best operational practices to minimize emissions are adhered to and the duration of excess emissions are minimized [Section 17-2.250(3), F.A.C.].

2. The maximum opacity from this source shall be 20 percent [Section 17-2.650(2)(c)2.b.(ii), F.A.C.] except for any 2 minutes during a 60 minute period in which the opacity shall not exceed 40 percent [Section 17-2.600(5), F.A.C.]; any 3

PERMITTEE  
Tampa Electric Company

Permit No.: AO29-125691  
Project: Hooker's Point  
Station Unit No.6

hours during a 24 hour period of excess emissions in which the boiler is being cleaned by soot blowing or experiencing a load change the opacity shall not exceed 60%; and excess emissions otherwise allowed under Sections 17-2.250(1) through (3), F.A.C.

3. The maximum allowable SO<sub>2</sub> emission rate from this unit shall be 1.1 pounds of SO<sub>2</sub> per MMBTU heat input [Subsection 17-2.600(5)(b)3.a.(v), F.A.C.].

4. Within 60 days after achieving 90% of the rated capacity but not more than 180 days from startup, and annually thereafter, or within a ninety (90) day period prior to the next annual due date, this unit shall be tested for particulate matter [under both sootblowing and non-sootblowing operating conditions], sulfur dioxide, and visible emissions. The Method 9 test interval on this source shall be sixty (60) minutes. Testing procedures shall be consistent with the requirements of Section 17-2.700, F.A.C. One copy of test data shall be submitted to the Air Section of the Hillsborough County Environmental Protection Commission and one copy to the Southwest District Department of Environmental Regulation within 45 days of testing.

5. Compliance with the SO<sub>2</sub> emission standard may be demonstrated by calculating SO<sub>2</sub> emissions based on the sulfur content of the fuel in lieu of stack sampling as provided in Section 17-2.700, F.A.C. An analysis of the fuel oil shall be submitted with the stack test report.

6. A report shall be submitted to both the Florida Department of Environmental Regulation and Hillsborough County Environmental Protection Commission within 30 days following each calendar quarter detailing any excess opacity readings recorded during the three month period. For the purpose of this report, excess emissions shall be defined as all six minute averages of opacity greater than 20% except as specified in Specific Condition No. 2.

7. Submit for this facility, each calendar year, on or before March 1, an emission report for the preceding calendar year containing the following information as per Section 17-4.14, F.A.C.

- (A) Annual amount of materials and/or fuels utilized.
- (B) Annual emissions (note calculation basis).
- (C) Any changes in the information contained in the permit application.

PERMITTEE  
Tampa Electric Company

Permit No.: AO29-125691  
Project: Hooker's Point  
Station Unit No.6

A copy of this report shall be submitted to the Southwest District Department of Environmental Regulation, and a copy to the Air Section, Hillsborough County Environmental Protection Commission.

8. Operation and Maintenance Plan [Section 17-2.650(2), F.A.C.].

A. Process System Performance Parameters:

- (1) Source Designator: Hooker's Point Unit No. 1
- (2) Design Fuel Consumption Rate: 43 barrels per hour
- (3) Steam Flow: 220,000 pounds per hour
- (4) Operating Temperature: 900 degrees F
- (5) Operating Pressure: 960 psi

B. The following observations, checks, and operations apply to this source while in operation and shall be conducted on the schedule specified:

Continuously Monitored and Recorded

Steam Flow  
Steam Temperature  
Steam Pressure  
Excess Air

Daily

Check visible emissions  
Sample fuel oil monthly composite analysis  
Maintain optimum flame pattern for efficient fuel combustion

Monthly

Monitor and back calculate fuel input rate

During Major Outages

Inspect boiler, controls, auxiliaries, and ductwork and repair as necessary.

Prior to Start-up

Inspect burners and clean as necessary.  
Inspect burner tips and replace as necessary.

C. Records of inspection, maintenance, and performance parameters shall be retained for a minimum of two years and shall be made available to the Department or Hillsborough County Environmental Protection Commission upon request [Subsection 17-2.650(2)(g)5., F.A.C.].

PERMITTEE  
Tampa Electric Company

Permit No.: AO29-125691  
Project: Hooker's Point  
Station Unit No.6

9. An original application to renew this operating permit shall be submitted to the Southwest District Department of Environmental Regulation, and a copy, with original seals and signatures, shall be submitted to the Hillsborough County Environmental Protection Commission, at least 60 days prior to the expiration date of this permit.

Issued this 29 day of Dec.  
1986

STATE OF FLORIDA DEPARTMENT OF  
ENVIRONMENTAL REGULATION



For Richard D. Garrity, Ph.D.  
District Manager

2-65447

CHECK NO.

65447


 POST OFFICE BOX 111  
 TAMPA, FLORIDA 33601

PAY:

DATE

 TWO THOUSAND SEVENTY AND NO/100 \*\*\*\*\*  
 DOLLARS \*\*\*\*\*

09 24 86

\$ \*\*\*\*\*2,070.00

 TO HILLSBOROUGH COUNTY BOARD OF  
 THE COUNTY COMMISSIONERS  
 ORDER  
 OF

ONLY ONE SIGNATURE REQUIRED ON CHECKS OF \$2500.00 OR LESS

NCNB NATIONAL BANK OF FLORIDA • TAMPA, FLORIDA

THE ACCOMPANYING CHECK IS IN FULL PAYMENT OF ITEMS BELOW - DETACH BEFORE CASHING

INVOICE NO.	DATE	VOUCHER	GROSS AMOUNT	DISCOUNT	NET AMOUNT
092286A	092286	222228	PERMIT 345.00		345.00
092286B	092286	222229	PERMIT 345.00		345.00
092286C	092286	222230	PERMIT 345.00		345.00
092286D	092286	222231	PERMIT 345.00		345.00
092286E	092286	222232	PERMIT 345.00		345.00
092286F	092286	222233	PERMIT 345.00		345.00
CHECK NO.	DATE	VENDOR NO.	VENDOR NAME	TOTAL AMOUNT	
65447	092486	H11076	HILLSBOROUGH COUNTY B	2,070.00	

TAMPA ELECTRIC COMPANY • P.O. BOX 111 TAMPA, FL. 33601 • (813) 228-4111

2-65563

CHECK NO.


65563

POST OFFICE BOX 111  
TAMPA, FLORIDA 33601

PAY:

DATE

THREE THOUSAND AND NO/100 DOLLARS \*\*\*\* 09 24 86 \$ \*\*\*\*\*3,000.00

TO  
THE  
ORDER  
OF  
FLORIDA DEPT OF ENVIRONMENTAL  
REGULATION  
W. H. Steff  
ONLY ONE SIGNATURE REQUIRED ON CHECKS OF \$2500.00 OR LESS

NCNB NATIONAL BANK OF FLORIDA • TAMPA, FLORIDA

THE ACCOMPANYING CHECK IS IN FULL PAYMENT OF ITEMS BELOW - DETACH BEFORE CASHING

INVOICE NO.	DATE	VOUCHER	GROSS AMOUNT	DISCOUNT	NET AMOUNT
092286A	092286	222234	PERMIT 500.00		500.00
092286B	092286	222235	PERMIT 500.00		500.00
092286C	092286	222236	PERMIT 500.00		500.00
092286D	092286	222237	PERMIT 500.00		500.00
092286E	092286	222238	PERMIT 500.00		500.00
092286F	092286	222239	PERMIT 500.00		500.00
CHECK NO.	DATE	VENDOR NO.	VENDOR NAME	TOTAL AMOUNT	
65563	092486	FLO004	FLORIDA DEPT OF ENVIR	3,000.00	

TAMPA ELECTRIC COMPANY • P.O. BOX 111 TAMPA, FL. 33601 • (813) 228-4111





September 25, 1986

RE: Hookers Point Station Boiler No. 6  
Air Operations Permit Application

TO WHOM IT MAY CONCERN:

Please be advised that A. Spencer Autry, Manager of Environmental Planning, is the authorized representative of Tampa Electric Company concerning matters with which this permit application deals.


Very truly yours,

Heywood A. Turner  
Senior Vice President  
Production

HAT/tb

STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL REGULATION

TWIN TOWERS OFFICE BUILDING  
2600 BLAIR STONE ROAD  
TALLAHASSEE, FLORIDA 32301



PAID OCT 2 1986

BOB GRAHAM  
GOVERNOR

VICTORIA J. TSCHINKEL  
SECRETARY

A029-125691

APPLICATION FOR RENEWAL OF  
PERMIT TO OPERATE AIR POLLUTION SOURCE(S)

If major alterations have occurred, the applicant should complete the Standard Air Permit Application Form.

Source Type: Air Pollution Renewal of DER Permit No. A029-47721

Company Name: Tampa Electric Company County: Hillsborough

Identify the specific emission point source(s) addressed in this application (i.e., Lime Kiln No. 4 with Venturi Scrubber; Peaking Unit No. 2, Gas Fired):

Hookers Point Station Boiler 6.

Source Location: Street: Hemlock Avenue City: Tampa

UTM: East 358,000 North 3,091,000

Latitude: 2 7° 5 6' 2 0"N. Longitude: 8 2° 2 6' 3 4"W.

1. Attach a check made payable to the Department of Environmental Regulation in accordance with operation permit fee schedule set forth in Florida Administrative Code Rule 17-4.05.
2. Have there been any alterations to the plant since last permitted? ☐ Yes ☒ No  
If minor alterations have occurred, describe on a separate sheet and attach.
3. Attach the last compliance test report required per permit conditions if not submitted previously. Submitted 2/13/86.
4. Have previous permit conditions been adhered to? ☒ Yes ☐ No If no, explain on a separate sheet and attach.
5. Has there been any malfunction of the pollution control equipment during tenure of current permit? ☐ Yes ☒ No If yes, and not previously reported, give brief details and what action was taken on a separate sheet and attach.
6. Has the pollution control equipment been maintained to preserve the collection efficiency last permitted by the Department? ☒ Yes ☐ No
7. Has the annual operating report for the last calendar year been submitted? ☒ Yes ☐ No If no, please attach.

1. Please provide the following information if applicable:

A. Raw Materials and Chemical Used in Your Process: Not Applicable.

Description	Type	Contaminant	%wt	Utilization
				Rate lbs/hr

B. Product Weight (lbs/hr): Not Applicable.

C. Fuels

Type (Be Specific)	Consumption*		Maximum Heat Input (MMBTU/hr)
	Avg/hr*	BBLS/HR Max/hr**	
Fuel Oil	77.6*	126.0	778

D. Normal Equipment Operating Time: hrs/day 24; days/wk 7; wks/yr 52;  
hrs/yr (power plants only) \*\*; if seasonal, describe \_\_\_\_\_

\*Average value, 1984 and 1985 emissions inventories.  
\*\*See Attachment A.

The undersigned owner or authorized representative\*\*\* of Tampa Electric Company is fully aware that the statements made in this application for a renewal of a permit to operate an air pollution source are true, correct and complete to the best of his knowledge and belief. Further, the undersigned agrees to maintain and operate the pollution source and pollution control facilities in such a manner as to comply with the provisions of Chapter 403, Florida Statutes, and all the rules and regulations of the Department. He also understands that a permit, if granted by the Department, will be non-transferable and he will promptly notify the Department upon sale or legal transfer of the permitted facility.

\*During actual time of operation.

\*\*Units: Natural Gas-MMCF/hr;  
Fuel Oils-barrels/hr; Coal-lbs/hr.

\*\*\*Attach letter of authorization if not previously submitted

A. Spencer Autry  
Signature, Owner or Authorized Representative  
(Notarization is mandatory)

A. Spencer Autry, Manager, Environmental Planning  
Typed Name and Title

P.O. Box 111

Address

Tampa

Florida 33601

City

State Zip

9/25/86

(813) 228-4111

Date

Telephone No.

ER Form 17-1, 2001  
Effective November 30, 1982.

Page 2 of 2

NOTARY PUBLIC  
9/25/86  
R. J. Zepher  
NOTARY PUBLIC STATE OF FLORIDA  
MY COMMISSION EXP. NOV 14, 1989  
BONDED THRU GENERAL INS. UND.

## ATTACHMENT A

### HOOKERS POINT STATION - BOILERS 1 THROUGH 6

#### OPERATION AND MAINTENANCE PLAN

##### Introduction

Hookers Point Station is owned and operated by Tampa Electric Company. The plant is located on the shore of Hillsborough Bay off Sparkman Channel. The plant consists of six boilers and five turbine generator units. Boilers 1 through 5 are connected to a header system which supplies steam to four turbine generators. Boiler 6 supplies steam to turbine generator number 5.

The Hookers Point boilers burn No. 6 fuel oil. The boiler manufacturers, types and in-service dates are listed below:

<u>Boiler</u>	<u>Service Date</u>	<u>Manufacturer</u>	<u>Type</u>
1	1948	Babcock and Wilcox	Front Firing
2	1948	Babcock and Wilcox	Front Firing
3	1950	Babcock and Wilcox	Front Firing
4	1950	Babcock and Wilcox	Front Firing
5	1953	Babcock and Wilcox	Front Firing
6	1955	Combustion Engineering	Tangential Firing

The boilers exhaust gases through stacks at an elevation of 280 feet.

##### Process System Performance Parameters

Boilers 1 through 6 burn low sulfur No. 6 fuel oil. Fuel oil quality is monitored upon delivery. In addition, daily samples are taken for a monthly composite analysis. The design fuel consumption, steam flow rates, operating temperatures and operating pressures are listed below.

<u>Boiler</u>	<u>Fuel Consumption</u>	<u>Steam Flow</u>	<u>Operating Temperature</u>	<u>Operating Pressure</u>
1	43.0 BBLS/HR	220,000 LBS/HR	900°F	960 psi
2	43.0	220,000	900°	960
3	59.4	303,000	900°	960
4	59.4	303,000	900°	960
5	86.2	440,000	900°	975
6	126.0	625,000	950°	1450

Actual fuel input to the boilers is back calculated from monthly fuel tank drawdown and boiler efficiencies. Steam flow, temperature and pressure are continuously monitored and recorded on control room charts. Fuel oil temperature and pressure are maintained at optimum levels. Excess air is continuously monitored, recorded and maintained at levels to produce efficient fuel combustion.

#### Maintenance Inspection

All generating units of the Tampa Electric Company system are regularly scheduled for periodic maintenance. The schedule for planned maintenance outages is affected by system load and forced outage requirements. Typically, planned outages are scheduled during non-peak load periods such as the spring or fall.

During major outages, the boilers, controls, auxiliaries and duct work are inspected and repaired as necessary. Ongoing procedures include burner inspections and cleanings, burner tip replacements and maintenance of optimum flame patterns to achieve efficient fuel combustion. All repair information is stored for future reference.

#### Plant Status

Hookers Point Station was placed on Long Term Reserve Standby status in April 1986. Under expected load growth conditions and present assumptions, these units are expected to be returned to service sometime after 1989. However, these units could be brought into service earlier if load growth is higher than expected or other circumstances dictate.

2-65447

CHECK NO.

65447

POST OFFICE BOX 111  
TAMPA, FLORIDA 33601

PAY:

DATE

TWO THOUSAND SEVENTY AND NO/100 \*\*\*\*\*  
DOLLARS \*\*\*\*\*

09 24 86

\$ \*\*\*\*\*2,070.00

TO HILLSBOROUGH COUNTY BOARD OF  
THE COUNTY COMMISSIONERS  
ORDER  
OF
  
 ONLY ONE SIGNATURE REQUIRED ON CHECKS OF \$2500.00 OR LESS

NCNB NATIONAL BANK OF FLORIDA • TAMPA, FLORIDA

THE ACCOMPANYING CHECK IS IN FULL PAYMENT OF ITEMS BELOW - DETACH BEFORE CASHING

INVOICE NO.	DATE	VOUCHER	GROSS AMOUNT	DISCOUNT	NET AMOUNT
092286A	092286	222228	PERMIT 345.00		345.00
092286B	092286	222229	PERMIT 345.00		345.00
092286C	092286	222230	PERMIT 345.00		345.00
092286D	092286	222231	PERMIT 345.00		345.00
092286E	092286	222232	PERMIT 345.00		345.00
092286F	092286	222233	PERMIT 345.00		345.00
CHECK NO.	DATE	VENDOR NO.	VENDOR NAME	TOTAL AMOUNT	
65447	092486	H11076	HILLSBOROUGH COUNTY B	2,070.00	

TAMPA ELECTRIC COMPANY • P.O. BOX 111 TAMPA, FL. 33601 • (813) 228-4111

2-65563

CHECK NO.

65563

TAMPA  
ELECTRIC  
A TECO ENERGY COMPANYPOST OFFICE BOX 111  
TAMPA, FLORIDA 33601

PAY:

DATE

THREE THOUSAND AND NO/100 DOLLARS \*\*\*\* 09 24 86 \$ \*\*\*\*\*3,000.00


TO  
THE  
ORDER  
OF  
FLORIDA DEPT OF ENVIRONMENTAL  
REGULATION  
W. H. Stapp  
ONLY ONE SIGNATURE REQUIRED ON CHECKS OF \$2500.00 OR LESS

NCNB NATIONAL BANK OF FLORIDA • TAMPA, FLORIDA

THE ACCOMPANYING CHECK IS IN FULL PAYMENT OF ITEMS BELOW - DETACH BEFORE CASHING

INVOICE NO.	DATE	VOUCHER	GROSS AMOUNT	DISCOUNT	NET AMOUNT
092286A	092286	222234	PERMIT 500.00		500.00
092286B	092286	222235	PERMIT 500.00		500.00
092286C	092286	222236	PERMIT 500.00		500.00
092286D	092286	222237	PERMIT 500.00		500.00
092286E	092286	222238	PERMIT 500.00		500.00
092286F	092286	222239	PERMIT 500.00		500.00
CHECK NO.	DATE	VENDOR NO.	VENDOR NAME	TOTAL AMOUNT	
65563	092486	FLO004	FLORIDA DEPT OF ENVIR	3,000.00	

TAMPA ELECTRIC COMPANY • P.O. BOX 111 TAMPA, FL. 33601 • (813) 228-4111



September 25, 1986

RE: Hookers Point Station Boiler No. 6  
Air Operations Permit Application

TO WHOM IT MAY CONCERN:

Please be advised that A. Spencer Autry, Manager of Environmental Planning, is the authorized representative of Tampa Electric Company concerning matters with which this permit application deals.

Very truly yours,

Heywood A. Turner  
Senior Vice President  
Production

HAT/tb



STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL REGULATION

TWIN TOWERS OFFICE BUILDING  
2600 BLAIR STONE ROAD  
TALLAHASSEE, FLORIDA 32301



BOB GRAHAM  
GOVERNOR  
VICTORIA J. TSCHINKEL  
SECRETARY

APPLICATION FOR RENEWAL OF  
PERMIT TO OPERATE AIR POLLUTION SOURCE(S)

If major alterations have occurred, the applicant should complete the Standard Air Permit Application Form.

Source Type: Air Pollution Renewal of DER Permit No. A029-47721  
Company Name: Tampa Electric Company County: Hillsborough

Identify the specific emission point source(s) addressed in this application (i.e., Lime Kiln No. 4 with Venturi Scrubber; Peaking Unit No. 2, Gas Fired):

Hookers Point Station Boiler 6.

Source Location: Street: Hemlock Avenue City: Tampa  
UTM: East 358,000 North 3,091,000  
Latitude: 2 7° 5 6' 2 0"N. Longitude: 8 2° 2 6' 3 4"W.

1. Attach a check made payable to the Department of Environmental Regulation in accordance with operation permit fee schedule set forth in Florida Administrative Code Rule 17-4.05.
2. Have there been any alterations to the plant since last permitted? ☐ Yes ☒ No  
If minor alterations have occurred, describe on a separate sheet and attach.
3. Attach the last compliance test report required per permit conditions if not submitted previously. Submitted 2/13/86.
4. Have previous permit conditions been adhered to? ☒ Yes ☐ No If no, explain on a separate sheet and attach.
5. Has there been any malfunction of the pollution control equipment during tenure of current permit? ☐ Yes ☒ No If yes, and not previously reported, give brief details and what action was taken on a separate sheet and attach.
6. Has the pollution control equipment been maintained to preserve the collection efficiency last permitted by the Department? ☒ Yes ☐ No
7. Has the annual operating report for the last calendar year been submitted? ☒ Yes ☐ No If no, please attach.

1. Please provide the following information if applicable:

A. Raw Materials and Chemical Used in Your Process: Not Applicable.

Description	Type	Contaminant	%Wt	Utilization	Rate	lbs/hr

B. Product Weight (lbs/hr): Not Applicable.

C. Fuels

Type (Be Specific)	Consumption*	BBLS/HR Avg/hr* Max/hr**	Maximum Heat Input (MMBTU/hr)
Fuel Oil	77.6*	126.0	778

D. Normal Equipment Operating Time: hrs/day 24 ; days/wk 7 ; wks/yr 52 ;  
hrs/yr (power plants only) \*\* ; if seasonal, describe

\*Average value, 1984 and 1985 emissions inventories.  
\*\*See Attachment A.

The undersigned owner or authorized representative\*\*\* of Tampa Electric Company is fully aware that the statements made in this application for a renewal of a permit to operate an air pollution source are true, correct and complete to the best of his knowledge and belief. Further, the undersigned agrees to maintain and operate the pollution source and pollution control facilities in such a manner as to comply with the provisions of Chapter 403, Florida Statutes, and all the rules and regulations of the Department. He also understands that a permit, if granted by the Department, will be non-transferable and he will promptly notify the Department upon sale or legal transfer of the permitted facility.

\*During actual time of operation.

\*\*Units: Natural Gas-MMCF/hr;  
Fuel Oils-barrels/hr; Coal-lbs/hr.

\*\*\*Attach letter of authorization if not previously submitted.

[Signature]  
Signature, Owner or Authorized Representative  
(Notarization is mandatory)

A. Spencer Autry, Manager, Environmental Planning  
Typed Name and Title

P.O. Box 111

Address

Tampa

City

Florida 33601

State Zip

9/25/86

Date

(813) 228-4111

Telephone No.

ER Form 17-1.202(4)  
Effective November 30, 1982

Page 2 of 2

NOTARY PUBLIC  
NOTARY PUBLIC STATE OF FLORIDA  
MY COMMISSION EXP. NOV 14, 1989

## ATTACHMENT A

### HOOKERS POINT STATION - BOILERS 1 THROUGH 6

#### OPERATION AND MAINTENANCE PLAN

##### Introduction

Hookers Point Station is owned and operated by Tampa Electric Company. The plant is located on the shore of Hillsborough Bay off Sparkman Channel. The plant consists of six boilers and five turbine generator units. Boilers 1 through 5 are connected to a header system which supplies steam to four turbine generators. Boiler 6 supplies steam to turbine generator number 5.

The Hookers Point boilers burn No. 6 fuel oil. The boiler manufacturers, types and in-service dates are listed below:

<u>Boiler</u>	<u>Service Date</u>	<u>Manufacturer</u>	<u>Type</u>
1	1948	Babcock and Wilcox	Front Firing
2	1948	Babcock and Wilcox	Front Firing
3	1950	Babcock and Wilcox	Front Firing
4	1950	Babcock and Wilcox	Front Firing
5	1953	Babcock and Wilcox	Front Firing
6	1955	Combustion Engineering	Tangential Firing

The boilers exhaust gases through stacks at an elevation of 280 feet.

##### Process System Performance Parameters

Boilers 1 through 6 burn low sulfur No. 6 fuel oil. Fuel oil quality is monitored upon delivery. In addition, daily samples are taken for a monthly composite analysis. The design fuel consumption, steam flow rates, operating temperatures and operating pressures are listed below.

<u>Boiler</u>	<u>Fuel Consumption</u>	<u>Steam Flow</u>	<u>Operating Temperature</u>	<u>Operating Pressure</u>
1	43.0 BBLs/HR	220,000 LBS/HR	900°F	960 psi
2	43.0	220,000	900°	960
3	59.4	303,000	900°	960
4	59.4	303,000	900°	960
5	86.2	440,000	900°	975
6	126.0	625,000	950°	1450

Actual fuel input to the boilers is back calculated from monthly fuel tank drawdown and boiler efficiencies. Steam flow, temperature and pressure are continuously monitored and recorded on control room charts. Fuel oil temperature and pressure are maintained at optimum levels. Excess air is continuously monitored, recorded and maintained at levels to produce efficient fuel combustion.

#### Maintenance Inspection

All generating units of the Tampa Electric Company system are regularly scheduled for periodic maintenance. The schedule for planned maintenance outages is affected by system load and forced outage requirements. Typically, planned outages are scheduled during non-peak load periods such as the spring or fall.

During major outages, the boilers, controls, auxiliaries and duct work are inspected and repaired as necessary. Ongoing procedures include burner inspections and cleanings, burner tip replacements and maintenance of optimum flame patterns to achieve efficient fuel combustion. All repair information is stored for future reference.

#### Plant Status

Hookers Point Station was placed on Long Term Reserve Standby status in April 1986. Under expected load growth conditions and present assumptions, these units are expected to be returned to service sometime after 1989. However, these units could be brought into service earlier if load growth is higher than expected or other circumstances dictate.

2-65447

CHECK NO.

65447

POST OFFICE BOX 111  
TAMPA, FLORIDA 33601

PAY:

DATE

TWO THOUSAND SEVENTY AND NO/100 \*\*\*\*\*  
DOLLARS \*\*\*\*\*

09 24 86

\$ \*\*\*\*\*2,070.00

TO HILLSBOROUGH COUNTY BOARD OF  
THE COUNTY COMMISSIONERS  
ORDER  
OF

ONLY ONE SIGNATURE REQUIRED ON CHECKS OF \$2500.00 OR LESS

NCNB NATIONAL BANK OF FLORIDA • TAMPA, FLORIDA

THE ACCOMPANYING CHECK IS IN FULL PAYMENT OF ITEMS BELOW - DETACH BEFORE CASHING

INVOICE NO.	DATE	VOUCHER	GROSS AMOUNT	DISCOUNT	NET AMOUNT
092286A	092286	222228	PERMIT 345.00		345.00
092286B	092286	222229	PERMIT 345.00		345.00
092286C	092286	222230	PERMIT 345.00		345.00
092286D	092286	222231	PERMIT 345.00		345.00
092286E	092286	222232	PERMIT 345.00		345.00
092286F	092286	222233	PERMIT 345.00		345.00
CHECK NO.	DATE	VENDOR NO.	VENDOR NAME	TOTAL AMOUNT	
65447	092486	H1076	HILLSBOROUGH COUNTY B	2,070.00	

TAMPA ELECTRIC COMPANY • P.O. BOX 111 TAMPA, FL. 33601 • (813) 228-4111

2-65563

CHECK NO.

65563

TAMPA  
ELECTRIC  
A TECO ENERGY COMPANYPOST OFFICE BOX 111  
TAMPA, FLORIDA 33601

PAY:

DATE

THREE THOUSAND AND NO/100 DOLLARS \*\*\*\* 09 24 86 \$ \*\*\*\*\*3,000.00


TO  
THE  
ORDER  
OFFLORIDA DEPT OF ENVIRONMENTAL  
REGULATIONW. H. Steff  
ONLY ONE SIGNATURE REQUIRED ON CHECKS OF \$2500.00 OR LESS

NCNB NATIONAL BANK OF FLORIDA • TAMPA, FLORIDA

THE ACCOMPANYING CHECK IS IN FULL PAYMENT OF ITEMS BELOW - DETACH BEFORE CASHING

INVOICE NO.	DATE	VOUCHER	GROSS AMOUNT	DISCOUNT	NET AMOUNT
092286A	092286	222234	PERMIT 500.00		500.00
092286B	092286	222235	PERMIT 500.00		500.00
092286C	092286	222236	PERMIT 500.00		500.00
092286D	092286	222237	PERMIT 500.00		500.00
092286E	092286	222238	PERMIT 500.00		500.00
092286F	092286	222239	PERMIT 500.00		500.00
CHECK NO.	DATE	VENDOR NO.	VENDOR NAME	TOTAL AMOUNT	
65563	092486	F00004	FLORIDA DEPT OF ENVIR	3,000.00	

TAMPA ELECTRIC COMPANY • P.O. BOX 111 TAMPA, FL. 33601 • (813) 228-4111



September 25, 1986

RE: Hookers Point Station Boiler No. 6  
Air Operations Permit Application

TO WHOM IT MAY CONCERN:

Please be advised that A. Spencer Autry, Manager of Environmental Planning, is the authorized representative of Tampa Electric Company concerning matters with which this permit application deals.


Very truly yours,

Heywood A. Turner  
Senior Vice President  
Production

HAT/tb

STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL REGULATION

TWIN TOWERS OFFICE BUILDING  
2800 BLAIR STONE ROAD  
TALLAHASSEE, FLORIDA 32301



BOB GRAHAM  
GOVERNOR  
VICTORIA J. TSCHINKEL  
SECRETARY

APPLICATION FOR RENEWAL OF  
PERMIT TO OPERATE AIR POLLUTION SOURCE(S)

If major alterations have occurred, the applicant should complete the Standard Air Permit Application Form.

Source Type: Air Pollution Renewal of DER Permit No. A029-47721  
Company Name: Tampa Electric Company County: Hillsborough

Identify the specific emission point source(s) addressed in this application (i.e., Lime Kiln No. 4 with Venturi Scrubber; Peaking Unit No. 2, Gas Fired):

Hookers Point Station Boiler 6.

Source Location: Street: Hemlock Avenue City: Tampa  
UTM: East 358,000 North 3,091,000  
Latitude: 2 7° 5 6' 2 0"N. Longitude: 8 2° 2 6' 3 4"W.

1. Attach a check made payable to the Department of Environmental Regulation in accordance with operation permit fee schedule set forth in Florida Administrative Code Rule 17-4.05.
2. Have there been any alterations to the plant since last permitted? ☐ Yes ☒ No  
If minor alterations have occurred, describe on a separate sheet and attach.
3. Attach the last compliance test report required per permit conditions if not submitted previously. Submitted 2/13/86.
4. Have previous permit conditions been adhered to? ☒ Yes ☐ No If no, explain on a separate sheet and attach.
5. Has there been any malfunction of the pollution control equipment during tenure of current permit? ☐ Yes ☒ No If yes, and not previously reported, give brief details and what action was taken on a separate sheet and attach.
6. Has the pollution control equipment been maintained to preserve the collection efficiency last permitted by the Department? ☒ Yes ☐ No
7. Has the annual operating report for the last calendar year been submitted? ☒ Yes ☐ No If no, please attach.



1. Please provide the following information if applicable:

A. Raw Materials and Chemical Used in Your Process: Not Applicable.

Description	Type	Contaminant	%Wt	Utilization	Rate	lbs/hr

B. Product Weight (lbs/hr): Not Applicable.

C. Fuels

Type (Be Specific)	Consumption* Avg/hr*	BBLS/HR Max/hr**	Maximum Heat Input (MMBTU/hr)
Fuel Oil	77.6*	126.0	778

D. Normal Equipment Operating Time: hrs/day 24 ; days/wk 7 ; wks/yr 52 ;  
hrs/yr (power plants only) \*\* ; if seasonal, describe \_\_\_\_\_

\*Average value, 1984 and 1985 emissions inventories.

\*\*See Attachment A.

The undersigned owner or authorized representative\*\*\* of Tampa Electric Company is fully aware that the statements made in this application for a renewal of a permit to operate an air pollution source are true, correct and complete to the best of his knowledge and belief. Further, the undersigned agrees to maintain and operate the pollution source and pollution control facilities in such a manner as to comply with the provisions of Chapter 403, Florida Statutes, and all the rules and regulations of the Department. He also understands that a permit, if granted by the Department, will be non-transferable and he will promptly notify the Department upon sale or legal transfer of the permitted facility.

\*During actual time of operation.

\*\*Units: Natural Gas-MMCF/hr;  
Fuel Oils-barrels/hr; Coal-lbs/hr.

\*\*\*Attach letter of authorization if not previously submitted

[Signature]  
Signature, Owner or Authorized Representative  
(Notarization is mandatory)

A. Spencer Autry, Manager, Environmental Planning  
Typed Name and Title

P.O. Box 111

Address

Tampa

City

Florida 33601

State Zip

9/25/86

Date

(813) 228-4111

Telephone No.

## ATTACHMENT A

### HOOKERS POINT STATION - BOILERS 1 THROUGH 6

#### OPERATION AND MAINTENANCE PLAN

##### Introduction

Hookers Point Station is owned and operated by Tampa Electric Company. The plant is located on the shore of Hillsborough Bay off Sparkman Channel. The plant consists of six boilers and five turbine generator units. Boilers 1 through 5 are connected to a header system which supplies steam to four turbine generators. Boiler 6 supplies steam to turbine generator number 5.

The Hookers Point boilers burn No. 6 fuel oil. The boiler manufacturers, types and in-service dates are listed below:

<u>Boiler</u>	<u>Service Date</u>	<u>Manufacturer</u>	<u>Type</u>
1	1948	Babcock and Wilcox	Front Firing
2	1948	Babcock and Wilcox	Front Firing
3	1950	Babcock and Wilcox	Front Firing
4	1950	Babcock and Wilcox	Front Firing
5	1953	Babcock and Wilcox	Front Firing
6	1955	Combustion Engineering	Tangential Firing

The boilers exhaust gases through stacks at an elevation of 280 feet.

##### Process System Performance Parameters

Boilers 1 through 6 burn low sulfur No. 6 fuel oil. Fuel oil quality is monitored upon delivery. In addition, daily samples are taken for a monthly composite analysis. The design fuel consumption, steam flow rates, operating temperatures and operating pressures are listed below.

<u>Boiler</u>	<u>Fuel Consumption</u>	<u>Steam Flow</u>	<u>Operating Temperature</u>	<u>Operating Pressure</u>
1	43.0 BBLS/HR	220,000 LBS/HR	900°F	960 psi
2	43.0	220,000	900°	960
3	59.4	303,000	900°	960
4	59.4	303,000	900°	960
5	86.2	440,000	900°	975
6	126.0	625,000	950°	1450

Actual fuel input to the boilers is back calculated from monthly fuel tank drawdown and boiler efficiencies. Steam flow, temperature and pressure are continuously monitored and recorded on control room charts. Fuel oil temperature and pressure are maintained at optimum levels. Excess air is continuously monitored, recorded and maintained at levels to produce efficient fuel combustion.

#### Maintenance Inspection

All generating units of the Tampa Electric Company system are regularly scheduled for periodic maintenance. The schedule for planned maintenance outages is affected by system load and forced outage requirements. Typically, planned outages are scheduled during non-peak load periods such as the spring or fall.

During major outages, the boilers, controls, auxiliaries and duct work are inspected and repaired as necessary. Ongoing procedures include burner inspections and cleanings, burner tip replacements and maintenance of optimum flame patterns to achieve efficient fuel combustion. All repair information is stored for future reference.

#### Plant Status

Hookers Point Station was placed on Long Term Reserve Standby status in April 1986. Under expected load growth conditions and present assumptions, these units are expected to be returned to service sometime after 1989. However, these units could be brought into service earlier if load growth is higher than expected or other circumstances dictate.

2-65447  
CHECK NO.

65447



POST OFFICE BOX 111  
TAMPA, FLORIDA 33601

PAY:

DATE

TWO THOUSAND SEVENTY AND NO/100 \*\*\*\*\*  
DOLLARS \*\*\*\*\*

09 24 86 \$ \*\*\*\*\*2,070.00

TO HILLSBOROUGH COUNTY BOARD OF  
THE COUNTY COMMISSIONERS  
ORDER  
OF

ONLY ONE SIGNATURE REQUIRED ON CHECKS OF \$2500.00 OR LESS

NCNB NATIONAL BANK OF FLORIDA • TAMPA, FLORIDA

THE ACCOMPANYING CHECK IS IN FULL PAYMENT OF ITEMS BELOW - DETACH BEFORE CASHING

INVOICE NO.	DATE	VOUCHER	GROSS AMOUNT	DISCOUNT	NET AMOUNT
092286A	092286	222228	PERMIT 345.00		345.00
092286B	092286	222229	PERMIT 345.00		345.00
092286C	092286	222230	PERMIT 345.00		345.00
092286D	092286	222231	PERMIT 345.00		345.00
092286E	092286	222232	PERMIT 345.00		345.00
092286F	092286	222233	PERMIT 345.00		345.00
CHECK NO.	DATE	VENDOR NO.	VENDOR NAME	TOTAL AMOUNT	
65447	092486	H1076	HILLSBOROUGH COUNTY	2,070.00	

TAMPA ELECTRIC COMPANY • P.O. BOX 111 TAMPA, FL. 33601 • (813) 228-4111

2-65563  
CHECK NO.

65563



POST OFFICE BOX 111  
TAMPA, FLORIDA 33601

PAY:

DATE

THREE THOUSAND AND NO/100 DOLLARS \*\*\*\* 09 24 86 \$ \*\*\*\*\*3,000.00

TO  
THE  
ORDER  
OF  
FLORIDA DEPT OF ENVIRONMENTAL  
REGULATION


*Barbara*  
*W. H. Staff*  
ONLY ONE SIGNATURE REQUIRED ON CHECKS OF \$2500.00 OR LESS

NCNB NATIONAL BANK OF FLORIDA • TAMPA, FLORIDA

THE ACCOMPANYING CHECK IS IN FULL PAYMENT OF ITEMS BELOW - DETACH BEFORE CASHING

INVOICE NO.	DATE	VOUCHER	GROSS AMOUNT	DISCOUNT	NET AMOUNT
092286A	092286	222234	PERMIT 500.00		500.00
092286B	092286	222235	PERMIT 500.00		500.00
092286C	092286	222236	PERMIT 500.00		500.00
092286D	092286	222237	PERMIT 500.00		500.00
092286E	092286	222238	PERMIT 500.00		500.00
092286F	092286	222239	PERMIT 500.00		500.00
CHECK NO.	DATE	VENDOR NO.	VENDOR NAME	TOTAL AMOUNT	
65563	092486	FLO004	FLORIDA DEPT OF ENVIR	3,000.00	

TAMPA ELECTRIC COMPANY • P.O. BOX 111 TAMPA, FL. 33601 • (813) 228-4111



September 25, 1986

RE: Hookers Point Station Boiler No. 6  
Air Operations Permit Application

TO WHOM IT MAY CONCERN:

Please be advised that A. Spencer Autry, Manager of Environmental Planning, is the authorized representative of Tampa Electric Company concerning matters with which this permit application deals.

Very truly yours,

Heywood A. Turner  
Senior Vice President  
Production

HAT/tb

STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL REGULATION

TWIN TOWERS OFFICE BUILDING  
2600 BLAIR STONE ROAD  
TALLAHASSEE, FLORIDA 32301



BOB GRAHAM  
GOVERNOR  
VICTORIA J. TSCHINKEL  
SECRETARY

APPLICATION FOR RENEWAL OF  
PERMIT TO OPERATE AIR POLLUTION SOURCE(S)

If major alterations have occurred, the applicant should complete the Standard Air Permit Application Form.

Source Type: Air Pollution Renewal of DER Permit No. A029-47721

Company Name: Tampa Electric Company County: Hillsborough

Identify the specific emission point source(s) addressed in this application (i.e., Lime Kiln No. 4 with Venturi Scrubber; Peaking Unit No. 2, Gas Fired):

Hookers Point Station Boiler 6.

Source Location: Street: Hemlock Avenue City: Tampa

UTM: East 358,000 North 3,091,000

Latitude: 2 7° 5 6' 2 0"N. Longitude: 8 2° 2 6' 3 4"W.

1. Attach a check made payable to the Department of Environmental Regulation in accordance with operation permit fee schedule set forth in Florida Administrative Code Rule 17-4.05.
2. Have there been any alterations to the plant since last permitted? ☐ Yes ☒ No  
If minor alterations have occurred, describe on a separate sheet and attach.
3. Attach the last compliance test report required per permit conditions if not submitted previously. Submitted 2/13/86.
4. Have previous permit conditions been adhered to? ☒ Yes ☐ No If no, explain on a separate sheet and attach.
5. Has there been any malfunction of the pollution control equipment during tenure of current permit? ☐ Yes ☒ No If yes, and not previously reported, give brief details and what action was taken on a separate sheet and attach.
6. Has the pollution control equipment been maintained to preserve the collection efficiency last permitted by the Department? ☒ Yes ☐ No
7. Has the annual operating report for the last calendar year been submitted? ☒ Yes ☐ No If no, please attach.

1. Please provide the following information if applicable:

A. Raw Materials and Chemical Used in Your Process: Not Applicable.

Description	Type	Contaminant	%wt	Rate	Utilization lbs/hr

B. Product Weight (lbs/hr): Not Applicable.

C. Fuels

Type (Be Specific)	Consumption* Avg/hr*	BBLS/HR Max/hr**	Maximum Heat Input (MMBTU/hr)
Fuel Oil	77.6*	126.0	778

D. Normal Equipment Operating Time: hrs/day 24; days/wk 7; wks/yr 52;  
hrs/yr (power plants only) \*\*; if seasonal, describe \_\_\_\_\_


\*Average value, 1984 and 1985 emissions inventories.  
\*\*See Attachment A.

The undersigned owner or authorized representative\*\*\* of Tampa Electric Company is fully aware that the statements made in this application for a renewal of a permit to operate an air pollution source are true, correct and complete to the best of his knowledge and belief. Further, the undersigned agrees to maintain and operate the pollution source and pollution control facilities in such a manner as to comply with the provisions of Chapter 403, Florida Statutes, and all the rules and regulations of the Department. He also understands that a permit, if granted by the Department, will be non-transferable and he will promptly notify the Department upon sale or legal transfer of the permitted facility.

\*During actual time of operation.

\*\*Units: Natural Gas-MMCF/hr;  
Fuel Oils-barrels/hr; Coal-lbs/hr.

\*\*\*Attach letter of authorization if not previously submitted

  
Signature, Owner or Authorized Representative  
(Notarization is mandatory)

A. Spencer Autry, Manager, Environmental Planning  
Typed Name and Title

P.O. Box 111

Address

Tampa

Florida 33601

City

State Zip

9/25/86

(813) 228-4111

Date

Telephone No.

9/25/86

PUBLIC



## ATTACHMENT A

### HOOKERS POINT STATION - BOILERS 1 THROUGH 6

#### OPERATION AND MAINTENANCE PLAN

##### Introduction

Hookers Point Station is owned and operated by Tampa Electric Company. The plant is located on the shore of Hillsborough Bay off Sparkman Channel. The plant consists of six boilers and five turbine generator units. Boilers 1 through 5 are connected to a header system which supplies steam to four turbine generators. Boiler 6 supplies steam to turbine generator number 5.

The Hookers Point boilers burn No. 6 fuel oil. The boiler manufacturers, types and in-service dates are listed below:

<u>Boiler</u>	<u>Service Date</u>	<u>Manufacturer</u>	<u>Type</u>
1	1948	Babcock and Wilcox	Front Firing
2	1948	Babcock and Wilcox	Front Firing
3	1950	Babcock and Wilcox	Front Firing
4	1950	Babcock and Wilcox	Front Firing
5	1953	Babcock and Wilcox	Front Firing
6	1955	Combustion Engineering	Tangential Firing

The boilers exhaust gases through stacks at an elevation of 280 feet.

##### Process System Performance Parameters

Boilers 1 through 6 burn low sulfur No. 6 fuel oil. Fuel oil quality is monitored upon delivery. In addition, daily samples are taken for a monthly composite analysis. The design fuel consumption, steam flow rates, operating temperatures and operating pressures are listed below.

<u>Boiler</u>	<u>Fuel Consumption</u>	<u>Steam Flow</u>	<u>Operating Temperature</u>	<u>Operating Pressure</u>
1	43.0 BBLS/HR	220,000 LBS/HR	900°F	960 psi
2	43.0	220,000	900°	960
3	59.4	303,000	900°	960
4	59.4	303,000	900°	960
5	86.2	440,000	900°	975
6	126.0	625,000	950°	1450

Actual fuel input to the boilers is back calculated from monthly fuel tank drawdown and boiler efficiencies. Steam flow, temperature and pressure are continuously monitored and recorded on control room charts. Fuel oil temperature and pressure are maintained at optimum levels. Excess air is continuously monitored, recorded and maintained at levels to produce efficient fuel combustion.

#### Maintenance Inspection

All generating units of the Tampa Electric Company system are regularly scheduled for periodic maintenance. The schedule for planned maintenance outages is affected by system load and forced outage requirements. Typically, planned outages are scheduled during non-peak load periods such as the spring or fall.

During major outages, the boilers, controls, auxiliaries and duct work are inspected and repaired as necessary. Ongoing procedures include burner inspections and cleanings, burner tip replacements and maintenance of optimum flame patterns to achieve efficient fuel combustion. All repair information is stored for future reference.

#### Plant Status

Hookers Point Station was placed on Long Term Reserve Standby status in April 1986. Under expected load growth conditions and present assumptions, these units are expected to be returned to service sometime after 1989. However, these units could be brought into service earlier if load growth is higher than expected or other circumstances dictate.

## DER PERMIT APPLICATION TRACKING SYSTEM MASTER RECORD

FILE#000000047721 COE# DER PROCESSOR:GARRETT DER OFFICE:TPA  
FILE NAME:TAMPA ELECTRIC CO. DATE FIRST REC: 09/15/81 APPLICATION TYPE:AQ  
APPL NAME:TAMPA ELECTRIC CO. APPL PHONE:(813)223-4111 PROJECT COUNTY:29  
ADDR:P.O. BOX 111 CITY:TAMPA ST:FLZIP:33601  
AGNT NAME:WILLIAM N. CANTRELL AGNT PHONE:(813)228-4111  
ADDR:P.O. BOX 111 CITY:TAMPA ST:FLZIP:33601

ADDITIONAL INFO REQ: / / / / / / REC: / / / / / /  
APPL COMPLETE DATE: 09/15/81 COMMENTS NEC:N DATE REQ: / / DATE REC: / /  
LETTER OF INTENT NEC:Y DATE WHEN INTENT ISSUED: / / WAIVER DATE:01/31/82


HEARING REQUEST DATES: / / / / / /  
HEARING WITHDRAWN/DENIED/ORDER -- DATES: / / / / / /  
HEARING ORDER OR FINAL ACTION DUE DATE: / / MANUAL TRACKING DESIRED:N

\*\*\* RECORD HAS BEEN SUCCESSFULLY UPDATED \*\*\* 01/29/82 11:03:25  
FEE PD DATE#1:09/17/81 \$0020 RECEIPT#00054851 REFUND DATE: / / REFUND \$  
FEE PD DATE#2: / / \$ RECEIPT# REFUND DATE: / / REFUND \$  
APPL:ACTIVE/INACTIVE/DENIED/WITHDRAWN/TRANSFERRED/EXEMPT/ISSUED:IS DATE:01/27/82  
REMARKS:TECO  
HOOKERS POINT STATION BOILER 6

STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL REGULATION

SOUTHWEST DISTRICT

7601 HIGHWAY 301 NORTH  
TAMPA, FLORIDA 33610



BOB GRAHAM  
GOVERNOR

XXXXXXXXXX  
JACOB B. LARK

SECRETARY

Vicki Tschinkel  
WILLIAM K. HENNESSEY  
DISTRICT MANAGER

Hillsborough County AP

Mr. Jerry L. Williams  
Manager Environmental Planning  
Tampa Electric Company  
P.O. Box 111  
Tampa, Fla. 33601

Dear Mr. Williams:

Enclosed is Permit Number AO29-47721, dated Jan. 27, 1982,  
to operate the subject air pollution source  
issued pursuant to Section 403, Florida Statutes.


Should you object to this permit, including any and all of the conditions contained therein, you may file an appropriate petition for administrative hearing. This petition must be filed within fourteen (14) days of the receipt of this letter. Further, the petition must conform to the requirements of Section 28-5.201, Florida Administrative Code, (see reverse side of this letter). The petition must be filed with the Office of General Counsel, Department of Environmental Regulation, Twin Towers Office Building, 2600 Blair Stone Road, Tallahassee, Florida 32301.

If no petition is filed within the prescribed time, you will be deemed to have accepted this permit and waived your right to request an administrative hearing on this matter.

Acceptance of the permit constitutes notice and agreement that the Department will periodically review this permit for compliance, including site inspections where applicable, and may initiate enforcement action for violation of the conditions and requirements thereof.

Sincerely,

cc: HCEPC  
William N. Cantrell

  
W.K. Hennessey  
District Manager

Enclosure

RULES OF THE ADMINISTRATION COMMISSION  
MODEL RULES OF PROCEDURE  
CHAPTER 28-5  
DECISIONS DETERMINING SUBSTANTIAL INTERESTS

PART II  
FORMAL PROCEEDINGS

28-5.201 Initiation of Formal Proceedings.

- (1) Initiation of formal proceedings shall be made by petition to the agency responsible for rendering final agency action. The term petition as used herein includes any application or other document which expresses a request for formal proceedings. Each petition should be printed, typewritten or otherwise duplicated in legible form on white paper of standard legal size. Unless printed, the impression shall be on one side of the paper only and lines shall be double-spaced and indented.
- (2) All petitions filed under these rules should contain:
  - (a) The name and address of each agency affected and each agency's file or identification number, if known;
  - (b) The name and address of the petitioner or petitioners, and an explanation of how his/her substantial interests will be affected by the agency determination;
  - (c) A statement of when and how petitioner received notice of the agency decision or intent to render a decision;
  - (d) A statement of all disputed issues of material fact. If there are none, the petition must so indicate;
  - (e) A concise statement of the ultimate facts alleged, as well as the rules and statutes which entitle the petitioner to relief;
  - (f) A demand for relief to which the petitioner deems himself entitled; and
  - (g) Other information which the petitioner contends is material.

\*\*\*\*\*

A petition may be denied if the petitioner does not state adequately a material factual allegation, such as a substantial interest in the agency determination, or if the petition is untimely. (Section 28-5.201(3)(a), FAC).

STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL REGULATION

SOUTHWEST DISTRICT

7601 HIGHWAY 301 NORTH  
TAMPA, FLORIDA 33610



BOB GRAHAM  
GOVERNOR

~~JOHN J. WALKER~~  
SECRETARY

Vicki Tschinkel  
WILLIAM K. HENNESSEY  
DISTRICT MANAGER

APPLICANT:

Tampa Electric Company  
P.O. Box 111  
Tampa, Fla. 33601

PERMIT/CERTIFICATION  
NO. AO29-47721

COUNTY: Hillsborough  
PROJECT: FFSG No. 6  
Hooker's Point

This permit is issued under the provisions of Chapter 403, Florida Statutes, and Chapter 17-2, Florida Administrative Code. The above named applicant, hereinafter called Permittee, is hereby authorized to perform the work or operate the facility shown on the approved drawing(s), plans, documents, and specifications attached hereto and made a part hereof and specifically described as follows:

For the operation of a 778 MMBTU/hr heat input steam generator No. 6,  
oil fired.

Located at foot of Hemlock Street, Tampa, Hillsborough County.

UTM: 17-358.0E and 3091.0N

Replaces Permit NO: AO29-7104 NEDS NO: 0038 Point ID: 06

Expires: January 25, 1987

PERMIT NO.: AO29-47721  
APPLICANT: Tampa Electric Company

**GENERAL CONDITIONS:**

1. The terms, conditions, requirements, limitations, and restrictions set forth herein are "Permit Conditions", and as such are binding upon the permittee and enforceable pursuant to the authority of Section 403.161(1), Florida Statutes. Permittee is hereby placed on notice that the department will review this permit periodically and may initiate court action for any violation of the "Permit Conditions" by the permittee, its agents, employees, servants or representatives.
2. This permit is valid only for the specific processes and operations indicated in the attached drawings or exhibits. Any unauthorized deviation from the approved drawings, exhibits, specifications, or conditions of this permit shall constitute grounds for revocation and enforcement action by the department.
3. If, for any reason, the permittee does not comply with or will be unable to comply with any condition or limitation specified in this permit, the permittee shall immediately notify and provide the department with the following information: (a) a description of and cause of non-compliance; and (b) the period of non-compliance, including exact dates and times; or, if not corrected, the anticipated time the non-compliance is expected to continue, and steps being taken to reduce, eliminate, and prevent recurrence of the non-compliance. The permittee shall be responsible for any and all damages which may result and may be subject to enforcement action by the department for penalties or revocation of this permit.
4. As provided in subsection 403.087(6), Florida Statutes, the issuance of this permit does not convey any vested rights or any exclusive privileges. Nor does it authorize any injury to public or private property or any invasion of personal rights, nor any infringement of federal, state or local laws or regulations.
5. This permit is required to be posted in a conspicuous location at the work site or source during the entire period of construction or operation.
6. In accepting this permit, the permittee understands and agrees that all records, notes, monitoring data and other information relating to the construction or operation of this permitted source, which are submitted to the department, may be used by the department as evidence in any enforcement case arising under the Florida Statutes or department rules, except where such use is proscribed by Section 403.111, F.S.
7. In the case of an operation permit, permittee agrees to comply with changes in department rules and Florida Statutes after a reasonable time for compliance, provided, however, the permittee does not waive any other rights granted by Florida Statutes or department rules.
8. This permit does not relieve the permittee from liability for harm or injury to human health or welfare, animal, plant, or aquatic life or property and penalties therefore caused by the construction or operation of this permitted source, nor does it allow the permittee to cause pollution in contravention of Florida Statutes and department rules, except where specifically authorized by an order from the department granting a variance or exception from department rules or state statutes.
9. This permit is not transferable. Upon sale or legal transfer of the property or facility covered by this permit, the permittee shall notify the department within thirty (30) days. The new owner must apply for a permit transfer within thirty (30) days. The permittee shall be liable for any non-compliance of the permitted source until the transferee applies for and receives a transfer of permit.
10. The permittee, by acceptance of this permit, specifically agrees to allow access to permitted source at reasonable times by department personnel presenting credentials for the purposes of inspection and testing to determine compliance with this permit and department rules.
11. This permit does not indicate a waiver of or approval of any other department permit that may be required for other aspects of the total project.
12. This permit conveys no title to land or water, nor constitutes state recognition or acknowledgement of title, and does not constitute authority for the reclamation of submerged lands unless herein provided and the necessary title or leasehold interests have been obtained from the state. Only the Trustees of the Internal Improvement Trust Fund may express state opinion as to title.
13. This permit also constitutes:
  - ☐ Determination of Best Available Control Technology (BACT)
  - ☐ Determination of Prevention of Significant Deterioration (PSD)
  - ☐ Certification of Compliance with State Water Quality Standards (Section 401, PL 92-500)

STATE OF FLORIDA

DEPARTMENT OF ENVIRONMENTAL REGULATION

SOUTHWEST DISTRICT

7601 HIGHWAY 301 NORTH  
TAMPA, FLORIDA 33610



BOB GRAHAM  
GOVERNOR

VICTORIA J. TSCHINKEL  
SECRETARY

WILLIAM K. HENNESSEY  
DISTRICT MANAGER

March 11, 1982

Mr. Jerry L. Williams  
Manager, Environmental Planning  
Tampa Electric Company  
P.O. Box 111  
Tampa, Fla. 33601

RE: Permit Nos. A029-47721 through A029-47731  
and A029-47735


Dear Mr. Williams:

Enclosed are revised provisos for each of the above referenced permits. Per conversation and negotiations between John Ramil of TECO and Dan Williams of DER the problems with the original permits issued January 11, 1982 have been resolved.

Your petition rights for administrative hearing remain the same as described in the original permit.

The revised provisos replace the original provisos and become a part of each permit.

Sincerely,

  
William K. Hennessey  
District Manager  
Southwest District

WKH/rkt

cc: HCEPC



SPECIFIC CONDITIONS

1. Test the emissions for the following pollutant(s) at intervals of 12 months from date of permit and submit a copy of test data to the District Engineer of and submit a copy of test data to the District Engineer of this agency within fifteen days of such testing.  
[Chapter 17-2.700(2); F.A.C.]

(X)Particulates	(X)Sulfur Oxides*
( )Fluorides	( )Nitrogen Oxides
(X)Plume Density	( )Hydrocarbons
	( )Total Reduced Sulfur

\*Fuel analysis is acceptable

2. Testing of emissions must be accomplished at approximately the rates as stated in the application. Failure to submit the input rates or operation at conditions which do not reflect actual operating conditions may invalidate the data [Chapter 403.161(1)(c), Florida Statutes].
3. Submit for this facility, each calendar year, on or before March 1, an emission report for the preceding calendar year containing the following information as per Chapter 17-4.14, F.A.C.  
  - (A) Annual amount of materials and/or fuels utilized.
  - (B) Annual emissions (note calculation basis).
  - (C) Any changes in the information contained in the permit application.
4. Particulate emission limits for this unit is 0.1 lb TSP/MMBTU heat input per F.A.C., 17-2.650(2)(c)2.
5. Visible emissions are limited to a density of number 1 on the Ringelmann Chart (20 percent opacity) except that a shade as dark as No. 2 of the Ringelmann Chart (40% opacity) shall be permissible for no more than 2 minutes in any hour. [F.A.C. 17-2.600(5)(b)1].
6. Sulfur dioxide emissions are limited to 1.1 lbs. of SO<sub>2</sub> per million BTU heat input for this unit.

Applicant: Tampa Electric Company  
Page 4 of 4 of Permit No. A029-47721

7. Operation and Maintenance Plan for Particulate Control, F.A.C.  
17-2.650

A. Process Parameters

- |                         |                           |
|-------------------------|---------------------------|
| 1. MMBTU Input:         | 778                       |
| 2. Fuel:                | Low Sulfur No. 6 Fuel Oil |
| 3. BBL/hr burned:       | 126                       |
| 4. Ash Content:         | as sampled                |
| 5. Steam Temp.:         | 950 F                     |
| 6. Steam Press:         | 1450 psig                 |
| 7. Steam Flow:          | 625 MPPH                  |
| 8. Air to Fuel Ratio:   | Continuously Monitored    |
| 9. Stack Height:        | 280 Ft.                   |
| 10. Boiler Make:        | Babcock & Wilcox          |
| 11. Firing Arrangement: | Tangential Firing         |

B. Inspection and Maintenance Schedules


1. Planned outages: non peak load periods (Spring or Fall)
2. Continuously Monitored
  - a. Steam Flow
  - b. Steam Temp.
  - c. Steam Pressure
  - d. Excess Air (recorded)
  - e. Fuel oil press and temp.
3. Back calculated
  - a. Fuel oil flow
  - b. Daily samples for fuel oil analysis

C. Records

Records of inspection, maintenance, and performance parameter data shall be retained for a minimum of two years and shall be made available to the Department upon request. [F.A.C. 17-2.650(2)(g)5].

Revised Provisos  
Issued this 11<sup>th</sup> day of March,  
1982

STATE OF FLORIDA DEPARTMENT OF  
ENVIRONMENTAL REGULATION

  
\_\_\_\_\_  
William K. Hennessey  
District Manager

EXPIRATION DATE: January 25, 1987

SPECIFIC CONDITIONS

1. Test the emissions for the following pollutant(s) at intervals of 12 months from date of permit and submit a copy of test data to the District Engineer of and submit a copy of test data to the District Engineer of this agency within fifteen days of such testing.  
[Chapter 17-2.700(2), F.A.C.]  

(X)Particulates	(X)Sulfur Oxides*
( )Fluorides	( )Nitrogen Oxides
(X)Plume Density	( )Hydrocarbons
	( )Total Reduced Sulfur

\*Fuel analysis is acceptable
2. Testing of emissions must be accomplished at approximately the rates as stated in the application. Failure to submit the input rates or operation at conditions which do not reflect actual operating conditions may invalidate the data [Chapter 403.161(1)(c), Florida Statutes].
3. Submit for this facility, each calendar year, on or before March 1, an emission report for the preceding calendar year containing the following information as per Chapter 17-4.14, F.A.C.  

(A) Annual amount of materials and/or fuels utilized.
(B) Annual emissions (note calculation basis).
(C) Any changes in the information contained in the permit application.
4. Particulate emission limits for this unit is 0.1 lb TSP/MMBTU/hr heat input per F.A.C. 17-4.650(2)(c)2.
5. Visible emissions are limited to a density of number 1 on the Ringelmann Chart (20 percent opacity) except that a shade as dark as No. 2 of the Ringelmann Chart (40% opacity) shall be permissible for no more than 2 minutes of any one hour. [F.A.C. 17-2.600(5)(a)1].
6. Sulfur dioxide emissions are limited to 1.1 lbs. of SO<sub>2</sub> per million BTU heat input for this unit.

7. Operation and Maintenance Plan for Particulate Control, F.A.C.  
17-2.650

A. Process Parameters

- |                         |                           |
|-------------------------|---------------------------|
| 1. MMBTU Input:         | 778                       |
| 2. Fuel:                | Low Sulfur No. 6 Fuel Oil |
| 3. BBL/hr burned:       | 126                       |
| 4. Ash Content:         | as sampled                |
| 5. Steam Temp.:         | 950 F                     |
| 6. Steam Press:         | 1450 psig                 |
| 7. Steam Flow:          | 625 MPPH                  |
| 8. Air to Fuel Ratio:   | Continuously Monitored    |
| 9. Stack Height:        | 280 Ft.                   |
| 10. Boiler Make:        | Babcock & Wilcox          |
| 11. Firing Arrangement: | Tangential Firing         |

B. Inspection and Maintenance Schedules


1. Planned outages: non peak load periods (Spring or Fall)
2. Continuously Monitored
  - a. Steam Flow
  - b. Steam Temp.
  - c. Steam Pressure
  - d. Excess Air (recorded)
  - e. Fuel oil press and temp.
3. Back calculated
  - a. Fuel oil flow
  - b. Daily samples for fuel oil analysis

C. Records

Records of inspection, maintenance, and performance parameter data shall be retained for a minimum of two years and shall be made available to the Department upon request. [F.A.C. 17-2.650(2)(g)5].

Issued this 27<sup>th</sup> day of January,  
1982.

STATE OF FLORIDA DEPARTMENT OF  
ENVIRONMENTAL REGULATION

  
William K. Hennessey  
District Manager

EXPIRATION DATE: January 25, 1987

State of Florida  
DEPARTMENT OF ENVIRONMENTAL REGULATION  
INTEROFFICE MEMORANDUM

For Routing To District Offices And/Or To Other Than The Addressee		
To: _____	Locn.: _____	
To: _____	Locn.: _____	
To: _____	Locn.: _____	
From: _____	Date: _____	
Reply Optional [ ]	Reply Required [ ]	Info. Only [ ]
Date Due: _____	Date Due: _____	

TO: The Files

*Copy for*  
THRU: Dan Williams

FROM: Bob Garrett

DATE: January 25, 1982

SUBJECT: RACT Applications from TECO, Hookers Point, (6) Permits,  
Hillsborough County, A/P

Tampa Electric Company has applied for renewal of the following permits to establish RACT compliance.

Unit	Old Permit	New Permit
1. Boiler No. 1	AO29-22018	AO29-47726
2. Boiler No. 2	AO29-22019	AO29-47725
3. Boiler No. 3	AO29-25432	AO29-47724
4. Boiler No. 4	AO29-7103	AO29-47723
5. Boiler No. 5	AO29-12942	AO29-47722
6. Boiler No. 6	AO29-7104	AO29-47721

FAC 17-2.650 establishes criteria for heavy polluters in Para. (2)(c)2 as 0.1 lbs. TSP/million BTU heat input for fossil fuel steam generators greater than 30 MMBTU/hr. and visible emissions not to exceed 20% opacity. In addition detail information is required by rule pertaining to operation, control devices, and maintenance procedures as part of the permit.

A last minute extension was obtained from TECO to allow both the company and the Department time for more refined information. General questions were answered but no specific numbers for operating parameters were given.

I recommend we issue these permits, accordingly, with an expiration date of January 25, 1987.



Bob Garrett

D.E.R.

JAN 21 1982

SOUTHWEST DISTRICT  
TAMPA

January 18, 1982

Mr. William K. Hennessey  
Southwest District Manager  
Florida Department of Environmental  
Regulation  
7601 Highway 301 North  
Tampa, Florida 33610

Re: Hookers Point and Gannon Stations  
RACT Permits

Dear Mr. Hennessey:

Enclosed please find revised operation and maintenance plans for Hookers Point Station, Boilers 1 through 6, and Gannon Station Units 1 through 6. These plans contain the information required by FAC 17-2.650 in addition to information requested by Mr. Robert R. Garrett's letter of December 7, 1981.

As noted in our December 11, 1981 letter, we feel that our original plans provided the required information. However, in that letter we agreed to waive the 90-Day permit processing time and cooperate with the Department in supplying the additional information.

The revised plans contain most of the additional information requested by Mr. Garrett. The remainder of the information is provided below:

1. Are fuel additions used?

A fuel additive, magnesium oxide, is added to the No. 6 fuel oil. This additive serves many purposes, but mainly provides better heat distribution within the boiler and helps prevent corrosion.

2. Under what conditions do you hook into other company's load sharing equipment? How long does it take?

Our system is tied directly into the state system grid. We rely on generation from other companies, if available, when for various reasons,

Mr. William K. Hennessey

January 18, 1982

Page 2

(emergency outages, severe weather, etc.) we are unable to meet our system load requirements with our own generating equipment. We also purchase power from other utilities when it is economical to do so.

3. When is flyash reinjected into the boiler? Is this a cleaning technique?

Flyash is reinjected into the boiler when it is produced at a rate greater than it can be removed from the site by the contractor to whom it is sold. Flyash reinjected into the boiler converts to slag which is more easily handled and stored.


4. How many sections of this ESP can be out and still maintain compliance?

A blanket statement as to the number of precipitator sections which may be out of service and still maintain compliance cannot be made. The precipitator collection efficiency is a function of a number of variables including the ash content of the fuel, the ash chemistry and the unit load. For instance, for a given number of sections out of service, a unit could maintain compliance at one load and not at another.

I trust that the above, along with the enclosures, will provide the information the Department felt necessary to finalize the subject permits.

Should you have any questions concerning this matter, please do not hesitate to call.

Sincerely,



Jerry L. Williams

Director

Environmental Planning

JLW:dh


Enclosures

cc: Mr. Dan Williams

Mr. Robert R. Garrett

D.E.R.

SEP 17 1981



PAID SEP 17 1981

RECEIVED

SEP 15 1981

H.C.E.P.A.

SOUTHWEST DISTRICT  
TAMPA

STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL REGULATION  
APPLICATION TO OPERATE/CONSTRUCT  
AIR POLLUTION SOURCES

SOURCE TYPE: AIR POLLUTION [ ] New<sup>1</sup> [X] Existing<sup>1</sup>  
APPLICATION TYPE: [ ] Construction [X] Operation [ ] Modification  
COMPANY NAME: Tampa Electric Company COUNTY: Hillsborough  
Identify the specific emission point source(s) addressed in this application (i.e. Lime Kiln No. 4 with Venturi Scrubber; Peeking Unit No. 2, Gas Fired) Hookers Point Station Boiler 6  
SOURCE LOCATION: Street Hemlock Avenue City Tampa  
UTM: East 358,000 m North 3,091,000 m  
Latitude 27 ° 56 ' 20 "N Longitude 82 ° 26 ' 34 "W  
APPLICANT NAME AND TITLE: Tampa Electric Company  
APPLICANT ADDRESS: P.O. Box 111, Tampa, Florida 33601

SECTION I: STATEMENTS BY APPLICANT AND ENGINEER

A. APPLICANT

I am the undersigned owner or authorized representative\* of Tampa Electric Company

I certify that the statements made in this application for an Operating permit are true, correct and complete to the best of my knowledge and belief. Further, I agree to maintain and operate the pollution control source and pollution control facilities in such a manner as to comply with the provision of Chapter 403, Florida Statutes, and all the rules and regulations of the department and revisions thereof. I also understand that a permit, if granted by the department, will be non-transferable and I will promptly notify the department upon sale or legal transfer of the permitted establishment.

\*Attach letter of authorization

Signed: Jerry L. Williams Environmental  
Jerry L. Williams, Manager Planning  
Name and Title (Please Type)  
Date: 9-15-81 Telephone No. 813/228-4111

B. PROFESSIONAL ENGINEER REGISTERED IN FLORIDA (where required by Chapter 471, F.S.)

This is to certify that the engineering features of this pollution control project have been designed/examined by me and found to be in conformity with modern engineering principles applicable to the treatment and disposal of pollutants characterized in the permit application. There is reasonable assurance, in my professional judgment, that the pollution control facilities, when properly maintained and operated, will discharge an effluent that complies with all applicable statutes of the State of Florida and the rules and regulations of the department. It is also agreed that the undersigned will furnish, if authorized by the owner, the applicant a set of instructions for the proper maintenance and operation of the pollution control facilities and applicable pollution sources.

Signed: William N. Cantrell  
William N. Cantrell  
Name (Please Type)  
Tampa Electric Company  
Company Name (Please Type)

(Affix Seal)

P. O. Box 111, Tampa, Florida 33601  
Mailing Address (Please Type)  
Date: 9-15-81 Telephone No. 813/228-4111

Florida Registration No. 23494

<sup>1</sup>See Section 17-2.02(15) and (22), Florida Administrative Code, (F.A.C.)



## SECTION II: GENERAL PROJECT INFORMATION

- A. Describe the nature and extent of the project. Refer to pollution control equipment, and expected improvements in source performance as a result of installation. State whether the project will result in full compliance. Attach additional sheet if necessary.
- The source is an oil fired boiler which generates steam to drive  
a turbine and produce electricity.
- B. Schedule of project covered in this application (Construction Permit Application Only) Not Applicable
- Start of Construction \_\_\_\_\_ Completion of Construction \_\_\_\_\_
- C. Costs of pollution control system(s): (Note: Show breakdown of estimated costs only for individual components/units of the project serving pollution control purposes. Information on actual costs shall be furnished with the application for operation permit.)
- Oil Conversion (Boilers 1-6) \$3,069,000 (High Sulfur to Low Sulfur)  
Stack Extension (Boilers 1-6) \$2,325,000
- D. Indicate any previous DER permits, orders and notices associated with the emission point, including permit issuance and expiration dates.
- A029-2483 Aug. 26, 1976 to Aug. 31, 1978  
A029-7104 Sept. 27, 1978 to July 1, 1983
- E. Is this application associated with or part of a Development of Regional Impact (DRI) pursuant to Chapter 380, Florida Statutes, and Chapter 22F-2, Florida Administrative Code? Yes X No
- F. Normal equipment operating time: hrs/day 24 ; days/wk 7 ; wks/yr 52 ; if power plant, hrs/yr \* \_\_\_\_\_ ; if seasonal, describe: Not Applicable
- G. If this is a new source or major modification, answer the following questions. (Yes or No) Not Applicable
1. Is this source in a non-attainment area for a particular pollutant? \_\_\_\_\_
    - a. If yes, has "offset" been applied? \_\_\_\_\_
    - b. If yes, has "Lowest Achievable Emission Rate" been applied? \_\_\_\_\_
    - c. If yes, list non-attainment pollutants. \_\_\_\_\_
  2. Does best available control technology (BACT) apply to this source? If yes, see Section VI. \_\_\_\_\_
  3. Does the State "Prevention of Significant Deterioration" (PSD) requirements apply to this source? If yes, see Sections VI and VII. \_\_\_\_\_
  4. Do "Standards of Performance for New Stationary Sources" (NSPS) apply to this source? \_\_\_\_\_
  5. Do "National Emission Standards for Hazardous Air Pollutants" (NESHAP) apply to this source? \_\_\_\_\_

Attach all supportive information related to any answer of "Yes". Attach any justification for any answer of "No" that might be considered questionable.

### SECTION III: AIR POLLUTION SOURCES & CONTROL DEVICES (Other than Incinerators)

A. Raw Materials and Chemicals Used in your Process, if applicable: Not Applicable

Description	Contaminants		Utilization Rate - lbs/hr	Relate to Flow Diagram
	Type	% Wt		

B. Process Rate, if applicable: (See Section V, Item 1)

1. Total Process Input Rate (lbs/hr): See Section III-E

2. Product Weight (lbs/hr): Not Applicable

C. Airborne Contaminants Emitted:

Name of Contaminant	Emission <sup>1</sup>		Allowed Emission <sup>2</sup> Rate per Ch. 17-2, F.A.C.	Allowable <sup>3</sup> Emission lbs/hr	Potential Emission <sup>4</sup>		Relate to Flow Diagram
	Maximum lbs/hr	Actual T/yr *			lbs/hr	T/yr	
Sulfur Dioxide	855.8	1368.6	1.1 lbs/MMBTU	855.8	855.8	3748	Fig 1
Particulates	77.8	63.5	0.1 lbs/MMBTU	77.8	77.8	341	

\*From 1980 Emission Inventories

D. Control Devices: (See Section V, Item 4) Not Applicable

Name and Type (Model & Serial No.)	Contaminant	Efficiency	Range of Particles <sup>5</sup> Size Collected (in microns)	Basis for Efficiency (Sec. V, It <sup>5</sup> )

<sup>1</sup>See Section V, Item 2.

<sup>2</sup>Reference applicable emission standards and units (e.g., Section 17-2.05(6) Table II, E. (1), F.A.C. — 0.1 pounds per million BTU heat input)

<sup>3</sup>Calculated from operating rate and applicable standard

<sup>4</sup>Emission, if source operated without control (See Section V, Item 3)

<sup>5</sup>If Applicable

E. Fuels From 1980 Emission Inventory

Type (Be Specific)	Consumption* Gal/Hr		Maximum Heat Input (MMBTU/hr)
	avg/hr	max./hr	
Fuel Oil	3538	5292	778

\*Units Natural Gas, MMCF/hr; Fuel Oils, barrels/hr; Coal, lbs/hr

Fuel Analysis:

Percent Sulfur: 0.97 Percent Ash: N.A.  
 Density: N.A. lbs/gal Typical Percent Nitrogen: N.A.  
 Heat Capacity: N.A. BTU/lb 149,810 BTU/gal  
 Other Fuel Contaminants (which may cause air pollution): \_\_\_\_\_

F. If applicable, indicate the percent of fuel used for space heating. Annual Average N.A. Maximum N.A.

G. Indicate liquid or solid wastes generated and method of disposal.

None

H. Emission Stack Geometry and Flow Characteristics (Provide data for each stack):

Stack Height: 280 ft. Stack Diameter: 9.4 ft.  
 Gas Flow Rate: 245,000 ACFM Gas Exit Temperature: 325 °F.  
 Water Vapor Content: \_\_\_\_\_ % Velocity: 58.8 FPS

SECTION IV: INCINERATOR INFORMATION

NOT APPLICABLE

Type of Waste	Type O (Plastics)	Type I (Rubbish)	Type II (Refuse)	Type III (Garbage)	Type IV (Pathological)	Type V (Liq & Gas By-prod.)	Type VI (Solid By-prod.)
Lbs/hr Incinerated							

Description of Waste \_\_\_\_\_

Total Weight Incinerated (lbs/hr) \_\_\_\_\_ Design Capacity (lbs/hr) \_\_\_\_\_

Approximate Number of Hours of Operation per day \_\_\_\_\_ days/week \_\_\_\_\_

Manufacturer \_\_\_\_\_

Date Constructed \_\_\_\_\_ Model No. \_\_\_\_\_

	Volume (ft) <sup>3</sup>	Heat Release (BTU/hr)	Fuel		Temperature (°F)
			Type	BTU/hr	
Primary Chamber					
Secondary Chamber					

Stack Height: \_\_\_\_\_ ft. Stack Diameter \_\_\_\_\_ Stack Temp. \_\_\_\_\_

Gas Flow Rate: \_\_\_\_\_ ACFM \_\_\_\_\_ DSCFM\* Velocity \_\_\_\_\_ FPS

\*If 50 or more tons per day design capacity, submit the emissions rate in grains per standard cubic foot dry gas corrected to 50% excess air.

Type of pollution control device: ☐ Cyclone ☐ Wet Scrubber ☐ Afterburner ☐ Other (specify) \_\_\_\_\_

Brief description of operating characteristics of control devices: \_\_\_\_\_

---



---



---



---

Ultimate disposal of any effluent other than that emitted from the stack (scrubber water, ash, etc.):

---



---



---



---

## SECTION V: SUPPLEMENTAL REQUIREMENTS

Please provide the following supplements where required for this application.

1. Total process input rate and product weight — show derivation.
2. To a construction application, attach basis of emission estimate (e.g., design calculations, design drawings, pertinent manufacturer's test data, etc.) and attach proposed methods (e.g., FR Part 60 Methods 1, 2, 3, 4, 5) to show proof of compliance with applicable standards. To an operation application, attach test results or methods used to show proof of compliance. Information provided when applying for an operation permit from a construction permit shall be indicative of the time at which the test was made.
3. Attach basis of potential discharge (e.g., emission factor, that is, AP42 test).
4. With construction permit application, include design details for all air pollution control systems (e.g., for baghouse include cloth to air ratio; for scrubber include cross-section sketch, etc.).
5. With construction permit application, attach derivation of control device(s) efficiency. Include test or design data. Items 2, 3, and 5 should be consistent: actual emissions = potential (1-efficiency).
6. An 8½" x 11" flow diagram which will, without revealing trade secrets, identify the individual operations and/or processes. Indicate where raw materials enter, where solid and liquid waste exit, where gaseous emissions and/or airborne particles are evolved and where finished products are obtained. SEE FIGURE 1
7. An 8½" x 11" plot plan showing the location of the establishment, and points of airborne emissions, in relation to the surrounding area, residences and other permanent structures and roadways (Example: Copy of relevant portion of USGS topographic map). SEE FIGURE 2
8. An 8½" x 11" plot plan of facility showing the location of manufacturing processes and outlets for airborne emissions. Relate all flows to the flow diagram. SEE FIGURE 3

9. An application fee of \$20, unless exempted by Section 17-4.05(3), F.A.C. The check should be made payable to the Department of Environmental Regulation.
10. With an application for operation permit, attach a Certificate of Completion of Construction indicating that the source was constructed as shown in the construction permit.

## SECTION VI: BEST AVAILABLE CONTROL TECHNOLOGY

NOT APPLICABLE

- A. Are standards of performance for new stationary sources pursuant to 40 C.F.R. Part 60 applicable to the source?  
☐ Yes ☐ No

Contaminant	Rate or Concentration

- B. Has EPA declared the best available control technology for this class of sources (If yes, attach copy) ☐ Yes ☐ No

Contaminant	Rate or Concentration

- C. What emission levels do you propose as best available control technology?

Contaminant	Rate or Concentration

- D. Describe the existing control and treatment technology (if any).

1. Control Device/System:

2. Operating Principles:

3. Efficiency: \*

4. Capital Costs:

5. Useful Life:

6. Operating Costs:

7. Energy:

8. Maintenance Cost:

9. Emissions:

Contaminant	Rate or Concentration

\*Explain method of determining D 3 above.

10. Stack Parameters

- |               |      |                 |     |
|---------------|------|-----------------|-----|
| a. Height:    | ft.  | b. Diameter:    | ft. |
| c. Flow Rate: | ACFM | d. Temperature: | °F  |
| e. Velocity:  | FPS  |                 |     |

E. Describe the control and treatment technology available (As many types as applicable, use additional pages if necessary).

1.

- a. Control Device:
- b. Operating Principles:
- c. Efficiency\*:
- d. Capital Cost:
- e. Useful Life:
- f. Operating Cost:
- g. Energy\*:
- h. Maintenance Cost:
- i. Availability of construction materials and process chemicals:
- j. Applicability to manufacturing processes:
- k. Ability to construct with control device, install in available space, and operate within proposed levels:

2.

- a. Control Device:
- b. Operating Principles:
- c. Efficiency\*:
- d. Capital Cost:
- e. Useful Life:
- f. Operating Cost:
- g. Energy\*\*:
- h. Maintenance Costs:
- i. Availability of construction materials and process chemicals:
- j. Applicability to manufacturing processes:
- k. Ability to construct with control device, install in available space, and operate within proposed levels:

\*Explain method of determining efficiency.

\*\*Energy to be reported in units of electrical power — KWH design rate.

3.

- a. Control Device:
- b. Operating Principles:
- c. Efficiency\*:
- d. Capital Cost:
- e. Life:
- f. Operating Cost:
- g. Energy:
- h. Maintenance Cost:

\*Explain method of determining efficiency above.

- i. Availability of construction materials and process chemicals:
- j. Applicability to manufacturing processes:
- k. Ability to construct with control device, install in available space and operate within proposed levels:

4.

- a. Control Device
- b. Operating Principles:
- c. Efficiency\*:
- d. Capital Cost:
- e. Life:
- f. Operating Cost:
- g. Energy:
- h. Maintenance Cost:
- i. Availability of construction materials and process chemicals:
- j. Applicability to manufacturing processes:
- k. Ability to construct with control device, install in available space, and operate within proposed levels:

F. Describe the control technology selected:

- 1. Control Device:
- 2. Efficiency\*:
- 3. Capital Cost:
- 4. Life:
- 5. Operating Cost:
- 6. Energy:
- 7. Maintenance Cost:
- 8. Manufacturer:
- 9. Other locations where employed on similar processes:

a.

- (1) Company:
- (2) Mailing Address:
- (3) City:
- (4) State:
- (5) Environmental Manager:
- (6) Telephone No.:

\*Explain method of determining efficiency above.

(7) Emissions\*:

Contaminant

Rate or Concentration


(8) Process Rate\*:

b.

- (1) Company:
- (2) Mailing Address:
- (3) City:
- (4) State:

\*Applicant must provide this information when available. Should this information not be available, applicant must state the reason(s) why.

(5) Environmental Manager:

(6) Telephone No.:

(7) Emissions\*:

Contaminant

Rate or Concentration


(8) Process Rate\*:

10. Reason for selection and description of systems:

\*Applicant must provide this information when available. Should this information not be available, applicant must state the reason(s) why.



# SECTION VII – PREVENTION OF SIGNIFICANT DETERIORATION

NOT APPLICABLE

## A. Company Monitored Data

1. \_\_\_\_\_ no sites \_\_\_\_\_ TSP \_\_\_\_\_ ( ) SO<sub>2</sub>\* \_\_\_\_\_ Wind spd/dir  
 Period of monitoring \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_ to \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_  
 month day year month day year

Other data recorded \_\_\_\_\_

Attach all data or statistical summaries to this application.

## 2. Instrumentation, Field and Laboratory

a) Was instrumentation EPA referenced or its equivalent? \_\_\_\_\_ Yes \_\_\_\_\_ No

b) Was instrumentation calibrated in accordance with Department procedures? \_\_\_\_\_ Yes \_\_\_\_\_ No \_\_\_\_\_ Unknown

## B. Meteorological Data Used for Air Quality Modeling

1. \_\_\_\_\_ Year(s) of data from \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_ to \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_  
 month day year month day year

2. Surface data obtained from (location) \_\_\_\_\_

3. Upper air (mixing height) data obtained from (location) \_\_\_\_\_

4. Stability wind rose (STAR) data obtained from (location) \_\_\_\_\_

## C. Computer Models Used

1. \_\_\_\_\_ Modified? If yes, attach description.

2. \_\_\_\_\_ Modified? If yes, attach description.

3. \_\_\_\_\_ Modified? If yes, attach description.

4. \_\_\_\_\_ Modified? If yes, attach description.

Attach copies of all final model runs showing input data, receptor locations, and principle output tables.

## D. Applicants Maximum Allowable Emission Data

Pollutant	Emission Rate
TSP	_____ grams/sec
SO <sub>2</sub>	_____ grams/sec

## E. Emission Data Used in Modeling

Attach list of emission sources. Emission data required is source name, description on point source (on NEDS point number), UTM coordinates, stack data, allowable emissions, and normal operating time.


## F. Attach all other information supportive to the PSD review.

\*Specify bubbler (B) or continuous (C).

## G. Discuss the social and economic impact of the selected technology versus other applicable technologies (i.e., jobs, payroll, production, taxes, energy, etc.). Include assessment of the environmental impact of the sources.

## H. Attach scientific, engineering, and technical material, reports, publications, journals, and other competent relevant information describing the theory and application of the requested best available control technology.

BEST AVAILABLE COPY



Note: There is one Hogging Jet Vent, one Dewaterer Vent, one Blowdown Tank Vent, and one Evaporator Vent associated with No. 6 Boiler. All these vent lines release steam to the atmosphere periodically.

FIGURE 1

FLOW DIAGRAM  
BOILER NO. 6 - FORT BELVOIR  
TAMPA ELECTRIC COMPANY

Doc. No. PD22063-3

2-26-63





FIGURE 2

# BEST AVAILABLE COPY

SECTION A-A  
NO SCALE



ATTACHMENT

HOOKERS POINT 6

CALCULATIONS

• Maximum/Allowable Emissions

$$\text{SO}_2 \quad \frac{1.1 \text{ lbs. SO}_2}{\text{MMBTU}} \times \frac{778 \text{ MMBTU}}{\text{HOUR}} = \frac{855.8 \text{ lbs. SO}_2}{\text{HOUR}}$$

$$\text{Particulate} \quad \frac{0.1 \text{ lbs.}}{\text{MMBTU}} \times \frac{778 \text{ MMBTU}}{\text{HOUR}} = \frac{77.8 \text{ lbs. Part.}}{\text{HOUR}}$$

• Potential Emissions

$$\text{SO}_2 \quad \frac{855.8 \text{ lbs. SO}_2}{\text{HOUR}} \times \frac{8760 \text{ Hour}}{\text{YEAR}} \times \frac{1 \text{ Ton}}{2000 \text{ lbs.}} = \frac{3748 \text{ Tons SO}_2}{\text{YEAR}}$$

$$\text{Particulate} \quad \frac{77.8 \text{ lbs.}}{\text{HOUR}} \times \frac{8760 \text{ Hour}}{\text{YEAR}} \times \frac{1 \text{ Ton}}{2000 \text{ lbs.}} = \frac{341 \text{ Tons}}{\text{YEAR}}$$

• Test Methods for Compliance

SO<sub>2</sub> - Fuel Analysis

Particulate - EPA Reference Method 17



POST OFFICE BOX 111 TAMPA, FLORIDA 33601 TELEPHONE (813) 879-4111

September 8, 1981

TO WHOM IT MAY CONCERN:

Please be advised that Jerry L. Williams,  
Manager of Environmental Planning, is the authorized  
representative of Tampa Electric Company concerning  
matters with which this permit application deals.

Very truly yours,

Alex Kaiser  
Vice President  
Energy Supply

## HOOKERS POINT STATION - BOILERS 1 THROUGH 6

### Operation and Maintenance Plan

#### Introduction

Hookers Point Station is owned and operated by Tampa Electric Company. The plant is located on the shore of Hillsborough Bay off Sparkman Channel. The plant consists of six boilers and five turbine generator units. Boilers 1 through 5 are connected to a header system which supplies steam to four turbine generators. Boiler 6 supplies steam to turbine generator number 5.

The Hookers Point boilers burn No. 6 fuel oil. The boiler manufacturers, types, and in service dates are listed below:

<u>BOILER</u>	<u>SERVICE DATE</u>	<u>MANUFACTURER</u>	<u>TYPE</u>
1	1948	Babcock and Wilcox	Front Firing
2	1948	Babcock and Wilcox	Front Firing
3	1950	Babcock and Wilcox	Front Firing
4	1950	Babcock and Wilcox	Front Firing
5	1953	Babcock and Wilcox	Front Firing
6	1955	Combustion Engineering	Front Firing

The boilers exhaust gases through stacks at an elevation of 280 feet.

#### Process System Performance Parameters

Boiler 1 through 6 burn low sulfur No. 6 fuel oil. Fuel oil quality is monitored upon delivery. In addition, daily samples are taken for a monthly composite analysis. The design fuel consumption and steam flow rates are listed below.

<u>BOILER</u>	<u>DESIGN FUEL CONSUMPTION</u>	<u>DESIGN STEAM FLOW</u>
1	86 BBLS./HR	200,000 lbs./HR
2	86 BBLS./HR	200,000 lbs./HR
3	118.8 BBLS./HR	275,000 lbs./HR
4	118.8 BBLS./HR	275,000 lbs./HR
5	86.2 BBLS./HR	440,000 lbs./HR
6	126 BBLS./HR	625,000 lbs./HR

Actual fuel input to the boilers is monitored continuously and calculated on a weekly basis. Steam flow is monitored and recorded each shift. Fuel oil temperature and pressure are maintained at optimum levels. Temperature is recorded continuously while pressure is recorded each hour. Excess air is monitored and maintained at levels to produce efficient fuel combustion.

## Maintenance and Inspection

All generating units of the Tampa Electric Company system are regularly scheduled for periodic maintenance. The schedule for planned maintenance outages is affected by system load and forced outage requirements.

During major outages, the boilers, controls, auxiliaries and duct work are inspected and repaired as necessary. On-going procedures include burner inspections and cleanings, burner tip replacements and maintenance of optimum flame patterns to achieve efficient fuel combustion.





STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL REGULATION

SOUTHWEST DISTRICT  
7601 HIGHWAY 301 NORTH  
TAMPA, FLORIDA 33610  
September 27, 1978  
Tampa Electric Company  
HILLSBOROUGH COUNTY- - A.P.

REUBIN O'D. ASKEW  
GOVERNOR

JOSEPH W. LANDERS, JR.  
SECRETARY  
P. David Puchaty  
District Manager

Alex Kaiser, Director  
Power Plant Engineering  
Tampa Electric Company  
P. O. Box 111  
Tampa, Florida 33601

Dear Mr. Kaiser:

Pursuant to Section 403.061(16), Florida Statutes, your application has been approved by the Department and, therefore, we are issuing to you the enclosed permit no. A029-7104 which will expire on July 1, 1983.

This permit is not effective unless you accept it, including any and all of the conditions contained therein. If you do not choose to accept it, you must file an appropriate petition for a hearing pursuant to the provisions of Section 120.57, Florida Statutes.

A petition for a hearing must comply with the requirements of Florida Administrative Code, Section 28-5.15 and be filed (postmarked) with the Secretary of the Department of Environmental Regulation at Twin Towers Office Building, 2600 Blair Stone Road, Tallahassee, Florida 32301, with a copy to this office within fourteen (14) days from receipt of this letter. Petitions which are not filed in accordance with the above provisions may be subject to dismissal.

Any time limits imposed in the permit are a condition to this permit and are enforceable under Section 403.061, Florida Statutes. You are hereby placed on notice that the Department will review this permit to check for compliance and will initiate enforcement action for violations of the conditions and requirements of this permit.

Your continued cooperation in this matter is appreciated. Please refer to your assigned permit number in all future communications.

Sincerely,

c: Central Files  
HCEPC

Bernard D. Kitching, P.E.  
Enclosures

*for* *B. Craig McArthur*  
P. David Puchaty  
District Manager

RULES OF THE ADMINISTRATION COMMISSION  
MODEL RULES OF PROCEDURE  
CHAPTER 28-5  
DECISIONS DETERMINING SUBSTANTIAL INTERESTS

28-5.15 Requests for Formal and Informal Proceedings

- (1) Requests for proceedings shall be made by petition to the agency involved. Each petition shall be printed, typewritten or otherwise duplicated in legible form on white paper of standard legal size. Unless printed, the impression shall be on one side of the paper only and lines shall be double spaced and indented.
- (2) All petitions filed under these rules should contain:
  - (a) The name and address of each agency affected and each agency's file or identification number, if known;
  - (b) The name and address of the petitioner or petitioners;
  - (c) All disputed issues of material fact. If there are none, the petition must so indicate;
  - (d) A concise statement of the ultimate facts alleged, and the rules, regulations and constitutional provisions which entitle the petitioner to relief;
  - (e) A statement summarizing any informal action taken to resolve the issues, and the results of that action;
  - (f) A demand for the relief to which the petitioner deems himself entitled; and,
  - (g) Such other information which the petitioner contends is material.

---

NOTE: At a formal hearing all parties shall have an opportunity to present evidence and argument on all issues involved, to conduct cross-examination and submit rebuttal evidence, to submit proposed findings of fact and orders, to file exceptions to any order or hearing officer's recommended order, and to be represented by counsel.

STATE OF FLORIDA  
DEPARTMENT OF  
ENVIRONMENTAL REGULATION

HILLSBOROUGH COUNTY

OPERATION PERMIT

FOR TAMPA ELECTRIC COMPANY

P. O. BOX 111

TAMPA, FLORIDA 33601

PERMIT NO. A029-7104 DATE OF ISSUE September 27, 1978

PURSUANT TO THE PROVISIONS OF SECTIONS 403.061 (16) AND 403.707 OF CHAPTER 403, FLORIDA  
STATUTES AND CHAPTERS 17-4 AND 17-7 FLORIDA ADMINISTRATIVE CODE, THIS PERMIT IS ISSUED TO:  
ALEX KAISER, DIRECTOR POWER PLANT ENGINEERING AND ENVIRONMENTAL PLANNING

FOR THE OPERATION OF THE FOLLOWING  
HOOKER'S POINT STATION NO. 6 STEAM GENERATOR OIL FIRED, SUBJECT TO  
ATTACHED CONDITIONS OF APPROVAL NOS: 1, 2, 3, 5, 6.

LOCATED AT FOOT OF HEMLOCK STREET, TAMPA

UTM: 358.00E - 3091.00N

IN ACCORDANCE WITH THE APPLICATION DATED 6/23/78

ANY CONDITIONS OR PROVISOS WHICH ARE ATTACHED HERETO ARE INCORPORATED INTO AND MADE A  
PART OF THIS PERMIT AS THOUGH FULLY SET FORTH HEREIN. FAILURE TO COMPLY WITH SAID  
CONDITIONS OR PROVISOS SHALL CONSTITUTE A VIOLATION OF THIS PERMIT AND SHALL SUBJECT THE  
APPLICANT TO SUCH CIVIL AND CRIMINAL PENALTIES AS PROVIDED BY LAW.

THIS PERMIT SHALL BE EFFECTIVE FROM THE DATE OF ISSUE UNTIL JULY 1, 1983

OR UNLESS REVOKED OR SURRENDERED AND SHALL BE SUBJECT TO ALL LAWS OF THE STATE AND THE  
RULES AND REGULATIONS OF THE DEPARTMENT

*for* *A. Williams*  
DISTRICT ENGINEER

*for* *J. W. Landers, Jr.*  
JOSEPH W. LANDERS, JR.  
SECRETARY

*for* *R. P. Stewart*  
ROGER P. STEWART, DIRECTOR  
HILLS. CTY. ENV. PROTECTION COMM.

*for* *B. Craig McArthur*  
DISTRICT MANAGER  
P. David Puchaty

JG Replaces A029-2483

101800052003806

State of Florida  
Department of Environmental Regulation

OPERATION PERMIT CONDITIONS  
FOR AIR POLLUTION SOURCES

Permit No.: AO29-7104


Date: September 27, 1978

An (X) indicates applicable conditions

- (X) 1. The permit holder must comply with Florida Statute, Chapter 403 and the applicable Chapters of the Department of Environmental Regulation in addition to the conditions of this permit (Chapter 403.161(1)(b), Florida Statutes).
- (X) 2. Test the emissions for the following pollutant(s) at intervals of TWELVE MONTHS from the date April, 1978 and submit a copy of test data to the District Engineer of this agency within fifteen days of such testing (Chapter 17-2.07(1), Florida Administrative Code (F.A.C.)).
- |  |                          |
|--|--------------------------|
| (X) Particulates   | (X) Sulfur Oxides *      |
| ( ) Fluorides  | ( ) Nitrogen Oxides      |
| (X) Plume Density  | ( ) Hydrocarbons         |
| * Fuel analysis will be accepted in lieu of stack analysis for SO <sub>2</sub> | ( ) Total Reduced Sulfur |
- (X) 3. Testing of emissions must be accomplished at approximately the rates as stated in the application. Failure to submit the input rates or operation at conditions which do not reflect actual operating conditions may invalidate the data (Chapter 403.161(1)(c), Florida Statutes).
- ( ) 4. Submit for this source quarterly reports showing the type and monthly quantities of fuels used in the operation of this source. Also state the sulfur content of each fuel (Chapter 17-4.14, F.A.C.).
- (X) 5. Submit for this facility, each calendar year, on or before March 1, an emission report for the preceding calendar year containing the following information as per Chapter 17-4.14, F.A.C.
- (A) Annual amount of materials and/or fuels utilized.
  - (B) Annual emissions (note calculation basis).
  - (C) Any changes in the information contained in the permit application.

- ( X ) 6. In the event the permittee is temporarily unable to comply with any of the conditions of the permit, the permittee shall immediately notify the District Office of the D.E.R. as per Chapter 17-4.13, F.A.C. The permittee shall be responsible for any and all damages which may result and may be subject to enforcement actions by the Department.
- ( ) 7. According to the Process Weight Table within Chapter 17-2.04(2), F.A.C., the maximum allowable emission rate of particulate matter for a process rate of \_\_\_\_\_ tons/hour is \_\_\_\_\_ pounds/hour. At lesser process rates, the allowable emission rates can be determined from the graph.
- ( ) 8. This permit is associated with a Development of Regional Impact (D.R.I.). It does not waive any other permits that may be required from this or any other state, federal, or local agency.

POUNDS OF PARTICULATES



PROCESS WEIGHT TONS/HOUR

## DER PERMIT APPLICATION TRACKING SYSTEM MASTER RECORD

FILE#0000000012434 COE# DER PROCESSOR: BROWN DER OFFICE: TPA  
FILE NAME: ALEX KAISER DATE FIRST REC: 08/14/78 APPLICATION TYPE: AD  
APPL NAME: TECO - 7404 APPL PHONE: (813) 879-4444 PROJECT COUNTY: 29  
ADDR: P.O. BOX 444 CITY: TAMPA ST: FL ZIP: 33604  
AGNT NAME: BERNARD D. KITCHING AGNT PHONE: (813) 879-4444  
ADDR: P.O. BOX 444 CITY: TAMPA ST: FL ZIP: 33604

ADDITIONAL INFO REQ: / / / / / / REC: / / / / / /  
APPL COMPLETE DATE: 09/08/78 COMMENTS NEC: N DATE REC: / / DATE REC: / /  
LETTER OF INTENT NEC: Y DATE WHEN INTENT ISSUED: / / WATER DATE: / /

HEARING REQUEST DATES: / / / / / /  
HEARING WITHDRAWN/DENIED/ORDER -- DATES: / / / / / /  
HEARING ORDER OR FINAL ACTION DUE DATE: / / MANUAL TRACKING DESIRED: N

RECORD HAS BEEN SUCCESSFULLY UPDATED

FEE PD DATE#1: 08/14/78 \$0020 RECEIPT#000023730 REFUND DATE: / / REFUND \$  
FEE PD DATE#2: / / \$ RECEIPT# REFUND DATE: / / REFUND \$  
APPL: ACTIVE/INACTIVE/DENIED/WITHDRAWN/TRANSFERRED/EXEMPT/ISSUED: IS DATE: 09/27/78  
REMARKS: AD29-7404 (HONKERS POINT)

DEPARTMENT OF ENVIRONMENTAL REGULATION

INTEROFFICE MEMORANDUM

For Routing To District Offices  
And/Or To Other Than The Addressee

To: _____	Locn.: _____
To: _____	Locn.: _____
To: _____	Locn.: _____
From: _____	Date: _____

TO: P. David Puchaty

THRU: Dan A. Williams *DW*

FROM: William H. Brown, II *WB*

DATE: September 15, 1978

SUBJECT: TECO - Hookers Point #6.

*A029-7104*

This unit is a 778 MMBTU/hr. steam boiler using #6 fuel oil, this fuel oil has 1% sulfur. The emission rate from this unit is 840.7 lb/hr. SO<sub>2</sub>, 44.7 lb/hr. TSP, allowable is 89.4 lb/hr. SO<sub>2</sub>, 983.8 lb/hr. ~~TSP~~. *SD<sub>2</sub>* *TSP*

These are in compliance with state regulations.

Please see Griffiths reason for a reduced term permit.

I concur and recommend this permit be approved.

WHB/ftb



D.E.R.

AUG 14 1978

SOUTHWEST DISTRICT  
TAMPA



0638  
06

RECEIVED  
JUN 27 1978

H.C.E.P.C.

STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL REGULATION

APPLICATION TO OPERATE/CONSTRUCT AIR POLLUTION SOURCES

Source Type Air Pollution ☒ Incinerator ☐  
Type application: ☒ Operation ☐ Construction  
Source Status: ☐ New ☒ Existing ☐ Modification  
Source Name: Hookers Point Station Boiler 6 County Hillsborough  
Source Location: Street Foot of Hemlock Street City Tampa  
UTM: East 358,000m North 3,091,000m  
Appl. Name and Title: Tampa Electric Company  
Appl. Address: P. O. Box 111, Tampa, Florida 33601

STATEMENTS BY APPLICANT AND ENGINEER

A. APPLICANT

The undersigned owner or authorized representative of \* Tampa Electric Company is fully aware that the statements made in this application for an operating permit are true, correct and complete to the best of his knowledge and belief. Further, the undersigned agrees to maintain and operate the pollution control source and pollution control facilities in such a manner as to comply with the provisions of Chapter 403, Florida Statutes, and all the rules and regulations of the Department or revisions thereof. He also understands that a permit, if granted by the Department, will be non-transferable and he will promptly notify the Department upon sale or legal transfer of the permitted establishment.

Signature of the Owner or Authorized Representative

Date: 6/23/78 Telephone No.:

\*Attach a letter of authorization. If applicant is a corporation, a Certificate of Good Standing must be submitted with application. This may be obtained, for a \$5.00 charge, from the Secretary of State, Bureau of Corporate Records, Tallahassee, Florida 32304.

B. PROFESSIONAL ENGINEER REGISTERED IN FLORIDA

This is to certify that the engineering features of this pollution control project have been designed/examined by me and found to be in conformity with modern engineering principles applicable to the treatment and disposal of pollutants characterized in the permit application. There is reasonable assurance, in my professional judgment, that the pollution control facilities, when properly maintained and operated, will discharge an effluent that complies with all applicable statutes of the State of Florida and the rules and regulations of the Department. It is also agreed that the undersigned will furnish the applicant a set of instructions for the proper maintenance and operation of the pollution control facilities and, if applicable, pollution sources.

Signature: Bernard D. Kitching Mailing Address: P. O. Box 111  
Name: Bernard D. Kitching Tampa, Fla. 33601  
Company Name: Tampa Electric Company Telephone No.: 813/879-4111  
Florida Registration Number: 6503 Date: June 23, 1978  
(Affix Seal)

## DETAILED DESCRIPTION OF SOURCE

- A. Describe the nature and extent of the project. Refer to existing pollution control facilities, expected improvement in performance of the facilities and state whether the project will result in full compliance. Attach additional sheet if necessary.

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

- B. Schedule of Project Covered in this Application (Construction Permit Application Only).

Start of Construction \_\_\_\_\_

Completion of Construction \_\_\_\_\_

- C. Costs of Construction (Show a breakdown of costs for individual components/units of the project serving pollution control purpose only). Information on actual costs shall be furnished with the application for operation permit.

Oil conversion, \$3,069,000, December 1977 estimate-Hookers Point 1-6

Stack extension, \$2,174,000, December 1977 estimate-Hookers Point 1-6

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

- D. For this source indicate any previous DER permit: issuance dates, and expiration dates; and orders and notices.

AO29-2483 dated August 26, 1976, expiration date: August 31, 1978

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

- E. Is this application associated with or part of a Development of Regional Impact ( DRI ) pursuant to Chapter 380, Florida Statutes, and Chapter 22F-2, Florida Administrative Code ? .....Yes ...XXNo

**AIR POLLUTION SOURCES & CONTROL DEVICES**  
(other than incinerators)

**A. Identification of Air Contaminants**

- 1) ☒ Particulates
  - a) ☐ Dust
  - b) ☒ Fly Ash
  - c) ☐ Smoke
  - d) ☐ Other (Identify) \_\_\_\_\_
- 2) ☒ Sulfur Compounds
  - a) ☒ SO<sub>x</sub> as SO<sub>2</sub>
  - b) ☐ Reduced Sulfur as H<sub>2</sub>S
  - c) ☐ Other (Identify) \_\_\_\_\_
- 3) ☒ Nitrogen Compounds
  - a) ☒ NO<sub>x</sub> as NO<sub>2</sub>
  - b) ☐ NH<sub>3</sub>
  - c) ☐ Other (Identify) \_\_\_\_\_
- 4) ☐ Fluorides
- 5) ☐ Acid Mist
- 6) ☐ Odor
- 7) ☐ Hydrocarbons
- 8) ☐ Volatile Organic Compounds
- 9) ☐ Other (Specify) \_\_\_\_\_

**B. Raw Materials and Chemicals Used (Be Specific)**

Description	Utilization Rate lbs./hr.	Approximate Contaminant Content		Relate to Flow Diagram
		Type	% Wt.	
N.A.				

**C. Process Rate:**

- 1) Total Process input Rate\* N.A. Units.
- 2) Product Weight\* electricity (megawatts) Units.
- 3) Normal Operating Time 24 hrs/day, 7 days/week, if seasonal describe: N.A.  
 hrs./day \_\_\_\_\_ days/wk. \_\_\_\_\_ wks/yr. \_\_\_\_\_

**D. Airborne Contaminants Discharged:**

Name of Contaminant	Actual** Discharge		Discharge Criteria Rate*	Allowable Discharge Lbs./hr.	Relate to Flow Diagram
	lbs./hr.	T/yr.			
Sulfur dioxide	840.7	686.5	1.1 lbs/MMBTU	983.8	(3)
Particulate	44.7	36.5	0.1 lbs/MMBTU	89.4	(3)
NOTE: (1) Calculated from source test data and fuel analysis data of March 8, 1978.					

\*Refer to Chapter 17-2.04(2), Florida Administrative Code.

(Discharge Criteria: Rate = #/ton P<sub>2</sub>O<sub>5</sub>, #/M BTU/hr., etc.)

\*\*Estimate only if this is an application to construct.

D. Airborne Contaminants Discharged. (Cont'd.)

Name of Contaminant	Hourly Emission <del>XXXXX</del> lbs/MMBTU	Daily Emission (lb./day)	Yearly Emission (T/yr.)	Basis for Emission Estimate (Test Data, Material Balance)
Sulfur dioxide	0.94	See previous page		Test data from March 8, 1978 stack test
Particulate	0.05			Test data from March 8, 1978 stack test

E. Control Devices:

Name and Type (Model and Serial No.)	Contaminant	Efficiency*	Conditions of Operations	Basis for Efficiency Operational Data, Test, Design, Data)
N.A.				

\*See required supplement.

(Include any test data and/or design data for efficiency substantiation)

F. Fuels

Type (Be Specific, includes %S, etc.)	Daily Consumption * gal/hour		Maximum Heat Input MBTU/hr.
	Avg./hr. 1	Max./hr.	
No. 6 oil (1.0% S annual average)	3986	5292	778
NOTE: (1) data from 1977 HCEPC Emission Inventory			

\* Units: Natural Gas - MCF/hr.; Fuel Oils, Coal - lbs./hr.

Fuel Analysis: from March 8, 1978 stack test.

Percent Sulfur .89 Percent Ash N.A.

Density N.A. lb./gal.

Heat Capacity 18657 BTU/lb. BTU/gal.

Other Fuel Contaminants

- G. Describe briefly, without revealing trade secrets, the processes/operations generating the airborne emissions identified in this application.

Oil is burned to generate steam which is used to generate electricity.

- H. Indicate liquid or solid wastes generated and method of disposal.

N.A.

- I. Emission Stack Geometry and Flow Characteristics, (Provide Date for each Stack). from 1977 HCEPC Emission Inventory

Stack Height 280 ft, Stack Diameter 9.4 ft.

245,000 max.

Gas Flow Rate 188,592 avg. ACFM, Gas Exit Temperature 325 °F

- J. Required Supplements:

1. Total process input rate and product weight – show deviation. Maximum heat input to boiler is 778 MMBTU/hr. Operating range is from 35% to 100% load.

2. Efficiency Estimation. N/A

3. An 8½" x 11" flow diagram, which will, without revealing trade secrets, identify the individual operations and/or processes. Indicate whether raw materials enter, where solid and liquid waste exit, where gaseous emissions and/or airborne particulates are evolved and where finished products are obtained.

See Figure 3-D1

4. An 8½" x 11" plot plan showing the exact location of manufacturing processes and outlets for airborne emissions. Relate all flows to the flow diagram.

See Figure 3-D2

5. An 8½" x 11" plot plan showing the exact location of the establishment, and points of airborne emissions in relation to the surrounding area, residences and other permanent structures and roadways.

See Figure 3-D3

6. If applicable, provide a brief description of the control device or treatment system serving the discharge point for airborne contaminants identified in this application. Include details of the manufacturer, model, size, type and capacity for control/treatment device and the features of the discharge point (height above ground, diameter, period(s) of discharge and discharge temperature).

N/A

7. Plans for storm water control during and after construction.

N/A

### INCINERATOR INFORMATION

Type of Waste	Type O (Plastics)	Type I (Rubbish)	Type II (Refuse)	Type III (Garbage)	Type IV (Patho- logical)	Type V (Liq. & Gas By-prod.)	Type VI (Solid By-prod.)
Lbs./Hr. incinerated							

[illegible]

Total Weight Incinerated lbs./hr. \_\_\_\_\_ Design Capacity lbs./hr. \_\_\_\_\_

Approximate Number of Hours of Operation per Day \_\_\_\_\_, days/week \_\_\_\_\_

Manufacturer \_\_\_\_\_ Model No.: \_\_\_\_\_

Date Constructed: \_\_\_\_\_

	Volume (ft. <sup>3</sup> )	Heat Release (BTU/hr.)	Fuel		Temp. (° F)
			Type	BTU/hr.	
Primary Chamber					
Secondary Chamber					

Stack Height: \_\_\_\_\_ ft. Stack Diameter: \_\_\_\_\_ Stack Temp.: \_\_\_\_\_ OF

Type of Pollution Control Device	<input type="checkbox"/> Cyclone	<input type="checkbox"/> Wet scrubber	<input type="checkbox"/> Afterburner
	<input type="checkbox"/> Other (Specify): _____		

Brief Description of Operating Characteristics of Control Device: \_\_\_\_\_

Ultimate disposal of any effluent other than that emitted from the stack (scrubber water, ash, etc.) . . . . .

HOOKERS POINT 6 OPERATING PERMIT

REAPPLICATION

ACTUAL DISCHARGE

$$\text{SO}_2 \quad 0.94 \text{ lbs/MMBTU} \times 894.4 \frac{\text{MMBTU}}{\text{Hr.}} = 840.7 \frac{\text{lbs/SO}_2}{\text{Hr.}}$$

$$840.7 \frac{\text{lbs}}{\text{Hr.}} \times 1 \text{ ton/2000 lbs.} \times 1633 \text{ hrs/year} = 686.5 \frac{\text{tons SO}_2}{\text{Year}}$$

$$\text{Part.} \quad 0.05 \text{ lbs/MMBTU} \times 894.4 \frac{\text{MMBTU}}{\text{Hour}} = 44.7 \frac{\text{lbs/part.}}{\text{hour}}$$


$$44.7 \times 1 \text{ ton/2000 lbs.} \times 1633 \text{ hrs/year} = 36.5 \frac{\text{tons part.}}{\text{year}}$$

ALLOWABLE DISCHARGE

$$\text{SO}_2 \quad 1.1 \text{ lbs/MMBTU} \times 894.4 \frac{\text{MMBTU}}{\text{Hr.}} = 983.8 \frac{\text{lbs SO}_2}{\text{Hr.}}$$

$$\text{Part.} \quad 0.1 \text{ lbs/MMBTU} \times 894.4 \frac{\text{MMBTU}}{\text{Hr.}} = 89.4 \frac{\text{lbs part.}}{\text{Hour}}$$

BEST AVAILABLE COPY




FLOW DIAGRAM  
BOILER NO. 6 - ROGERS POINT STATION  
TRAFALGAR ELECTRIC COMPANY


Dwg. No. PD22663-3

2-25-63





## PLOT PLAN





REUBIN O'D. ASKEW  
GOVERNOR

STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL REGULATION

SOUTHWEST DISTRICT  
9721 EXECUTIVE CENTER DRIVE, NORTH, SUITE 200

~~PO BOX 20350~~  
ST. PETERSBURG, FLORIDA ~~33749~~ 33702

TAMPA ELECTRIC COMPANY  
HILLSBOROUGH COUNTY - AP

AUGUST 26, 1976

WAS SUPER  
updated with  
permit  
JOSEPH W. LANDERS, JR.  
SECRETARY

MR. ALEX KAISER, DIRECTOR OF POWER PLANT ENGINEERING  
AND ENVIRONMENTAL PLANNING  
TAMPA ELECTRIC COMPANY  
P. O. BOX 111  
TAMPA, FLORIDA 33601

Dear Mr. Kaiser:

Pursuant to your recent application, please find enclosed a permit (No. A029-2483 ) dated 8/26/76 to ~~construct~~/operate the subject pollution source.

This permit will expire on 8/31/78, and will be subject to the conditions, requirements and restrictions checked or otherwise indicated in the attached sheet "~~Construction~~/Operation Permit Conditions".

This permit is issued under the authority of Florida Statute 403.061(16). The time limits imposed herein are a condition to this permit and are enforceable under Florida Statute 403.161. You are placed on Notice that the Department will review this permit before the scheduled date of expiry and will seek court action for violation of the conditions and requirements of this permit.

You have ten days from the date of receipt hereof within which to seek a review of the conditions and requirements contained in this permit. Failure to file a written request to review or modify the conditions or requirements contained in this permit shall be deemed a waiver of any objections thereto.

Your continued cooperation in this matter is appreciated and in future communication please refer to your permit number.

Sincerely,

*B B Vest*  
B. B. Vest, Jr.  
District Manager  
Southwest District

*c.s.*  
cc: Central Files  
HCEPC  
B. D. Kitching

101800052003806

# STATE OF FLORIDA DEPARTMENT OF ENVIRONMENTAL REGULATION

## OPERATION PERMIT

FOR TAMPA ELECTRIC COMPANY

P. O. BOX 111

TAMPA, FLORIDA 33601

PERMIT NO. FA029-2483

DATE OF ISSUE August 26, 1976

PURSUANT TO THE PROVISIONS OF SECTIONS 403.061 (16) AND 403.707 OF CHAPTER 403, FLORIDA STATUTES AND CHAPTERS 17-4 AND 17-7, FLORIDA ADMINISTRATIVE CODE, THIS PERMIT IS ISSUED TO: ALEX KAISER, DIRECTOR OF POWER PLANT ENGINEERING AND ENVIRONMENTAL PLANNING

FOR THE OPERATION OF THE FOLLOWING:

HOOKER'S POINT STATION NO. 6 STEAM GENERATOR USING LOW SULFUR NO. 6

FUEL OIL SUBJECT TO ATTACHED CONDITIONS OF APPROVAL NOS: 1, 2, 3, 4, 5, 6, 7 &amp; 8.

LOCATED AT FOOT OF HEMLOCK AVENUE, HOOKER'S POINT, TAMPA

UTM: 17-358.00 E 3091


IN ACCORDANCE WITH THE APPLICATION DATED

8/1/75

ANY CONDITIONS OR PROVISOS WHICH ARE ATTACHED HERETO ARE INCORPORATED INTO AND MADE A PART OF THIS PERMIT AS THOUGH FULLY SET FORTH HEREIN. FAILURE TO COMPLY WITH SAID CONDITIONS OR PROVISOS SHALL CONSTITUTE A VIOLATION OF THIS PERMIT AND SHALL SUBJECT THE APPLICANT TO SUCH CIVIL AND CRIMINAL PENALTIES AS PROVIDED BY LAW.


THIS PERMIT SHALL BE EFFECTIVE FROM THE DATE OF ISSUE UNTIL 8/31/78

OR UNLESS REVOKED OR SURRENDERED AND SHALL BE SUBJECT TO ALL LAWS OF THE STATE AND THE RULES AND REGULATIONS OF THE DEPARTMENT.



DISTRICT ENGINEER

ROGER P. STEWART, DIRECTOR  
HILLSBOROUGH COUNTY ENVIRONMENTAL PROTECTION COMMISSION


JOSEPH W. LANDERS, JR.  
SECRETARY
  
DISTRICT MANAGER

1800052003806

## AIR POLLUTION SOURCES

Permit No.: A029-2483

BEST AVAILABLE COPY

Date: 8/26/76

- (X) 1. Fugitive dusts, odors and other pollutants from all sources shall be effectively controlled or eliminated by suitable means. (Chapter 17-2.04 (3)(4)(5) )
- (X) 2. The pollution control equipment shall be maintained and operated in such a manner that all emissions will be in compliance with applicable rules and regulations of the DER. A log of maintenance activities shall be kept and available for DER review. (Chapter 17-2.03 (7) )
- (X) 3. Report any problems encountered in the operation of the source that may result in discharge of pollutants in amounts higher than permitted herein. Cease operation forthwith unless permission has been obtained from the regional office of the DER to operate the source for an interim period. (Chapter 17-4.13)
- (X) 4. This permit is issued on the basis of the data submitted in the application and the existing requirements of this agency as set forth in Chapter 17-2 (revised January 18, 1972) Florida Administrative Code. The owner shall obtain written permission from the DER before making changes in the operation of the source (i.e. higher production rate, different raw materials and fuels, etc.) that may increase the quantity of pollutants or change their composition. (Chapter 17-2.01)
- (X) 5. This permit is not transferable. Upon the sale or legal transfer of the source covered by this permit, the new owner must apply by letter for a transfer of this permit within thirty days. (Chapter 17-4.12)
- (X) 6. Test the emissions for the following pollutant(s) at intervals of TWELVE MONTHS from the date of this permit and submit two copies of test results to the District engineer of this agency within fifteen days of such testing. (Chapter 17-2.07 (1) )
- |                   |                     |
|-------------------|---------------------|
| (X) Particulates  | (X) Sulfur Oxides * |
| ( ) Fluorides     | ( ) Nitrogen Oxides |
| (X) Plume Density | ( ) Hydrocarbons    |
- \* FUEL ANALYSIS MAY BE SUBMITTED IN LIEU OF SO<sub>2</sub> STACK TEST REPORT.
- (X) 7. Provide such sampling and testing facilities as may be necessary for the proper determination of the nature and quantity of air pollutants emitted from this source. (Chapter 17-2.07)
- (X) 8. Submit for this facility, each calendar year, on or before March 1, an emission report for the preceeding calendar year containing the following information:
- Annual amount of materials and/or fuel utilized.
  - Annual emissions.
  - Any changes in the information contained in the permit application.

AUG 9 1976



A029-2483

0038

Tampa Electric Company  
Hookers Point Station  
No. 6 Boiler

STATE OF FLORIDA  
DEPARTMENT OF POLLUTION CONTROL

APPLICATION TO OPERATE/CONSTRUCT POLLUTION SOURCES

AUG 16 1976

SECTION I - GENERAL INFORMATION FOR ALL POLLUTION SOURCES

I TO BE FILLED IN BY APPLICANT

Source Type: Air Pollution  
Type application: ☒ Operation ☐ Temporary Operation ☐ Construction  
Status Source: ☐ New ☒ Existing ☐ Modification

Source Name: Hookers Point Station No. 6 Boiler

County: Hillsborough

Source Location: Street: Foot of Hemlock Avenue

City: Tampa

(Water Source Only) Lat: \_\_\_\_\_ Long: \_\_\_\_\_  
(Air Source Only) UTM: East 358,000m North 3,091,000m

Appl. Name and Title: Tampa Electric Company

Appl. Address: P.O. Box 111, Tampa, Florida 33601

II TO BE FILLED IN BY REGION (\*BY BUREAU OF PERMITTING)

Control No: Region \_\_\_\_\_ County \_\_\_\_\_ Type \_\_\_\_\_ \*Project \_\_\_\_\_

Type Permit	Date Rec'd	*Permit No.	*Issue Date	*Compl. Date	*Exp. Date
-------------	------------	-------------	-------------	--------------	------------

Source Description: \_\_\_\_\_  
Control Equipment: \_\_\_\_\_

Water Permits

Receiving Body Code: \_\_\_\_\_ Surface Water Code: \_\_\_\_\_  
Station No.: Influent: \_\_\_\_\_ Effluent: \_\_\_\_\_

Effluent:	Average	Design	% Reduction
Flow rate, MGD	_____	_____	_____
BOD, lbs/day	_____	_____	_____
Susp. Sol., lbs/day	_____	_____	_____
Other: _____	_____	_____	_____

Air Permits

Operating Time: ☐ Continuous ☐ Intermittent  
Fuel: Type \_\_\_\_\_ M-BTU/hr. In Put \_\_\_\_\_  
Incinerator: Capacity, tons/day \_\_\_\_\_ Type Waste \_\_\_\_\_  
Mfg. & Model \_\_\_\_\_  
Pollutant Emissions, lbs/day

	Actual	Design	Allowable
Particulate	_____	_____	_____
Sulfur Oxides	_____	_____	_____
Other: _____	_____	_____	_____

Implementation: Estimated Appl. Filing Date \_\_\_\_\_  
Estimated Start of Const. \_\_\_\_\_ Estimated Compliance Date \_\_\_\_\_

## DESCRIPTION OF PROPOSED PROJECT

- A. Describe the nature and extent of the proposed project. Refer to existing pollution control facilities, DPC permits, conditions, orders and notices, expected improvement in performance of the facilities and state whether the proposed project will result in full compliance of the source. Attach additional sheet if necessary.

---

---

---

---

---

---

---

---

---

---

---

---

- B. Schedule of Project Covered in this Application (Construction Permit Application Only). N/A

Federally or State Financed Projects only:

Planning Complete \_\_\_\_\_

Financing Program Complete \_\_\_\_\_

Indicate other local, state and/or federal agency approvals and dates \_\_\_\_\_

All projects:

Start of Construction \_\_\_\_\_

Completion of Construction \_\_\_\_\_

- C. Costs of Construction (Show a breakdown of costs for individual components/units of the proposed project serving pollution control purpose only). Information on actual costs shall be furnished with the application for operation permit.

Oil conversion \$3,079,000 latest revised estimate, Hookers Point Units 1-6

Stack Extension \$2,278,000 latest revised estimate, Hookers Point Units 1-6

---

---

---

---

---

---

---

---

---

---

---

---

- D. Indicate any previous DPC permits, issuance dates, and expiration dates.

A029-2093 dated May 25, 1973, expiration date: June 30, 1974

---

---

---

---

## AIR POLLUTION SOURCES & CONTROL DEVICES

### A. Identification of Air Contaminants

- 1) ☒ Particulates
  - a) ☐ Dust
  - b) ☒ Fly Ash
  - c) ☐ Smoke
  - d) ☐ Other (Identify) \_\_\_\_\_
- 2) ☒ Sulfur Compounds
  - a) ☒ SO<sub>x</sub> as SO<sub>2</sub>
  - b) ☐ Reduced Sulfur as H<sub>2</sub>S
  - c) ☐ Other (Identify) \_\_\_\_\_
- 3) ☒ Nitrogen Compounds
  - a) ☒ NO<sub>x</sub> as NO<sub>2</sub>
  - b) ☐ NH<sub>3</sub>
  - c) ☐ Other (Identify) \_\_\_\_\_
- 4) ☐ Fluorides
- 5) ☐ Acid Mist
- 6) ☐ Odor
- 7) ☐ Hydrocarbons
- 8) ☐ Volatile Organic Compounds
- 9) ☐ Other (Specify): \_\_\_\_\_

### B. Raw Materials and Chemicals Used (Be Specific)

Description	Utilization Tons/day, lbs./day, etc.	Approximate Contaminant Content		Relate to Flow Diagram
		Type	% Wt.	
NONE				

### C. Process Weight:

- 1) Total Process Weight Rate N/A lbs./hr. [See Sec. 17-2.04(2)]
- 2) Product ~~Weight~~ electricity ~~expressed as~~ 36.8 MWH/hr.
- 3) Normal Operating Time 0-24 hr/day; 7 days/wk, if seasonal describe: N/A

### D. Airborne Contaminants Discharged:

Name of Contaminant	Actual Discharge	Discharge Criteria*	Allowable Discharge*	Relate Location to Flow Diagram
Sulfur dioxide	1.1	1bs/MM BTU	1.1	(3)
Particulates	0.1	1bs/MM BTU	0.1	(3)

\* Refer to Chapter 17-2 Florida Administrative Code  
(Discharge Criteria: Process Weight Rate, #/tonP<sub>2</sub>O<sub>5</sub>, #/M BTU/hr etc.)



E. Control Devices:

Name	Eff.	Conditions of Operation, Particle Size Range, etc.	Relate to Flow Diagram
NONE			

F. Fuels:

Type (Be specific)	Daily Consumption	Heat Input BTU/hr.	Relate to Flow Diagram
No.6 fuel oil (1% S)	3153 $\frac{\text{gal.}}{\text{hr.}}$ (avg.)	46.3 x 10 <sup>7</sup>	(1)
	5292 $\frac{\text{gal.}}{\text{hr.}}$ (max.)	77.8 x 10 <sup>7</sup>	(1)

G. Describe briefly, without revealing trade secrets, the unit processes/operations generating the airborne emissions identified in this application:

Oil burned to generate steam which is used to generate electricity.

H. Indicate liquid or solid wastes generated and method of disposal.

None

STACK PARAMETERS:

Height: 280 ft.  
Diameter: 9.4 ft.  
Temperature: 325°F @ 100% load  
Flow: 245,500 ACFM @ 100% load

## STATEMENTS BY APPLICANT AND ENGINEER

### A. Applicant

The undersigned owner or authorized representative of \* Tampa Electric Company is fully aware that the statements made in this application for a Operation of Air Pollution Source permit are true, correct and complete to the best of his knowledge and belief. Further, the undersigned agrees to maintain and operate the pollution source and pollution control facilities in such a manner as to comply with the provisions of Chapter 403 Florida Statutes and all the rules and regulations of the Department or revisions thereof. He also understands that a permit, if granted by the Department, will be non-transferable and he will promptly notify the Department upon sale or legal transfer of the permitted establishment.

*Alex Kaiser*

Signature of the Owner or Authorized Representative

Alex Kaiser, Director of Power Plant Engineering &

Environmental Planning

Name and Title (Please Type)

Date: August 1, 1975

Telephone No.: 813/876-4111

\* Attach a letter of authorization

### B. Professional Engineer Registered in Florida:

This is to certify that the engineering features of this pollution control project have been designed/examined by me and found to be in conformity with modern engineering principles applicable to the control and discharge of pollutants characterized in the permit application. There is reasonable assurance, in my professional judgment, that the pollution source(s) with appropriate control facilities, when properly maintained and operated, will comply with all applicable statutes of the State of Florida and the rules and regulations of the Department. It is also agreed that the undersigned will furnish the applicant a set of instructions for the proper maintenance and operation of the installation covered in this application.

Signature

*B. D. Kitching*

Mailing Address: Tampa Electric Company

P.O. Box 111

Tampa, Florida 33601

Name: B. D. Kitching


(please type)

Telephone No.: 813/876-4111

Florida Registration Number 6503  
(Please affix seal)

Date: 8-20-57





3-D1

FLOW DIAGRAM  
BOILER NO. 6 - HOOKERS POINT STATION  
TAMPA ELECTRIC COMPANY

Dwg. No. PD22663-3

2-26-63

FUEL OIL LINES AT DOCK.  
NO SCALE

Y-

X- X

SPARKMAN CHANNEL  
Stock No.  
H.P. 3

Stack No.  
H.P. 3 -

(2)  
Stack No. H.P. 4

STEEL SHEET PILING-CONCRETE CAP- TOP OF CAP 5.00'

159.1'  
TO FACE OF CAP

150.7 (ORIGINAL)  
TO FACE OF CAP

LEASED PROPERTY  
LINE - EXISTING FENCE

RELEASED PROPERTY LINE

Stack No. H.P. 2

Stack No. H.P. 1

NOTES

BMM - BENCH MARK MONUMENT, ELEV. 70.7'  
BRASS PLATE ON TOP CONCRETE PILE.  
PLM - PROPERTY LINE MONUMENT, IN AGREEMENT  
WITH SOUTH PROPERTY LINE.  
1 - INTERSECTION OF TAMPA RIVER TO BASE LINE AND  
SECTION 34.  
FOR PROPERTY LINES BASED ON THE C.S. SURVEY PRINTS  
Nos. F-1, 2 AND MONUMENT AND PART OF AGRIEMENT  
WITH TAMPA SHEDDERS CO. ON DATED 10-20-41 SEE ENDS  
OF EASES AND OF EASES.  
CP - TACK PLATE MONUMENT ON TOP LINE 10.22' SOUTH OF  
SECTION WELL UNIT No. 4

ALL BEARINGS ARE BASED ON THE STANDARD PLANE RECTANGULAR COORDINATE SYSTEM FOR THE WEST ZONE OF FLORIDA. THE ORIGINAL SURVEY BEARINGS WERE BASED ON A LOCAL GRID SYSTEM.

3-D2

## PLOT PLAN

DATE OF BIRTH: 05/11/1945  
4  
DATE OF BIRTH: 05/11/1945  
3  
DATE OF BIRTH: 05/11/1945  
2  
DATE OF BIRTH: 05/11/1945  
1  
FIELD NUMBER: 111  
TABLE: 111  
USE ONLY PRINTED CHARACTERS



Black  
Point C

D. E. R.

AUG 16 1976

RECEIVED  
AUG 5 1975

SOUTH WEST DISTRICT  
ST. PETERSBURG

H.C.E.P.C.


# STATE OF FLORIDA

DEPARTMENT OF STATE



I, BRUCE A. SMATHERS, Secretary of State of the State of Florida, do hereby certify from the records of this office that TAMPA ELECTRIC COMPANY is a corporation duly organized and existing under the laws of the State of Florida.

I further certify that said corporation has paid all fees and taxes due this office to date, has otherwise fully complied with the corporation laws administered by this office, and that its Charter is in full force and effect.



GIVEN under my hand and the Great Seal of the State of Florida, at Tallahassee, the Capital, this the 3rd day of July,

19 75.

*Bruce A. Smathers*

SECRETARY OF STATE

# PERMIT APPLICATION DATA INPUT SHEET

Sequence number assigned by main office  
region code 1 Mo Yr 3 6 number 7 10

Section 1

Source name 1 Tampa Electric Co.

street address Foot of Hemlock Ave city Tampa

ZIP 33601 county code 29

(col 1-10 duplicate) Owner or Agent name 2 H.A. Moshell Jr.

Section 2

street address P.O. Box 111 city Tampa zip 33601

(col 1-10 duplicate) Application Type code 3 0 AP

Section 3

Industry Type (SIC code) 17 22

Location UTM East U North 31 37

Latitude deg 1 min 29 sec 24 Longitude deg 1 min 31 sec 27

Effluent description Boiler # 6 Hookers Point Station

continued effluent description (if needed)

Section 4

(col 1-10 duplicate) 4 11 12 45 46 80

Liquid effluent disposal and analysis

Section 5

(col 1-10 duplicate) Type of receiving body - code 5  
(surface fresh = 1 , salt = 2 , etc.)  
(central sewer system = 7 )

Additional description of surface waters - code 1  
(drainage ditch = 1 , river = 2 , etc.)

station number assigned to influent 14

effluent 26

Record raw influent and final effluent analysis on water quality report forms, use agency code APPLIC if analysis is from applicant.

effluent flow rate MGD 34 45

5 day BOD load lb/day 46 57

Liquid effluent additional remarks

Section 6

(col 1-10 duplicate) 6 11 12 45 46 80

AIR POLLUTION DISPOSAL AND ANALYSIS(col 1-10 duplicate) Number of discharges this application 7  
11 12Number of discharges, this site 15 number currently not permitted 20  
15 17 18 20Average total flow rate SCFM 103,000  
21 30Total particulate, lb/day 470 sulfur oxides, lb/day 25,300  
31 40 41 50nitrogen oxides, lb/day 15 fluoride, lb/day 10  
51 60 61 70other pollutants, lb/day 17  
71 90

## Section 8

SIGNIFICANT DATES AND PERMIT NUMBERS

(col 1-10 duplicate) Use month-day-year, all dates

modyyr  
permit issued 8 Permit number 18  
11 12 17 18 27CONSTRUCTION PERMITS AND TEMPORARY PERMITSProject completion date 28 Permit expires 34 modyyr  
28 33 34 39OPERATING PERMITSTemporary or old construction permit number 40  
40 49

Implementation schedule:

A. Estimated filing of application 50 modyyr  
50 55B. Estimated start of construction 56  
56 61C. Estimated date for compliance 62  
62 69



Unit #6



29-974  
**RECEIVED**

FEB 26 1971

DEPT. OF A.W.P.C.  
WEST CENTRAL REGION  
WINTER HAVEN

State of Florida  
Department of Air and Water Pollution Control

Application For Permit to Operate Air Pollution  
Control Facilities

Applicant  
(Owner or authorized agent)

H. A. Moshell, Jr.  
General Manager of Production

(Name and Title)

Name of Establishment

TAMPA ELECTRIC COMPANY  
Hookers Point Station - No. 6 Boiler

(Corporation, Company, Political SD, Firm, etc.)

Mailing Address

P.O. Box 111 Tampa, Florida 33601

Location of Pollution Source

Foot of Hemlock Avenue, Tampa

(Number and Street)

(City)

Hillsborough

(County)

Nature of Industrial Operation

Generation of Electricity

Permit Applied For Operating:

Project Engineer:

New Source ☐

B. D. Kitching

Name

Existing Source ☒

TAMPA ELECTRIC COMPANY

Firm

Existing Source after modification ☐

P.O. Box 111, Tampa, Florida 33601

Mailing Address

Existing Source after Expansion ☐

Signature

Existing Source After relocation,  
expansion or reconstruction ☐

6503  
Florida Registration Number

For Department's Use Only

Permit No. #6

Date:

The undersigned owner or authorized representative\* of TAMPA ELECTRIC COMPANY  
is fully aware that the statements made in this form and the attached exhibits and statements constitute the  
application for a Operating Permit from the Florida Department of Air and Water Pollution  
Control and certifies that the information in this application is true, correct and complete to the best of his  
knowledge and belief. Further, the undersigned agrees to comply with the provisions of Chapter 403 Florida  
Statutes and all the rules and regulations of the Department or revisions thereof. He also understands that the  
Permit is non transferable and, if granted a permit, will promptly notify the Department upon sale or legal  
transfer of the permitted establishment.

H. A. Moshell, Jr.

Signature of owner or agent.

H. A. Moshell, Jr.  
General Manager of Production

Name and Title

Date: 2-25-71

\*Attach letter of authorization.


**Information Regarding Pollution Sources  
and Proposed Control Facilities**

1. Estimated cost of ~~proposed~~ control facilities \$ 0.
2. Prepare and attach an 8½" x 11" flow diagram, without revealing trade secrets, identifying the individual operations, and/or processes. Indicate where raw materials enter, where solid and liquid waste exit, where gaseous emissions and/or airborne particulates are evolved and where finished products are obtained.  
P. 3-D1
3. Include an 8½" x 11" plot plan showing location of manufacturing processes and location of outlets for airborne emissions. Relate all flows to the flow diagram.  
P. 3-D2
4. Submit an 8½" x 11" plot plan showing the exact location of the establishment and points of discharge in relation to the surrounding area, residences and other permanent structures and roadways.  
P. 3-D3

**I General**

**A. Raw Materials and Chemicals Used.**


Description	Utilization Tons/day, Lbs./day, etc.	Approximate Contaminant Content		Relate to Flow Diagram
		Type	Percent Dry Weight	
None				




FLOW DIAGRAM  
 BOILER NO. 6 - HOOKERS POINT STATION  
 TAMPA ELECTRIC COMPANY

Dwg. No. PD22663-3

2-26-63







# B. Fuels

Type (Be Specific)	Daily Consumption	Gross Maximum Heat Output	Relate to Flow Diagram
Bunker "C" Fuel Oil	616,000 lb/day	$11.32 \times 10^9$ BTU/day	<i>11320 mm BTU/day</i> <i>472 mm/hr</i> (1)
Liquimag	271 lb/day	$17.3 \times 10^5$ BTU/day	(2)

# C. Products

Description	Average Daily Production (Tons/Day. Lbs/Hr. etc.)
Electricity	973 MWH/day <i>&gt; 40 MW</i>

D. Normal operation: Hours/Day 24 hr/day Day and Week 7 days/wk

If operation or process is seasonal, describe: \_\_\_\_\_

*allowable part 1132*  
*SO2 9056*

## II Identification of Air Contaminants

Compounds of:

Also -

Chlorine	<input type="checkbox"/>	Hydrocarbons	<input type="checkbox"/>	Acid Mists	<input type="checkbox"/>
Flourine	<input type="checkbox"/>	Smoke	<input type="checkbox"/>	Odors	<input type="checkbox"/>
Nitrogen	<input type="checkbox"/>	Fly Ash	<input checked="" type="checkbox"/>	Radioisotopes	<input type="checkbox"/>
Sulfur	<input checked="" type="checkbox"/>	Dusts	<input type="checkbox"/>	Other _____	<input type="checkbox"/>

Specific Compounds SO2, SO3, Flyash

### III Air Pollution Control Devices

Contaminant	Control Device	Relate to Flow Diagram	Operating Efficiency	Conditions (Particle Size Range, Temp. etc.)
Ash	None		N/A	N/A
SO <sub>x</sub>	None		N/A	N/A

Provide a brief description of the control device or treatment system. Attach separate sheets giving details regarding principle of operation, manufacturer, model, size, type and capacity of control/treatment device and the basis for calculating its efficiency. Show any bypasses of the control device and specify when such bypasses are to be used and under what conditions.

N/A



#### IV. Contaminant Balance

From contaminant content in raw materials, waste products, and manufactured products, summarize daily contaminant flow:

	Pounds Contaminant per Day	
	Input	Output
<b>List Raw Materials:</b> Fuel Ash Fuel Sulfur MgO Ash	 308 12,650 162	
<b>List Manufactured Products:</b>  Electricity		
<b>List Solid Wastes:</b>  None		
<b>List Liquid Wastes:</b>  None		
<b>Totals</b>	<b>13,120</b>	<b>0</b>
<b>Airborne Wastes (Total input minus total output)</b>	<b>13,120</b>	

Note: If more than one contaminant, specify each

Contaminants recovered in control devices should be shown as either a liquid or a solid waste.

## V. Discharged Emmissions to Atmosphere

### A. Discharge Points and Design Conditions

Discharge Point Description	Relate to Flow Diagram	Height above Ground (ft.)	Cross Sect. Area (sq. ft.)	Periods of Flow Hrs./Day	Day/yr.	Temp. of Discharge (°F)
Stack	(3)	172.7	127.5	23.9	361	325° F

### B. Tabulation of Discharged Contaminants

		Total Contaminants Discharged					
	Discharge Point — Relate to Flow Diagram	Flow Rate at Std. Cond. (cfm)	Particulates		Other Contaminants ( F <sup>-</sup> , SO <sub>x</sub> , NO <sub>x</sub> etc.)		
			Gr/ft3 (Std.Cond.)	lbs./Day	Gr/ft3 (Std. Cond.)	lbs./Day	Gr/ft3 (Std.Cond.)
Avg. Cond.	Stack (3)	103,000	0.0223	470	1.200	25,300	
Peak Emission	Stack (3)	193,000	0.0223	-	1.200		
Totals				470		25,300	

NOTE: Standard conditions used are 20° C and 1 atm.


## **VI. Treatment and Disposal of Liquid and Solid Waste**

1. Identify the contaminants which will be discharged as liquid or solid wastes.

None

2. Describe the treatment and disposal of liquid and solid wastes. Indicate the concentrations and volume of individual contaminants in treated wastes before disposal.

None



# Florida Department of Environmental Regulation

**Southwest District**

Lawton Chiles, Governor

3804 Coconut Palm

813-744-6100

April 13, 1993

Tampa, Florida 33619

Virginia B. Wetherell, Secretary

MR LYNN ROBINSON  
MGR ENV PLANNING  
TAMPA ELECTRIC CO  
PO BOX 111  
TAMPA FL 33601-0111

Dear Permittee:

RE: Permit Expiration Letters for Non-delegated Facility in  
Hillsborough County

The Department recently delegated air permitting authority to the Environmental Protection Commission of Hillsborough County, except for a few non-delegated facilities, such as yours. This letter is to advise you that in the future, the Department will not continue the practice of notifying your facility of permits due to expire. This service was provided by the County in the past.

For information purposes only please note the following:

Pursuant to Rule 17-4.080(3), F.A.C., *Modification of Permit Conditions*, the permittee, may, for good cause, request that a construction permit be extended. Such a request shall be submitted to the Department at least 60 days prior to the expiration date of the permit.

Pursuant to Rule 17-4.090(1), F.A.C., *Renewals*, an application to renew an operating permit shall be submitted to the Department no later than 60 days prior to the expiration date of the permit.

Thank you for your cooperation in this matter. If you have any questions, please call Mr. J. Harry Kerns, P.E., District Air Engineer, of my staff at (813)744-6100 extension 419.

Sincerely,

W. C. Thomas, P.E.  
Air Program Administrator

WCT/HK/ss

cc: Read file  
EPCHC

permutx.ltr

COMMISSION  
PHYLLIS BUSANSKY  
JOE CHILLURA  
PAM IORIO  
SYLVIA KIMBELL  
JAN KAMINIS PLATT  
JAMES D. SELVEY  
ED TURANCHIK

FAX (813) 272-5157



ROGER P. STEWART  
EXECUTIVE DIRECTOR  
ADMINISTRATIVE OFFICES  
AND  
WATER MANAGEMENT DIVISION  
1900 - 9TH AVENUE  
TAMPA, FLORIDA 33605  
TELEPHONE (813) 272-5960

AIR MANAGEMENT DIVISION  
TELEPHONE (813) 272-5530

WASTE MANAGEMENT DIVISION  
TELEPHONE (813) 272-5788

ECOSYSTEMS MANAGEMENT DIVISION  
TELEPHONE (813) 272-7104

D.E.R.

DEC 16 1991

SOUTHWEST DISTRICT  
TAMPA

MEMORANDUM

DATE: December 11, 1991

TO: J. Harry Kerns, P.E. *JK*

FROM: Sterlin Woodard *SW* THRU: Jerry Campbell, P.E. *Jc*

SUBJECT: Permit Renewal - TECO - Hookers Point Unit #6

Attached is Permit No. A029-203002 for the operation of the above company's steam generator designated as Unit #6. The unit had been on long-term reserve standby since April 1986. All start-up stack testing has been done (copy attached).

The source is subject to 17-2.600(5)(a) and RACT with a particulate matter emission standard of 0.1 lbs./MMBTU, a SO<sub>2</sub> emission standard of 1.1 lb./MMBTU and a 20% opacity standard, except during one 2 minute period per hour of 40% opacity.

On December 6, 1991, I met with Janice Taylor (TECO) to discuss the draft permit and all issues were resolved.

The EPC/HC recommends issuing the above operating permit. A draft and diskette are enclosed for your review.

SKW:A0203002

PERMIT APPLICATION STATUS SHEET

COMPANY: Tampa Electric Co.

PROCESSOR: Gr. Maier

PERMIT NO.: A029-203002

DATE RECEIVED: 09/23/91

PE SEAL & SIGNATURE: (Y) N

CHECK: (Y) N

Default Date 12/21/91

	<u>DATE TASK COMPLETED</u>	<u>INITIALS</u>
DATE RECEIVED BY SECTION:	<u>10/02/91</u>	<u>MQ</u>
LOGGED BY SECTION SECRETARY:	<u>                    </u>	<u>                    </u>
PERMITTING ENGINEER SUBMIT FINISHED PERMIT PACKAGE & RECOMMENDATIONS TO DISTRICT AIR ENGINEER:	<u>12-17-91</u>	<u>JK</u>
PERMIT PACKAGE TO DISTRICT AIR ADMINISTRATOR:	<u>12/18/91</u>	<u>WGT</u>
PERMIT PACKAGE TO DISTRICT DEPUTY ASSISTANT SECRETARY:	<u>                    </u>	<u>                    </u>
PERMIT PACKAGE MAILED OUT:	<u>DEC 19 1991</u>	<u>MQ</u>

DATA FOLLOW UP

ISSUE DATE UPDATED ON PATS:	<u>DEC 19 1991</u>	<u>MQ</u>
UPDATED ON WANG:	<u>DEC 19 1991</u>	<u>MQ</u>

(10-06-89)

## APPLICATION TRACKING SYSTEM

DEC 19 1991

10/02/91

APPL NO:203002

APPL RECVD:09/23/91 TYPE CODE:AD SUBCODE:00

LAST UPDATE:10/02/91

DER OFFICE RECVD:TPA DER OFFICE TRANSFER TO:\_\_\_ APPLICATION COMPLETE:\_\_\_/\_\_\_/\_\_\_

DER PROCESSOR:AIR MAILER

APPL STATUS:AC DATE:09/23/91 (ACTIVE/DENIED/WITHDRAWN/EXEMPT/ISSUED/GENERAL)

RELIEF:\_\_\_ (SSAC/EXEMPTIONS/VARIANCE)

(Y/N) N MANUAL TRACKING

DISTRICT:40 COUNTY:29

(Y/N) N OGC HEARING REQUESTED

LAT/LONG:27.56.20/82.26.34

(Y/N) N PUBLIC NOTICE REQD?

BASIN-SEGMENT:\_\_\_

(Y/N) N GOV BODY LOCAL APPROVAL REQD?

COE #:\_\_\_\_\_

(Y/N) Y LETTER OF INTENT REQD? \_ (I/ISSUE D/DENY)

ALT#:\_\_\_\_\_

PROJECT SOURCE NAME:HOOKERS POINT STATION #6

STREET:FOOT OF HEMLOCK

CITY:TAMPA

STATE:FL

ZIP:\_\_\_\_\_

PHONE:\_\_\_\_\_

APPLICATION NAME:TAMPA ELECTRIC COMPANY

STREET:P.O. BOX 111

CITY:TAMPA

STATE:FL

ZIP:33601

PHONE:813-228-4836

AGENT NAME:\_\_\_\_\_

STREET:\_\_\_\_\_

CITY:\_\_\_\_\_

STATE:\_\_\_\_\_

ZIP:\_\_\_\_\_

PHONE:\_\_\_\_\_

FEE #1 DATE PAID:\_\_\_/\_\_\_/\_\_\_ AMOUNT PAID:NOFEE RECEIPT NUMBER:\_\_\_\_\_

B	DATE	APPLICANT	INFORMED	OF	NEED	FOR	PUBLIC	NOTICE	-	-	-	___/___/___
C	DATE	DER	SENT	DNR	APPLICATION/SENT	DNR	INTENT	-	-	-	___/___/___	
D	DATE	DER	REQ.	COMMENTS	FROM	GOV.	BODY	FOR	LOCAL	APP.	___/___/___	
E	DATE	#1	ADDITIONAL	INFO	REQ--REC	FROM	APPLICANT	-	-	-	___/___/___	
E	DATE	#2	ADDITIONAL	INFO	REQ--REC	FROM	APPLICANT	-	-	-	___/___/___	
E	DATE	#3	ADDITIONAL	INFO	REQ--REC	FROM	APPLICANT	-	-	-	___/___/___	
E	DATE	#4	ADDITIONAL	INFO	REQ--REC	FROM	APPLICANT	-	-	-	___/___/___	
E	DATE	#5	ADDITIONAL	INFO	REQ--REC	FROM	APPLICANT	-	-	-	___/___/___	
E	DATE	#6	ADDITIONAL	INFO	REQ--REC	FROM	APPLICANT	-	-	-	___/___/___	
F	DATE	LAST	45	DAY	LETTER	WAS	SENT	-	-	-	___/___/___	
G	DATE	FIELD	REPORT	WAS	REQ--REC	-	-	-	-	-	___/___/___	
H	DATE	DNR	REVIEW	WAS	COMPLETED	-	-	-	-	-	___/___/___	
I	DATE	APPLICATION	WAS	COMPLETE	-	-	-	-	-	-	9/13/91	
J	DATE	GOVERNING	BODY	PROVIDED	COMMENTS	OR	OBJECTIONS	-	-	-	___/___/___	
K	DATE	NOTICE	OF	INTENT	WAS	SENT--REC	TO	APPLICANT	-	-	___/___/___	
L	DATE	PUBLIC	NOTICE	WAS	SENT	TO	APPLICANT	-	-	-	___/___/___	
M	DATE	PROOF	OF	PUBLICATION	OF	PUBLIC	NOTICE	RECEIVED	-	-	___/___/___	
N	WAIVER	DATE	BEGIN--END	(DAY	90)	-	-	-	-	-	___/___/___	

COMMENTS:

STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL REGULATION

179100

RECEIPT FOR APPLICATION FEES AND MISCELLANEOUS REVENUE

Received from Tampa Electric Date 9-30-91

Address PO Box 3285 Tampa Dollars \$ 2000.00

Applicant Name & Address Same

Source of Revenue Steam Boilers 203002, 203001

Revenue Code 1032 Application Number AD29-202997; 202998

033601 By Alvina King 202999  
203000



Tampa Electric A029-203002

Hooker Point #6

Renewal of A029-125691

Stack test looks OK

application complete

2 A.M.

10-21-91

TO: .Teco - Hookers Point File  
THRU: W.C. Thomas *WCT 12/25/86*  
THRU: J. Estler  
FROM: Tom John *TJ*  
DATE: December 22, 1986  
SUBJECT: Recommend that permit Nos. AO29-125685, 125686,  
125687, 125689, 125690, and 125691 be issued  
to TECO Hookers Point Stations No. 1, 2, 3, 4, 5,  
and 6 respectively

From the information received, both HCEPC and I recommend that permit Nos. AO29-125685, 86, 87, 89, 90, and 91 be issued respectively to TECO Hookers point stations Nos. 1, 2, 3, 4, 5, and 6, as conditioned. All the units are temporarily shut down, but will be returned to service after 1989. A compliance test is to be run on each unit shortly after startup.

COMPANY NAME

Tampa Electric Co.

Processor

File Number A029-125691

## PERMIT APPLICATION STATUS SHEET

Type of permit applied for Air OperationCounty HillsboroughDate Received 10/2/86P.E. seal & signature ☒Check ☒

No Check

Letter of Corp. standing

Clock  
Days

Date Task Completed

Initials

3 Logging by Sec'y

10/6/86AWA5 Review by Sec. head and  
transfer to permitting  
Engineer

28 Completeness Review

request additional info \*  
information received \*Public Notice Published \*  
(for Air Construction Only)55 Letter of Intent sent to \*  
Supervisor60 Letter of Intent submitted  
to District Manager

75 Intent to issue/deny mailed\*

80 Permitting Eng'r submit  
finished permit package &  
recommendations to supervisor

83 Permit Package to Dist. Engr.

85 Permit Package to Dist.  
Manager

90 Final Issuance/denial

12/29/86WKS

\*If needed, If not indicate by N/A



September 25, 1986

Dr. Richard D. Garrity, Ph.D.  
Florida Department of  
Environmental Regulation  
7601 Highway 301 North  
Tampa, Florida 33610-9544

Mr. Roger P. Stewart  
Hillsborough County Environmental  
Protection Commission  
1900 - 9th Avenue  
Tampa, Florida 33605

Re: Tampa Electric Company  
Air Operations Permit  
Renewal Application  
Hookers Point Station  
Boiler Nos. 1, 2, 3, 4, 5, and 6


Gentlemen:

Enclosed please find an original and four (4) copies of an Application for Renewal of Permit to Operate an Air Pollution Source for each boiler, including an operation and maintenance plan for the station and an authorization letter for the applicant.

The six application packages, together with a check for a total of \$2,070.00 (\$345.00 per application) to the Hillsborough County Board of County Commissioners and a check for a total of \$3,000.00 (\$500.00 per application) to the Florida Department of Environmental Regulation, are included with Mr. Stewart's copy.

If you should have any questions, please feel free to call.

Sincerely,


  
A. Spencer Autry  
Manager  
Environmental Planning

ASA/jst/020/EE1

Enclosures

*TOM*


*Air  
Est Her*



*JS*

 **TAMPA  
ELECTRIC**  
A TECO ENERGY COMPANY  
P.O. Box 111 Tampa, Florida 33601

Richard D. Garrity, Ph.D.  
Florida Department of  
Environmental Regulation  
District Office  
7601 Highway 301 North  
Tampa, Florida 33610-9544



## APPLICATION TRACKING SYSTEM

10/03/86

APPL NO:125691

APPL RECVD:10/02/86 TYPE CODE:A0 SUBCODE:06

LAST UPDATE:10/03/86

DER OFFICE RECVD:TPA DER OFFICE TRANSFER TO:\_\_\_ APPLICATION COMPLETE:\_\_\_/\_\_\_/\_\_\_

DER PROCESSOR:ESTLER

APPL STATUS:AC DATE:10/02/86 (ACTIVE/DENIED/WITHDRAWN/EXEMPT/ISSUED/GENERAL)

RELIEF:\_\_\_ (SSAC/EXEMPTIONS/VARIANCE)

(Y/N) N MANUAL TRACKING

DISTRICT:40 COUNTY:29

(Y/N) N DNR REVIEW REQD?

LAT/LONG:27.56.20/82.26.34

(Y/N) N PUBLIC NOTICE REQD?

BASIN-SEGMENT:\_\_\_

(Y/N) N GOV BODY LOCAL APPROVAL REQD?

COE #:\_\_\_\_\_

(Y/N) Y LETTER OF INTENT REQD? \_ (I/ISSUE D/DENY)

ALT#:\_\_\_\_\_

PROJECT SOURCE NAME:HOOKERS POINT STATION BOILER 6

STREET:HEMLOCK AVE.

CITY:TAMPA

STATE:FL

ZIP:\_\_\_\_\_

PHONE:\_\_\_\_\_

APPLICATION NAME:TAMPA ELECTRIC CO.

STREET:P.O. BOX 111

CITY:TAMPA

STATE:FL

ZIP:33601

PHONE:813-223-4111

AGENT NAME:A. SPENCER AUTREY

STREET:P.O. BOX 111

CITY:TAMPA

STATE:FL

ZIP:33601

PHONE:813-228-4111

FEE #1 DATE PAID:10/02/86 AMOUNT PAID:00500 RECEIPT NUMBER:00105557

B DATE APPLICANT INFORMED OF NEED FOR PUBLIC NOTICE - - - - - / / / / /  
C DATE DER-SENT DNR APPLICATION/SENT DNR INTENT - - - - - / / / / /  
D DATE DER REQ. COMMENTS FROM GOV. BODY FOR LOCAL APP. -- / / / / /  
E DATE #1 ADDITIONAL INFO REQ--REC FROM APPLICANT - - - - - / / / / /  
E DATE #2 ADDITIONAL INFO REQ--REC FROM APPLICANT - - - - - / / / / /  
E DATE #3 ADDITIONAL INFO REQ--REC FROM APPLICANT - - - - - / / / / /  
E DATE #4 ADDITIONAL INFO REQ--REC FROM APPLICANT - - - - - / / / / /  
E DATE #5 ADDITIONAL INFO REQ--REC FROM APPLICANT - - - - - / / / / /  
E DATE #6 ADDITIONAL INFO REQ--REC FROM APPLICANT - - - - - / / / / /  
F DATE GOVERNING BODY REQUESTED SURVEY RESULTS/REPORTS - - / / / / /  
G DATE FIELD REPORT WAS REQ--REC - - - - - / / / / /  
H DATE DNR REVIEW WAS COMPLETED - - - - - / / / / /  
I DATE APPLICATION WAS COMPLETE - - - - - / / / / /  
J DATE GOVERNING BODY PROVIDED COMMENTS OR OBJECTIONS - - / / / / /  
K DATE NOTICE OF INTENT WAS SENT--REC TO APPLICANT - - / / / / /  
L DATE PUBLIC NOTICE WAS SENT TO APPLICANT - - / / / / /  
M DATE PROOF OF PUBLICATION OF PUBLIC NOTICE RECEIVED - - / / / / /  
N WAIVER DATE BEGIN--END (DAY 90) - - - - - / / / / /

COMMENTS:

STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL REGULATION

Nº 105557

RECEIPT FOR APPLICATION FEES AND MISCELLANEOUS REVENUE

Received from Tampa Electric Co. Date 10-2-86

Address P.O. Box 111 Tampa FL Dollars \$ 3,000.00

Applicant Name & Address Same

Source of Revenue Renewal of Air permits A029-125691 A029-125690

Revenue Code 001032 Application Number A029-125687 A029-125689

A029-125685 A029-125686

CK # 65563 By Alvin King



June 2, 1986

Mr. Bill Thomas  
Florida Department of  
Environmental Regulation  
District Office  
7601 Highway 301 North  
Tampa, Florida 33610-9544

Re: Tampa Electric Company  
Administrative Changes to  
Air Permits

Dear Mr. Thomas:

During a recent review of Tampa Electric Company's air permits, administrative inconsistencies were identified that have lead to hardships on us that we feel are not intended by the Department. As shown on the attachment, the inconsistencies involve stack test scheduling, notifications and reporting requirements contained in older air permits. The requested modifications reflect recent changes in Department regulations which depart from previous Department rules or policies.

In order to communicate our concerns and get feedback from the Department, members of my staff met with Mr. Jim Estler of your staff and Mr. Jerry Campbell of the Hillsborough County Environmental Protection Commission on May 29, 1986. Based on this meeting, it is our understanding that neither Mr. Estler nor Mr. Campbell are opposed to modifying the applicable air permits to provide consistency as outlined to them.

Tampa Electric Company respectfully requests that the air permits listed on the attachment be modified to reflect consistent administrative conditions as stated. The requested modification will not change our environmental limits, they only clarify the conditions and time frames for compliance related reports.

We would greatly appreciate an expeditious review of our request for permit modifications, especially as they relate to Units 4, 5 and 6 at Gannon Station which will required compliance testing or excess opacity report submittal in the near future.

D. E. R.

JUN 04 1986


SOUTH WEST DISTRICT  
TAMPA



Mr. Bill Thomas  
June 2, 1986  
Page 2

Thank you for your cooperation, and, please call me if you have any questions.

Sincerely,

A handwritten signature in cursive script, appearing to read "A. Spencer Autry".

A. Spencer Autry  
Manager  
Environmental Planning

ASA/jst/004/EE1

Attachment

cc: Jim Estler, FDER  
Jerry Campbell, HCEPC

INCONSISTENCIES IN ADMINISTRATIVE PROCEDURES

DER AIR PERMITS  
TAMPA ELECTRIC COMPANY (TEC)

The following modifications will provide consistent reporting and administrative requirements for the two major reports required in TEC's air permits:

1. Specify that all annual compliance testing should be done within a 90 day period prior to the specified annual test date. (The regulations require annual test during Fiscal year - October 1 to September 30.)

The permits below either do not address the 90 day test window, or are more stringent than 90 days:

<u>Source</u>	<u>Permit Number</u>	<u>Specific Condition</u>
<u>Hookers Point</u>		
Unit 1	A029-47726	1
Unit 2	A029-47725	1
Unit 3	A029-47724	1
Unit 4	A029-47723	1
Unit 5	A029-47722	1
Unit 6	A029-47721	1
 <u>F.J. Gannon</u>		
Unit 4	A029-80043	4
Unit 5	A029-47728	1
Unit 6	A029-47727	1
Combustion Turbine 1	A029-85099	1
Fly Ash Silo 1	A029-80048	1
Fly Ash Silo 2	A029-80046	1
Economiser Silo	A029-87409	1
 <u>Big Bend</u>		
Unit 1	A029-63296	1
Combustion Turbine 1	A029-85100	1

2. Specify that all compliance test notifications be non-written notifications pursuant to 17-2.700(2)(a)5:

The permits below contain a written notification requirement:

<u>Source</u>	<u>Permit Number</u>	<u>Specific Condition</u>
<u>F.J. Gannon</u>		
Combustion Turbine 1	A029-85099	4
Fly Ash Silo 1	A029-80048	5
Fly Ash Silo 2	A029-80046	3
Economiser Ash Silo	A029-87409	3

Big Bend

Combustion Turbine 1	A029-85100	5
----------------------	------------	---

3. Specify that all compliance test submittals shall be within 45 days as required in 17-2.700(7).

The permits below contain a test submittal date more stringent than 45 days.

<u>Source</u>	<u>Permit Number</u>	<u>Specific Condition</u>
<u>Hookers Point</u>		
Unit 1	A029-47726	1
Unit 2	A029-47725	1
Unit 3	A029-47724	1
Unit 4	A029-47723	1
Unit 5	A029-47722	1
Unit 6	A029-47721	1

F.J. Gannon

Unit 5	A029-47728	1
Unit 6	A029-47727	1

4. Specify that excess emissions refer to 6-minute average opacity.


The permits below either do not address the averaging time or specify a 1-minute average:

<u>Source</u>	<u>Permit Number</u>	<u>Specific Condition</u>
<u>F.J. Gannon</u>		
Unit 4	A029-80043	7
<u>Big Bend</u>		
Unit 1	A029-63296	6

HILLSBOROUGH COUNTY  
ENVIRONMENTAL PROTECTION

COMMISSION

RODNEY COLSON  
RON GLICKMAN  
PAM IORIO  
RUBIN E. PADGETT  
JAN KAMINIS PLATT  
JAMES D. SELVEY  
PICKENS C. TALLEY II



ROGER P. STEWART  
DIRECTOR

1900 - 9th AVE  
TAMPA, FLORIDA 33605

TELEPHONE (813) 272-5960

MEMORANDUM

D. E. R.

Date June 12, 1986

To Jim Estler

From Jerry Campbell *Jc*

*[Signature]*  
JUN 16 1986

SOUTH WEST DISTRICT  
TAMPA

Subject: TECO Permit Amendments

Having reviewed TECO's requests in Spencer Autry's letter of June 2, 1986 to Bill Thomas, I recommend approval of the following amendments:

Gannon Unit 4 (A029-80043)

Change Specific condition #4 to read:

4. This unit shall be stack tested for particulate matter (under both soot blowing and non soot blowing operating conditions), sulfur dioxide and visible emissions at intervals of 12 months from the date of May 30, 1984 or within a ninety (90) day period prior to this date. The Method 9 Test period on this source shall be sixty (60) minutes. Testing procedures shall be consistent with the requirements of Section 17-2.700, F.A.C.

Change specific condition #7 to read:

7. A report shall be submitted to both the Department of Environmental Regulation and the Hillsborough County Environmental Protection Commission within 30 days following each calendar quarter detailing any excess opacity readings recorded during the three month period. For the purpose of this report, excess emission shall be defined as all six minute averages of opacity greater than 20 percent, except as specified in Specific Condition No. 2. The information supplied in this report shall be consistent with the reporting requirements of 40 CFR 51 Appendix P [Section 17-2.710(1), F.A.C.]. This report shall be submitted in duplicate to the Hillsborough County Environmental Protection Commission.

Gannon Unit 5 (A029-47728)

Change specific condition #1 to read:

1. This unit shall be stack tested for particulate matter (under both soot blowing and non soot blowing operating conditions), sulfur dioxide and visible emissions at intervals of 12 months from the date of July 29, 1981 or within a ninety (90) day period prior to this date. The Method 9 Test period on this source shall be sixty (60) minutes. Testing procedures shall be consistent with the requirements of Section 17-2.700, F.A.C. Two copies of the test report shall be submitted to the Air Section of the Hillsborough County Environmental Protection Commission within 45 days of testing.

Gannon Unit #6 (A029-47727)

Change Specific condition #1 to read:

1. This unit shall be stack tested for particulate matter (under both soot blowing and non soot blowing operating conditions), sulfur dioxide and visible emissions at intervals of 12 months from the date of July 29, 1981 or within a ninety (90) day period prior to this date. The Method 9 Test period on this source shall be sixty (60) minutes. Testing procedures shall be consistent with the requirements of Section 17-2.700, F.A.C. Two copies of the test report shall be submitted to the Air Section of the Hillsborough County Environmental Protection Commission within 45 days of testing.

Hookers Point Unit #1 (A029-47726)

Change specific condition #1 to read:

1. This unit shall be stack tested for particulate matter (under both soot blowing and non soot blowing operating conditions), sulfur dioxide and visible emissions at intervals of 12 months from the date of January 27, 1982 or within a ninety (90) day period prior to this date. The Method 9 Test period on this source shall be sixty (60) minutes. Testing procedures shall be consistent with the requirements of Section 17-2.700, F.A.C. Two copies of the test report shall be submitted to the Air Section of the Hillsborough County Environmental Protection Commission within 45 days of testing. A fuel analysis may be submitted in lieu of stack testing for sulfur dioxide.

Hookers Point Unit #2 (A029-47725)

Change specific condition #1 to read:

1. This unit shall be stack tested for particulate matter (under both soot blowing and non soot blowing operating conditions), sulfur dioxide and visible emissions at intervals of 12 months from the date of January 27, 1982 or within a ninety (90) day period prior to this date. The Method 9 Test period on this source shall be sixty (60) minutes. Testing procedures shall be consistent with the requirements of Section 17-2.700, F.A.C. Two copies of the test report shall be submitted to the Air Section of the Hillsborough County Environmental Protection Commission within 45 days of testing. A fuel analysis may be submitted in lieu of stack testing for sulfur dioxide.

Hookers Point Unit #3 (A029-47724)

Change specific condition #1 to read:

1. This unit shall be stack tested for particulate matter (under both soot blowing and non soot blowing operating conditions), sulfur dioxide and visible emissions at intervals of 12 months from the date of January 27, 1982 or within a ninety (90) day period prior to this date. The Method 9 Test period on this source shall be sixty (60) minutes. Testing procedures shall be consistent with the requirements of Section 17-2.700, F.A.C. Two copies of the test report shall be submitted to the Air Section of the Hillsborough County Environmental Protection Commission within 45 days of testing. A fuel analysis may be submitted in lieu of stack testing for sulfur dioxide.

Hookers Point Unit #4 (A029-47723)

Change specific condition #1 to read:

1. This unit shall be stack tested for particulate matter (under both soot blowing and non soot blowing operating conditions), sulfur dioxide and visible emissions at intervals of 12 months from the date of January 27, 1982 or within a ninety (90) day period prior to this date. The Method 9 Test period on this source shall be sixty (60) minutes. Testing procedures shall be consistent with the requirements of Section 17-2.700, F.A.C. Two copies of the test report shall be submitted to the Air Section of the Hillsborough County Environmental Protection Commission within 45 days of testing. A fuel analysis may be submitted in lieu of stack testing for sulfur dioxide.

Hookers Point Unit #5 (A029-47722)

Change specific condition #1 to read:

1. This unit shall be stack tested for particulate matter (under both soot blowing and non soot blowing operating conditions), sulfur dioxide and visible emissions at intervals of 12 months from the date of January 27, 1982 or within a ninety (90) day period prior to this date. The Method 9 Test period on this source shall be sixty (60) minutes. Testing procedures shall be consistent with the requirements of Section 17-2.700, F.A.C. Two copies of the test report shall be submitted to the Air Section of the Hillsborough County Environmental Protection Commission within 45 days of testing. A fuel analysis may be submitted in lieu of stack testing for sulfur dioxide.

Hookers Point Unit #6 (A029-47721)

Change specific condition #1 to read:

1. This unit shall be stack tested for particulate matter (under both soot blowing and non soot blowing operating conditions), sulfur dioxide and visible emissions at intervals of 12 months from the date of January 27, 1982 or within a ninety (90) day period prior to this date. The Method 9 Test period on this source shall be sixty (60) minutes. Testing procedures shall be consistent with the requirements of Section 17-2.700, F.A.C. Two copies of the test report shall be submitted to the Air Section of the Hillsborough County Environmental Protection Commission within 45 days of testing. A fuel analysis may be submitted in lieu of stack testing for sulfur dioxide.

Gannon Combustion Turbine #1 (A029-85099)

Change specific condition #1 to read:

1. Test the emissions for the following pollutant(s) at intervals of 12 months from the date March 15, 1984, or within a ninety (90) day period prior to this date, and submit 2 copies of test data to the Air Section of the Hillsborough County Environmental Protection Commission office within forty five days of such testing [Section 17-2.700 (2), Florida Administrative Code, (F.A.C.)].

( ) Particulates	( ) Sulfur Oxides
( ) Fluorides	( ) Nitrogen Oxides
(X) Opacity	( ) Hydrocarbons
	( ) Total Reduced Sulfur

\*Fuel analysis may be submitted for required sulfur dioxide emission test.

Page 4

Change specific condition #4 to read:

4. The Hillsborough County Environmental Protection Commission shall be notified 15 days prior to compliance testing.

Gannon Fly Ash Silo #1 - 4 (A029-80048)

Change specific condition #1 to read:

1. Compliance with the opacity standard set forth below shall be demonstrated by conducting 30 minute visible emission tests as units #3, #2 & #1 are converted to coal and begin utilizing this silo. By November 15, 1984, 60 days prior to the expiration of construction permit #AC29-41941, a visible emission test shall be submitted while loading the silo from Units #3 & #4. By January 15, 1986, 60 days prior to the expiration of construction permit A029-41942, a visible emission test shall be submitted while loading the silo from Units #2, #3 & #4. By January 15, 1987, 60 days prior to the expiration of construction permit AC29-41943, a visible emission test shall be submitted while loading the silo from Unit #1 and two of the remaining 3 units. Thereafter, visible emissions tests shall be conducted while loading the silo from 3 of the 4 units at 12 month intervals. Tests can be conducted within a ninety (90) day period prior to the dates specified above.

Change specific condition #5 to read:

5. The Hillsborough County Environmental Protection Commission shall be notified 15 days prior to compliance testing.

Gannon Fly Ash Silo #5-6 (A029-80046)

Change specific condition #1 to read:

1. Test the baghouse for visible emissions at intervals of twelve months from the date of November 15, 1983 or within a ninety (90) day period prior to this date. The compliance test shall be conducted using EPA Method #9 (opacity). The Method #9 test interval on this source shall be thirty (30) minutes. Two copies of the test data shall be submitted to the Air Section of the Hillsborough County Environmental Protection Commission within 45 days of testing.

Change specific condition #3 to read:

3. The Hillsborough County Environmental Protection Commission shall be notified 15 days prior to compliance testing.

Gannon Economiser Silo (A029-87409)

Change specific condition #1 to read:

1. Test the baghouse for visible emissions at intervals of twelve months from the date of December 4, 1983 or within a ninety (90) day period prior to this date. The compliance test shall be conducted using EPA Method #9 (opacity). The Method #9 test interval on this source shall be thirty (30) minutes. Two copies of the test data shall be submitted to the Air Section of the Hillsborough County Environmental Protection Commission within 45 days of testing.

Page 6

Change specific condition #2 to read:

2. The Hillsborough County Environmental Protection Commission shall be notified 15 days prior to compliance testing.

If you have any questions concerning the contents of this memorandum, please contact me.

JC/ch

CH2/16



STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL REGULATION



**SOUTHWEST DISTRICT**

7601 HIGHWAY 301 NORTH  
TAMPA, FLORIDA 33610

813-985-7402  
SunCom - 570-8000

BOB GRAHAM  
GOVERNOR

VICTORIA J. TSCHINKEL  
SECRETARY

DR. RICHARD D. GARRITY  
DISTRICT MANAGER

June 12, 1986

Mr. A. Spencer Autry, Manager  
Environmental Planning  
Tampa Electric Company  
Post Office Box 111  
Tampa, FL 33601-0111

RE: Modification of Conditions  
Permit No. A029-47721

Dear Mr. Autry:

We are in receipt of your request for a modification of the permit conditions.  
The conditions are changed as follows:

Specific Condition No. 1

From:

1. Test the emissions for the following pollutant(s) at intervals of 12 months from date of permit and submit a copy of test data to the District Engineer of this agency within fifteen days of such testing. (Chapter 17-2.700(2), F.A.C.)

(X) Particulates	(X) Sulfur Oxides*
( ) Fluorides	( ) Nitrogen Oxides
(X) Plume Density	( ) Hydrocarbons
	( ) Total Reduced Sulfur

\*Fuel analysis is acceptable

To:

1. This unit shall be stack tested for particulate matter (under both soot blowing and non-soot blowing operating conditions), sulfur dioxide and visible emissions at intervals of 12 months from the date of January 27, 1982 or within a ninety (90) day period prior to this date. The Method 9 Test period on this source shall be sixty (60) minutes. Testing procedures shall be consistent with the requirements of Section 17-2.700, F.A.C. A fuel analysis can be submitted for the required sulfur dioxide emission test. Two copies of test data shall be submitted to the Air Section of the Hillsborough County Environmental Protection Commission Office within forty-five days of such testing.

Mr. A. Spencer Autry, Manager  
Tampa, FL

Page Two

This letter must be attached to your permit and becomes a part of that permit.

Sincerely,

A handwritten signature in cursive script, appearing to read "W. C. Thomas".

W. C. Thomas, P.E.  
District Air Engineer

JWE/js

Mr. A. Spencer Autry, Manager  
Tampa, FL

Page Three

CERTIFICATE OF SERVICE

This is to certify that this NOTICE OF PERMIT and all copies were mailed before the close of business on 6-13-86 to the listed persons.

FILING AND ACKNOWLEDGEMENT  
FILED, on this date, pursuant to  
§120.52(10), Florida Statutes, with  
the designated Department Clerk,  
receipt of which is hereby  
acknowledged.

Jean Sehester      6/13/86  
Clerk                                  Date

STATE APIS  
9-24  
COUNTY  
9-25

WILLSBOROUGH COUNTY ENVIRONMENTAL  
PROTECTION COMMISSION

INSPECTION REPORT  
EXECUTIVE SUMMARY

TYPE III

PLANT NAME TECO - HOOKERS POINT NEDS 038 DATE/TIME 9-24-85

PLANT LOCATION HOOKERS POINT HEMLOCK AVE. # OF NEDS POINTS 6

PROCESS DESCRIPTION ELECTRICAL POWER GENERATION

COMPLIANCE VERIFICATION  
ENFORCEMENT  
ANNOUNCED  
PERSONS CONTACTED-TITLE



PERMIT REVIEW  
OTHER  
UNANNOUNCED

( )  
( )  
( )

BOB STAFFORD / DAVID JELLERSON

NEDS POINTS  
CHECKED

03, 04, 06

NEDS POINTS

IN COMPLIANCE 03, 04, 06

NEDS POINTS

IN VIOLATION

0

SUMMARY OF FINDINGS NEDS #3 & #6 REFER TO UNITS #3 & #6 WHICH WERE BOTH DOWN AT THE TIME OF THIS INSPECTION DUE TO SLACK DEMAND FOR POWER. THIS DOWN STATUS WAS EVIDENCED BY BOTH STEAM CHARTS INDICATING A 0 STEAM PRODUCTION IN THESE TWO BOILERS. NEDS #04 REFERS TO UNIT #4 WHICH WAS OPERATING AT A MINIMUM LOAD CAPACITY OF 6,500 POUNDS OF STEAM GENERATING 60 MW OF POWER. THE FUEL CONSUMPTION RATE OF UNIT 4 IS DETERMINED BY A TOTALIZER WHICH KEEPS A RUNNING TALLY IN THE FORM OF GALLONS BURNED. IT SHOULD BE NOTED THAT BOILERS 1 THRU 5 CAN OPERATE ANY ONE, OR ANY COMBINATION, OF 4 POWER GENERATING TURBINES. UNIT #6 IS DEDICATED TO ONE TURBINE.

SPECTION COMMENTS FOR APIS (LIMIT 50 SPACES)

SPECTOR'S SIGNATURE Michael D. Elliott / CARLOS GONZALEZ

### SECTION III - AIR CLEANING EQUIPMENT

Source Code	Type of Air Cleaning Equipment : a,b	Pollutant Removed c	Inlet Gas Temp °F	Inlet Gas Flow Rate ACFM	Maximum Pressure Drop PSI d	Efficiency e	
						Design Percent	Operating Percent
	Not Applicable						

Wet scrubber, electrostatic precipitator, fabric filter, etc.

Please list future equipment separately

- c. Pollutants to be covered in this survey are specified in the accompanying instructions.
- d. Give maximum normal operating pressure drop across air cleaning system.
- e. Give efficiency in terms of pollutant removed.

SOUTH WEST DISTRICT  
TAMPA

三  
二  
一

10

#### SECTION IV - STACK AND POLLUTANT EMISSIONS DATA

[illegible]

UNIT: 6

HOOKERS POINT

1984

$$\frac{3189 \text{ GAL. OIL}}{\text{HR}} \times 151,387 \frac{\text{BTU}}{\text{GAL.}} = 482.8 \frac{\text{MMBTU}}{\text{HR}} \text{ (AVG)}$$

$$\text{DESIGN} = 778.0 \frac{\text{MMBTU}}{\text{HR.}} \text{ (MAX.)}$$

$$\frac{6,088,475 \text{ GAL. OIL}}{19} \times 151,387 \frac{\text{BTU}}{\text{GAL.}} = 921,716 \frac{\text{MMBTU}}{1984} \text{ (ACTUAL)}$$

PARTICULATE EMISSIONS

$$0.06 \frac{\text{lbs. PART}}{\text{MMBTU}} \times 482.8 \frac{\text{MMBTU}}{\text{HR}} = 29.0 \frac{\text{lbs. PART}}{\text{HR.}} \text{ (AVG.)}$$

$$0.06 \frac{\text{lbs. PART}}{\text{MMBTU}} \times 778.0 \frac{\text{MMBTU}}{\text{HR}} = 46.7 \frac{\text{lbs. PART}}{\text{HR.}} \text{ (MAX.)}$$

$$0.06 \frac{\text{lbs. PART}}{\text{MMBTU}} \times 921,716 \frac{\text{MMBTU}}{1984} \times \frac{1 \text{ TON}}{2,000 \text{ lb}} = 27.7 \frac{\text{TONS PART}}{1984}$$

SULFUR DIOXIDE EMISSIONS

$$1.07^* \frac{\text{lbs. SO}_2}{\text{MMBTU}} \times 482.8 \frac{\text{MMBTU}}{\text{HR}} = 516.6 \frac{\text{lbs. SO}_2}{\text{HR.}} \text{ (AVG.)}$$

$$1.07^* \frac{\text{lbs. SO}_2}{\text{MMBTU}} \times 778.0 \frac{\text{MMBTU}}{\text{HR}} = 832.5 \frac{\text{lbs. SO}_2}{\text{HR.}} \text{ (MAX.)}$$

$$1.07^* \frac{\text{lbs. SO}_2}{\text{MMBTU}} \times 921,716 \frac{\text{MMBTU}}{1984} \times \frac{1 \text{ TON}}{2000 \text{ lb}} = 493.1 \frac{\text{TONS SO}_2}{1984}$$

\* lbs SO<sub>2</sub>/mmBtu value of 1.07 is a 1984 weighted average,

GANNON STATION

1994

GANNON 1-4 FLYASH SILO

$$\text{EMISSION} = (1.32 \text{ lb/hr}) \left( \frac{8021 \text{ hrs OP.}}{\text{yr}} \right) \left( \frac{1 \text{ Ton}}{2000 \text{ lbs}} \right) = 5.29 \text{ TONS/yr.}$$

GANNON 5+6 FLYASH SILO

$$\text{EMISSION} = (\overset{\text{DESIGN}}{2.07} \text{ lb/hr}) \left( \frac{8257 \text{ hrs. OP.}}{\text{yr}} \right) \left( \frac{1 \text{ Ton}}{2000 \text{ lbs}} \right) = 8.58 \text{ TONS/yr.}$$

GANNON 4 FLOXIMIZER ASH SILO

$$\text{EMISSION} = (\overset{\text{DESIGN}}{0.14} \text{ lb/hr}) \left( \frac{7133 \text{ hrs OP.}}{\text{yr}} \right) \left( \frac{1 \text{ Ton}}{2000 \text{ lbs}} \right) = 0.50 \text{ TONS/yr.}$$

## GANNON STATION

GAS TURBINE  
FUEL CONSUMED

1984

$$\text{TOTAL CONSUMPTION} = 3174.11 \text{ BBLs} = 133,313 \text{ GALS.}$$

$$\text{TOTAL GENERATED} = 885,000 \text{ KWH}$$

$$\text{AVG \% Sulfur} = 0.37$$

$$\text{AVG Btu/lb} = 19,468$$

$$\text{AVG Density (lb/gal)} = 7.121$$

$$\text{AVG Hourly Consumption} = \frac{133,313 \text{ gal oil 1984}}{120 \text{ hrs. operation}} = 1111 \frac{\text{gal}}{\text{hr.}}$$

$$V = (133,313 \text{ gals}) (7.121 \frac{\text{lb}}{\text{gal}}) \left( \frac{1 \text{ yr}}{12.0 \text{ hrs. op.}} \right) \left( \frac{1}{3600 \text{ sec.}} \right) \left( \frac{239 \text{ ft}^3 \text{ gas}}{1 \text{ bbl oil}} \right) \left( \frac{1470^\circ \text{R}}{492^\circ \text{R}} \right) \left( \frac{1}{95.7 \text{ ft}^3} \right) = 16.40 \text{ fps}$$

$$\text{Flow (avg)} = (16.40 \text{ fps}) (95.7 \text{ ft}^3) (60 \frac{\text{sec}}{\text{min}}) = 94,169 \text{ CFM}$$

## SULFUR DIOXIDE (AVG)

$$\left( \frac{133,313 \text{ gal}}{\text{yr}} \right) (7.121 \frac{\text{lb}}{\text{gal}}) \left( \frac{0.0037 \text{ TON S}}{\text{TON OIL}} \right) (1.9 \frac{\text{TON SO}_2}{\text{TON S}}) \left( \frac{1 \text{ TON}}{2000 \text{ lb.}} \right) = 3.3 \frac{\text{TON}}{\text{yr}}$$

$$\left( 1111 \frac{\text{gal}}{\text{hr}} \right) (7.121 \frac{\text{lb}}{\text{gal}}) \left( 0.0037 \frac{\text{TON S}}{\text{TON OIL}} \right) (1.9) = 55.6 \frac{\text{lb}}{\text{hr.}}$$

## SULFUR DIOXIDE (MAX)

$$(1885 \text{ gal/hr}) (7.121 \frac{\text{lb}}{\text{gal}}) \left( 0.0037 \frac{\text{TON S}}{\text{TON OIL}} \right) (1.9 \frac{\text{TON SO}_2}{\text{TON S}}) = 94.4 \frac{\text{lb}}{\text{hr}}$$

## PARTICULATE (AVG)

$$\left( \frac{133,313 \text{ gal}}{\text{yr}} \right) (7.121 \frac{\text{lb}}{\text{gal}}) (19,468 \frac{\text{Btu}}{\text{lb}}) \left( \frac{0.1 \text{ lb}}{\text{MM Btu}} \right) \left( \frac{1 \text{ TON}}{2000 \text{ lbs}} \right) = 0.924 \frac{\text{TON}}{\text{yr}}$$

$$\left( 1111 \text{ gal/hr} \right) (7.121 \frac{\text{lb}}{\text{gal}}) (19,468 \frac{\text{Btu}}{\text{lb}}) \left( \frac{0.1 \text{ lb}}{\text{MM Btu}} \right) = 15.4 \frac{\text{lb}}{\text{hr.}}$$

## PARTICULATE (MAX)

$$(1885 \frac{\text{gal}}{\text{hr}}) (7.121 \frac{\text{lb}}{\text{gal}}) (19,468 \frac{\text{Btu}}{\text{lb}}) \left( \frac{0.1 \text{ lb}}{\text{MM Btu}} \right) = 26.1 \frac{\text{lb}}{\text{hr}}$$



D. E. J.

100-100000

SOUTH WEST DISTRICT  
TAMPA

CANNONUNIT: 6YEAR 1984

$$\frac{119.7 \text{ TONS}}{\text{HR}} \times \frac{2,000 \text{ lbs.}}{\text{TON}} \times \frac{12,480 \text{ BTU}}{\text{lb.}} = \frac{2987.7 \text{ MMBTU}}{\text{HR.}} \quad (\text{AVG})$$

$$\text{DESIGN} = \frac{3,798 \text{ MMBTU}}{\text{HR.}} \quad (\text{MAX})$$

$$\frac{809,008 \text{ TONS}}{\text{YR.}} \times \frac{2,000 \text{ lbs.}}{\text{TON}} \times \frac{12,480 \text{ BTU}}{\text{lb.}} = \frac{20,192,840 \text{ MMBTU}}{1984} \quad (\text{ACTUAL})$$

PARTICULATE EMISSIONS

$$\frac{0.03 \text{ lbs. PART.}}{\text{MM BTU}} \times \frac{2,987.7 \text{ MMBTU}}{\text{HR.}} = \frac{89.6 \text{ lbs. PART.}}{\text{HR.}} \quad (\text{AVG})$$

$$\frac{0.03 \text{ lbs. PART.}}{\text{MM BTU}} \times \frac{3,798 \text{ MMBTU}}{\text{HR.}} = \frac{113.9 \text{ lbs. PART.}}{\text{HR.}} \quad (\text{MAX})$$

$$\frac{0.03 \text{ lbs. PART.}}{\text{MM BTU}} \times \frac{20,192,840 \text{ MMBTU}}{1984} \times \frac{1 \text{ TON}}{2,000 \text{ lb.}} = \frac{302.9 \text{ TONS PART.}}{1984}$$

SULFUR DIOXIDE EMISSIONS

$$\frac{1.85^* \text{ lbs. SO}_2}{\text{MM BTU}} \times \frac{2,987.7 \text{ MMBTU}}{\text{HR.}} = \frac{5,527.2 \text{ lbs. SO}_2}{\text{HR.}} \quad (\text{AVG})$$

$$\frac{1.85^* \text{ lbs. SO}_2}{\text{MM BTU}} \times \frac{3,798 \text{ MMBTU}}{\text{HR.}} = \frac{7,026.3 \text{ lbs. SO}_2}{\text{HR.}} \quad (\text{MAX})$$

$$\frac{1.85^* \text{ lbs. SO}_2}{\text{MM BTU}} \times \frac{20,192,840 \text{ MMBTU}}{1984} \times \frac{1 \text{ TON}}{2,000 \text{ lb.}} = \frac{18,678.4 \text{ TONS SO}_2}{1984}$$

\*-lbs SO<sub>2</sub> value of 1.85 is a weighted average for 1984.  
MM Btu

CANNOXUNIT: 6YEAR 1984

$$\frac{119.7 \text{ TONS}}{\text{HR}} \times \frac{2,000 \text{ lbs.}}{\text{TON}} \times \frac{12,480 \text{ BTU}}{\text{lb}} = \frac{2,987.7}{\text{HR.}} \text{ MMBTU (AVG)}$$

$$\text{DESIGN} = \frac{3,798}{\text{HR.}} \text{ MMBTU (MAX)}$$

$$\frac{809,008 \text{ TONS}}{\text{YR.}} \times \frac{2,000 \text{ lbs.}}{\text{TON}} \times \frac{12,480 \text{ BTU}}{\text{lb}} = \frac{20,192,840}{1984} \text{ MMBTU (ACTUAL)}$$

PARTICULATE EMISSIONS

$$\frac{0.03 \text{ lbs. PART.}}{\text{MM BTU}} \times \frac{2,987.7}{\text{HR.}} \text{ MMBTU} = \frac{89.6 \text{ lbs. PART.}}{\text{HR.}} \text{ (AVG)}$$

$$\frac{0.03 \text{ lbs. PART.}}{\text{MM BTU}} \times \frac{3,798}{\text{HR.}} \text{ MMBTU} = \frac{113.9 \text{ lbs. PART.}}{\text{HR.}} \text{ (MAX)}$$

$$\frac{0.03 \text{ lbs. PART.}}{\text{MM BTU}} \times \frac{20,192,840 \text{ MMBTU}}{1984} \times \frac{1 \text{ TON}}{2,000 \text{ lb}} = \frac{302.9 \text{ TONS PART.}}{1984}$$

SULFUR DIOXIDE EMISSIONS

$$\frac{1.85^* \text{ lbs. SO}_2}{\text{MM BTU}} \times \frac{2,987.7}{\text{HR.}} \text{ MMBTU} = \frac{5,527.2 \text{ lbs. SO}_2}{\text{HR.}} \text{ (AVG)}$$

$$\frac{1.85^* \text{ lbs. SO}_2}{\text{MM BTU}} \times \frac{3,798}{\text{HR.}} \text{ MMBTU} = \frac{7,026.3 \text{ lbs. SO}_2}{\text{HR.}} \text{ (MAX)}$$

$$\frac{1.85^* \text{ lbs. SO}_2}{\text{MM BTU}} \times \frac{20,192,840 \text{ MMBTU}}{1984} \times \frac{1 \text{ TON}}{2,000 \text{ lb}} = \frac{18,678.4 \text{ TONS SO}_2}{1984}$$

\*-lbs SO<sub>2</sub> value of 1.85 is a weighted average for 1984.  
MM Btu

D. E. R.

MAR 11 1985

SOUTH WEST DISTRICT  
TAMPA

Representing Calender Year 1984

Plant, institution, or establishment name Tampa Electric Company (Hookers Point Station)  
Plant, institution, or establishment address: P.O. Box 111 Tampa FL 33601  
(Street or Box Number) (City) (State) (Zip)  
Person to contact regarding this report: A. Spencer Autry Title: Environmental Planning Telephone: 228-4838  
Mailing address: P.O. Box 111 Tampa FL 33601  
(Street or Box Number) (City) (State) (Zip)

Normal operating schedule: \_\_\_\_\_ Hours per day \_\_\_\_\_ Days per week \_\_\_\_\_ Weeks per year \_\_\_\_\_ Hours per year.  
Seasonal and/or peak operation period: \_\_\_\_\_  
Dates of annually occurring shutdowns of operations: \_\_\_\_\_ Additional operating info. enclosed \_\_\_\_\_

[illegible]

- a. List a separate code number to represent each source (e.g., IV-a, IV-b, IV-c, etc.) then enter required data on this page and for the same code number sources in Section III. IV, and V.
- b. Multiple sources may be grouped if similar in size and type.
- c. Sulfuric acid-contact: aluminum smelting-crucible furnace; cement manufacturing-dry process; etc (See instruction for examples and use approximate identification numbers); other non-listed processes and operations (specify).
- d. The pollutants to be covered in this report are listed in the accompanying instructions.
- e. Sulfur burned: pig, foundry returns, or scrap aluminum melted; limestone, cement rock, clay, iron ore used; etc.
- f. Pounds, tons, gallons, barrels, etc.
- g. Sulfuric acid produced; aluminum ingots produced; etc.
- h. For intermittent processes, indicate average number of hours per week of operation so that estimates of yearly emissions may be obtained.

SECTION V - STACK AND POLLUTANT EMISSIONS DATA

STACK DATA					ESTIMATE OF POLLUTANT EMISSIONS				
Source Code	Height Above Grade ft.	Inside Diameter at Top ft.	Exit Gas Velocity ft./sec.	Exit Gas Temperature °F.	Pollutant	Technique	Quantity tons/yr.	Average lb/hr.	Maximum lb/hr.
Hookers Point 5	Common with Boiler	No. 1			Particulate	Stack Test	16.7	10.5	24.4
Hookers Point 6	280	9.41	40.29	325	Sulf. Dioxide	Fuel Anal.	446.9	281.1	652.7
					Particulate	Stack Test	27.7	29.0	46.7
					Sulf. Dioxide	Fuel Anal.	493.1	516.6	832.5

- List code numbers corresponding to each emissions source reported in Section II, III, and IV.
- Values should be representative of average flow conditions for hours of operation.
- At actual flow conditions.
- The pollutants to be covered in this survey are specified in the accompanying instructions.
- Give stack test data if available (indicate stack sampling method used), otherwise, specify basis used. If unknown, please do not complete these columns.
- Note technique used to arrive at estimation; AP-42, stack test, etc.

INSPECTION REPORT  
EXECUTIVE SUMMARYPLANT NAME TECO NEDS 040 DATE/TIME 1/10/85 AMPLANT LOCATION GANNON # OF NEDS POINTSPROCESS DESCRIPTION Power Generating Boiler #6 using coal for fuel  
and Electrostatic Precipitator for control device.COMPLIANCE VERIFICATION  
ENFORCEMENT  
ANNOUNCED  
PERSONS CONTACTED-TITLE(✓)  
(✓)  
(✓)PERMIT REVIEW  
OTHER  
UNANNOUNCED(✓)  
(✓)  
(✓)

Type 4 audit

Hugh Smith / Neil OakesNEDS POINTS  
CHECKED 06NEDS POINTS  
IN COMPLIANCENEDS POINTS  
IN VIOLATION

SUMMARY OF FINDINGS While visiting the Gannon Station, Unit #6 was being  
tested for TSP, SO<sub>2</sub> and V.E. All test parameters were being  
conducted simultaneously, at least during the first particulate  
test run which started at 9:30 a.m. Mr. Gary McRae and  
two assistants were at the stack performing the TSP and SO<sub>2</sub>  
tests. Mr. Greg Williams was collecting operating parameter  
data (% O<sub>2</sub>, opacity etc). At about 10:15 a control light  
turn "on" in the control room "Precipitator Control RM FIRE". Before entering  
the plant building Mike & I noticed two short periods (1-2 min)  
of dust leakage around the bottom of the precipitator hopper.  
The second one occurred while we were entering the building with  
Hugh Smith. I asked him about it and he said he did not  
know what could cause such condition. We noticed that during

INSPECTION COMMENTS FOR APIS (LIMIT 50 SPACES) the rest of the visit and as we  
left the plant ground this condition was not seen anymore. I suspect  
this was tied to a short boiler upset that caused an overload to the

INSPECTOR'S SIGNATURE Mike S.

precipitator. I expect the V.E. during this period to be higher.  
ash handling.

COMPANY NAME

Lampa Electric Co.

RRG

Processor

Hookers Point  
Boiler # 6

File Number A029-47721

## PERMIT APPLICATION STATUS SHEET

Type of permit applied for Air Operation

County Hillborough

Date Recieved 9/15/81

P.E. seal & signature ☐Check ☒No check ☐Letter of corp. standing ☐CLOCK  
DAYS

DATE TASK COMPLETED

INITIALS

- 3 Logging by Sec'y
- 5 Review by Sec. head and transfer to permitting Engineer
- 28 Completeness Review
- request additional info \*
- information received \*
- Public Notice Published \*  
(for Air Construction only)
- 55 Letter of Intent sent to \* Supervisor
- 60 Letter of Intent submitted \* to District Manager
- 75 Intent to issue/deny mailed \*
- 80 Permitting Eng'r submit finished permit package & recommendations to supervisor
- 83 Permit Package to Dist. Engr.
- 85 Permit Package to Dist. Manager
- 90 Final Issuance/denial

9/21/81

PKT

11-3-81

SZ

1-27-82

PKT

\*If needed, If not indicate by N/A



## HOOKERS POINT STATION - BOILERS 1 THROUGH 6

### Operation and Maintenance Plan

#### Introduction

Hookers Point Station is owned and operated by Tampa Electric Company. The plant is located on the shore of Hillsborough Bay off Sparkman Channel. The plant consists of six boilers and five turbine generator units. Boilers 1 through 5 are connected to a header system which supplies steam to four turbine generators. Boiler 6 supplies steam to turbine generator number 5.

The Hookers Point boilers burn No. 6 fuel oil. The boiler manufacturers, types and in-service dates are listed below:

<u>Boiler</u>	<u>Service Date</u>	<u>Manufacturer</u>	<u>Type</u>
1	1948	Babcock and Wilcox	Front Firing
2	1948	Babcock and Wilcox	Front Firing
3	1950	Babcock and Wilcox	Front Firing
4	1950	Babcock and Wilcox	Front Firing
5	1953	Babcock and Wilcox	Front Firing
6	1955	Combustion Engineering	Tangential Firing

The boilers exhaust gases through stacks at an elevation of 280 feet.

#### Process System Performance Parameters

Boilers 1 through 6 burn low sulfur No. 6 fuel oil. Fuel oil quality is monitored upon delivery. Four samples are taken for analysis, one of the four being sent to the fuel supplier. In addition, daily samples are taken for a monthly composite analysis. The design fuel consumption, steam flow rates, operating temperatures and operating pressures are listed below.

<u>Boiler</u>	<u>Fuel Consumption</u>	<u>Steam Flow</u>	<u>Operating Temperature</u>	<u>Operating Pressure</u>
1	86.0 BBLS/HR	220,000 LBS/HR	900°F	960 psi
2	86.0	220,000	900°	960
3	118.8	275,000	900°	960
4	118.8	275,000	900°	960
5	86.2	440,000	900°	975
6	126.0	625,000	950°	1450

Actual fuel input to the boilers is back calculated from weekly fuel tank drawdown and boiler efficiencies. Steam flow, temperature and pressure are continuously monitored and recorded on control room charts. Fuel oil temperature and pressure are maintained at optimum levels. Excess air is continuously monitored and recorded and maintained at levels to produce efficient fuel combustion.

#### Maintenance Inspection

All generating units of the Tampa Electric Company system are regularly scheduled for periodic maintenance. The schedule for planned maintenance outages is affected by system load and forced outage requirements. Typically, planned outages are scheduled during non-peak load periods such as the spring or fall.

During major outages, the boilers, controls, auxiliaries and duct work are inspected and repaired as necessary. On-going procedures include burner inspections and cleanings, burner tip replacements and maintenance of optimum flame patterns to achieve efficient fuel combustion. All repair information is stored on magnetic tape for future reference.



POST OFFICE BOX 111 TAMPA, FLORIDA 33601 TELEPHONE (813) 879-1111

Please file 1029-7104

D.E.R.


MAR 14 1980

SOUTHWEST DISTRICT  
TAMPA

March 7, 1980

Mr. Joe Griffiths  
Hillsborough County Environmental  
Protection Commission  
1900 9th Avenue  
Tampa, Florida 33605

RE: Stack Emission Test  
Hookers Point Unit 6  
Tampa Electric Company



Dear Joe:

Enclosed please find two (2) copies of a stack test report for a compliance test performed on Hookers Point Unit 6 on January 31, 1980.

As stated in the Summary of Results, the average particulate emission rate for three test runs was 0.05 lbs. per million BTU, which is in compliance with Florida Administrative Code, Chapter 17-2.05 (6)(e)(1)(b)2.b of 0.1 lbs. per million BTU.

Included in the Summary of Results, the average sulfur dioxide emission rate from fuel analysis conducted by our Central Testing Laboratory was 1.07 lbs. per million BTU which is in compliance with Florida Administrative Code, Chapter 17-2.05 (6)(e)(1)(b)2.b of 1.1 lbs. per million BTU.

Also included are nitrogen dioxide results, a process statement, and visible emission report. If you have any questions, please call.

Yours truly,

*William N. Cantrell*

W.N. Cantrell  
Engineer  
Environmental Planning

WNC:mo  
enclosure

cc: J.D. Hicks  
H.A. Turner  
A. Kaiser  
W.J. Johnson  
A.S. Autry  
F.L. Burkhard  
R.P. Murray

04/03/80

DER AIR PERMIT INVENTORY SYSTEM  
SOUTHWEST DISTRICT HILLSBOROUGH COUNTY

40/29/0038/03  
PAGE 1

PLANT 0038 TECO HOOKERS POINT  
FOOT OF MEMLOCK AVE  
TAMPA  
ALEX KAISER  
PO BOX 111  
TAMPA FL

. 33604

UTILITY FILE STATUS SENT  
POWER PLANT  
FL. 33605  
AOCR=052 SIC=4911  
LAT=28:02:32N LON=82:25:31W  
UTM ZONE 17 358.0KM E. 3094.0KM N.

POINT 03 CONST PATS#

OPER PATS#

A029-25432

ISS= / / EXP= / /

ISS=12/18/79 EXP=12/01/84

OIL FIRED BOILER

SOURCE= IPP=00 EXIST

COMM.PNTS. -

STACK HT= 280FT DIAM=11.3FT TEMP= 265F FLOW= 356400CFM PLUME= 0FT

BOILER CAP= 411MBTU/HR FUEL FOR SPACE HEAT= .0%

OPERATING PROCESS RATES YOR=79 RAW MATERIAL= 0 OTHER

PRODUCT 0 OTHER FUEL 0 OTHER

NORMAL COND. DEC-FEB=11% MAR-MAY=30% JUN-AUG=42% SEP-NOV=17%

PERMIT SCHEDULE 12HRS/DAY 6DAYS/WK 52WKS/YR

ADR FOR 12/31/79 10HRS/DAY 6DAYS/WK 52WKS/YR

COMPLIANCE NEDS=1 ORC=2 UPDATE08/79 SCHED.08/80 UPDATED08/15/79

PERMIT=1 YOR=79 INSPECTED / / NEXT DUE 08/01/80


/

SCC'S

1-01-004-01 YOR=79 SOURCE=8 RATE= 7574 MAX= 1.999 KGL/BRN  
FUEL CONT SO2= .95% ASH= 0.0% 411MBTU FYOR=79 CONFID=2

POLLUTANTS MONITORED

TSP 11101 NORM= 41.00 EST/METH= 55/1 MAX.ALW= 78 TNS/YR.  
CTLS.PRI= 0 SEC= 0 EFF= 0.0% NEXT DUE 08/28/80 TEST/FREQ=1  
TESTED 08/28/79 AGENCY=3 REG=.05(2) COMPLIANCE=1  
EMITTED= 35.00 ALLOWED= 41.00LBS/HR OP-RATE= 410 OTH/BR  
VE 11204 NORM= 600.03 EST/METH= 60003/1 MAX.ALW= 20 TNS/YR.  
CTLS.PRI= 0 SEC= 0 EFF= 0.0% NEXT DUE 08/28/80 TEST/FREQ=1  
TESTED 08/28/79 AGENCY=3 REG=.05(1)A COMPLIANCE=1  
EMITTED= 600.03 ALLOWED= 0.20LBS/HR OP-RATE= 411 OTH/BR  
CO 42101 NORM= 0.00 EST/METH= 42/3 MAX.ALW= 0 TNS/YR.  
CTLS.PRI= 0 SEC= 0 EFF= 0.0% NEXT DUE / / TEST/FREQ=  
SO2 42401 NORM= 452.00 EST/METH= 761/1 MAX.ALW= 856 TNS/YR.  
CTLS.PRI= 0 SEC= 0 EFF= 0.0% NEXT DUE 08/28/80 TEST/FREQ=1  
TESTED 08/28/79 AGENCY=3 REG=.05(B) COMPLIANCE=1  
EMITTED= 402.00 ALLOWED= 451.00LBS/HR OP-RATE= 410 OTH/BR  
NOX 42603 NORM= 0.00 EST/METH= 882/3 MAX.ALW= 0 TNS/YR.  
CTLS.PRI= 0 SEC= 0 EFF= 0.0% NEXT DUE / / TEST/FREQ=  
TESTED 00/00/78 AGENCY= REG= COMPLIANCE=  
EMITTED= 1.52 ALLOWED= 0.00LBS/HR OP-RATE= 0 OTHER



COUNTY HILLSBOROUGH

MEMORANDUM

Date August 10, 1978

To P. David Puchaty, District Manager, SW District DER

From Joe Griffiths, Environmental Protection Commission

Subject: TECO Permits: Hooker's Point 4 & 6, Gannon 1 & 5

Each facility showed compliance during the latest stack test. The reason each source was permitted till July, 1981 is because: All sources are located in the non-attainment area for TSP and may be contributing to the overall problem. If that is the case some changes in operating time, performance standards, start-up procedures, etc. may be required and the changes could be incorporated into the next permit before the January 1, 1982 deadline.

cc: Files

JG/dj

*Joe agreed to  
five year permits after  
telephone conversation 8/19/78.*

*Don Williams*

**D.E.R.**

AUG 14 1978

SOUTHWEST DISTRICT  
TAMPA



EC D  
Hookers Pt. #6

File Number A029-7104

PERMIT APPLICATION STATUS SHEET

Type of permit applied for Air Operation

County Hillsborough

Date Recieved 8-14-78

P.E. seal & signature ☒  
Check ☒  
No check ☐  
Letter of corp. standing ☐

CLOCK DAYS		DATE TASK COMPLETED	INITIALS
3	Logging by Sec'y	<u>8-16-78</u>	<u>ff</u>
15	Review by Sec. head and transfer to permitting Engineer	<u>8-23-78</u>	<u>dw</u>
28	Completeness Review		
	request additiona info *		
	information received *		
	Public Notice Published * (for Air Construction only)		
55	Letter of Intent sent to * Supervisor		
60	Letter of Intent submitted * to District Manager		
75	Intent to issue/deny mailed *		
80	Permitting Eng'r submit finished permit package & recommendations to supervisor	<u>9-14-78</u>	<u>VB</u>
83	Permit Package to Dist. Engr.	<u>9-18-78</u>	<u>dw</u>
85	Permit Package to Dist. Manager	<u>9-18-78</u>	<u>dw</u>
90	Final Issuance/denial	<u>9/20/78</u>	<u>RRT</u>

\*If needed, If not indicate by N/A

STATE		COUNTY					AQCR			PLANT #				POINT ID	
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	
1	0	1	8	0	0	0	5	2	0	0	3	8	0	6	

[illegible]

YEAR OF RECORD		CONSTRUCTION PERMIT										ISSUE DATE						EXPIRATION DATE						OPERATING PERMIT						ISSUE DATE						EXPIRATION DATE						LATITUDE						LONGITUDE						PERMIT TYPE	SOURCE TYPE	ACTION					
		15	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67				68	69	70	71	72
15	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77
15	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77
15	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77
15	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77
15	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77
15	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77
15	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77
15	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68									

[illegible][illegible][illegible]

# PERMIT WORK SHEET

SOURCE Teco Hooker Co # 6 DATE 9-14-78  
 COUNTY Willsborough TYPE PERMIT 29-7104

ACTION	INITIAL WHEN COMPLETED	DATE
Preliminary Review		
Assigned for Review to		
Review Comments	<u>9-14-78</u>	<u>[Signature]</u>

I have reviewed the plans and applications submitted and find that the above mentioned source will not reasonably be expected to cause pollution in violation of the Department standards, rules and regulations. I recommend approval of this permit.

Number Assigned		
Permit Issued & Signed		
Permit Logged		
Permit Mailed		
Data Forms Completed		
Permit Denied		



## TYPE PERMIT ACTION

## DESCRIPTION OF PRIMARY SOURCE

New Source (No related permits) \_\_\_\_\_

Boiler \_\_\_\_\_

Renewed or modified permit \_\_\_\_\_

Solid Waste (Incinerator) \_\_\_\_\_

Point source deleted \_\_\_\_\_

Other Combustion \_\_\_\_\_

Point source added \_\_\_\_\_

Process \_\_\_\_\_

New Source replacing old source \_\_\_\_\_

Product (Name) \_\_\_\_\_

## BRIEF DESCRIPTION OF PROCESS

778 MMBTU Steam generator using #6  
fuel oil

OPERATING TIME: \_\_\_\_\_

HR/D2 \_\_\_\_\_

Da/Wk \_\_\_\_\_

Wk/ \_\_\_\_\_

## STACK DATA

## OPERATING DATA

Height (FT) \_\_\_\_\_

Process Rate \_\_\_\_\_

Diam. (FT) \_\_\_\_\_

Process Rate \_\_\_\_\_

TON \_\_\_\_\_

Temp. (°F) \_\_\_\_\_

Max Design Rate \_\_\_\_\_

L/Hr \_\_\_\_\_

Flow Rate (CFM) \_\_\_\_\_

Combustion (Units) Gal \_\_\_\_\_

TONS \_\_\_\_\_

FT \_\_\_\_\_

Plume Height (FT) \_\_\_\_\_

Rate \_\_\_\_\_

Unit/Hr \_\_\_\_\_

Unit/ \_\_\_\_\_

Common Stack (Explain) \_\_\_\_\_

Heat Content \_\_\_\_\_

BTU/Gal \_\_\_\_\_

Boiler Capacity \_\_\_\_\_

BTU/Hr \_\_\_\_\_

Max Design Rate \_\_\_\_\_

Unit/Hr \_\_\_\_\_

Fuel (Name) #6

SS

1%

SA

## COMMENTS:

fuel and SO<sub>2</sub>  $3986 \times 8 \times .02 = 637.8 \text{ lb/hr SO}_2$   $0.8 \text{ lb/MMBTU}$   
 { TSP  $44.7 \text{ lb/hr}$   $36.5 \text{ T/y}$   $\text{also } 89.4 \text{ lb/hr}$   
 { SO<sub>2</sub>  $840.7 \text{ lb/hr}$   $686.5 \text{ T/y}$   $\text{also } 983.8 \text{ lb/hr}$

Particulates  
Particulates  
Particulates  
SO<sub>2</sub>  
NO<sub>x</sub>  
HC  
F<sup>-</sup>

EMISSIONS

POLLUTANT	lb/hr		lb/ton Product		lb/10 <sup>6</sup> BTU		Regulation
	Emission	Allowable	Emission	Allowable	Emission	Allowable	
Particulate							
SO <sub>2</sub>							
NO <sub>x</sub>							
HC							
F <sup>-</sup>							

CAPACITY      Test \_\_\_\_\_      Allowable \_\_\_\_\_

BASIS FOR ESTIMATE

\_\_\_\_\_ Stack Test Results      Date \_\_\_\_\_      Report Received \_\_\_\_\_  
\_\_\_\_\_ V. E. Test      Date \_\_\_\_\_      Report Received \_\_\_\_\_  
\_\_\_\_\_ Other tests or emission measurement  
\_\_\_\_\_ Material balance of process using engineering knowledge  
\_\_\_\_\_ Emissions calculated using EPA emission factors  
\_\_\_\_\_ Other Method (Describe): \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL REGULATION  
ANNUAL OPERATIONS REPORT FORM  
FOR AIR EMISSIONS SOURCES

D.E.R.

MAR 13 1978

For each permitted emission point, please submit a separate report for calendar year 19 77 prior to March 1st of the following year.

SOUTHWEST DISTRICT  
TAMPA

I GENERAL INFORMATION:

- Source Name: Tampa Electric Company (Hookers Point Boiler #6)
- Permit Number: AO 20-2483
- Source Address: P. O. Box 111  
Tampa, Florida 33601
- Description of Source: Fossil fuel steam generator

II OPERATING SCHEDULE: 24 hrs/day 7 days/wk 52 wks/yr  
actual hours of operation 1633

III RAW MATERIAL INPUT PROCESS WEIGHT:

Raw Material	Input Process Weight	
		tons/yr
		tons/yr
<u>N/A</u>	<u>N/A</u>	tons/yr
		tons/yr
		tons/yr

IV TOTAL FUEL USAGE, including standby fuels. If fuel is oil, specify weight and sulfur content (e.g., No. 6 oil with 1% S).

<u>10<sup>6</sup> cubic feet Natural Gas</u>	<u>6508</u>	<u>10<sup>3</sup> gallons No. 6 Oil, 0.9% S</u>
<u>10<sup>3</sup> gallons Propane</u>		<u>10<sup>3</sup> gallons Kerosene</u>
<u>tons Coal</u>		<u>10<sup>6</sup> lb Black Liquor Solids</u>
<u>tons Carbonaceous</u>		<u>tons Refuse</u>
<u>Other (Specify type and units)</u>		

V EMISSION LEVEL (tons/yr):

A. <u>19.3</u>	<u>Particulates</u>	<u>Carbon Monoxide</u>
	<u>Nitrogen Oxide</u>	<u>Total Reduced Sulfur</u>
	<u>Hydrocarbon</u>	<u>Flouride</u>
<u>445.5</u>	<u>Sulfur Dioxide</u>	
<u>Other (Specify type and units)</u>		

B. Method of calculating emission rates (e.g., use of fuel analysis and materials balance, emission factors drawn from AP 42, etc.)

Fuel analysis and/or compliance testing.

VI CERTIFICATION:

I hereby certify that the information given in this report is correct to the best of my knowledge.

W. J. Johnson  
Signature of Owner or Authorized Representative

W.J. Johnson, Acting Manager  
Typed Name and Title

3/8/78  
Date

ANNUAL OPERATING REPORT  
Calendar year 1976

Submit a separate report for each permitted source by FEBRUARY 28, 1977

## SECTION 1: General

SOURCE NAME: Tampa Electric Company (Hookers Point Unit 6)

MAILING ADDRESS: P. O. Box 111 (Attention: Jeff Rankin)

Tampa, Florida 33601

TELEPHONE NO: 813/879-4111

OPERATING PERMIT NO: FDER AO29-2483

SOURCE DESCRIPTION: Fossil-fuel steam generator

**D. E. R.**  
**APR 15 1977**  
**SOUTH WEST DISTRICT**  
**ST. PETERSBURG**

## SECTION 2: PROCESS OPERATIONS:

- a. DURATION OF OPERATION AND FREQUENCY: 24 hrs/dy 7 dys/wk 52 wk/yr  
e.g. 8 hrs perday, 5 dys per wk and 50 wk/yr. actual hours operation 3913
- b. DESIGN CRITERIA: MAXIMUM OUTPUT 81.6 MW (from FPC-67 Form)  
e.g. 850 MW, 750 tons/dy
- c. ~~XXXXX~~ NORMAL (AVERAGE) OUTPUT 49.7 MW (during actual hours of operation)  
e.g. 424 MW, 670 tons/dy.
- d. MAXIMUM PEAK THAT OCCURED DURING ANY ONE DAY 81.6 MW  
e.g. 910 MW, 810 tons/dy.

## SECTION 3: TOTAL AMOUNT OF MATERIALS USED/PROCESSED, COMPUTED ON THE SAME BASIS AS PROCESS WEIGHT:

TYPE(MATERIAL)	INPUT PROCESS WEIGHT- DRY
	tons/yr
N.A.	N.A. tons/yr
	tons/yr
	tons/yr

## SECTION 4: TOTAL AMOUNT OF FUEL USED. IF FUEL IS OIL, SPECIFY WEIGHT, e.g. NO 2, and % sulfur by weight. INCLUDE STANDBY FUELS.

--	10 <sup>6</sup> cu. ft	16,195	10 <sup>3</sup> gal NO. 6 OIL .94 %SULFUR
--	10 <sup>3</sup> gal PROPANE	--	10 <sup>3</sup> gal KEROSENE
--	tons COAL	--	10 <sup>6</sup> lb BLACK LIQUOR SOLIDS
--	OTHER, specify type and units		

## SECTION 5: EMISSION: ESTIMATED/TESTED EMISSIONS(TONS PER YEAR)

- a. 117.7 tons of particulates 1146 tons of sulfur dioxide  
-- tons of nitrogen dioxide -- tons of carbon monoxide  
-- tons of hydrocarbon -- tons (other)

b. ~~STATE~~ METHOD OF CALCULATIONS USED IN DETERMINING EMISSION RATES

Particulates - gallons oil X  $\frac{\text{BTU}}{\text{gal.}}$  X  $\frac{\text{tons part.}}{\text{BTU}}$  = tons particulate

SO<sub>2</sub> - gallons oil X  $\frac{\text{BTU}}{\text{gal.}}$  X  $\frac{\text{tons SO}_2}{\text{BTU}}$  = tons SO<sub>2</sub>

ANNUAL OPERATING REPORT  
calendar year 1976

## SECTION 5(cont't)

c. STACK TESTED: None yet date \_\_\_\_\_


STACK TEST CONDITIONS: \_\_\_\_\_ PROCESS RATE DURING TEST \_\_\_\_\_

STACK TEST CONDUCTED BY: \_\_\_\_\_

STACK TEST WITNESSED BY: \_\_\_\_\_

SECTION 6: OPERATIONAL PROBLEMS, IF ANY: Routinea. IMPROVEMENTS MADE TO PROCESS/POLLUTION CONTROL EQUIPMENT: Noneb. TYPE OF MAINTENANCE PERFORMED: Routinec. NUMBER OF UPSETS LASTING MORE THAN FOUR HOURS DURING THE YEAR: 0d. NUMBER OF UPSETS LASTING MORE THAN ONE HOUR BUT NOT MORE THAN FOUR HOURS: Unknowne. NUMBER OF UPSETS LASTING LESS THAN ONE HOUR: Unknown

## CERTIFICATION:

I HEREBY CERTIFY THAT THE INFORMATION GIVEN IN THIS REPORT IS CORRECT TO THE  
BEST OF MY KNOWLEDGE.  
\_\_\_\_\_  
Signature of owner or authorized representativeAlex Kaiser, Director of Power Plant Engineering  
\_\_\_\_\_  
Typed name and titleApril 5, 1977  
\_\_\_\_\_  
Date



POST OFFICE BOX 111 TAMPA, FLORIDA 33601 TELEPHONE (813) 876-4111

September 14, 1976

Ms. Sandra Walters  
Florida Department of  
Environmental Regulation  
Southwest District  
9721 Executive Center Drive, N.  
Suite 200  
St. Petersburg, Florida 33702

Dear Ms. Walters:

As per your request, we are returning permit  
No. AO-29-2483 (Hookers Point No. 6) for the purpose  
of having Mr. Vest sign it.

We will look forward to receiving the fully exe-  
cuted copy back shortly.

Yours very truly,

Alex Kaiser, Director  
Power Plant Engineering

Enclosure

*Sent the signed copy to  
Mr. Kaiser on 9/17/76*

*Sandi*

**TECO**  
TAMPA ELECTRIC COMPANY

**D. E. R.**

AUG 16 1976

POST OFFICE BOX 111 TAMPA, FLORIDA 33601 TELEPHONE (813) 876-4111  
SOUTH WEST DISTRICT  
ST. PETERSBURG

August 4, 1976

Mr. Arturo McDonald  
Air Engineer  
Hillsborough County Environmental  
Protection Commission  
7402 North 56th St., Bldg. 500  
Tampa, Florida 33617

**RECEIVED**

AUG 5 1976

**H.C.E.P.C.**

Dear Mr. McDonald:

Enclosed are three reports from Conservation Consultants, Inc. on the source compliance test for Unit No. 6 at Hookers Point Station.

The test was made on June 2, 1976 and a summary of the results is as follows:

Test #1	0.027 #/MBTU
Test #2	0.081 #/MBTU
Test #3	0.025 #/MBTU
Average	0.044 #/MBTU

The regulation governing the particulate emissions is 0.1 #/MBTU and the average emissions for the test period was 0.044 #/MBTU. As we have said in the past, the oil burning will continue to be well below the particulate emissions standards and we, therefore, request that no further testing be required.

Very truly yours,

*0.97% S burned = 1.00 \* SO<sub>2</sub>/MM Btu.*

*A. Spencer Autry*  
A. Spencer Autry, Biologist  
Environmental Planning

ASA:sac



Hookers Pt.

J.L.T  
File ✓

POST OFFICE BOX 111 TAMPA, FLORIDA 33601 TELEPHONE (813) 876-4111

July 15, 1975

D.P.C.

JUL 21 1975

WEST CENTRAL REGION  
WINTER HAVEN

Mr. Joe Tessatore  
Florida Department of  
Environmental Regulation  
P. O. Box 9205  
Winter Haven, Florida 33880

RE: Particulate Emission Testing

Dear Mr. Tessatore:

As per our recent telephone conversation, I would like to provide you with the data we have taken on particulate emissions from our Hookers Point Station. The actual results are enclosed, but the following is a brief synopsis of the tests:

<u>Boiler No.</u>	<u>Date of Test</u>	<u>Particulate Emission</u>	<u>Fuel % Ash</u>
5	7-9-74	0.0997 #/10 <sup>6</sup> BTU	0.06 <sup>1</sup>
6	6-25-74	0.43 #/10 <sup>6</sup> BTU	0.06 <sup>2</sup>

NOTE: (1) Assumed to be the same as June 25, 1974 sample  
(2) Fuel sample taken during test - analysis sheet is enclosed

As you can see, Boiler No. 6 was in violation of the emission regulations and Boiler No. 5 was in compliance by a slim margin. As you can also see, the ash content of the oil was 0.06% during the June 25, 1974 test and was assumed to be the same for the July 9, 1974 test. The reason the ash content was so high was because high sulfur oil (1.7%) was being burned.



Mr. Joe Tessatore  
Page 2  
July 15, 1975

Since the time of the above testing, we have switched to low sulfur oil. This oil typically has an ash content of 0.01% or 1/6 the ash content of the oil burned during the emission tests. Obviously, the particulate emissions are much lower with the cleaner oil that we are now burning and although we have not run particulate emission tests, we have noticed a considerable improvement as far as visible emissions are concerned and are confident that the particulate emission regulations are now being complied with. Enclosed are results of a visible emissions check that was run June 23, 1975. We think these results, which are on the order of 1/20 of the allowable opacity, substantiate that particulate emissions we are now experiencing are within the allowable emission regulation.

The reason for bringing this matter up, as discussed on the telephone, is to determine if it is necessary for us to run annual particulate tests on the Hookers Point boilers as presently required by our operating permit. Since these boilers will continue to burn the clean low sulfur oil in the future, since the procedure and equipment for burning the oil will remain the same and since there is no removal equipment or cleanup device involved which must be checked periodically to ensure it is operating as designed, we feel that the particulate emissions can be adequately estimated by using the EPA emission factor of 8 # part/10<sup>3</sup> gallon oil or 0.055 # part/10<sup>6</sup> BTU. The alternative is to perform actual tests at a cost of approximately \$2,000/boiler and we know you will agree that if there is no measurable benefit to be derived, then the public should not have to pay this amount of money.

We would be happy for you to come to Tampa and tour the Hookers Point Station if you think it would be helpful for you to get more familiar with our operation and procedures. Also, if you would like any other information, we will be happy to provide it for you.

We hope that after you have evaluated all the information, you will agree that annual testing of the boilers is not necessary. We will look forward to an early reply.

Yours very truly,



Jeff Rankin  
Senior Engineer  
Environmental Planning

DJR:sac  
Enclosures

cc: Mr. Bennie Caramella, HCEPC

**D. P. C.**

11 22 1975

**WEST CENTRAL REGION  
WINTER HAVEN**

SUMMARY

Hookers Point: Unit 5

32,350 lbs. of fuel per hour  
18,777 BTU's per pound  
607.4 million BTU's/hr.  
607.4 X 0.1 lb. = 60.74 lbs. particulate per hour  
allowed for this unit

Hookers Point: Unit 6

46,430 lbs. of fuel per hour  
18,509 BTU's per pound of fuel  
859.4 million BTU's per hour  
859.4 X 0.1 lbs. = 85.9 lbs. particulate per hour  
allowed for this unit

	<u>Actual lbs. Particulate/hr.</u>	<u>Lbs. Particulate/ Million BTU of Heat Input</u>
Hookers Point:		
Unit 5		
Run 1	59.8	
Run 2	61.36	
Average	60.58	.0997
Unit 6		
Run 1	296.81	
Run 2	447.99	
Average	372.40	.43

# TECHNICAL SERVICES, INC.

103 Stockton Street  
P. O. Box 628  
Jacksonville, Fla. 32201

BEST AVAILABLE COPY

## SOURCE SAMPLING CALCULATIONS PARTICULATE EMISSIONS

PLANT-TECO HOOKERS POINT

STACK - UNIT NO. 6

WEATHER CONDITIONS - CLOUDY

AS' - 113.1 SQ. FEET TS - 782.5 DEGREES R TM - 555 DEGREES R H - 0.528 IN H2O

AH - 0.75 ON H2O AN - 0.000341 SQ. FT CP - 0.85 VM - 36.8 CF VC - 70 ML

TOTAL TIME - 72 MIN. NPTS - 24 ORSAT: CO2 - 9.00 O2 - 4 CO - 0 N2 - 87

DATE - 6/25/74

RUN 2 FROM 15:30-17:00

PB - 29.78 IN HG PS - 29.75 IN HG

1. Volume Water Vapor	1. 3.318	SCF
2. Stack Gas Volume - STPD	2. 35.042	SCF
3. Total Volume	3. 38.36	SCF
4. Moisture in Stack Gas - Volume Fraction	4. 0.086	
5. Dry Stack Gas - Volume Fraction	5. 0.914	
6. Assumed Moisture in Stack Gas - Volume Fraction	6. 0.1	
7. Molecular Weight of Stack Gas - Dry Basis	7. 29.6	
8. Molecular Weight of Stack Gas - Stack Conditions	8. 38.6	
9. Specific Gravity of Stack Gas Relative to Air	9. 0.99	
10. Excess Air - Percent	10. 21.	%
11. Average of Factor ( $\sqrt{VH \times TS}$ )	11. 14.78	
12. Average Stack Velocity	12. 2207.3	FE
13. Actual Stack Gas Flow Rate	13. 249640	ACF
14. Actual Stack Gas Flow Rate Dry	14. 228048	CFD
15. Stack Gas Flow Rate - STPD	15. 153583	SCF
16. Percent Isokinetic	16. 105.1	%

MG	GR/SCF	GR/ACF	MG/SCF	MG/ACF	LBS/HR
THIMBLE 772.7	0.3395	0.2090	778.50	478.81	447.99
TOTAL 772.6	0.3395	0.2090	778.50	478.81	447.99

Comments: Operating at maximum attainable load of 70 MW  
859.4 X 10<sup>6</sup> BTU/hr heat input

Test Conducted By: A. E. Henderson & F. M. Raggett

## SOURCE SAMPLING FIELD DATA SHEET

Plant TECO BROOKER POINT

Sampling Location Unit 6 Stack

Date 6/25/74 Run No. 1

Time Start 1310 Time End 1500

Sampling Time/Point 3 min.

DB 323 °F, WB °F, VF @ DP "Hg

Moisture 10 %, FMA Gas Density Factor

Barometric Press 29.76" Hg Stack Press 29.73" Hg

Weather Cloudy & Warm

Temp. 85 °F, W/D NW, W/S 10

Sample Box No. 1 Meter Box No. 1

Meter AQ 1.68 Pitot Corr. Factor .85

Nozzle Dia. 1/4 in., Probe Length 10 ft

Probe Heater Setting

Stack Dimensions: Inside Diameter 144 in  
 Inside Area 113.1 ft<sup>2</sup>  
 Height ft

Mat'l Processing Rate 70 MW

Final Gas Meter Reading 036.85 ft<sup>3</sup>

Initial Gas Meter Reading 999.41 ft<sup>3</sup>

Total Condensate in Impingers 70 ml

Moisture in Silica Gel 10.0 gm

Silica Gel Container No. 2 Filter No. 4 F

Orsat: CO<sub>2</sub> 9.0%

O<sub>2</sub> 4.0%

CO 0.0%

N<sub>2</sub> 87.0%

Excess Air

Test Conducted by: A. E. Henderson  
F. M. Raggett

Remarks:

Port and Traverse Point No.	Distance from End of Port (in.)	Clock Time	Gas Meter Reading (ft <sup>3</sup> )	Stack Velocity Head ("H <sub>2</sub> O)	Meter Orifice Press. Diff. ("H <sub>2</sub> O)		Stack Gas Temp. (°F)	Gas Sample Temp. & Dry Gas Meter (°F)		Sample Box Temp. (°F)	Last Impinger Test (°F)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
		13:10										
	South	00	999.41									
		03	000.9	.26	.67	.67	350	89	88		.510	
		06	002.6	.38	.98	.98	350	91	89		.616	
		09	004.4	.44	1.15	1.15	350	92	89		.663	
		12	006.2	.44	1.15	1.15	350	94	90		.663	
		15	008.1	.44	1.15	1.15	350	95	91		.663	
		18	009.8	.31	0.80	.80	350	95	91		.557	

[illegible]

# TECHNICAL SERVICES, INC.

BEST AVAILABLE COPY

103 Stockton Street  
P. O. Box 628  
Jacksonville, Fla. 32201

## SOURCE SAMPLING CALCULATIONS PARTICULATE EMISSIONS

PLANT - TECO HOOKERS POINT

STACK - UNIT NO. 6

WEATHER CONDITIONS - CLOUDY

AS' - 113.1 SQ. FEET TS - 783 DEGREES R TM - 555 DEGREES R H - 0.542 IN H2O

AH - 0.79 IN H2O AN - 0.000341 SQ FT CP - 0.85 VM - 37.44 CF VC - 80 ML

TOTAL TIME - 72 MIN NPTS - 24 ORSAT: CO2 - 9.00 O2 - 4 CO - 0 N2 87

DATE - 6/25/64

RUN J FROM 13:10 - 15:00

PS - 29.73 IN HG

1. Volume Water Vapor	1. 3.792	SCF
2. Stack Gas Volume - STPD	2. 35.631	SCF
3. Total Volume	3. 39.423	SCF
4. Moisture in Stack Gas - Volume Fraction	4. 0.096	
5. Dry Stack Gas - Volume Fraction	5. 0.904	
6. Assumed Moisture in Stack Gas - Volume Fraction	6. 0.1	
7. Molecular Weight of Stack Gas - Dry Basis	7. 29.6	
8. Molecular Weight of Stack Gas - Stack Conditions	8. 28.46	
9. Specific Gravity of Stack Gas Relative to Air	9. 0.98	
10. Excess Air - Percent	10. 21	%
11. Average of Factor ( $\sqrt{VH \times TS}$ )	11. 15.168	
12. Average Stack Velocity	12. 2270.4	FE
13. Actual Stack Gas Flow Rate	13. 256788	ACF
14. Actual Stack Gas Flow Rate Dry	14. 232088	CF
15. Stack Gas Flow Rate - STPD	15. 156099	SCF
16. Percent Isokinetic	16. 105.2	%

MG	GR/SCF	GR/ACF	MG/SCF	MG/ACF	LBS/HR
THIMBLE - 512.1	0.2213	0.1346	507.48	308.41	296.81
TOTAL 512.1	0.2213	0.1346	507.48	308.41	296.81

Comments: Operating at maximum attainable load of 70 MW  
859.4 X 10<sup>6</sup> BTU/hr heat input

Test Conducted By: A. E. Henderson & F. M. Razzett

## SOURCE SAMPLING FIELD DATA SHEET

Plant TECO HOOKERS POINT  
 Sampling Location Unit 6 Stack  
 Date 6/25/74 Run No. 2  
 Time Start 1530 Time End 1700  
 Sampling Time/Point 3 minutes  
 DB 323 °F, WB      °F, VF @ DP      "Hg  
 Moisture 10 %, FDA     , Gas Density Factor       
 Barometric Press 29.78 "HG Stack Press 29.75 "HG  
 Weather Cloudy & Warm  
 Temp. 85 °F, W/DNW     , W/S 10  
 Sample Box No. 1 Meter Box No. 1  
 Meter ΔH@ 1.68 Pitot Corr. Factor .85  
 Nozzle Dia. 1/4 in., Probe Length 10 ft  
 Probe Heater Setting --  
 Stack Dimensions: Inside Diameter 144 in  
                           Inside Area 113.1 ft<sup>2</sup>  
                           Height      ft

Mat'l Processing Rate 70 MW  
 Final Gas Meter Reading 74.52 ft<sup>3</sup>  
 Initial Gas Meter Reading 37.72 ft<sup>3</sup>  
 Total Condensate in Impingers 66 ml  
 Moisture in Silica Gel 14 gm  
 Silica Gel Container No.      Filter No.       
 Orsat: CO<sub>2</sub> 9.0%  
           O<sub>2</sub> 4.0%  
           CO --  
           N<sub>2</sub> 87.0%  
 Excess Air       
 Test Conducted by: A. E. Henderson  
                           F. M. Raggett

Remarks:       
      
    

Point and Traverse Point No.	Distance from End of Port (in.)	Clock Time	Gas Meter Reading (ft <sup>3</sup> )	Stack Velocity Head ("H <sub>2</sub> O)	Meter Orifice Press. Diff. ("H <sub>2</sub> O)		Stack Gas Temp. (°F)	Gas Sample Temp. & Dry Gas Meter (°F)		Sample Box Temp. (°F)	Last Impinger Test (°F)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
			1530									
		00	37.72									
North		03	39.0	.15	.41	.41	300	94	92			
		06	40.4	.25	.68	.68	300	94	93			
		09	41.9	.30	.80	.80	300	95	93			
		12	43.5	.30	.80	.80	300	95	93			
		15	45.2	.33	.90	.90	300	96	94			
		18	47.1	.38	1.05	1.05	300	97	94			

[illegible]



THORNTON LABORATORIES, INC.

ANALYTICAL AND CONSULTING CHEMISTS

CHARLES C. THORNTON, PRESIDENT  
K. KHAJEH-NOORI, VICE-PRES.

1145 EAST CASS STREET  
TAMPA, FLORIDA 33601

TELEPHONE 229-2641  
AREA CODE 813  
P. O. Box 2880

July 23, 1974

Laboratory Mark 453488  
Sample of Fuel Oil  
Date Received July 10, 1974  
For Tampa Electric Company  
P. O. Box 111  
Marks: Tampa, Florida  
#6 Boiler 2:00 P.M. 6/25/74  
P. O. #96473

CERTIFICATE OF ANALYSIS

Flash Point, Cleveland Open Cup	142°F
Fire Point, Cleveland Open Cup	244°F
Saybolt Furol Viscosity @ 122°F	59.2 sec.
Sediment by extraction	0.04%
Water by distillation	0.30%
Sulfur	1.77%
A.P.I. Gravity @ 60°F	17.2
Weight per Gallon, lbs	7.925
B.T.U. per pound	18,509
B.T.U. per gallon	146,684
B.T.U. per barrel	6,160,721
Specific Gravity @ 60°F	0.9513
Vanadium	150 ppm
Ash	0.06%

For Tampa Electric Company  
Invoice Auditing Dept.

THORNTON LABORATORIES, INC.

*Kamran Noori*

## SOURCE EMISSION TEST DATA

Test Number -  
 Plant Name -  
 Source Tested -  
 Type of Plant -  
 Control Equipment -  
 Pollutant Sampled -

	1	2	
1. Run Number	6/25/74	6/25/74	
2. Date	13:10	15:30	
3. Time Began	15:00	17:00	
4. Time End	72	72	
5. T - Net Time of Test, Minutes	29.76	29.78	
6. PB - Barometric Pressure, Inches Hg	29.73	29.75	
7. PS - Stack Pressure, Inches Hg	0.70	0.75	
8. ΔH - Gas Meter Orifice Pressure Drop, Inches H <sub>2</sub> O	95	95	
9. TM - Gas Meter Average Temperature, °F	80	70	
10. VC - Total H <sub>2</sub> O Collected, ml	3.70	3.32	
11. VWV - Volume H <sub>2</sub> O Vapor Collected, cubic ft., STP	37.44	36.3	
12. VM - Volume Dry Gas Sampled, cu. ft., Meter Cond.	35.631	35.042	
13. VSTPD - Volume Dry Gas Sampled, cu. ft., STP	9.6	8.6	
14. W(PCT) - Stack Gas Moisture, PCT Volume	323	322.5	
15. TS - Average Stack Gas Temperature, °F	9	9	
16. CO <sub>2</sub> - Stack Gas CO <sub>2</sub> , PCT Volume	4	4	
17. O <sub>2</sub> - Stack Gas O <sub>2</sub> , PCT Volume	0	0	
18. CO - Stack Gas CO, PCT Volume	87	87	
19. N <sub>2</sub> - Stack Gas N <sub>2</sub> , PCT Volume	21.	21.	
20. EA - Stack Gas Excess Air, PCT Volume	29.6	29.6	
21. MD - Stack Gas Molecular Weight, Dry	28.48	28.6	
22. MS - Stack Gas Molecular Weight, Stack Cond.	0.18	0.90	
23. GS - Stack Gas Specific Gravity, Ref Air	0.542	0.529	
24. H - Average Square Root Velocity Head, Inches H <sub>2</sub> O	15.160	14.78	
25. Average Square Root (Stk Temp x Vel Head)	0.85	0.85	
26. CP - Pitot Tube Correction Factor	2270.4	2297.3	
27. U - Stack Gas Velocity, Feet/Minute	113.1	113.1	
28. AS - Stack Area, Square Feet	113.1	113.1	
29. AS' - Effective Stack Area, Square Feet	250788	243340	
30. QS - Stack Gas Flow Rate, cu.ft./min., Stk Cond.	155007	155333	
31. QSTPD - Stack Gas Flow Rate, cu.ft./min. STP	0.25	0.25	
32. DN - Sampling Nozzle Diameter, inches	0.00034	0.00034	
33. AN - Sampling Nozzle Area, Square Feet	108.2	108.1	
34. PCT ISO - Isokinetic Sampling, Percent			

\*\*\* STP - Dry, 70 Degrees F, 29.92 Inches Hg

THE  
BOARD OF COUNTY COMMISSIONERS

ROBERT E. CURRY, CHAIRMAN  
DIST. 1, TAMPA

BOB LESTER, VICE-CHAIRMAN  
DIST. 5, RUSKIN

RUDY RODRIGUEZ, DIST. 2, TAMPA  
ELIZABETH B. CASTOR, DIST. 3, TAMPA  
CARL L. CARPENTER, JR., DIST. 4, PLANT CITY

P. O. Box 1110  
TAMPA, FLORIDA 33601

TELEPHONE: (813) 223-1311



COUNTY of HILLSBOROUGH  
*Tampa, Florida 33601*



JAMES F. TAYLOR, JR.  
CLERK

RUDY SPOTO  
COUNTY ADMINISTRATOR

ENVIRONMENTAL PROTECTION COMMISSION  
305 NORTH MORGAN STREET  
TAMPA, FLORIDA 33602

ROGER P. STEWART  
DIRECTOR

November 5, 1974

Alex Kaiser, Director  
Power Plant Engineering and  
Environmental Planning  
Tampa Electric Company  
P. O. Box 111  
Tampa, Florida 33601

Re: Stack Test Results  
Submitted on 10/10/74 for  
Gannon Unit 6, Big Bend Unit 1 and  
Hooker's Point Units 5 and 6.

Dear Mr. Kaiser:

The referenced stack tested results have indicated Hooker's Point Unit # 6 to be emitting particulate matter in excess of 5 times that of the allowable. It was mentioned that the Hooker's Point facility had begun burning a cleaner lower sulfur fuel but to date no substantiating data has been submitted to this office.

Until this data is received verifying the Hooker's Point facility to be in compliance with all State and Local regulations, we will continue to report this facility to be out of compliance with final emission requirements.

Please take appropriate action on or before December 1, 1974.

Sincerely,

A handwritten signature in cursive script, reading "Bennie J. Caramella".

Bennie J. Caramella  
Environmental Engineer  
Hillsborough County Environmental  
Protection Commission

BJC/fd

**RECEIVED**  
OCT 15 1974  
H.C.E.P.C.

103 Stockton Street  
P. O. Box 628  
Jacksonville, Fla. 32201

NOV 19 1974

SOURCE SAMPLING CALCULATIONS  
PARTICULATE EMISSIONS

## WEST CENTRAL REGION

PLANT - TECO HOOKERS POINT

STACK - UNIT NO. 6

WEATHER CONDITIONS - CLOUDY

AS' - 113.1 SQ. FEET TS - 783 DEGREES R TM - 555 DEGREES R H - 0.542 IN H2O

AH - 0.79 IN H2O AN - 0.000341 SQ FT CP - 0.85 VM - 37.44 CF VC - 80 ML

TOTAL TIME - 72 MIN NPTS - 24 ORSAT: CO2 - 9.00 O2 - 4 CO - 0 N2 87

DATE - 6/25/64

RUN J FROM 13:10 - 15:00

PS - 29.73 IN HG

1. Volume Water Vapor	1. 3.792	SC
2. Stack Gas Volume - STPD	2. 35.631	SC
3. Total Volume	3. 39.423	SC
4. Moisture in Stack Gas - Volume Fraction	4. 0.096	
5. Dry Stack Gas - Volume Fraction	5. 0.904	
6. Assumed Moisture in Stack Gas - Volume Fraction	6. 0.1	
7. Molecular Weight of Stack Gas - Dry Basis	7. 29.6	
8. Molecular Weight of Stack Gas - Stack Conditions	8. 28.46	
9. Specific Gravity of Stack Gas Relative to Air	9. 0.98	
10. Excess Air - Percent	10. 21	%
11. Average of Factor ( $\sqrt{VH \times TS}$ )	11. 15.168	
12. Average Stack Velocity	12. 2270.4	FT
13. Actual Stack Gas Flow Rate	13. 256788	ACF
14. Actual Stack Gas Flow Rate Dry	14. 232088	CF
15. Stack Gas Flow Rate - STPD	15. 156099	SC
16. Percent Isokinetic	16. 105.2	%

MG	GR/SCF	GR/ACF	MG/SCF	MG/ACF	LBS/HR
THIMBLE - 512.1	0.2213	0.1346	507.48	308.41	296.81
TOTAL 512.1	0.2213	0.1346	507.48	308.41	296.81

Comments: Operating at maximum attainable load of 70 MW  
859.4 X 10<sup>6</sup> BTU/hr heat input

Test Conducted By: A. E. Henderson & F. M. Razzetti

## SOURCE SAMPLING FIELD DATA SHEET

Plant TECO HOOKERS POINT  
 Sampling Location Unit 6 Stack  
 Date 6/25/74 Run No. 2  
 Time Start 1530 Time End 1700  
 Sampling Time/Point 3 minutes  
 DB 323 °F, WB      °F, VF @ DP      "Hg  
 Moisture 10 %, FDA     , Gas Density Factor       
 Barometric Press 29.78 "HG Stack Press 29.75 "HG  
 Weather Cloudy & Warm  
 Temp. 85 °F, W/DNW     , W/S 10  
 Sample Box No. 1 Meter Box No. 1  
 Meter ΔH@ 1.68 Pitot Corr. Factor .85  
 Nozzle Dia. 1/4 in., Probe Length 10 ft  
 Probe Heater Setting --  
 Stack Dimensions: Inside Diameter 144 in  
                             Inside Area 113.1 ft<sup>2</sup>  
                             Height      ft

Mat'l Processing Rate 70 MW  
 Final Gas Meter Reading 74.52 ft<sup>3</sup>  
 Initial Gas Meter Reading 37.72 ft<sup>3</sup>  
 Total Condensate in Impingers 66 ml  
 Moisture in Silica Gel 14 gm  
 Silica Gel Container No.      Filter No.       
 Orsat: CO<sub>2</sub> 9.0%  
           O<sub>2</sub> 4.0%  
           CO --  
           N<sub>2</sub> 87.0%  
 Excess Air     

Test Conducted by: A. E. Henderson  
                             F. M. Raggett

Remarks:       
      
    

Port and Traverse Point No.	Distance from End of Port (in.)	Clock Time	Gas Meter Reading (ft <sup>3</sup> )	Stack Velocity Head ("H <sub>2</sub> O)	Meter Orifice Press. Diff. ("H <sub>2</sub> O)		Stack Gas Temp. (°F)	Gas Sample Temp. & Dry Gas Meter (°F)		Sample Box Temp. (°F)	Last Impinger Test (°F)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
			1530									
		00	37.72									
North		03	39.0	.15	.41	.41	300	94	92			
		06	40.4	.25	.68	.68	300	94	93			
		09	41.9	.30	.80	.80	300	95	93			
		12	43.5	.30	.80	.80	300	95	93			
		15	45.2	.33	.90	.90	300	96	94			
		18	47.1	.38	1.05	1.05	300	97	94			



BEST AVAILABLE COPY

## SOURCE EMISSION TEST DATA

Test Number -  
 Plant Name -  
 Source Tested -  
 Type of Plant -  
 Control Equipment -  
 Pollutant Sampled -

1. Run Number
2. Date
3. Time Began
4. Time End
5. T - Net Time of Test, Minutes
6. PB - Barometric Pressure, Inches Hg
7. PS - Stack Pressure, Inches Hg
8.  $\Delta H$  - Gas Meter Orifice Pressure Drop, Inches H<sub>2</sub>O
9. TM - Gas Meter Average Temperature, °F
10. VC - Total H<sub>2</sub>O Collected, ml
11. VWV - Volume H<sub>2</sub>O Vapor Collected, cubic ft., STP
12. VM - Volume Dry Gas Sampled, cu. ft., Meter Cond.
13. VSTPD - Volume Dry Gas Sampled, cu. ft., STP
14. W(PCT) - Stack Gas Moisture, PCT Volume
15. TS - Average Stack Gas Temperature, °F
16. CO<sub>2</sub> - Stack Gas CO<sub>2</sub>, PCT Volume
17. O<sub>2</sub> - Stack Gas O<sub>2</sub>, PCT Volume
18. CO - Stack Gas CO, PCT Volume
19. N<sub>2</sub> - Stack Gas N<sub>2</sub>, PCT Volume
20. EA - Stack Gas Excess Air, PCT Volume
21. MD - Stack Gas Molecular Weight, Dry
22. MS - Stack Gas Molecular Weight, Stack Cond.
23. GS - Stack Gas Specific Gravity, Ref Air
24. H - Average Square Root Velocity Head, Inches H<sub>2</sub>O
25. Average Square Root (Stk Temp x Vel Head)
26. CP - Pitot Tube Correction Factor
27. U - Stack Gas Velocity, Feet/Minute
28. AS - Stack Area, Square Feet
29. AS' - Effective Stack Area, Square Feet
30. QS - Stack Gas Flow Rate, cu.ft./min., Stk Cond.
31. QSTPD - Stack Gas Flow Rate, cu.ft./min. STP
32. DN - Sampling Nozzle Diameter, inches
33. AN - Sampling Nozzle Area, Square Feet
34. PCT ISO - Isokinetic Sampling, Percent

1	2	
6/25/74	6/25/74	
13:17	13:18	
15:00	17:19	
72	72	
29.76	29.76	
29.73	29.75	
0.71	0.75	
85	85	
80	75	
3.71	3.82	
37.84	37.8	
35.631	35.142	
3.6	3.6	
323	312.5	
3	3	
4	4	
0	0	
87	87	
21.	21.	
23.6	23.6	
28.43	21.6	
0.14	0.14	
0.342	0.337	
19.28	19.71	
0.85	0.85	
2270.8	2277.6	
228.1	228.1	
223.1	223.1	
151.782	151.782	
151.782	151.782	
0.48	0.48	
0.0034	0.0034	
1.0.2	1.0.2	

\*\*\* STP - Dry, 70 Degrees F, 29.92 Inches Hg

103 Stockton Street  
P. O. Box 628  
Jacksonville, Fla. 32201

NOV 19 1974

RECEIVED

SOURCE SAMPLING CALCULATIONS

OCT 15 1974 PARTICULATE EMISSIONS

WEST CENTRAL REGION

PLANT-TECO HOOKERS POINT

STACK - UNIT NO. 6

WEATHER CONDITIONS - CLOUDY

AS' - 113.1 SQ. FEET

 $\Delta H$  - 0.75 ON H2O

TOTAL TIME - 72 MIN.

H.C.E.P.C.

TS - 782.5 DEGREES R

AN -0.000341 SQ. FT

NPTS - 24

PB- 29.78 IN HG

TM - 555 DEGREES R

CP- 0.85

VM - 36.8

ORSAT: CO2 - 9.00

02 - 4

DATE -6/25/74

RUN 2 FROM 15:30-17:00

PS - 29.75 IN HG

H - 0.528 IN H2O

CF VC - 70 ML

CO - 0 N2- 87

1. Volume Water Vapor
2. Stack Gas Volume - STPD
3. Total Volume
4. Moisture in Stack Gas - Volume Fraction
5. Dry Stack Gas - Volume Fraction
6. Assumed Moisture in Stack Gas - Volume Fraction
7. Molecular Weight of Stack Gas - Dry Basis
8. Molecular Weight of Stack Gas - Stack Conditions
9. Specific Gravity of Stack Gas Relative to Air
10. Excess Air - Percent
11. Average of Factor ( $\sqrt{VH \times TS}$ )
12. Average Stack Velocity
13. Actual Stack Gas Flow Rate
14. Actual Stack Gas Flow Rate Dry
15. Stack Gas Flow Rate - STPD
16. Percent Isokinetic

1. 3.318
2. 35.042
3. 33.36
4. 0.086
5. 0.914
6. 0.1
7. 29.6
8. 38.6
9. 0.99
10. 21.
11. 14.78
12. 2207.3
13. 249640
14. 228048
15. 153583
16. 105.1

MG	GR/SCF	GR/ACF	MG/SCF	MG/ACF	LBS/HR
THIMBLE 772.7	0.3395	0.2090	778.50	478.81	447.99
TOTAL 772.6	0.3395	0.2090	778.50	478.81	447.99

Comments: Operating at maximum attainable load of 70 MW  
859.4 X 10<sup>6</sup> BTU/hr heat input

Test Conducted By: A. E. Henderson & F. M. Raggett



## SOURCE SAMPLING FIELD DATA SHEET

Plant TECO HOOKER POINT  
 Sampling Location Unit 6 Stack  
 Date 6/25/74 Run No. 1  
 Time Start 1310 Time End 1500  
 Sampling Time/Point 3 min.  
 DB 323 °F, WB °F, VP @ DP "Hg  
 Moisture 10 %, FDA Gas Density Factor  
 Barometric Press 29.76" Hg Stack Press 29.73 "Hg  
 Weather Cloudy & Warm  
 Temp. 85 °F, W/D NW, W/S 10  
 Sample Box No. 1 Meter Box No. 1  
 Meter Alt 1.68 Pitot Corr. Factor .85  
 Nozzle Dia. 1/4 in., Probe Length 10 ft  
 Probe Heater Setting   
 Stack Dimensions: Inside Diameter 144 in  
 Inside Area 113.1 ft<sup>2</sup>  
 Height ft

Mat'l Processing Rate 70 MW  
 Final Gas Meter Reading 036.85 ft<sup>3</sup>  
 Initial Gas Meter Reading 999.41 ft<sup>3</sup>  
 Total Condensate in Impingers 70 ml  
 Moisture in Silica Gel 10.0 gm  
 Silica Gel Container No. 2 Filter No. 4 F  
 Orsat: CO<sub>2</sub> 9.0%  
 O<sub>2</sub> 4.0%  
 CO 0.0%  
 N<sub>2</sub> 87.0%  
 Excess Air

Test Conducted by: A. E. Henderson  
F. M. Raggett

Remarks:

Port and Traverse Point No.	Distance from End of Port (in.)	Clock Time	Gas Meter Reading (ft <sup>3</sup> )	Stack Velocity Head ("H <sub>2</sub> O)	Meter Orifice Press. Diff. ("H <sub>2</sub> O)		Stack Gas Temp. (°F)	Gas Sample Temp. & Dry Gas Meter (°F)		Sample Box Temp. (°F)	Last Impinger Test (°F)	Vacuum on Sample Train ("Hg)
					Calc.	Actual		In	Out			
		13:10										
	South	00	999.41									
		03	000.9	.26	.67	.67	350	89	88		.510	
		06	002.6	.38	.98	.98	350	91	89		.616	
		09	004.4	.44	1.15	1.15	350	92	89		.663	
		12	006.2	.44	1.15	1.15	350	94	90		.663	
		15	008.1	.44	1.15	1.15	350	95	91		.663	
		18	009.8	.31	0.80	.80	350	95	91		.557	

[illegible]

November 30, 1973

Mr. Roger P. Stewart, Director  
Hillsborough County Environmental  
Protection Commission  
666 Jackson Street  
Tampa, Florida 33602

*Unit No. 6  
Common*

RE: Compliance Schedule, Tampa Electric Company  
Common Station Unit No. 6  
Particulate Control  
Report No. AEP-21-1

Dear Mr. Stewart:

The fourth increment of progress (construction completion) for upgrading the particulate removal equipment on Unit No. 6 Common Station is presently set for November 30, 1973. Due to construction delays and the inability to remove this unit from service and still maintain a reliable electric supply, we have been unable to make the final tie-in between the new precipitator (which is essentially complete) and the boiler.

We now plan to remove this unit from service on December 7, 1973 to make the final tie-in. This shutdown will last for approximately twelve weeks, with the new precipitator being operational when the boiler comes back on-line.

In light of this, we would respectfully request that the date of the fourth increment of progress be moved to March 1, 1974. We anticipate that this schedule will still allow the present final compliance date of May 30, 1974 to be met.

If you have any questions, please don't hesitate to contact us.

Very truly yours,

*Alex Kaiser*

Alex Kaiser, Director  
Power Plant Engineering &  
Environmental Planning

cc: Mr. W. E. Dunne  
Regional Administrator  
Florida Department of Pollution Control

bcc: Mr. J. D. Hicks                      Mr. H. A. Moshell, Jr.  
Mr. R. D. Welch                      Mr. A. D. Jones