



Syed  
**RECEIVED**

JUN 06 2001

BUREAU OF AIR REGULATION

June 5, 2001

Mr. Clair Fancy  
Florida Department of Environmental  
Protection  
2600 Blair Stone Road  
Twin Towers Office Building  
Tallahassee, Florida 32399-2400

Via Fed Ex  
Airbill No. 7915 7699 6507

**Re: Tampa Electric Company (TEC) – Hookers Point Power Station  
Diesel Fired Internal Combustion Engine Generator Sets  
Proposed Initial NO<sub>x</sub> Compliance Testing Protocol  
FDEP Permit No. 0570038-002-AC**

Dear Mr. Fancy:

Please find enclosed the oxides of nitrogen (NO<sub>x</sub>) emissions test protocol for the Hookers Point Power Station Diesel Fired Internal Combustion Engine Generator Sets. As required by specific condition 20 of the above referenced air construction permit, TEC is required to conduct initial compliance testing for NO<sub>x</sub> on five randomly selected units.

The enclosed document describes the protocol for this testing, and TEC requests approval from the Department as soon as possible so that the testing can be scheduled and performed as outlined by the above referenced permit condition.

If you have any questions, please feel free to contact Shannon Todd or me at (813) 641-5125.

Sincerely,

Laura R. Crouch  
Manager - Air Programs  
Environmental Affairs

EPW/MSKT259

Enclosure

c/enc: Mr. Al Linero - FDEP  
Mr. Syed Arif - FDEP  
Mr. Joseph Kahn - FDEP  
Mr. Jerry Kissel - FDEP SW  
Mr. Steve Pak - EPCHC

TAMPA ELECTRIC COMPANY  
P. O. BOX 111 TAMPA, FL 33601-0111

(813) 228-4111

AN EQUAL OPPORTUNITY COMPANY  
HTTP://WWW.TECOENERGY.COM

CUSTOMER SERVICE:  
HILLSBOROUGH COUNTY (813) 223-0800  
OUTSIDE HILLSBOROUGH COUNTY 1 (888) 223-0800

**NO<sub>x</sub> Emission Test Protocol  
For  
Ringhaver – Caterpillar Power  
Diesel Fired Internal Combustion Engine Generator Sets  
At**

**Hookers Point Station**

**Tampa, Florida**



**TAMPA ELECTRIC**

**Prepared for  
Tampa Electric Company  
By  
Environmental Affairs  
Of  
Tampa Electric Company**

**June 5, 2001**

## **Introduction**

As required by the Florida Department of Environmental Protection (FDEP) air construction permit (ARMS 0570038-002-AC), Tampa Electric Company (TEC) is planning to perform NO<sub>x</sub> emissions testing on five (5) randomly selected Ringhaver Caterpillar diesel fired internal combustion engine generator sets, for the purpose of determining initial compliance. Each engine will be tested using United States Environmental Protection Agency (USEPA) Reference Method 7E – Determination of Nitrogen Oxides Emissions from Stationary Sources (Instrumental Analyzer Procedure). As stated in specific condition 20 of the permit and under Rule 62-297.310 (7)(a)1., F.A.C.:

*“Initial performance tests to demonstrate compliance with the emission standards specified in this permit shall be conducted within 60 days after achieving at least 90% of permitted capacity, but not later than 180 days after initial operation of the emissions unit.”*

Using the certified flow test data from the manufacturer in conjunction with the measured NO<sub>x</sub> concentrations, the NO<sub>x</sub> emission rate in pounds per hour will be calculated and compared to the limit of 53 pounds of NO<sub>x</sub> emitted per hour.

Submission of this document ensures that the Department is provided with the test protocol, including a time schedule, 15 days prior to the initial test. Tampa Electric Company will provide the Department with the emissions test results 45 days after the test is performed. The Department shall be notified and the reasons provided if a scheduled test is delayed or canceled.

## **Facility Description**

Source: Hookers Point Station consists of six oil-fired boilers (units 1 through 6) that are fired with No. 6 fuel oil. The total generation of these boilers is 227 megawatts. In addition, thirty Caterpillar XQ2000 Power Modules are installed with a total generation capacity of 54.75 megawatts. Each Power Module consists of a Caterpillar 3516B 16-cylinder, 4-stroke cycle diesel internal combustion engine and a Caterpillar SR4B generator. The Caterpillar engine has a power rating of 2,593 brake horsepower (bhp) at 100 percent load. The Caterpillar SR4B generator has a power output rating of 1,825 kilowatts at 100 percent load. Each IC engine will be fired exclusively with low-sulfur diesel fuel oil.

**Location:** Hookers Point Station is located at 1700 Hemlock Street, Tampa, in Hillsborough County Florida. UTM Coordinates, Zone 17, 358.0 km East and 3091.0 km North.

**Regulation:** Acid Rain provisions of the Clean Air Act, Title V major source of air pollution and PSD major source.

**Test Coordinator:** Air Services- Environmental Affairs  
Tampa Electric Company

### **Proposed Testing Schedule**

The final testing schedule is yet to be determined based on unit operation, resource availability, equipment availability, and approval of this testing protocol by the Department. Once begun, testing will continue on all five units for a period of at least 3 days and no more than 5 days until completed. Upon finalizing the testing schedule, TEC will notify the Department at least 15 days prior to the test.

### **Testing Protocol**

- 1) Gaseous Emission Test Matrix & Gas Sample Strategy
  - A) Three test runs will be performed with each unit operating at maximum load. The average of the three runs will be used for reporting purposes.
  - B) Gaseous emission test runs will be measured at the exhaust outlet of the engine for a minimum of 1 hour in duration.
  
- 2) Turbine Exhaust Gas Measurements – A transportable laboratory grade analyzer system (see enclosed diagram) will be used with continuous monitors capable of measuring NO<sub>x</sub> emissions. The analyzer and system will be calibrated in the field and QA/QC procedures will be performed as required by the EPA test method. Following initial calibrations of the equipment, a sample of exhaust gas will be continuously extracted from the exhaust stack and delivered to the individual analyzer at the same flow rate as used for instrument calibration. The results of these measurements will be recorded on a portable personal computer to document the sample analysis, calibrations and quality assurance activities conducted during the tests. All results are stored on the hard drive and printed on a dot matrix printer.
  - A) EPA Method 7-E for NO<sub>x</sub>  
NO<sub>x</sub> will be measured using a Thermo Environmental 42 CHL NO/NO<sub>x</sub> analyzer that uses the measurement technique of chemiluminescence. The NO<sub>x</sub> concentration is also measured on a dry basis. The measurement range of the analyzer will be

determined such that the pollutant gas concentration is not less than the instrument span.

3) Gaseous Samples Quality Assurance/Quality Control

- A) Zero and span calibration drift checks before and after each test run. Test run validated by  $\pm 3\%$  drift from full scale response. Emission concentration measurements corrected for zero and span drift.
- B) NO<sub>x</sub> analyzer NO<sub>2</sub> to NO converter efficiency check results to verify a minimum 90% converter efficiency.
- C) Calibration gases traceable to EPA Protocol 1 and the National Institute of Standards and Technology.
- D) Multi-point instrument calibration error test  $\pm 2\%$  linearity check.
- E) Interference response test of the analyzer prior to it's initial use in the field.
- F) Sample system bias check before each series of tests to  $\pm 5\%$  of span.
- G) All sampling and analysis conducted on site with on-site results.

In accordance with specific condition 17 (enclosed) of the governing air construction permit, TEC requests that the Department provide written approval to move forward with the initial compliance testing as soon as possible.




FIGURE 1

USEPA METHODS 3A, 6C, 7E CEM SYSTEM LAYOUT

**TECO**  
TAMPA ELECTRIC

### SECTION III. EMISSIONS UNIT SPECIFIC CONDITIONS

---

method for visible emissions shall be EPA Method 9, incorporated and adopted by reference in Chapter 62-297, F.A.C. Test procedures shall meet all applicable requirements of Chapter 62-297, F.A.C. [Rule 62-296.320(4)(b)1, F.A.C.]

#### EXCESS EMISSIONS

9. Excess Emissions Prohibited: Excess emissions caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure that may reasonably be prevented during startup, shutdown or malfunction, shall be prohibited. [Rule 62-210.700(4), F.A.C.]
10. Excess Emissions Allowed: Providing the permittee adheres to best operational practices to minimize the amount and duration of excess emissions, the following conditions shall apply:
  - (a) During startup and shutdown, visible emissions shall not exceed 20% opacity for up to 2 hours in any 24-hour period. [Design; Rule 62-210.700(1), F.A.C.]

#### OPERATIONAL LIMITATIONS

11. Fuel Oil Specification: Only No. 2 fuel oil can be fired in the internal combustion engines. The maximum sulfur content of the No. 2 fuel oil shall not exceed 0.05 percent, by weight. [Rule 62-210.200, F.A.C. (Definitions – PTE)]
12. Fuel Oil Consumption: The maximum No. 2 fuel oil allowed to be burned in thirty internal combustion engines combined is 3,180,152 gallons per year, which is equivalent to 25,897 engine-hours per year at 100% load. [Rule 62-210.200, F.A.C. (Definitions – PTE)]
13. Permitted Capacity: The heat input to each internal combustion engine from firing No. 2 fuel oil shall not exceed 17 MMBtu per hour at 100% load. [Design, Rule 62-210.200, F.A.C. (Definition - PTE)]
14. Hours of Operation: The thirty internal combustion engines shall operate no more than 25,897 engine-hours during any consecutive 12-month period. The permittee shall install, calibrate, operate and maintain a monitoring system to measure the hours of operation on each internal combustion engine. [Rule 62-210.200, F.A.C. (Definitions - PTE)]
15. Operational Period: The thirty internal combustion engines shall cease operation in June 2003. [Applicant Request]

#### EMISSIONS PERFORMANCE TESTING

16. Sampling Facilities: The permittee shall design the internal combustion engine stack to accommodate adequate testing and sampling locations in order to determine compliance with the applicable emission limits specified by this permit. [Rule 62-297.310(6), F.A.C.]
17. Performance Test Methods: Initial (I) and Annual (A) compliance tests shall be performed in accordance with the following reference methods as described in 40 CFR 60, Appendix A, and adopted by reference in Chapter 62-204.800, F.A.C.
  - (a) EPA Method 7 or 7E – Determination of Nitrogen Oxide Emissions from Stationary Sources (I, A);
  - (b) EPA Method 9 - Visual Determination of the Opacity of Emissions from Stationary Sources (I, A);

No other test methods may be used for compliance testing unless prior DEP approval is received, in writing, from the DEP Emissions Monitoring Section Administrator in accordance with an alternate sampling procedure specified in Rule 62-297.620, F.A.C.

### SECTION III. EMISSIONS UNIT SPECIFIC CONDITIONS


---

18. Fuel Oil Monitoring: The fuel shall be monitored initially and annually for the sulfur content using ASTM D4294 Method (or equivalent). The permittee shall also maintain daily records of fuel oil consumption for the emission units. [Rules 62-297.440, F.A.C., and 62-210.200, F.A.C.]
19. Test Notification: The permittee shall notify the Compliance Authority in writing at least 15 days prior to the date on which each formal compliance test is to begin, of the date, time, and place of each such test, and the test contact person who will be responsible for coordinating and having such test conducted for the owner or operator. [Rule 62-297.310(7)(a)9., F.A.C.]
20. Initial Tests Required: Initial performance tests to demonstrate compliance with the emission standards specified in this permit shall be conducted within 60 days after achieving at least 90% of permitted capacity, but not later than 180 days after initial operation of the emissions unit. Initial performance tests shall be conducted for NO<sub>x</sub> and visible emissions on one of the internal combustion engines. [Rule 62-297.310(7)(a)1., F.A.C.]
21. Annual Performance Tests: To demonstrate compliance with the emission standards specified in this permit, the permittee shall conduct annual performance tests for NO<sub>x</sub> and visible emissions on the emission units that operated for more than 400 hours in the preceding 12-month period. Tests required on an annual basis shall be conducted at least once during each federal fiscal year (October 1<sup>st</sup> to September 30<sup>th</sup>). [Rule 62-297.310(7)(a)4., F.A.C.]
22. Tests Prior to Permit Renewal: Prior to renewing the air operation permit, the permittee shall conduct performance tests for NO<sub>x</sub> and visible emissions on one of the internal combustion engines. These tests shall be conducted within the 12-month period prior to renewing the air operation permit. For pollutants required to be tested annually, the permittee may submit the most recent annual compliance test to satisfy the requirements of this provision. [Rule 62-297.310(7)(a)3., F.A.C.]
23. Internal Combustion Engine Testing Capacity: Performance tests for compliance with standards specified in this permit shall be conducted with the emission unit operating at permitted capacity. Permitted capacity is defined as 90-100 percent of the maximum heat input rate allowed by the permit. If it is impracticable to test at permitted capacity, the source may be tested at less than permitted capacity. However, subsequent operation is limited to 110 percent of the value reached during the test until a new test is conducted. Once the unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purposes of additional compliance testing to regain the permitted capacity. Emissions performance tests shall meet all applicable requirements of Chapters 62-204 and 62-297, F.A.C. [Rule 62-297.310(2), F.A.C.]
24. Calculation of Emission Rate: For each emissions performance test, the indicated emission rate or concentration shall be the arithmetic average of the emission rate or concentration determined by each of the three separate test runs unless otherwise specified in a particular test method or applicable rule. [Rule 62-297.310(3), F.A.C.]
25. Applicable Test Procedures
  - (a) Required Sampling Time.
    1. Unless otherwise specified in the applicable rule, the required sampling time for each test run shall be no less than one hour and no greater than four hours, and the sampling time at each sampling point shall be of equal intervals of at least two minutes. [Rule 62-297.310(4)(a)1., F.A.C.]
    2. The minimum observation period for a visible emissions compliance test shall be thirty (30) minutes. The observation period shall include the period during which the highest opacity can reasonably be expected to occur. [Rule 62-297.310(4)(a)2., F.A.C.]

PLEASE FOLD THIS SHIPPING DOCUMENT IN HALF AND PLACE IT IN A WAYBILL POUCH AFFIXED TO YOUR SHIPMENT SO THAT THE BAR-CODE PORTION OF THE LABEL CAN BE READ AND SCANNED.  
\*\*\*WARNING: USE ONLY THE PRINTED ORIGINAL LABEL FOR SHIPPING. USING A PHOTOCOPY OF THIS LABEL FOR SHIPPING PURPOSES IS FRAUDULENT AND COULD RESULT IN ADDITIONAL BILLING CHARGES, ALONG WITH THE CANCELLATION OF YOUR FEDEX ACCOUNT NUMBER.

FROM: Gina Morales (813)641-5036  
Tampa Electric Company  
6944 U.S. Highway 41 North  
Apollo Beach, FL 33572

SHIPPER'S FEDEX ACCOUNT NUMBER



TO: Mr. Clair Fancy (850)488-1344  
Fla. Dept. of Env. Protection  
111 S. Magnolia Dr.  
Ste. 4

SHIP DATE: 22JAN01  
MAN-WGT: 1 LBS

REF: Tallahassee, FL 32301-  
445-506-68-18-369



DELIVERY ADDRESS BARCODE (FEDEX-EDR)

CAD # 3093289

**PRIORITY OVERNIGHT**

**TUE**  
AA


TRK # 7904 5117 9175 FORM 0201

TLH

Deliver By:  
23JAN01

32301-FL-US

**XB TLHA**



**RECEIVED**

JAN 23 2001

BUREAU OF AIR REGULATION

U.S. Postal Service  
**CERTIFIED MAIL RECEIPT**  
 (Domestic Mail Only; No Insurance Coverage Provided)

**OFFICIAL USE**

7000 2870 0000 7028 2911

Postage	\$	Postmark Here
Certified Fee		
Return Receipt Fee (Endorsement Required)		
Restricted Delivery Fee (Endorsement Required)		
<b>Total Postage &amp; Fees</b>	<b>\$</b>	

**Sent To** Karen Sheffield  
 Street, Apt. No.; or PO Box No.  
 PO Box 111  
 City, State, ZIP+4  
 Tampa, FL 33601-0111

PS Form 3800, May 2000 See Reverse for Instructions

**SENDER: COMPLETE THIS SECTION**


- Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1 Article Addressed to:

Ms. Karen Sheffield  
 General Manager  
 Gannon Power Station  
 Tampa Electric Company  
 P. O. Box 111  
 Tampa, FL 33601-0111

2 Article Number (Copy from service label)  
 7000 2870 0000 7028 2911

**COMPLETE THIS SECTION ON DELIVERY**

A. Received by (Please Print Clearly) B. Date of Delivery  
 C. Signature  11-26-01  
 Agent  
 Addressee  
 D. Is delivery address different from item 1?  Yes  
 If YES, enter delivery address below:  No

3. Service Type  
 Certified Mail  Express Mail  
 Registered  Return Receipt for Merchandise  
 Insured Mail  C.O.D.

4. Restricted Delivery? (Extra Fee)  Yes

UNITED STATES POSTAL SERVICE



First-Class Mail  
Postage & Fees Paid  
USPS  
Permit No. G-10

• Sender: Please print your name, address, and ZIP+4 in this box •

RECEIVED

NOV 28 2001

BUREAU OF AIR REGULATION

Dept. of Environmental Protection  
Division of Air Resources Mgt.  
Bureau of Air Regulation, NSR  
2600 Blair Stone Rd., MS 5505  
Tallahassee, FL 32399-2400





Jeb Bush  
Governor

# Department of Environmental Protection

Marjory Stoneman Douglas Building  
3900 Commonwealth Boulevard  
Tallahassee, Florida 32399-3000

David B. Struhs  
Secretary

November 20, 2001

CERTIFIED MAIL - RETURN RECEIPT REQUESTED

Ms. Karen Sheffield, General Manager  
Gannon Power Station  
Tampa Electric Company  
Post Office Box 111  
Tampa, Florida 33601-0111

Re: Extension Request – Hookers Point Station IC Engines  
DEP File No. 0570038-002-AC

Dear Ms. Sheffield:

The Department reviewed your request dated October 18, 2001 for an extension of the expiration date of the referenced air construction permit to install thirty (30) diesel IC engines at the Hookers Point Station in Hillsborough County.

For construction permits, an extension shall be granted if the applicant can demonstrate that, upon completion, the extended permit will comply with the standards and conditions required by the applicable regulations. [Rule 62-4.080(3), F.A.C.]

The construction is complete and the compliance test on five IC engines was conducted as required by the construction permit. The initial emissions performance test demonstrated that the IC engines were operating in compliance with permit limits for NO<sub>x</sub> and visible emissions. The permit extension is sought to file a Title V air operation permit revision application to include the new IC engines. The expiration date is hereby extended from December 1, 2001 to March 1, 2002 to allow sufficient time for submission of the Title V Operation Permit Application.

A copy of this letter shall be filed with the referenced permit and shall become part of the permit. This permitting decision is issued pursuant to Chapter 403, Florida Statutes.

A person whose substantial interests are affected by the proposed permitting decision may petition for an administrative proceeding (hearing) under sections 120.569 and 120.57 of the Florida Statutes. The petition must contain the information set forth below and must be filed (received) in the Office of General Counsel of the Department at 3900 Commonwealth Boulevard, Mail Station #35, Tallahassee, Florida, 32399-3000. Petitions filed by the permit applicant or any of the parties listed below must be filed within fourteen days of receipt of this notice of intent. Petitions filed by any persons other than those entitled to written notice under section 120.60(3) of the Florida Statutes must be filed within fourteen days of publication of the public notice or within fourteen days of receipt of this notice of intent, whichever occurs first. Under section 120.60(3), however, any person who asked the Department for notice of agency action may file a petition within fourteen days of receipt of that notice, regardless of the date of publication. A petitioner shall mail a copy of the petition to the applicant at the address indicated above at the time of filing. The failure of any person to file a petition within the appropriate time period shall constitute a waiver of that person's right to request an administrative determination (hearing) under

*"More Protection, Less Process"*

*Printed on recycled paper.*

sections 120.569 and 120.57 F.S., or to intervene in this proceeding and participate as a party to it. Any subsequent intervention will be only at the approval of the presiding officer upon the filing of a motion in compliance with Rule 28-106.205 of the Florida Administrative Code.

A petition that disputes the material facts on which the Department's action is based must contain the following information: (a) The name and address of each agency affected and each agency's file or identification number, if known; (b) The name, address, and telephone number of the petitioner, the name, address, and telephone number of the petitioner's representative, if any, which shall be the address for service purposes during the course of the proceeding; and an explanation of how the petitioner's substantial interests will be affected by the agency determination; (c) A statement of how and when petitioner received notice of the agency action or proposed action; (d) A statement of all disputed issues of material fact. If there are none, the petition must so indicate; (e) A concise statement of the ultimate facts alleged, including the specific facts the petitioner contends warrant reversal or modification of the agency's proposed action; (f) A statement of the specific rules or statutes the petitioner contends require reversal or modification of the agency's proposed action; and (g) A statement of the relief sought by the petitioner, stating precisely the action petitioner wishes the agency to take with respect to the agency's proposed action.

A petition that does not dispute the material facts upon which the Department's action is based shall state that no such facts are in dispute and otherwise shall contain the same information as set forth above, as required by Rule 28-106.301.

Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the Department's final action may be different from the position taken by it in this notice. Persons whose substantial interests will be affected by any such final decision of the Department on the application have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above. Mediation is not available in this proceeding.

In addition to the above, a person subject to regulation has a right to apply for a variance from or waiver of the requirements of particular rules, on certain conditions, under Section 120.542 F.S. The relief provided by this state statute applies only to state rules, not statutes, and not to any federal regulatory requirements. Applying for a variance or waiver does not substitute or extend the time for filing a petition for an administrative hearing or exercising any other right that a person may have in relation to the action proposed in this notice of intent.

The application for a variance or waiver is made by filing a petition with the Office of General Counsel of the Department, 3900 Commonwealth Boulevard, Mail Station #35, Tallahassee, Florida 32399-3000. The petition must specify the following information: (a) The name, address, and telephone number of the petitioner; (b) The name, address, and telephone number of the attorney or qualified representative of the petitioner, if any; (c) Each rule or portion of a rule from which a variance or waiver is requested; (d) The citation to the statute underlying (implemented by) the rule identified in (c) above; (e) The type of action requested; (f) The specific facts that would justify a variance or waiver for the petitioner; (g) The reason why the variance or waiver would serve the purposes of the underlying statute (implemented by the rule); and (h) A statement whether the variance or waiver is permanent or temporary and, if temporary, a statement of the dates showing the duration of the variance or waiver requested.

The Department will grant a variance or waiver when the petition demonstrates both that the application of the rule would create a substantial hardship or violate principles of fairness, as each of those terms is defined in Section 120.542(2) F.S., and that the purpose of the underlying statute will be or has been achieved by other means by the petitioner.

Persons subject to regulation pursuant to any federally delegated or approved air program should be aware that Florida is specifically not authorized to issue variances or waivers from any requirements of any such federally delegated or approved program. The requirements of the program remain fully enforceable by the Administrator of the EPA and by any person under the Clean Air Act unless and until the Administrator separately approves any variance or waiver in accordance with the procedures of the federal program.

This permitting decision is final and effective on the date filed with the clerk of the Department unless a petition is filed in accordance with the above paragraphs or unless a request for extension of time in which to file a petition is filed within the time specified for filing a petition pursuant to Rule 62-110.106, F.A.C., and the petition conforms to the content requirements of Rules 28-106.201 and 28-106.301, F.A.C. Upon timely filing of a petition or a request for extension of time, this order will not be effective until further order of the Department.

Any party to this permitting decision (order) has the right to seek judicial review of it under section 120.68 of the Florida Statutes, by filing a notice of appeal under Rule 9.110 of the Florida Rules of Appellate Procedure with the clerk of the Department of Environmental Protection in the Office of General Counsel, Mail Station #35, 3900 Commonwealth Boulevard, Tallahassee, Florida, 32399-3000, and by filing a copy of the notice of appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal. The notice must be filed within thirty days after this order is filed with the clerk of the Department.

Executed in Tallahassee, Florida.



Howard L. Rhodes, Director  
Division of Air Resources  
Management


**CERTIFICATE OF SERVICE**

The undersigned duly designated deputy agency clerk hereby certifies that this PERMIT MODIFICATION was sent by certified mail (\*) and copies were mailed by U.S. Mail before the close of business on 11/21/01 to the person(s) listed:

Karen Sheffield, TECO\*  
Bill Thomas, DEP SWD  
A. Harmon, EPCHC  
Shannon Todd, TECO

Clerk Stamp

**FILING AND ACKNOWLEDGMENT FILED**, on this date, pursuant to §120.52, Florida Statutes, with the designated Department Clerk, receipt of which is hereby acknowledged.

  
(Clerk)

11/21/01  
(Date)



TAMPA ELECTRIC

RECEIVED

OCT 22 2001

BUREAU OF AIR REGULATION

October 18, 2001

Mr. Clair Fancy, P.E., Chief  
Bureau of Air Regulation  
Florida Department of Environmental Protection  
111 South Magnolia Drive, Suite 4  
Tallahassee, Florida 32301

Via FedEx  
Airbill No. 7924 5905 8568

Re: Tampa Electric Company  
Hookers Point Station Internal Combustion Engines  
Final Permit No. 0570038-002-AC

Dear Mr. Fancy:

Final Permit No. 0570038-002-AC was issued to Tampa Electric Company (TEC) on April 20, 2001 authorizing the installation and initial operation of thirty (30) diesel internal combustion (IC) engines at its Hookers Point Station in Tampa, Hillsborough County. Final Permit No. 0570038-002-AC expires on December 1, 2001.

As required by Final Permit No. 0570038-002-AC, Section III., Condition No. 20, initial performance testing of five IC engines was conducted during July 16 – 19, 2001. The initial emissions performance testing demonstrated that the IC engines were operating in compliance with permit limits for nitrogen oxides (NO<sub>x</sub>) and visible emissions. A report of the initial performance testing was submitted to the Department on August 21, 2001.

Operation of the Hookers Point Station is currently authorized by Title V Final Permit No. 0570038-001-AV. Final Permit No. 0570038-001-AV was issued with an effective date of January 1, 1998 and expires on January 1, 2003. TEC plans to file a Title V air operation permit revision application to include the new IC engines during the week of October 22<sup>nd</sup>. Because issuance of a revised Title V permit is expected to take place after the December 1, 2001 expiration date of Final Permit No. 0570038-002-AC, TEC requests an extension of the expiration date to March 1, 2002. This extension will allow an adequate amount of time for Department and EPA processing of the Title V permit revision application.

Mr. Clair Fancy  
October 19, 2001  
Page 2 of 2

If you have any questions, please contact Shelly Castro (813) 641-5033.

Sincerely,



Karen Sheffield  
General Manager  
Gannon Power Station

EA/br/SSC102

Enclosure

c: J. Kissel, SWD  
J. Campbell, EPCHC  
A. Harman, EPCHC  
S. Arif, FDEP



RECEIVED

OCT 22 2001

BUREAU OF AIR REGULATION

October 18, 2001

Mr. Clair Fancy, P.E., Chief  
Bureau of Air Regulation  
Florida Department of Environmental Protection  
111 South Magnolia Drive, Suite 4  
Tallahassee, Florida 32301

Via FedEx  
Airbill No. 7924 5905 8568

**Re: Tampa Electric Company  
Hookers Point Station Internal Combustion Engines  
Final Permit No. 0570038-002-AC**

Dear Mr. Fancy:

Final Permit No. 0570038-002-AC was issued to Tampa Electric Company (TEC) on April 20, 2001 authorizing the installation and initial operation of thirty (30) diesel internal combustion (IC) engines at its Hookers Point Station in Tampa, Hillsborough County. Final Permit No. 0570038-002-AC expires on December 1, 2001.

As required by Final Permit No. 0570038-002-AC, Section III., Condition No. 20, initial performance testing of five IC engines was conducted during July 16 – 19, 2001. The initial emissions performance testing demonstrated that the IC engines were operating in compliance with permit limits for nitrogen oxides (NO<sub>x</sub>) and visible emissions. A report of the initial performance testing was submitted to the Department on August 21, 2001.

Operation of the Hookers Point Station is currently authorized by Title V Final Permit No. 0570038-001-AV. Final Permit No. 0570038-001-AV was issued with an effective date of January 1, 1998 and expires on January 1, 2003. TEC plans to file a Title V air operation permit revision application to include the new IC engines during the week of October 22<sup>nd</sup>. Because issuance of a revised Title V permit is expected to take place after the December 1, 2001 expiration date of Final Permit No. 0570038-002-AC, TEC requests an extension of the expiration date to March 1, 2002. This extension will allow an adequate amount of time for Department and EPA processing of the Title V permit revision application.

Mr. Clair Fancy  
October 19, 2001  
Page 2 of 2

If you have any questions, please contact Shelly Castro (813) 641-5033.

Sincerely,



Karen Sheffield  
General Manager  
Gannon Power Station

EA/br/SSC102

Enclosure

c: J. Kissel, SWD  
J. Campbell, EPCHC  
A. Harman, EPCHC  
S. Arif, FDEP



RECEIVED

FEB 07 2001

BUREAU OF AIR REGULATION

February 6, 2001

Mr. A.A. Linero  
New Source Review Section  
Bureau of Air Regulation  
Florida Department of Environmental Protection  
111 South Magnolia Avenue, Suite 4  
Tallahassee, FL 32301

Via FedEx  
Airbill No. 7904 6459 9513

**Re: Request for Additional Information  
DEP File No. 0570038-002-AC  
Hookers Point Station - Installation of 30 Internal Combustion Engines**

Dear Mr. Linero:

Tampa Electric Company has received your letter dated January 30, 2001 regarding the above referenced project and offers the following responses to the issues raised by the Department:

**FDEP Issue 1**

Page 14 of the application requests 8,760 hours per year operation for the referenced internal combustion engines. Based on full time operation of the engines, the facility will not have enough offsets available, specifically for NO<sub>x</sub>, to remain below the PSD significant emission rate thresholds for major modification. If the intent of the project is to limit the hours of operation of the thirty internal combustion engines, then resubmit the maximum operating schedule and recalculate emissions for all the affected pollutants.

**TEC Response 1**

*Section III, Emissions Unit Information, of the application provides information for each of the proposed internal combustion (IC) engines. To provide flexibility in operation of the IC engines, a Hookers Point Station facility-wide cap on NO<sub>x</sub> emissions of 682.4 tons per year was proposed. Under this approach, each IC engine could operate up to 8,760 hr/yr as long as the cap was not exceeded. As shown on the potential emission inventory worksheet, all 30 IC engines could not operate concurrently for a full 8,760 hr/yr and still remain below the facility-wide NO<sub>x</sub> emissions cap. Assuming the existing Hookers Point Station Units 1 through 6 do not operate, the 30 IC engines would be limited to a total of 25,897 engine-hours or approximately ten percent of the total available engine-hours. This operating limit is equivalent to 863 hr/yr/engine, assuming all thirty engines operate for the same amount of time. NO<sub>x</sub> was selected for the facility-wide cap because NO<sub>x</sub> is the predominant pollutant emitted by the IC engines and because existing Units 1 through 6 are equipped with NO<sub>x</sub> continuous emissions monitoring systems (CEMS). Compliance with the facility-wide station NO<sub>x</sub> cap will ensure that the remaining PSD pollutants do not*

*exceed their significant net emission increase thresholds. Assuming 863 hr/yr/engine, total IC engine emissions (for all 30 engines) are 12.6 tpy (for CO and VOC), 13.6 tpy (for SO<sub>2</sub>), and 6.2 tpy (for PM/PM<sub>10</sub>). These rates are well below the levels that would trigger PSD review as a major modification.*

*TEC understands that the Department would prefer to have the operating constraint on the IC engines expressed in annual engine-hours, rather than a facility-wide NO<sub>x</sub> cap, in order to provide reasonable assurance that emissions of the remaining PSD pollutants will remain below the significant net emission increase thresholds. Because TEC wishes to retain the option to operate existing Units 1 through 6 in the future, a limit on total IC engine operations of 25,897 engine-hours would need to include a permit condition allowing for commensurate operation of existing Units 1 through 6 in the event total IC engine annual operating hours were less than the 25,897 engine-hours limit in any particular 12-month period.*

*Based on the IC engine electrical generation rate of 1.825 megawatts (MW) per engine, IC engine NO<sub>x</sub> emissions are 28.88 lb/MW-hr. The average 1998/1999 electrical generation for the Hookers Point Station existing Units 1 through 6 is 186,923 MW-hr/yr. 1998/1999 average emission rates for the existing units are calculated to be 6.87 lb/MW-hr (for NO<sub>x</sub>), 0.47 lb/MW-hr (for CO), 16.32 lb/MW-hr (for SO<sub>2</sub>), 2.06 lb/MW-hr (for PM/PM<sub>10</sub>), and 0.08 lb/MW-hr (for VOC). Because the NO<sub>x</sub> emission rate of existing Units 1 through 6 is 23.8 percent of the IC engine rate on a lb/MW-hr basis, TEC proposes the following:*

- (1) IC engine operations (for all 30 engines) be limited to a total of 25,897 engine-hours and 47,262 MW-hr/yr; and*
- (2) For each 12-month period that the IC engines operate below 47,262 MW-hr/yr, existing Units 1 through 6 may generate 4.20 MW-hr/yr for each MW-hr/yr that the IC engines are below 47,262 MW-hr/yr. In any 12-month period, existing Units 1 through 6 may not generate more than 186,923 MW-hr/yr [equal to the 1998/1999 average].*

*Due to the added complexity of tracking and calculating emissions on a lb/MW-hr/yr basis, TEC requests that the Department give additional consideration to the original proposal of a facility-wide NO<sub>x</sub> cap. Compliance with the facility-wide NO<sub>x</sub> cap can be verified easily using the existing Unit 1 through 6 NO<sub>x</sub> CEMS and run-time meters for the IC engines. Assurance that emissions of the remaining PSD pollutants do not exceed the significant net emission rate increase thresholds is provided by evaluating maximum IC engine emission rates for these pollutants while operating under the facility-wide NO<sub>x</sub> cap.*

#### **FDEP Issue 2**

If available, please provide emissions data for the six boilers for the year 2000. Also, provide the operating hours history for all six boilers. Please explain the reasons for the pollutant emissions, specifically NO<sub>x</sub> and SO<sub>2</sub>, to be high in 1999 for boilers number 3, 4, 5 and 6 as compared to other years.

Mr. A.A. Linero  
Page 3 of 3  
February 6, 2001

**TEC Response 2**

*The final emissions data for the year 2000 will not be available until mid February 2001. Emissions of NO<sub>x</sub> and SO<sub>2</sub> during 1999 were higher than those in 1998 due to normal demand and weather related increases in electrical generation during 1999.*

**FDEP Issue 3**

The Caterpillar Diesel Generator Set Performance Data as submitted with the application indicates that the diesel engine NO<sub>x</sub> emission limit in California is 6.9 g/hp-hr whereas for this project an emission limit of 9.22 g/hp-hr is being proposed. Please indicate if the California emission limit is established with some add-on controls. If not, then why is the same limit not proposed for this project.

**TEC Response 3**

*The California NO<sub>x</sub> emission limit was not established with add on controls. Rather, the limit is a composite of NO<sub>x</sub> emission rates tested at 25%, 50%, 75%, and 100% load. The proposed units to be sited at Hooker's Point will only run at 100% load, so in an effort to be conservative, the NO<sub>x</sub> emission rate at 100% load was used to calculate the potential annual emissions.*

TEC appreciates the opportunity to comment on these issues and understands that the satisfaction of these issues will allow the Department to continue processing the application. If you have questions, please feel free to call Shannon Todd or me at (813) 641-5125.

Sincerely,



Darryl Scott  
General Manager  
Hookers Point Station

EP\gm\SKT231

c: J. Kissel, SWD  
J. Campbell, EPCHC  
A. Harman, EPCHC  
S. Arif, FDEP

**RECEIVED**  
FEB 07 2001  
BUREAU OF AIR REGULATION

*AK*



TAMPA ELECTRIC

RECEIVED

AUG 22 2001

BUREAU OF AIR REGULATION

August 21, 2001

Mr. Clair Fancy  
Florida Department of Environmental Protection  
111 South Magnolia Drive, Suite 4  
Tallahassee, Florida 32301

Via Fed Ex  
Airbill No. 7909 5206 3655

**Re: Tampa Electric Company  
Hookers Point Station  
Temporary Mobile Generation Project - Initial Compliance Test Report Submittal  
FDEP File No. 0570038-002-AC**

Dear Mr. Fancy:

Please find enclosed the above referenced initial compliance test report for five randomly selected Caterpillar XQ2000 Power Modules located at Hookers Point Station. Each unit was tested for emissions of oxides of nitrogen and visible emissions between July 16, 2001 and July 19, 2001. Based on the emissions limits found in the air construction permit, each unit is operating in compliance with its respective emission limit for oxides of nitrogen and visible emissions.

If you have any questions, please telephone Shannon Todd or me at (813) 641-5125.

Sincerely,

*Laura R. Crouch*

Laura R. Crouch  
Manager - Air Programs  
Environmental Affairs

EP\gm\SKT272

Enclosure

c/enc: Jerry Campbell, EPCHC  
Joseph Kahn, FDEP  
Syed Arif, FDEP  
Bill Proses, FDEP - SWD

*Patty - To  
Tampa Electric  
Hookers Pt project  
file -  
al*

AR

**EMISSIONS TEST REPORT  
OXIDES OF NITROGEN  
JULY 16-19, 2001  
HOOKERS POINT STATION  
DIESEL COMBUSTION ENGINE GENERATOR SETS  
UNITS 26 - 30**

Prepared For:  
Tampa Electric Company

Prepared By:  
Environmental Affairs Department  
of  
Tampa Electric Company



Environmental Services  
Air Services Group  
5010 Causeway Boulevard  
Tampa, Florida 33619-6130

**EMISSIONS TEST REPORT  
OXIDES of NITROGEN  
JULY 16-19, 2001  
TAMPA ELECTRIC COMPANY  
HOOKERS POINT STATION  
FACILITY ID NUMBER: 0570038  
UNITS 26 - 30**

Prepared For:  
Tampa Electric Company  
Hookers Point Power Station  
1700 Hemlock Street  
Tampa, Florida 33601

**RECEIVED**

**AUG 22 2001**

**BUREAU OF AIR REGULATION**

Prepared By:  
Tampa Electric Company  
Environmental Affairs Department  
Environmental Services, Air Services Group

## REPORT CERTIFICATION

---

I have reviewed the test performance, the resulting calculations, and contents of this report, and verified that all project quality objectives have been met.

Date 8/15/2001 Signature 

Senior Environmental Technician  
Quality Assurance/Quality Control Specialist  
Air Services  
Environmental Affairs  
Tampa Electric Company

The sampling, analysis and calculations performed for this report were carried out under my direction. I have reviewed the results of this test report and I hereby certify that this test report is authentic and accurate to the best of my knowledge.

Date 8/15/01 Signature 

Coordinator – Air Services  
Environmental Services  
Environmental Affairs  
Tampa Electric Company

## TABLE OF CONTENTS

---

<u>SECTION</u>	<u>PAGE NO.</u>
1.0 SUMMARY OF RESULTS	1
2.0 SOURCE DESCRIPTION/TEST PROCEDURES	3
TCEM SAMPLING SYSTEM DIAGRAM - FIGURE 1	5
3.0 TEST RESULTS	7
UNIT 26 NITROGEN OXIDES RESULTS	8
UNIT 27 NITROGEN OXIDES RESULTS	9
UNIT 28 NITROGEN OXIDES RESULTS	10
UNIT 29 NITROGEN OXIDES RESULTS	11
UNIT 30 NITROGEN OXIDES RESULTS	12

### APPENDICES

- A. NITROGEN OXIDES CALCULATIONS
- B. UNCORRECTED REFERENCE METHOD DATA
- C. VISIBLE EMISSIONS DATA SHEETS
- D. TCEMS CALIBRATION DATA
  - D.1 INITIAL/FINAL TCEMS CALIBRATIONS
  - D.2 SYSTEM BIAS TESTS
  - D.3 SYSTEM BIAS AND DRIFT CALCULATIONS
- E. CALIBRATION GAS CERTIFICATES OF ANALYSIS
- F. FIELD DATA SHEETS
- G. TEST PARTICIPANTS

## 1.0 SUMMARY OF RESULTS

---

On July 16 through July 19, 2001, the Environmental Services group of Tampa Electric Company performed initial NO<sub>x</sub> source emission tests on five (5) randomly selected Caterpillar SR4B generators, located at Hookers Point Station. The generators selected were units 26 through 30, operating on diesel fuel with a full load generating capacity of 1.825 megawatts each. Testing was conducted according to United States Environmental Protection Agency (USEPA) test methods stipulated in 40 CFR Part 60, Appendix A and air construction permit ARMS 0570038-002-AC.

The initial Nitrogen Oxides (NO<sub>x</sub>) emission concentration for unit 26 was derived from three test runs. The calculated average was 564 ppmvd, and the corresponding emission rate was 38.2 pounds per hour at an average exhaust temperature of 851 degrees Fahrenheit. The Florida Department of Environmental Protection (FDEP) permit limit is 53 pounds per hour. The average opacity observed during the thirty minute visible emissions test was 6 percent. The FDEP permit limit is 20 percent.

The initial NO<sub>x</sub> emission concentration for unit 27 was derived from three test runs. The calculated average was 568 ppmvd, and the corresponding emission rate was 39.2 pounds per hour at an average exhaust temperature of 828 degrees Fahrenheit. The FDEP permit limit is 53 pounds per hour. The average opacity observed during the thirty minute visible emissions test was 6 percent. The FDEP permit limit is 20 percent.

The initial NO<sub>x</sub> emission concentration for unit 28 was derived from three test runs. The calculated average was 540 ppmvd, and the corresponding emission rate was 36.8 pounds per hour at an average exhaust temperature of 850 degrees Fahrenheit. The FDEP permit limit is 53 pounds per hour. The average opacity observed during the thirty minute visible emissions test was 5 percent. The FDEP permit limit is 20 percent.

The initial NO<sub>x</sub> emission concentration for unit 29 was derived from three test runs. The calculated average was 557 ppmvd, and the corresponding emission rate was 36.3

pounds per hour at an average exhaust temperature of 905 degrees Fahrenheit. The FDEP permit limit is 53 pounds per hour. The average opacity observed during the thirty minute visible emissions test was 6 percent. The FDEP permit limit is 20 percent.

The initial NO<sub>x</sub> emission concentration for unit 30 was derived from three test runs. The calculated average was 569 ppmvd, and the corresponding emission rate was 38.8 pounds per hour at an average exhaust temperature of 847 degrees Fahrenheit. The FDEP permit limit is 53 pounds per hour. The average opacity observed during the thirty minute visible emissions test was 5 percent. The FDEP permit limit is 20 percent.

During the tests on July 18, 2001, each combustion engine was operated at an average load of 1,825 kilowatts and the average quantity of fuel burned was 123 gallons per hour of diesel fuel.

## **2.0 SOURCE DESCRIPTION/TEST PROCEDURES**

---

The Caterpillar generator field of thirty power modules is located at the Hookers Point Station on Hemlock Street, Tampa, Florida at UTM coordinates East 358.0 North 3091.0. Each generating unit, XQ2000 Power Module, consists of a 4-stroke cycle diesel engine with a generation capacity of 1.825 megawatts or a total generation capacity of 54.75 megawatts. Source sampling was performed from the rectangular exhaust vent on the roof of each engine compartment housed in a semi-tractor trailer.

Nitrogen Oxides sampling was performed in accordance with USEPA Reference Method 7E (40 CFR Part 60, Appendix A) "Determination of Nitrogen Oxides Emissions from Stationary Sources". Testing was performed using an Advanced Pollution Instruments model 200AH Chemiluminescent NO-NO<sub>2</sub>-NO<sub>x</sub> Gas Analyzer.

A visible emission test was performed using FDEP Method 9 "Visual Determination of the Opacity of Emissions from Stationary Sources".

### **TCEMS Description**

The following discussion briefly outlines the operation principles of Environmental Services Transportable Continuous Emissions Monitoring System (TCEMS). Additional information on instrument operation may be found in the individual instrument manuals provided by the manufacturers. A schematic of the TCEMS set-up is presented in Figure 1.

## **Advanced Pollution Instruments Model 200AH NO/NO<sub>x</sub> Analyzer**

The Advanced Pollution Instruments model 200AH NO/NO<sub>x</sub> analyzer automatically and continuously determines the concentration of nitric oxide (NO) and/or oxides of nitrogen (NO<sub>x</sub>) in a flowing gas mixture. The analytical technique is chemiluminescence.

To measure NO concentrations, the gas sample to be analyzed is blended with ozone (O<sub>3</sub>) in a reaction chamber. The resulting chemiluminescence activity is monitored through an optical filter by a high sensitivity photomultiplier tube positioned at one end of the chamber.

This filter and photomultiplier combination responds to light of a narrow wavelength band unique to the NO/O<sub>3</sub> reaction, producing an interference free signal. The output from the photomultiplier is linearly proportional to the NO concentration.

To measure NO<sub>x</sub> concentrations (i.e., NO plus NO<sub>2</sub>), the sample gas flow is diverted through an NO<sub>2</sub>-to-NO converter. The Chemiluminescent action in the reaction chamber to the converter effluent is linearly proportional to the NO<sub>x</sub> concentration entering the converter.

### **Data Acquisition System**

The data acquisition system (DAS) developed by Entropy Environmentalists Inc., uses a portable personal computer with an internal 32 bit analog-to-digital converter with an external 16 channel multiplexer. In addition to providing an instantaneous display of analyzer responses, the DAS can average data, calculate emission rates, and document analyzer calibrations. The test results and calibrations are stored on the hard disk and printed on a dot matrix printer.

### **TCEMS Sample Handling System**

The extractive monitors utilized in the TCEMS require that the effluent stream be conditioned to eliminate any possible interference (i.e., water vapor and particulate matter), before being transported and injected into each analyzer. Figure 1 depicts a schematic of the entire sample handling system. The major components of this system are listed below:

- Gas transport tubing
- Moisture removal system
- Sampling pump

### **Gas Transport Tubing**


Two separate 1/4 inch O.D. Teflon tubes were used for the sample gas transport.

### **Moisture Removal System**

The moisture removal system was comprised of an ice bath condenser, constructed of a 30-foot section of 3/8 inch O.D. Teflon tubing wrapped in a 12-inch coil. Effluent travels through this coil and then passes, in series, through two stainless steel moisture traps where the condensate drops out and is removed via a condensate discharge pump. With the exception of the discharge pump, the entire assembly is chilled in an ice bath.

### **Sampling Pump**

The Thomas Model 2107CE20-TFE pump is used to transport the effluent sample through the conditioning system to the analyzers. All internal parts of the pump that come into contact with the gas sample are constructed of 316 stainless steel or Teflon.



**FIGURE 1**  
Carbon Monoxide and Nitrogen Oxide Sampling Trains  
USEPA METHODS 3A, 10, 20, 25 CEM SYSTEM LAYOUT

## 3.0 TEST RESULTS

---

# HOOKERS POINT CATERPILLAR GENERATING FIELD

## NITROGEN OXIDES TESTING

**XP2000 COMBUSTION ENGINE UNIT 26**  
**JULY 19, 2001**

RUN NO.	TIME	Exhaust Temperature Degrees F	ppm NO <sub>x</sub> Dry	ppm NO <sub>x</sub> Corrected to lbs/Hr
1	11:40 –12:40	846.2	570	38.8
2	13:01 –14:01	852.6	506	34.3
3	14:18 –15:18	853.2	615	41.6
<b>Average</b>		850.6	564	38.2

NO<sub>x</sub> corrected to lbs/Hr.  
 by  
 NO<sub>x</sub> Mass Flow Rate:

$$Flow \left[ \frac{\mu g}{min} \right] = \frac{GMW \left[ \frac{g}{mol} \right] \times NO_x \text{ concentration } [ppm] \times \frac{V_c \left[ \frac{ft^3}{min} \right]}{35.31 \left[ \frac{ft^3}{m^3} \right]} \times 1,000 \left[ \frac{L}{m^3} \right]}{22.414 \left[ \frac{L}{mol} \right] \times \frac{T_{ref} [K]}{273.15 [K]}}$$

$$Flow \left[ \frac{lb}{hr} \right] = Flow \left[ \frac{\mu g}{min} \right] \times \frac{1}{1,000,000} \left[ \frac{g}{\mu g} \right] \times \frac{1}{454} \left[ \frac{lb}{g} \right] \times \frac{60}{1} \left[ \frac{min}{hr} \right]$$

where:

- GMW = gram molecular weight of NO<sub>x</sub> = 76 g/mol
- V<sub>c</sub> = temperature corrected volumetric flow rate of flue gas
- T<sub>ref</sub> = ambient temperature

# HOOKERS POINT CATERPILLAR GENERATING FIELD NITROGEN OXIDES TESTING

**XP2000 COMBUSTION ENGINE UNIT 27  
JULY 16, 2001**

RUN NO.	TIME	Exhaust Temperature Degrees F	ppm NO <sub>x</sub> Dry	ppm NO <sub>x</sub> Corrected to lbs/Hr
1	12:46 –13:46	820.4	504	35.0
2	14:06 –15:06	830.6	693	47.8
3	15:18 –16:18	833.0	507	34.9
	<b>Average</b>	828.0	568	39.2

NO<sub>x</sub> corrected to lbs/Hr.  
by  
NO<sub>x</sub> Mass Flow Rate:

$$Flow \left[ \frac{\mu g}{min} \right] = \frac{GMW \left[ \frac{g}{mol} \right] \times NO_x \text{ concentration } [ppm] \times \frac{V_c \left[ \frac{ft^3}{min} \right]}{35.31 \left[ \frac{ft^3}{m^3} \right]} \times 1,000 \left[ \frac{L}{m^3} \right]}{22.414 \left[ \frac{L}{mol} \right] \times \frac{T_{ref} [K]}{273.15 [K]}}$$

$$Flow \left[ \frac{lb}{hr} \right] = Flow \left[ \frac{\mu g}{min} \right] \times \frac{1}{1,000,000} \left[ \frac{g}{\mu g} \right] \times \frac{1}{454} \left[ \frac{lb}{g} \right] \times \frac{60}{1} \left[ \frac{min}{hr} \right]$$

where:

GMW = gram molecular weight of NO<sub>x</sub> = 76 g/mol  
V<sub>c</sub> = temperature corrected volumetric flow rate of flue gas  
T<sub>ref</sub> = ambient temperature

# HOOKERS POINT CATERPILLAR GENERATING FIELD NITROGEN OXIDES TESTING

## XP2000 COMBUSTION ENGINE UNIT 28 JULY 18, 2001

RUN NO.	TIME	Exhaust Temperature Degrees F	ppm NO <sub>x</sub> Dry	ppm NO <sub>x</sub> Corrected to lbs/Hr
1	09:28 – 10:28	846.7	589	40.3
2	10:46 – 11:46	850.0	523	35.6
3	12:07 – 13:07	854.6	508	34.4
	<b>Average</b>	850.4	540	36.8

NO<sub>x</sub> corrected to lbs/Hr.  
by

NO<sub>x</sub> Mass Flow Rate:

$$Flow \left[ \frac{\mu g}{min} \right] = \frac{GMW \left[ \frac{g}{mol} \right] \times NO_x \text{ concentration } [ppm] \times \frac{V_c \left[ \frac{ft^3}{min} \right]}{35.31 \left[ \frac{ft^3}{m^3} \right]} \times 1,000 \left[ \frac{L}{m^3} \right]}{22.414 \left[ \frac{L}{mol} \right] \times \frac{T_{ref} [K]}{273.15 [K]}}$$

$$Flow \left[ \frac{lb}{hr} \right] = Flow \left[ \frac{\mu g}{min} \right] \times \frac{1}{1,000,000} \left[ \frac{g}{\mu g} \right] \times \frac{1}{454} \left[ \frac{lb}{g} \right] \times \frac{60}{1} \left[ \frac{min}{hr} \right]$$

where:

GMW = gram molecular weight of NO<sub>x</sub> = 76 g/mol

V<sub>c</sub> = temperature corrected volumetric flow rate of flue gas

T<sub>ref</sub> = ambient temperature

# HOOKERS POINT CATERPILLAR GENERATING FIELD NITROGEN OXIDES TESTING

## XP2000 COMBUSTION ENGINE UNIT 29 JULY 18, 2001

RUN NO.	TIME	Exhaust Temperature Degrees F	ppm NO <sub>x</sub> Dry	ppm NO <sub>x</sub> Corrected to lbs/Hr
1	14:15 – 15:15	906.4	561	36.6
2	15:33 – 16:33	907.1	561	36.5
3	16:51 – 17:51	902.2	550	35.9
<b>Average</b>		905.2	557	36.3

NO<sub>x</sub> corrected to lbs/Hr.  
by  
NO<sub>x</sub> Mass Flow Rate:

$$Flow \left[ \frac{\mu g}{min} \right] = \frac{GMW \left[ \frac{g}{mol} \right] \times NO_x \text{ concentration } [ppm] \times \frac{V_c \left[ \frac{ft^3}{min} \right]}{35.31 \left[ \frac{ft^3}{m^3} \right]} \times 1,000 \left[ \frac{L}{m^3} \right]}{22.414 \left[ \frac{L}{mol} \right] \times \frac{T_{ref} [K]}{273.15 [K]}}$$

$$Flow \left[ \frac{lb}{hr} \right] = Flow \left[ \frac{\mu g}{min} \right] \times \frac{1}{1,000,000} \left[ \frac{g}{\mu g} \right] \times \frac{1}{454} \left[ \frac{lb}{g} \right] \times \frac{60}{1} \left[ \frac{min}{hr} \right]$$

where:

- GMW = gram molecular weight of NO<sub>x</sub> = 76 g/mol
- V<sub>c</sub> = temperature corrected volumetric flow rate of flue gas
- T<sub>ref</sub> = ambient temperature

# HOOKERS POINT CATERPILLAR GENERATING FIELD NITROGEN OXIDES TESTING

## XP2000 COMBUSTION ENGINE UNIT 30 JULY 19, 2001

RUN NO.	TIME	Exhaust Temperature Degrees F	ppm NO <sub>x</sub> Dry	ppm NO <sub>x</sub> Corrected to lbs/Hr
1	06:50 -07:50	839.1	569	39.0
2	08:07 -09:07	849.4	531	36.1
3	09:27 -10:27	853.2	608	41.2
<b>Average</b>		847.2	569	38.8

NO<sub>x</sub> corrected to lbs/Hr.  
by  
NO<sub>x</sub> Mass Flow Rate:

$$Flow \left[ \frac{\mu g}{min} \right] = \frac{GMW \left[ \frac{g}{mol} \right] \times NO_x \text{ concentration } [ppm] \times \frac{V_c \left[ \frac{ft^3}{min} \right]}{35.31 \left[ \frac{ft^3}{m^3} \right]} \times 1,000 \left[ \frac{L}{m^3} \right]}{22.414 \left[ \frac{L}{mol} \right] \times \frac{T_{ref} [K]}{273.15 [K]}}$$

$$Flow \left[ \frac{lb}{hr} \right] = Flow \left[ \frac{\mu g}{min} \right] \times \frac{1}{1,000,000} \left[ \frac{g}{\mu g} \right] \times \frac{1}{454} \left[ \frac{lb}{g} \right] \times \frac{60}{1} \left[ \frac{min}{hr} \right]$$

where:

GMW = gram molecular weight of NO<sub>x</sub> = 76 g/mol  
V<sub>c</sub> = temperature corrected volumetric flow rate of flue gas  
T<sub>ref</sub> = ambient temperature

## HOOKERS POINT CATERPILLAR GENERATING FIELD NITROGEN OXIDES TESTING

---

### Volumetric Flow Rate Temperature Correction

$$V_c = \frac{T_{ref} + 460^{\circ}R}{T_s + 460^{\circ}R} \times Q_{ref} \left[ \frac{ft^3}{min} \right]$$

where:

$T_{ref}$  = ambient temperature

$T_s$  = stack temperature

$Q_{ref}$  = 14,267 = manufacturer's specification wet exhaust flow

**A. NITROGEN OXIDES CALCULATIONS**

CALCULATION OF AVERAGE NITROGEN OXIDES EMISSIONS

RUN: 1  
 SOURCE: HOOKERS POINT POWER CAT UNIT 26  
 TEST DATE: 7/19/01

GAS VALUE	INITIAL CAL	FINAL CAL	MEAN CAL
0.0 ppm NOx	3.1	4.6	3.9
1268.0 ppm NOx	1277.2	1276.9	1277.1
0.00 ppmNO	3.10	3.10	3.1
1268.00 ppmNO	1279.50	1277.90	1278.7

$\bar{C}(\text{NOx}) = 576.6$        $\bar{C}(\text{NO}) = 563.9$

CORRECTED RESULTS

570 ppm NOx  
 558 ppmNO  
 13 ppm NO2

Corr. Conc. =  $\bar{C}_m(C - C_o)/(C_m - C_o)$  (for NOx)

Corr. Conc. =  $[(C_m - C_o)/(C_m - C_o)](C - C_m) + C_m$  (for O2)

Where:  $\bar{C}$  = mean reference measurement  
 $C_o$  = mean zero calibration response  
 $C_oa$  = actual low-level calibration gas concentration  
 $C_m$  = mean mid or upscale calibration gas response  
 $C_ma$  = actual mid or upscale calibration gas concentration

CALCULATION OF AVERAGE NITROGEN OXIDES EMISSIONS

RUN: 2  
 SOURCE: HOOKERS POINT POWER CAT UNIT 26  
 TEST DATE: 7/19/01

GAS VALUE	INITIAL CAL	FINAL CAL	MEAN CAL
0.0 ppm NOx	4.6	6.0	5.3
1268.0 ppm NOx	1276.9	1275.7	1276.3
0.00 ppmNO	3.10	3.10	3.1
1268.00 ppmNO	1277.90	1276.30	1277.1

$\bar{C}(\text{NOx}) = 512.5$        $\bar{C}(\text{NO}) = 502.5$

**CORRECTED RESULTS**

506 ppm NOx  
 497 ppmNO  
 9 ppm NO2

Corr. Conc. =  $\bar{C}_m(C - C_o)/(C_m - C_o)$  (for NOx)

Corr. Conc. =  $[(C_{ma} - C_{oa})/(C_m - C_o)](C - C_m) + C_{ma}$  (for O2)

- Where:  $\bar{C}$  = mean reference measurement  
 C<sub>o</sub> = mean zero calibration response  
 C<sub>oa</sub> = actual low-level calibration gas concentration  
 C<sub>m</sub> = mean mid or upscale calibration gas response  
 C<sub>ma</sub> = actual mid or upscale calibration gas concentration

CALCULATION OF AVERAGE NITROGEN OXIDES EMISSIONS

RUN: 3  
 SOURCE: HOOKERS POINT POWER CAT UNIT 26  
 TEST DATE: 7/19/01

GAS VALUE	INITIAL CAL	FINAL CAL	MEAN CAL
0.0 ppm NOx	6.0	6.0	6.0
1268.0 ppm NOx	1275.7	1272.6	1274.2
0.00 ppmNO	3.10	4.60	3.9
1268.00 ppmNO	1276.30	1273.30	1274.8

$\bar{C}(\text{NOx}) = 621.0$        $\bar{C}(\text{NO}) = 607.2$

CORRECTED RESULTS

615 ppm NOx  
 602 ppmNO  
 13 ppm NO2

Corr. Conc. =  $\bar{C}_{ma}(C - C_o)/(C_m - C_o)$  (for NOx)

Corr. Conc. =  $[(C_{ma} - C_{oa})/(C_m - C_o)](C - C_m) + C_{ma}$  (for O2)

Where:  $\bar{C}$  = mean reference measurement  
 C<sub>o</sub> = mean zero calibration response  
 C<sub>oa</sub> = actual low-level calibration gas concentration  
 C<sub>m</sub> = mean mid or upscale calibration gas response  
 C<sub>ma</sub> = actual mid or upscale calibration gas concentration

CALCULATION OF AVERAGE NITROGEN OXIDES EMISSIONS

RUN: 1  
 SOURCE: RING-HAVER CAT POWER, UNIT 27  
 TEST DATE: 7/16/01

GAS VALUE	INITIAL CAL	FINAL CAL	MEAN CAL
0.0 ppm NOx	-9.8	6.9	-1.5
1268.0 ppm NOx	1240.1	1281.0	1260.6

$\bar{C}(\text{NO}_x) = 500.2$

CORRECTED RESULTS  
 504 ppm NOx

Corr. Conc. =  $\bar{C}_m(C - C_o)/(C_m - C_o)$  (for NOx)

Corr. Conc. =  $[(C_m - C_o)/(C_m - C_o)](C - C_m) + C_m$  (for O2)

Where:  $\bar{C}$  = mean reference measurement  
 Co = mean zero calibration response  
 Coa = actual low-level calibration gas concentration  
 Cm = mean mid or upscale calibration gas response  
 Cma = actual mid or upscale calibration gas concentration

CALCULATION OF AVERAGE NITROGEN OXIDES EMISSIONS

RUN: 2  
 SOURCE: RING-HAVER CAT POWER, UNIT 27  
 TEST DATE: 7/16/01

GAS VALUE	INITIAL CAL	FINAL CAL	MEAN CAL
0.0 ppm NOx	6.9	5.8	6.4
1268.0 ppm NOx	1281.0	1278.2	1279.6

$\bar{C}(\text{NO}_x) = 702.0$

CORRECTED RESULTS  
 693 ppm NOx

Corr. Conc. =  $\bar{C}_m(C - C_o)/(C_m - C_o)$  (for NOx)

Corr. Conc. =  $[(C_m - C_o)/(C_m - C_o)](C - C_m) + C_m$  (for O2)

Where:  $\bar{C}$  = mean reference measurement  
 $C_o$  = mean zero calibration response  
 $C_oa$  = actual low-level calibration gas concentration  
 $C_m$  = mean mid or upscale calibration gas response  
 $C_ma$  = actual mid or upscale calibration gas concentration

CALCULATION OF AVERAGE NITROGEN OXIDES EMISSIONS

RUN: 3

SOURCE: RING-HAVER CAT POWER, UNIT 27

TEST DATE: 7/16/01

GAS VALUE	INITIAL CAL	FINAL CAL	MEAN CAL
0.0 ppm NOx	5.8	1.7	3.8
1268.0 ppm NOx	1278.2	1279.9	1279.1

$\bar{C}(\text{NO}_x) = 513.9$

CORRECTED RESULTS  
507 ppm NOx

Corr. Conc. =  $\bar{C}_m(C - C_o)/(C_m - C_o)$  (for NOx)

Corr. Conc. =  $[(C_m - C_o_a)/(C_m - C_o)](C - C_m) + C_m$  (for O2)

- Where:  $\bar{C}$  = mean reference measurement  
 $C_o$  = mean zero calibration response  
 $C_o_a$  = actual low-level calibration gas concentration  
 $C_m$  = mean mid or upscale calibration gas response  
 $C_m_a$  = actual mid or upscale calibration gas concentration

CALCULATION OF AVERAGE NITROGEN OXIDES EMISSIONS

RUN: 1  
 SOURCE: H.P RING-HAVER CAT POWER UNIT 28  
 TEST DATE: 7/18/01

GAS VALUE	INITIAL CAL	FINAL CAL	MEAN CAL
0.0 ppm NOx	1.5	3.0	2.3
1268.0 ppm NOx	1280.1	1269.7	1274.9
1.50 ppmNO	1.5	3.1	2.3
1268.00 ppmNO	1279.3	1271.9	1275.6

$\bar{C}(\text{NOx}) = 593.4$        $\bar{C}(\text{NO}) = 582.9$

CORRECTED RESULTS

589 ppm NOx  
 579 ppmNO  
 10 ppm NO2

Corr. Conc. =  $\bar{C}_m(C - C_o)/(C_m - C_o)$  (for NOx)

Corr. Conc. =  $[(C_{ma} - C_{oa})/(C_m - C_o)](C - C_m) + C_{ma}$  (for O2)

Where:  $\bar{C}$  = mean reference measurement  
 $C_o$  = mean zero calibration response  
 $C_{oa}$  = actual low-level calibration gas concentration  
 $C_m$  = mean mid or upscale calibration gas response  
 $C_{ma}$  = actual mid or upscale calibration gas concentration

CALCULATION OF AVERAGE NITROGEN OXIDES EMISSIONS

RUN: 2  
 SOURCE: H.P RING-HAVER CAT POWER UNIT 28  
 TEST DATE: 7/18/01

GAS VALUE	INITIAL CAL	FINAL CAL	MEAN CAL
0.0 ppm NOx	3.0	-1.9	0.6
1268.0 ppm NOx	1269.7	1266.8	1268.3
1.50 ppmNO	3.1	0.0	1.6
1268.00 ppmNO	1271.9	1267.6	1269.8

$\bar{C}(\text{NOx}) = 523.5$        $\bar{C}(\text{NO}) = 515.9$

CORRECTED RESULTS

523 ppm NOx  
 515 ppmNO  
 8 ppm NO2

Corr. Conc. =  $\bar{C}_m(C - C_o)/(C_m - C_o)$  (for NOx)

Corr. Conc. =  $[(C_m - C_o)/(C_m - C_o)](C - C_m) + C_m$  (for O2)

Where:  $\bar{C}$  = mean reference measurement  
 Co = mean zero calibration response  
 Coa = actual low-level calibration gas concentration  
 Cm = mean mid or upscale calibration gas response  
 Cma = actual mid or upscale calibration gas concentration

CALCULATION OF AVERAGE NITROGEN OXIDES EMISSIONS

RUN: 3  
 SOURCE: H.P RING-HAVER CAT POWER UNIT 28  
 TEST DATE: 7/18/01

GAS VALUE	INITIAL CAL	FINAL CAL	MEAN CAL
0.0 ppm NOx	-1.9	-0.2	-1.1
1268.0 ppm NOx	1266.8	1262.5	1264.7
1.50 ppmNO	0.0	1.5	0.8
1268.00 ppmNO	1267.6	1264.6	1266.1

$\bar{C}(\text{NOx}) = 506.4$        $\bar{C}(\text{NO}) = 499.2$

CORRECTED RESULTS

508 ppm NOx  
 500 ppmNO  
 8 ppm NO2

Corr. Conc. =  $\bar{C}_m(C - C_o)/(C_m - C_o)$  (for NOx)

Corr. Conc. =  $[(C_m - C_o_a)/(C_m - C_o)](C - C_m) + C_m$  (for O2)

Where:  $\bar{C}$  = mean reference measurement  
 C<sub>o</sub> = mean zero calibration response  
 C<sub>o<sub>a</sub></sub> = actual low-level calibration gas concentration  
 C<sub>m</sub> = mean mid or upscale calibration gas response  
 C<sub>m<sub>a</sub></sub> = actual mid or upscale calibration gas concentration

CALCULATION OF AVERAGE NITROGEN OXIDES EMISSIONS

RUN: 1  
 SOURCE: HOOKERS POINT POWER CAT UNIT 29 TEST  
 TEST DATE: 7/18/01

GAS VALUE	INITIAL CAL	FINAL CAL	MEAN CAL
0.0 ppm NOx	6.0	3.1	4.6
1268.0 ppm NOx	1275.8	1277.1	1276.5
0.00 ppmNO	4.6	3.1	3.9
1268.00 ppmNO	1276.4	1279.4	1277.9

$\bar{C}(\text{NOx}) = 567.0$        $\bar{C}(\text{NO}) = 557.3$

CORRECTED RESULTS

561 ppm NOx  
 551 ppmNO  
 10 ppm NO2

Corr. Conc. =  $\bar{C}_m(C - C_o)/(C_m - C_o)$  (for NOx)

Corr. Conc. =  $[(C_m - C_o_a)/(C_m - C_o)](C - C_m) + C_m$  (for O2)

Where:  $\bar{C}$  = mean reference measurement  
 $C_o$  = mean zero calibration response  
 $C_o_a$  = actual low-level calibration gas concentration  
 $C_m$  = mean mid or upscale calibration gas response  
 $C_m_a$  = actual mid or upscale calibration gas concentration

CALCULATION OF AVERAGE NITROGEN OXIDES EMISSIONS

RUN: 2

SOURCE: HOOKERS POINT POWER CAT UNIT 29 TEST

TEST DATE: 7/18/01

GAS VALUE	INITIAL CAL	FINAL CAL	MEAN CAL
0.0 ppm NOx	3.1	4.6	3.9
1268.0 ppm NOx	1277.1	1272.7	1274.9
0.00 ppmNO	3.1	3.1	3.1
1268.00 ppmNO	1279.4	1270.5	1275.0

$\bar{C}(\text{NO}_x) = 565.8$        $\bar{C}(\text{NO}) = 556.2$

**CORRECTED RESULTS**

561 ppm NOx  
 551 ppmNO  
 10 ppm NO2

Corr. Conc. =  $\bar{C}_m(C - C_o)/(C_m - C_o)$  (for NOx)

Corr. Conc. =  $[(C_m - C_o_a)/(C_m - C_o)](C - C_m) + C_m$  (for O2)

- Where:  $\bar{C}$  = mean reference measurement  
 $C_o$  = mean zero calibration response  
 $C_o_a$  = actual low-level calibration gas concentration  
 $C_m$  = mean mid or upscale calibration gas response  
 $C_m_a$  = actual mid or upscale calibration gas concentration

CALCULATION OF AVERAGE NITROGEN OXIDES EMISSIONS

RUN: 3

SOURCE: HOOKERS POINT POWER CAT UNIT 29 TEST

TEST DATE: 7/18/01

GAS VALUE	INITIAL CAL	FINAL CAL	MEAN CAL
0.0 ppm NOx	4.6	4.4	4.5
1268.0 ppm NOx	1272.7	1269.7	1271.2
0.00 ppmNO	3.1	3.1	3.1
1268.00 ppmNO	1270.5	1271.9	1271.2

$\bar{C}(\text{NOx}) = 554.4$        $\bar{C}(\text{NO}) = 544.9$

CORRECTED RESULTS

550 ppm NOx  
 542 ppmNO  
 8 ppm NO2

Corr. Conc. =  $\bar{C}_m(C - C_o)/(C_m - C_o)$  (for NOx)

Corr. Conc. =  $[(C_m - C_o_a)/(C_m - C_o)](C - C_m) + C_m$  (for O2)

- Where:  $\bar{C}$  = mean reference measurement  
 $C_o$  = mean zero calibration response  
 $C_o_a$  = actual low-level calibration gas concentration  
 $C_m$  = mean mid or upscale calibration gas response  
 $C_m_a$  = actual mid or upscale calibration gas concentration

CALCULATION OF AVERAGE NITROGEN OXIDES EMISSIONS

RUN: 1

SOURCE: HOOKERS POINTCAT POWER UNIT 30

TEST DATE: 7/19/01

GAS VALUE	INITIAL CAL	FINAL CAL	MEAN CAL
0.0 ppm NOx	4.6	4.5	4.6
1268.0 ppm NOx	1275.7	1275.6	1275.7
0.00 ppmNO	2.9	3.0	3.0
1268.00 ppmNO	1276.4	1274.4	1275.4

$\bar{C}(\text{NOx}) = 575.1$        $\bar{C}(\text{NO}) = 562.9$

CORRECTED RESULTS

569 ppm NOx  
 558 ppmNO  
 11 ppm NO2

Corr. Conc. =  $\bar{C}_m(C - C_o)/(C_m - C_o)$  (for NOx)

Corr. Conc. =  $[(C_m - C_o)/(C_m - C_o)](C - C_m) + C_m$  (for O2)

- Where:  $\bar{C}$  = mean reference measurement  
 $C_o$  = mean zero calibration response  
 $C_oa$  = actual low-level calibration gas concentration  
 $C_m$  = mean mid or upscale calibration gas response  
 $C_ma$  = actual mid or upscale calibration gas concentration

CALCULATION OF AVERAGE NITROGEN OXIDES EMISSIONS

RUN: 2  
 SOURCE: HOOKERS POINT CAT POWER UNIT 30  
 TEST DATE: 7/19/01

GAS VALUE	INITIAL CAL	FINAL CAL	MEAN CAL
0.0 ppm NOx	4.5	4.6	4.6
1268.0 ppm NOx	1275.6	1274.2	1274.9
0.00 ppmNO	3.0	3.1	3.1
1268.00 ppmNO	1274.4	1273.5	1274.0

$\bar{C}(\text{NOx}) = 536.6$        $\bar{C}(\text{NO}) = 525.9$

CORRECTED RESULTS

531 ppm NOx  
 522 ppmNO  
 9 ppm NO2

Corr. Conc. =  $\bar{C}_m(C - C_o)/(C_m - C_o)$  (for NOx)

Corr. Conc. =  $[(C_m - C_o)/(C_m - C_o)](C - C_m) + C_m$  (for O2)

Where:  $\bar{C}$  = mean reference measurement  
 $C_o$  = mean zero calibration response  
 $C_oa$  = actual low-level calibration gas concentration  
 $C_m$  = mean mid or upscale calibration gas response  
 $C_ma$  = actual mid or upscale calibration gas concentration

CALCULATION OF AVERAGE NITROGEN OXIDES EMISSIONS

RUN: 3  
 SOURCE: HOOKERS POINT CAT POWER UNIT 30  
 TEST DATE: 7/19/01

GAS VALUE	INITIAL CAL	FINAL CAL	MEAN CAL
0.0 ppm NOx	4.6	3.1	3.9
1268.0 ppm NOx	1274.2	1271.2	1272.7
0.00 ppmNO	3.1	2.8	3.0
1268.00 ppmNO	1273.5	1267.6	1270.6

$\bar{C}(\text{NOx}) = 612.1$        $\bar{C}(\text{NO}) = 599.0$

CORRECTED RESULTS

608 ppm NOx  
 596 ppmNO  
 12 ppm NO2

Corr. Conc. =  $\bar{C}_m(C - C_o)/(C_m - C_o)$  (for NOx)

Corr. Conc. =  $[(C_m - C_o)/(C_m - C_o)](C - C_m) + C_m$  (for O2)

Where:  $\bar{C}$  = mean reference measurement  
 $C_o$  = mean zero calibration response  
 $C_oa$  = actual low-level calibration gas concentration  
 $C_m$  = mean mid or upscale calibration gas response  
 $C_ma$  = actual mid or upscale calibration gas concentration

**B. UNCORRECTED REFERENCE METHOD DATA**

RING-HAVER POWER CAT TESTING

07-19-2001

TIME	CHAN 4 OUTLET ppmNOX	CHAN 5 OUTLET ppmNO
11:40	649.8	633.5
11:41	644.0	630.8
11:42	641.7	628.0
11:43	641.5	626.0
11:44	636.3	619.9
11:45	630.3	615.6
11:46	628.7	612.2
11:47	621.3	606.3
11:48	614.7	599.9
11:49	614.7	601.7
11:50	617.3	603.8
11:51	615.7	600.7
11:52	611.2	596.2
11:53	607.8	593.1
11:54	603.1	590.9
11:55	599.1	585.2
11:56	596.9	583.7
11:57	597.2	583.6
11:58	593.1	579.0
11:59	588.6	576.0
12:00	590.4	575.7
12:01	584.8	570.7
12:02	582.3	570.0
12:03	582.6	568.3
12:04	579.4	565.2
12:05	574.3	561.3
12:06	567.2	555.1
12:07	565.9	553.5
12:08	567.0	553.8
12:09	565.7	552.6
12:10	563.2	551.7
12:11	560.9	548.4
12:12	558.6	545.7
12:13	557.3	544.0
12:14	556.7	543.0
12:15	556.3	542.9
12:16	553.8	541.8
12:17	552.4	540.1
12:18	550.6	540.4
12:19	553.8	543.4
12:20	551.4	539.1
12:21	549.0	537.5
12:22	553.4	545.9
12:23	546.3	541.5
12:24	548.9	536.7
12:25	545.4	532.9
12:26	545.4	534.7
12:27	546.2	534.7
12:28	544.0	533.4
12:29	544.9	533.3
12:30	546.0	534.8
12:31	548.2	535.7
12:32	546.5	533.9
12:33	543.8	533.4
12:34	544.0	534.6

## RING-HAVER POWER CAT TESTING

07-19-2001

	CHAN 4	CHAN 5
	OUTLET	OUTLET
TIME	ppmNOX	ppmNO
12:35	544.9	533.3
12:36	542.8	530.8
12:37	541.6	530.7
12:38	541.8	531.8
12:39	541.9	530.9

-----  
AVERAGE VALUES FOR THE LAST HOUR: 60 MINUTES OF VALID DATA

12:39	576.6	563.9
-------	-------	-------

*PAE*

<del>12:40</del>	<del>540.0</del>	<del>529.0</del>
------------------	------------------	------------------

COMMENTS: END RUN ONE  
UNIT 26

RING-HAVER POWER CAT TESTING

07-19-2001

TIME	CHAN 4 OUTLET ppmNOX	CHAN 5 OUTLET ppmNO
13:02	523.6	512.7
13:03	523.1	511.1
13:04	521.4	510.8
13:05	520.0	509.7
13:06	518.7	509.2
13:07	519.4	508.9
13:08	516.6	507.3
13:09	516.9	508.1
13:10	516.5	505.6
13:11	516.6	507.4
13:12	518.0	508.8
13:13	520.1	510.6
13:14	518.9	507.7
13:15	515.8	505.4
13:16	515.4	507.5
13:17	515.6	505.1
13:18	512.7	503.4
13:19	514.6	504.6
13:20	512.2	502.0
13:21	511.8	502.2
13:22	509.8	499.2
13:23	507.9	498.6
13:24	509.6	500.4
13:25	512.0	502.3
13:26	511.3	500.1
13:27	511.8	501.3
13:28	512.4	502.6
13:29	513.9	505.5
13:30	515.4	506.9
13:31	516.3	506.8
13:32	517.4	506.9
13:33	516.9	505.4
13:34	512.8	502.3
13:35	513.9	505.1
13:36	515.7	505.9
13:37	515.6	504.6
13:38	510.8	499.3
13:39	505.9	494.9
13:40	506.5	498.7
13:41	510.2	500.1
13:42	509.3	498.5
13:43	506.9	497.5
13:44	508.1	497.4
13:45	507.3	497.7
13:46	506.8	497.4
13:47	506.6	496.7
13:48	508.6	499.4
13:49	509.7	499.7
13:50	506.7	497.6
13:51	506.5	497.4
13:52	507.8	498.2
13:53	509.1	499.5
13:54	508.1	498.5
13:55	506.9	496.0
13:56	507.1	497.2

RING-HAVER POWER CAT TESTING

07-19-2001

TIME	CHAN 4 OUTLET ppmNOX	CHAN 5 OUTLET ppmNO
13:57	509.1	497.8
13:58	509.2	498.0
13:59	507.2	496.9
14:00	506.7	496.5
14:01	507.8	498.6

-----  
AVERAGE VALUES FOR THE LAST HOUR: 60 MINUTES OF VALID DATA  
14:01      512.5      502.5  
-----

COMMENTS: END RUN 2  
          UNIT 26

RING-HAVER POWER CAT TESTING

07-19-2001

TIME	CHAN 4 OUTLET ppmNOX	CHAN 5 OUTLET ppmNO
14:19	649.0	632.9
14:20	639.3	624.8
14:21	639.6	623.4
14:22	637.3	622.8
14:23	639.9	626.3
14:24	637.6	623.4
14:25	633.1	618.7
14:26	633.3	618.2
14:27	630.6	615.8
14:28	627.6	612.7
14:29	623.8	610.6
14:30	623.0	609.0
14:31	619.7	607.9
14:32	622.1	608.9
14:33	625.6	613.2
14:34	632.6	620.4
14:35	636.5	621.4
14:36	632.3	618.6
14:37	630.7	615.9
14:38	628.4	615.0
14:39	630.7	616.1
14:40	628.7	614.9
14:41	628.1	614.1
14:42	625.1	613.1
14:43	625.9	612.6
14:44	625.7	612.0
14:45	625.9	610.8
14:46	624.8	611.1
14:47	623.2	609.9
14:48	621.1	608.5
14:49	622.2	607.8
14:50	621.9	607.0
14:51	619.0	604.9
14:52	618.2	604.3
14:53	619.6	605.3
14:54	617.5	603.4
14:55	617.0	603.1
14:56	614.7	599.7
14:57	612.5	599.1
14:58	609.7	597.2
14:59	613.3	600.0
15:00	612.8	599.9
15:01	611.6	597.7
15:02	608.6	594.8
15:03	610.2	597.6
15:04	609.2	595.5
15:05	606.7	594.6
15:06	610.1	596.7
15:07	611.8	597.7
15:08	609.8	595.6
15:09	606.9	593.4
15:10	607.5	593.5
15:11	607.9	594.7
15:12	607.6	596.0
15:13	608.6	595.5

## RING-HAVER POWER CAT TESTING

07-19-2001

	CHAN 4	CHAN 5
	OUTLET	OUTLET
TIME	ppmNOX	ppmNO
15:14	609.1	594.9
15:15	606.7	595.1
15:16	608.5	594.1
15:17	609.6	595.4
15:18	610.0	596.3

-----  
AVERAGE VALUES FOR THE LAST HOUR: 60 MINUTES OF VALID DATA

15:18	621.0	607.2
-------	-------	-------

  
-----COMMENTS: END RUN 3  
UNIT 26

## RING-HAVER POWER CAT TESTING

07-16-2001

TIME	OUTLET ppmNOX
12:47	503.6
12:48	500.5
12:49	492.3
12:50	499.7
12:51	495.5
12:52	489.4
12:53	487.2
12:54	481.8
12:55	476.0
12:56	478.4
12:57	483.7
12:58	481.9
12:59	480.5
13:00	477.1
13:01	477.8
13:02	480.9
13:03	487.1
13:04	484.0
13:05	483.4
13:06	483.4
13:07	481.5
13:08	488.0
13:09	486.5
13:10	489.3
13:11	489.8
13:12	488.9
13:13	482.2
13:14	485.2
13:15	486.5
13:16	486.9
13:17	484.2
13:18	482.3
13:19	486.5
13:20	487.5
13:21	484.9
13:22	483.3
13:23	484.2
13:24	487.4
13:25	488.4
13:26	515.6
13:27	546.2
13:28	542.7
13:29	544.0
13:30	539.5
13:31	534.8
13:32	536.9
13:33	529.9
13:34	522.2
13:35	518.4
13:36	524.2
13:37	524.5
13:38	520.8
13:39	519.0
13:40	512.7
13:41	523.7

RING-HAVER POWER CAT TESTING

07-16-2001

TIME	ppmNOX
14:07	710.6
14:08	716.9
14:09	713.4
14:10	710.2
14:11	715.0
14:12	708.5
14:13	708.7
14:14	711.6
14:15	712.6
14:16	713.5
14:17	707.9
14:18	709.6
14:19	708.3
14:20	707.6
14:21	719.5
14:22	716.2
14:23	710.2
14:24	706.2
14:25	703.3
14:26	703.9
14:27	702.5
14:28	697.7
14:29	697.9
14:30	692.8
14:31	687.1
14:32	694.3
14:33	686.3
14:34	716.7
14:35	709.0
14:36	712.1
14:37	707.2
14:38	710.8
14:39	706.3
14:40	710.1
14:41	716.0
14:42	703.3
14:43	705.1
14:44	709.9
14:45	713.0
14:46	719.2
14:47	702.2
14:48	702.0
14:49	694.7
14:50	695.2
14:51	690.3
14:52	703.1
14:53	694.2
14:54	690.8
14:55	703.2
14:56	697.3
14:57	696.0
14:58	689.1
14:59	684.0
15:00	687.5
15:01	678.0

RING-HAVER POWER CAT TESTING

07-16-2001

CHAN 6

OUTLET

TIME ppmNOX

15:02 680.5

15:03 681.8

15:04 682.8

15:05 680.2

15:06 676.9

-----  
AVERAGE VALUES FOR THE LAST HOUR: 60 MINUTES OF VALID DATA

15:06 702.0  
-----

COMMENTS: END RUN TWO  
CAT UNIT 27.

RING-HAVER POWER CAT TESTING

07-16-2001

CHAN 6  
OUTLET  
TIME ppmNOX

15:19	513.8
15:20	527.5
15:21	515.8
15:22	506.3
15:23	508.2
15:24	512.9
15:25	518.1
15:26	509.6
15:27	502.5
15:28	514.6
15:29	510.4
15:30	499.2
15:31	504.3
15:32	509.3
15:33	514.3
15:34	514.6
15:35	519.4
15:36	522.1
15:37	510.1
15:38	502.5
15:39	492.5
15:40	505.9
15:41	511.6
15:42	512.3
15:43	513.7
15:44	514.3
15:45	494.7
15:46	520.1
15:47	511.5
15:48	518.1
15:49	517.1
15:50	506.7
15:51	510.0
15:52	530.1
15:53	525.1
15:54	519.8
15:55	525.8
15:56	522.8
15:57	525.1
15:58	525.4
15:59	518.3
16:00	507.9
16:01	515.0
16:02	525.9
16:03	514.4
16:04	517.4
16:05	514.1
16:06	509.7
16:07	507.8
16:08	528.8
16:09	508.3
16:10	503.5
16:11	515.1
16:12	512.3
16:13	511.7

RING-HAVER POWER CAT TESTING

07-16-2001

CHAN 6

OUTLET

TIME ppmNOX

16:14 521.4

16:15 515.9

16:16 520.1

16:17 512.5

16:18 515.6

-----  
AVERAGE VALUES FOR THE LAST HOUR: 60 MINUTES OF VALID DATA

16:18 513.9  
-----

COMMENTS: END RUN THREE  
CAT UNIT 27

RING-HAVER POWER CAT TESTING

07-18-2001

TIME	CHAN 4 OUTLET ppmNOX	CHAN 5 OUTLET ppmNO
09:29	675.4	661.1
09:30	668.7	656.4
09:31	682.4	672.1
09:32	676.6	659.3
09:33	663.1	648.2
09:34	653.1	640.7
09:35	650.8	639.0
09:36	646.5	634.5
09:37	643.9	632.6
09:38	639.0	626.4
09:39	633.9	621.3
09:40	627.9	616.7
09:41	624.0	611.7
09:42	620.0	608.9
09:43	615.6	605.4
09:44	614.2	602.8
09:45	611.3	600.4
09:46	610.9	601.4
09:47	608.1	597.2
09:48	605.7	594.2
09:49	603.5	594.0
09:50	602.6	591.9
09:51	600.1	589.0
09:52	595.4	585.7
09:53	592.4	582.1
09:54	587.7	577.6
09:55	587.0	576.4
09:56	586.2	575.8
09:57	581.1	571.5
09:58	579.0	568.7
09:59	576.5	566.2
10:00	576.3	565.5
10:01	575.6	565.2
10:02	572.6	562.3
10:03	571.6	560.3
10:04	567.4	557.4
10:05	569.1	559.5
10:06	567.2	557.5
10:07	565.8	558.6
10:08	566.8	557.3
10:09	564.1	554.1
10:10	561.9	552.4
10:11	562.6	553.1
10:12	565.3	555.9
10:13	571.2	560.9
10:14	570.3	559.7
10:15	566.0	556.5
10:16	562.4	554.1
10:17	562.9	554.4
10:18	562.5	553.1
10:19	559.6	551.0
10:20	557.7	548.2
10:21	555.0	548.3
10:22	558.5	551.5
10:23	557.7	547.8

RING-HAVER POWER CAT TESTING

07-18-2001

TIME	CHAN 4 OUTLET ppmNOX	CHAN 5 OUTLET ppmNO
10:24	554.8	546.1
10:25	555.0	547.3
10:26	552.3	542.5
10:27	553.3	544.3
10:28	553.5	542.6

-----  
AVERAGE VALUES FOR THE LAST HOUR: 60 MINUTES OF VALID DATA

10:28	593.4	582.9
-------	-------	-------

-----

COMMENTS: END RUN ONE  
CAT UNIT 28

RING-HAVER POWER CAT TESTING

07-18-2001

TIME	CHAN 4 OUTLET ppmNOX	CHAN 5 OUTLET ppmNO
10:46	542.9	534.8
10:47	541.1	532.2
10:48	543.0	534.0
10:49	540.0	532.3
10:50	540.5	531.8
10:51	538.6	531.5
10:52	536.7	529.7
10:53	535.6	527.4
10:54	535.9	528.1
10:55	532.3	524.1
10:56	527.1	518.9
10:57	528.3	520.3
10:58	528.4	521.2
10:59	528.0	519.8
11:00	528.0	518.8
11:01	524.9	516.3
11:02	522.9	514.9
11:03	523.8	515.0
11:04	526.9	518.3
11:05	526.1	517.9
11:06	525.3	517.4
11:07	524.0	516.3
11:08	520.2	512.7
11:09	518.8	512.2
11:10	522.7	516.1
11:11	523.3	516.9
11:12	518.8	512.8
11:13	518.4	512.4
11:14	518.0	512.5
11:15	520.7	512.8
11:16	521.2	515.4
11:17	522.6	515.8
11:18	522.0	514.4
11:19	519.9	513.1
11:20	521.0	513.8
11:21	520.8	513.6
11:22	519.1	510.4
11:23	519.5	511.0
11:24	520.8	512.7
11:25	522.9	514.6
11:26	521.0	512.7
11:27	518.5	510.9
11:28	515.8	507.9
11:29	516.4	509.5
11:30	516.4	510.4
11:31	514.2	506.9
11:32	515.1	507.2
11:33	513.9	507.8
11:34	516.6	509.3
11:35	517.3	509.6
11:36	518.9	511.1
11:37	517.8	510.7
11:38	520.4	513.1
11:39	517.2	509.7
11:40	516.1	508.5

## RING-HAVER POWER CAT TESTING

07-18-2001

TIME	CHAN 4 OUTLET ppmNOX	CHAN 5 OUTLET ppmNO
11:41	515.0	507.1
11:42	515.3	507.9
11:43	516.7	509.2
11:44	515.8	509.9
11:45	520.0	512.3

-----  
AVERAGE VALUES FOR THE LAST HOUR: 60 MINUTES OF VALID DATA

11:45	523.5	515.9
-------	-------	-------

  
-----COMMENTS: END RUN TWO  
CAT UNIT 28

RING-HAVER POWER CAT TESTING

07-18-2001

TIME	CHAN 4	CHAN 5
	OUTLET	OUTLET
	ppmNOX	ppmNO
12:07	539.6	530.2
12:08	539.0	530.3
12:09	536.2	528.0
12:10	532.3	524.3
12:11	526.8	518.8
12:12	525.0	517.7
12:13	522.7	514.5
12:14	520.8	512.4
12:15	519.9	511.6
12:16	517.7	509.1
12:17	515.8	508.3
12:18	514.1	506.8
12:19	516.3	509.7
12:20	517.8	510.9
12:21	516.9	509.1
12:22	518.3	512.7
12:23	525.3	517.9
12:24	523.0	513.7
12:25	516.1	508.5
12:26	513.9	508.0
12:27	519.4	512.7
12:28	519.4	511.2
12:29	515.5	507.0
12:30	517.0	509.8
12:31	516.2	508.8
12:32	513.6	507.5
12:33	514.2	507.6
12:34	514.4	506.2
12:35	512.8	504.1
12:36	512.2	504.9
12:37	509.3	501.8
12:38	506.3	498.5
12:39	504.5	497.9
12:40	504.6	498.1
12:41	504.8	497.6
12:42	505.3	497.9
12:43	503.5	496.1
12:44	505.0	498.2
12:45	503.8	498.5
12:46	505.7	498.7
12:47	506.8	498.6
12:48	504.7	497.5
12:49	504.4	496.7
12:50	502.7	495.2
12:51	502.1	492.3
12:52	489.1	480.1
12:53	482.6	476.3
12:54	479.7	473.5
12:55	478.2	472.0
12:56	478.7	472.0
12:57	478.7	472.7
12:58	479.2	473.1
12:59	479.9	476.2
13:00	480.5	474.4
13:01	480.1	473.4

## RING-HAVER POWER CAT TESTING

07-18-2001

	CHAN 4	CHAN 5
	OUTLET	OUTLET
TIME	ppmNOX	ppmNO
13:02	479.8	473.7
13:03	478.7	472.0
13:04	477.8	471.5
13:05	478.3	471.6
13:06	478.5	472.1

-----  
AVERAGE VALUES FOR THE LAST HOUR: 60 MINUTES OF VALID DATA

13:06	506.4	499.2
-------	-------	-------

  
-----COMMENTS: END RUN THREE  
CAT UNIT 28

RING-HAVER POWER CAT TESTING 07-18-2001

TIME	CHAN 4 OUTLET ppmNOX	CHAN 5 OUTLET ppmNO
14:16	563.2	552.2
14:17	559.3	547.9
14:18	556.6	548.1
14:19	558.5	548.8
14:20	558.0	548.4
14:21	558.4	549.1
14:22	562.3	552.6
14:23	562.1	553.7
14:24	566.7	557.8
14:25	567.8	559.3
14:26	567.3	556.4
14:27	565.1	556.3
14:28	566.7	557.2
14:29	566.0	555.6
14:30	563.5	553.9
14:31	565.9	557.0
14:32	573.1	564.1
14:33	574.4	562.7
14:34	573.0	564.5
14:35	577.4	569.1
14:36	577.3	567.4
14:37	573.7	565.8
14:38	576.0	567.4
14:39	575.7	566.2
14:40	576.3	566.1
14:41	573.5	563.2
14:42	573.6	564.3
14:43	575.5	564.8
14:44	573.7	561.5
14:45	569.7	558.5
14:46	567.7	557.9
14:47	566.6	555.6
14:48	566.4	556.2
14:49	573.8	564.3
14:50	572.8	562.6
14:51	570.3	560.0
14:52	569.6	559.9
14:53	570.4	559.9
14:54	568.8	558.5
14:55	568.1	557.2
14:56	566.1	555.3
14:57	565.9	555.8
14:58	566.4	556.7
14:59	565.0	554.8
15:00	561.8	551.8
15:01	561.3	552.2
15:02	559.5	549.7
15:03	563.2	554.0
15:04	564.8	554.1
15:05	563.8	553.8
15:06	558.7	549.0
15:07	561.9	554.3
15:08	567.7	558.7
15:09	561.6	551.5
15:10	565.3	556.6

RING-HAVER POWER CAT TESTING

07-18-2001

	CHAN 4	CHAN 5
	OUTLET	OUTLET
TIME	ppmNOX	ppmNO
15:11	564.6	554.2
15:12	565.4	556.9
15:13	566.0	557.5
15:14	564.1	556.2
15:15	564.5	555.6

-----  
AVERAGE VALUES FOR THE LAST HOUR: 60 MINUTES OF VALID DATA

15:15	567.0	557.3
-------	-------	-------

-----

COMMENTS: END RUN ONE  
CAT UNIT 29

## RING-HAVER POWER CAT TESTING

07-18-2001

TIME	CHAN 4 OUTLET ppmNOX	CHAN 5 OUTLET ppmNO
15:34	587.7	577.3
15:35	587.6	575.9
15:36	583.4	573.4
15:37	581.9	572.6
15:38	582.7	570.6
15:39	576.9	566.5
15:40	577.2	566.2
15:41	580.4	569.4
15:42	574.3	564.9
15:43	571.9	562.3
15:44	572.2	561.8
15:45	568.4	558.5
15:46	569.7	561.1
15:47	574.3	565.1
15:48	572.7	563.7
15:49	572.5	560.7
15:50	566.9	556.9
15:51	564.2	554.6
15:52	563.6	553.6
15:53	563.8	553.6
15:54	560.7	552.4
15:55	563.0	554.5
15:56	564.7	554.2
15:57	563.0	552.7
15:58	562.3	551.8
15:59	558.9	549.7
16:00	558.6	550.1
16:01	557.5	549.9
16:02	560.3	551.0
16:03	559.5	549.5
16:04	558.2	548.6
16:05	558.8	550.2
16:06	559.3	550.1
16:07	559.8	551.5
16:08	561.5	553.4
16:09	560.1	550.1
16:10	561.2	553.4
16:11	563.5	553.1
16:12	562.3	552.2
16:13	563.4	553.0
16:14	561.3	552.5
16:15	563.5	551.4
16:16	559.2	549.1
16:17	561.6	552.4
16:18	561.4	551.9
16:19	560.0	551.2
16:20	561.8	552.2
16:21	561.1	551.5
16:22	556.8	548.4
16:23	559.5	552.0
16:24	560.6	551.6
16:25	561.1	551.0
16:26	560.6	549.7
16:27	558.7	550.3
16:28	565.5	556.6

## RING-HAVER POWER CAT TESTING

07-18-2001

	CHAN 4	CHAN 5
	OUTLET	OUTLET
TIME	ppmNOX	ppmNO
16:29	565.1	556.5
16:30	565.7	557.7
16:31	566.8	558.7
16:32	561.8	553.5
16:33	564.2	554.4

-----  
AVERAGE VALUES FOR THE LAST HOUR: 60 MINUTES OF VALID DATA

16:33	565.8	556.2
-------	-------	-------

  
-----COMMENTS: END RUN TWO  
CAT UNIT 29

RING-HAYER POWER CAT TESTING

07-18-2001

TIME	CHAN 4 OUTLET ppmNOX	CHAN 5 OUTLET ppmNO
16:51	571.5	561.2
16:52	569.3	558.2
16:53	565.7	556.6
16:54	568.6	559.3
16:55	569.7	559.9
16:56	567.3	557.0
16:57	562.3	552.2
16:58	560.1	552.7
16:59	562.4	552.0
17:00	559.6	550.9
17:01	558.8	548.1
17:02	557.6	549.0
17:03	558.1	548.0
17:04	558.3	548.2
17:05	557.0	545.0
17:06	554.5	545.1
17:07	554.3	543.9
17:08	553.3	542.7
17:09	554.0	543.0
17:10	552.6	543.2
17:11	552.2	543.3
17:12	551.9	544.2
17:13	551.4	543.9
17:14	550.7	541.6
17:15	550.3	540.8
17:16	553.3	544.8
17:17	552.2	542.2
17:18	551.6	542.0
17:19	551.8	542.8
17:20	553.4	544.4
17:21	554.4	544.5
17:22	553.1	543.5
17:23	553.3	543.1
17:24	551.9	542.2
17:25	551.7	542.8
17:26	549.9	541.9
17:27	547.7	539.5
17:28	546.2	537.7
17:29	549.6	540.4
17:30	548.9	538.3
17:31	544.6	535.3
17:32	549.7	540.7
17:33	552.2	541.8
17:34	552.8	542.9
17:35	552.6	542.5
17:36	550.2	541.2
17:37	553.3	544.8
17:38	553.1	543.8
17:39	553.0	544.0
17:40	553.9	543.5
17:41	552.8	543.0
17:42	549.7	540.6
17:43	549.3	541.2
17:44	551.1	541.8
17:45	550.0	541.5

## RING-HAVER POWER CAT TESTING

07-18-2001

	CHAN 4	CHAN 5
	OUTLET	OUTLET
TIME	ppmNOX	ppmNO
17:46	548.6	539.5
17:47	550.4	541.4
17:48	553.0	542.8
17:49	552.3	541.5
17:50	549.3	540.0

-----  
AVERAGE VALUES FOR THE LAST HOUR: 60 MINUTES OF VALID DATA

17:50	554.4	544.9
-------	-------	-------

  
-----COMMENTS: END RUN THREE  
CAT UNIT 29

RING-HAVER POWER CAT TESTING

07-19-2001

TIME	CHAN 4	CHAN 5
	OUTLET	OUTLET
	ppmNOX	ppmNO
06:51	638.5	624.2
06:52	634.5	618.5
06:53	629.6	614.2
06:54	625.6	610.9
06:55	622.6	608.3
06:56	619.6	606.2
06:57	617.5	603.2
06:58	614.6	600.4
06:59	612.7	598.2
07:00	608.9	595.1
07:01	605.6	592.3
07:02	601.7	589.8
07:03	597.6	584.8
07:04	597.6	583.5
07:05	596.2	582.6
07:06	591.2	577.9
07:07	586.6	573.3
07:08	583.7	570.9
07:09	580.6	569.1
07:10	578.5	566.6
07:11	577.8	565.6
07:12	576.7	565.3
07:13	576.2	564.0
07:14	573.8	563.2
07:15	571.9	560.2
07:16	570.7	559.4
07:17	569.4	557.4
07:18	566.8	555.6
07:19	566.8	556.7
07:20	566.4	555.0
07:21	564.0	552.7
07:22	563.4	552.5
07:23	565.2	552.5
07:24	565.4	552.3
07:25	563.9	552.6
07:26	564.1	551.2
07:27	562.0	549.4
07:28	560.3	549.0
07:29	559.4	547.2
07:30	558.5	546.4
07:31	557.8	545.8
07:32	557.9	546.0
07:33	556.1	545.0
07:34	556.8	546.1
07:35	555.6	545.6
07:36	554.6	543.3
07:37	553.1	542.8
07:38	551.6	541.0
07:39	551.2	539.1
07:40	549.1	537.2
07:41	548.0	535.9
07:42	547.3	536.1
07:43	546.0	535.9
07:44	546.1	536.3
07:45	545.3	535.2

RING-HAVER POWER CAT TESTING

07-19-2001

	CHAN 4	CHAN 5
	OUTLET	OUTLET
TIME	ppmNOX	ppmNO
07:46	546.7	535.6
07:47	549.2	538.3
07:48	549.2	538.4
07:49	548.6	536.9
07:50	548.1	535.9

-----  
AVERAGE VALUES FOR THE LAST HOUR: 60 MINUTES OF VALID DATA

07:50	575.1	562.9
-------	-------	-------

-----

COMMENTS: END RUN ONE  
CAT UNIT 30

## RING-HAVER POWER CAT TESTING

07-19-2001

TIME	CHAN 4	CHAN 5
	OUTLET	OUTLET
	ppmNOX	ppmNO
08:08	561.2	549.8
08:09	558.9	548.0
08:10	556.3	545.8
08:11	554.1	543.7
08:12	554.2	542.5
08:13	553.1	540.3
08:14	551.2	538.2
08:15	548.2	536.0
08:16	545.2	534.5
08:17	545.3	534.3
08:18	546.9	537.4
08:19	546.6	534.9
08:20	542.8	532.3
08:21	542.8	531.3
08:22	539.7	529.9
08:23	538.9	528.6
08:24	538.8	527.3
08:25	538.4	527.3
08:26	537.9	527.0
08:27	537.1	525.9
08:28	533.7	523.6
08:29	533.0	522.6
08:30	531.3	521.0
08:31	529.9	519.7
08:32	532.3	521.8
08:33	534.1	524.3
08:34	533.7	524.2
08:35	533.9	524.1
08:36	534.6	524.8
08:37	537.0	526.6
08:38	534.4	524.5
08:39	533.0	521.7
08:40	547.4	535.0
08:41	547.6	536.8
08:42	544.1	533.7
08:43	542.9	532.4
08:44	539.4	527.7
08:45	537.6	525.7
08:46	535.1	523.4
08:47	531.8	520.5
08:48	531.4	520.7
08:49	532.6	522.9
08:50	532.4	522.1
08:51	531.5	520.9
08:52	532.3	521.5
08:53	530.4	519.8
08:54	529.2	518.2
08:55	527.5	516.8
08:56	527.3	517.9
08:57	528.6	518.0
08:58	527.1	516.3
08:59	525.6	514.1
09:00	525.1	514.7
09:01	522.6	512.7
09:02	522.4	512.4

## RING-HAVER POWER CAT TESTING

07-19-2001

	CHAN 4	CHAN 5
	OUTLET	OUTLET
TIME	ppmNOX	ppmNO
09:03	522.9	511.6
09:04	522.6	511.5
09:05	521.7	511.0
09:06	519.7	510.8
09:07	521.4	512.3

-----  
AVERAGE VALUES FOR THE LAST HOUR: 60 MINUTES OF VALID DATA

09:07	536.6	525.9
-------	-------	-------

  
-----COMMENTS: END RUN TWO  
CAT UNIT 30

RING-HAVER POWER CAT TESTING

07-19-2001

TIME	CHAN 4 OUTLET ppmNOX	CHAN 5 OUTLET ppmNO
09:28	643.0	627.9
09:29	642.0	627.3
09:30	639.4	624.7
09:31	633.5	619.0
09:32	637.6	626.2
09:33	640.2	624.7
09:34	632.9	617.1
09:35	630.6	615.6
09:36	625.1	610.7
09:37	621.0	605.9
09:38	616.2	603.1
09:39	615.3	603.7
09:40	619.0	606.5
09:41	621.9	609.0
09:42	620.1	606.1
09:43	616.0	601.6
09:44	612.5	598.8
09:45	609.3	596.2
09:46	606.1	594.1
09:47	607.9	596.1
09:48	615.1	602.4
09:49	618.5	606.7
09:50	620.9	606.8
09:51	615.6	600.8
09:52	609.6	596.3
09:53	612.1	600.3
09:54	613.9	600.0
09:55	611.5	598.9
09:56	611.6	600.2
09:57	614.9	601.6
09:58	612.8	599.2
09:59	612.3	599.3
10:00	611.2	597.3
10:01	609.6	596.8
10:02	610.2	597.1
10:03	607.0	594.6
10:04	607.8	596.6
10:05	612.6	599.8
10:06	612.8	599.1
10:07	610.3	597.1
10:08	608.8	596.9
10:09	610.9	598.1
10:10	606.8	593.1
10:11	601.9	589.4
10:12	600.6	589.3
10:13	601.5	588.2
10:14	600.0	586.9
10:15	601.0	589.5
10:16	600.9	589.0
10:17	600.5	587.5
10:18	598.8	585.0
10:19	600.1	587.3
10:20	601.1	586.2
10:21	598.0	585.1
10:22	600.0	587.7

## RING-HAVER POWER CAT TESTING

07-19-2001

	CHAN 4	CHAN 5
	OUTLET	OUTLET
TIME	ppmNOX	ppmNO
10:23	601.2	588.9
10:24	600.5	586.2
10:25	588.3	574.9
10:26	582.2	570.5
10:27	584.6	572.6

-----  
AVERAGE VALUES FOR THE LAST HOUR: 60 MINUTES OF VALID DATA

10:27	612.1	599.0
-------	-------	-------

  
-----COMMENTS: END RUN THREE  
CAT UNIT 30

C. VISIBLE EMISSIONS DATA SHEETS

SOURCE NAME: *Hobbs Court 10 Engines*  
SOURCE LOCATION: *Tampa*


OBSERVATION DATE: *7/19/2001*  
START TIME: *11:23*  
STOP TIME: *11:53*

TYPE OF FACILITY: *Trailer Diesel Generator*

SEC.	MIN	0	15	30	45	SEC	MIN	0	15	30	45
------	-----	---	----	----	----	-----	-----	---	----	----	----

DISTANCE FROM OBSERVER: *~70'*

SKY CONDITIONS/PLUME BACKGROUND: *broken / tampa skyline as background (gray/green)*



AVERAGE OPACITY: *5.8%*

WIND SPEED (EST.): *light ~3-8 mph*  
WIND DIRECTION (EST.): *SSW to S variable*

OBSERVER'S NAME (PRINT): *K.A. McDarby*

OBSERVER'S SIGNATURE: *[Signature]*  
DATE: *7/19/2001*

COMMENTS: *Power Unit #26.*

1	5	0	5	5	31				
2	5	5	5	5	32				
3	0	5	5	5	33				
4	5	5	5	5	34				
5	10	10	5	10	35				
6	10	10	10	5	36				
7	5	5	5	5	37				
8	5	5	5	5	38				
9	5	5	5	5	39				
10	5	5	5	5	40				
11	5	5	10	5	41				
12	10	5	5	5	42				
13	5	5	5	10	43				
14	5	5	10	5	44				
15	5	5	5	5	45				
16	5	10	10	5	46				
17	5	5	5	5	47				
18	10	5	5	5	48				
19	5	10	10	5	49				
20	5	5	5	5	50				
21	5	5	5	5	51				
22	5	5	5	5	52				
23	10	5	5	5	53				
24	10	10	5	5	54				
25	5	5	5	5	55				
26	5	10	5	5	56				
27	5	5	5	5	57				
28	10	5	5	5	58				
29	5	5	5	5	59				
30	10	5	5	5	60				



State of Florida  
**Department of Environmental Protection**

This is to Certify That **RAY MCDARBY**  
has completed the STATE OF FLORIDA visible emissions evaluation training and is a qualified observer of visible emissions as specified by EPA reference method 9.

This Certificate Expires **Aug 22, 2001**

*[Signature]*  
Certificate Officer

*[Signature]*  
Bearer's Signature

**VISIBLE EMISSION OBSERVATION**

E-496 R 10/85

SOURCE NAME		SOURCE LOCATION		OBSERVATION DATE				START TIME		STOP TIME			
H. Oles Pt. 1C Engine		Tampa		7/14/2001				14:49		15:19			
TYPE OF FACILITY		DISTANCE FROM OBSERVER		SEC.				MIN		SEC			
Trailer Diesel Generator		~100'		MIN	0	15	30	45	MIN	0	15	30	45
SKY CONDITIONS/PLUME BACKGROUND		1		2		3		4		5		6	
Overcast / green (trees)		5		5		5		5		31			
SOURCE LAYOUT SKETCH		DRAW NORTH ARROW		7		8		9		10		11	
<p>WINDS WERE VARIABLE</p>				10		10		10		33			
AVERAGE OPACITY		12		13		14		15		16		17	
6.2%		5		5		10		10		42			
WIND SPEED (EST.)		WIND DIRECTION (EST.)		18		19		20		21		22	
light ~3 to 8 mph		variable		5		5		5		43			
OBSERVER'S NAME (PRINT)		OBSERVER'S SIGNATURE		DATE		23		24		25		26	
R.A. McDarby				7/14/2001		5		5		44			
COMMENTS		27		28		29		30		31		32	
Power Unit #27 Thunderstorms forming + moving to NNW Exhaust temperatures ~800°F, some "swirling" of plume.		5		5		5		5		46			
COPY OF		30		31		32		33		34		35	
		5		5		5		5		47			
		10		5		10		10		48			
		5		5		5		5		49			
		20		21		22		23		24		25	
		5		5		10		5		50			
		26		27		28		29		30		31	
		5		5		5		10		51			
		22		23		24		25		26		27	
		5		5		5		5		52			
		28		29		30		31		32		33	
		5		5		5		5		53			
		34		35		36		37		38		39	
		5		10		5		5		54			
		40		41		42		43		44		45	
		5		5		5		5		55			
		46		47		48		49		50		51	
		5		5		10		5		56			
		52		53		54		55		56		57	
		5		5		5		5		57			
		58		59		60		61		62		63	
		5		10		5		5		58			
		64		65		66		67		68		69	
		5		5		5		5		59			
		70		71		72		73		74		75	
		10		5		5		5		60			



State of Florida  
Department of  
Environmental Protection

This is to Certify That RAY MCDARBY

has completed the STATE OF FLORIDA visible emissions evaluation training and is a qualified observer of visible emissions as specified by EPA reference method 9.

This Certificate Expires Aug 22, 2001

Certificate Officer

Bearer's Signature

**VISIBLE EMISSION OBSERVATION**

E-496 R 10/85

SOURCE NAME: *Hookers Point 10 Engine*  
SOURCE LOCATION: *Tampa*


OBSERVATION DATE: *7/10/2001*  
START TIME: *10 15*  
STOP TIME: *10 45*

TYPE OF FACILITY: *Tractor Diesel Generator*

SEC.	MIN	0	15	30	45	SEC	MIN	0	15	30	45
1	5	5	5	5	5	31					
2	5	∅	5	5	5	32					
3	5	5	5	5	5	33					
4	5	5	5	10	5	34					
5	5	5	5	∅	5	35					
6	5	5	5	5	5	36					
7	5	5	5	5	5	37					
8	5	5	5	5	5	38					
9	5	10	5	5	5	39					
10	5	5	5	5	5	40					
11	5	5	5	5	5	41					
12	∅	∅	5	5	5	42					
13	5	5	5	5	5	43					
14	5	5	5	∅	5	44					
15	∅	5	5	5	5	45					
16	∅	∅	5	10	5	46					
17	5	5	5	5	5	47					
18	5	5	5	5	5	48					
19	5	5	5	5	5	49					
20	10	5	5	5	5	50					
21	5	5	5	5	5	51					
22	10	5	5	5	5	52					
23	5	5	5	5	5	53					
24	5	5	10	5	5	54					
25	5	5	5	5	5	55					
26	5	5	5	5	5	56					
27	5	5	5	5	5	57					
28	5	5	5	5	5	58					
29	5	5	5	5	5	59					
30	5	5	5	5	5	60					

DISTANCE FROM OBSERVER: *~90'*

SKY CONDITIONS/PLUME BACKGROUND: *clear skies / background is Tampa skyline*



AVERAGE OPACITY: *4.990*

WIND SPEED (EST.): *light / variable ~3-8 mph*  
WIND DIRECTION (EST.): *~5*

OBSERVER'S NAME (PRINT): *R.A. McDarby*

OBSERVER'S SIGNATURE: *[Signature]*  
DATE: *7/10/2001*

COMMENTS: *Power Unit #28*

COPY OF



This is to Certify That **RAY MCDARBY**  
has completed the STATE OF FLORIDA visible emissions evaluation training and is a qualified observer of visible emissions as specified by EPA reference method 9.

This Certificate Expires **Aug 22, 2001**

*[Signature]* Certificate Officer  
*[Signature]* Bearer's Signature

SEC.	MIN	0	15	30	45	SEC	MIN	0	15	30	45
1	5	5	5	5	5	31					
2	5	∅	5	5	5	32					
3	5	5	5	5	5	33					
4	5	5	5	10	5	34					
5	5	5	5	∅	5	35					
6	5	5	5	5	5	36					
7	5	5	5	5	5	37					
8	5	5	5	5	5	38					
9	5	10	5	5	5	39					
10	5	5	5	5	5	40					
11	5	5	5	5	5	41					
12	∅	∅	5	5	5	42					
13	5	5	5	5	5	43					
14	5	5	5	∅	5	44					
15	∅	5	5	5	5	45					
16	∅	∅	5	10	5	46					
17	5	5	5	5	5	47					
18	5	5	5	5	5	48					
19	5	5	5	5	5	49					
20	10	5	5	5	5	50					
21	5	5	5	5	5	51					
22	10	5	5	5	5	52					
23	5	5	5	5	5	53					
24	5	5	10	5	5	54					
25	5	5	5	5	5	55					
26	5	5	5	5	5	56					
27	5	5	5	5	5	57					
28	5	5	5	5	5	58					
29	5	5	5	5	5	59					
30	5	5	5	5	5	60					

SOURCE NAME		SOURCE LOCATION		OBSERVATION DATE				START TIME		STOP TIME			
Hollow Point KC Engine		Tampa		7/18/2001				1015		1045			
TYPE OF FACILITY		DISTANCE FROM OBSERVER		SEC.		MIN		SEC		MIN			
Trailend Diesel Generator		~ 90'		MIN	0	15	30	45	MIN	0	15	30	45
SKY CONDITIONS/PLUME BACKGROUND		clear skies / background is Tampa sky / in											
SOURCE LAYOUT SKETCH		DRAW NORTH ARROW											
AVERAGE OPACITY		5.7											
WIND SPEED (EST.)		WIND DIRECTION (EST.)											
Light/variable ~ 3-8 mph		~ S											
OBSERVER'S NAME (PRINT)		OBSERVER'S SIGNATURE		DATE									
K.A. McDarby				7/18/2001									
COMMENTS		Point unit # 29											
COPY OF													



State of Florida  
**Department of Environmental Protection**

This is to Certify That **RAY MCDARBY**

has completed the STATE OF FLORIDA visible emissions evaluation training and is a qualified observer of visible emissions as specified by EPA reference method 9.

This Certificate Expires **Aug 22, 2001**

Certificate Officer

Bearer's Signature

1	5	0	5	5	31						
2	5	5	5	5	32						
3	5	0	5	5	33						
4	10	5	5	5	34						
5	5	5	5	5	35						
6	5	10	5	5	36						
7	5	10	5	10	37						
8	5	5	10	5	38						
9	10	10	5	10	39						
10	5	10	5	5	40						
11	0	5	5	5	41						
12	5	5	5	5	42						
13	5	10	5	10	43						
14	5	5	5	5	44						
15	0	5	5	5	45						
16	5	5	5	10	46						
17	5	5	5	5	47						
18	5	10	5	5	48						
19	5	5	10	5	49						
20	5	5	5	5	50						
21	5	5	5	5	51						
22	10	10	5	10	52						
23	5	5	5	5	53						
24	5	5	5	5	54						
25	5	5	5	5	55						
26	5	5	10	5	56						
27	5	5	5	5	57						
28	5	5	5	5	58						
29	5	5	5	5	59						
30	5	10	5	10	60						

SOURCE NAME		SOURCE LOCATION		OBSERVATION DATE				START TIME		STOP TIME																																																																																																																																																																																																																																																																																																																																																																																																								
Hookers Point IC Engine		Tampa		7/19/2001				10:29		10:59																																																																																																																																																																																																																																																																																																																																																																																																								
TYPE OF FACILITY		DISTANCE FROM OBSERVER		SEC.				MIN		SEC																																																																																																																																																																																																																																																																																																																																																																																																								
Trailer Diesel Generator		~70'		MIN	0	15	30	45	MIN	0	15	30	45																																																																																																																																																																																																																																																																																																																																																																																																					
SKY CONDITIONS/PLUME BACKGROUND		broken / background is Hookers Point facility tan/green																																																																																																																																																																																																																																																																																																																																																																																																																
SOURCE LAYOUT SKETCH		DRAW NORTH ARROW																																																																																																																																																																																																																																																																																																																																																																																																																
		<table border="1"> <tr><td>1</td><td>5</td><td>5</td><td>5</td><td>5</td><td>31</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>2</td><td>5</td><td>5</td><td>5</td><td>5</td><td>32</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>3</td><td>5</td><td>5</td><td>5</td><td>5</td><td>33</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>4</td><td>5</td><td>5</td><td>5</td><td>5</td><td>34</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>5</td><td>5</td><td>5</td><td>5</td><td>5</td><td>35</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>6</td><td>5</td><td>5</td><td>5</td><td>5</td><td>36</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>7</td><td>5</td><td>5</td><td>5</td><td>5</td><td>37</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>8</td><td>5</td><td>10</td><td>5</td><td>5</td><td>38</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>9</td><td>5</td><td>5</td><td>5</td><td>10</td><td>39</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>10</td><td>5</td><td>5</td><td>5</td><td>5</td><td>40</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>11</td><td>10</td><td>5</td><td>5</td><td>5</td><td>41</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>12</td><td>5</td><td>5</td><td>5</td><td>5</td><td>42</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>13</td><td>5</td><td>10</td><td>5</td><td>5</td><td>43</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>14</td><td>5</td><td>5</td><td>5</td><td>5</td><td>44</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>15</td><td>5</td><td>5</td><td>5</td><td>5</td><td>45</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>16</td><td>5</td><td>5</td><td>5</td><td>5</td><td>46</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>17</td><td>5</td><td>5</td><td>5</td><td>5</td><td>47</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>18</td><td>5</td><td>5</td><td>10</td><td>5</td><td>48</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>19</td><td>5</td><td>5</td><td>5</td><td>5</td><td>49</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>20</td><td>5</td><td>5</td><td>5</td><td>5</td><td>50</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>21</td><td>5</td><td>5</td><td>5</td><td>5</td><td>51</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>22</td><td>5</td><td>5</td><td>5</td><td>5</td><td>52</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>23</td><td>5</td><td>5</td><td>5</td><td>10</td><td>53</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>24</td><td>5</td><td>5</td><td>5</td><td>5</td><td>54</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>25</td><td>5</td><td>5</td><td>5</td><td>5</td><td>55</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>26</td><td>5</td><td>5</td><td>5</td><td>5</td><td>56</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>27</td><td>5</td><td>5</td><td>5</td><td>5</td><td>57</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>28</td><td>5</td><td>5</td><td>5</td><td>5</td><td>58</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>29</td><td>10</td><td>5</td><td>5</td><td>5</td><td>59</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td>30</td><td>5</td><td>5</td><td>5</td><td>5</td><td>60</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </table>											1	5	5	5	5	31								2	5	5	5	5	32								3	5	5	5	5	33								4	5	5	5	5	34								5	5	5	5	5	35								6	5	5	5	5	36								7	5	5	5	5	37								8	5	10	5	5	38								9	5	5	5	10	39								10	5	5	5	5	40								11	10	5	5	5	41								12	5	5	5	5	42								13	5	10	5	5	43								14	5	5	5	5	44								15	5	5	5	5	45								16	5	5	5	5	46								17	5	5	5	5	47								18	5	5	10	5	48								19	5	5	5	5	49								20	5	5	5	5	50								21	5	5	5	5	51								22	5	5	5	5	52								23	5	5	5	10	53								24	5	5	5	5	54								25	5	5	5	5	55								26	5	5	5	5	56								27	5	5	5	5	57								28	5	5	5	5	58								29	10	5	5	5	59								30	5	5	5	5	60							
1	5	5	5	5	31																																																																																																																																																																																																																																																																																																																																																																																																													
2	5	5	5	5	32																																																																																																																																																																																																																																																																																																																																																																																																													
3	5	5	5	5	33																																																																																																																																																																																																																																																																																																																																																																																																													
4	5	5	5	5	34																																																																																																																																																																																																																																																																																																																																																																																																													
5	5	5	5	5	35																																																																																																																																																																																																																																																																																																																																																																																																													
6	5	5	5	5	36																																																																																																																																																																																																																																																																																																																																																																																																													
7	5	5	5	5	37																																																																																																																																																																																																																																																																																																																																																																																																													
8	5	10	5	5	38																																																																																																																																																																																																																																																																																																																																																																																																													
9	5	5	5	10	39																																																																																																																																																																																																																																																																																																																																																																																																													
10	5	5	5	5	40																																																																																																																																																																																																																																																																																																																																																																																																													
11	10	5	5	5	41																																																																																																																																																																																																																																																																																																																																																																																																													
12	5	5	5	5	42																																																																																																																																																																																																																																																																																																																																																																																																													
13	5	10	5	5	43																																																																																																																																																																																																																																																																																																																																																																																																													
14	5	5	5	5	44																																																																																																																																																																																																																																																																																																																																																																																																													
15	5	5	5	5	45																																																																																																																																																																																																																																																																																																																																																																																																													
16	5	5	5	5	46																																																																																																																																																																																																																																																																																																																																																																																																													
17	5	5	5	5	47																																																																																																																																																																																																																																																																																																																																																																																																													
18	5	5	10	5	48																																																																																																																																																																																																																																																																																																																																																																																																													
19	5	5	5	5	49																																																																																																																																																																																																																																																																																																																																																																																																													
20	5	5	5	5	50																																																																																																																																																																																																																																																																																																																																																																																																													
21	5	5	5	5	51																																																																																																																																																																																																																																																																																																																																																																																																													
22	5	5	5	5	52																																																																																																																																																																																																																																																																																																																																																																																																													
23	5	5	5	10	53																																																																																																																																																																																																																																																																																																																																																																																																													
24	5	5	5	5	54																																																																																																																																																																																																																																																																																																																																																																																																													
25	5	5	5	5	55																																																																																																																																																																																																																																																																																																																																																																																																													
26	5	5	5	5	56																																																																																																																																																																																																																																																																																																																																																																																																													
27	5	5	5	5	57																																																																																																																																																																																																																																																																																																																																																																																																													
28	5	5	5	5	58																																																																																																																																																																																																																																																																																																																																																																																																													
29	10	5	5	5	59																																																																																																																																																																																																																																																																																																																																																																																																													
30	5	5	5	5	60																																																																																																																																																																																																																																																																																																																																																																																																													

AVERAGE OPACITY		5.3%												
WIND SPEED (EST.)		WIND DIRECTION (EST.)		light ~3-8 mph ~S to SSW variable										
OBSERVER'S NAME (PRINT)		R.A. McDarby												
OBSERVER'S SIGNATURE		DATE		7/19/2001										
COMMENTS		Power Unit #30												
COPY OF														


State of Florida  
**Department of Environmental Protection**

This is to Certify That **RAY MCDARBY**

has completed the STATE OF FLORIDA visible emissions evaluation training and is a qualified observer of visible emissions as specified by EPA reference method 9.

This Certificate Expires **Aug 22, 2001**

Certificate Officer

Bearer's Signature

**D. TCEMS CALIBRATION DATA**  
D.1 INITIAL/FINAL TCEMS CALIBRATIONS  
D.2 SYSTEM BIAS TESTS  
D.3 SYSTEM BIAS AND DRIFT CALCULATIONS

**D.1 INITIAL/FINAL TCEMS CALIBRATIONS**

CALIBRATION SUMMARY

SOURCE: RING-HAVER POWER CAT TESTING

REASON: INITIAL DAILY CAL UNIT 26

DATE : 07-19-2001 TIME: 11:04 - 11:37

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
4	OUTLET	ppmNOX	0.0	3.1
4	OUTLET	ppmNOX	1268.0	1277.2
4	OUTLET	ppmNOX	2224.0	2222.6
5	OUTLET	ppmNO	0.0	3.1
5	OUTLET	ppmNO	1268.0	1279.5
5	OUTLET	ppmNO	2224.0	2226.5

CONTINUOUS EMISSIONS MONITORING SET-UP

SOURCE: RING-HAVER POWER CAT TESTING

DATE: 07-16-2001 TIME: 12:09

A/D CHAN	DESCRIP	UNITS	SPAN	INPUT VOLTAGE	ZERO OFFSET
6	OUTLET	ppmNOX	2500	10.00 V	0%

AVERAGING PERIODS: ONE HOUR,  
NO EMISSION RATE CALCULATIONS

CALIBRATION SUMMARY

SOURCE: RING-HAVER POWER CAT TESTING

REASON: INITIAL DAILY CAL UNIT 27

DATE : 07-16-2001 TIME: 10:14 - 10:19

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
6	OUTLET	ppmNOX	0.0	0.3
6	OUTLET	ppmNOX	44.7	42.8
6	OUTLET	ppmNOX	92.4	92.8

CALIBRATION SUMMARY

SOURCE: RING-HAVER POWER CAT TESTING

REASON: INITIAL DAILY CAL

DATE : 07-16-2001 TIME: 12:10 - 12:24

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
6	OUTLET	ppmNOX	0.0	0.6
6	OUTLET	ppmNOX	1268.0	1239.8
6	OUTLET	ppmNOX	2224.0	2221.3

## RING-HAVER POWER CAT TESTING

07-16-2001

CHAN 6  
OUTLET  
TIME ppmNOX

10:42	46.0
10:43	46.2
10:44	46.3
10:45	46.4
10:46	46.5
10:47	46.6
10:48	46.7
10:49	46.7
10:50	46.8
10:51	46.9
10:52	46.9
10:53	47.0
10:54	47.0
10:55	47.0
10:56	47.0
10:57	47.1
10:58	47.1
10:59	47.1
11:00	47.1
11:01	47.1
11:02	47.0
11:03	46.8
11:04	46.6
11:05	46.5
11:06	46.3
11:07	46.0
11:08	45.8
11:09	45.8
11:10	45.4
11:11	45.4

AVERAGE VALUES FOR THE LAST 30 MINUTES

11:11 46.6

COMMENTS: END CONVERTER EFFICIENCY TEST

CONTINUOUS EMISSIONS MONITORING SET-UP

SOURCE: RING-HAVER POWER CAT TESTING

DATE: 07-18-2001 TIME: 08:48

A/D CHAN	DESCRIP	UNITS	SPAN	INPUT VOLTAGE	ZERO OFFSET
4	OUTLET	ppmNOX	2500	5.00 V	0%
5	OUTLET	ppmNO	2500	5.00 V	0%

AVERAGING PERIODS: ONE HOUR,  
NO EMISSION RATE CALCULATIONS

CALIBRATION SUMMARY

SOURCE: RING-HAVER POWER CAT TESTING

REASON: INITIAL DAILY CAL

DATE : 07-18-2001      TIME: 08:48 - 09:04

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
4	OUTLET	ppmNOX	0.0	1.5
4	OUTLET	ppmNOX	1268.0	1293.2
4	OUTLET	ppmNOX	2224.0	2234.2
5	OUTLET	ppmNO	0.0	1.5
5	OUTLET	ppmNO	1268.0	1286.6
5	OUTLET	ppmNO	2224.0	2230.9

CALIBRATION SUMMARY

SOURCE: RING-HAVER POWER CAT TESTING

REASON: INITIAL CALIBRATION UNIT 29

DATE : 07-18-2001      TIME: 13:35 - 13:57

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
4	OUTLET	ppmNOX	0.0	1.5
4	OUTLET	ppmNOX	1268.0	1285.9
4	OUTLET	ppmNOX	2224.0	2222.9
5	OUTLET	ppmNO	0.0	1.5
5	OUTLET	ppmNO	1268.0	1285.2
5	OUTLET	ppmNO	2224.0	2226.5

## CALIBRATION SUMMARY

SOURCE: RING-HAVER POWER CAT TESTING

REASON: INITIAL DAILY CAL

DATE : 07-19-2001      TIME: 05:56 - 06:22

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
4	OUTLET	ppmNOX	0.0	1.7
4	OUTLET	ppmNOX	1268.0	1271.2
4	OUTLET	ppmNOX	2224.0	2229.8
5	OUTLET	ppmNO	0.0	1.7
5	OUTLET	ppmNO	1268.0	1271.8
5	OUTLET	ppmNO	2224.0	2224.8

## D.2 SYSTEM BIAS TESTS

CALIBRATION SUMMARY

SOURCE: RING-HAVER POWER CAT TESTING

REASON: RUN ONE BIAS CAL UNIT 26

DATE : 07-19-2001 TIME: 12:44 - 12:51

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
4	OUTLET	ppmNOX	0.0	4.6
4	OUTLET	ppmNOX	1268.0	1276.9
5	OUTLET	ppmNO	0.0	3.1
5	OUTLET	ppmNO	1268.0	1277.9

CALIBRATION SUMMARY

SOURCE: RING-HAVER POWER CAT TESTING

REASON: BIAS CHECKS BETWEEN RUNS 2 AND 3

DATE : 07-19-2001 TIME: 14:02 - 14:08

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
4	OUTLET	ppmNOX	0.0	6.0
4	OUTLET	ppmNOX	1268.0	1275.7
5	OUTLET	ppmNO	0.0	3.1
5	OUTLET	ppmNO	1268.0	1276.3

CALIBRATION SUMMARY

SOURCE: RING-HAVER POWER CAT TESTING

REASON: BIAS CHECK END OF RUN 3

DATE : 07-19-2001 TIME: 15:18 - 15:26

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
4	OUTLET	ppmNOX	0.0	6.0
4	OUTLET	ppmNOX	1268.0	1272.6
5	OUTLET	ppmNO	0.0	4.6
5	OUTLET	ppmNO	1268.0	1273.3

CALIBRATION SUMMARY

SOURCE: RING-HAVER POWER CAT TESTING

REASON: INITIAL BIAS CAL UNIT 27

DATE : 07-16-2001 TIME: 12:32 - 12:35

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
6	OUTLET	ppmNOX	0.0	-9.8
6	OUTLET	ppmNOX	1268.0	1240.1

CALIBRATION SUMMARY

SOURCE: RING-HAVER POWER CAT TESTING

REASON: RUN BIAS CAL UNIT 27

DATE : 07-16-2001 TIME: 13:47 - 13:58

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
6	OUTLET	ppmNOX	0.0	6.9
6	OUTLET	ppmNOX	1268.0	1281.0

CALIBRATION SUMMARY

SOURCE: RING-HAVER POWER CAT TESTING

REASON: RUN TWO BIAS CAL UNIT 27

DATE : 07-16-2001 TIME: 15:07 - 15:11

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
6	OUTLET	ppmNOX	0.0	5.8
6	OUTLET	ppmNOX	1268.0	1278.2

CALIBRATION SUMMARY

SOURCE: RING-HAVER POWER CAT TESTING

REASON: RUN THREE BIAS UNIT 27

DATE : 07-16-2001 TIME: 16:18 - 16:20

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
6	OUTLET	ppmNOX	0.0	1.7
6	OUTLET	ppmNOX	1268.0	1279.9

?
   
CALIBRATION SUMMARY

SOURCE: RING-HAVER POWER CAT TESTING

REASON: INITIAL BIAS CAL UNIT 28

DATE : 07-18-2001      TIME: 09:13 - 09:21

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
4	OUTLET	ppmNOX	0.0	1.5
4	OUTLET	ppmNOX	1268.0	1280.1
5	OUTLET	ppmNO	0.0	1.5
5	OUTLET	ppmNO	1268.0	1279.3

CALIBRATION SUMMARY

SOURCE: RING-HAVER POWER CAT TESTING

REASON: RUN ONE BIAS CAL UNIT 28

DATE : 07-18-2001 TIME: 10:31 - 10:37

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
4	OUTLET	ppmNOX	0.0	3.0
4	OUTLET	ppmNOX	1268.0	1269.7
5	OUTLET	ppmNO	0.0	3.1
5	OUTLET	ppmNO	1268.0	1271.9

CALIBRATION SUMMARY

SOURCE: RING-HAVER POWER CAT TESTING

REASON: RUN TWO BIAS CAL UNIT 28

DATE : 07-18-2001 TIME: 11:49 - 11:59

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
4	OUTLET	ppmNOX	0.0	-1.9
4	OUTLET	ppmNOX	1268.0	1266.8
5	OUTLET	ppmNO	0.0	-0.0
5	OUTLET	ppmNO	1268.0	1267.6

CALIBRATION SUMMARY

SOURCE: RING-HAVER POWER CAT TESTING

REASON: RUN THREE BIAS CAL UNIT 28

DATE : 07-18-2001 TIME: 13:09 - 13:16

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
4	OUTLET	ppmNOX	0.0	-0.2
4	OUTLET	ppmNOX	1268.0	1262.5
5	OUTLET	ppmNO	0.0	1.5
5	OUTLET	ppmNO	1268.0	1264.6

CALIBRATION SUMMARY

SOURCE: RING-HAVER POWER CAT TESTING

REASON: INITIAL BIAS CAL UNIT 29

DATE : 07-18-2001 TIME: 13:59 - 14:07

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
4	OUTLET	ppmNOX	0.0	6.0
4	OUTLET	ppmNOX	1268.0	1275.8
5	OUTLET	ppmNO	0.0	4.6
5	OUTLET	ppmNO	1268.0	1276.4

CALIBRATION SUMMARY

SOURCE: RING-HAVER POWER CAT TESTING

REASON: RUN ONE BIAS CAL UNIT 29

DATE : 07-18-2001 TIME: 15:18 - 15:27

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
4	OUTLET	ppmNOX	0.0	3.1
4	OUTLET	ppmNOX	1268.0	1277.1
5	OUTLET	ppmNO	0.0	3.1
5	OUTLET	ppmNO	1268.0	1279.4

CALIBRATION SUMMARY

SOURCE: RING-HAVER POWER CAT TESTING

REASON: RUN TWO BIAS CAL UNIT 29

DATE : 07-18-2001 TIME: 16:34 - 16:41

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
4	OUTLET	ppmNOX	0.0	4.6
4	OUTLET	ppmNOX	1268.0	1272.7
5	OUTLET	ppmNO	0.0	3.1
5	OUTLET	ppmNO	1268.0	1270.5

}
   
 CALIBRATION SUMMARY

SOURCE: RING-HAVER POWER CAT TESTING

REASON: RUN THREE BIAS CAL UNIT 29

DATE : 07-18-2001      TIME: 17:52 - 17:58

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
4	OUTLET	ppmNOX	0.0	4.4
4	OUTLET	ppmNOX	1268.0	1269.7
5	OUTLET	ppmNO	0.0	3.1
5	OUTLET	ppmNO	1268.0	1271.9

}
   
 CALIBRATION SUMMARY

SOURCE: RING-HAVER POWER CAT TESTING

REASON: INITIAL BIAS CAL UNIT 30

DATE : 07-19-2001 TIME: 06:32 - 06:40

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
4	OUTLET	ppmNOX	0.0	4.6
4	OUTLET	ppmNOX	1268.0	1275.7
5	OUTLET	ppmNO	0.0	2.9
5	OUTLET	ppmNO	1268.0	1276.4

CALIBRATION SUMMARY

SOURCE: RING-HAVER POWER CAT TESTING

REASON: RUN ONE BIAS CAL UNIT 30

DATE : 07-19-2001      TIME: 07:51 - 07:56

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
4	OUTLET	ppmNOX	0.0	4.5
4	OUTLET	ppmNOX	1268.0	1275.6
5	OUTLET	ppmNO	0.0	3.0
5	OUTLET	ppmNO	1268.0	1274.4

CALIBRATION SUMMARY

SOURCE: RING-HAVER POWER CAT TESTING

REASON: RUN TWO BIAS CAL UNIT 30

DATE : 07-19-2001 TIME: 09:13 - 09:21

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
4	OUTLET	ppmNOX	0.0	4.6
4	OUTLET	ppmNOX	1268.0	1274.2
5	OUTLET	ppmNO	0.0	3.1
5	OUTLET	ppmNO	1268.0	1273.5

CALIBRATION SUMMARY

SOURCE: RING-HAVER POWER CAT TESTING

REASON: RUN THREE BIAS CAL UNIT 30

DATE : 07-19-2001 TIME: 10:28 - 10:36

A/D CHAN	MONITOR DESCRIPTION	UNITS	GAS VALUE	MONITOR RESPONSE
4	OUTLET	ppmNOX	0.0	3.1
4	OUTLET	ppmNOX	1268.0	1271.2
5	OUTLET	ppmNO	0.0	2.8
5	OUTLET	ppmNO	1268.0	1267.6

### D.3 SYSTEM BIAS AND DRIFT CALCULATIONS

SYSTEM CALIBRATION BIAS AND DRIFT CALCULATIONS

SOURCE: HOOKERS POINT POWER CAT UNIT 26

TEST DATE: 7/19/01

RUN NUMBER: 1

SPAN VALUES: 2500 ppm NOx  
2500 ppmNO

	-----INITIAL VALUES-----			-----FINAL VALUES-----		
	ANALYZER CAL. RESPONSE	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	DRIFT (% OF SPAN)
NOx ZERO GAS	3.1	3.1	0.00	4.6	0.06	0.06
NOx UP-SCALE	1277.2	1277.2	0.00	1276.9	-0.01	-0.01
NO ZERO GAS	3.10	3.10	0.00	3.10	0.00	0.00
NO UP-SCALE	1279.50	1279.50	0.00	1277.90	-0.06	-0.06

$$\text{SYSTEM CAL. BIAS} = \frac{\text{SYSTEM CAL. RESPONSE} - \text{ANALYZER CAL. RESPONSE}}{\text{SPAN}} \times 100$$

$$\text{DRIFT} = \frac{\text{FINAL SYSTEM CAL. RESPONSE} - \text{INITIAL CAL. RESPONSE}}{\text{SPAN}} \times 100$$

SYSTEM CALIBRATION BIAS AND DRIFT CALCULATIONS

SOURCE: HOOKERS POINT POWER CAT UNIT 26

TEST DATE: 7/19/01

RUN NUMBER: 2

SPAN VALUES: 2500 ppm NOx  
2500 ppmNO

	-----INITIAL VALUES-----			-----FINAL VALUES-----		
	ANALYZER CAL. RESPONSE	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	DRIFT (% OF SPAN)
NOx ZERO GAS	3.1	4.6	0.06	6.0	0.12	0.06
NOx UP-SCALE	1277.2	1276.9	-0.01	1275.7	-0.06	-0.05
NO ZERO GAS	3.10	3.10	0.00	3.10	0.00	0.00
NO UP-SCALE	1279.50	1277.90	-0.06	1276.30	-0.13	-0.06

$$\text{SYSTEM CAL. BIAS} = \frac{\text{SYSTEM CAL. RESPONSE} - \text{ANALYZER CAL. RESPONSE}}{\text{SPAN}} \times 100$$

$$\text{DRIFT} = \frac{\text{FINAL SYSTEM CAL. RESPONSE} - \text{INITIAL CAL. RESPONSE}}{\text{SPAN}} \times 100$$

SYSTEM CALIBRATION BIAS AND DRIFT CALCULATIONS

SOURCE: HOOKERS POINT POWER CAT UNIT 26

TEST DATE: 7/19/01

RUN NUMBER: 3

SPAN VALUES: 2500 ppm NOx  
2500 ppmNO

	-----INITIAL VALUES-----			-----FINAL VALUES-----		
	ANALYZER CAL. RESPONSE	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	DRIFT (% OF SPAN)
NOx ZERO GAS	3.1	6.0	0.12	6.0	0.12	0.00
NOx UP-SCALE	1277.2	1275.7	-0.06	1272.6	-0.18	-0.12
NO ZERO GAS	3.10	3.10	0.00	4.60	0.06	0.06
NO UP-SCALE	1279.50	1276.30	-0.13	1273.30	-0.25	-0.12

$$\text{SYSTEM CAL. BIAS} = \frac{\text{SYSTEM CAL. RESPONSE} - \text{ANALYZER CAL. RESPONSE}}{\text{SPAN}} \times 100$$

$$\text{DRIFT} = \frac{\text{FINAL SYSTEM CAL. RESPONSE} - \text{INITIAL CAL. RESPONSE}}{\text{SPAN}} \times 100$$

SYSTEM CALIBRATION BIAS AND DRIFT CALCULATIONS

SOURCE: RING-HAVER CAT POWER, UNIT 27

TEST DATE: 7/16/01

RUN NUMBER: 1

SPAN VALUES: 2500 ppm NOx

	-----INITIAL VALUES-----			-----FINAL VALUES-----		
	ANALYZER CAL. RESPONSE	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	DRIFT (% OF SPAN)
NOx ZERO GAS	-9.8	-9.8	0.00	6.9	0.67	0.67
NOx UP-SCALE	1240.1	1240.1	0.00	1281.0	1.64	1.64

$$\text{SYSTEM CAL. BIAS} = \frac{\text{SYSTEM CAL. RESPONSE} - \text{ANALYZER CAL. RESPONSE}}{\text{SPAN}} \times 100$$

$$\text{DRIFT} = \frac{\text{FINAL SYSTEM CAL. RESPONSE} - \text{INITIAL CAL. RESPONSE}}{\text{SPAN}} \times 100$$

SYSTEM CALIBRATION BIAS AND DRIFT CALCULATIONS

SOURCE: RING-HAVER CAT POWER, UNIT 27

TEST DATE: 7/16/01

RUN NUMBER: 2

SPAN VALUES: 2500 ppm NOx

	-----INITIAL VALUES-----			-----FINAL VALUES-----		
	ANALYZER CAL. RESPONSE	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	DRIFT (% OF SPAN)
NOx ZERO GAS	-9.8	6.9	0.67	5.8	0.62	-0.04
NOx UP-SCALE	1240.1	1281.0	1.64	1278.2	1.52	-0.11

$$\text{SYSTEM CAL. BIAS} = \frac{\text{SYSTEM CAL. RESPONSE} - \text{ANALYZER CAL. RESPONSE}}{\text{SPAN}} \times 100$$

$$\text{DRIFT} = \frac{\text{FINAL SYSTEM CAL. RESPONSE} - \text{INITIAL CAL. RESPONSE}}{\text{SPAN}} \times 100$$

SYSTEM CALIBRATION BIAS AND DRIFT CALCULATIONS

SOURCE: RING-HAVER CAT POWER, UNIT 27

TEST DATE: 7/16/01

RUN NUMBER: 3

SPAN VALUES: 2500 ppm NOx

	-----INITIAL VALUES-----			-----FINAL VALUES-----		
	ANALYZER CAL. RESPONSE	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	DRIFT (% OF SPAN)
NOx ZERO GAS	-9.8	5.8	0.62	1.7	0.46	-0.16
NOx UP-SCALE	1240.1	1278.2	1.52	1279.9	1.59	0.07

$$\text{SYSTEM CAL. BIAS} = \frac{\text{SYSTEM CAL. RESPONSE} - \text{ANALYZER CAL. RESPONSE}}{\text{SPAN}} \times 100$$

$$\text{DRIFT} = \frac{\text{FINAL SYSTEM CAL. RESPONSE} - \text{INITIAL CAL. RESPONSE}}{\text{SPAN}} \times 100$$

SYSTEM CALIBRATION BIAS AND DRIFT CALCULATIONS

SOURCE: H.P RING-HAVER CAT POWER UNIT 28

TEST DATE: 7/18/01

RUN NUMBER: 1

SPAN VALUES: 2500 ppm NOx  
2500 ppmNO

	-----INITIAL VALUES-----			-----FINAL VALUES-----		
	ANALYZER CAL. RESPONSE	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	DRIFT (% OF SPAN)
NOx ZERO GAS	1.5	1.5	0.00	3.0	0.06	0.06
NOx UP-SCALE	1280.1	1280.1	0.00	1269.7	-0.42	-0.42
NO ZERO GAS	1.5	1.5	0.00	3.1	0.06	0.06
NO UP-SCALE	1279.3	1279.3	0.00	1271.9	-0.30	-0.30

$$\text{SYSTEM CAL. BIAS} = \frac{\text{SYSTEM CAL. RESPONSE} - \text{ANALYZER CAL. RESPONSE}}{\text{SPAN}} \times 100$$

$$\text{DRIFT} = \frac{\text{FINAL SYSTEM CAL. RESPONSE} - \text{INITIAL CAL. RESPONSE}}{\text{SPAN}} \times 100$$

SYSTEM CALIBRATION BIAS AND DRIFT CALCULATIONS

SOURCE: H.P RING-HAVER CAT POWER UNIT 28

TEST DATE: 7/18/01

RUN NUMBER: 2

SPAN VALUES: 2500 ppm NOx  
2500 ppmNO

	-----INITIAL VALUES-----			-----FINAL VALUES-----		
	ANALYZER CAL. RESPONSE	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	DRIFT (% OF SPAN)
NOx ZERO GAS	1.5	3.0	0.06	-1.9	-0.14	-0.20
NOx UP-SCALE	1280.1	1269.7	-0.42	1266.8	-0.53	-0.12
NO ZERO GAS	1.50	3.10	0.06	0.00	-0.06	-0.12
NO UP-SCALE	1279.30	1271.90	-0.30	1267.60	-0.47	-0.17

$$\text{SYSTEM CAL. BIAS} = \frac{\text{SYSTEM CAL. RESPONSE} - \text{ANALYZER CAL. RESPONSE}}{\text{SPAN}} \times 100$$

$$\text{DRIFT} = \frac{\text{FINAL SYSTEM CAL. RESPONSE} - \text{INITIAL CAL. RESPONSE}}{\text{SPAN}} \times 100$$

SYSTEM CALIBRATION BIAS AND DRIFT CALCULATIONS

SOURCE: H.P RING-HAVER CAT POWER UNIT 28

TEST DATE: 7/18/01

RUN NUMBER: 3

SPAN VALUES: 2500 ppm NOx  
2500 ppmNO

	-----INITIAL VALUES-----			-----FINAL VALUES-----		DRIFT (% OF SPAN)
	ANALYZER CAL. RESPONSE	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	
NOx ZERO GAS	1.5	-1.9	-0.14	-0.2	-0.07	0.07
NOx UP-SCALE	1280.1	1266.8	-0.53	1262.5	-0.70	-0.17
NO ZERO GAS	1.50	0.0	-0.06	1.5	0.00	0.06
NO UP-SCALE	1279.30	1267.6	-0.47	1264.6	-0.59	-0.12

$$\text{SYSTEM CAL. BIAS} = \frac{\text{SYSTEM CAL. RESPONSE} - \text{ANALYZER CAL. RESPONSE}}{\text{SPAN}} \times 100$$

$$\text{DRIFT} = \frac{\text{FINAL SYSTEM CAL. RESPONSE} - \text{INITIAL CAL. RESPONSE}}{\text{SPAN}} \times 100$$

SYSTEM CALIBRATION BIAS AND DRIFT CALCULATIONS

SOURCE: HOOKERS POINT POWER CAT UNIT 29 TEST

TEST DATE: 7/18/01

RUN NUMBER: 1

SPAN VALUES: 2500 ppm NOx  
2500 ppmNO

	-----INITIAL VALUES-----			-----FINAL VALUES-----		
	ANALYZER CAL. RESPONSE	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	DRIFT (% OF SPAN)
NOx ZERO GAS	6.0	6.0	0.00	3.1	-0.12	-0.12
NOx UP-SCALE	1275.8	1275.8	0.00	1277.1	0.05	0.05
NO ZERO GAS	4.60	4.6	0.00	3.1	-0.06	-0.06
NO UP-SCALE	1276.40	1276.4	0.00	1279.4	0.12	0.12

$$\text{SYSTEM CAL. BIAS} = \frac{\text{SYSTEM CAL. RESPONSE} - \text{ANALYZER CAL. RESPONSE}}{\text{SPAN}} \times 100$$

$$\text{DRIFT} = \frac{\text{FINAL SYSTEM CAL. RESPONSE} - \text{INITIAL CAL. RESPONSE}}{\text{SPAN}} \times 100$$

SYSTEM CALIBRATION BIAS AND DRIFT CALCULATIONS

SOURCE: HOOKERS POINT POWER CAT UNIT 29 TEST

TEST DATE: 7/18/01

RUN NUMBER: 2

SPAN VALUES: 2500 ppm NOx  
2500 ppmNO

	-----INITIAL VALUES-----			-----FINAL VALUES-----			DRIFT (% OF SPAN)
	ANALYZER CAL. RESPONSE	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)		
	NOx ZERO GAS	6.0	3.1	-0.12	4.6	-0.06	
NOx UP-SCALE	1275.8	1277.1	0.05	1272.7	-0.12	-0.18	
NO ZERO GAS	4.60	3.1	-0.06	3.1	-0.06	0.00	
NO UP-SCALE	1276.40	1279.4	0.12	1270.5	-0.24	-0.36	

$$\text{SYSTEM CAL. BIAS} = \frac{\text{SYSTEM CAL. RESPONSE} - \text{ANALYZER CAL. RESPONSE}}{\text{SPAN}} \times 100$$

$$\text{DRIFT} = \frac{\text{FINAL SYSTEM CAL. RESPONSE} - \text{INITIAL CAL. RESPONSE}}{\text{SPAN}} \times 100$$

SYSTEM CALIBRATION BIAS AND DRIFT CALCULATIONS

SOURCE: HOOKERS POINT POWER CAT UNIT 29 TEST

TEST DATE: 7/18/01

RUN NUMBER: 3

SPAN VALUES: 2500 ppm NOx  
2500 ppmNO

	-----INITIAL VALUES-----			-----FINAL VALUES-----		
	ANALYZER CAL. RESPONSE	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	DRIFT (% OF SPAN)
NOx ZERO GAS	6.0	4.6	-0.06	4.4	-0.06	-0.01
NOx UP-SCALE	1275.8	1272.7	-0.12	1269.7	-0.24	-0.12
NO ZERO GAS	4.60	3.1	-0.06	3.1	-0.06	0.00
NO UP-SCALE	1276.40	1270.5	-0.24	1271.9	-0.18	0.06

$$\text{SYSTEM CAL. BIAS} = \frac{\text{SYSTEM CAL. RESPONSE} - \text{ANALYZER CAL. RESPONSE}}{\text{SPAN}} \times 100$$

$$\text{DRIFT} = \frac{\text{FINAL SYSTEM CAL. RESPONSE} - \text{INITIAL CAL. RESPONSE}}{\text{SPAN}} \times 100$$

SYSTEM CALIBRATION BIAS AND DRIFT CALCULATIONS

SOURCE: HOKERS POINT RING-HAVER UNIT 30

TEST DATE: 7/19/01

RUN NUMBER: 1

SPAN VALUES: 2500 ppm NOx  
2500 ppmNO

	-----INITIAL VALUES-----			-----FINAL VALUES-----		
	ANALYZER CAL. RESPONSE	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	DRIFT (% OF SPAN)
NOx ZERO GAS	4.6	4.6	0.00	4.5	-0.00	-0.00
NOx UP-SCALE	1275.7	1275.7	0.00	1275.6	-0.00	-0.00
NO ZERO GAS	2.9	2.9	0.00	3.0	0.00	0.00
NO UP-SCALE	1276.4	1276.4	0.00	1274.4	-0.08	-0.08

$$\text{SYSTEM CAL. BIAS} = \frac{\text{SYSTEM CAL. RESPONSE} - \text{ANALYZER CAL. RESPONSE}}{\text{SPAN}} \times 100$$

$$\text{DRIFT} = \frac{\text{FINAL SYSTEM CAL. RESPONSE} - \text{INITIAL CAL. RESPONSE}}{\text{SPAN}} \times 100$$

SYSTEM CALIBRATION BIAS AND DRIFT CALCULATIONS

SOURCE: HOKERS POINT RING-HAVER UNIT 30

TEST DATE: 7/19/01

RUN NUMBER: 2

SPAN VALUES: 2500 ppm NOx  
2500 ppmNO

	-----INITIAL VALUES-----			-----FINAL VALUES-----		
	ANALYZER CAL. RESPONSE	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	DRIFT (% OF SPAN)
NOx ZERO GAS	4.6	4.5	-0.00	4.6	0.00	0.00
NOx UP-SCALE	1275.7	1275.6	-0.00	1274.2	-0.06	-0.06
NO ZERO GAS	2.9	3.0	0.00	3.1	0.01	0.00
NO UP-SCALE	1276.4	1274.4	-0.08	1273.5	-0.12	-0.04

$$\text{SYSTEM CAL. BIAS} = \frac{\text{SYSTEM CAL. RESPONSE} - \text{ANALYZER CAL. RESPONSE}}{\text{SPAN}} \times 100$$

$$\text{DRIFT} = \frac{\text{FINAL SYSTEM CAL. RESPONSE} - \text{INITIAL CAL. RESPONSE}}{\text{SPAN}} \times 100$$

SYSTEM CALIBRATION BIAS AND DRIFT CALCULATIONS

SOURCE: HOKERS POINT RING-HAVER UNIT 30

TEST DATE: 7/19/01

RUN NUMBER: 3

SPAN VALUES: 2500 ppm NOx  
2500 ppmNO

	-----INITIAL VALUES-----			-----FINAL VALUES-----		
	ANALYZER CAL. RESPONSE	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	SYSTEM CAL. RESPONSE	SYSTEM CAL. BIAS (% OF SPAN)	DRIFT (% OF SPAN)
NOx ZERO GAS	4.6	4.6	0.00	3.1	-0.06	-0.06
NOx UP-SCALE	1275.7	1274.2	-0.06	1271.2	-0.18	-0.12
NO ZERO GAS	2.9	3.1	0.01	2.8	-0.00	-0.01
NO UP-SCALE	1276.4	1273.5	-0.12	1267.6	-0.35	-0.24

$$\text{SYSTEM CAL. BIAS} = \frac{\text{SYSTEM CAL. RESPONSE} - \text{ANALYZER CAL. RESPONSE}}{\text{SPAN}} \times 100$$

$$\text{DRIFT} = \frac{\text{FINAL SYSTEM CAL. RESPONSE} - \text{INITIAL CAL. RESPONSE}}{\text{SPAN}} \times 100$$

E. CALIBRATION GAS CERTIFICATES OF ANALYSIS

EAPh.1 1

# RATA CLASS



## Scott Specialty Gases

Dual-Analyzed Calibration Standard

6141 EASTON ROAD, BLDG 1, PLUMSTEADVILLE, PA 18949-0310

Phone: 800-331-4953

Fax: 215-766-7226

### CERTIFICATE OF ACCURACY: Interference Free <sup>TM</sup> EPA Protocol Gas

#### Assay Laboratory

SCOTT SPECIALTY GASES  
6141 EASTON ROAD, BLDG 1  
PLUMSTEADVILLE, PA 18949-0310

P.O. No.: E-N75516  
Project No.: 01-51597-001

#### Customer

TAMPA ELECTRIC  
5010 CAUSEWAY BLVD  
TAMPA FL 33619

#### ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards; Procedure #G1; September, 1997.

Cylinder Number: ALM005388      Certification Date: 3/26/01      Exp. Date: 3/26/2003  
Cylinder Pressure\*\*\*: 1982 PSIA

#### ANALYTICAL

COMPONENT	CERTIFIED CONCENTRATION (Moles)	ACCURACY**	TRACEABILITY
NITRIC OXIDE	1,265 PPM	+/- 1%	Direct NIST and NMI
NITROGEN - OXYGEN FREE	BALANCE		
TOTAL OXIDES OF NITROGEN	1,268 PPM		Reference Value Only

\*\*\* Do not use when cylinder pressure is below 150 psig.

\*\* Analytical accuracy is based on the requirements of EPA Protocol procedure G1, September 1997.

Product certified as +/- 1% analytical accuracy is directly traceable to NIST or NMI standards.

#### REFERENCE STANDARD

TYPE/SRM NO.	EXPIRATION DATE	CYLINDER NUMBER	CONCENTRATION	COMPONENT
NTRM 1687	3/01/03	ALM018805	1000. PPM	NO/N2

#### INSTRUMENTATION

INSTRUMENT/MODEL/SERIAL#	DATE LAST CALIBRATED	ANALYTICAL PRINCIPLE
FTIR System/B220/AAB9300174	03/05/01	Scott Enhanced FTIR

#### ANALYZER READINGS

(Z = Zero Gas    R = Reference Gas    T = Test Gas    r = Correlation Coefficient)

First Triad Analysis

Second Triad Analysis

Calibration Curve

#### NITRIC OXIDE

Date: 03/19/01	Response Unit: PPM		
Z1 = -0.22040	R1 = 1000.334	T1 = 1267.950	
R2 = 1002.529	Z2 = -0.00910	T2 = 1270.028	
Z3 = -0.14000	T3 = 1262.812	R3 = 997.1362	
Avg. Concentration:	1267.	PPM	

Date: 03/26/01	Response Unit: PPM		
Z1 = -0.00390	R1 = 1000.372	T1 = 1261.864	
R2 = 999.2310	Z2 = 0.33130	T2 = 1264.124	
Z3 = 0.20130	T3 = 1263.092	R3 = 1000.396	
Avg. Concentration:	1263.	PPM	

Concentration = A + Bx + Cx <sup>2</sup> + Dx <sup>3</sup> + Ex <sup>4</sup>	
r = 0.999990	
Constants:	A = 0.000000
B = 1.000000	C = 0.000000
D = 0.000000	E = 0.000000

APPROVED BY:

*Michael A. Kuhns*  
Michael A. Kuhns

CES Phil 2

# RATA CLASS



## Scott Specialty Gases

### Dual-Analyzed Calibration Standard

1750 EAST CLUB BLVD, DURHAM, NC 27704

Phone: 919-220-0803

Fax: 919-220-0808

## CERTIFICATE OF ACCURACY: Interference Free <sup>TM</sup> EPA Protocol Gas

### Assay Laboratory

SCOTT SPECIALTY GASES  
1750 EAST CLUB BLVD  
DURHAM, NC 27704

P.O. No.: N31923  
Project No.: 12-35384-003

### Customer

TAMPA ELECTRIC CO  
RAY MCDARBY  
5010 CAUSEWAY BLVD  
TAMPA FL 33619

### ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards; Procedure #G1; September, 1997.

Cylinder Number: ALM039857      Certification Date: 8/03/99      Exp. Date: 8/02/2001  
48T Cylinder Pressure\*\*\*: 1956 PSIG

COMPONENT	CERTIFIED CONCENTRATION (Moles)	ANALYTICAL ACCURACY**	TRACEABILITY
NITRIC OXIDE	2,219 PPM	+/- 1%	Direct NIST and NMI
NITROGEN - OXYGEN FREE	BALANCE		
TOTAL OXIDES OF NITROGEN	2,224 PPM		Reference Value Only

\*\*\* Do not use when cylinder pressure is below 150 psig.

\*\* Analytical accuracy is based on the requirements of EPA Protocol procedure G1, September 1997.

Product certified as +/- 1% analytical accuracy is directly traceable to NIST or NMI standards.

### REFERENCE STANDARD

TYPE/SRM NO.	EXPIRATION DATE	CYLINDER NUMBER	CONCENTRATION	COMPONENT
NTRM2631	3/01/03	ALM061390	2780. PPM	NO/N2

### INSTRUMENTATION

INSTRUMENT/MODEL/SERIAL#	DATE LAST CALIBRATED	ANALYTICAL PRINCIPLE
FTIR System/8220/AAB9400252	07/22/99	Scott Enhanced FTIR

### ANALYZER READINGS

(Z = Zero Gas    R = Reference Gas    T = Test Gas    r = Correlation Coefficient)

First Triad Analysis      Second Triad Analysis      Calibration Curve

#### NITRIC OXIDE

Date: 07/27/99	Response Unit: PPM		
Z1 = 0.12400	R1 = 2778.260	T1 = 2221.730	
R2 = 2781.907	Z2 = 0.38800	T2 = 2218.676	
Z3 = 0.13240	T3 = 2220.326	R3 = 2782.917	
Avg. Concentration: 2220.		PPM	

Date: 08/03/99	Response Unit: PPM		
Z1 = 0.20240	R1 = 2778.364	T1 = 2215.877	
R2 = 2781.396	Z2 = 0.62730	T2 = 2221.267	
Z3 = 0.48200	T3 = 2218.886	R3 = 2780.239	
Avg. Concentration: 2219.		PPM	

Concentration = A + Bx + Cx <sup>2</sup> + Dx <sup>3</sup> + Ex <sup>4</sup>	
r = 0.999990	
Constants:	A = 0.000000
B = 1.000000	C = 0.000000
D = 0.000000	E = 0.000000

Recd 8-9-99

APPROVED BY:   
B.M. Becton

F. FIELD DATA SHEETS



# TEMPERATURE MEASUREMENTS FIELD DATA SHEET

Date 7/19/01

Facility Hookers Ring-Haver

Unit No. 26

Location Outlet

Load (mw) 1.825 Pyrometer I. D. 28-02800

Operator D. Smith

## RUN 1

TIME	Temp. deg <sup>F</sup>
11:40	846.0
11:54	847.5
12:17	846.9
12:39	844.6
Avg.	846.2

## RUN 2

TIME	Temp. deg <sup>F</sup>
13:04	851.1
13:17	853.9
13:31	852.9
13:52	852.5
Average:	852.6

## RUN 3

TIME	Temp. deg <sup>F</sup>
14:19	849.5
14:38	853.4
14:56	854.0
15:12	855.2
Average:	853.2

Molecular Weight of Emissions 76

Time	Ambient	Stack	Corrected	NOx	Nox [lb/hr]
	Temperature [F]	Temperature [F]	Flue Gas Volumetric Flow Rate [ft <sup>3</sup> /min]		
RUN 1 11:40	90	846	6008.3	649.8	44.3
11:41	90	846	6008.3	644	43.9
11:42	90	846	6008.3	641.7	43.7
11:43	90	846	6008.3	641.5	43.7
11:44	90	846	6008.3	636.3	43.4
11:45	90	846	6008.3	630.3	43.0
11:46	90	846	6008.3	628.7	42.9
11:47	90	846	6008.3	621.3	42.4
11:48	90	846	6008.3	614.7	41.9
11:49	90	846	6008.3	614.7	41.9
11:50	90	846	6008.3	617.3	42.1
11:51	90	846	6008.3	615.7	42.0
11:52	90	846	6008.3	611.2	41.7
11:53	90	846	6008.3	607.8	41.4
11:54	90	847.5	6001.4	603.1	41.1
11:55	90	847.5	6001.4	599.1	40.8
11:56	90	847.5	6001.4	596.9	40.6
11:57	90	847.5	6001.4	597.2	40.7
11:58	90	847.5	6001.4	593.1	40.4
11:59	90	847.5	6001.4	588.6	40.1
12:00	90	847.5	6001.4	590.4	40.2
12:01	90	847.5	6001.4	584.8	39.8
12:02	90	847.5	6001.4	582.3	39.6
12:03	90	847.5	6001.4	582.6	39.7
12:04	90	847.5	6001.4	579.4	39.5
12:05	90	847.5	6001.4	574.3	39.1
12:06	90	847.5	6001.4	567.2	38.6
12:07	90	847.5	6001.4	565.9	38.5
12:08	90	847.5	6001.4	567	38.6
12:09	90	847.5	6001.4	565.7	38.5
12:10	90	847.5	6001.4	563.2	38.3
12:11	90	847.5	6001.4	560.9	38.2
12:12	90	847.5	6001.4	558.6	38.0
12:13	90	847.5	6001.4	557.3	37.9
12:14	90	847.5	6001.4	556.7	37.9
12:15	90	847.5	6001.4	556.3	37.9
12:16	90	847.5	6001.4	553.8	37.7
12:17	90	846.9	6004.2	552.4	37.6
12:18	90	846.9	6004.2	550.6	37.5
12:19	90	846.9	6004.2	553.8	37.7
12:20	90	846.9	6004.2	551.4	37.6
12:21	90	846.9	6004.2	549	37.4
12:22	90	846.9	6004.2	553.4	37.7
12:23	90	846.9	6004.2	546.3	37.2
12:24	90	846.9	6004.2	548.9	37.4

## Unit 26

12:25	90	846.9	6004.2	545.4	37.2
12:26	90	846.9	6004.2	545.4	37.2
12:27	90	846.9	6004.2	546.2	37.2
12:28	90	846.9	6004.2	544	37.1
12:29	90	846.9	6004.2	544.9	37.1
12:30	90	846.9	6004.2	546	37.2
12:31	90	846.9	6004.2	548.2	37.3
12:32	90	846.9	6004.2	546.5	37.2
12:33	90	846.9	6004.2	543.8	37.0
12:34	90	846.9	6004.2	544.9	37.1
12:35	90	846.9	6004.2	544.9	37.1
12:36	90	846.9	6004.2	542.8	37.0
12:37	90	846.9	6004.2	541.6	36.9
12:38	90	846.9	6004.2	541.8	36.9
12:39	90	844.6	6014.8	541.9	37.0
Run 1	90.0	846.9	6004.3	570.0	38.8
13:02	90	851.1	5984.9	523.6	35.6
13:03	90	851.1	5984.9	523.1	35.5
13:04	90	851.1	5984.9	521.4	35.4
13:05	90	851.1	5984.9	520	35.3
13:06	90	851.1	5984.9	518.7	35.2
13:07	90	851.1	5984.9	519.4	35.3
13:08	90	851.1	5984.9	516.6	35.1
13:09	90	851.1	5984.9	516.9	35.1
13:10	90	851.1	5984.9	516.5	35.1
13:11	90	851.1	5984.9	516.6	35.1
13:12	90	851.1	5984.9	518	35.2
13:13	90	851.1	5984.9	520.1	35.3
13:14	90	851.1	5984.9	518.9	35.2
13:15	90	851.1	5984.9	515.8	35.0
13:16	90	851.1	5984.9	515.4	35.0
13:17	90	853.9	5972.2	515.6	34.9
13:18	90	853.9	5972.2	512.7	34.7
13:19	90	853.9	5972.2	514.6	34.9
13:20	90	853.9	5972.2	512.2	34.7
13:21	90	853.9	5972.2	511.8	34.7
13:22	90	853.9	5972.2	509.8	34.5
13:23	90	853.9	5972.2	507.9	34.4
13:24	90	853.9	5972.2	509.6	34.5
13:25	90	853.9	5972.2	512	34.7
13:26	90	853.9	5972.2	511.3	34.6
13:27	90	853.9	5972.2	511.8	34.7
13:28	90	853.9	5972.2	512.4	34.7
13:29	90	853.9	5972.2	513.9	34.8
13:30	90	853.9	5972.2	515.4	34.9
13:31	90	852.9	5976.7	516.3	35.0
13:32	90	852.9	5976.7	517.4	35.1
13:33	90	852.9	5976.7	516.9	35.1
13:34	90	852.9	5976.7	512.8	34.8
13:35	90	852.9	5976.7	513.9	34.8
13:36	90	852.9	5976.7	515.7	35.0

Unit 26

13:37	90	852.9	5976.7	515.6	35.0
13:38	90	852.9	5976.7	510.8	34.6
13:39	90	852.9	5976.7	505.9	34.3
13:40	90	852.9	5976.7	506.5	34.3
13:41	90	852.9	5976.7	510.2	34.6
13:42	90	852.9	5976.7	509.3	34.5
13:43	90	852.9	5976.7	506.9	34.4
13:44	90	852.9	5976.7	508.1	34.5
13:45	90	852.9	5976.7	507.3	34.4
13:46	90	852.9	5976.7	506.8	34.4
13:47	90	852.9	5976.7	506.6	34.4
13:48	90	852.9	5976.7	508.6	34.5
13:49	90	852.9	5976.7	509.7	34.6
13:50	90	852.9	5976.7	506.7	34.4
13:51	90	852.9	5976.7	506.5	34.3
13:52	90	852.5	5978.6	507.8	34.4
13:53	90	852.5	5978.6	509.1	34.5
13:54	90	852.5	5978.6	508.1	34.5
13:55	90	852.5	5978.6	506.9	34.4
13:56	90	852.5	5978.6	507.1	34.4
13:57	90	852.5	5978.6	509.1	34.5
13:58	90	852.5	5978.6	509.2	34.5
13:59	90	852.5	5978.6	507.2	34.4
14:00	90	852.5	5978.6	506.7	34.4
14:01	90	852.5	5978.6	507.8	34.4
Run 2	90.0	852.7	5977.4	506.0	34.3
14:19	90	849.5	5992.2	649	44.1
14:20	90	849.5	5992.2	639.3	43.5
14:21	90	849.5	5992.2	639.6	43.5
14:22	90	849.5	5992.2	637.3	43.3
14:23	90	849.5	5992.2	639.9	43.5
14:24	90	849.5	5992.2	637.6	43.3
14:25	90	849.5	5992.2	633.1	43.0
14:26	90	849.5	5992.2	633.3	43.1
14:27	90	849.5	5992.2	630.6	42.9
14:28	90	849.5	5992.2	627.6	42.7
14:29	90	849.5	5992.2	623.8	42.4
14:30	90	849.5	5992.2	623	42.4
14:31	90	849.5	5992.2	619.7	42.1
14:32	90	849.5	5992.2	622.1	42.3
14:33	90	849.5	5992.2	625.6	42.5
14:34	90	849.5	5992.2	632.6	43.0
14:35	90	849.5	5992.2	636.5	43.3
14:36	90	849.5	5992.2	632.3	43.0
14:37	90	849.5	5992.2	630.7	42.9
14:38	90	853.4	5974.5	628.4	42.6
14:39	90	853.4	5974.5	630.7	42.8
14:40	90	853.4	5974.5	628.7	42.6
14:41	90	853.4	5974.5	628.1	42.6
14:42	90	853.4	5974.5	625.1	42.4
14:43	90	853.4	5974.5	625.9	42.4
14:44	90	853.4	5974.5	625.7	42.4

Unit 26

14:45	90	853.4	5974.5	625.9	42.4
14:46	90	853.4	5974.5	624.8	42.4
14:47	90	853.4	5974.5	623.2	42.2
14:48	90	853.4	5974.5	621.1	42.1
14:49	90	853.4	5974.5	622.2	42.2
14:50	90	853.4	5974.5	621.9	42.2
14:51	90	853.4	5974.5	619	42.0
14:52	90	853.4	5974.5	618.2	41.9
14:53	90	853.4	5974.5	619.6	42.0
14:54	90	853.4	5974.5	617.5	41.9
14:55	90	853.4	5974.5	617	41.8
14:56	90	854.6	5969.0	614.7	41.6
14:57	90	854.6	5969.0	612.5	41.5
14:58	90	854.6	5969.0	609.7	41.3
14:59	90	854.6	5969.0	613.3	41.5
15:00	90	854.6	5969.0	612.8	41.5
15:01	90	854.6	5969.0	611.6	41.4
15:02	90	854.6	5969.0	608.6	41.2
15:03	90	854.6	5969.0	610.2	41.3
15:04	90	854.6	5969.0	609.2	41.3
15:05	90	854.6	5969.0	606.7	41.1
15:06	90	854.6	5969.0	610.1	41.3
15:07	90	854.6	5969.0	611.8	41.4
15:08	90	854.6	5969.0	609.8	41.3
15:09	90	854.6	5969.0	606.9	41.1
15:10	90	854.6	5969.0	607.5	41.1
15:11	90	854.6	5969.0	607.9	41.2
15:12	90	855.2	5966.3	607.6	41.1
15:13	90	855.2	5966.3	608.6	41.2
15:14	90	855.2	5966.3	609.1	41.2
15:15	90	855.2	5966.3	606.7	41.1
15:16	90	855.2	5966.3	608.5	41.2
15:17	90	855.2	5966.3	609.6	41.3
15:18	90	855.2	5966.3	610	41.3
Run 3	90.0	854.6	5968.9	615.0	41.6
	Test Avg.	Test Avg.	Calc. Avg.	Corr. Avg.	Corr. lbs/Hour



# TEMPERATURE MEASUREMENTS FIELD DATA SHEET

Date 7/16/01

Facility Ring-Haver

Unit No. 27

Location <sup>DIS</sup>~~Hooker~~ Outlet

Load (mw) 1825 Pyrometer I. D. 28-02800

Operator D. Smith

### RUN 1

TIME	Temp. deg <sup>F</sup>
12:47	807.9
13:02	820.5
13:17	826.1
13:32	826.9
Avg.	820.4

### RUN 2

TIME	Temp. deg <sup>F</sup>
14:07	832.8
14:22	834.0
14:45	828.7
14:58	827.0
Avg.	830.6

### RUN 3

TIME	Temp. deg <sup>F</sup>
15:19	830.5
15:34	832.6
15:58	834.7
16:15	834.2
Avg.	833.0

Molecular Weight of Emissions 76

Time	Ambient Temperature [F]	Stack Temperature [F]	Corrected Flue Gas Volumetric Flow Rate [ft <sup>3</sup> /min]	NOx [ppm]	Nox [lb/hr]
12:47	32	807.9	5536.2	503.6	35.4
12:48	90	807.9	6188.9	500.5	35.1
12:49	90	807.9	6188.9	492.3	34.6
12:50	90	807.9	6188.9	499.7	35.1
12:51	90	807.9	6188.9	495.5	34.8
12:52	90	807.9	6188.9	489.4	34.4
12:53	90	807.9	6188.9	487.2	34.2
12:54	90	807.9	6188.9	481.8	33.8
12:55	90	807.9	6188.9	476	33.4
12:56	90	807.9	6188.9	478.4	33.6
12:57	90	807.9	6188.9	483.7	34.0
12:58	90	807.9	6188.9	481.9	33.8
12:59	90	807.9	6188.9	480.5	33.7
13:00	90	807.9	6188.9	477.1	33.5
13:01	90	807.9	6188.9	477.8	33.5
13:02	90	820.5	6128.0	480.9	33.4
13:03	90	820.5	6128.0	487.1	33.9
13:04	90	820.5	6128.0	484	33.7
13:05	90	820.5	6128.0	483.4	33.6
13:06	90	820.5	6128.0	483.4	33.6
13:07	90	820.5	6128.0	481.5	33.5
13:08	90	820.5	6128.0	488	33.9
13:09	90	820.5	6128.0	486.5	33.8
13:10	90	820.5	6128.0	489.3	34.0
13:11	90	820.5	6128.0	489.8	34.1
13:12	90	820.5	6128.0	488.9	34.0
13:13	90	820.5	6128.0	482.2	33.5
13:14	90	820.5	6128.0	485.2	33.7
13:15	90	820.5	6128.0	486.5	33.8
13:16	90	820.5	6128.0	486.9	33.9
13:17	90	826.1	6101.3	484.2	33.5
13:18	90	826.1	6101.3	482.3	33.4
13:19	90	826.1	6101.3	486.5	33.7
13:20	90	826.1	6101.3	487.5	33.7
13:21	90	826.1	6101.3	484.9	33.6
13:22	90	826.1	6101.3	483.3	33.5
13:23	90	826.1	6101.3	484.2	33.5
13:24	90	826.1	6101.3	487.4	33.7
13:25	90	826.1	6101.3	488.4	33.8
13:26	90	826.1	6101.3	515.6	35.7
13:27	90	826.1	6101.3	546.2	37.8
13:28	90	826.1	6101.3	542.7	37.6
13:29	90	826.1	6101.3	544	37.7
13:30	90	826.1	6101.3	539.5	37.3
13:31	90	826.1	6101.3	534.8	37.0

## Unit 27

13:32	90	826.9	6097.5	536.9	37.1
13:33	90	826.9	6097.5	529.9	36.7
13:34	90	826.9	6097.5	522.2	36.1
13:35	90	826.9	6097.5	518.4	35.9
13:36	90	826.9	6097.5	524.2	36.3
13:37	90	826.9	6097.5	524.5	36.3
13:38	90	826.9	6097.5	520.8	36.0
13:39	90	826.9	6097.5	519	35.9
13:40	90	826.9	6097.5	512.7	35.5
13:41	90	826.9	6097.5	523.7	36.2
13:42	90	826.9	6097.5	522.5	36.1
13:43	90	826.9	6097.5	520.5	36.0
13:44	90	826.9	6097.5	507.2	35.1
13:45	90	826.9	6097.5	520.9	36.0
13:46	90	826.9	6097.5	527.1	36.5
13:47	90	826.9	6097.5	521.4	36.1
Run 1	89.0	820.5	6117.7	504.0	35.0
14:07	90	832.8	6069.7	710.6	48.9
14:08	90	832.8	6069.7	716.9	49.4
14:09	90	832.8	6069.7	713.4	49.1
14:10	90	832.8	6069.7	710.2	48.9
14:11	90	832.8	6069.7	715	49.2
14:12	90	832.8	6069.7	708.5	48.8
14:13	90	832.8	6069.7	708.7	48.8
14:14	90	832.8	6069.7	711.6	49.0
14:15	90	832.8	6069.7	712.6	49.1
14:16	90	832.8	6069.7	713.5	49.1
14:17	90	832.8	6069.7	707.9	48.7
14:18	90	832.8	6069.7	709.6	48.9
14:19	90	832.8	6069.7	708.3	48.8
14:20	90	832.8	6069.7	707.6	48.7
14:21	90	834	6064.0	719.5	49.5
14:22	90	834	6064.0	716.2	49.3
14:23	90	834	6064.0	710.2	48.9
14:24	90	834	6064.0	706.2	48.6
14:25	90	834	6064.0	703.3	48.4
14:26	90	834	6064.0	703.9	48.4
14:27	90	834	6064.0	702.5	48.3
14:28	90	834	6064.0	697.7	48.0
14:29	90	834	6064.0	697.9	48.0
14:30	90	834	6064.0	692.8	47.7
14:31	90	834	6064.0	687.1	47.3
14:32	90	834	6064.0	694.3	47.8
14:33	90	834	6064.0	686.3	47.2
14:34	90	834	6064.0	716.7	49.3
14:35	90	834	6064.0	709	48.8
14:36	90	834	6064.0	712.1	49.0
14:37	90	834	6064.0	707.2	48.7
14:38	90	834	6064.0	710.8	48.9
14:39	90	834	6064.0	706.3	48.6
14:40	90	834	6064.0	710.1	48.9

## Unit 27

14:41	90	834	6064.0	716	49.3
14:42	90	834	6064.0	703.3	48.4
14:43	90	834	6064.0	705.1	48.5
14:44	90	834	6064.0	709.9	48.8
14:45	90	828.7	6089.0	713	49.3
14:46	90	828.7	6089.0	719.2	49.7
14:47	90	828.7	6089.0	702.2	48.5
14:48	90	828.7	6089.0	702	48.5
14:49	90	828.7	6089.0	694.7	48.0
14:50	90	828.7	6089.0	695.2	48.0
14:51	90	828.7	6089.0	690.3	47.7
14:52	90	828.7	6089.0	703.1	48.6
14:53	90	828.7	6089.0	694.2	48.0
14:54	90	828.7	6089.0	690.8	47.7
14:55	90	828.7	6089.0	703.2	48.6
14:56	90	828.7	6089.0	697.3	48.2
14:57	90	828.7	6089.0	696	48.1
14:58	90	827	6097.0	689.1	47.7
14:59	90	827	6097.0	684	47.3
15:00	90	827	6097.0	687.5	47.6
15:01	90	827	6097.0	678	46.9
15:02	90	827	6097.0	680.5	47.1
15:03	90	827	6097.0	681.8	47.2
15:04	90	827	6097.0	682.8	47.2
15:05	90	827	6097.0	680.2	47.1
15:06	90	827	6097.0	676.9	46.8
Run 2	90.0	831.5	6075.7	693.0	47.8
15:19	90	830.5	6080.5	513.8	35.4
15:20	90	830.5	6080.5	527.5	36.4
15:21	90	830.5	6080.5	515.8	35.6
15:22	90	830.5	6080.5	506.3	34.9
15:23	90	830.5	6080.5	508.2	35.1
15:24	90	830.5	6080.5	512.9	35.4
15:25	90	830.5	6080.5	518.1	35.7
15:26	90	830.5	6080.5	509.6	35.2
15:27	90	830.5	6080.5	502.5	34.7
15:28	90	830.5	6080.5	514.6	35.5
15:29	90	830.5	6080.5	510.4	35.2
15:30	90	830.5	6080.5	499.2	34.4
15:31	90	830.5	6080.5	504.3	34.8
15:32	90	830.5	6080.5	509.3	35.1
15:33	90	830.5	6080.5	514.3	35.5
15:34	90	832.6	6070.6	514.6	35.4
15:35	90	832.6	6070.6	519.4	35.8
15:36	90	832.6	6070.6	522.1	36.0
15:37	90	832.6	6070.6	510.1	35.1
15:38	90	832.6	6070.6	502.5	34.6
15:39	90	832.6	6070.6	492.5	33.9
15:40	90	832.6	6070.6	505.9	34.8
15:41	90	832.6	6070.6	511.6	35.2
15:42	90	832.6	6070.6	512.3	35.3

Unit 27

15:43	90	832.6	6070.6	513.7	35.4
15:44	90	832.6	6070.6	514.3	35.4
15:45	90	832.6	6070.6	494.7	34.1
15:46	90	832.6	6070.6	520.1	35.8
15:47	90	832.6	6070.6	511.5	35.2
15:48	90	832.6	6070.6	518.1	35.7
15:49	90	832.6	6070.6	517.1	35.6
15:50	90	832.6	6070.6	506.7	34.9
15:51	90	832.6	6070.6	510	35.1
15:52	90	832.6	6070.6	530.1	36.5
15:53	90	832.6	6070.6	525.1	36.2
15:54	90	832.6	6070.6	519.8	35.8
15:55	90	832.6	6070.6	525.8	36.2
15:56	90	832.6	6070.6	522.8	36.0
15:57	90	832.6	6070.6	525.1	36.2
15:58	90	834.7	6060.7	525.4	36.1
15:59	90	834.7	6060.7	518.3	35.6
16:00	90	834.7	6060.7	507.9	34.9
16:01	90	834.7	6060.7	515	35.4
16:02	90	834.7	6060.7	525.9	36.2
16:03	90	834.7	6060.7	514.4	35.4
16:04	90	834.7	6060.7	517.4	35.6
16:05	90	834.7	6060.7	514.1	35.4
16:06	90	834.7	6060.7	509.7	35.0
16:07	90	834.7	6060.7	507.8	34.9
16:08	90	834.7	6060.7	528.8	36.4
16:09	90	834.7	6060.7	508.3	35.0
16:10	90	834.7	6060.7	503.5	34.6
16:11	90	834.7	6060.7	515.1	35.4
16:12	90	834.7	6060.7	512.3	35.2
16:13	90	834.7	6060.7	511.7	35.2
16:14	90	834.7	6060.7	521.4	35.9
16:15	90	834.2	6063.1	515.9	35.5
16:16	90	834.2	6063.1	520.1	35.8
16:17	90	834.2	6063.1	512.5	35.3
16:18	90	834.2	6063.1	515.6	35.5
Run 3	90.0	832.8	6069.8	507.0	34.9
	Test Avg.	Test Avg.	Calc. Avg.	Corr. Avg.	Corr. lbs/Hour



# TEMPERATURE MEASUREMENTS FIELD DATA SHEET

Date 7/18/01

Facility Ring-Haver

Unit No. 28

Location Outlet

Load (mw) 1,825 Pyrometer I. D. 28-02800

Operator D. Smith

## RUN 1

TIME	Temp. deg <sup>F</sup>
09:31	836
10:11	855.3
10:22	847.6
10:29	847.9
Avg.	846.7

## RUN 2

TIME	Temp. deg <sup>F</sup>
11:00	848.3
11:18	848.8
11:36	851.4
11:46	851.7
Avg.	850.0

## RUN 3

TIME	Temp. deg <sup>F</sup>
12:07	850.3
12:26	851.8
12:53	859.1
13:04	857.0
Avg.	854.6

Molecular Weight of Emissions 76

Time	Ambient Temperature [F]	Stack Temperature [F]	Corrected Flue Gas Volumetric Flow Rate [ft <sup>3</sup> /min]	NOx [ppm]	Nox [lb/hr]
9:29	90	836	6054.7	675.4	46.4
9:30	90	836	6054.7	668.7	45.9
9:31	90	836	6054.7	682.4	46.9
9:32	90	836	6054.7	676.6	46.5
9:33	90	836	6054.7	663.1	45.6
9:34	90	836	6054.7	653.1	44.9
9:35	90	836	6054.7	650.8	44.7
9:36	90	836	6054.7	646.5	44.4
9:37	90	836	6054.7	643.9	44.2
9:38	90	836	6054.7	639	43.9
9:39	90	836	6054.7	633.9	43.5
9:40	90	836	6054.7	627.9	43.1
9:41	90	836	6054.7	624	42.9
9:42	90	836	6054.7	620	42.6
9:43	90	836	6054.7	615.6	42.3
9:44	90	836	6054.7	614.2	42.2
9:45	90	836	6054.7	611.3	42.0
9:46	90	836	6054.7	610.9	42.0
9:47	90	836	6054.7	608.1	41.8
9:48	90	836	6054.7	605.7	41.6
9:49	90	836	6054.7	603.5	41.5
9:50	90	836	6054.7	602.6	41.4
9:51	90	836	6054.7	600.1	41.2
9:52	90	836	6054.7	595.4	40.9
9:53	90	836	6054.7	592.4	40.7
9:54	90	836	6054.7	587.7	40.4
9:55	90	836	6054.7	587	40.3
9:56	90	836	6054.7	586.2	40.3
9:57	90	836	6054.7	581.1	39.9
9:58	90	836	6054.7	579	39.8
9:59	90	836	6054.7	576.5	39.6
10:00	90	836	6054.7	576.3	39.6
10:01	90	836	6054.7	575.6	39.5
10:02	90	836	6054.7	572.6	39.3
10:03	90	836	6054.7	571.6	39.3
10:04	90	836	6054.7	567.4	39.0
10:05	90	836	6054.7	569.1	39.1
10:06	90	836	6054.7	567.2	39.0
10:07	90	836	6054.7	565.8	38.9
10:08	90	836	6054.7	566.8	38.9
10:09	90	836	6054.7	564.1	38.7
10:10	90	836	6054.7	561.9	38.6
10:11	90	855.3	5965.8	562.6	38.1
10:12	90	855.3	5965.8	565.3	38.3
10:13	90	855.3	5965.8	571.2	38.7

## Unit 28

10:14	90	855.3	5965.8	570.3	38.6
10:15	90	855.3	5965.8	566	38.3
10:16	90	855.3	5965.8	562.4	38.1
10:17	90	855.3	5965.8	562.9	38.1
10:18	90	855.3	5965.8	562.5	38.1
10:19	90	855.3	5965.8	559.6	37.9
10:20	90	855.3	5965.8	557.7	37.7
10:21	90	855.3	5965.8	555	37.6
10:22	90	847.6	6001.0	558.5	38.0
10:23	90	847.6	6001.0	557.7	38.0
10:24	90	847.6	6001.0	554.8	37.8
10:25	90	847.6	6001.0	555	37.8
10:26	90	847.6	6001.0	552.3	37.6
10:27	90	847.6	6001.0	553.3	37.7
10:28	90	847.6	6001.0	553.5	37.7
Run 1	90.0	840.9	6032.1	589.0	40.3
10:46	90	848.3	5997.7	542.9	36.9
10:47	90	848.3	5997.7	541.1	36.8
10:48	90	848.3	5997.7	543	36.9
10:49	90	848.3	5997.7	540	36.7
10:50	90	848.3	5997.7	540.5	36.8
10:51	90	848.3	5997.7	538.6	36.7
10:52	90	848.3	5997.7	536.7	36.5
10:53	90	848.3	5997.7	535.6	36.4
10:54	90	848.3	5997.7	535.9	36.5
10:55	90	848.3	5997.7	532.3	36.2
10:56	90	848.3	5997.7	527.1	35.9
10:57	90	848.3	5997.7	528.3	35.9
10:58	90	848.3	5997.7	528.4	36.0
10:59	90	848.3	5997.7	528	35.9
11:00	90	848.3	5997.7	528	35.9
11:01	90	848.3	5997.7	524.9	35.7
11:02	90	848.3	5997.7	522.9	35.6
11:03	90	848.3	5997.7	523.8	35.6
11:04	90	848.3	5997.7	526.9	35.9
11:05	90	848.3	5997.7	526.1	35.8
11:06	90	848.3	5997.7	525.3	35.7
11:07	90	848.3	5997.7	524	35.7
11:08	90	848.3	5997.7	520.2	35.4
11:09	90	848.3	5997.7	518.8	35.3
11:10	90	848.3	5997.7	522.7	35.6
11:11	90	848.3	5997.7	523.3	35.6
11:12	90	848.3	5997.7	518.8	35.3
11:13	90	848.3	5997.7	518.4	35.3
11:14	90	848.3	5997.7	518	35.2
11:15	90	848.3	5997.7	520.7	35.4
11:16	90	848.3	5997.7	521.2	35.5
11:17	90	848.3	5997.7	522.6	35.6
11:18	90	848.8	5995.5	522	35.5
11:19	90	848.8	5995.5	519.9	35.4
11:20	90	848.8	5995.5	521	35.4

## Unit 28

11:21	90	848.8	5995.5	520.8	35.4
11:22	90	848.8	5995.5	519.1	35.3
11:23	90	848.8	5995.5	519.5	35.3
11:24	90	848.8	5995.5	520.8	35.4
11:25	90	848.8	5995.5	522.9	35.6
11:26	90	848.8	5995.5	521	35.4
11:27	90	848.8	5995.5	518.5	35.3
11:28	90	848.8	5995.5	515.8	35.1
11:29	90	848.8	5995.5	516.4	35.1
11:30	90	848.8	5995.5	516.4	35.1
11:31	90	848.8	5995.5	514.2	35.0
11:32	90	848.8	5995.5	515.1	35.0
11:33	90	848.8	5995.5	513.9	35.0
11:34	90	848.8	5995.5	516.6	35.1
11:35	90	848.8	5995.5	517.3	35.2
11:36	90	851.4	5983.6	518.9	35.2
11:37	90	851.4	5983.6	517.8	35.2
11:38	90	851.4	5983.6	520.4	35.3
11:39	90	851.4	5983.6	517.2	35.1
11:40	90	851.4	5983.6	516.1	35.0
11:41	90	851.4	5983.6	515	35.0
11:42	90	851.4	5983.6	515.3	35.0
11:43	90	851.4	5983.6	516.7	35.1
11:44	90	851.4	5983.6	515.8	35.0
11:45	90	851.4	5983.6	520	35.3
Run 2	90.0	849.0	5994.7	523.0	35.6
12:07	90	850.3	5988.6	539.6	36.7
12:08	90	850.3	5988.6	539	36.6
12:09	90	850.3	5988.6	536.2	36.4
12:10	90	850.3	5988.6	532.3	36.2
12:11	90	850.3	5988.6	526.8	35.8
12:12	90	850.3	5988.6	525	35.7
12:13	90	850.3	5988.6	522.7	35.5
12:14	90	850.3	5988.6	520.8	35.4
12:15	90	850.3	5988.6	519.9	35.3
12:16	90	850.3	5988.6	517.7	35.2
12:17	90	850.3	5988.6	515.8	35.0
12:18	90	850.3	5988.6	514.1	34.9
12:19	90	850.3	5988.6	516.3	35.1
12:20	90	850.3	5988.6	517.8	35.2
12:21	90	850.3	5988.6	516.9	35.1
12:22	90	850.3	5988.6	518.3	35.2
12:23	90	850.3	5988.6	525.3	35.7
12:24	90	850.3	5988.6	523	35.5
12:25	90	850.3	5988.6	516.1	35.1
12:26	90	851.8	5981.7	513.9	34.9
12:27	90	851.8	5981.7	519.4	35.2
12:28	90	851.8	5981.7	519.4	35.2
12:29	90	851.8	5981.7	515.5	35.0
12:30	90	851.8	5981.7	517	35.1
12:31	90	851.8	5981.7	516.2	35.0

Unit 28

12:32	90	851.8	5981.7	513.6	34.9
12:33	90	851.8	5981.7	514.2	34.9
12:34	90	851.8	5981.7	514.4	34.9
12:35	90	851.8	5981.7	512.8	34.8
12:36	90	851.8	5981.7	512.2	34.8
12:37	90	851.8	5981.7	509.3	34.6
12:38	90	851.8	5981.7	506.3	34.4
12:39	90	851.8	5981.7	504.5	34.2
12:40	90	851.8	5981.7	504.6	34.2
12:41	90	851.8	5981.7	504.8	34.3
12:42	90	851.8	5981.7	505.3	34.3
12:43	90	851.8	5981.7	503.5	34.2
12:44	90	851.8	5981.7	505	34.3
12:45	90	851.8	5981.7	503.8	34.2
12:46	90	851.8	5981.7	505.7	34.3
12:47	90	851.8	5981.7	506.8	34.4
12:48	90	851.8	5981.7	504.7	34.3
12:49	90	851.8	5981.7	504.4	34.2
12:50	90	851.8	5981.7	502.7	34.1
12:51	90	851.8	5981.7	502.1	34.1
12:52	90	851.8	5981.7	489.1	33.2
12:53	90	859.1	5948.6	482.6	32.6
12:54	90	859.1	5948.6	479.7	32.4
12:55	90	859.1	5948.6	478.2	32.3
12:56	90	859.1	5948.6	478.7	32.3
12:57	90	859.1	5948.6	478.7	32.3
12:58	90	859.1	5948.6	479.2	32.3
12:59	90	859.1	5948.6	479.9	32.4
13:00	90	859.1	5948.6	480.5	32.4
13:01	90	859.1	5948.6	480.1	32.4
13:02	90	859.1	5948.6	479.8	32.4
13:03	90	859.1	5948.6	478.7	32.3
13:04	90	859.1	5948.6	477.8	32.2
13:05	90	859.1	5948.6	478.3	32.3
13:06	90	859.1	5948.6	478.5	32.3
Run 3	90.0	853.0	5976.2	508.0	34.4
	Test Avg.	Test Avg.	Calc. Avg.	Corr. Avg.	Corr. lbs/Hour



# TEMPERATURE MEASUREMENTS FIELD DATA SHEET

Date 7/18/01

Facility H.P. Ring-Haver

Unit No. 29

Location Outlet

Load (mw) 1.825 Pyrometer I. D. 28-02800

Operator D. Smith

## RUN 1

TIME	Temp. deg <sup>F</sup>
14:20	903.4
14:35	905.8
14:50	907.3
15:07	909.1
Avg.	906.4

## RUN 2

TIME	Temp. deg <sup>F</sup>
15:39	910.8
15:56	905.8
16:17	905.8
16:29	906.1
Avg.	907.1

## RUN 3

TIME	Temp. deg <sup>F</sup>
16:51	905.0
17:04	903.0
17:25	901.3
17:47	899.5
Avg.	902.2

Molecular Weight of Emissions 76

Time	Ambient Temperature [F]	Stack Temperature [F]	Corrected Flue Gas Volumetric Flow Rate [ft <sup>3</sup> /min]	NOx [ppm]	Nox [lb/hr]
14:16	90	903.4	5755.4	563.2	36.8
14:17	90	903.4	5755.4	559.3	36.5
14:18	90	903.4	5755.4	556.6	36.3
14:19	90	903.4	5755.4	558.5	36.5
14:20	90	903.4	5755.4	558	36.4
14:21	90	903.4	5755.4	558.4	36.5
14:22	90	903.4	5755.4	562.3	36.7
14:23	90	903.4	5755.4	562.1	36.7
14:24	90	903.4	5755.4	566.7	37.0
14:25	90	903.4	5755.4	567.8	37.1
14:26	90	903.4	5755.4	567.3	37.0
14:27	90	903.4	5755.4	565.1	36.9
14:28	90	903.4	5755.4	566.7	37.0
14:29	90	903.4	5755.4	566	37.0
14:30	90	903.4	5755.4	563.5	36.8
14:31	90	903.4	5755.4	565.9	37.0
14:32	90	903.4	5755.4	573.1	37.4
14:33	90	903.4	5755.4	574.4	37.5
14:34	90	903.4	5755.4	573	37.4
14:35	90	905.8	5745.2	577.4	37.6
14:36	90	905.8	5745.2	577.3	37.6
14:37	90	905.8	5745.2	573.7	37.4
14:38	90	905.8	5745.2	576	37.5
14:39	90	905.8	5745.2	575.7	37.5
14:40	90	905.8	5745.2	576.3	37.6
14:41	90	905.8	5745.2	573.5	37.4
14:42	90	905.8	5745.2	573.6	37.4
14:43	90	905.8	5745.2	575.5	37.5
14:44	90	905.8	5745.2	573.7	37.4
14:45	90	905.8	5745.2	569.7	37.1
14:46	90	905.8	5745.2	567.7	37.0
14:47	90	905.8	5745.2	566.6	36.9
14:48	90	905.8	5745.2	566.4	36.9
14:49	90	905.8	5745.2	573.8	37.4
14:50	90	907.3	5738.9	572.8	37.3
14:51	90	907.3	5738.9	570.3	37.1
14:52	90	907.3	5738.9	569.6	37.1
14:53	90	907.3	5738.9	570.4	37.1
14:54	90	907.3	5738.9	568.8	37.0
14:55	90	907.3	5738.9	568.1	37.0
14:56	90	907.3	5738.9	566.1	36.9
14:57	90	907.3	5738.9	565.9	36.8
14:58	90	907.3	5738.9	566.4	36.9
14:59	90	907.3	5738.9	565	36.8
15:00	90	907.3	5738.9	561.8	36.6

## Unit 29

15:01	90	907.3	5738.9	561.3	36.5
15:02	90	907.3	5738.9	559.5	36.4
15:03	90	907.3	5738.9	563.2	36.7
15:04	90	907.3	5738.9	564.8	36.8
15:05	90	907.3	5738.9	563.8	36.7
15:06	90	907.3	5738.9	558.7	36.4
15:07	90	909.1	5731.4	561.9	36.5
15:08	90	909.1	5731.4	567.7	36.9
15:09	90	909.1	5731.4	561.6	36.5
15:10	90	909.1	5731.4	565.3	36.8
15:11	90	909.1	5731.4	564.6	36.7
15:12	90	909.1	5731.4	565.4	36.8
15:13	90	909.1	5731.4	566	36.8
15:14	90	909.1	5731.4	564.1	36.7
15:15	90	909.1	5731.4	564.5	36.7
Run 1	90.0	906.0	5744.6	561.0	36.6
15:34	90	906.4	5742.7	587.7	38.3
15:35	90	906.4	5742.7	587.6	38.3
15:36	90	906.4	5742.7	583.4	38.0
15:37	90	906.4	5742.7	581.9	37.9
15:38	90	906.4	5742.7	582.7	38.0
15:39	90	910.8	5724.3	576.9	37.5
15:40	90	910.8	5724.3	577.2	37.5
15:41	90	910.8	5724.3	580.4	37.7
15:42	90	910.8	5724.3	574.3	37.3
15:43	90	910.8	5724.3	571.9	37.1
15:44	90	910.8	5724.3	572.2	37.2
15:45	90	910.8	5724.3	568.4	36.9
15:46	90	910.8	5724.3	569.7	37.0
15:47	90	910.8	5724.3	574.3	37.3
15:48	90	910.8	5724.3	572.7	37.2
15:49	90	910.8	5724.3	572.5	37.2
15:50	90	910.8	5724.3	566.9	36.8
15:51	90	910.8	5724.3	564.2	36.6
15:52	90	910.8	5724.3	563.6	36.6
15:53	90	910.8	5724.3	563.8	36.6
15:54	90	910.8	5724.3	560.7	36.4
15:55	90	910.8	5724.3	563	36.6
15:56	90	905.8	5745.2	564.7	36.8
15:57	90	905.8	5745.2	563	36.7
15:58	90	905.8	5745.2	562.3	36.7
15:59	90	905.8	5745.2	558.9	36.4
16:00	90	905.8	5745.2	558.6	36.4
16:01	90	905.8	5745.2	557.5	36.3
16:02	90	905.8	5745.2	560.3	36.5
16:03	90	905.8	5745.2	559.5	36.5
16:04	90	905.8	5745.2	558.2	36.4
16:05	90	905.8	5745.2	558.8	36.4
16:06	90	905.8	5745.2	559.3	36.5
16:07	90	905.8	5745.2	559.8	36.5
16:08	90	905.8	5745.2	561.5	36.6

## Unit 29

16:09	90	905.8	5745.2	560.1	36.5
16:10	90	905.8	5745.2	561.2	36.6
16:11	90	905.8	5745.2	563.5	36.7
16:12	90	905.8	5745.2	562.3	36.7
16:13	90	905.8	5745.2	563.4	36.7
16:14	90	905.8	5745.2	561.3	36.6
16:15	90	905.8	5745.2	563.5	36.7
16:16	90	905.8	5745.2	559.2	36.5
16:17	90	905.8	5745.2	561.6	36.6
16:18	90	905.8	5745.2	561.4	36.6
16:19	90	905.8	5745.2	560	36.5
16:20	90	905.8	5745.2	561.8	36.6
16:21	90	905.8	5745.2	561.1	36.6
16:22	90	905.8	5745.2	556.8	36.3
16:23	90	905.8	5745.2	559.5	36.5
16:24	90	905.8	5745.2	560.6	36.5
16:25	90	905.8	5745.2	561.1	36.6
16:26	90	905.8	5745.2	560.6	36.5
16:27	90	905.8	5745.2	558.7	36.4
16:28	90	905.8	5745.2	565.5	36.9
16:29	90	906.1	5744.0	565.1	36.8
16:30	90	906.1	5744.0	565.7	36.9
16:31	90	906.1	5744.0	566.8	36.9
16:32	90	906.1	5744.0	561.8	36.6
16:33	90	906.1	5744.0	564.2	36.8
Run 2	90.0	907.3	5739.0	561.0	36.5
16:51	90	905	5748.6	571.5	37.3
16:52	90	905	5748.6	569.3	37.1
16:53	90	905	5748.6	565.7	36.9
16:54	90	905	5748.6	568.6	37.1
16:55	90	905	5748.6	569.7	37.2
16:56	90	905	5748.6	567.3	37.0
16:57	90	905	5748.6	562.3	36.7
16:58	90	905	5748.6	560.1	36.5
16:59	90	905	5748.6	562.4	36.7
17:00	90	905	5748.6	559.6	36.5
17:01	90	905	5748.6	558.8	36.4
17:02	90	905	5748.6	557.6	36.4
17:03	90	905	5748.6	558.1	36.4
17:04	90	903	5757.0	558.3	36.5
17:05	90	903	5757.0	557	36.4
17:06	90	903	5757.0	554.5	36.2
17:07	90	903	5757.0	554.3	36.2
17:08	90	903	5757.0	553.3	36.1
17:09	90	903	5757.0	554	36.2
17:10	90	903	5757.0	552.6	36.1
17:11	90	903	5757.0	552.2	36.1
17:12	90	903	5757.0	551.9	36.0
17:13	90	903	5757.0	551.4	36.0
17:14	90	903	5757.0	550.7	36.0
17:15	90	903	5757.0	550.3	35.9

Unit 29

17:16	90	903	5757.0	553.3	36.1
17:17	90	903	5757.0	552.2	36.1
17:18	90	903	5757.0	551.6	36.0
17:19	90	903	5757.0	551.8	36.0
17:20	90	903	5757.0	553.4	36.1
17:21	90	903	5757.0	554.4	36.2
17:22	90	903	5757.0	553.1	36.1
17:23	90	903	5757.0	553.3	36.1
17:24	90	903	5757.0	551.9	36.0
17:25	90	901.3	5764.2	551.7	36.1
17:26	90	901.3	5764.2	549.9	36.0
17:27	90	901.3	5764.2	547.7	35.8
17:28	90	901.3	5764.2	546.2	35.7
17:29	90	901.3	5764.2	549.6	35.9
17:30	90	901.3	5764.2	548.9	35.9
17:31	90	901.3	5764.2	544.6	35.6
17:32	90	901.3	5764.2	549.7	35.9
17:33	90	901.3	5764.2	552.2	36.1
17:34	90	901.3	5764.2	552.8	36.2
17:35	90	901.3	5764.2	552.6	36.1
17:36	90	901.3	5764.2	550.2	36.0
17:37	90	901.3	5764.2	553.3	36.2
17:38	90	901.3	5764.2	553.1	36.2
17:39	90	901.3	5764.2	553	36.2
17:40	90	901.3	5764.2	553.9	36.2
17:41	90	901.3	5764.2	552.8	36.2
17:42	90	901.3	5764.2	549.7	35.9
17:43	90	901.3	5764.2	549.3	35.9
17:44	90	901.3	5764.2	551.1	36.0
17:45	90	901.3	5764.2	550	36.0
17:46	90	901.3	5764.2	548.6	35.9
17:47	90	899.5	5771.9	550.4	36.0
17:48	90	899.5	5771.9	553	36.2
17:49	90	899.5	5771.9	552.3	36.2
17:50	90	899.5	5771.9	549.3	36.0
Run 2	90.0	902.6	5758.8	550.0	35.9
Test Avg.	Test Avg.	Calc. Avg.	Corr. Avg.	Corr. lbs/Hour	



# TEMPERATURE MEASUREMENTS FIELD DATA SHEET

Date 7/19/01

Facility Hookers Ring-Haver

Unit No. 30

Location Outlet

Load (mw) 1,825 Pyrometer I. D. 28-02800

Operator D. Smith

## RUN 1

TIME	Temp. deg <sup>F</sup>
06:59	834.5
07:15	836.6
07:29	839.7
07:46	845.4
Avg.	839.1

## RUN 2

TIME	Temp. deg <sup>F</sup>
08:18	847.5
08:33	849.9
08:52	850.2
09:06	850.2
Avg.	849.4

## RUN 3

TIME	Temp. deg <sup>F</sup>
<del>10:27</del> 09:29	850.6
09:46	853.2
10:00	853.4
10:16	855.4
Avg.	853.2

## TEST PARTICIPANTS

---

### Tampa Electric Company

Raymond McDarby	Sr. Environmental Technician
David Perez	Boiler Turbine Operator
David Smith	Coordinator – Air Services
Shannon Todd	Principle Engineer

### Ring Haver

Carlos Acosta	Technician
---------------	------------

### Hillsborough County EPC

Alan Rodriguez	Compliance Engineer
----------------	---------------------

### Florida Environmental Protection Commission

Martin Costello	Professional Engineer
-----------------	-----------------------