

**BIG BEND STATION**  
**TITLE V AIR OPERATION PERMIT**  
**REVISION APPLICATION**

**Prepared for:**



**TAMPA ELECTRIC**  
**Tampa, Florida**

**Prepared by:**



***Environmental Consulting & Technology, Inc.***  
***3701 Northwest 98<sup>th</sup> Street***  
***Gainesville, Florida 32606***

**ECT No. 030609-0100**

**December 2003**



TAMPA ELECTRIC

January 15, 2004

Mr. Al Linero  
Florida Department of Environmental Protection  
Division of Air Resource Management  
111 South Magnolia, Suite 4  
Tallahassee, FL 32301

RECEIVED

JAN 16 2004

BUREAU OF AIR REGULATION

Via FedEx  
Airbill No. 7925 5079 2123

Re: Tampa Electric Company  
Big Bend Station  
Title V Air Operation Permit Revision Request  
Permit No. 0570039-010-AV

Project No.: 0570039-015-AV

Dear Mr. Linero:

Tampa Electric Company (TEC) submits a request for changes to several conditions of Big Bend Station Title V Air Operation Permit Number 0570039-010-AV. The requested permit condition changes are minor in nature and provide consistency with applicable provisions of the Environmental Protection Agency (EPA) Consent Decree and Florida Department of Environmental Protection (FDEP) Consent Final Judgment. TEC continues to review the Title V permit to ensure it reflects current operations; therefore this request does not include all corrections to the permit. As TEC determines additional corrections may be useful, a separate permit modification request will be submitted. This request is submitted as a Title V air operation permit revision in accordance with FDEP guidance.

The proposed Title V permit condition changes address the monitoring of sulfur dioxide emissions due to the combustion of petcoke and other solid fuels, coal washing, spare flue gas desulfurization system module, flyash handling rates, limestone handling, and various clerical corrections to the current Title V permit.

As requested by the Department per the August 22, 2003 conversation, the enclosed Title V air operation permit revision application includes the following material:

- (1) Attachment A: Completed Application for Air Permit – Long Form (Facility Information section only, including Responsible Official and Professional Engineer certifications);
- (2) Attachment B: Compliance Report and Plan;
- (3) Attachment C: Detailed narrative describing each requested permit condition change and the rationale for the change;
- (4) Attachment D: Marked-up copy of the current Title V permit that contains the requested permit condition changes. For each permit condition change, the requested permit language (strikeout and/or additional text) is shown followed by the rationale for the permit condition change;
- (5) Attachment E: Flow diagrams of the limestone handling equipment;
- (6) Attachment F: Visible emission data supporting the removal of the limestone unloading area baghouse; and
- (7) Attachment G: Copy of the recent Modifications to the Big Bend Station Conditions of Certification.

TAMPA ELECTRIC COMPANY  
P. O. BOX 111 TAMPA, FL 33601-0111

(813) 228-4111

AN EQUAL OPPORTUNITY COMPANY  
HTTP://WWW.TAMPAELECTRIC.COM

CUSTOMER SERVICE:  
HILLSBOROUGH COUNTY (813) 223-0800  
OUTSIDE HILLSBOROUGH COUNTY 1 (888) 223-0800

Mr. Al Linero  
January 15, 2004  
Page 2 of 2

To facilitate the Department's review of this Title V permit revision request, an electronic copy of the marked-up Big Bend Station Title V permit is also being submitted to you via e-mail. This electronic file of the complete Big Bend Station Title V permit shows the requested permit condition changes using highlighted formats (i.e., blue strikeout for deleted text and blue underline for added text) as well as the rationale for each requested permit condition change.

TEC appreciates the cooperation and consideration of the Department in this requested Title V permit revision for the Big Bend Station. Your expeditious processing of this request for a permit revision to the Big Bend Station Title V permit will be appreciated. If you have any questions or comments pertaining to this request, please direct them to Raiza Calderon at (813) 641-5261 or me.

Sincerely,

A handwritten signature in black ink, appearing to read 'Laura Crouch', followed by a small 'for' written in the same ink.

Laura Crouch  
Manager - Air Programs  
Environmental, Health, and Safety

EA/bmr/RC171

Enclosure

c/enc: Ms. Cindy Phillips, FDEP  
Mr. Jerry Kissel, FDEP SW District  
Mr. Jerry Campbell – EPCHC

**BIG BEND STATION**  
**TITLE V AIR OPERATION PERMIT**  
**REVISION APPLICATION**

**Prepared for:**



**TAMPA ELECTRIC**  
**Tampa, Florida**

**Prepared by:**



***Environmental Consulting & Technology, Inc.***  
*3701 Northwest 98<sup>th</sup> Street*  
*Gainesville, Florida 32606*

**ECT No. 030609-0100**

**December 2003**

## INTRODUCTION

Tampa Electric Company (TEC) operates four, solid fuel-fired steam boilers (Emission Units ID Nos. 001 through 004) at its Big Bend Station located at Big Bend Road, North Ruskin, Hillsborough County, Florida. In addition to the four solid fuel-fired boilers, the Big Bend Station emission sources include three combustion turbines (Emission Units ID Nos. 005 through 007) and various solid fuel material handling and storage activities (Emission Units ID Nos. 008 through 036). Operation of the Big Bend Station emission units is currently authorized by FINAL Title V Permit Revision No. 0570039-010-AV. FINAL Permit No. 0570039-010-AV was issued with an effective date of January 1, 2001, and expires on December 31, 2004.

The purpose of this Title V air operation permit revision application is to request changes to several conditions of FINAL Title V Permit Revision No. 0570039-010-AV. The proposed Title V permit condition changes address the monitoring of sulfur dioxide emissions due to the combustion of petcoke and other solid fuels, coal washing, spare flue gas desulfurization system module, flyash handling rates, limestone handling, and various clerical corrections to the current Title V permit.

A brief overview of the proposed permit condition changes is as follows:

- **Petcoke Sulfur Content (Emission Units 1, 2, and 3)**—Deletion of Specific Conditions A.16 and A.26 regarding petcoke sulfur content monitoring for Units 1, 2, and 3. SO<sub>2</sub> continuous emissions monitoring systems (CEMS) are presently used for compliance purposes.
- **Coal Washing (Emission Unit 4)**—Deletion of obsolete Specific Condition B.2.d regarding coal washing for Unit 4. The U.S. Environmental Protection Agency (EPA) Consent Decree and Florida Department of Environmental Protection (FDEP) Consent Final Judgment supersede this coal washing requirement. In addition, the proposed June 6, 2003, modifications to Unit 4 Conditions of Certification delete the requirement for coal washing.

- **Spare Flue Gas Desulfurization System Module (Emission Unit 4)**—Deletion of obsolete Specific Condition B.12 regarding the requirement for a spare flue gas desulfurization system module. The common FGD scrubbing of Units 3 and 4, EPA Consent Decree, and FDEP Consent Final Judgment all supersede the requirements for a Unit 4 spare flue gas desulfurization module.
- **SO<sub>2</sub> Percent Reduction Calculations (Emission Unit 4)**—Deletion of obsolete Specific Condition B.28 concerning the calculation of potential SO<sub>2</sub> percent reductions based on coal washing and fuel sampling and analysis for Unit 4. The SO<sub>2</sub> CEMS is used for compliance monitoring. The common FGD scrubbing of Units 3 and 4, EPA Consent Decree, and FDEP Consent Final Judgment all supersede the coal washing requirement for Unit 4. Also, the proposed June 6, 2003 modifications to Unit 4 Conditions of Certification delete requirement for coal washing.
- **Flyash Handling and Storage (Emission Units 9 and 19)**—Revision to Condition D.1 to specify maximum loading rate of 44.5 tons per hour for Fly Ash Silo No. 2 consistent with the permit language used for Fly Ash Silo No. 1.
- **Administrative Corrections (Steam Generators, Flyash Handling and Storage, Flyash Silo No. 3, Limestone Handling and Storage, Coal Bunkers, Solid Fuel Yard, Surface Coating of Miscellaneous Metal Parts, Lime Silo, and Acid Rain Part Emission Units)**—Various clerical corrections and updates.

FDEP's *Application for Air Permit—Long Form*, DEP Form No. 62-210.900(1), Effective June 16, 2003, follows this introduction (Attachment A). A Compliance Report and Plan is provided in Attachment B. A detailed discussion of each request permit condition change is provided in Attachment C. A marked-up copy of the current Big Bend Station Title V permit is provided in Attachment D. Attachments E, F, and G contain a flow diagram of the limestone handling system, visible emissions data to support the removal of the limestone unloading area baghouse, and recent modifications to the Big Bend Station Conditions of Certification, respectively. An electronic copy of Attachment D has also been provided to the Department via electronic mail.

**ATTACHMENT A**

**APPLICATION FOR AIR PERMIT – LONG FORM**



# Department of Environmental Protection

## Division of Air Resource Management

### APPLICATION FOR AIR PERMIT - LONG FORM

#### I. APPLICATION INFORMATION

**Air Construction Permit** – Use this form to apply for an air construction permit for a proposed project:

- subject to prevention of significant deterioration (PSD) review, nonattainment area (NAA) new source review, or maximum achievable control technology (MACT) review; or
- where the applicant proposes to assume a restriction on the potential emissions of one or more pollutants to escape a federal program requirement such as PSD review, NAA new source review, Title V, or MACT; or
- at an existing federally enforceable state air operation permit (FESOP) or Title V permitted facility.

**Air Operation Permit** – Use this form to apply for:

- an initial federally enforceable state air operation permit (FESOP); or
- an initial/revised/renewal Title V air operation permit.

**Air Construction Permit & Revised/Renewal Title V Air Operation Permit (Concurrent Processing Option)**

– Use this form to apply for both an air construction permit and a revised or renewal Title V air operation permit incorporating the proposed project.

To ensure accuracy, please see form instructions.

#### Identification of Facility

1. Facility Owner/Company Name: <b>Tampa Electric Company</b>	
2. Site Name: <b>Big Bend Station</b>	
3. Facility Identification Number: <b>0570039</b>	
4. Facility Location... Street Address or Other Locator: <b>Big Bend Road</b> City: <b>North Ruskin</b> County: <b>Hillsborough</b> Zip Code: <b>33575</b>	
5. Relocatable Facility? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	6. Existing Title V Permitted Facility? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

#### Application Contact

1. Application Contact Name: <b>Raiza Calderon</b>	
2. Application Contact Mailing Address... Organization/Firm: <b>Tampa Electric Company</b> Street Address: <b>6994 U.S. Highway 41 North</b> City: <b>Apollo Beach</b> State: <b>FL</b> Zip Code: <b>33572-9200</b>	
3. Application Contact Telephone Numbers... Telephone: <b>(813) 641-5261</b> ext.                      Fax: <b>(813) 641-5081</b>	
4. Application Contact Email Address: <b>rcalderon@tecoenergy.com</b>	

#### Application Processing Information (DEP Use)

1. Date of Receipt of Application:	
2. Project Number(s):	
3. PSD Number (if applicable):	
4. Siting Number (if applicable):	



**APPLICATION INFORMATION**

**Purpose of Application**

**This application for air permit is submitted to obtain: (Check one)**

**Air Construction Permit**

Air construction permit.

**Air Operation Permit**

Initial Title V air operation permit.

Title V air operation permit revision.

Title V air operation permit renewal.

Initial federally enforceable state air operation permit (FESOP) where professional engineer (PE) certification is required.

Initial federally enforceable state air operation permit (FESOP) where professional engineer (PE) certification is not required.

**Air Construction Permit and Revised/Renewal Title V Air Operation Permit  
(Concurrent Processing)**

Air construction permit and Title V permit revision, incorporating the proposed project.

Air construction permit and Title V permit renewal, incorporating the proposed project.

**Note: By checking one of the above two boxes, you, the applicant, are requesting concurrent processing pursuant to Rule 62-213.405, F.A.C. In such case, you must also check the following box:**

I hereby request that the department waive the processing time requirements of the air construction permit to accommodate the processing time frames of the Title V air operation permit.

**Application Comment**

**This permit revision application requests changes to the conditions of FINAL Title V Permit Revision No. 0570039-010-AV. Please refer to see Attachments C and D for a discussion of the requested permit condition changes.**



**APPLICATION INFORMATION**

**Owner/Authorized Representative Statement N/A**


**Complete if applying for an air construction permit or an initial FESOP.**

1. Owner/Authorized Representative Name :
2. Owner/Authorized Representative Mailing Address... Organization/Firm: Street Address: City: State: Zip Code:
3. Owner/Authorized Representative Telephone Numbers... Telephone: ( ) - ext. Fax: ( ) -
4. Owner/Authorized Representative Email Address:
5. Owner/Authorized Representative Statement:  <i>I, the undersigned, am the owner or authorized representative of the facility addressed in this air permit application. I hereby certify, based on information and belief formed after reasonable inquiry, that the statements made in this application are true, accurate and complete and that, to the best of my knowledge, any estimates of emissions reported in this application are based upon reasonable techniques for calculating emissions. The air pollutant emissions units and air pollution control equipment described in this application will be operated and maintained so as to comply with all applicable standards for control of air pollutant emissions found in the statutes of the State of Florida and rules of the Department of Environmental Protection and revisions thereof and all other requirements identified in this application to which the facility is subject. I understand that a permit, if granted by the department, cannot be transferred without authorization from the department, and I will promptly notify the department upon sale or legal transfer of the facility or any permitted emissions unit.</i>  _____ Signature  _____ Date



**APPLICATION INFORMATION**  
**Professional Engineer Certification**

1. Professional Engineer Name: <b>Thomas W. Davis</b> Registration Number: <b>36777</b>
2. Professional Engineer Mailing Address... Organization/Firm: <b>Environmental Consulting &amp; Technology, Inc.</b> Street Address: <b>3701 Northwest 98<sup>th</sup> Street</b> City: <b>Gainesville</b> State: <b>FL</b> Zip Code: <b>32606-5004</b>
3. Professional Engineer Telephone Numbers. Telephone: <b>(352) 332-0444</b> ext. Fax: <b>(352) 332-6722</b>
4. Professional Engineer Email Address: <b>tdavis@ectinc.com</b>
5. Professional Engineer Statement: <p><i>I, the undersigned, hereby certify, except as particularly noted herein*, that:</i></p> <p><i>(1) To the best of my knowledge, there is reasonable assurance that the air pollutant emissions unit(s) and the air pollution control equipment described in this application for air permit, when properly operated and maintained, will comply with all applicable standards for control of air pollutant emissions found in the Florida Statutes and rules of the Department of Environmental Protection; and</i></p> <p><i>(2) To the best of my knowledge, any emission estimates reported or relied on in this application are true, accurate, and complete and are either based upon reasonable techniques available for calculating emissions or, for emission estimates of hazardous air pollutants not regulated for an emissions unit addressed in this application, based solely upon the materials, information and calculations submitted with this application.</i></p> <p><i>(3) If the purpose of this application is to obtain a Title V air operation permit (check here <input checked="" type="checkbox"/> , if so), I further certify that each emissions unit described in this application for air permit, when properly operated and maintained, will comply with the applicable requirements identified in this application to which the unit is subject, except those emissions units for which a compliance plan and schedule is submitted with this application.</i></p> <p><i>(4) If the purpose of this application is to obtain an air construction permit (check here <input type="checkbox"/> , if so) or concurrently process and obtain an air construction permit and a Title V air operation permit revision or renewal for one or more proposed new or modified emissions units (check here <input type="checkbox"/> , if so), I further certify that the engineering features of each such emissions unit described in this application have been designed or examined by me or individuals under my direct supervision and found to be in conformity with sound engineering principles applicable to the control of emissions of the air pollutants characterized in this application.</i></p> <p><i>(5) If the purpose of this application is to obtain an initial air operation permit or operation permit revision or renewal for one or more newly constructed or modified emissions units (check here <input type="checkbox"/> , if so), I further certify that, with the exception of any changes detailed as part of this application, each such emissions unit has been constructed or modified in substantial accordance with the information given in the corresponding application for air construction permit and with all provisions contained in such permit.</i></p> <p><i>Thomas W. Davis</i>  _____  Signature  (seal)</p> <p><u>12/4/03</u>  _____  Date</p>



Attach any exception to certification statement.



**Facility Regulatory Classifications**

Check all that would apply *following* completion of all projects and implementation of all other changes proposed in this application for air permit. Refer to instructions to distinguish between a “major source” and a “synthetic minor source.”

1. <input type="checkbox"/> Small Business Stationary Source	<input type="checkbox"/> Unknown
2. <input type="checkbox"/> Synthetic Non-Title V Source	
3. <input checked="" type="checkbox"/> Title V Source	
4. <input checked="" type="checkbox"/> Major Source of Air Pollutants, Other than Hazardous Air Pollutants (HAPs)	
5. <input type="checkbox"/> Synthetic Minor Source of Air Pollutants, Other than HAPs	
6. <input checked="" type="checkbox"/> Major Source of Hazardous Air Pollutants (HAPs)	
7. <input type="checkbox"/> Synthetic Minor Source of HAPs	
8. <input checked="" type="checkbox"/> One or More Emissions Units Subject to NSPS (40 CFR Part 60)	
9. <input type="checkbox"/> One or More Emissions Units Subject to Emission Guidelines (40 CFR Part 60)	
10. <input type="checkbox"/> One or More Emissions Units Subject to NESHAP (40 CFR Part 61 or Part 63)	
11. <input type="checkbox"/> Title V Source Solely by EPA Designation (40 CFR 70.3(a)(5))	
12. Facility Regulatory Classifications Comment:	

**List of Pollutants Emitted by Facility**

1. Pollutant Emitted	2. Pollutant Classification	3. Emissions Cap [Y or N]?
NOX	A	N
SO2	A	Y
CO	A	N
PM10	A	Y
PM	A	Y
SAM (Sulfuric Acid Mist)	A	N
VOC	A	N
PB	B	N
H106 (Hydrogen Chloride)	A	N
H107 (Hydrogen Fluoride)	A	N
H133 (Nickel Compounds)	A	N
HAPS (Total HAPs)	A	N



## B. EMISSIONS CAPS

### Facility-Wide or Multi-Unit Emissions Caps

1. Pollutant Subject to Emissions Cap	2. Facility Wide Cap [Y or N]? (all units)	3. Emissions Unit ID No.s Under Cap (if not all units)	4. Hourly Cap (lb/hr)	5. Annual Cap (ton/yr)	6. Basis for Emissions Cap
<b>SO2</b>	<b>N</b>	<b>001, 002, 003, 004</b>		<b>71,810</b>	<b>ESCPSD</b>
<b>PM/PM10</b>	<b>N</b>	<b>001, 002, 003, 004</b>		<b>2,767</b>	<b>ESCPSD</b>

7. Facility-Wide or Multi-Unit Emissions Cap Comment:

**Additional SO<sub>2</sub> caps for Units 001, 002, and 003 are 6.5 lb/mmBtu (2-hour average), 31.5 ton/hr (3-hour average), and 25 ton/hr (24-hour midnight to midnight block average). In addition, Units 001 and 002 are limited to 16.5 ton/hr (24-hour midnight to midnight block average).**

### C. FACILITY ADDITIONAL INFORMATION

#### Additional Requirements for All Applications, Except as Otherwise Stated

1. Facility Plot Plan: (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought) <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Previously Submitted, Date: _____
2. Process Flow Diagram(s): (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought) <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Previously Submitted, Date: _____
3. Precautions to Prevent Emissions of Unconfined Particulate Matter: (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought) <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Previously Submitted, Date: _____

#### Additional Requirements for Air Construction Permit Applications N/A

1. Area Map Showing Facility Location: <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable (existing permitted facility)
2. Description of Proposed Construction or Modification: <input type="checkbox"/> Attached, Document ID: _____
3. Rule Applicability Analysis: <input type="checkbox"/> Attached, Document ID: _____
4. List of Exempt Emissions Units (Rule 62-210.300(3)(a) or (b)1., F.A.C.): <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable (no exempt units at facility)
5. Fugitive Emissions Identification (Rule 62-212.400(2), F.A.C.): <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable
6. Preconstruction Air Quality Monitoring and Analysis (Rule 62-212.400(5)(f), F.A.C.): <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable
7. Ambient Impact Analysis (Rule 62-212.400(5)(d), F.A.C.): <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable
8. Air Quality Impact since 1977 (Rule 62-212.400(5)(h)5., F.A.C.): <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable
9. Additional Impact Analyses (Rules 62-212.400(5)(e)1. and 62-212.500(4)(e), F.A.C.): <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable
10. Alternative Analysis Requirement (Rule 62-212.500(4)(g), F.A.C.): <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable



**ATTACHMENT B**

**COMPLIANCE REPORT AND PLAN**

**TAMPA ELECTRIC COMPANY  
BIG BEND STATION**

**COMPLIANCE REPORT, PLAN,  
AND CERTIFICATION**

**1. Compliance Report and Plan**

Appendix A of the initial Big Bend Station Title V operation permit application, FINAL Permit No. 0570039-012-AC, and FINAL Title V Permit Revision No. 0570039-010-AV identify the requirements that are applicable to the emission units that comprise this Title V source. Each emissions unit is in compliance, and will continue to comply, with the respective applicable requirements.

The emission units that comprise this Title V source will comply with future-effective applicable requirements on a timely basis.

**2. Proposed Schedule for the Submission of Periodic Compliance Statements Throughout the Permit Term**

Periodic compliance statements are proposed to be submitted on an annual basis within 60 days after the end of each calendar year pursuant to the requirements of FDEP Rule 62-213.440(3)(a)2.a, F.A.C.

**3. Compliance Certification**

I, the undersigned, am the responsible official as defined in Chapter 62-210.200(220), F.A.C., of the Title V source for which this report is being submitted. I hereby certify, based on information and belief formed after reasonable inquiry, that the statements made and data contained in this report are true, accurate, and complete.

Karen A. Sheffield  
Karen Sheffield  
General Manager—Big Bend Station

11/15/09  
Date

**ATTACHMENT C**

**REQUESTED TITLE V PERMIT  
CONDITION CHANGES**

**TITLE V AIR OPERATING PERMIT  
FINAL PERMIT REVISION NO.: 0570039-010-AV  
REQUESTED PERMIT CONDITION CHANGES**

The proposed Title V permit condition changes address the monitoring of sulfur dioxide emissions due to the combustion of petcoke and other solid fuels, coal washing, spare flue gas desulfurization system module, flyash handling rates, limestone handling, and various clerical corrections to the current Title V permit. A discussion of each requested permit condition change is provided in the following sections. The page numbers indicated below are references to Title V FINAL Permit Revision No: 0570039-010-AV.

**Permit Change No. 1**

**Overall Facility Process Description – Pages 2 and 3**

Requested revisions to the overview description of the Big Bend Station facility reflect current equipment description terminology and update the description with respect to the limestone handling system.

**Permit Change No. 2**

**Emission Unit Summary – Page 4**

Deletion of duplicate emission units is requested. Emission Unit ID 024 (Limestone Handling Conveyor LE transfers to limestone storage silos) is requested since this activity is also addressed by Emission Unit 020. Consistent with the permit organizational scheme used for Units 1, 2, and 3 coal bunkers, and the addition of a new emission unit (EU ID 037) for Unit 4 coal bunker is requested. Deletion of Emission Unit 031 (cyclone collectors for fuel bunkers) is requested since this activity is also addressed by Emission Unit IDs 015, 016, 017, and 037.

**Permit Change No. 3**

**Condition A.1 on Page 9**

Correction of a typographical error is requested.

**Permit Change No. 4**

**Condition A.2 on Page 9-10**

Correction of a typographical error is requested.

**Permit Change No. 5**

**Condition A.11 on Page 12-13**

Correction of a typographical error is requested.

**Permit Change No. 6**

**Condition A.16 on Page 14 - Petcoke Sulfur Content Monitoring**

Deletion of this obsolete petcoke fuel sulfur content monitoring condition is requested. SO<sub>2</sub> emissions due to the combustion of all solid fuels (including petcoke) from Units 1, 2, and 3 are measured directly using continuous emissions monitoring systems (CEMS).

**Permit Change No. 7**

**Condition A.23 on Page 15**

Correction of a typographical error is requested.

**TITLE V AIR OPERATING PERMIT  
FINAL PERMIT REVISION NO.: 0570039-010-AV  
REQUESTED PERMIT CONDITION CHANGES**

**Permit Change No. 8**

**Condition A.24 on Page 15**

Correction of a typographical error is requested.

**Permit Change No. 9**

**Condition A.26 on Page 15 - Petcoke Sulfur Content Recordkeeping**

Deletion of this obsolete petcoke fuel sulfur content recordkeeping condition is requested. Units 1, 2, and 3 SO<sub>2</sub> emissions due to the combustion of all solid fuels (including petcoke) are measured directly using CEMS. The SO<sub>2</sub> CEMS emission data is recorded in accordance with Acid Rain Program requirements.

**Permit Change No. 10**

**Condition A.29 on Page 16**

Correction of a typographical error is requested.

**Permit Change No. 11**

**Condition A.30 on Page 16**

Deletion of this obsolete recordkeeping condition is requested. This condition has already been demonstrated and complied with for 5 years.

**Permit Change No. 12**

**Condition A.32 on Page 16**

Correction of a clerical error is requested. Emissions from common stacks CS0W1 and CS001 represent the combined emissions from Units 1 and 2.

**Permit Change No. 13**

**Unit 4 Description – Page 18**

Deletion of “SCC 1-01-002-12” from the Unit 4 description is requested. This SCC is specific to bituminous coal. However, Unit 4 is authorized to burn other solid fuels in addition to bituminous coal; e.g., petcoke.

Corrections to the Unit 3/Unit 4 FGD process description and emissions monitoring are requested.

**Permit Change No. 14**

**Condition B.2 on Page 19 – Unit 4 Coal Washing**

Use of current equipment terminology (i.e., “mill” instead of “crusher”) is requested.

Deletion of this obsolete permit condition requiring coal washing for Unit 4 is requested. The EPA Consent Decree and FDEP Consent Final Judgment requirements with respect to Unit 4 SO<sub>2</sub> emissions supersede the coal washing requirement. Unit 4 utilizes a SO<sub>2</sub> CEMS for compliance monitoring. Also, the proposed June 6, 2003 modifications to Unit 4 Conditions of Certification delete the requirement for coal washing.



**TITLE V AIR OPERATING PERMIT  
FINAL PERMIT REVISION NO.: 0570039-010-AV  
REQUESTED PERMIT CONDITION CHANGES**

**Permit Change No. 15**

**Condition B.12 on Page 21 – Spare flue gas desulfurization system**

Deletion of the obsolete permit condition requiring operating a spare flue gas desulfurization system module is requested. Common FGD scrubbing of Units 3 and 4, EPA Consent Decree, and FDEP Consent Final Judgment supersede requirements for a spare flue gas desulfurization module.

**Permit Change No. 16**

**Condition B.13 on Page 21**

Correction of a typographical error is requested.

**Permit Change No. 17**

**Condition B.19 on Page 22-23 – Unit 4 CEMS**

Corrections to the Unit 4 FGD configuration and emissions monitoring description are requested.

**Permit Change No. 18**

**Condition B.28 on Page 25-26 – Unit 4 SO<sub>2</sub> Percent Reduction**

Deletion of this obsolete permit condition requiring the calculation of SO<sub>2</sub> percent reduction for Unit 4 is requested. Unit 4 utilizes a SO<sub>2</sub> CEMS for compliance monitoring. The common scrubbing of Units 3 and 4, the EPA Consent Decree, and FDEP Consent Final Judgment requirements with respect to Unit 4 SO<sub>2</sub> emissions supersedes the requirements for SO<sub>2</sub> percent reduction calculation.

**Permit Change No. 19**

**Condition B.29 on Page 26**

Correction of a typographical error is requested.

**Permit Change No. 20**

**Condition B.35 on Page 27-28**

Deletion of this obsolete permit condition requiring fuel pretreatment credit records to be submitted is requested. The EPA Consent Decree and FDEP Consent Final Judgment requirements with respect to Unit 4 SO<sub>2</sub> emissions supersede the coal washing requirement. Unit 4 utilizes a SO<sub>2</sub> CEMS for compliance monitoring. Also, the proposed June 6, 2003 modifications to Unit 4 Conditions of Certification delete the requirement for coal washing.

**Permit Change No. 21**

**Fly Ash Handling Description – Page 39**

Corrections to the fly ash handling system process description are requested.

**TITLE V AIR OPERATING PERMIT  
FINAL PERMIT REVISION NO.: 0570039-010-AV  
REQUESTED PERMIT CONDITION CHANGES**

**Permit Change No. 22**

**Condition D.1 on Page 39-40 – Fly Ash Handling Capacity**

Addition of a 44.5 ton per hour maximum loading rate for Fly Ash Silo No. 2 consistent with the permit language used for Fly Ash Silo No. 1 is requested.

**Permit Change No. 23**

**Condition D.10 on Page 41 – Fly Ash Tanker Truck Loading Test Conditions**

Request removal of the word “completely” with regards to tanker truck loading valve position since the truck loading valves are not normally operated completely open.

**Permit Change No. 24**

**Fly Ash Silo No 3 Description – Page 43**

An addition to the Fly Ash Silo No. 3 process description to include fly ash pugmill operations is requested.

**Permit Change No. 25**

**Limestone Handling and Storage Emission Unit Description – Page 44**

Request a change to the description of EU 011 to remove railcar limestone unloading and the limestone receiving hopper baghouse. Limestone is no longer received by railcar. As received, the limestone has a high moisture content (average moisture content of 12.4 weight percent) and therefore the limestone truck unloading process generates insignificant amounts of fugitive particulate matter (PM) emissions. Limestone truck unloading potential emission rates, using AP-42 procedures, are estimated to total 0.12 and 0.06 tons per year for PM and PM<sub>10</sub>, respectively. Actual visible emission observations of the limestone truck unloading process (without the baghouse in service) conducted recently have shown no visible emissions. Accordingly, a baghouse is not necessary to comply with permit opacity limits. Since the existing baghouse is prone to high maintenance and is not needed to meet current Title V permit limits, removal of this baghouse from the Title V permit is requested.

Deletion of Emission Unit ID 024 (Limestone Handling Conveyor LE transfers to limestone storage silos) is requested since this activity is also addressed by Emission Unit 020.

**Permit Change No. 26**

**Condition F.1 on Page 44 – Limestone Handling PTE Parameters**

Deletion of “hoppers” from this condition consistent with Permit Change No. 19 above is requested.

**Permit Change No. 27**

**Condition F.4 on Page 45 – Limestone Handling Exhaust Requirements**

Deletion of “hoppers” from this condition consistent with Permit Change No. 19 above is requested.

**TITLE V AIR OPERATING PERMIT  
FINAL PERMIT REVISION NO.: 0570039-010-AV  
REQUESTED PERMIT CONDITION CHANGES**

**Permit Change No. 28**

**Coal Bunker Emission Unit Description – Page 46**

Consistent with the permit organizational scheme used for Unit 1, 2, and 3 coal bunkers, the additional of a new emission unit (EU ID 037) and description for Unit 4 coal bunker are requested.

**Permit Change No. 29**

**Condition G.2 on Page 46**

Correction of a typographical error is requested.

**Permit Change No. 30**

**Condition G.4 on Page 46-47 – Coal Bunker Maximum PM Emissions**

Use of current equipment terminology (i.e., “rotoclone” instead of “cyclone”) is requested.

**Permit Change No. 31**

**Solid Fuel Yard Description – Page 48**

Deletion of Emission Unit 031 (cyclone collectors for fuel bunkers) is requested since this activity is also addressed by Emission Unit IDs 015, 016, 017, and 037.

Use of current equipment terminology (i.e., “mills/pulverizers” instead of “crushers”) is requested.

**Permit Change No. 32**

**Condition I.6 on Page 51 – Surface Coating Emission Limits**

Correction of a typographical error is requested.

**Permit Change No. 33**

**Lime Silo Description – Page 69**

Corrections to the lime silo process description are requested.

**Permit Change No. 34**

**Acid Rain Part Condition 2 on Page 76-79 – SO<sub>2</sub> Allowances**

Corrections of typographical errors are requested.

**ATTACHMENT D**

**MARK-UP OF CURRENT  
TITLE V PERMIT**

Tampa Electric Company  
Big Bend Station  
**Facility ID No.:** 0570039  
Hillsborough County

Title V Air Operation Permit Revision  
**FINAL Permit Revision No.:** 0570039-010-AV

Permitting Authority:

State of Florida  
Department of Environmental Protection  
Division of Air Resources Management  
Bureau of Air Regulation  
Title V Section

Mail Station #5505  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

Telephone: 850/488-0114  
Fax: 850/922-6979

Compliance Authority:

Environmental Protection Commission  
of Hillsborough County  
1410 North 21 Street  
Tampa, Florida 33605  
Telephone: 813/272-5530  
Fax: 813/272-5605

Title V Air Operation Permit  
FINAL Permit Revision No.: 0570039-010-AV

**Table of Contents**

<u>Section</u>	<u>Page Number</u>
Placard Page .....	1
I. Facility Information .....	2 - 5
A. Facility Description.	
B. Summary of Emissions Unit ID Nos. and Brief Descriptions.	
C. Relevant Documents.	
II. Facility-wide Conditions .....	5 - 7
III. Regulated Emissions Units Conditions.....	8 - 72
A. Steam Generators Units Nos. 1, 2, & 3 .....	8 - 16
B. Steam Generator Unit No. 4 (and No. 3 in integrated mode).....	17 - 33
C. Combustion Turbine.....	34 - 36
D. Flyash Handling and Storage.....	37 - 40
E. Flyash Silo No. 3.....	41
F. Limestone Handling and Storage.....	42 - 43
G. Coal Bunkers with Roto-Clones.....	44 - 45
H. Solid Fuel Yard.....	46 - 47
I. Surface Coating of Miscellaneous Metal Parts.....	48 - 49
J. Abrasive Blasting.....	50 - 51
K. Surface Coating of Ships.....	52 - 62
L. Limestone Handling System for FGD System for Units 1 & 2.....	63 - 66
M. Lime Silo for Wastewater Treatment Plant for the Chloride Bleed Stream...	67 - 68
N. Common Conditions.....	69 - 73
IV. Acid Rain Part.....	74 - 77

**Permittee:**  
Tampa Electric Company  
P.O. Box 111  
Tampa, Florida 33601-0111

**FINAL Permit Revision No.:** 0570039-010-AV  
**Facility ID No.:** 0570039  
**SIC Nos.:** 49, 4911  
**Project:** Initial Title V Air Operation Permit

This permit revision is for the purpose of changing several Specific Conditions established in the initial Title V Air Operation Permit, No. 0570039-002-AV, and based on air construction permitting action No. 0570039-009-AC. This permit is for the operation of the Tampa Electric Company (TEC) Big Bend Station. This facility is located at Big Bend Road, North Ruskin, Hillsborough County; UTM Coordinates: Zone 17, 361.9 km East and 3075.0 km North; Latitude: 27° 47' 36" North and Longitude: 82° 24' 11" West.

STATEMENT OF BASIS: This Title V air operation permit is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and Florida Administrative Code (F.A.C.) Chapters 62-4, 62-210, 62-213 and 62-214. The above named permittee is hereby authorized to perform the work or operate the facility shown on the application and approved drawing(s), plans, and other documents, attached hereto or on file with the permitting authority, in accordance with the terms and conditions of this permit.

**Referenced attachments made a part of this permit:**

Appendix U-1, List of Unregulated Emissions Units and/or Activities  
Appendix I-1, List of Insignificant Emissions Units and/or Activities  
APPENDIX TV-3, TITLE V CONDITIONS (version dated 04/30/99)  
APPENDIX SS-1, STACK SAMPLING FACILITIES (version dated 10/07/96)  
TABLE 297.310-1, CALIBRATION SCHEDULE (version dated 10/07/96)  
FIGURE 1 - SUMMARY REPORT-GASEOUS AND OPACITY EXCESS EMISSIONS AND MONITORING SYSTEM PERFORMANCE REPORT (version dated 7/96)  
DOCUMENT III.I.6 - PROCEDURES FOR STARTUP AND SHUTDOWN UNITS 1 - 4  
DOCUMENT III.I.7 - OPERATION AND MAINTENANCE PLAN (version dated 7/18/97)  
40 CFR 60 Subpart A - General Provisions  
40 CFR 63 Subpart A - General Provisions modified for Subpart II  
40 CFR 63 Subpart II - § 63.782 Definitions  
40 CFR 63 Subpart II - Figure 1. Flow diagram of compliance procedures  
40 CFR 63 Subpart II - TABLE 2 VOLATILE ORGANIC HAP (VOHAP) LIMITS FOR MARINE COATINGS  
40 CFR 63 Subpart II - TABLE 3 SUMMARY OF RECORDKEEPING & REPORTING REQUIREMENTS  
40 CFR 63 Subpart II - APPENDIX A VOC DATA SHEET  
40 CFR 63 Subpart II - APPENDIX B  
DEP Form No. 62-210.900(1)(a), version 07/01/95, received 12/26/95 (signed 12/19/95).  
Consent Final Judgement (DEP vs. TEC) dated December 6, 1999  
Phase II NOx Compliance Plan received December 22, 1999  
Phase II NOx Averaging Plan received December 22, 1999  
Consent Decree (U.S. vs. TEC) dated February 29, 2000; amended October 4, 2000.

**Effective Date:** January 1, 2001  
**Revision Effective Date:** July 24, 2001  
**Renewal Application Due Date:** July 5, 2004  
**Expiration Date:** December 31, 2004

\_\_\_\_\_  
Howard L. Rhodes, Director,  
Division of Air Resources Management

HLR/CLP

## Section I. Facility Information.

### Subsection A. Facility Description.

TEC Big Bend is a nominal 2,028 MW electric generation facility. This facility consists of four steam boilers (Units Nos. 1 through 4); four steam turbines; three simple-cycle combustion turbines (CT Nos. 1, 2, and 3); solid fuels, fly ash, limestone, gypsum, slag, and bottom ash storage and handling facilities, and fuel oil storage tanks. Units No. 1, 2, 3, and 4 have nominal maximum heat inputs of 4037, 3996, 4115 and 4330 million BTU per hour, respectively. Units No. 1 through 4 are fired with coal and with petcoke in a mixture with coal up to 20.0% petcoke/80.0% coal (by weight). The combustion turbines are fired with No. 2 distillate fuel oil. In addition, there is a ship surface coating operation.

Also included in this permit are miscellaneous unregulated emissions units and insignificant emissions units and/or activities.

Based on the initial Title V permit application received June 14, 1996, this facility is a major source of hazardous air pollutants (HAPs).

#### Overview of the facility's operation:

Solid fuel is unloaded from ship/barge into the solid fuel yard, the blending bins or directly to the tripper room via belt conveyors. Solid fuel from the piles is loaded onto belt conveyors using a rail mounted or mobile reclaimer. The solid fuel is then belt conveyed to the blending ~~tower~~ bins, which consists of six storage bins, where the solid fuel is may be blended for use at the plant, or transloaded into trucks for shipment off site. ~~From the solid fuel yard conveyors, the solid fuel is screw conveyed into the bins.~~ Particulate matter (PM) emissions from the conveyors in the solid fuel yard blending bins are controlled by 3.4 ~~3.4~~ rotoclones, one at the conveyor drop and one for every 2 bins. ~~PM emissions from the screw conveyor are controlled by the fourth rotoclone.~~ Storage bins can either ~~Each has 2 hoppers, which feed the transloader, or can be~~ are conveyed, via 2 parallel belts (T1, T2) to 2 crushers (each belt has a crusher), or diverted directly to the tripper room. PM emissions from the 2 crushers and transfer tower are controlled by 2 rotoclones.

~~From the solid fuel yard tripper room, the solid fuel is conveyed to the tripper room where 2 trippers bunker the solid fuels into 4 solid fuel bunkers. Each unit has its own respective bunker. Solid fuel samples are taken every 15 minutes during bunkering, and composited for analysis. From the bunkers, the solid fuel is gravity fed into 14 crushers mills, and then gravity-fed into the boilers. There are 3 tall crushers ball mills, each for Unit Nos. 1 - 3, and 5 bowl crushers mills for Unit No. 4. From the crushers mills, the solid fuel is pneumatically fed into classifiers, two for each mill crusher on Unit Nos. 1-3 and one for each mill on Unit No. 4 for a total of 283 classifiers, and then into the respective boilers.~~

PM emissions from Boiler Nos. 1-3-4 are controlled by individual Electrostatic Precipitators (ESPs). Unit Nos. 1- 4 ~~PM emissions are controlled by an ESP, and the SO<sub>2</sub> emissions are controlled by an FGD scrubber systems.~~ When Unit No. 1-3 burns petroleum coke, the exhaust gases, following particulate matter removal by the units's ESPs, will be routed to the inlet of the ~~Unit No. 4~~ flue gas desulfurization (FGD) system scrubber. ~~In this~~ the integrated mode, Unit No. 3 will meet the same sulfur dioxide



emissions limitations as Unit No. 4. The FGD scrubber will continue to treat the exhaust gas from Unit No. 4. The FGD scrubber outlet stream, consisting of the combined Unit No. 3 and Unit No. 4 treated exhaust, will then be split and discharged through stacks CS002 and CS003.

Fly ash from Units No. 1 and No. 2 is vented into Fly Ash Silo #1 ~~which is controlled by a baghouse~~. Fly ash from Unit No. 3 is vented into Silo #2, ~~which can also receive fly ash from Units No.1 and 2. while~~ Fly ash from Unit No. 4 is vented into Silo #3. The fly ash from each silo is then loaded into trucks and transported off site, while the bottom ash from Unit No. 4 is conveyed across Big Bend Road south of the Big Bend facility to a settling pond. Each fly ash silo is controlled by a baghouse.

The byproduct gypsum is conveyed to the east side of the plant for ~~diverting dewatering~~ and transporting off site. Limestone is unloaded to an underground hopper conveyor belt system to the limestone storage building on the east side of the by-product gypsum area. ~~Particulate matter emissions from the limestone trucks unloading is controlled by a baghouse.~~ From the storage building, limestone is belt conveyed into ~~23~~ storage silos and then gravity fed into the mill room. ~~Two~~ Three rotary mills grind the limestone and mix it with water to form a slurry that is stored in ~~2-3~~ storage tanks for use in the FGD. The slurry is then pumped to the reaction tanks of Unit 1-4 scrubbers that are located directly south of and adjacent to the absorption towers of the FGD scrubber. ~~Most of the by-product gypsum is wallboard grade, however, gypsum that is produced during start up, shutdown or upset conditions is de-watered and belt conveyed across the street to the southeast of the plant for drying and transportation off site. Gypsum is sold and transported offsite and can be stored south of Big Bend road prior to offsite removal.~~

There are 3-combustion turbines (CT) manufactured by Westinghouse. They are all fired on No. 2 fuel oil. ~~Unit CT~~ No. 1 is near the plant and ~~Unit CT~~ Nos. 2 and 3 are on the north side of the property. There is a large No. 2 fuel oil storage tank near ~~Unit CT~~ Nos. 2 and 3 and a small day tank near ~~Unit CT~~ No. 1.

**TEC Rationale for Revision: Administrative corrections to process descriptions.**

**Subsection B. Summary of Emissions Unit ID Nos. and Brief Descriptions.**

**E.U.**

<b><u>ID No.</u></b>	<b><u>Brief Description</u></b>
-001	Unit No. 1 Steam Generator
-002	Unit No. 2 Steam Generator
-003	Unit No. 3 Steam Generator
-004	Unit No. 4 Steam Generator
-005	Combustion Turbine No. 2
-006	Combustion Turbine No. 3
-007	Combustion Turbine No. 1
-008	Fly Ash Silo No. 1 Baghouse
-018	Flyash Silo No. 1 Truck Loadout
-009	Fly Ash Silo No. 2 Baghouse
-019	Flyash Silo No. 2 Truck Loadout
-026	Fly Ash Handling and Storage Fugitive Emissions <u>from Unit No. 1-3</u> (all except silos)
-014	Fly Ash Silo No. 3 Baghouse
-027	Fly Ash Silo No. 3 Truck Loadout
-028	Fly Ash Handling System Fugitive Emissions <u>from Unit No. 4</u>

- 011 Truck Unloading of Limestone
- 012 Limestone Silo A with one baghouse and one backup baghouse
- 013 Limestone Silo B with one baghouse and one backup baghouse
- 023 Limestone Handling Conveyor LB to Conveyor LC with baghouse  
Limestone Handling Conveyor LD to Conveyor LE with baghouse

**E.U.**      **Subsection B. Summary of Emissions Unit ID Nos. and Brief Descriptions.**  
**ID No.**      **(continued)**

**Brief Description**

- 024 ~~Limestone Handling Conveyor LE to South Storage Silo with baghouse~~  
~~Limestone Handling Conveyor LE to North Storage Silo with baghouse~~
- 025 Limestone Storage and Handling Fugitive Emissions
- 010 Solid Fuel Yard, Fugitive Emissions
- 029 Cyclone collectors for fuel blending bins (FH-032 and FH-035)
- 030 Cyclone collectors for fuel crushers (FH-048 and FH-049)
- 031 ~~Cyclone collectors for bunkers (FH-059 through FH-062)~~
- 015 Unit No. 1 Coal Bunker
- 016 Unit No. 2 Coal Bunker
- 017 Unit No. 3 Coal Bunker
- 037 Unit No. 4 Coal Bunker
- 032 Surface coating of miscellaneous metal parts
- 033 Abrasive Blast Booth with baghouse
- 034 Abrasive Blast Media Storage with baghouse
- 035 Surface coating of ships
- 020 **Drops from limestone handling conveyors LE, LF, and LG and silo C belt feeder with baghouse**
- 021 **Silo C with one baghouse**
- 022 **Lime silo with one baghouse for the waste water treatment plant for the chloride bleed stream**
- 036 Unregulated Emissions Units and/or Activities

**TEC Rationale for Revision:** The emission units addressed by Emission Unit ID No. 024 are also addressed by Emission Unit ID 020. The emission units addressed by Emission Unit ID No. 031 are also addressed by Emission Unit IDs 015, 016, 017, and 037. Accordingly, deletion of duplicate Emission Unit ID Nos. 024 and 031 is requested. For consistency with Units 1-3, addition of an Emission Unit ID for Unit No. 4 Coal Bunker (now addressed by Emission Unit ID No. 031) is requested.

***Please reference the Permit No., Facility ID No., and appropriate Emissions Unit(s) ID No(s). on all correspondence, test report submittals, applications, etc.***

**Subsection C. Relevant Documents.**

The documents listed below are not a part of this permit; however, they are specifically related to this permitting action.

These documents are provided to the permittee for information purposes only:

Appendix A-1, Abbreviations, Acronyms, Citations, and Identification Numbers  
Appendix H-1, Permit History

These documents are on file with the permitting authority:

Phase I Acid Rain Permit dated July 15, 1994  
Initial Title V Permit Application received June 14, 1996  
Additional Information Request dated February 13, 1997  
Letter dated June 27, 1997, changing the Designated Representative  
Additional Information Response received July 21, 1997  
Additional Information Response received July 21, 1997  
Proposed Compliance Plan dated December 30, 1998, requesting additional SO<sub>2</sub> limits

These documents are on file with the permitting authority (continued):

Memo from Power Plant Siting dated February 23, 1999, to confirm COC correction.  
FDEP letter dated December 23, 1999 Allowing Discontinuance of TSP/SO<sub>2</sub> Ambient Monitoring  
Additional Information received January 17, 2000  
Plant diagrams as provided in the Title V Permit application and additional information  
TEC comments dated June 23, 2000 and July 5, 2000 on the 2<sup>nd</sup> Revised DRAFT permit  
USEPA Region 4 objections and comments letter dated September 5, 2000.  
FDEP letter dated December 1, 2000 resolving USEPA Region 4 objections and comments.  
FDEP letter dated December 14, 2000 clarifying December 1, 2000 resolution letter.  
TEC request received February 7, 2001 to revise vanadium limitation wording in PSD-FL-040  
TEC request received February 16, 2001 to revise vanadium limitation wording in Title V permit

**Section II. Facility-wide Conditions.**

**The following conditions apply facility-wide:**

1. APPENDIX TV-3, TITLE V CONDITIONS, is a part of this permit.  
{Permitting note: APPENDIX TV-3, TITLE V CONDITIONS, is distributed to the permittee only.  
Other persons requesting copies of these conditions shall be provided a copy when requested or otherwise appropriate.}
2. **Not federally enforceable. General Pollutant Emission Limiting Standards. Objectionable Odor Prohibited.** No person shall cause, suffer, allow, or permit the discharge of air pollutants which cause or contribute to an objectionable odor.  
[Rule 62-296.320(2), F.A.C.]
3. **General Particulate Emission Limiting Standards. General Visible Emissions Standard.**  
Except for emissions units that are subject to a particulate matter or opacity limit set forth or established by rule and reflected by conditions in this permit, no person shall cause, let, permit, suffer or allow to be discharged into the atmosphere the emissions of air pollutants from any activity, the density of which is equal to or greater than that designated as Number 1 on the Ringelmann Chart (20 percent opacity). EPA Method 9 is the method of compliance pursuant to Chapter 62-297, F.A.C.

[Rules 62-296.320(4)(b)1. & 4., F.A.C.]

{Permitting Note: Although the Permittee is not required to perform a visible emissions compliance test to demonstrate compliance with the facility-wide limitations annually or before renewal, if the Department believes that the general visible emissions standard is being violated, the Department may require that the owner or operator perform a visible emissions compliance test per Chapter 62-297.310(7)(b), Special Compliance Tests. In addition, Department personnel who are certified to perform visible emissions tests may determine compliance with the general visible emissions standard.}

**4. Prevention of Accidental Releases (Section 112(r) of CAA). [40 CFR 68]**

- a. The permittee shall submit its Risk Management Plan (RMP) to the Chemical Emergency Preparedness and Prevention Office (CEPPO) RMP Reporting Center when, and if, such requirement becomes applicable; and
- b. The permittee shall submit to the permitting authority Title V certification forms or a compliance schedule in accordance with Rule 62-213.440(2), F.A.C.

**5. Unregulated Emissions Units and/or Activities. Appendix U-1, List of Unregulated Emissions Units and/or Activities, is a part of this permit.**

[Rule 62-213.440(1), F.A.C.]

**6. Insignificant Emissions Units and/or Activities. Appendix I-1, List of Insignificant Emissions Units and/or Activities, is a part of this permit.**

[Rules 62-213.440(1), 62-213.430(6) and 62-4.040(1)(b), F.A.C.]

**7. General Pollutant Emission Limiting Standards. Volatile Organic Compounds (VOC) Emissions or Organic Solvents (OS) Emissions. The permittee shall allow no person to store, pump, handle, process, load, unload or use in any process or installation, volatile organic compounds or organic solvents without applying known and existing vapor emission control devices or systems deemed necessary and ordered by the Department.**

[Rule 62-296.320(1)(a), F.A.C.]

**8. The Permittee shall take reasonable precautions to prevent emissions of unconfined particulate matter at this facility.**

[Rule 62-296.320(4)(c)2., F.A.C.]

{Note: This condition implements the requirements of Rules 62-296.320(4)(c)1., 3., & 4. F.A.C. (condition 58. of APPENDIX TV-3, TITLE V CONDITIONS.)}

**9. When appropriate, any recording, monitoring, or reporting requirements that are time-specific shall be in accordance with the effective date of the permit, which defines day one.**

[Rule 62-213.440, F.A.C.]

**10. Statement of Compliance. The annual statement of compliance pursuant to Rule 62-213.440(3)(a)2., F.A.C., shall be submitted within 60 (sixty) days after the end of the calendar year using DEP form No. 62-213.900(7), F.A.C.**

[Rule 62-213.440(3) and 62-213.900, F.A.C.]

11. The Consent Final Judgement (DEP vs. TEC) dated December 6, 1999; and the Consent Decree (U.S. vs. TEC) dated February 29, 2000, including the October 4, 2000 amendment; are attached hereto and made a part of this permit. The permittee shall comply with the Consent Final Judgement and the Consent Decree. Wherever the Consent Decree conflicts with this permit the terms and conditions of the Consent Decree control. Upon expiration of the Consent Decree the Title V permit shall be modified to incorporate any terms and conditions that are deemed necessary by the permitting authority for the continued operation of the facility.

[Rules 62-4.070(3)&(5) and 62-213.440, F.A.C.]

12. Unless otherwise stated in a specific condition, averaging times for specified emission standards are based on the run time of the test method(s) used for determining compliance.

[Rule 62-4.070(3), F.A.C.]

13. a. The permittee shall submit all compliance related notifications and reports required of this permit to the Environmental Protection Commission of Hillsborough County:

Environmental Protection Commission  
of Hillsborough County  
1410 North 21 Street  
Tampa, Florida 33605  
Telephone: 813/272-5530  
Fax: 813/272-5605

b. The permittee shall provide timely notification to the Environmental Protection Commission of Hillsborough County prior to implementing any changes that may result in a modification to this permit. The changes may include, but are not limited to, the following, and may also require prior authorization before implementation:

1. Alteration or replacement of any equipment\* or parameter listed in the Facility or Subsection descriptions.
2. Installation or addition of any equipment\* which is a source of air pollution.
3. Any changes in the method of operation, raw materials, products of fuels.

\*Not applicable to normal maintenance and repairs, and vehicles used for transporting material.

[Rules 62-4.070(3) and 62-210.300, F.A.C.]

14. Any reports, data, notifications, certifications, and requests required to be sent to the United States Environmental Protection Agency, Region 4, should be sent to:

United States Environmental Protection Agency  
Region 4  
Air, Pesticides & Toxics Management Division  
Air and EPCRA Enforcement Branch, Air Enforcement Section  
61 Forsyth Street  
Atlanta, Georgia 30303  
Telephone: 404/562-9155, Fax: 404/562-9163

### Section III. Regulated Emissions Units Conditions.

#### Subsection A. Steam Generators Units Nos. 1, 2, & 3

This section addresses the following Regulated Emissions Units:

<u>E.U. ID No.</u>	<u>Brief Description</u>
-001	Unit No. 1 Steam Generator
-002	Unit No. 2 Steam Generator
-003	Unit No. 3 Steam Generator

Descriptions. Unit No. 1 is a fossil fuel fired steam boiler generating unit rated at 4037 MMBtu/hour with an electrical generating capacity of 445 MW. It is a "wet" bottom utility boiler manufactured by Riley Stoker Corporation. This unit may be fired on coal or a coal/petroleum coke blend consisting of a maximum of 20.0 percent petroleum coke by weight. Unit No. 1 began commercial operation in 1970.

Unit No. 2 is a fossil fuel fired steam boiler generating unit rated at 3996 MMBtu/hour with an electrical generating capacity of 445 MW. It is a "wet" bottom utility boiler manufactured by Riley Stoker Corporation. This unit may be fired on coal or a coal/petroleum coke blend consisting of a maximum of 20.0 percent petroleum coke by weight. Unit No. 2 began commercial operation in 1973.

Unit No. 1 and Unit No. 2 share two common stacks (Stacks CS001 and CS0W1). Particulate emissions generated during the operation of the units are controlled by dry electrostatic precipitators (ESPs) manufactured by Western Precipitator Division, Joy Manufacturing Corporation. ESP control efficiency is 99.7%. Whenever either unit is fired with petcoke in any amount up to the allowable ratio (20% petcoke/80% coal, by wt.), its flue gases must be directed from its ESP to the FGD system and then to stack CS0W1. Otherwise, if petcoke is not fired, the flue gases may bypass the FGD system and stack CS0W1, and the flue gases are routed from the ESP directly to stack CS001.

Unit No. 3 is a fossil fuel fired steam boiler generating unit rated at 4115 MMBtu/hour with an electrical generating capacity of 445 MW. It is a "wet" bottom utility boiler manufactured by Riley Stoker Corporation. This unit may be fired on coal or a coal/petroleum coke blend consisting of a maximum of 20.0 percent petroleum coke by weight. Operation of this unit may include diverting all of the flue gas into the existing Big Bend Unit No. 4 flue gas desulfurization (FGD) system for sulfur dioxide emission reduction. Sulfur dioxide emissions that are generated and not diverted through the Unit No. 4 FGD system are uncontrolled. Particulate matter emissions generated during the operation of the unit are controlled by a dry electrostatic precipitator (ESP) manufactured by Research-Cottrell, Inc. The ESP control efficiency is 99.7%. Unit No. 3 began commercial operation in 1976.

{Permitting note: Units No. 1, No. 2, and No. 3 are regulated under the federal Acid Rain Program for Phase II SO<sub>2</sub> and NO<sub>x</sub>, adopted and incorporated by reference in Rule 62-204.800, F.A.C.; and regulated under 62-296.405, F.A.C. These units were also formerly regulated under the federal Acid Rain Program as Phase I SO<sub>2</sub> substitution units.}

The following specific conditions apply to the emissions units listed above:

**ESSENTIAL POTENTIAL TO EMIT (PTE) PARAMETERS**

A.1. Capacity. The maximum permitted heat input rate for each unit is as follows:

<u>Unit No.</u>	<u>MMBTU/hr</u>
1	4037
2	3996
3	4115

[Rules 62-4.160(2), 62-210.200(PTE) and 62-296.405, F.A.C.]

{Permitting note: The heat input limitations have been placed in this permit to identify the capacity of each unit for the purposes of confirming that emissions testing is conducted within 90 to 100 percent of the unit's rated capacity (or to limit future operation to 110 percent of the test load), to establish appropriate emission limits and to aid in determining future rule applicability. Regular recordkeeping, other than annual, is not required for heat input. Instead the owner or operator is expected to determine heat input whenever emission testing is required, to demonstrate at what percentage of the rated capacity that the unit was tested. Rule 62-297.310(5), F.A.C., requires measurement of the process variables for emission tests. Such heat input determination may be based on measurements of fuel consumption by various methods to calculate average hourly heat input during the test. Annual heat input must be calculated in order to determine annual emissions of pollutants whose limits are based upon heat input.}

**TEC Rationale for Revision: Administrative correction.**

A.2. Methods of Operation - Fuels.

a. Normal operation: The only fuels allowed to be burned in Units Nos. 1, 2, and 3 is coal or a coal/petroleum coke blend containing a maximum of 20.0% petroleum coke by weight. The vanadium content of the petroleum coke fired shall not exceed 2660 ppm. The ash content of the petroleum coke fired shall not exceed 0.76% by weight on a dry basis. The permittee shall maintain and submit to the Department, and to the Environmental Protection Commission of Hillsborough County, on an annual basis for the years 2001, 2002, 2003, 2004, and 2005 data demonstrating that removal of the sulfur content limit and the revision of the vanadium content limit in the petroleum coke fired did not result in a significant increase in the representative actual annual emissions of any regulated pollutant.

b. Other operation:

1. In addition to the fuels allowed to be burned during normal operation, each unit may also burn new No. 2 fuel during startup, shutdown, flame stabilization, and during the start of a mill on an already operating unit.
2. Evaporation of up to 150,000 gallons per year, total at the facility, is allowed of non-hazardous, but potentially HAP-emitting, mineral acid solution boiler chemical cleaning waste which was generated on site.

[Rules 62-4.070(3), 62-4.160(2), 62-210.200, and 62-213.440(1), F.A.C.]

{Permitting note: "Flame stabilization" is defined as the use of new No. 2 fuel oil to stabilize a flame during times of unexpected poor coal quality or equipment failure such as coal piping pluggage. Flame stabilization due to poor coal quality occurs when coal is wet or does not provide the necessary heat to maintain a stable flame. In this situation, new No. 2 fuel oil is combusted to provide the additional required heat input to maintain a stable flame. Flame stabilization due to equipment failure occurs when coal piping is plugged, or equipment is otherwise damaged, that results in an inconsistent amount of coal reaching the burners. Under certain conditions, this may result in the burners intermittently seeing large amounts of fuel at one time, causing a potentially explosive flame "puff". In this situation, new No. 2

fuel oil must be used for stabilization to prevent flame “puffing” and ensure safe operation. Combustion of No. 2 fuel oil is also necessary during periods of load change to initialize and stabilize the flame until coal flow to the burners reaches steady state. As defined in 62-210.700(3), F.A.C., Load change occurs when the operational capacity of a unit is in the 10 to 100 percent capacity range, other than startup or shutdown, which exceeds 10 percent of the unit's rated capacity and which occurs at a rate of 0.5 percent per minute or more.}

**TEC Rationale for Revision: Administrative correction.**

**A.3. FGD Operation Required for Petcoke:**

- a. Whenever emissions Unit No. 1 or No. 2 is fired with petcoke in any amount up to the allowable percentage, its flue gases shall be directed to FGD system for Units No. 1 and No. 2.

[Permit Nos. 0570039-003-AC and 0570039-004-AC]

{Note: The owner or operator may operate each emissions unit without directing its emissions to the FGD system whenever petcoke is not being fired in the emissions unit.}

{Note: The excess emissions provisions of specific condition A.11. of this permit are also applicable to the FGD system operation.}

- b. The permittee is allowed to divert and integrate all of Unit No. 3 flue gas for purposes of treating that flue gas in the existing Unit No. 4 flue gas desulfurization (FGD) system. At all times while firing any permitted blend of coal and petroleum coke, Unit No. 3 shall operate only in the integrated mode except during startups, shutdowns, and/or malfunctions during all of which best operational practices shall be employed including the cessation of petroleum coke bunkering.

[Rule 62-4.070(3), F.A.C., 40 CFR 60.40a, and Permit No. PSD-FL-040]

**A.4. Limit on Petcoke Bunkering:** The owner or operator at any given time shall not bunker more than the amount of petcoke that may be fired in each emissions Unit No. 1 or No. 2 in one day. [0570039-003-AC and 0570039-004-AC]

[Note: This condition is intended to limit possible excess emissions in the event of an unexpected breakdown of the FGD system that requires its shutdown while either emissions unit is firing petcoke.]

**A.5. Hours of Operation.** Unit No. 1, Unit No. 2, and Unit No. 3 are each allowed to operate continuously, i.e., 8760 hours/year.

[Rule 62-210.200, F.A.C., Definitions (PTE)]

**EMISSION LIMITATIONS AND STANDARDS**

**A.6.** Except as provided in Specific Condition No. A.11., visible emissions from each unit shall not exceed 20% opacity except for one six-minute period per hour during which opacity shall not exceed 27%.

[Rule 62-296.405(1)(a), F.A.C.]

**A.7.** Except as provided in Specific Condition No. A.11., the particulate matter emission rate for each unit shall not exceed 0.1 pounds per million BTU heat input. {Permitting note: The averaging time for



the emissions standard in this condition shall be equal to the cumulative run time required by the specified test method.}

[Rule 62-296.405(1)(b), F.A.C.]

A.8. Based on the maximum permitted heat input rates listed in Specific Condition A.1., the maximum permitted particulate matter annual emission rate for each unit is as follows:

<u>Unit No.</u>	<u>tons/yr</u>
1	1768
2	1750
3	1802

In the event that a maximum permitted heat input rate for a unit is reduced, the maximum annual permitted particulate matter emission rate for that unit shall also be reduced accordingly.

[Rule 62-296.700(4)(b)1., F.A.C.]

A.9. Sulfur Dioxide Emission Limits. {Permitting Note: The Consent Final Judgement (DEP vs. TEC) dated December 6, 1999; and the Consent Decree (U.S. vs. TEC) dated February 29, 2000, including the October 4, 2000 amendment; which are part of this permit, supercede this specific condition. Wherever the Consent Decree conflicts with this permit condition, the Consent Decree takes precedence.}

a. Units No. 1, No. 2, and No. 3, each shall not emit more than 6.5 pounds of sulfur dioxide per million BTU heat input on a two-hour average; nor shall Units No. 1, No. 2, and No. 3, in total, emit more than 31.5 tons per hour of sulfur dioxide on a three-hour average and 25 tons per hour of sulfur dioxide on a 24-hour block average (midnight to midnight).

[Rules 62-296.405(1)(c)2.b. and 3., F.A.C.; and Rule 62-204.240(1), F.A.C.]

b. Integrated Operation - While in the integrated mode Units No. 3 and 4 shall meet the pounds per million Btu and percent reduction sulfur dioxide limitations that are applicable to Unit No. 4. (Specific Conditions B.7. and B.8.). Unit 3 will be operated in this integrated mode except during unit or FGD startups, shutdowns, maintenance and/or malfunctions, during all of which best operational practices shall be employed, including the cessation of bunkering fuels that would emit higher than 6.5 lb SO<sub>2</sub> per MMBtu.

c. Units No. 1 and No. 2, in total, shall not emit more than 16.5 tons per hour of sulfur dioxide on a 24-hour block average.

d. Unit No. 3 shall not emit more than 8.5 tons per hour of sulfur dioxide on a twenty-four hour block average.

e. While scrubbing sulfur dioxide emissions, the following table lists the sulfur dioxide emissions limits (lbs/hr) for six different operating scenarios:

Operating Scenario	Operating Mode, Emission Limits (lbs/hour)			Averaging Period (Calendar day basis)
	Unit 1	Unit 2	Unit 3	
1	Scrubbed, 3310	Scrubbed*, 3277	Unscrubbed*, 14814	24 hours
2	Scrubbed, 3310	Unscrubbed, 9590	Unscrubbed, 9876	24 hours
3	Scrubbed, 3310	Scrubbed, 3277	Scrubbed, 3374	24 hours
4	Scrubbed, 3310	Unscrubbed, 11588	Scrubbed, 3374	24 hours
5	Unscrubbed,	Scrubbed,	Scrubbed,	24 hours

	11707	3277	3374	
6	Unscrubbed, 9689	Scrubbed, 3277	Unscrubbed, 9876	24 hours

\*"Scrubbed" refers to operation while directing flue gas to the FGD system. "Unscrubbed" refers to operation while not directing flue gas to the FGD system.

[40 CFR 60.40a; Permit Nos. PSD-FL-040, 0570039-003-AC, and 0570039-004-AC; Applicant request.]

A.10. Unit No. 3 shall not emit more than 0.70 of a pound of nitrogen oxides (expressed as NO<sub>2</sub>) per million BTU heat input based upon a 30-day rolling average. [Rule 62-296.405(1)(d)4. and Rule 62-296.405(1)(e)4., F.A.C.]

A.11. *Excess Emissions.*

(1) Excess emissions resulting from startup, shutdown or malfunction of any emissions unit shall be permitted providing (a) best operational practices to minimize emissions are adhered to and (b) the duration of excess emissions shall be minimized but in no case exceed two hours in any 24 hour period unless specifically authorized by the Department or the Environmental Protection Commission of Hillsborough County (EPCHC) for longer duration.

(2) Excess emissions from existing fossil fuel steam generators resulting from startup or shutdown shall be permitted provided that best operational practices to minimize emissions are adhered to and the duration of excess emissions shall be minimized.

(3) Excess emissions from existing fossil fuel steam generators resulting from boiler cleaning (soot blowing) and load change shall be permitted provided the duration of such excess emissions shall not exceed 3 hours in any 24-hour period and visible emissions shall not exceed Number 3 of the Ringelmann Chart (60 percent opacity), and providing (a) best operational practices to minimize emissions are adhered to and (b) the duration of excess emissions shall be minimized. A load change occurs when the operational capacity of a unit is in the 10 percent to 100 percent capacity range, other than startup or shutdown, which exceeds 10 percent of the unit's rated capacity and which occurs at a rate of 0.5 percent per minute or more. Visible emissions above 60 percent opacity shall be allowed for not more than 4, six (6)-minute periods, during the 3-hour period of excess emissions allowed by this specific condition A.11.(3), for boiler cleaning and load changes, at units which have installed and are operating continuous opacity monitors. Particulate matter emissions shall not exceed an average of 0.3 lbs. per million BTU heat input during the 3-hour period of excess emissions allowed by this specific condition A.11.(3).

(4) Excess emissions which are caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure which may reasonably be prevented during startup, shutdown, or malfunction shall be prohibited.

(5) In case of excess emissions resulting from malfunctions, TECO shall notify the EPCHC in accordance with Rule 62-4.130, F.A.C. A full written report on the malfunctions shall be submitted in a quarterly report, if requested by the permitting authority or the EPCHC.

[Rule 62-210.700, F.A.C.]

**TEC Rationale for Revision: Administrative correction.**

**TEST METHODS AND PROCEDURES**

{Permitting note: Table 2-1, Summary of Compliance Requirements, summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.}

A.12. During each federal fiscal year (October 1 - September 30), unless otherwise specified by rule, order, or permit, the TEC shall have formal compliance tests conducted on each Steam Generator Unit. Unit No. 1, Unit No. 2, and Unit No. 3 shall each be individually stack tested for particulate matter and visible emissions, under both sootblowing and non-sootblowing operation conditions. When testing in CS0W1 or when testing in CS001, Unit No. 1 shall not be in operation during the compliance testing of Unit No. 2, and Unit No. 2 shall not be in operation during the compliance testing of Unit No. 1, but when testing in the ductwork between CS001 and the scrubber tower inlet, Unit No. 1 may operate during the compliance testing of Unit No. 2 and Unit No. 2 may operate during the compliance testing of Unit No. 1. Testing of Unit No. 3 emissions shall be prior to their mixing with the exhaust from the scrubber for Unit No. 4.

[Rules 62-297.310(7)(a)2. and 4., and 62-4.070(3), F.A.C.]

A.13. The test method for visible emissions shall be DEP Method 9, incorporated in Chapter 62-297, F.A.C. In lieu of Method 9 testing, a transmissometer utilizing a 6-minute block average for opacity measurement may be used, provided such transmissometer is installed, certified, calibrated, operated and maintained in accordance with the provisions of 40 CFR Part 75.

[Rule 62-296.405(1)(e)1., F.A.C., and request of applicant.]

A.14. The test methods for particulate emissions shall be EPA Methods 17, 5, 5B, or 5F, incorporated and adopted by reference in Chapter 62-297, F.A.C. The minimum sample volume shall be 30 dry standard cubic feet. EPA Method 5 may be used with filter temperature at no more than 320 degrees Fahrenheit. For EPA Method 17, stack temperature shall be less than 375 degrees Fahrenheit. The owner or operator may use EPA Method 5 to demonstrate compliance. EPA Method 3 or 3A with Orsat analysis shall be used when the oxygen base F-factor computed according to EPA Method 19 is used in lieu of heat input. Acetone wash shall be used with EPA Method 5 or 17.

[Rule 62-296.405(1)(e)2., F.A.C.]

A.15. Compliance testing for particulate matter emissions and visible emissions may be conducted either: (a) without fly ash re-injections occurring, or (b) while fly ash collected by the electrostatic precipitator is being re-injected into the boiler at a rate which is representative of the maximum anticipated fly ash re-injection rate. If the most recent particulate and visible emission compliance tests were conducted without fly ash re-injection occurring, and fly ash re-injection occurs for any reason other than a malfunction, then the results from new particulate and visible emissions compliance tests, conducted while fly ash collected by the precipitator is being re-injected into the boiler at a rate which is representative of the maximum anticipated fly ash re-injection rate, shall be submitted to the EPCHC within 60 days of the date that such fly ash re-injection occurred. The EPCHC may, for good cause shown, grant an extension of the 60-day time limit on a case-by-case basis.

[AO29-219924, AO29-179912, and AO29-179911]

~~A.16. Peteoke Sulfur Content: The owner or operator shall measure the sulfur content of representative samples of all peteoke received using appropriate ASTM methods to demonstrate compliance with the sulfur content limit of this permit. [Permit Nos. 0570039-003-AC & 0570039-004-AC]~~

**TEC Rationale for Revision: Obsolete permit condition. SO<sub>2</sub> CEMS is used for compliance purposes in lieu of fuel sulfur analyses.**

A.17. Monitor Petcoke Usage: The owner or operator shall operate and maintain equipment to record and calculate the weight percentage of petcoke and coal bunkered and fired in each emissions unit, to verify compliance with the bunkering limit and the percentage limitation on petcoke usage of this permit. [Rule 62-4.070(3), F.A.C.]

A.18. The permittee shall demonstrate compliance with the sulfur dioxide limits in Specific Condition A.9. by means of continuous emissions monitoring systems (CEMS). In addition to any other requirements associated with the operation and maintenance of these CEMS (i.e., Acid Rain requirements), operation of the CEMS shall be in accordance with the requirements listed in Specific Condition A.19. The annual calibration RATA associated with these CEMS may be used in lieu of the required annual EPA Reference Method 6, as long as all of the requirements of Rule 62-297.310, F.A.C., are met (i.e., prior test notification, proper test result submittal, etc.). [Applicant request.]

A.19. Continuous Monitor Performance Specifications. If continuous monitoring systems are required by rule or are elected by the permittee to be used for demonstrating compliance with the standards of the Department, they must be installed, maintained and calibrated, either:

(a) in accordance with the EPA performance specifications listed below. These Performance Specifications are contained in 40 CFR 60, Appendix B, and are adopted by reference in Rule 62-204.800, F.A.C.

(1) [Reserved]

(2) Performance Specification 2--Specifications and Test Procedures for SO<sub>2</sub> Continuous Emission Monitoring Systems in Stationary Sources.

(3) [Reserved], Or,

(b) in accordance with the applicable requirements of 40 CFR 75, Subparts B and C. Excess emissions pursuant to Rule 62-210.700, F.A.C., shall be determined using the 40 CFR part 75 CEMS.

[Rule 62-297.520, F.A.C.; 40 CFR 75; and, Applicant request.]

A.20. Compliance with nitrogen oxides emission limit for Unit No. 3 shall be demonstrated continuously based upon a 30-day rolling average. The 30-day rolling average shall be determined by calculating the arithmetic average of all hourly emission rates for NO<sub>x</sub> for the 30 successive boiler operating days, except for data obtained during startup, shutdown, malfunction. The calculations shall be consistent with the equations in 40 CFR 60, Appendix A, Reference Method 19. For the purpose of calculating a 30-day rolling average, a boiler operating day is defined as a 24-hour period (between 12:01 a.m. and 12:00 midnight) during which fossil fuel is combusted in a steam operating unit for the entire 24-hours. [Permit No. AO29-179911 (July 29, 1994 amendment); 40 CFR 60.46a(g)]

A.21. The continuous emission monitors shall meet the quality assurance requirements and performance specifications contained in 40 CFR 75.

[Rule 62-296.401(1)(e)4., F.A.C.]

A.22. Test procedures shall meet all applicable requirements of Chapter 62-297, F.A.C.

[Rule 62-296.401(1)(e)5., F.A.C.]

A.23. For Units. No. 1, No. 2, and No. 3, TEC shall operate, calibrate, and maintain a continuous monitoring system for continuously monitoring opacity. For Unit Nos. 1- 3, TECO shall also operate calibrate, and maintain a continuous monitoring system for continuously monitoring nitrogen oxides (expressed as NO<sub>2</sub>). In addition, TEC shall operate calibrate, and maintain a continuous monitoring system for continuously monitoring sulfur dioxide for Unit Nos. 1, 2, and 3 in a manner sufficient to demonstrate compliance with the emission limits of this permit. Performance specifications, location of monitor, data requirements, data reduction and reporting requirements shall conform with the requirements of 40 CFR Part 51, Appendix P, adopted and incorporated by reference in Rule 62-204.800(2), F.A.C., and 40 CFR Part 60, Appendix B, adopted by reference in Rule 62-204.800(7), F.A.C.  
[Rule 62-296.401(1)(f), F.A.C.]

**TEC Rationale for Revision: Administrative correction.**

A.24. An oxygen or carbon dioxide continuous monitoring system shall be operated for Unit Nos. 1- 3. Measurements of oxygen or carbon dioxide in the flue gas shall be utilized to convert nitrogen oxides and sulfur dioxide continuous emission monitoring data to units of pounds per million BTU heat input for proof of compliance.  
[Rule 62-296.401(1)(f)1.d., F.A.C.]

**TEC Rationale for Revision: Administrative correction.**

#### **REPORTING AND RECORD KEEPING REQUIREMENTS**

A.25. Records of Operation: The owner or operator shall make and maintain a daily record of operation of each emissions unit showing the date, fuel(s) used, whether flue gas was directed to the FGD system, and the duration of all startups, shutdowns and malfunctions. Records of fuel bunkering and petcoke usage (weight percent of petcoke fired) shall also be made on at least a daily basis. Data that verifies compliance with the percentage limitation on petcoke usage shall be submitted with the annual operating report. [Rule 62-4.070(3), F.A.C.]

~~A.26. Records of Petcoke Sulfur Content: The owner or operator shall maintain records of petcoke sampling and analysis results performed as required by Specific Condition A.16. of this section. [Rule 62-4.070(3), F.A.C., and permit nos. 0570039-003-AC & 0570039-004-AC]~~

**TEC Rationale for Revision: Obsolete permit condition. SO<sub>2</sub> CEMS is used for compliance monitoring in lieu of fuel sulfur analyses.**

A.27. Quarterly Reporting Requirements: The owner or operator shall submit to the Department a written report of emissions in excess of emission limiting standards of this permit for each calendar quarter. The nature and cause of the excessive emissions shall be explained. This report does not relieve the owner or operator of the legal liability for violations. All recorded data shall be maintained on file for a period of five years. Copies of all submittals shall be submitted to the Air Management Division, Hillsborough County Environmental Protection Commission. [Rules 62-4.070(3) and 62-296.405(1)(g), F.A.C.]

A.28. For each unit, TEC shall submit to the EPCHC a written report of emissions in excess of the emission limiting standards as set forth in Rule 62-296.405(1), F.A.C., for each calendar quarter. The

nature and cause of the excessive emissions shall be explained. This report does not relieve TEC of the legal liability for violations. All recorded data shall be maintained on file for a period of at least 5 years. The report shall be submitted within 30 days following each calendar quarter.

[Rule 62-296.405(1)(g) and Rule 62-213.440(1)(b)2.b., F.A.C.]

A.29. For Unit No. 1-3, gravimetric instrument data verifying that the 20.0% maximum petroleum coke content by weight has not been exceeded shall be maintained for two years and submitted to the Department and the EPCHC with each annual operating report. Also to be maintained and available for inspection shall be a record of operation showing the date, fuel used, mode of operation (integrated/non-integrated), and the duration of all startups, shutdowns and malfunctions.

[Rule 62-4.070(3), F.A.C.]

**TEC Rationale for Revision: Administrative correction.**

~~A.30. For Unit No. 3, TEC shall maintain and submit to the Department and the EPCHC on an annual basis for a period of 5 years from the date the unit begins firing petroleum coke, data demonstrating that the operational change did not result in an emissions increase.~~

~~[Rule 62-4.070(3), F.A.C.]~~

**TEC Rationale for Revision: Deletion of this obsolete recordkeeping condition is requested. This condition has already been demonstrated and complied with for 5 years.**

A.31. For Unit No. 3, TEC shall submit a quarterly report to the Department and the EPCHC within 30 days following each calendar quarter. This report shall contain the 30-day NO<sub>x</sub> rolling average, all time periods of boiler operation as well as a statement of CEM and/or boiler malfunction, start-up or shutdown.

[Permit No. AO29-179911 (July 29, 1994 amendment)]

**A.32. Continuous Emission Monitoring Network and Alarms:**

To demonstrate compliance with emission limits that are protective of AAQS, data inputs will consist of hourly CEM data from the SO<sub>2</sub>, flow, and CO<sub>2</sub> monitors for Units 1-3 at Big Bend Station. TEC will use CEM data from common stack CS0W1 and/or CS001 to represent ~~individual-combined~~ unit compliance with the emission limitations for each Unit 1 and Unit 2. When Unit 3 is operated in the integrated mode, TEC will use apportioned CEM data from both common stacks CS002 and CS003 to represent individual unit compliance with the emission limitations for Unit 3. In the event any monitor fails, TEC will comply with 40 CFR 75, Subpart D – Missing Data Substitution Procedures.

[Applicant request.]

**TEC Rationale for Revision: Administrative correction.**

**A.33. Compliance Plan Verification:**

1. *Frequency* – Reporting of compliance status shall be performed on a quarterly calendar basis. Reports will be due no later than 45 days following the last day of the reporting quarter.
2. *Content* – Quarterly reports will consist of:
  - a. two-hour average SO<sub>2</sub> emissions rate for each Units 1, 2, and 3 in lb/MMBtu;
  - b. three-hour average SO<sub>2</sub> emissions for Units 1-3 in ton per hour;
  - c. 24-hour average SO<sub>2</sub> emissions for Units 1-3 in tons per hour; and

- d. 24-hour average SO<sub>2</sub> emissions for Units 1-2 and Unit 3 in tons per hour.  
[Applicant request.]

**Subsection B. Steam Generator Unit No. 4 (and No. 3 in integrated mode)**

**This section addresses the following Regulated Emissions Units:**

<u>E.U. ID No.</u>	<u>Brief Description</u>
-004	Unit No. 4 Steam Generator
-003	Unit No. 3 Steam Generator, only when operated in integrated mode.

Unit No. 4 is a 4330 MMBTU/hour, dry-bottom tangentially fired utility boiler, ~~SCC 1-01-002-12~~. The generator nameplate capacity is 486 MW. Unit No. 4 began commercial operation in 1985. Particulate matter emissions generated during the operation of the unit are controlled by a dry electrostatic precipitator (ESP) manufactured by Belco. The control efficiency of the ESP is 99.7%. Sulfur dioxide emissions are controlled by flue gas desulfurization equipment manufactured by Research-Cottrell.

**TEC Rationale for Revision: SCC 1-01-002-12 is specific to bituminous coal. Since Unit 4 is authorized to burn additional solid fuels, deletion of this SCC is requested.**

As an option, Unit No. 3 exhaust gas, following particulate matter removal by the unit's ESP, will be routed to the inlet of the Unit No. 4 flue gas desulfurization (FGD) system scrubber. In this integrated mode, Unit No. 3 will meet the same sulfur dioxide emissions limitations as Unit No. 4. The FGD scrubber will continue to treat the exhaust gas from Unit No. 4. The FGD scrubber outlet stream, consisting of the combined Unit No. 3 and Unit No. 4 treated exhaust, will then be split and discharged through stacks CS002 and CS003. Stack ~~CS003-CS002~~ does not include a recirculation duct to return exhaust gas to the inlet of the FGD scrubber. Continuous opacity monitoring systems (COMS) will be located at the outlet of Unit No. 3 and Unit No. 4 ESPs. Continuous SO<sub>2</sub> and CO<sub>2</sub>, and NO<sub>x</sub> emissions monitoring systems (CEMS) will be located in stacks CS002 and CS003. Continuous NO<sub>x</sub> emissions monitoring systems (CEMS) will be located in the inlet ducts of each unit. These monitoring systems will be used to determine compliance with all current applicable requirements.

**TEC Rationale for Revision: Administrative corrections.**

{Applicable regulations for Unit No. 4: 40 CFR 60 Subpart Da, and the federal Acid Rain Program, Phase II SO<sub>2</sub> and NO<sub>x</sub>, adopted and incorporated by reference in Rule 62-204.800, F.A.C.; PA79-12, PSD-FL-040 and an ASP for Coal Sampling.}

**The following conditions apply to the emissions unit listed above:**

**Essential Potential to Emit (PTE) Parameters**

B.1. Capacity. The maximum permitted heat input rate for Unit No. 4 is 4330 MMBTU/hr. [Rules 62-4.160(2), and 62-4.070(3), F.A.C.]

{Permitting note: The heat input limitation has been placed in this permit to identify the capacity of the unit for the purposes of confirming that emissions testing is conducted within 90 to 100 percent of the unit's rated capacity (or to limit future operation to 110 percent of the test load), to establish appropriate emission limits and to aid in determining future rule applicability. Regular recordkeeping, other than annual, is not required for heat input. Instead the owner or operator is expected to determine heat input whenever emission testing is required, to demonstrate at what percentage of the rate capacity that the unit



was tested. Rule 62-297.310(5), F.A.C., requires measurement of the process variables for emission tests. Such heat input determination may be based on measurements of fuel consumption by various methods to calculate average hourly heat input during the test. Annual heat input must be calculated in order to determine annual emissions of pollutants whose limits are based upon heat input.}

**B.2. Methods of Operation - Fuels.**

a. Normal operation: The only fuels fired in Unit No. 4 shall be coal or a coal/petroleum coke Blend containing a maximum of 20.0% petroleum coke by weight. The vanadium content of the petroleum coke fired shall not exceed 2660 ppm. The ash content of the petroleum coke fired shall not exceed 0.76% by weight on a dry basis. The permittee shall maintain and submit to the Department, and to the Environmental Protection Commission of Hillsborough County, on an annual basis for the years 2001, 2002, 2003, 2004, and 2005 data demonstrating that removal of the sulfur content limit and the revision of the vanadium content limit in the petroleum coke fired did not result in a significant increase in the representative actual annual emissions of any regulated pollutant.

b. Other operation:

1. In addition to the fuels allowed to be burned during normal operation, Unit No. 4 may also burn new No. 2 fuel during startup, shutdown, flame stabilization and during the start of an additional solid fuel ~~crusher~~ mill on an already operating unit.

2. Evaporation of up to 150,000 gallons per year, total at the facility, is allowed of non-hazardous, but potentially HAP-emitting, mineral acid solution boiler chemical cleaning waste which was generated on site.

c. Coal shall not be burned in Unit No. 4 unless both the electrostatic precipitator and limestone scrubber are operating properly.

~~d. Coal burned in Unit No. 4 shall be washed before it is transported to the plant site. TEC shall maintain records of all coal washing and preparation activities for any coal which is to be fired in Big Bend Unit No. 4. These reports shall be submitted to the Department on a quarterly basis.~~

**TEC Rationale for Revision: Administrative correction and obsolete permit condition. SO<sub>2</sub> CEMS is used for compliance monitoring. EPA Consent Decree and FDEP Consent Final Judgment supersede coal washing requirement. Proposed June 6, 2003 modifications to Unit 4 Conditions of Certification delete requirement for coal washing.**

e. TEC shall maintain a daily log of the amounts and types of fuels used and copies of fuel analyses containing information on sulfur content, ash content and heating values. [Rules 62-4.070(3), 62-4.160(2), 62-210.200, and 62-213.440(1), F.A.C.; PSD-FL-040; Power Plant Siting Certification PA 79-12]

{Permitting note: "Flame stabilization" is defined as the use of No. 2 fuel oil to stabilize a flame during times of unexpected poor coal quality or equipment failure such as coal piping pluggage. Flame stabilization due to poor coal quality occurs when coal is wet or does not provide the necessary heat to maintain a stable flame. In this situation, No. 2 fuel oil is combusted to provide the additional required heat input to maintain a stable flame. Flame stabilization due to equipment failure occurs when coal piping is plugged, or equipment is otherwise damaged, that results in an inconsistent amount of coal reaching the burners. Under certain conditions, this may result in the burners intermittently seeing large amounts of fuel at one time, causing a potentially explosive flame "puff". In this situation, No. 2 fuel oil must be used for stabilization to prevent flame "puffing" and ensure safe operation. Combustion of No. 2 fuel oil is also necessary during periods of load change to initialize and stabilize the flame until coal flow

to the burners reaches steady state. As defined in 62-210.700(3), F.A.C., Load change occurs when the operational capacity of a unit is in the 10 to 100 percent capacity range, other than startup or shutdown, which exceeds 10 percent of the unit's rated capacity and which occurs at a rate of 0.5 percent per minute or more.}

B.3. Mode of Operation. Tampa Electric Company is allowed to divert and integrate all of the flue gas from Unit No. 3 for purposes of treating that flue gas in the existing Unit No. 4 flue gas desulfurization (FGD) system.

[Rule 62-4.070(3), F.A.C., 40 CFR 60.40a, and Permit No. PSD-FL-040]

B.4. Hours of Operation. Unit No. 4 is allowed to operate continuously, i.e., 8760 hours/year.

[Rule 62-210.200, F.A.C., Definitions (PTE)]

#### Emission Limitations and Standards

B.5.a. Particulate matter emissions from Unit No. 4 shall not exceed 0.03 lb/million Btu heat input. This standard applies at all times except during periods of startup, shutdown, or malfunction.

[Rule 62-204.800(7)(b)2., F.A.C.; 40 CFR 60.42a(a); 40 CFR 60.46a(a); 40 CFR 60.46a(c)]

b. Based on the maximum permitted heat input rate listed in Specific Condition B.1., particulate matter emissions from Unit No. 4 shall not exceed 129.9 lbs/hour, 3118 lbs/day, and 569.0 tons/year.

[PSD-FL-040 and Rule 62-296.700(4)(b)1., F.A.C.]

{Permitting note: The averaging time for the emissions standard in this condition shall be equal to the cumulative run time required by the specified test method.}

B.6. Visible emissions from Unit No. 4 shall not exceed 20 (twenty) percent opacity (6-minute average), except for one 6-minute period per hour of not more than 27 (twenty-seven) percent opacity.

[Rule 62-204.800(7)(b)2., F.A.C.; 40 CFR 60.42a(b); PSD-FL-040]

B.7. Sulfur dioxide emissions from Unit No. 4 when combusting solid fuel shall not exceed 0.82 lb/million Btu heat input and 10 percent of the potential combustion concentration (90 percent reduction). Based upon a heat input of 4330 million Btu/hour, SO<sub>2</sub> emissions shall not exceed 3551 lb/hr.

[Rule 62-204.800(7)(b)2., F.A.C.; 40 CFR 60.43a(a)(1); PSD-FL-040]

B.8. Compliance with sulfur dioxide emission limitations and percent reduction requirements is determined on a 30-day rolling average basis.

[Rule 62.204.800(7)(b)2., F.A.C.; 40 CFR 60.43a(g)]

B.9. Nitrogen dioxide emissions from Unit No. 4 when combusting bituminous or anthracite coal, or a coal/petroleum coke blend, shall not exceed 0.60 lb/million Btu heat input. Based upon a heat input of 4330 million Btu/hour, NO<sub>x</sub> emissions shall not exceed 2598 lb/hr. These emission limits are based on a 30-day rolling average. These standards apply at all times except during periods of startup, shutdown, or malfunction.

[Rule 62-204.800(7)(b)2., F.A.C.; 40 CFR 60.44a(a); 40 CFR 60.4a(c), PSD-FL-040]

B.10. Carbon monoxide (CO) emissions from Unit No. 4 shall not exceed 0.029 lb/million Btu heat input, and shall not exceed 124 lb/hr.

[PSD-FL-040 (October 9, 1985 modification)]

{Permitting note: The averaging time for the emissions standard in this condition shall be equal to the cumulative run time required by the specified test method.}

Compliance provisions.

B.11. The sulfur dioxide emission standards in specific condition B.7. apply at all times except during periods of startup, shutdown, or when both emergency conditions exist and the following procedures in specific condition B.12. are implemented.

[Rule 62-296.800(7)(b)2., F.A.C.; 40 CFR 60.46a(c)]

B.12. During emergency conditions in the principal company, an affected facility with a malfunctioning flue gas desulfurization system may be operated if sulfur dioxide emissions are minimized by:

(1) Operating all operable flue gas desulfurization system modules, and bringing back into operation any malfunctioned module as soon as repairs are completed,

(2) Bypassing flue gases around only those flue gas desulfurization system modules that have been taken out of operation because they were incapable of any sulfur dioxide emission reduction or which would have suffered significant physical damage if they had remained in operation, and

~~(3) Operating a spare flue gas desulfurization system module. The Department or EPCHC may at their discretion require TEC within 60 days of notification to demonstrate spare module capability. To demonstrate this capability, the owner or operator must demonstrate compliance with the appropriate requirements of specific conditions B.5. and B.7. for any period of operation lasting from 24 hours to 30 days when:~~

~~(i) Any one flue gas desulfurization module is not operated,~~

~~(ii) The affected facility is operating at the maximum heat input rate,~~

~~(iii) The fuel fired during the 24 hour to 30 day period is representative of the type and average sulfur content of fuel used over a typical 30 day period, and~~

~~(iv) TEC has given the Department or EPCHC at least 30 days notice of the date and period of time over which the demonstration will be performed.~~

[Rule 62-204.800(7)(b)2., F.A.C.; 40 CFR 60.46a(d)]

**TEC Rationale for Revision: Obsolete permit conditions. Common FGD scrubbing of Units 3 and 4, EPA Consent Decree, and FDEP Consent Final Judgment supersede requirements for a spare flue gas desulfurization module.**

B.13. Compliance with the sulfur dioxide emission limitations and percentage reduction requirements in specific condition B.7., and the nitrogen oxides emission limitations in specific condition B.10., is based on the *average emission rate* for 30 successive boiler operating days. A separate performance test is completed at the end of each boiler operating day after the initial performance test, and a new 30 day *average emission rate* for both sulfur dioxide and nitrogen oxides and a new percent reduction for sulfur dioxide are calculated to show compliance with the standards.

[Rule 62-204.800(7)(b)2., F.A.C.; 40 CFR 60.46a(e)]

**TEC Rationale for Revision: Administrative correction.**

B.14. Compliance is determined by calculating the arithmetic average of all hourly *emission rates* for SO<sub>2</sub> and NO<sub>x</sub> for the 30 successive boiler operating days, except for data obtained during startup, shutdown, malfunction (NO<sub>x</sub> only), or emergency conditions (SO<sub>2</sub> only). Compliance with the percentage reduction requirement for SO<sub>2</sub> is determined based on the average inlet and average outlet SO<sub>2</sub> emission rates for the 30 successive boiler operating days.

[Rule 62-204.800(7)(b)2., F.A.C.; 40 CFR 60.46a(g)]

B.15. If TEC has not obtained the minimum quantity of emission data as required in the following emission monitoring specific conditions B.16. through B.25, compliance of Unit No. 4 with the sulfur dioxide and nitrogen oxides standards for the day on which the 30-day period ends may be determined by the Administrator by following the applicable procedures in section 7 of Method 19, *Determination of Compliance When Minimum Data Requirement Is Not Met*.

[Rule 62-204.800(7)(b)2., F.A.C.; 40 CFR 60.46a(h); 40 CFR 60, Appendix A, Method 19]

#### Emission Monitoring.

B.16. TEC shall calibrate, maintain, and operate a continuous monitoring system, and record the output of the system, for measuring the opacity of emissions discharged to the atmosphere. If opacity interference due to water droplets exists in the stack (for example, from the use of an FGD system), the opacity is monitored upstream of the interference (at the inlet to the FGD system). If opacity interference is experienced at all locations (both at the inlet and outlet of the sulfur dioxide control system), alternate parameters indicative of the particulate matter control system's performance are monitored (subject to the approval of the Department and the EPCHC.)

[Rule 62-204.800(7)(b)2., F.A.C.; 40 CFR 60.47a(a)]

B.17. TEC shall calibrate, maintain, and operate a continuous monitoring system, and record the output of the system, for measuring sulfur dioxide emissions as follows:

(1) Sulfur dioxide emissions are monitored at both the inlet and outlet of the sulfur dioxide control device.

(2) An "as fired" fuel monitoring system (upstream of coal pulverizers) meeting the requirements of Method 19, Determination of Sulfur Dioxide Removal Efficiency and Particulate Matter, Sulfur Dioxide, and Nitrogen Oxides Emission Rates, may be used to determine potential sulfur dioxide emissions in place of a continuous sulfur dioxide emission monitor at the inlet to the sulfur dioxide control device as required in the preceding specific condition B.17.(1).

[Rule 62-204.800(7)(b)2., F.A.C.; 40 CFR 60.47a(b); 40 CFR 60, App. A, Method 19]

B.18. TEC shall calibrate, maintain, and operate a continuous monitoring system, and record the output of the system, for measuring nitrogen oxides emissions discharged to the atmosphere.

[Rule 62-204.800(7)(b)2., F.A.C.; 40 CFR 60.47a(c)]

B.19. TEC shall calibrate, maintain, and operate a continuous monitoring system, and record the output of the system, for measuring the oxygen and/or carbon dioxide content of the flue gases at each location where sulfur dioxide or nitrogen oxides emissions are monitored. The sulfur dioxide, nitrogen dioxide, oxygen and/or carbon dioxide, and opacity monitoring devices shall meet the applicable requirements of Section 62-214, F.A.C., 40 CFR 60.47a., and 40 CFR 75. ). The opacity monitors shall be placed in the duct work between the electrostatic precipitator and the FGD scrubber. ~~When Units 3 and 4 are operating in the integrated mode (Unit 3 flue gases routed through the Unit 4 FGD system),~~ The continuous

monitoring system will measure sulfur dioxide emissions at the inlet of each unit and outlet of the Unit 4 FGD system and from the Unit 3 stack (CS002) and Unit 4 stack (CS003), while emissions of nitrogen oxides, oxygen and/or carbon dioxide, and opacity shall be measured in the Unit 3 & 4 ducts prior to the FGD system. When Unit 4 is operating and Unit 3 and 4 are is not operating in the integrated mode, the continuous monitoring system will measure only Unit 4's inlet duct and stack for SO<sub>2</sub> emissions. The emissions of nitrogen oxides, oxygen and/or carbon dioxide, and opacity shall be measured in the Unit 4 duct prior to the FGD system. The emissions of carbon dioxide and sulfur dioxides are both measured in the inlet and outlet ducts.

[Rule 62-204.800(7)(b)2., F.A.C.; 40 CFR 60.47a(d); Power Plant Siting Certification PA 79-12D]

**TEC Rationale for Revision: Administrative corrections.**

B.20. The continuous monitoring systems required in specific conditions B.17., B.18., and B.19., shall be operated and record data during all periods of operation of Unit No. 4 including periods of startup, shutdown, malfunction or emergency conditions, except for continuous monitoring system breakdowns, repairs, calibration checks, and zero and span adjustments.

[Rule 62-204.800(7)(b)2., F.A.C.; 40 CFR 60.47a(e)]

B.21. TEC shall obtain emission data for at least 18 hours in at least 22 out of 30 successive boiler operating days. If this minimum data requirement cannot be met with a continuous monitoring system, TEC shall supplement emission data with other monitoring systems approved by the Department or the EPCHC, or the reference methods and procedures as described in Specific Condition B.23.

[Rule 62-204.800(7)(b)2., F.A.C.; 40 CFR 60.47a (f)]

B.22. The 1-hour averages required under 40 CFR 60.13(h), *Monitoring Requirements*, are expressed in lbs/million Btu heat input and used to calculate the average emission rates required in specific conditions B.13. and B.14. The 1-hour averages are calculated using the data points required under 40 CFR 60.13(b), *Monitoring Requirements*. At least two data points must be used to calculate the 1-hour averages.

[Rule 62-204.800(7)(b)2., F.A.C.; 40 CFR 60.47a(g)]

B.23. When it becomes necessary to supplement continuous monitoring system data to meet the minimum data requirements in specific condition B.21., TEC shall use the following reference methods and procedures. Acceptable alternative methods and procedures are given in specific condition B.25.

(1) Method 6 shall be used to determine the SO<sub>2</sub> concentration at the same location as the SO<sub>2</sub> monitor. Samples shall be taken at 60-minute intervals. The sampling time and sample volume for each sample shall be at least 20 minutes and 0.020 dscm (0.71 dscf). Each sample represents a 1-hour average.

(2) Method 7 shall be used to determine the NO<sub>x</sub> concentration at the same location as the NO<sub>x</sub> monitor. Samples shall be taken at 30-minute intervals. The arithmetic average of two consecutive samples represents a 1-hour average.

(3) The emission rate correction factor, integrated bag sampling and analysis procedure of Method 3B shall be used to determine the O<sub>2</sub> or CO<sub>2</sub> concentration at the same location as the O<sub>2</sub> or CO<sub>2</sub> monitor. Samples shall be taken for at least 30 minutes in each hour. Each sample represents a 1-hour average.

(4) The procedures in Method 19 shall be used to compute each 1-hour average concentration in lb/million Btu heat input.

[Rule 62-204.800(7)(b)2., F.A.C.; 40 CFR 60.47a(h); 40 CFR 60, Appendix A, Methods 3B, 6, 7, and 19]

B.24. TEC shall use the following methods and procedures to conduct the monitoring system performance evaluations required under 40 CFR 60.13(c), *Monitoring Requirements*, and the calibration checks required under 40 CFR 60.13(d), *Monitoring Requirements*. Acceptable alternative methods and procedures are given in specific condition B.25.

(1) Methods 6, 7, and 3B, as applicable, shall be used to determine O<sub>2</sub>, SO<sub>2</sub>, and NO<sub>x</sub> concentrations  
 (2) SO<sub>2</sub> or NO<sub>x</sub> (NO), as applicable, shall be used for preparing the calibration gas mixtures (in N<sub>2</sub>, as applicable) under 40 CFR 60 Appendix B, Performance Specification 2.

(3) The span value for a continuous monitoring system for measuring opacity is between 60 and 80 percent and for a continuous monitoring system measuring nitrogen oxides is determined as follows

Fossil fuel	Span value for nitrogen oxides (ppm)
Solid.....	1,000

(4) Reserved

(5) For affected facilities burning fossil fuel alone or in combination with non-fossil fuel, the span value of the sulfur dioxide continuous monitoring system at the inlet to the sulfur dioxide control device is 125 percent of the maximum estimated hourly potential emissions of the fuel fired, and the outlet of the sulfur dioxide control device is 50 percent of maximum estimated hourly potential emissions oil fuel, alone or in combination with non-fossil fuel, the span value of the fuel fired.

[Rule 62-204.800(7)(b)2., F.A.C.; 40 CFR 60.47a(i); 40 CFR 60.13; 40 CFR 60 Appendix A, Methods 3B, 6, and 7; 40 CFR 60 Appendix B, Performance Specification 2.]

B.25. TEC may use the following as alternatives to the reference methods and procedures specified in conditions B.23. and B.24.:

(1) For Method 6, Method 6A or 6B (whenever Methods 6 and 3 or 3B data are used) or 6C may be used. Each Method 6B sample obtained over 24 hours represents 24 1-hour averages. If Method 6A or 6B is used under specific condition B.24., the conditions under 40 CFR 60.46(d)(1) apply; these conditions do not apply under specific condition B.23.

(2) For Method 7, Method 7A, 7C, 7D, or 7E may be used. If Method 7C, 7D, or 7E is used, the sampling time for each run shall be 1 hour.

(3) For Method 3, Method 3A or 3B may be used if the sampling time is 1 hour.

(4) For Method 3B, Method 3A may be used.

[Rule 62-204.800(7)(b)2., F.A.C.; 40 CFR 60.47a(j); 40 CFR 60.46(d)(1), 40 CFR 60 Appendix A, Methods 3, 3A, 3B, 6, 6A, 6B, 6C, 7, 7A, 7C, 7D, and 7E]

Compliance determination procedures and methods.

B.26. In conducting the performance tests required in 40 CFR 60.8, the owner or operator shall use as reference methods and procedures the methods in appendix A of 40 CFR 60 or the methods and procedures as specified in conditions B.27. through B.30., except as provided in 40 CFR 60.8(b). 40 CFR 60.8(f) does not apply to specific conditions B.28 and B.29. for SO<sub>2</sub> and NO<sub>x</sub>. Acceptable alternative methods are given in specific condition B.30.

[Rule 62-204.800(7)(b)2., F.A.C.; 40 CFR 60.48a(a); 40 CFR 60.8]

B.27. TEC shall determine compliance with the particulate matter standards in specific condition B.5. as follows:

(1) The dry basis F factor ( $O_2$ ) procedures in Method 19 shall be used to compute the emission rate of particulate matter.

(2) For the particular matter concentration, Method 5B shall be used after wet FGD systems.

(i) The sampling time and sample volume for each run shall be at least 120 minutes and 1.70 dscm (60 dscf). The probe and filter holder heating system in the sampling train may be set to provide an average gas temperature of no greater than  $160 \pm 14$  °C ( $320 \pm 25$  °F).

(ii) For each particulate run, the emission rate correction factor, integrated or grab sampling and analysis procedures of Method 3B shall be used to determine the  $O_2$  concentration. The  $O_2$  sample shall be obtained simultaneously with, and at the same traverse points as, the particulate run. If the particulate run has more than 12 traverse points, the  $O_2$  traverse points may be reduced to 12 provided that Method 1 is used to locate the 12  $O_2$  traverse points. If the grab sampling procedure is used, the  $O_2$  concentration for the run shall be the arithmetic mean of all the individual  $O_2$  concentrations at each traverse point.

(3) Method 9 and the procedures in 40 CFR 60.11 shall be used to determine opacity.

[Rule 62-204.800(7)(b)2., F.A.C.; 40 CFR 60.48a(b); 40 CFR 60.11, 40 CFR 60 Appendix A, Methods 1, 3B, 5B, 9, and 19]

~~B.28. TEC shall determine compliance with the  $SO_2$  standards in specific condition B.7. as follows:~~

~~(1) The percent of potential  $SO_2$  emissions ( $\%P_s$ ) to the atmosphere shall be computed using the following equation:~~

$$\%P_s = [(100 - \%R_f)(100 - \%R_g)]/100$$

~~where:~~

~~$\%P_s$  = percent of potential  $SO_2$  emissions, percent.~~

~~$\%R_f$  = percent reduction from fuel pretreatment, percent.~~

~~$\%R_g$  = percent reduction by  $SO_2$  control system, percent.~~

~~(2) The procedures in Method 19 may be used to determine percent reduction ( $\%R_f$ ) of sulfur by such processes as fuel pretreatment (physical coal cleaning, hydrodesulfurization of fuel oil, etc.), coal pulverizers, and bottom and flyash interactions. This determination is optional.~~

~~(3) The procedures in Method 19 shall be used to determine the percent  $SO_2$  reduction ( $\%R_g$ ) of any  $SO_2$  control system. Alternatively, a combination of an "as fired" fuel monitor and emission rates measured after the control system, following the procedures in Method 19, may be used if the percent reduction is calculated using the average emission rate from the  $SO_2$  control device and the average  $SO_2$  input rate from the "as fired" fuel analysis for 30 successive boiler operating days.~~

~~(4) The appropriate procedures in Method 19 shall be used to determine the emission rate.~~

~~(5) The continuous monitoring systems specified in conditions B.17. and B.19. shall be used to determine the concentrations of  $SO_2$  and  $CO_2$  or  $O_2$ .~~

~~[Rule 62-204.800(7)(b)2., F.A.C.; 40 CFR 60.48a (c); 40 CFR 60.43a; 40 CFR 60.47a(b) and (d); 40 CFR 60 Appendix A, Method 19]~~

**TEC Rationale for Revision:** Obsolete permit condition.  $SO_2$  CEMS is used for compliance monitoring. Common FGD scrubbing of Units 3 and 4, EPA Consent Decree, and FDEP Consent

**Final Judgment supersede coal washing requirement. Proposed June 6, 2003 modifications to Unit 4 Conditions of Certification delete requirement for coal washing.**

B.29. TEC shall determine compliance with the NO<sub>x</sub> standards in specific condition B.9. as follows:

(1) The appropriate procedures in Method 19 shall be used to determine the emission rate of NO<sub>x</sub>.

(2) The ~~continuous~~ continuous monitoring systems specified in specific conditions B.18. and B.19. shall be used to determine the concentrations of NO<sub>x</sub> and CO<sub>2</sub> or O<sub>2</sub>.

[Rule 62-204.800(7)(b)2., F.A.C.; 40 CFR 60.48a(d); 40 CFR 60.44a; 40 CFR 60.47a(c); 40 CFR 60.47a(d)]

**TEC Rationale for Revision: Administrative correction.**

B.30. TEC may use the following as alternatives to the reference methods and procedures specified in condition B.27:

(1) For Method 5 or 5B, Method 17 may be used at Unit No. 4 if the stack temperature at the sampling location does not exceed an average temperature of 160 °C (320 °F). The procedures of sections 2.1 and 2.3 of Method 5B may be used in Method 17 only if it is used after wet FGD systems. Method 17 shall not be used after wet FGD systems if the effluent is saturated or laden with water droplets.

(2) The F<sub>c</sub> factor (CO<sub>2</sub>) procedures in Method 19 may be used to compute the emission rate of particulate matter under the stipulations of *40 CFR 60.46(d)(1)*. The CO<sub>2</sub> shall be determined in the same manner as the O<sub>2</sub> concentration.

[Rule 62-204.800(7)(b)2., F.A.C.; 40 CFR 60.48a(e); 40 CFR 60.46(d)(1); 40 CFR 60 Appendix A, Methods 5, 5B, 17, and 19]

**Reporting requirements.**

B.31. For sulfur dioxide, nitrogen oxides, and particulate matter emissions, the performance test data from the initial performance test and from the performance evaluation of the continuous monitors (including the transmissometer) shall be submitted to the Department and the EPCHC.

[Rule 62-204.800(7)(b)2., F.A.C.; 40 CFR 60.49a(a)]

B.32. For sulfur dioxide and nitrogen oxides the following information shall be reported to the Department and the EPCHC for each 24-hour period.

(1) Calendar date.

(2) The average sulfur dioxide and nitrogen oxide emission rates (lb/million Btu heat input) for each 30 successive boiler operating days, ending with the last 30-day period in the quarter; reasons for non-compliance with the emission standards; and, description of corrective actions taken.

(3) Percent reduction of the potential combustion concentration of sulfur dioxide for each 30 successive boiler operating days, ending with the last 30-day period in the quarter; reasons for non-compliance with the standard; and, description of corrective actions taken.

(4) Identification of the boiler operating days for which pollutant or diluent data have not been obtained by an approved method for at least 18 hours of operation of the facility; justification or not obtaining sufficient data; and description of corrective actions taken.

(5) Identification of the times when emissions data have been excluded from the calculation of average emission rates because of startup, shutdown, malfunction (NO<sub>x</sub> only), emergency conditions (SO<sub>2</sub> only), or other reasons, and justification for excluding data for reasons other than startup, shutdown, malfunction, or emergency conditions.



(6) Identification of "F" factor used for calculations, method of determination, and type of fuel combusted.

(7) Identification of times when hourly averages have been obtained based on manual sampling methods.

(8) Identification of the times when the pollutant concentration exceeded full span of the continuous monitoring system.

(9) Description of any modifications to the continuous monitoring system which could affect the ability of the continuous monitoring system to comply with 40 CFR 60 Appendix B, Performance Specifications 2 or 3.

[Rule 62-204.800(7)(b)2., F.A.C.; 40 CFR 60.49a(b); 40 CFR 60 Appendix B]

B.33. If the minimum quantity of emission data, as required by the emission monitoring specific conditions B.16. through B.25., is not obtained for any 30 successive boiler operating days, the following information obtained under the requirements of specific condition B.15. shall be reported to the Administrator for that 30-day period:

(1) The number of hourly averages available for outlet emission rates ( $n_o$ ) and inlet emission rates ( $n_i$ ) as applicable.

(2) The standard deviation of hourly averages for outlet emission rates ( $s_o$ ) and inlet emission rates ( $s_i$ ) as applicable.

(3) The lower confidence limit for the mean outlet emission rate ( $E_o^*$ ) and the upper confidence limit for the mean inlet emission rate ( $E_i^*$ ) as applicable.

(4) The applicable potential combustion concentration.

(5) The ratio of the upper confidence limit for the mean outlet emission rate ( $E_o^*$ ) and the allowable emission rate ( $E_{std}$ ) as applicable.

[Rule 62-204.800(7)(b)2., F.A.C.; 40 CFR 60.49a(c); 40 CFR 60 Appendix A, Method 19]

B.34. If any sulfur dioxide standards under specific condition B.7. is exceeded during emergency conditions because of control system malfunction, the owner or operator of the affected facility shall submit a signed statement:

(1) Indicating if emergency conditions existed and requirements under specific condition B.14. were met during each period, and

(2) Listing the following information:

(i) Time periods the emergency condition existed;

(ii) Electrical output and demand on the owner or operator's electric utility system and the affected facility;

(iii) Amount of power purchased from interconnected neighboring utility companies during the emergency period;

(iv) Percent reduction in emissions achieved;

(v) Atmospheric emission rate (ng/J or lb/MMBtu) of the pollutant discharged; and

(vi) Actions taken to correct control system malfunction.

[Rule 62-204.800(7)(b)2., F.A.C.; 40 CFR 60.49a(d); 40 CFR 60.43a; 40 CFR 60.46a(d)]

~~B.35. If fuel pretreatment credit is claimed toward the sulfur dioxide emission standards in specific condition B.7. TEC shall submit a signed statement:~~

~~—(1) Indicating what percentage cleaning credit was taken for the calendar quarter, and whether the credit was determined in accordance with the provisions of specific condition B.28. and Method 19 (Appendix A of 40 CFR 60); and~~

~~—(2) Listing the quantity, heat content, and date each pretreated fuel shipment was received during the previous quarter; the name and location of the fuel pretreatment facility; and the total quantity and total heat content of all fuels received at the affected facility during the previous quarter.~~

~~[Rule 62-204.800(7)(b)2., F.A.C.; 40 CFR 60.49a(e), 40 CFR 60.48a(c)]~~

**TEC Rationale for Revision: Administrative correction and obsolete permit condition. SO<sub>2</sub> CEMS is used for compliance monitoring. EPA Consent Decree and FDEP Consent Final Judgment supersede coal washing requirement. Proposed June 6, 2003 modifications to Unit 4 Conditions of Certification delete the requirement for coal washing.**

B.36. For any periods for which opacity, sulfur dioxide or nitrogen oxides emissions data are not available, the owner or operator of the affected facility shall submit a signed statement indicating if any changes were made in operation of the emission control system during the period of data unavailability. Operations of the control system and affected facility during periods of data unavailability are to be compared with operation of the control system and affected facility before and following the period of data unavailability.

[Rule 62-204.800(7)(b)2., F.A.C.; 40 CFR 60.49a(f)]

B.37. The owner or operator of the affected facility shall submit a signed statement indicating whether:

(1) The required continuous monitoring system calibration, span, and drift checks or other periodic audits have or have not been performed as specified.

(2) The data used to show compliance was or was not obtained in accordance with approved methods and procedures of this part and is representative of plant performance.

(3) The minimum data requirements have or have not been met; or, the minimum data requirements have not been met for errors that were unavoidable.

(4) Compliance with the standards has or has not been achieved during the reporting period.

[Rule 62-204.800(7)(b)2., F.A.C.; 40 CFR 60.49a(g)]

B.38. For the purposes of the reports required under 40 CFR 60.7, periods of excess emissions are defined as all 6-minute periods during which the average opacity exceeds the applicable opacity standards under specific condition B.6. Opacity levels in excess of the applicable opacity standard and the date of such excesses are to be submitted to the Administrator each calendar quarter.

[Rule 62-204.800(7)(b)2., F.A.C.; 40 CFR 60.49a(h)]

B.39. The owner or operator of an affected facility shall submit the written reports required under this section and subpart A to the Department and the EPCHC for every calendar quarter. All quarterly reports shall be postmarked by the 30th day following the end of each calendar quarter.

[Rule 62-204.800(7)(b)2., F.A.C.; 40 CFR 60.49a(i)]

B.40. Gravimetric instrument data verifying that the 20.0% maximum petroleum coke content by weight has not been exceeded shall be maintained for five years and submitted to the Department and the EPCHC with each annual operating report. Also to be maintained and available for inspection shall be a daily record of operation showing the date, fuel used, mode of operation (integrated/non-integrated), and the duration of all startups, shutdowns and malfunctions. TEC shall maintain copies of fuel analyses containing information on sulfur content, ash content, and heating values.

[PSD-FL-040; Rules 62-4.070(3), 62-213.440(1)(b)2.b., F.A.C., and Power Plant Siting Certification PA 79-12]

B.41. TEC shall submit to the Department a standardized plan or procedure that will allow the permittee to monitor emission control equipment efficiency and enable the permittee to return malfunctioning equipment to proper operation as expeditiously as possible.  
[Power Plant Siting Certification PA 79-12]

B.42. Pursuant to Rule 62-212.200(2)(d), F.A.C., the actual emissions of the No. 4 Unit shall equal the representative actual emissions as defined in 40 CFR 52.21(b)(33). TEC shall maintain and submit to the Department and the EPCHC on an annual basis for a period of 5 years from the date the unit begins firing petroleum coke, data demonstrating that the operational change did not result in an emissions increase.  
[PSD-FL-040; PA 79-12, Conditions of Certification]

B.43. Stack height. The height of the boiler exhaust stack for Unit No. 4 (CS003) shall not be less than 490 ft. above grade.  
[Power Plant Siting Certification PA 79-12]

**The following requirements of 40 CFR 60, Subpart A - General Provisions Requirements, apply to Unit No. 4:**

B.44. Definitions. For the purposes of Rule 62-204.800(7), F.A.C., the definitions contained in the various provisions of 40 CFR 60, shall apply except that the term "Administrator" when used in 40 CFR 60, shall mean the Secretary or the Secretary's designee.  
[40 CFR 60.2; Rule 62-204.800(7)(a), F.A.C.]

40 CFR 60.7 Notification and record keeping.

B.45. The owner or operator subject to the provisions of 40 CFR 60 shall furnish the Administrator written notification as follows:

A notification of any physical or operational change to an existing facility which may increase the emission rate of any air pollutant to which a standard applies, unless that change is specifically exempted under an applicable subpart or in 40 CFR 60.14(e). This notice shall be postmarked 60 days or as soon as practicable before the change is commenced and shall include information describing the precise nature of the change, present and proposed emission control systems, productive capacity of the facility before and after the change, and the expected completion date of the change. The Administrator may request additional relevant information subsequent to this notice.

[40 CFR 60.7(a)(4)]

B.46. The owner or operator subject to the provisions of 40 CFR 60 shall maintain records of the occurrence and duration of any startup, shutdown, or malfunction in the operation of an affected facility; any malfunction of the air pollution control equipment; or, any periods during which a continuous monitoring system or monitoring device is inoperative.

[40 CFR 60.7(b)]

B.47. Each owner or operator required to install a continuous monitoring system (CMS) or monitoring device shall submit an excess emissions and monitoring systems performance report (excess emissions are defined in applicable subparts) and/or a summary report form [see 40 CFR 60.7(d)] to the Administrator semiannually, except when: more frequent reporting is specifically required by an

applicable subpart; or, the CMS data are to be used directly for compliance determination, in which case quarterly reports shall be submitted; or, the Administrator, on a case-by-case basis, determines that more frequent reporting is necessary to accurately assess the compliance status of the source. All reports shall be postmarked by the 30th day following the end of each calendar half (or quarter, as appropriate).

Written reports of excess emissions shall include the following information:

- (1) The magnitude of excess emissions computed in accordance with 40 CFR 60.13(h), any conversion factor(s) used, and the date and time of commencement and completion of each time period of excess emissions. The process operating time during the reporting period.
- (2) Specific identification of each period of excess emissions that occurs during startups, shutdowns, and malfunctions of the affected facility. The nature and cause of any malfunction (if known), the corrective action taken or preventative measures adopted.
- (3) The date and time identifying each period during which the continuous monitoring system was inoperative except for zero and span checks and the nature of the system repairs or adjustments.
- (4) When no excess emissions have occurred or the continuous monitoring system(s) have not been inoperative, repaired, or adjusted, such information shall be stated in the report.

[40 CFR 60.7(c)(1), (2), (3), and (4)]

B.48. The summary report form shall contain the information and be in the format shown in Figure 1 (attached) unless otherwise specified by the Administrator. One summary report form shall be submitted for each pollutant monitored at each affected facility.

(1) If the total duration of excess emissions for the reporting period is less than 1 percent of the total operating time for the reporting period and CMS downtime for the reporting period is less than 5 percent of the total operating time for the reporting period, only the summary report form shall be submitted and the excess emission report described in 40 CFR 60.7(c) need not be submitted unless requested by the Administrator.

(2) If the total duration of excess emissions for the reporting period is 1 percent or greater of the total operating time for the reporting period or the total CMS downtime for the reporting period is 5 percent or greater of the total operating time for the reporting period, the summary report form and the excess emission report described in 40 CFR 60.7(c) shall both be submitted.

***{See attached Figure 1: Summary Report-Gaseous and Opacity Excess Emission and Monitoring System Performance} (electronic file name: figure1.doc)***

[40 CFR 60.7(d)(1) and (2)]

B.49. (1) Notwithstanding the frequency of reporting requirements specified in 40 CFR 60.7(c), an owner or operator who is required by an applicable subpart to submit excess emissions and monitoring systems performance reports (and summary reports) on a quarterly (or more frequent) basis may reduce the frequency of reporting for that standard to semiannual if the following conditions are met:

(i) For 1 full year (e.g., 4 quarterly or 12 monthly reporting periods) the affected facility's excess emissions and monitoring systems reports submitted to comply with a standard under this part continually demonstrate that the facility is in compliance with the applicable standard;

(ii) The owner or operator continues to comply with all recordkeeping and monitoring requirements specified in 40 CFR 60, Subpart A, and the applicable standard; and

(iii) The Administrator does not object to a reduced frequency of reporting for the affected facility, as provided in 40 CFR 60.7(e)(2).

(2) The frequency of reporting of excess emissions and monitoring systems performance (and summary) reports may be reduced only after the owner or operator notifies the Administrator in writing of his or her intention to make such a change and the Administrator does not object to the intended

change. In deciding whether to approve a reduced frequency of reporting, the Administrator may review information concerning the source's entire previous performance history during the required recordkeeping period prior to the intended change, including performance test results, monitoring data, and evaluations of an owner or operator's conformance with operation and maintenance requirements. Such information may be used by the Administrator to make a judgment about the source's potential for noncompliance in the future. If the Administrator disapproves the owner or operator's request to reduce the frequency of reporting, the Administrator will notify the owner or operator in writing within 45 days after receiving notice of the owner or operator's intention. The notification from the Administrator to the owner or operator will specify the grounds on which the disapproval is based. In the absence of a notice of disapproval within 45 days, approval is automatically granted.

(3) As soon as monitoring data indicate that the affected facility is not in compliance with any emission limitation or operating parameter specified in the applicable standard, the frequency of reporting shall revert to the frequency specified in the applicable standard, and the owner or operator shall submit an excess emissions and monitoring systems performance report (and summary report, if required) at the next appropriate reporting period following the noncomplying event. After demonstrating compliance with the applicable standard for another full year, the owner or operator may again request approval from the Administrator to reduce the frequency of reporting for that standard as provided for in 40 CFR 60.7(e)(1) and (e)(2).

[40 CFR 60.7(e)(1)]

B.50. Any owner or operator subject to the provisions of 40 CFR 60 shall maintain a file of all measurements, including continuous monitoring system, monitoring device, and performance testing measurements; all continuous monitoring system performance evaluations; all continuous monitoring system or monitoring device calibration checks; adjustments and maintenance performed on these systems or devices; and, all other information required by 40 CFR 60 recorded in a permanent form suitable for inspection. The file shall be retained for at least 5 (five) years following the date of such measurements, maintenance, reports, and records.

[40 CFR 60.7(f); Rule 62-213.440(1)(b)2.b., F.A.C.]

#### 40 CFR 60.8 Performance tests.

B.51. Performance tests shall be conducted under such conditions as the Administrator shall specify to the plant operator based on representative performance of the affected facility. The owner or operator shall make available to the Administrator such records as may be necessary to determine the conditions of the performance tests. Operations during periods of startup, shutdown, and malfunction shall not constitute representative conditions for the purpose of a performance test nor shall emissions in excess of the level of the applicable emission limit during periods of startup, shutdown, and malfunction be considered a violation of the applicable emission limit unless otherwise specified in the applicable standard.

[40 CFR 60.8(c)]

B.52. The owner or operator of an affected facility shall provide the Administrator at least 30 days prior notice of any performance test, except as specified under other subparts, to afford the Administrator the opportunity to have an observer present.

[40 CFR 60.8(d)]

#### 40 CFR 60.11 Compliance with standards and maintenance requirements.

B.53. Compliance with standards in 40 CFR 60, other than opacity standards, shall be determined in accordance with performance tests established by 40 CFR 60.8, unless otherwise specified in the applicable standard.  
[40 CFR 60.11(a)]

B.54. Compliance with opacity standards in 40 CFR 60 shall be determined by conducting observations in accordance with Reference Method 9 in Appendix A of 40 CFR 60, any alternative method that is approved by the Administrator, or as provided in 40 CFR 60.11(e)(5).  
[40 CFR 60.11(b)]

B.55. The opacity standards set forth in 40 CFR 60 shall apply at all times except during periods of startup, shutdown, malfunction, and as otherwise provided in the applicable standard.  
[40 CFR 60.11(c)]

B.56. At all times, including periods of startup, shutdown, and malfunction, owners and operators shall, to the extent practicable, maintain and operate any affected facility including associated air pollution control equipment in a manner consistent with good air pollution control practice for minimizing emissions. Determination of whether acceptable operating and maintenance procedures are being used will be based on information available to the Administrator which may include, but is not limited to, monitoring results, opacity observations, review of operating and maintenance procedures, and inspection of the source.  
[40 CFR 60.11(d)]

B.57. The owner or operator of an affected facility subject to an opacity standard may submit, for compliance purposes, continuous opacity monitoring system (COMS) data results produced during any performance test required under 40 CFR 60.8 in lieu of EPA Method 9 observation data. If an owner or operator elects to submit COMS data for compliance with the opacity standard, he or she shall notify the Administrator of that decision, in writing, at least 30 days before any performance test required under 40 CFR 60.8 is conducted. Once the owner or operator of an affected facility has notified the Administrator to that effect, the COMS data results will be used to determine opacity compliance during subsequent tests required under 40 CFR 60.8 until the owner or operator notifies the Administrator, in writing, to the contrary. For the purpose of determining compliance with the opacity standard during a performance test required under 40 CFR 60.8 using COMS data, the minimum total time of COMS data collection shall be averages of all 6-minute continuous periods within the duration of the mass emission performance test. Results of the COMS opacity determinations shall be submitted along with the results of the performance test required under 60.8. The owner or operator of an affected facility using a COMS for compliance purposes is responsible for demonstrating that the COMS meets the requirements specified in 40 CFR 60.13(c), that the COMS has been properly maintained and operated, and that the resulting data have not been altered in any way. If COMS data results are submitted for compliance with the opacity standard for a period of time during which EPA Method 9 data indicates noncompliance, the EPA Method 9 data will be used to determine opacity compliance.  
[40 CFR 60.11(e)(5)]

40 CFR 60.12 Circumvention.

B.58. No owner or operator subject to the provisions of 40 CFR 60 shall build, erect, install, or use any article, machine, equipment or process, the use of which conceals an emission which would otherwise constitute a violation of an applicable standard. Such concealment includes, but is not limited to, the use of gaseous diluents to achieve compliance with an opacity standard or with a standard which is based on the concentration of a pollutant in the gases discharged to the atmosphere.

[40 CFR 60.12]

**40 CFR 60.13 Monitoring requirements.**

B.59. For the purposes of 40 CFR 60.13, all continuous monitoring systems (CMS) required under applicable subparts shall be subject to the provisions of 40 CFR 60.13 upon promulgation of performance specifications for continuous monitoring systems under Appendix B of 40 CFR 60 and, if the continuous monitoring system is used to demonstrate compliance with emission limits on a continuous basis, Appendix F of 40 CFR 60, unless otherwise specified in an applicable subpart or by the Administrator.

Appendix F is applicable December 4, 1987.

[40 CFR 60.13(a)]

B.60. If the owner or operator of an affected facility elects to submit continuous opacity monitoring system (COMS) data for compliance with the opacity standard as provided under 40 CFR 60.11(e)(5), he shall conduct a performance evaluation of the COMS as specified in Performance Specification 1, Appendix B, of 40 CFR 60 before the performance test required under 40 CFR 60.8 is conducted.

Otherwise, the owner or operator of an affected facility shall conduct a performance evaluation of the COMS or continuous emission monitoring system (CEMS) during any performance test required under 40 CFR 60.8 or within 30 days thereafter in accordance with the applicable performance specification in Appendix B of 40 CFR 60. The owner or operator of an affected facility shall conduct COMS or CEMS performance evaluations at such other times as may be required by the Administrator under section 114 of the Act.

(1) The owner or operator of an affected facility using a COMS to determine opacity compliance during any performance test required under 60.8 and as described in 40 CFR 60.11(e)(5) shall furnish the Administrator two or, upon request, more copies of a written report of the results of the COMS performance evaluation described in 40 CFR 60.13(c) at least 10 days before the performance test required under 60.8 is conducted.

[40 CFR 60.13(c)(1)]

B.61. (1) Owners and operators of all continuous emission monitoring systems (CEMS) installed in accordance with the provisions of this part shall check the zero (or low-level value between 0 and 20 percent of span value) and span (50 to 100 percent of span value) calibration drifts at least once daily in accordance with a written procedure. The zero and span shall, as a minimum, be adjusted whenever the 24-hour zero drift or 24-hour span drift exceeds two times the limits of the applicable performance specifications in Appendix B. The system must allow the amount of excess zero and span drift measured at the 24-hour interval checks to be recorded and quantified, whenever specified. For continuous monitoring systems measuring opacity of emissions, the optical surfaces exposed to the effluent gases shall be cleaned prior to performing the zero and span drift adjustments except that for systems using automatic zero adjustments. The optical surfaces shall be cleaned when the cumulative automatic zero compensation exceeds 4 percent opacity.

(2) Unless otherwise approved by the Administrator, the following procedures shall be followed for continuous monitoring systems measuring opacity of emissions. Minimum procedures shall include a

method for producing a simulated zero opacity condition and an upscale (span) opacity condition using a certified neutral density filter or other related technique to produce a known obscuration of the light beam. Such procedures shall provide a system check of the analyzer internal optical surfaces and all electronic circuitry including the lamp and photo detector assembly.  
[40 CFR 60.13(d)(1) and (2)]

B.62. Except for system breakdowns, repairs, calibration checks, and zero and span adjustments required under 40 CFR 60.13(d), all continuous monitoring systems (CMS) shall be in continuous operation and shall meet minimum frequency of operation requirements as follows:

(1) All continuous monitoring systems referenced by 40 CFR 60.13(c) for measuring opacity of emissions shall complete a minimum of one cycle of sampling and analyzing for each successive 10-second period and one cycle of data recording for each successive 6-minute period.

(2) All continuous monitoring systems referenced by 40 CFR 60.13(c) for measuring emissions, except opacity, shall complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each successive 15-minute period.

[40 CFR 60.13(e)(1) and (2)]

B.63. All continuous monitoring systems (CMS) or monitoring devices shall be installed such that representative measurements of emissions or process parameters from the affected facility are obtained. Additional procedures for location of continuous monitoring systems contained in the applicable Performance Specifications of Appendix B of 40 CFR 60 shall be used.  
[40 CFR 60.13(f)]

B.64. When the effluents from a single affected facility or two or more affected facilities subject to the same emission standards are combined before being released to the atmosphere, the owner or operator may install applicable continuous monitoring systems (CMS) on each effluent or on the combined effluent. When the affected facilities are not subject to the same emission standards, separate continuous monitoring systems shall be installed on each effluent. When the effluent from one affected facility is released to the atmosphere through more than one point, the owner or operator shall install an applicable continuous monitoring system on each separate effluent unless the installation of fewer systems is approved by the Administrator. When more than one continuous monitoring system is used to measure the emissions from one affected facility (e.g., multiple breechings, multiple outlets), the owner or operator shall report the results as required from each continuous monitoring system.  
[40 CFR 60.13(g)]

B.65. Owners or operators of all continuous monitoring systems for measurement of opacity shall reduce all data to 6-minute averages and for continuous monitoring systems other than opacity to 1-hour averages for time periods as defined in 40 CFR 60.2. Six-minute opacity averages shall be calculated from 36 or more data points equally spaced over each 6-minute period. For continuous monitoring systems other than opacity, 1-hour averages shall be computed from four or more data points equally spaced over each 1-hour period. Data recorded during periods of continuous monitoring system breakdowns, repairs, calibration checks, and zero and span adjustments shall not be included in the data averages computed under this paragraph. An arithmetic or integrated average of all data may be used. The data may be recorded in reduced or non reduced form (e.g., ppm pollutant and percent O<sub>2</sub> or ng/J of pollutant). All excess emissions shall be converted into units of the standard using the applicable conversion procedures specified in subparts. After conversion into units of the standard, the data may be



rounded to the same number of significant digits as used in the applicable subparts to specify the emission limit (e.g., rounded to the nearest 1 percent opacity).  
[40 CFR 60.13(h)]

### Subsection C. Combustion Turbines

**This section addresses the following Regulated Emissions Units:**

<u>E.U. ID No.</u>	<u>Brief Description</u>
-007	Combustion Turbine No. 1
-005	Combustion Turbine No. 2
-006	Combustion Turbine No. 3

#### Descriptions

Combustion Turbine No. 1 is a self-contained combustion turbine generating unit. The unit is a predesigned integrated simple-cycle, single-shaft, three-bearing machine with the load connected at the exhaust end of the unit. The turbine is fired on No. 2 distillate fuel oil and operated for intermittent peaking and emergency services only. The generator nameplate capacity is 18 MW. Unit No. 1 began commercial operation in 1969.

Combustion Turbine No. 2 is a self-contained Westinghouse combustion turbine generating unit. The unit is a predesigned integrated simple-cycle, single-shaft, three-bearing machine with the load connected at the exhaust end of the unit. The turbine is fired on No. 2 distillate fuel oil and operated for intermittent peaking and emergency services only. The generator nameplate capacity is 78 MW. Unit No. 2 began commercial operation in 1974.

Combustion Turbine No. 3 is a self-contained Westinghouse combustion turbine generating unit. The unit is a predesigned integrated simple-cycle, single-shaft, multi-bearing machine with the load connected at the exhaust end of the unit. The turbine is fired on No. 2 distillate fuel oil and operated for intermittent peaking and emergency services only. The generator nameplate capacity is 78 MW. Unit No. 3 began commercial operation in 1974.

{Permitting note: These are pre-NSPS combustion turbines.}

**The following conditions apply to the Emissions Units listed above:**

#### Essential Potential to Emit (PTE) Parameters

C.1. Methods of Operation - Fuels. The combustion turbines shall be fired on No. 2 distillate fuel oil and operated for intermittent peaking and emergency services only.  
[Rule 62-4.160(2), F.A.C., Construction application request]

C.2. Hours of Operation. Operation of each gas turbine shall not exceed 3650 hours of operation during any consecutive 12 months. [Design; Rule 62-210.200, F.A.C. (Definitions - PTE), Permit No. 057-0039-006-AC]

C.3. Inlet Fogger Operation: Combined operation of the inlet air foggers for both gas turbines CT-2 and CT-3 shall not exceed 1365 total hours during any consecutive 12 months. [Design; Rule 62-212.400, F.A.C. (BACT); Rule 62-210.200, F.A.C. (Definitions - PTE), Permit No. 057-0039-006-AC]

C.4. Plant Operation - Problems: If temporarily unable to comply with any of the conditions of this permit due to breakdown of equipment or destruction by fire, wind or other cause, the owner or operator

shall notify the Compliance Authority by phone, FAX, or letter as soon as possible, but at least within one working day, excluding weekends and holidays. The notification shall include pertinent information as to the cause of the problem, the steps being taken to correct the problem and prevent future recurrence, and the owner's intent toward reconstruction of destroyed facilities. Such notification does not release the permittee from any liability for failure to comply with the conditions of this permit and the regulations. [Rule 62-4.130, F.A.C., Permit No. 057-0039-006-AC]

#### Emission Limitations and Standards

C.5. Visible emissions from each combustion turbine shall not be equal to or greater than 20 percent opacity.

[Rule 62-296.320(4)(b)1., F.A.C.]

C.6. During each federal fiscal year (October 1 - September 30) the Tampa Electric Company shall have formal compliance tests conducted on each combustion turbine for opacity. Any combustion turbine that does not operate for more than 400 hours per year shall conduct a visible emissions compliance test once per each five-year period, coinciding with the term of its air operation permit.

[Rule 62-296.712, Rule 62-297.310(7)(a)4.a., , and Rule 62-297.310(7)(a)8., F.A.C.]

C.7. The test methods for visible emissions shall be EPA Method 9, incorporated and adopted by reference in Chapter 62-297, F.A.C. Test procedures shall meet all applicable requirements of Chapter 62-297, F.A.C.

#### Recordkeeping and Reporting Requirements

C.8. If TEC chooses to conduct a visible emissions compliance test only once per five-year period, per Rule 62-297.310(7)(a)8., daily recordkeeping of the hours of operation is required to show that the 400-hour annual limit is not exceeded each year during the five-year period.

[Rule 62-297.310(7)(a)8., and Rule 62-4.070(3), F.A.C.]

C.9. Documentation of the type, quantity, and analysis of the fuel oil used/received is required. Records shall be kept for five years.

[Rules 62-4.070(3) and 62-213.440(1), F.A.C.]

C.10. The average daily and total annual hours of operation for each combustion turbine shall be submitted in an annual operation report. In addition, for each combustion turbine, annual emissions reporting requirements, apply to emissions of each pollutant that a turbine emits in the following quantities:

- (1) for PM<sub>10</sub>, sulfur oxides, VOC, and nitrogen oxides - 25 tons per year or more,
- (2) for carbon monoxide - 250 tons per year or more,
- (3) for lead or lead compounds, measured as elemental lead - 5 tons per year or more.

[62-210.370(3), F.A.C., 40 CFR 51.322(b)]

Tampa Electric will evaluate emissions from the turbines through the use of AP-42 emission factors or another equivalent method such as fuel analysis. [USEPA objection resolution.]

Compliance Demonstrations

C.11. Records: All measurements, records, and other data required by this permit shall be documented in a permanent, legible format and retained for at least five (5) years following the date on which such measurements, records, or data are recorded. Records shall be made available to DEP representatives upon request. [Rules 62-4.160(14) and 62-213.440(1)(b)2., F.A.C.]

C.12. Monthly Operations Summary: By the fifth calendar day of each month, the permittee shall record the following information in a written log for the previous month of operation and for the previous 12 months of operation: the number of operational hours for each gas turbine; the number of hours of inlet air fogging for each gas turbine; and the total combined number of hours of inlet air fogging for both gas turbines. The Monthly Operations Summary shall be maintained on site in a legible format available for inspection at the Department's request. [Rule 62-4.160(15), F.A.C.]

### Subsection D. Flyash Handling and Storage

This section addresses the following Regulated Emissions Units:

<u>E.U. ID No.</u>	<u>Brief Description</u>
-008	Fly Ash Silo No. 1 Baghouse
-018	Fly Ash Silo No. 1 Truck Loadout
-009	Fly Ash Silo No. 2 Baghouse
-019	Fly Ash Silo No. 2 Truck Loadout
-026	Fly Ash Handling and Storage Fugitive Emissions (all except silos)

#### Descriptions

Fly Ash Silo No. 1 handles fly ash from Steam Generator Units No. 1 and No. 2. Fly ash is pneumatically conveyed from the individual electrostatic precipitators to Silo No. 1. Also, the fly ash may be pneumatically conveyed from tanker trucks to and/or from Silo No. 12 and to Silo No. 21, and between Silo No. 1 and Silo No. 2. The sum total loading rate to the silo for all the processes combined is 44.5 tons per hour. Fly ash from Silo No. 1 is discharged in either a wet or dry state. The dry fly ash is gravity fed by tubing into totally enclosed tanker trucks. The wet fly ash is processed through a pugmill and then unloaded into a dump truck. Particulate matter emissions generated by silo loading and silo unloading to a tanker truck are controlled by a 20,081 DSCFM Flex Kleen Model No. 84 UDTR-640 baghouse in addition to reasonable precautions. All fly ash handled is generated on-site.

Fly Ash Silo No. 2 handles fly ash from Steam Generator Units Nos. 1, 2, and/or 3. Fly ash is pneumatically conveyed in a series of pipes from the individual unit precipitators (Units 1, 2, and/or 3, only two units at any time) to the silo for temporary storage. From the silo, the fly ash is gravity fed by tubing into closed tanker trucks and transported to an off-site consumer. Particulate emissions generated during silo loading operation and from the tanker truck loadout chutes are controlled by a 20,081 DSCFM Flex Kleen, Model No. 84 UDTR-640 baghouse in addition to reasonable precautions.

TEC Rationale for Revision: Administrative corrections.

**The following conditions apply to the Emissions Units listed above:**

#### Essential Potential to Emit (PTE) Parameters

D.1. Capacity. The maximum permitted loading rate for all Fly Ash Silo No. 1 processes combined is 44.5 tons per hour. The maximum permitted loading rate for all Fly Ash Silo No. 2 processes combined is 44.5 tons per hour. ~~For Fly Ash Silo No. 2, the maximum permitted loading rate is the simultaneous maximum transfer of flyash from boiler Units 1, 2, and 3.~~ Separate testing of emissions from each unit shall be conducted with each emissions unit operation at 90 to 100 percent of the maximum permitted heat input rate capacity. If it is impractical to test at permitted capacity, an emissions unit may be tested at less than the minimum permitted capacity; in this case, subsequent emissions unit operation is limited to 110 percent of the test load capacity until a new test is conducted. Once the unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purpose of additional compliance testing to regain the authority to operate at the permitted capacity. [AC29-194516; AO29-161082; Rule 62-4.160(2), and Rule 62-297.310(2), F.A.C.]

**{Permitting note: The material loading limitations have been placed in each permit to identify the capacity of each emissions unit for the purposes of confirming that emissions testing is conducted within 90 to 100 percent of the emissions unit's rated capacity (or to limit future operation to 110 percent of the test load), to establish appropriate emission limits and to aid in determining future rule applicability. Regular recordkeeping is not required for material loading. Instead the owner or operator is expected to determine material loading whenever the emission testing is required, to demonstrate at what percentage of the rated capacity that the emissions unit was tested. Rule 62-297.310(5), F.A.C., included in the permit, requires measurement of process variables for emission tests. Material loading demonstrations may be based on best engineering evaluation of the operating requirements necessary to achieve 90 to 100 percent of the rated loading, unless such operating conditions are otherwise specified by permit condition.}**

**TEC Rationale for Revision: Provides clarification of maximum loading rate for Fly Ash Silo No. 2 consistent with the permit language used for Fly Ash Silo No. 1.**

D.2. Hours of Operation. Fly Ash Silos No. 1 and No. 2 are each allowed to operate continuously, i.e., 8760 hours/year.  
[Rule 62-210.200, F.A.C., Definitions (PTE)]

#### Emission Limitations and Standards

D.3. Visible emissions from each silo baghouse shall not be equal to or greater than 20 percent opacity. Visible emissions from each silo truck loadout shall not be equal to or greater than 20 percent opacity.  
[Rule 62-296.320(4)(b)1., F.A.C.]

D.4. Visible emissions from the flyash handling system and flyash silos are limited to 5% opacity.  
[Power Plant Siting Certification PA 79-12]

D.5. Total maximum allowable emissions of particulate matter from the each silo baghouse shall not exceed 0.03 grains/DSCF, 5.16 lbs./hr. and 22.62 tons/yr. based on a design flow rate of 20,081 DSCFM. The requirement of formal particulate matter compliance testing as provided in specific condition D.6. shall be waived if the baghouse meets the alternative standard of 5% opacity. If the Department or the Environmental Protection Commission of Hillsborough County has reason to believe that the particulate weight emission standard is not being met, the agency shall require that compliance be demonstrated by EPA Method 17 specified in Rule 62-297, F.A.C.  
[Rule 62-4.160(2) and Rule 62-297.620(4), F.A.C.; AO29-160255; AO29-161082]

#### Test Methods and Procedures

D.6. During each federal fiscal year (October 1 - September 30), unless otherwise specified by rule, order, or permit, the Tampa Electric Company shall have formal compliance tests conducted on each silo baghouse for opacity and particulate matter and formal compliance test conducted on each silo truck loadout for opacity.  
[Rule 62-297.310(7)(a)4., F.A.C.]

D.7. The test method for particulate emissions shall be EPA Method 17, with an acetone wash and an average stack temperature below 275 degrees Fahrenheit, or EPA Method 5 with an acetone wash. These

test methods are incorporated and adopted by reference in Chapter 62-297, F.A.C. Test procedures shall meet all applicable requirements of Chapter 62-297, F.A.C.  
[Rules 62-296.320(4)(a)3.a.(ii) and 62-296.320(4)(a)3.c., F.A.C.]

D.8. The test methods for visible emissions shall be EPA Method 9, incorporated and adopted by reference in Chapter 62-297, F.A.C. Test procedures shall meet all applicable requirements of Chapter 62-297, F.A.C.  
[Rule 62-296.320(4)(b)4., F.A.C.]

D.9. All reasonable precautions shall be taken to prevent and control generation of unconfined emissions of particulate matter in accordance with the provisions in Rule 62-296.320(4), F.A.C. These provisions are applicable to any source, including, but not limited to, vehicular movement, transportation of materials, construction, alterations, demolition or wrecking, or industrial related activities such as loading, unloading, storing and handling. The following reasonable precaution shall be taken to control unconfined particulate matter emissions associated with the fly ash silo/truck operations. Reasonable precautions shall include, but not limited to:

- A) Fly ash transported by dump truck shall be adequately wetted and processed through the pugmill.
- B) Dump trucks used to transport fly ash shall utilize tarps at all times except when loading/unloading.
- C) Fly ash transported in a dry state shall be accomplished utilizing an enclosed tanker truck.
- D) Fly ash spilled and/or leaked on plant grounds shall be adequately wetted and disposed of daily.
- E) Fly ash collected from spills and/or leaks must be adequately wetted at all times.
- F) Ensure the proper seating of the unloader chute onto the tanker inlet prior to loading.
- G) Keep the dust extractor operational during loading.
- H) Close the tanker's inlet as soon as practical after the loading process.
- I) Extend the tubing from the silo into the closed tanker type trucks during loadout.
- J) Periodic watering of plant roads.

[Rule 62-296.320(4)(c)2., F.A.C., AO29-160255, and precautions specified in initial Title V application.]

D.10. Compliance testing for the silo and tanker truck loading operations shall be conducted under the following conditions:

- a. All conveyance hoppers will be operational during the test.
- b. All fly ash will be directed to the silo, no reinjection of fly ash to the boiler systems will occur during the test.
- c. The boilers shall operate at the maximum capability of this unit under normal operating conditions during the test.
- d. Two tanker trucks shall be loaded during the test. The loading valve shall be completely open during filling.
- e. The visible emission test shall be at least 30 minutes in duration and the period of time during which truck loading occurred indicated on the test report.

[Rule 62-4.070(3), F.A.C.].

**TEC Rationale for Revision: Administrative correction.**

D.11. Compliance with the emission limitations of Specific Conditions Nos. 3 and 4 shall be determined using EPA Methods 1, 2, 4, 5 and 9 contained in 40 CFR 60, Appendix A and adopted by reference in Rule 62-297.401, F.A.C. The Method 9 observation period for the silo and tanker truck loading operations shall be at least thirty (30) minutes in duration. The

minimum requirements for stack sampling facilities, source sampling and reporting, shall be in accordance with Rule 62-297, F.A.C. and 40 CFR 60, Appendix A.  
[Rule 62-297, F.A.C.]

D.12. All compliance tests shall be conducted while loading the silo at approximately the maximum feed rate (24 hour average). Failure to submit the feed rate or operating at conditions during testing which do not reflect normal operating conditions may invalidate the data.  
[Rule 62-4.070(3), F.A.C.].



**Subsection E. Flyash Silo No. 3**

**This section addresses the following Regulated Emissions Units:**

<u>E.U. ID No.</u>	<u>Brief Description</u>
-014	Fly Ash Silo No. 3 Baghouse
-027	Fly Ash Silo No. 3 Truck Loadout
-028	Fly Ash Handling System Fugitive Emissions

Description

Fly Ash Silo No. 3 handles fly ash from Steam Generator Unit No. 4. Also, fly ash may be pneumatically conveyed from tanker trucks to Silo No. 3. Particulate matter emissions are controlled by a 1,200 DSCFM Flex Kleen Model 84-WRTC-80-II-G baghouse. The flyash may be processed through a pugmill and then unloaded into a dump truck.

**TEC Rationale for Revision: Administrative correction.**

**The following conditions apply to the Emissions Unit listed above:**

Essential Potential to Emit (PTE) Parameters

E.1. Particulate matter emissions from the flyash handling system and flyash silo shall not exceed 0.2 lb/hr.

[Power Plant Siting Certification PA 79-12; PSD-FL-040]

E.2. Visible emissions from the flyash handling system and the flyash silo are limited to 5% opacity.

[Power Plant Siting Certification PA 79-12]

E.3. The flyash handling system (including transfer and silo storage) will be maintained at negative pressures and vented to a control system.

[PSD-FL-040]

E.4. Tampa Electric will perform an annual VE test to satisfy the periodic monitoring requirements of these conditions. In addition, the system pressure will be monitored quarterly to assess that the system is operating under negative pressure.

[USEPA objection resolution.]

### **Subsection F. Limestone Handling and Storage**

**This section addresses the following Regulated Emissions Units:**

<u>E.U. ID No.</u>	<u>Brief Description</u>
-011	Truck/Railcar Limestone Unloading Receiving Hopper with baghouse
-012	Limestone Silo A with 2 baghouses
-013	Limestone Silo B with 2 baghouses
-023	Limestone Handling Conveyor LB to Conveyor LC with baghouse, Limestone Handling Conveyor LD to Conveyor LE with baghouse
-024	Limestone Handling Conveyor LE to South Storage Silo with baghouse, Limestone Handling Conveyor LE to North Storage Silo with baghouse
-025	Limestone Storage and Handling Fugitive Emissions

**TEC Rationale for Revision:** Visible emissions occurring during the unloading of moist limestone without the use of a baghouse are five percent opacity, or less. Accordingly, a baghouse is not necessary to comply with permit opacity limits. The emission units addressed by Emission Unit ID No. 024 are also addressed by Emission Unit ID 020. Accordingly, deletion of duplicate Emission Unit ID No. 024 is requested.

#### Descriptions

~~Particulate matter emissions from the truck and railcar unloading of limestone are controlled by a Mikro-Pulsaire Model 400S12TR baghouse. Particulate matter emissions generated by the transfer of limestone from Handling Conveyor LB to Conveyor LC are controlled by a Sternvent Model DKED18003 baghouse. Particulate matter emissions generated by the transfer of limestone from Handling Conveyor LD to Conveyor LE are controlled by a Sternvent Model DKED 18003 baghouse. Particulate matter emissions generated by the transfer of limestone from Handling Conveyor LE to the South Storage Silo are controlled by a Flex Kleen Model 58-BVBC-36-HG baghouse. Particulate matter emissions generated by the transfer of limestone from Handling Conveyor LE to the North Storage Silo are controlled by a Flex Kleen Model 58-BVBC-36-HG baghouse.~~

**TEC Rationale for Revision:** Visible emissions occurring during the unloading of moist limestone without the use of a baghouse are five percent opacity, or less. Accordingly, a baghouse is not necessary to comply with permit opacity limits. Handling Conveyor LE activities are also addressed by Emission Unit ID No. 020.

**The following conditions apply to the Emissions Units listed above:**

#### Essential Potential to Emit (PTE) Parameters

F.1. Total combined particulate matter emissions from the limestone handling hoppers/conveyors shall not exceed 0.65 lb/hr. Visible emissions are limited to 5% opacity. Compliance testing for particulate matter emissions is not required provided the opacity limit is maintained.  
[PSD-FL-040; Power Plant Siting Certification PA 79-12]

**TEC Rationale for Revision:** Administrative correction.

F.2. Total combined particulate matter emissions from the limestone silos shall not exceed 0.05 lb/hr. Visible emissions are limited to 5% opacity. Compliance testing for particulate matter emissions is not required provided the opacity limit is maintained.

[PSD-FL-040; Power Plant Siting Certification PA 79-12]

F.3. All conveyors and conveyor transfer points shall be enclosed to preclude particulate matter emissions.

[PSD-FL-040]

F.4. The limestone handling ~~receiving hopper~~, conveyor transfer points and silos shall be maintained at negative pressures with the exhaust vented to a control system(s).

[PSD-FL-040]

**TEC Rationale for Revision: Visible emissions occurring during the unloading of moist limestone without the use of a baghouse are five percent opacity, or less. Accordingly, a baghouse is not necessary to comply with meet permit opacity limits.**

F.5. Tampa Electric will perform an annual VE test to satisfy the periodic monitoring requirements of these conditions. In addition, the system pressure will be monitored quarterly to assess that the system is operating under negative pressure.

[USEPA objection resolution.]

**Subsection G. Coal Bunkers with Roto-Clones**

**This section addresses the following Regulated Emissions Units:**

<u>E.U. ID No.</u>	<u>Brief Description</u>
-015	Unit No. 1 Coal Bunker with Roto-Clone
-016	Unit No. 2 Coal Bunker with Roto-Clone
-017	Unit No. 3 Coal Bunker with Roto-Clone
-037	Unit No. 4 Coal Bunker with Roto-Clone

Descriptions

These emission units are Steam Generator Units Nos. 1-3-4 Coal Bunkers with an exhaust fan/cyclone collector (Roto-Clone controlling dust emission from each unit's respective bunker. Two moving transfer stations via their respective conveyor belts route coal through enclosed chutes to the various bunkers. Coal Bunkers 1-3-4 are each equipped with a 9400 ACFM American Air Filter (AAF) Company Type D Roto-Clone to abate dust emissions during ventilation. A number of vent pipes convey fresh air from each bunker to a Roto-Clone during particulate matter removal. Particulate matter removed by the Roto-Clones is returned to the coal bunkers via a hopper and return line. Unit No. 1 Coal Bunker is situated west of Unit No. 2 Coal Bunker. Unit No. 3 Coal Bunker is situated east of Unit No. 2 Coal Bunker. Unit No. 4 Coal Bunker is located east of Unit No. 3.

**TEC Rationale for Revision: For consistency with Units 1-3, addition of an Emission Unit ID for Unit No. 4 Coal Bunker (now addressed by Emission Unit ID No. 031) is requested.**

**The following conditions apply to the Emissions Units listed above:**

Essential Potential to Emit (PTE) Parameters

G.1. Capacity. The annual coal throughput shall not exceed 4,000 TPH per bunker.  
[Rule 62-4.160(2), F.A.C.]

G.2. Hours of Operation. To show compliance with the annual allowable emission rate, the hours of bunker loading operation shall not exceed 4,167 hours per year.  
[Rule 62-210.200, F.A.C., Definitions (PTE)]

**TEC Rationale for Revision: Administrative correction.**

Emission Limitations and Standards

G.3. Visible emissions from each unit shall not be equal to or greater than 20% opacity. The test method for visible emissions shall be EPA Method 9, incorporated and adopted by reference in Chapter 62-297, F.A.C.  
[Rule 62-296.320(4)(b)1. and 4., F.A.C.]

G.4. Since a source of less than 1 TPY is exempt from particulate matter RACT provisions, the maximum allowable particulate emissions shall not exceed 0.99 tons per year from each

~~eyelone~~erotoclone exhaust. Also maximum allowable particulate matter emissions shall not exceed 0.48 lbs/hr from each cyclone exhaust.  
[AO29-163788 to escape RACT]

**TEC Rationale for Revision: Administrative correction.**

G.5. The maximum allowable emission rate for particulate matter for this source is set by specific condition no. G.4. Because of the expense and complexity of conducting a stack test on minor sources of particulate matter, the Department hereby waives the requirement for a stack test. The alternative standard establishes a visible emission limitation not to exceed an opacity of 5%. Compliance with this alternate emission limitation shall be determined using DEP Method 9 contained in 62-297.401, F.A.C.  
[AO29-163788]

G.6. Should the Department have reason to believe the particulate matter emission standard is not being met, the Department may require that compliance with the particulate emission standards be demonstrated by testing using EPA Methods 1, 2, 4 and 5 in accordance with 62-297.401, F.A.C.  
[Rule 62-297.310(7)(b), F.A.C.]

G.7. Tampa Electric will monitor the hours of operation of coal bunker loading. In addition, Tampa Electric will perform an annual VE test to satisfy the periodic monitoring requirements of this condition.  
[USEPA objection resolution.]

### Subsection H. Solid Fuel Yard

**This section addresses the following Regulated Emissions Units:**

<u>E.U. ID No.</u>	<u>Brief Description</u>
-010	Solid Fuel Yard, Fugitive Emissions
-029	Cyclone collectors for fuel blending bins (FH-032 through FH-035)
-030	Cyclone collectors for fuel crushers (FH-048 and FH-049)
-031	Cyclone collectors for bunkers (FH-059 through FH-062)

**TEC Rationale for Revision: The emission units addressed by Emission Unit ID No. 031 are also addressed by Emission Unit IDs 015, 016, 017, and 037. Accordingly, deletion of duplicate Emission Unit ID No. 031 is requested.**

#### Descriptions

Solid fuel is unloaded from ship/barge into the Solid fuel yard, the blending bins or directly to the tripper room via belt conveyors. Solid fuel from the piles is loaded onto belt conveyors using a rail mounted or mobile reclaimer. The solid fuel is then belt conveyed to the blending tower bins, which consists of six storage bins, where the solid fuel is may be blended for use at the plant, or transloaded into trucks for shipment off site. ~~From the solid fuel yard conveyors, the solid fuel is screw conveyed into the bins.~~ Particulate matter (PM) emissions from the conveyors in the solid fuel yard blending bins are controlled by 3 4 rotoclones, one at the conveyor drop and one for every 2 bins. ~~PM emissions from the screw conveyor are controlled by the fourth rotoclone.~~ Storage bins can either Each has 2 hoppers, which feed the transloader, or can be conveyed, via 2 parallel belts (T1, T2) to 2 crushers (each belt has a crusher), or diverted directly to the tripper room. PM emissions from the 2 crushers and transfer tower are controlled by 2 rotoclones.

~~From the solid fuel yard tripper room, the solid fuel is conveyed to the tripper room where 2 trippers bunker the solid fuels into 4 solid fuel bunkers. Each unit has its own respective bunker. Solid fuel samples are taken every 15 minutes during bunkering, and composited for analysis. From the bunkers, the solid fuel is gravity fed into 14 crushers mills, and then gravity-fed into the boilers. There are 3 tall crushers ball mills, each for Unit Nos. 1 – 3, and 5 bowl crushers mills for Unit No. 4. From the crushers mills, the solid fuel is pneumatically fed into classifiers, two for each crusher mill on Unit Nos. 1-3 and one for each mill on Unit No. 4 for a total of 283 classifiers, and then into the respective boilers.~~

**TEC Rationale for Revision: Administrative corrections.**

**The following conditions apply to the Emissions Units listed above:**

H.1. TEC shall maintain a daily log of the amounts and types of fuels used and copies of fuel analyses containing information on sulfur content, ash content and heating values.  
[Power Plant Siting Certification PA 79-12]

H.2. Particulate matter emissions from the solid fuel handling facilities:

(a) Pursuant to Chapter 1-3.62 Rules of the Environmental Protection Commission of Hillsborough County, visible emission shall not exceed 20% opacity for any unconfined emission unit in the fuel yard. Unconfined emissions as defined by Rule 62-296.200, F.A.C., shall include the static fuel

piles, etc. Pursuant to Rule 62.296.711(2), F.A.C., visible emissions shall not exceed 5 percent opacity for the remaining emission units in the fuel yard. Visible emissions compliance tests shall be demonstrated using EPA Reference Method 9, 40 CFR Part 60, Appendix A, Visual Determination of Fugitive Emissions from Material Sources (July 1, 1993 version). All testing shall be done within 90 days of completing reconfiguration of the fuel yard, and prior notification of testing shall be submitted in writing at least 15 days beforehand to the EPC of Hillsborough County. Particulate emissions shall be controlled by use of control devices. Tampa Electric will perform an annual VE test to demonstrate compliance with the opacity standard established for the solid fuel yard.

(b) The permittee must submit to the Department within ten (10) working days after it becomes available, copies of technical data pertaining to the selected particulate emissions control for the coal handling facility. These data should include, but not be limited to, guaranteed efficiency and emission rates, and major design parameters such as air/cloth ratio and flow rate. The Department may, upon review of these data, disapprove the use of such device if the Department determines the selected control device to be inadequate to meet the emission limits specified in condition (a) above. Such disapproval shall be issued within 30 days of receipt of the technical data.

(c) The fuel pile operations are subject to Rule 62-296.310(3), F.A.C., Unconfined Emissions of Particulate Matter. Reasonable precautions to minimize unconfined particulate matter shall be in accordance with Rule 62-296.310(3)(c), F.A.C., and, may include, but shall not be limited to, the coating of roads and construction sites used by contractors and regrassing or watering areas of disturbed fuel.

(d) From each fuel transloading source/emissions point (i.e., off-loading and loading of fuel {for export from Big Bend Station}), the maximum hourly transloading transfer of fuel shall not exceed 4,000 tons, 24-hour rolling average.

(e) From each fuel transloading source/emissions point, (i.e., off-loading and loading of fuel {for export from Big Bend Station}), the maximum annual transloading transfer of fuel shall not exceed 1,428,030 tons.

(f) The number of railcars and trucks and the quantity of fuel loaded by each fuel transloading source/emissions point (i.e., off-loading and loading of fuel {for export from Big Bend Station\*}) shall be recorded, maintained, and kept on file for a minimum of five years. The annual quantity of fuel loaded by each fuel transloading source/emissions point shall be submitted in the Annual Operation Report.

[Power Plant Siting Certification PA 79-12]

\*Permitting Note.

H.3. All conveyors and conveyor transfer points shall be enclosed to preclude particulate matter emissions excepting the coal handling stacker reclaimer, the tail end conveyor feeding the tripper and the barge unloading belt which are exempted for feasibility considerations.

[PSD-FL-040]

H.4. Coal storage piles shall be shaped, compacted and oriented to minimize wind erosion.

[PSD-FL-040]

H.5. Water sprays for storage piles, handling equipment, etc., including the handling equipment exempted from the conveyor enclosure requirement, shall be applied during dry periods and as necessary to all facilities to maintain opacity below 20 percent.

[Rules 62-4.160(2) and 62-296.320(4)(c), F.A.C.]

### **Subsection I. Surface Coating of Miscellaneous Metal Parts**

**This section addresses the following Regulated Emissions Units:**

-032 Surface coating of miscellaneous metal parts

#### Description

These conditions apply to the surface coating of miscellaneous metal parts as defined in Rule 62-296.513, F.A.C. These parts include such things as pumps, compressors, conveyor components, fans, blowers, transformers.

**The following conditions apply to the Emissions Unit listed above:**

I.1. Hours of Operation. Miscellaneous metal parts surface coating operations are allowed to operate for a total 3500 hours/year.

[Rule 62-210.200, F.A.C., Definitions (PTE)]

I.2. Capacity. The total maximum coating usage shall not exceed 2 gallons per hour, on a 24-hr basis, and 7000 gallons per year.

[Rule 62-210.200, F.A.C., Definitions (PTE)]

I.3. Recordkeeping. TEC shall maintain daily records of operations for the most recent 5 year period. The records shall be made available to the local, state, or federal air pollution agency upon request. The records shall include, but not be limited to, the following:

- a. The rule number applicable to the operation for which the records are being maintained.
- b. The application method and substrate type (metal, etc.).
- c. The amount and type of adhesive, coatings (including catalyst and reducer for multicomponent coatings), solvent, and/or graphic arts material used at each point of application, including exempt compounds.
- d. The VOC content as applied in each adhesive, coating, solvent, and/or graphic arts material.
- e. The date for each application of each adhesive, coating, solvent, and/or graphic arts material.
- f. The amount of surface preparation, clean-up, wash-up of solvent (including exempt compounds) used and the VOC content of each.

[Rule 62-296.500(2)(b)1., F.A.C.]

I.4. The VOC content shall be calculated using a percent solids basis (less water and exempt solvents) for adhesives, coating, and inks, using EPA Reference Method 24.

[Rule 62-296.500(2)(b)2., F.A.C.]

I.5. Reporting. Annually, in accordance with a schedule and reporting format provided by the Department or EPCHC, TEC shall provide EPCHC with proof of compliance with the limitations in this section.

[Rule 62-296.500(2)(c), F.A.C.]



**The following conditions apply to the Emissions Unit listed above if the Emissions Unit emits more than 15 pounds of VOC in any one day and 3 pounds VOC in any one hour:**

**I.6. Emissions Limits for surface coating of miscellaneous metal parts.**

(a) No owner or operator of a coating line for miscellaneous metal parts and products shall cause, allow, or permit the discharge into the atmosphere of any volatile organic compounds in excess of:

(1) 4.3 pounds per gallon of coating (0.52 kilograms per liter), excluding water, delivered to a coating applicator that applies clear coatings;

(2) 3.5 pounds per gallon of coating (0.42 kilograms per liter), excluding water, delivered to a coating applicator in coating application system that is air dried or forced warm air dried at temperatures up to 194 degrees Fahrenheit (90 degrees Celsius);

(3) 3.5 pounds per gallon of coating (0.42 kilograms per liter), excluding water, delivered to a coating applicator that applies extreme performance coatings; or,

(4) 3.0 pounds per gallon of coating (0.36 kilograms per liter), excluding water, delivered to a coating applicator for all other coatings and coating application systems.

(b) If more than one emission limitation in condition I.56.(a) above applies to a specific coating, then the least stringent emission limitation shall be applied.

(c) All volatile organic compound emissions from solvent washings shall be considered in the emission limitations in condition I.6.(a) above unless the solvent is directed into containers that prevent evaporation into the atmosphere.

[Rule 62-296.513(2), F.A.C.]

**TEC Rationale for Revision: Administrative correction.**

**I.7. Control Technology.** The emission limits in condition I.6.(a) above shall be achieved by:  
The application of low solvent coating technology.

[Rule 62-296.513(3), F.A.C.]

**I.8. Test Methods and Procedures to Determine Low Solvent Technology.** The test method for volatile organic compounds shall be EPA Method 24 or EPA 450/3-84-019, incorporated and adopted by reference in Chapter 62-297, F.A.C. Test procedures shall meet all applicable requirements of Chapter 62-297, F.A.C.]

[Rules 62-296.513(4)(a) and (c), F.A.C.]

### **Subsection J. Abrasive Blasting**

**This section addresses the following Regulated Emissions Units:**

- 033 Abrasive Blast Booth with baghouse
- 034 Abrasive Blast Media Storage with baghouse

Description

The abrasive blast booth is used to prepare miscellaneous metal parts for surface coating. Particulate matter emissions from the abrasive blast booth are controlled by a Torit Model No. DFT 4-16 pulse jet baghouse with an inlet flow rate of 7,500 acfm. Particulate emissions from the abrasive blast media storage are controlled by a pulse jet baghouse with an inlet air flow rate of 800 dscfm.

**The following conditions apply to the Emissions Units listed above:**

J.1. Capacity. The maximum annual usage of abrasive blast media in the abrasive blast booth shall not exceed 300 tons per year.

[Rules 62-4.160(2), 62-210.200(PTE)]

J.2. Hours of Operation. These emissions units are each allowed to operate continuously, i.e., 8760 hours/year.

[Rule 62-210.200, F.A.C., Definitions (PTE)]

J.3. Emission Limitations. The particulate matter emissions from each baghouse shall not exceed 0.03 gr/dscf, or any visible emissions greater than 5% opacity. However, TEC may exceed these emission limits if a pollution control device for particulate matter is utilized that has an actual particulate matter collection efficiency of at least 98 percent. The opacity standard for the emissions units shall be the average opacity level achieved during the initial compliance test which established compliance with the standard, plus 5% opacity.

[Rules 62-296.712(2), F.A.C.]

J.4. Test Methods and Procedures.

(a) The test method for visible emissions shall be EPA Method 9, incorporated and adopted by reference by reference in Chapter 62-297, F.A.C.

(b) The test method for particulate matter emissions shall be EPA Method 5, incorporated and adopted by reference in Chapter 62-297, F.A.C. The minimum sample volume shall be 30 dry standard cubic feet.

(c) A visible emissions test indicating no visible emissions (5 percent opacity) may be submitted in lieu of a particular stack test for materials handling emissions subject to this rule, where the emissions unit is equipped with a baghouse.

(d) Test procedures shall meet all applicable requirements of Chapter 62-297, F.A.C.

[Rule 62-296.712(3), F.A.C.]

J.5. Particulate matter emissions from the abrasive blasting operations shall not exceed 15 tons for any 12 consecutive month period.

[Rule 62-212.300, F.A.C.]

J.6. No used or waste oils shall be burned in the diesel compressors. The observation point for the blasting operation tests shall be at the point of maximum opacity leaving the enclosure.  
[Rule 62-070(3), F.A.C.]

J.7. TEC shall maintain monthly records on the type and amount of abrasive blasting material used . A rolling 12-month total shall be kept as well.  
[Rule 62-070(3), F.A.C.]

J.8. During each month that the Abrasive Blast Booth is used, a VE test must be performed. A monthly VE test is not required during any month that the Abrasive Blast Booth is not used. During each month that abrasive blast media is transferred to or from Abrasive Blast Media Storage, a VE test must be performed. A monthly VE test is not required during any month that no abrasive blast media is transferred to or from Abrasive Blast Media Storage. However, at a minimum, an annual VE test must be performed.

[USEPA objection resolution.]

### **Subsection K. Surface Coating of Ships**

**This section addresses the following Regulated Emissions Units:**

-035 Surface coating of ships

Description

Surface coating maintenance of ships.

**The following conditions apply to the Emissions Units listed above:**

K.1. The emissions unit must comply with the attached 40 CFR 63 Subpart A – General Provisions modified for Subpart II.

[40 CFR 63 Subpart A, Rule 62-204.800, F.A.C.]

K.2. This emissions unit must also comply with the following:

#### **40 CFR 63 Subpart II – National Emission Standards for Shipbuilding and Ship Repair (Surface Coating)**

{Source: 40 CFR 63 Subpart II (7/1/96 version), and Fed. Register revision dated 12/17/96}

63.781 Applicability

63.782 Definitions

63.783 Standards.

63.784 Compliance dates.

63.785 Compliance procedures.

63.786 Test methods and procedures.

63.787 Notification requirements.

63.788 Recordkeeping and reporting requirements.}

#### **§ 63.781 Applicability.**

(a) The provisions of this subpart apply to shipbuilding and ship repair operations at any facility that is a major source.

(b) The provisions of this subpart do not apply to coatings used in volumes of less than 200 liters (52.8 gallons) per year, provided the total volume of coating exempt under this paragraph does not exceed 1,000 liters per year (264 gallons per year) at any facility. Coatings exempt under this paragraph shall be clearly labeled as “low-usage exempt,” and the volume of each such coating applied shall be maintained in the facility’s records.

(c) The provisions of this subpart do not apply to coatings applied with hand-held, nonrefillable, aerosol containers or to unsaturated polyester resin (i.e., fiberglass lay-up) coatings. Coatings applied to suitably prepared fiberglass surfaces for protective or decorative purposes are subject to this subpart.

(d) The provisions in subpart A of this part [See specific condition K.1., General Provisions] pertaining to startups, shutdowns, and malfunctions and continuous monitoring do not apply to this source category unless an add-on control system is used to comply with this subpart in accordance with § 63.783(c).

**The following specific conditions from 40 CFR Part 63, Subpart II - Shipbuilding and Ship Repair (Surface Coating) apply:**

**40 CFR 63.783 Standards**

(a) No owner or operator of any existing or new affected source shall cause or allow the application of any coating to a ship with an as-applied VOHAP content exceeding the applicable limit given in Table 2 of this subpart (see attachment), as determined by the procedures described in 40 CFR 63.785(c)(1)-(4). For the compliance procedures described in 40 CFR 63.785(c)(1)-(3), VOC shall be used as a surrogate for VOHAP, and the EPA Reference Method 24 shall be used as the definitive measure for determining compliance. For the compliance procedure described in 40 CFR 63.785(c)(4), an alternative test method capable of measuring independent VOHAP shall be used to determine compliance. The method must be submitted to and approved by the Administrator.

[40 CFR 63.783(a)]

(b) Each owner or operator of a new or existing affected source shall ensure that:

(1) All handling and transfer of VOHAP-containing materials to and from containers, tanks, vats, drums, and piping systems is conducted in a manner that minimizes spills.

(2) All containers, tanks, vats, drums, and piping systems are free of cracks, holes, and other defects and remain closed unless materials are being added to or removed from them.

[40 CFR 63.783(b)]

(c) Approval of alternative means of limiting emissions.

(1) The owner or operator of an affected source may apply to the Permitting authority for permission to use an alternative means (such as an add-on control system) of limiting emissions from coating operations. The application must include:

(i) An engineering material balance evaluation that provides a comparison of the emissions that would be achieved using the alternative means to those that would result from using coatings that comply with the limits in Table 2 of this section, or the results from an emission test that accurately measures the capture efficiency and control device efficiency achieved by the control system and the composition of the associated coatings so that the emissions comparison can be made;

(ii) A proposed monitoring protocol that includes operating parameter values to be monitored for compliance and an explanation of how the operating parameter values will be established through a performance test; and

(iii) Details of appropriate recordkeeping and reporting procedures.

(2) The Permitting authority shall approve the alternative means of limiting emissions if, in the Permitting authority's judgment, postcontrol emissions of VOHAP per volume applied solids will be no greater than those from the use of coatings that comply with the limits in Table 2 of this section.

(3) The Permitting authority may condition approval on operation, maintenance, and monitoring requirements to ensure that emissions from the source are no greater than those that would otherwise result from this subpart. [Rule 62-296.820, F.A.C.; 40 CFR 63.783(c)]

**40 CFR 63.784 Compliance Dates**

(a) Each owner or operator of an existing affected source shall comply by 12/16/97.  
[40 CFR 63.784(a)]

(b) Each owner or operator of an existing unaffected area source that increases its emissions of (or its potential to emit) HAP such that the source becomes a major source that is subject to this subpart shall comply within 1 year after the date of becoming a major source.  
[40 CFR 63.784(b)]

(c) Each owner or operator of a new or reconstructed source shall comply with this subpart according to the schedule in 40 CFR 63.6(b) of subpart A.  
[40 CFR 63.784(c)]

**40 CFR 63.785 Compliance Procedures**

(a) For each batch of coating that is received by an affected source, the owner or operator shall (see Figure 1 for a flow diagram of the compliance procedures):

(1) Determine the coating category and the applicable VOHAP limit as specified in 40 CFR 63.783(a).

(2) Certify the as-supplied VOC content of the batch of coating. The owner or operator may use a certification supplied by the manufacturer for the batch, although the owner or operator retains liability should subsequent testing reveal a violation. If the owner or operator performs the certification testing, only one of the containers in which the batch of coating was received is required to be tested.  
[40 CFR 63.785(a)]

(b) (1) In lieu of testing each batch of coating, as applied, the owner or operator may determine compliance with the VOHAP limits using any combination of the procedures described in paragraphs (c)(1), (c)(2), (c)(3), and (c)(4) of this section. The procedure used for each coating shall be determined and documented prior to application.

(2) The results of any compliance demonstration conducted by the affected source or any regulatory agency using Method 24 shall take precedence over the results using the procedures in paragraphs (c)(1), (c)(2), or (c)(3) of this section.

(3) The results of any compliance demonstration conducted by the affected source or any regulatory agency using an approved test method to determine VOHAP content shall take precedence over the results using the procedures in paragraph (c)(4) of this section.  
[40 CFR 63.785(b)]

(c) (1) Coatings to which thinning solvent will not be added. For coatings to which thinning solvent (or any other material) will not be added under any circumstance or to which only water is added, the owner or operator of an affected source shall comply as follows:

(i) Certify the as-applied VOC content of each batch of coating.

(ii) Notify the persons responsible for applying the coating that no thinning solvent may be added to the coating by affixing a label to each container of coating in the batch or through another means described in the implementation plan required in 40 CFR 63.787(b).

(iii) If the certified as-applied VOC content of each batch of coating used during a calendar month is less than or equal to the applicable VOHAP limit in 40 CFR 63.783(a) (either in terms of g/L of coating or g/L of solids), then compliance is demonstrated for that calendar month, unless a violation is revealed using Method 24.

(2) Coatings to which thinning solvent will be added--coating-by-coating compliance. For a coating to which thinning solvent is routinely or sometimes added, the owner or operator shall comply as follows:

- (i) Prior to the first application of each batch, designate a single thinner for the coating and calculate the maximum allowable thinning ratio (or ratios, if the affected source complies with the cold-weather limits in addition to the other limits specified in Table 2) for each batch as follows:

$$R = \frac{(V_s)(VOHAP\ limit) - m_{VOC}}{D_{th}} \quad \text{Eqn. 1}$$

where:

- R = Maximum allowable thinning ratio for a given batch (L thinner/L coating as supplied);
- $V_s$  = Volume fraction of solids in the batch as supplied (L solids/L coating as supplied);
- VOHAP limit = Maximum allowable as-applied VOHAP content of the coating (g VOHAP/L solids);
- $m_{VOC}$  = VOC content of the batch as supplied [g VOC (including cure volatiles and exempt compounds on the HAP list)/L coating (including water and exempt compounds) as supplied];
- $D_{th}$  = Density of the thinner (g/L).

If  $V_s$  is not supplied directly by the coating manufacturer, the owner or operator shall determine  $V_s$  as follows:

$$V_s = 1 - \frac{m_{volatiles}}{D_{avg}} \quad \text{Eqn. 2}$$

where:

- $m_{volatiles}$  = Total volatiles in the batch, including VOC, water, and exempt compounds, (g/L coating); and
- $D_{avg}$  = Average density of volatiles in the batch (g/L).

The procedures specified in 40 CFR 63.786(d) may be used to determine the values of variables defined in this paragraph. In addition, the owner or operator may choose to construct nomographs, based on Equation 1, similar or identical to the one provided in appendix B as a means of easily estimating the maximum allowable thinning ratio.

(ii) Prior to the first application of each batch, notify painters and other persons, as necessary, of the designated thinner and maximum allowable thinning ratio(s) for each batch of the coating by affixing a label to each container of coating or through another means described in the implementation plan required in 40 CFR 63.787(b).

(iii) By the 15th day of each calendar month, determine the volume of each batch of the coating used, as supplied, during the previous month.

(iv) By the 15th day of each calendar month, determine the total allowable volume of thinner for the coating used during the previous month as follows:

$$V_{th} = \sum_{i=1}^n (R \times V_b)_i + \sum_{i=1}^n (R_{cold} \times V_{b-cold})_i \quad \text{Eqn 3.}$$

where:

- $V_{th}$  = Total allowable volume of thinner for the previous month (L thinner);
- $V_b$  = Volume of each batch, as supplied and before being thinned, used during non-cold-weather days of the previous month (L coating as supplied);
- $R_{cold}$  = Maximum allowable thinning ratio for each batch used during cold-weather days (L thinner/L coating as supplied);
- $V_{b-cold}$  = Volume of each batch, as supplied and before being thinned, used during cold-weather days of the previous month (L coating as supplied);
- $i$  = Each batch of coating; and
- $n$  = Total number of batches of the coating.

(v) By the 15th day of each calendar month, determine the volume of thinner actually used with the coating during the previous month.

(vi) If the volume of thinner actually used with the coating [paragraph (c)(3)(v) of this section] is less than or equal to the total allowable volume of thinner for the coating [paragraph (c)(3)(iv) of this section], then compliance is demonstrated for the coating for the previous month, unless a violation is revealed using Method 24.

(3) Coatings to which the same thinning solvent will be added--group compliance. For coatings to which the same thinning solvent (or other material) is routinely or sometimes added, the owner or operator shall comply as follows:

(i) Designate a single thinner to be added to each coating during the month and "group" coatings according to their designated thinner.

(ii) Prior to the first application of each batch, calculate the maximum allowable thinning ratio (or ratios, if the affected source complies with the cold-weather limits in addition to the other limits specified in Table 2) for each batch of coating in the group using the equations in paragraph (c)(2) of this section.

(iii) Prior to the first application of each "batch," notify painters and other persons, as necessary, of the designated thinner and maximum allowable thinning ratio(s) for each batch in the group by affixing a label to each container of coating or through another means described in the implementation plan required in 40 CFR 63.787(b).

(iv) By the 15th day of each calendar month, determine the volume of each batch of the group used, as supplied, during the previous month.



(v) By the 15th day of each calendar month, determine the total allowable volume of thinner for the group for the previous month using Equation 3.

(vi) By the 15th day of each calendar month, determine the volume of thinner actually used with the group during the previous month.

(vii) If the volume of thinner actually used with the group [paragraph (c)(3)(vi) of this section] is less than or equal to the total allowable volume of thinner for the group [paragraph (c)(3)(v) of this section], then compliance is demonstrated for the group for the previous month, unless a violation is revealed using Method 24.

(4) Demonstration of compliance through an alternative (i.e., other than Method 24) test method.  
The owner or operator shall comply as follows:

(i) Certify the as-supplied VOHAP content (g VOHAP/L solids) of each batch of coating.

(ii) If no thinning solvent will be added to the coating, the owner or operator of an affected source shall follow the procedure described in 40 CFR 63.785(c)(1), except that VOHAP content shall be used in lieu of VOC content.

(iii) If thinning solvent will be added to the coating, the owner or operator of an affected source shall follow the procedure described in 40 CFR 63.785(c)(2) or (3), except that in Equation 1: the term " $m_{VOC}$ " shall be replaced by the term " $m_{VOHAP}$ ," defined as the VOHAP content of the coating as supplied (g VOHAP/L coating) and the term " $D_{th}$ " shall be replaced by the term " $D_{th(VOHAP)}$ " defined as the average density of the VOHAP thinner(s) (g/L).

[40 CFR 63.785(c)]

(d) A violation revealed through any approved test method shall result in a 1-day violation for enforcement purposes. A violation revealed through the recordkeeping procedures described in paragraphs (c)(1) through (c)(4) of this section shall result in a 30-day violation for enforcement purposes, unless the owner or operator provides sufficient data to demonstrate the specific days during which noncompliant coatings were applied.

[40 CFR 63.785(d)]

#### **40 CFR 63.786 Test Methods and Procedures**

(a) For the compliance procedures described in 40 CFR 63.785(c)(1)-(3), Method 24 of 40 CFR part 60, appendix A, is the definitive method for determining the VOC content of coatings, as supplied or as applied. When a coating or thinner contains exempt compounds that are volatile HAP or VOHAP, the owner or operator shall ensure, when determining the VOC content of a coating, that the mass of these exempt compounds is included.

[40 CFR 63.786(a)]

(b) For the compliance procedure described in 40 CFR 63.785(c)(4), the Permitting authority must approve the test method for determining the VOHAP content of coatings and thinners. As part of the approval, the test method must meet the specified accuracy limits indicated below for sensitivity, duplicates, repeatability, and reproducibility coefficient of variation each determined at the 95 percent confidence limit. Each percentage value below is the corresponding coefficient of variation multiplied by 2.8 as in the ASTM Method E180-93: Standard Practice for Determining the Precision of ASTM Methods for Analysis and Testing of Industrial Chemicals (incorporation by reference--see 40 CFR 63.14).

**Sensitivity:** The overall sensitivity must be sufficient to identify and calculate at least one mass percent of the compounds of interest based on the original sample. The sensitivity is defined as ten times the noise level as specified in ASTM Method D3257-93: Standard Test Methods for Aromatics in Mineral Spirits by Gas Chromatography (incorporation by reference--see 40 CFR 63.14). In determining the sensitivity, the level of sample dilution must be factored in.

**Repeatability:** First, at the 0.1-5 percent analyte range the results would be suspect if duplicates vary by more than 6 percent relative and/or day to day variation of mean duplicates by the same analyst exceeds 10 percent relative. Second, at greater than 5 percent analyte range the results would be suspect if duplicates vary by more than 5 percent relative and/or day to day variation of duplicates by the same analyst exceeds 5 percent relative.

**Reproducibility:** First, at the 0.1-5 percent analyte range the results would be suspect if lab to lab variation exceeds 60 percent relative. Second, at greater than 5 percent range the results would be suspect if lab to lab variation exceeds 20 percent relative.

Any test method should include information on the apparatus, reagents and materials, analytical procedure, procedure for identification and confirmation of the volatile species in the mixture being analyzed, precision and bias, and other details to be reported. The reporting should also include information on quality assurance (QA) auditing.

Multiple and different analytical techniques must be used for positive identification if the components in a mixture under analysis are not known. In such cases a single column gas chromatograph (GC) may not be adequate. A combination of equipment may be need such as a GC/mass spectrometer or GC/infrared system. (If a GC method is used, the operator must use practices in ASTM Method E260-91: Standard Practice for Gas Chromatography [incorporation by reference--see 40 CFR 63.14].) . [40 CFR 63.786(b)]

(c) A coating manufacturer or the owner or operator of an affected source may use batch formulation data as a test method in lieu of Method 24 to certify the as-supplied VOC content of a coating if the manufacturer or the owner or operator has determined that batch formulation data have a consistent and quantitatively known relationship to Method 24 results. This determination shall consider the role of cure volatiles, which may cause emissions to exceed an amount based solely upon coating formulation data. Notwithstanding such determination, in the event of conflicting results, Method 24 shall take precedence.

[40 CFR 63.786(c)]

(d) Each owner or operator of an affected source shall use or ensure that the manufacturer uses the form and procedures mentioned in appendix A of this subpart to determine values for the thinner and coating parameters used in Equations 1 and 2. The owner or operator shall ensure that the coating/thinner manufacturer (or supplier) provides information on the VOC and VOHAP contents of the coatings/thinners and the procedure(s) used to determine these values.

[40 CFR 63.786(d)]

#### **40 CFR 63.787 Notification Requirements**

(a) Each owner or operator of an affected source shall comply with all applicable notification requirements in 40 CFR 63.9(a)-(d) and (i)-(j) of subpart A (General Provisions), with the exception that the deadline specified in 40 CFR 63.9(b)(2) and (3) shall be extended from 120 days to 180 days. Any owner or operator that receives approval pursuant to 40 CFR 63.783(c) of this subpart to use an add-on control system to control coating emissions shall comply with the applicable requirements of 40 CFR 63.9(e)-(h) of subpart A.

[40 CFR 63.787(a)]

(b) Implementation plan. The provisions of 40 CFR 63.9(a) (Notification requirements/Applicability and general information) of subpart A apply to the requirements of this paragraph.

(1) Each owner or operator of an affected source shall:

(i) Prepare a written implementation plan that addresses each of the subject areas specified in paragraph (b)(3) of this section; and

(ii) Not later than December 16, 1996, submit the implementation plan to the Administrator along with the notification required by 40 CFR 63.9(b)(2) or (5) of subpart A, as applicable.

(2) [Reserved]

(3) *Implementation plan contents*. Each implementation plan shall address the following subject areas:

(i) *Coating compliance procedures*. The implementation plan shall include the compliance procedure(s) under 40 CFR 63.785(c) that the source intends to use.

(ii) *Recordkeeping procedures*. The implementation plan shall include the procedures for maintaining the records required under 40 CFR 63.788, including the procedures for gathering the necessary data and making the necessary calculations.

(iii) *Transfer, handling, and storage procedures*. The implementation plan shall include the procedures for ensuring compliance with 40 CFR 63.783(b).

(4) *Major sources that intend to become area sources by the compliance date*. Existing major sources that intend to become area sources by the December 16, 1997 compliance date may choose to submit, in lieu of the implementation plan required under paragraph (b)(1) of this section, a statement that, by the compliance date, the major source intends to obtain and comply with federally enforceable limits on their potential to emit which make the facility an area source.

[40 CFR 63.787(b)]

**40 CFR 63.788 Recordkeeping and reporting requirements.**

(a) Each owner or operator of an affected source shall comply with the applicable recordkeeping and reporting requirements in 40 CFR 63.10(a), (b), (d), and (f) of subpart A (General Provisions). Any owner that receives approval pursuant to 40 CFR 63.783(c) of this subpart to use an add-on control system to control coating emissions shall also comply with the applicable requirements of 40 CFR 63.10(c) and (e). A summary of recordkeeping and reporting requirements is provided in Table 3. [40 CFR 63.788(a)]

(b) Recordkeeping requirements.

(1) Each owner or operator of a major source shipbuilding or ship repair facility having surface coating operations with less than 1000 liters (264 gallons) annual marine coating usage shall record the total volume of coating applied at the source to ships. Such records shall be compiled monthly and maintained for a minimum of 5 years.

(2) Each owner or operator of an affected source shall compile records on a monthly basis and maintain those records for a minimum of 5 years. At a minimum, these records shall include:

- (i) All documentation supporting initial notification;
- (ii) A copy of the affected source's approved implementation plan;
- (iii) The volume of each low-usage-exempt coating applied;
- (iv) Identification of the coatings used, their appropriate coating categories, and the applicable VOHAP limit;
- (v) Certification of the as-supplied VOC content of each batch of coating;
- (vi) A determination of whether containers meet the standards as described in 40 CFR 63.783(b)(2); and
- (vii) The results of any Method 24 or approved VOHAP measurement test conducted on individual containers of coating, as applied.

(3) The records required by paragraph (b)(2) of this section shall include additional information, as determined by the compliance procedure(s) described in 40 CFR 63.785(c) that each affected source followed:

(i) Coatings to which thinning solvent will not be added. The records maintained by facilities demonstrating compliance using the procedure described in 40 CFR 63.785(c)(1) shall contain the following information:

- (A) Certification of the as-applied VOC content of each batch of coating; and
- (B) The volume of each coating applied.

(ii) Coatings to which thinning solvent will be added--coating-by-coating compliance. The records maintained by facilities demonstrating compliance using the procedure described in 40 CFR 63.785(c)(2) shall contain the following information:

- (A) The density and mass fraction of water and exempt compounds of each thinner and the volume fraction of solids (nonvolatiles) in each batch, including any calculations;
- (B) The maximum allowable thinning ratio (or ratios, if the affected source complies with the cold-weather limits in addition to the other limits specified in Table 2 of this subpart) for each batch of coating, including calculations;
- (C) If an affected source chooses to comply with the cold-weather limits, the dates and times during which the ambient temperature at the affected source was below 4.5°C (40°F) at the time the coating was applied and the volume used of each batch of the coating, as supplied, during these dates;

(D) The volume used of each batch of the coating, as supplied;  
(E) The total allowable volume of thinner for each coating, including calculations; and

(F) The actual volume of thinner used for each coating.

(iii) Coatings to which the same thinning solvent will be added--group compliance. The records maintained by facilities demonstrating compliance using the procedure described in 40 CFR 63.785(c)(3) shall contain the following information:

(A) The density and mass fraction of water and exempt compounds of each thinner and the volume fraction of solids in each batch, including any calculations;

(B) The maximum allowable thinning ratio (or ratios, if the affected source complies with the cold-weather limits in addition to the other limits specified in Table 2) for each batch of coating, including calculations;

(C) If an affected source chooses to comply with the cold-weather limits, the dates and times during which the ambient temperature at the affected source was below 4.5°C (40°F) at the time the coating was applied and the volume used of each batch in the group, as supplied, during these dates;

(D) Identification of each group of coatings and their designated thinners;

(E) The volume used of each batch of coating in the group, as supplied;

(F) The total allowable volume of thinner for the group, including calculations;

and

(G) The actual volume of thinner used for the group.

(iv) Demonstration of compliance through an alternative (i.e., non-Method 24) test method. The records maintained by facilities demonstrating compliance using the procedure described in 40 CFR 63.785(c)(4) shall contain the following information:

(A) Identification of the Permitting authority-approved VOHAP test method or certification procedure;

(B) For coatings to which the affected source does not add thinning solvents, the source shall record the certification of the as-supplied and as-applied VOHAP content of each batch and the volume of each coating applied;

(C) For coatings to which the affected source adds thinning solvent on a coating-by-coating basis, the source shall record all of the information required to be recorded by paragraph (b)(3)(ii) of this section; and

(D) For coatings to which the affected source adds thinning solvent on a group basis, the source shall record all of the information required to be recorded by paragraph (b)(3)(iii) of this section.

(4) If the owner or operator of an affected source detects a violation of the standards specified in 40 CFR 63.783, the owner or operator shall, for the remainder of the reporting period during which the violation(s) occurred, include the following information in his or her records:

(i) A summary of the number and duration of deviations during the reporting period, classified by reason, including known causes for which a Federally-approved or promulgated exemption from an emission limitation or standard may apply.

(ii) Identification of the data availability achieved during the reporting period, including a summary of the number and total duration of incidents that the monitoring protocol failed to perform in accordance with the design of the protocol or produced data that did not meet minimum data accuracy and precision requirements, classified by reason.

(iii) Identification of the compliance status as of the last day of the reporting period and whether compliance was continuous or intermittent during the reporting period.

(iv) If, pursuant to paragraph (b)(4)(iii) of this section, the owner or operator identifies any deviation as resulting from a known cause for which no Federally-approved or promulgated exemption from an emission limitation or standard applies, the monitoring report shall also include all

records that the source is required to maintain that pertain to the periods during which such deviation occurred and:

- (A) The magnitude of each deviation;
  - (B) The reason for each deviation;
  - (C) A description of the corrective action taken for each deviation, including action taken to minimize each deviation and action taken to prevent recurrence; and
  - (D) All quality assurance activities performed on any element of the monitoring protocol.
- [40 CFR 63.788(b)]

(c) Reporting requirements. Before the 60th day following completion of each 6-month period after the compliance date specified in 40 CFR 63.784, each owner or operator of an affected source shall submit a report to the Permitting authority for each of the previous 6 months. The report shall include all of the information that must be retained pursuant to paragraphs (b)(2)-(3) of this section, except for that information specified in paragraphs (b)(2)(i)-(ii), (b)(2)(v), (b)(3)(i)(A), (b)(3)(ii)(A), and (b)(3)(iii)(A). If a violation at an affected source is detected, the source shall also report the information specified in paragraph (b)(4) of this section for the reporting period during which the violation(s) occurred. To the extent possible, the report shall be organized according to the compliance procedure(s) followed each month by the affected source.

[40 CFR 63.788(c)]

## **Subsection L. Limestone Handling System for FGD System for Units 1 & 2**

### **This section addresses the following Regulated Emissions Units:**

- 020 Drops from limestone conveyors LE, LF and LG and Silo C belt feeder with baghouse
- 021 Silo C with one baghouse

#### Description

New components of the limestone handling system to provide limestone for the new FGD system. The components are Silo C and its related rotary unloader, belt feeder and wet ball mill, and reversible belt conveyors LF and LG. Conveyors LF and LG replace an existing bifurcated chute which feeds from conveyor LE to silos A and B. Particulate emissions from drops from limestone handling conveyors LE, LF and LG and the silo C belt feeder are controlled by a baghouse: American Air Filter Fabripulse - Model B, size 12-72-1155. Particulate emissions from displaced air in silo C will be controlled by a baghouse: American Air Filter Fabripak, size 6-16-132. The new wet ball mill is a wet process with no expected particulate emissions.

[Note: These emissions units are subject to 40 CFR 60, Subpart OOO, Standards of Performance for Nonmetallic Mineral Processing Plants (40 CFR 60.670 - 60.676) and 40 CFR 60 Subpart A; Rule 1-3.61, Rules of the Environmental Protection Commission (EPC) of Hillsborough County; Rule 62-296.700, F.A.C.; and are subject to the requirements of the state rules as indicated in this permit. The visible emission limit of specific condition 16 is more stringent than the limitations of 40 CFR 60.672(a)(2) and 60.672(f), and compliance with this limit will assure compliance with those requirements.]

### **The following conditions apply to the Emissions Units listed above:**

#### **OPERATIONAL REQUIREMENTS**

- L.1. Hours of Operation: These emissions units may operate continuously, i.e., 8,760 hours/year. [Rule 62-210.200, F.A.C., Definitions-potential to emit (PTE)]
- L.2. Enclosure of Equipment: All conveyors and conveyor transfer points shall be enclosed and exhaust from this equipment shall be directed to a baghouse to minimize particulate matter emissions. [62-4.070(3), F.A.C.]
- L.3. Operating Procedures: Enclosures and baghouses for these emissions units shall be properly operated and maintained at all times in a condition to minimize particulate emissions. The owner and operator shall ensure that all facility staff responsible for these emissions units are trained in their operation and maintenance in accordance with the guidelines and procedures as established by the equipment manufacturers. [Rule 62-4.070(3), F.A.C.]

#### **EMISSION LIMITATIONS AND PERFORMANCE STANDARDS**

- L.4. Particulate and Visible Emissions: No owner or operator shall cause or allow visible emissions from the baghouses controlling these emissions units in excess of 0.03 gr/dscf and 5% opacity. [40 CFR 60.672(a)(1) and (2); Rules 62-4.070(3) and Rule 62-296.711(2)(b), F.A.C., Rule 1-3.61, Rules of the EPC, and request of applicant (VE limit)]

[Note: The visible emission limit of this condition is more stringent than the limitations of 40 CFR 60.672(a)(2) and 60.672(f), and compliance with this limit will assure compliance with those requirements.]

#### **COMPLIANCE MONITORING AND TESTING REQUIREMENTS**

- L.5. Visible Emissions Tests: Compliance with the visible emission limits of this permit shall be demonstrated by an annual compliance test using EPA Method 9. The duration of initial tests shall

be three hours and the duration of subsequent annual tests shall be thirty minutes.  
[Rules 62-4.070(3) and 62-297.310(4)(a)2., F.A.C., and 40 CFR 60.11(b)]

[Note: The three hour duration of initial tests complies with the requirements of the NSPS and the thirty minute duration of subsequent tests complies with state rules.]

**L.6. Visible Emissions Tests in Lieu of Stack Tests, Emissions Unit 020:** After passing the initial test required by specific condition 21 of this section, the owner or operator is permitted to comply with the visible emission limit of specific condition 16 and the testing requirement of specific condition 17 of this section in lieu of regularly demonstrating compliance with the limitations of 40 CFR 60.672(a)(1) and (2) and the particulate matter limitation of specific condition 16 of this section. If the Department has reason to believe that the particulate weight emission limit of 40 CFR 60.672(a)(1) or the particulate matter limitation of specific condition 16 of this section is not being met, it shall require compliance be demonstrated by the test method specified by 40 CFR 60.675.  
[Rules 62-4.070(3) and 62-297.620(4), F.A.C.]

#### **REPORTING AND RECORD KEEPING REQUIREMENTS**

**L.7. Records of Maintenance:** The owner or operator shall make and maintain records of maintenance on the enclosures and baghouses sufficient to demonstrate compliance with the operating procedures requirements of specific condition 15 of this section. [Rule 62-4.070(3), F.A.C.]

#### **NSPS SUBPART OOO REQUIREMENTS**

[Note: The numbering of the original rules in the following conditions has been preserved for ease of reference to the rules. The definitions of terms of this part shall have the meanings as defined in 40 CFR 60.671 Definitions. The term "Administrator" when used in 40 CFR 60 shall mean the Secretary or the Secretary's designee.]

**L.8. Pursuant to 40 CFR 60.672 Standard for Particulate Matter:**

[Note: The requirements of 40 CFR 60.672(a)(1) and (2) apply to emissions unit 020, and the requirements of 40 CFR 60.672(f) apply to emissions unit 021.]

- (a) No owner or operator shall cause to be discharged into the atmosphere from any transfer point on belt conveyors or from any other affected facility any stack emissions which:
- (1) Contain particulate matter in excess of 0.05 g/dscm; and
  - (2) Exhibit greater than 7 percent opacity.

[Note: The emission limit of specific condition 16 of this section is more stringent than the limitation of 40 CFR 60.672(a)(2).]

- (f) No owner or operator shall cause to be discharged into the atmosphere from any baghouse that controls emissions from only an individual, enclosed storage bin, stack emissions which exhibit greater than 7 percent opacity.

[Note: The emission limit of specific condition 16 of this section is more stringent than the limitation of 40 CFR 60.672(f). See the note for that condition.]



L.9. Pursuant to 40 CFR 60.675 Test Methods and Procedures:

- (a) In conducting the performance tests required in 40 CFR 60.8, the owner or operator shall use as reference methods and procedures the test methods in appendix A of 40 CFR 60 or other methods and procedures as specified in this section, except as provided in 40 CFR 60.8(b).
- (b) The owner or operator shall determine compliance with the particulate matter standards in 40 CFR 60.672(a) as follows:
  - (1) Method 5 or Method 17 shall be used to determine the particulate matter concentration. The sample volume shall be at least 1.70 dscm (60 dscf). For Method 5, if the gas stream being sampled is at ambient temperature, the sampling probe and filter may be operated without heaters. If the gas stream is above ambient temperature, the sampling probe and filter may be operated at a temperature high enough, but no higher than 121 °C (250 °F), to prevent water condensation on the filter.
  - (2) Method 9 and the procedures in 40 CFR 60.11 shall be used to determine opacity.

[Note: The owner or operator is required to demonstrate compliance with the particulate matter emission limitation of 40 CFR 60.672(a)(1) by performing and passing an initial particulate matter test in accordance with the requirements of this section, unless such requirement is waived by the US Environmental Protection Agency. No subsequent regular annual particulate matter testing is required. The owner or operator is permitted to comply with the visible emission limit of specific condition 16 of this section in lieu of regularly demonstrating compliance with the limitations of 40 CFR 60.672(a)(1) and (2). See also specific condition 18 of this section.]

- (c) (2) In determining compliance with the opacity of stack emissions from any baghouse that controls emissions only from an individual enclosed storage bin under 40 CFR 60.672(f) of this subpart, using Method 9, the duration of the Method 9 observations shall be 1 hour (ten 6-minute averages).

[Note: The initial Method 9 test duration for emissions unit 021 is one hour pursuant to 40 CFR 60.675(c)(2), while the initial Method 9 test duration for emissions unit 020 is 3 hours pursuant to 40 CFR 60.11(b). Subsequent annual Method 9 tests shall be conducted for 30 minutes for emissions units 020 and 021.]

- (g) If, after 30 days notice for an initially scheduled performance test, there is a delay (due to operational problems, etc.) in conducting any rescheduled performance test required in this section, the owner or operator of an affected facility shall submit a notice to the Administrator at least 7 days prior to any rescheduled performance test.

L.10. Pursuant to 40 CFR 60.676 Reporting and Recordkeeping:

- (f) The owner or operator of any affected facility shall submit written reports of the results of all performance tests conducted to demonstrate compliance with the standards set forth in 40 CFR 60.672 of this subpart.
- (h) The subpart A requirement under 40 CFR 60.7(a)(2) for notification of the anticipated date of initial startup of an affected facility shall be waived for owners or operators of affected facilities regulated under this subpart.
- (i) A notification of the actual date of initial startup of each affected facility shall be submitted to the Administrator.
- (1) For a combination of affected facilities in a production line that begin actual initial startup on the same day, a single notification of startup may be submitted by the owner or operator to the Administrator. The notification shall be postmarked within 15 days after such date and shall

include a description of each affected facility, equipment manufacturer, and serial number of the equipment, if available.

L.11. The attached 40 CFR 60 Subpart A NSPS General Provisions also apply to these emissions units.

### **Subsection M. Lime Silo for Wastewater Treatment Plant for the Chloride Bleed Stream**

**This section addresses the following Regulated Emissions Units:**

-022 Lime silo with one baghouse for the waste water treatment plant for the chloride bleed stream

#### Description

A lime silo with one baghouse (Griffin Environmental 36-LS Filter Vent) ~~to serve a new~~ which supplies limestone to the waste water treatment plant for the FGD chloride bleed stream. This plant will serve the new and existing FGD systems. Particulate emissions from displaced air from periodically filling the lime silo will be controlled with the related baghouse.

[Note: This emissions unit is subject to the requirements of the state rules as indicated in this permit. This emissions unit is subject to Rule 1-3.61, Rules of the Environmental Protection Commission (EPC) of Hillsborough County, but it exempt from the requirements of Rule 62-296.711, F.A.C., pursuant to Rule 62-296.700(2)(c), F.A.C., because it has an allowable emission rate of less than one ton per year.]

**TEC Rationale for Revision: Administrative corrections.**

**The following conditions apply to the Emissions Unit listed above:**

#### **OPERATIONAL REQUIREMENTS**

- M.1. Hours of Operation: This emissions units may operate continuously, i.e., 8,760 hours/year. [Rule 62-210.200, F.A.C., Definitions-potential to emit (PTE)]
- M.2. Operating Procedures: The baghouse for this emissions unit shall be properly operated and maintained at all times in a condition to minimize particulate emissions. The owner and operator shall ensure that all facility staff responsible for these emissions units are trained in their operation and maintenance in accordance with the guidelines and procedures as established by the equipment manufacturers. [Rule 62-4.070(3), F.A.C.]

#### **EMISSION LIMITATIONS AND PERFORMANCE STANDARDS**

- M.3. Particulate and Visible Emissions: No owner or operator shall cause or allow visible emissions from the baghouse controlling this emissions unit in excess of 0.03 gr/dscf and 5% opacity. [Rules 62-4.070(3) and 62-296.700(2)(c), F.A.C.]

[Note: The particulate matter limitation will ensure that allowable emissions are less than one ton per year for this emissions unit.]

#### **COMPLIANCE MONITORING AND TESTING REQUIREMENTS**

- M.4. Visible Emissions Tests: Compliance with the visible emission limit of this permit shall be demonstrated by an annual compliance test using EPA Method 9. The duration of annual tests shall be thirty minutes. [Rules 62-4.070(3) and 62-297.310(4)(a)2., F.A.C.]
- M.5. Visible Emissions Tests in Lieu of Stack Tests: The owner or operator is permitted to comply with the visible emission limit of specific condition 25 and the testing requirement of specific condition 26 of this section in lieu of regularly demonstrating compliance with the particulate matter limitation of specific condition 25 of this section. If the Department has reason to believe that the particulate matter limitation of specific condition 25 of this section is not being met, it shall require

compliance be demonstrated by conducting a particulate matter test in accordance with EPA Method 5 specified at 40 CFR 60 Appendix A. [Rules 62-4.070(3) and 62-297.620(4), F.A.C.]

**REPORTING AND RECORD KEEPING REQUIREMENTS**

M.6. Records of Maintenance: The owner or operator shall make and maintain records of maintenance on the baghouse sufficient to demonstrate compliance with the operating procedures requirements of specific condition M.2. of this section. [Rule 62-4.070(3), F.A.C.]

M.7. Tampa Electric shall keep records of facility staff training, and shall maintain, on site, an Operations and Maintenance Plan for the baghouse that details how it shall be properly operated and maintained at all times. Tampa Electric shall also take weekly pressure readings from the baghouse pressure-sensing device.  
[USEPA objection resolution.]

## Subsection N. Common Conditions

**This section addresses the all of the Regulated Emissions Units:**

**{Permitting note: For emissions units subject to NESHAP or NSPS requirements, when more stringent, the requirements of the NESHAPS or NSPS supercede these common conditions.}**

N.1. Compliance Test Notification. TECO shall notify the EPCHC, at least 15 days prior to the date on which each formal compliance test is to begin, of the date, time, and place of each such test, and the test contact person who will be responsible for coordinating and having such test conducted for TECO. [Rule 62-297.310(7)(a)9., F.A.C.]

N.2. Special Compliance Tests. When, after inspection, the Department or the Environmental Protection Commission of Hillsborough County has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it shall require the Tampa Electric Company to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emission unit and to provide a report on the results of said test to the requesting agency. [Rule 62-297.310(7)(b), F.A.C.]

### GENERAL TEST REQUIREMENTS

N.3. Required Number of Test Runs. For mass emission limitations, a compliance test shall consist of three complete and separate determinations of the total air pollutant emission rate through the test section of the stack or duct and three complete and separate determinations of any applicable process variables corresponding to the three distinct time periods during which the stack emission rate was measured provided, however, that three complete and separate determinations shall not be required if the process variables are not subject to variation during a compliance test, or if three determinations are not necessary in order to calculate the unit's emission rate. The three required test runs shall be completed within one consecutive five day period. In the event that a sample is lost or one of the three runs must be discontinued because of circumstances beyond the control of the owner or operator, and a valid third run cannot be obtained within the five day period allowed for the test, the Secretary or his or her designee may accept the results of the two complete runs as proof of compliance, provided that the arithmetic mean of the results of the two complete runs is at least 20 percent below the allowable emission limiting standards. [Rule 297.310(1), F.A.C.]

N.4. Operating Rate During Testing for Emission Units other than Combustion Turbines. Unless otherwise stated an emission unit's specific condition in this permit, testing of emissions shall be conducted with the emissions unit operation at 90 to 100 percent of the maximum operation rate allowed by specific condition in this permit. If it is impracticable to test at permitted capacity, an emissions unit may be tested at less than the minimum permitted capacity; in this case, subsequent emissions unit operation is limited to 110 percent of the test load until a new test is conducted. Once the unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purpose of additional compliance testing to regain the authority to operate at the permitted capacity. [Rule 62-297.310(2), F.A.C.]

N.5. Calculation of Emission Rate. The indicated emission rate or concentration shall be the arithmetic average of the emission rate or concentration determined by each of the three separate test runs unless otherwise specified in a particular test method or applicable rule.  
[Rule 62-297.310(3), F.A.C.]

N.6. Applicable Test Procedures.

(a) *Required Sampling Time.*

1. Unless otherwise specified in the specific conditions of this permit, the required sampling time for each test run shall be no less than one hour and no greater than four hours, and the sampling time at each sampling point shall be of equal intervals of at least two minutes.

2. Opacity Compliance Tests. When either EPA Method 9 or DEP Method 9 is specified as the applicable opacity test method, the required minimum period of observation for a compliance test shall be sixty (60) minutes for emissions units which emit or have the potential to emit 100 tons per year or more of particulate matter, and thirty (30) minutes for emissions units which have potential emissions less than 100 tons per year of particulate matter and are not subject to a multiple-valued opacity standard. The opacity test observation period shall include the period during which the highest opacity emissions can reasonably be expected to occur. Exceptions to these requirements are as follows:

a. For batch, cyclical processes, or other operations which are normally completed within less than the minimum observation period and do not recur within that time, the period of observation shall be equal to the duration of the batch cycle or operation completion time.

b. The observation period for special opacity tests that are conducted to provide data to establish a surrogate standard pursuant to Rule 62-297.310(5)(k), F.A.C., Waiver of Compliance Test Requirements, shall be established as necessary to properly establish the relationship between a proposed surrogate standard and an existing mass emission limiting standard.

c. The minimum observation period for opacity tests conducted by employees or agents of the Department to verify the day-to-day continuing compliance of a unit or activity with an applicable opacity standard shall be twelve minutes.

(b) *Minimum Sample Volume.* Unless otherwise specified in the applicable rule, the minimum sample volume per run shall be 25 dry standard cubic feet.

(c) *Required Flow Rate Range.* For EPA Method 5 particulate sampling, acid mist/sulfur dioxide, and fluoride sampling which uses Greenburg Smith type impingers, the sampling nozzle and sampling time shall be selected such that the average sampling rate will be between 0.5 and 1.0 actual cubic feet per minute, and the required minimum sampling volume will be obtained.

(d) *Calibration of Sampling Equipment.* Calibration of the sampling train equipment shall be conducted in accordance with the schedule shown in Table 297.310-1 (see attachment).

(e) *Allowed Modification to EPA Method 5.* When EPA Method 5 is required, the following modification is allowed: the heated filter may be separated from the impingers by a flexible tube.  
[Rule 297.310(4), F.A.C.]

N.7. Determination of Process Variables.

(a) *Required Equipment.* The owner or operator of an emissions unit for which compliance tests are required shall install, operate, and maintain equipment or instruments necessary to determine process variables, such as process weight input or heat input, when such data are needed in conjunction with emissions data to determine the compliance of the emissions unit with applicable emission limiting standards.

(b) *Accuracy of Equipment.* Equipment or instruments used to directly or indirectly determine process variables, including devices such as belt scales, weight hoppers, flow meters, and tank scales, shall be calibrated and adjusted to indicate the true value of the parameter being measured with sufficient accuracy to allow the applicable process variable to be determined within 10% of its true value.

[Rule 62-297.310(5), F.A.C.]

N.8. Frequency of Compliance Tests. The following provisions apply to those emissions units that are subject to an emissions limiting standard for which compliance testing is required, unless otherwise provided in a specific emission unit condition of this permit.

*(a) General Compliance Testing.*

1. The owner or operator of a new or modified emissions unit that is subject to an emission limiting standard shall conduct a compliance test that demonstrates compliance with the applicable emission limiting standard prior to obtaining an operation permit for such emissions unit.

2. For excess emission limitations for particulate matter specified in Rule 62-210.700, F.A.C., a compliance test shall be conducted annually while the emissions unit is operating under soot blowing conditions in each federal fiscal year during which soot blowing is part of normal emissions unit operation, except that such test shall not be required in any federal fiscal year in which a fossil fuel steam generator does not burn liquid and/or solid fuel for more than 400 hours other than during startup.

3. The owner or operator of an emissions unit that is subject to any emission limiting standard shall conduct a compliance test that demonstrates compliance with the applicable emission limiting standard prior to obtaining a renewed operation permit. Emissions units that are required to conduct an annual compliance test may submit the most recent annual compliance test to satisfy the requirements of this provision. In renewing an air operation permit pursuant to Rule 62-210.300(2)(a)3.b., c., or d., F.A.C., the Department shall not require submission of emission compliance test results for any emissions unit that, during the year prior to renewal:

a. Did not operate; or

b. In the case of a fuel burning emissions unit, burned liquid and/or solid fuel for a total of no more than 400 hours.

4. During each federal fiscal year (October 1 - September 30), unless otherwise specified by rule, order, or permit, the owner or operator of each emissions unit shall have a formal compliance test conducted for:

a. Visible emissions, if there is an applicable standard;

b. Each of the following pollutants, if there is an applicable standard, and if the emissions unit emits or has the potential to emit: 5 tons per year or more of lead or lead compounds measured as elemental lead; 30 tons per year or more of acrylonitrile; or 100 tons per year or more of any other regulated air pollutant; and

c. Each NESHAP pollutant, if there is an applicable emission standard.

5. An annual compliance test for particulate matter emissions shall not be required for any fuel burning emissions unit that, in a federal fiscal year, does not burn liquid and/or solid fuel, other than during startup, for a total of more than 400 hours.

6. For fossil fuel steam generators on a semi-annual particulate matter emission compliance testing schedule, a compliance test shall not be required for any six-month period in which liquid and/or solid fuel is not burned for more than 200 hours other than during startup.

7. For emissions units electing to conduct particulate matter emission compliance testing quarterly pursuant to Rule 62-296.405(2)(a), F.A.C., a compliance test shall not be required for any quarter in which liquid and/or solid fuel is not burned for more than 100 hours other than during startup.

8. Any combustion turbine that does not operate for more than 400 hours per year shall conduct a visible emissions compliance test once per each five-year period, coinciding with the term of its air operation permit.

9. The owner or operator shall notify the Department and the Environmental Protection Commission of Hillsborough County, at least 15 days prior to the date on which each formal compliance test is to begin, of the date, time, and place of each such test, and the test contact person who will be responsible for coordinating and having such test conducted for the owner or operator.

10. An annual compliance test conducted for visible emissions shall not be required for units exempted from permitting at Rule 62-210.300(3)(a), F.A.C., or units permitted under the General Permit provisions at Rule 62-210.300(4), F.A.C.

*(b) Special Compliance Tests.* When the Department or Environmental Protection Commission of Hillsborough County, after investigation, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it shall require the owner or operator of the emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emissions unit and to provide a report on the results of said tests to the Department and the Environmental Protection Commission of Hillsborough County.

*(c) Waiver of Compliance Test Requirements.* If the owner or operator of an emissions unit that is subject to a compliance test requirement demonstrates to the Department, pursuant to the procedure established in Rule 62-297.620, F.A.C., that the compliance of the emissions unit with an applicable weight emission limiting standard can be adequately determined by means other than the designated test procedure, such as specifying a surrogate standard of no visible emissions for particulate matter sources equipped with a bag house or specifying a fuel analysis for sulfur dioxide emissions, the Department shall waive the compliance test requirements for such emissions units and order that the alternate means of determining compliance be used, provided, however, the provisions of Rule 62-297.310(7)(b), F.A.C., shall apply.

[Rule 62-297.310(7), F.A.C.]

#### N.9. Test Reports.

(a) The owner or operator of an emissions unit for which a compliance test is required shall file a report with the Department and the EPCHC on the results of each such test.

(b) The required test report shall be filed with the EPCHC as soon as practical but no later than 45 days after the last sampling run of each test is completed.

(c) The test report shall provide sufficient detail on the emissions unit tested and the test procedures used to allow the EPCHC and the Department to determine if the test was properly conducted and the test results properly computed. As a minimum, the test report, other than for an EPA or DEP Method 9 test, shall provide the following information:

1. The type, location, and designation of the emissions unit tested.
2. The facility at which the emissions unit is located.
3. The owner or operator of the emissions unit.
4. The normal type and amount of fuels used and materials processed, and the types and amounts of fuels used and material processed during each test run.
5. The means, raw data and computations used to determine the amount of fuels used and materials processed, if necessary to determine compliance with an applicable emission limiting standard.
6. The type of air pollution control devices installed on the emissions unit, their general condition, their normal operating parameters (pressure drops, total operating current and GPM scrubber water), and their operating parameters during each test run.
7. A sketch of the duct within 8 stack diameters upstream and 2 stack diameters downstream of the sampling ports, including the distance to any upstream and downstream bends or other flow disturbances.
8. The date, starting time and duration of each sampling run.
9. The test procedures used, including any alternative procedures authorized pursuant to Rule 62-297.620, F.A.C. Where optional procedures are authorized in this chapter, indicate which option was used.
10. The number of points sampled and configuration and location of the sampling plane.
11. For each sampling point for each run, the dry gas meter reading, velocity head, pressure drop across the stack, temperatures, average meter temperatures and sample time per point.



12. The type, manufacturer and configuration of the sampling equipment used.
  13. Data related to the required calibration of the test equipment.
  14. Data on the identification, processing and weights of all filters used.
  15. Data on the types and amounts of any chemical solutions used.
  16. Data on the amount of pollutant collected from each sampling probe, the filters, and the impingers, are reported separately for the compliance test.
  17. The names of individuals who furnished the process variable data, conducted the test, analyzed the samples and prepared the report.
  18. All measured and calculated data required to be determined by each applicable test procedure for each run.
  19. The detailed calculations for one run that relate the collected data to the calculated emission rate.
  20. The applicable emission standard, and the resulting maximum allowable emission rate for the emissions unit, plus the test result in the same form and unit of measure.
  21. A certification that, to the knowledge of the owner or his authorized agent, all data submitted are true and correct. When a compliance test is conducted for the EPCHC or the Department, the person who conducts the test shall provide the certification with respect to the test procedures used. The owner or his authorized agent shall certify that all data required and provided to the person conducting the test are true and correct to his knowledge.
- [Rule 62-297.310(8), F.A.C.]

**Section IV. This section is the Phase II Acid Rain Part.**

**Operated by:** Tampa Electric Company  
**ORIS code:** 0645

**The emissions units listed below are regulated under Acid Rain:**

**E.U.**

<b><u>ID No.</u></b>	<b><u>Brief Description</u></b>
-001	Unit No. 1 Steam Generator [EPA ID #: BB01]
-002	Unit No. 2 Steam Generator [EPA ID #: BB02]
-003	Unit No. 3 Steam Generator [EPA ID #: BB03]
-004	Unit No. 4 Steam Generator [EPA ID #: BB04]

1. The Phase II permit application, the Phase II NO<sub>x</sub> compliance plan, and the Phase II NO<sub>x</sub> averaging plan submitted for this facility, as approved by the Department, is a part of this permit. The owners and operators of these acid rain units must comply with the standard requirements and special provisions set forth in the application listed below:

DEP Form No. 62-210.900(1)(a), version 07/01/95, received 12/26/95 (signed 12/19/95).

DEP Form No. 62-210.900(1)(a)4., F.A.C., received 12/22/99 (signed 12/20/99).

DEP Form No. 62-210.900(1)(a)5., F.A.C., received 12/22/99 (signed 12/20/99).

[Chapter 62-213, F.A.C. and Rule 62-214.320, F.A.C.]

2. Sulfur dioxide (SO<sub>2</sub>) allowance allocations and nitrogen oxide (NO<sub>x</sub>) requirements for each Acid Rain unit are as follows:

E.U. ID No.	EPA ID		Year				
			2000	2001	2002	2003	2004
-001	BB01	SO <sub>2</sub> allowances, under Table 2 of 40 CFR 73	12132*	12132*	12132*	12132*	12132*
		NO <sub>x</sub> limit**	<p>Note: The applicable emission limitation, under 40 CFR 76.6(a)(23), is <b>0.84</b> lb/mmBtu.</p> <p><b><u>TEC Rationale for Revision: Administrative correction.</u></b></p> <p><b>2.a.</b> Pursuant to 40 CFR 76.11, the Florida Department of Environmental Protection approves the NO<sub>x</sub> emissions averaging plan submitted on 12/22/99 for this unit. Under the plan, this unit's NO<sub>x</sub> emissions shall not exceed the annual average alternative contemporaneous emission limitation of <b>0.74</b> lb/MMBtu. In addition, this unit shall not have an annual heat input less than <b>23,000,000</b> MMBtu.</p>				

E.U. ID No.	EPA ID		Year				
			2000	2001	2002	2003	2004
-002	BB02	SO <sub>2</sub> allowances, under Table 2 of 40 CFR 73	12196*	12196*	12196*	12196*	12196*
		NO <sub>x</sub> limit**	<p>Note: The applicable emission limitation, under 40 CFR 76.6(a)(23), is <b>0.84 lb/mmBtu</b>.</p> <p><b>TEC Rationale for Revision: Administrative correction.</b></p> <p><b>2.b.</b> Pursuant to 40 CFR 76.11, the Florida Department of Environmental Protection approves the NO<sub>x</sub> emissions averaging plan submitted on 12/22/99 for this unit. Under the plan, this unit's NO<sub>x</sub> emissions shall not exceed the annual average alternative contemporaneous emission limitation of <b>0.74 lb/MMBtu</b>. In addition, this unit shall not have an annual heat input less than <b>24,000,000 MMBtu</b>.</p>				
-003	BB03	SO <sub>2</sub> allowances, under Table 2 of 40 CFR 73	11444*	11444*	11444*	11444*	11444*

		NO <sub>x</sub> limit**	<p>Note: The applicable emission limitation, under 40 CFR 76.6(a)(23), is <b>0.84</b> lb/mmBtu.</p> <p><b><u>TEC Rationale for Revision: Administrative correction.</u></b></p> <p><b>2.c.</b> Pursuant to 40 CFR 76.11, the Florida Department of Environmental Protection approves the NO<sub>x</sub> emissions averaging plan submitted on 12/22/99 for this unit. Under the plan, this unit's NO<sub>x</sub> emissions shall not exceed the annual average alternative contemporaneous emission limitation of <b>0.53</b> lb/MMBtu. In addition, this unit shall not have an annual heat input less than <b>10,000,000</b> MMBtu.</p>				
E.U. ID No.	EPA ID		Year				
			2000	2001	2002	2003	2004
-004	BB04	SO <sub>2</sub> allowances, under Table 2 of 40 CFR 73	8780*	8780*	8780*	8780*	8780*

		NO <sub>x</sub> limit**	<p>Note: The applicable emission limitation, under 40 CFR 76.65(a)(21), is 0.45 lb/mmBtu.</p> <p><b><u>TEC Rationale for Revision: Administrative corrections.</u></b></p> <p><b>2.d.</b> Pursuant to 40 CFR 76.11, the Florida Department of Environmental Protection approves the NO<sub>x</sub> emissions averaging plan submitted on 12/22/99 for this unit. Under the plan, this unit's NO<sub>x</sub> emissions shall not exceed the annual average alternative contemporaneous emission limitation of 0.44 lb/MMBtu. In addition, this unit shall not have an annual heat input less than 20,000,000 MMBtu.</p>
--	--	-------------------------	--

\*The number of allowances held by an Acid Rain source in a unit account may differ from the number allocated by the USEPA under Table 2 of 40 CFR 73. "Allowance" means an authorization by the USEPA Administrator under the federal Acid Rain Program to emit up to one ton of sulfur dioxide during a specified calendar year.

\*\* Based on the Phase II NO<sub>x</sub> applications.

**2.e. Additional Requirements**

i. Under the plan (NO<sub>x</sub> Phase II averaging plan), the actual Btu-weighted annual average NO<sub>x</sub> emission rate for the units in the plan shall be less than or equal to the Btu-weighted annual average NO<sub>x</sub> emission rate for the same units had they each been operated, during the same period of time, in accordance with the applicable emission limitations under 40 CFR 76.5, 76.6, or 76.7, except that for any early election units, the applicable emission limitations shall be under 40 CFR 76.7. If the designated representative demonstrates that the requirement of the prior sentence (as set forth in 40 CFR 76.11(d)(1)(ii)(A)) is met for a year under the plan, then this unit shall be deemed to be in compliance for that year with its alternative contemporaneous annual emission limitation and annual heat input limit.

ii. In addition to the described NO<sub>x</sub> compliance plan, these units shall comply with all other applicable requirements of 40 CFR Part 76, including the duty to reapply for a NO<sub>x</sub> compliance plan and requirements covering excess emissions.

**3. Emission Allowances.** Emissions from sources subject to the Federal Acid Rain Program (Title IV) shall not exceed any allowances that the source lawfully holds under the Federal Acid Rain Program. Allowances shall not be used to demonstrate compliance with a non-Title IV applicable requirement of the Act.

a. No permit revision shall be required for increases in emissions that are authorized by allowances acquired pursuant to the Federal Acid Rain Program, provided that such increases do not require a permit revision pursuant to Rule 62-213.400(3), F.A.C.

b. No limit shall be placed on the number of allowances held by the source under the Federal Acid Rain Program.

c. Allowances shall be accounted for under the Federal Acid Rain Program.

[Rule 62-213.440(1)(c), F.A.C.]

**4. Fast-Track Revisions of Acid Rain Parts.** Those Acid Rain sources making a change described at Rule 62-214.370(4), F.A.C., may request such change as provided in Rule 62-213.413, F.A.C. [Rules 62-213.413 and 62-214.370(4), F.A.C.]

**5.** No permit revision shall be required for increases in emissions that are authorized by allowances acquired pursuant to the Federal Acid Rain Program, provided that such increases do not require a permit revision pursuant to Rule 62-213.400, F.A.C. [40 CFR 70.6(a)(4)(i); and, Rule 62-213.440(1)(c)1., F.A.C.]


**6.** Where an applicable requirement of the Act is more stringent than applicable regulations promulgated under Title IV of the Act, both provisions shall be incorporated into the permit and shall be enforceable by the Administrator. [40 CFR 70.6(a)(1)(ii); and, Rule 62-210.200, F.A.C., Definitions – Applicable Requirements.]

**7. Comments, notes, and justifications:**

The designated representative was changed to Gregory M. Nelson, P.E., effective July 1, 1998.

**ATTACHMENT E**

**LIMESTONE HANDLING  
PROCESS FLOW DIAGRAM**




LEGEND




DOCUMENT I.D.3.J.

LIMESTONE HANDLING PROCESS FLOW DIAGRAM

Source: ECT, 1996.







LEGEND



ATTACHMENT E.  
LIMESTONE HANDLING PROCESS FLOW DIAGRAM

Source: ECT, 2003.



**ATTACHMENT F**

**LIMESTONE UNLOADING AREA  
VISIBLE EMISSION DATA**



**TAMPA ELECTRIC**

July 8, 2003

Ms. Diana Lee  
 Air Engineering Department  
 Environmental Protection Commission  
 of Hillsborough County  
 1410 North 21st Street  
 Tampa, Florida 33605

**Via FedEx**  
**Airbill No. 7916 2757 1297**

**Re: Tampa Electric Company  
 Big Bend Station  
 Permit No. 0570039-010-AV  
 E.U. ID 011 - Truck/Railcar Limestone Unloading  
 Receiving Hopper with Baghouse**

Dear Ms. Lee:

As per our conversation on June 16, 2003, TEC is hereby providing notification that the Truck/Railcar Limestone Unloading Receiving Hopper with Baghouse, emission unit identification 011 (E.U. ID 011) will be unavailable due to an equipment outage. The equipment is being repaired to ensure the motor does not fail and preventative maintenance can be performed on this equipment. The bags in the baghouse are plugging more frequently due to the moisture content of the limestone and the recent rain events. The equipment outage is expected to occur from July 7, 2003 through August 31, 2003.

Limestone is delivered to the plant by truck or railcar and unloaded into E.U. ID 011. The particulate matter emissions from this activity are controlled by a baghouse. The moisture content of the limestone is approximately 15%. The limestone truck unloading occurs Monday through Friday from 4:30 AM to 5:30 PM. The frequency of limestone delivery is approximately 80 trucks per day.

Given the moisture content of the limestone and the unloading times, TEC is proposing to perform a visible emissions (VE) test once a week to ensure the 5% opacity requirements are met, during the equipment outage.


Ms. Diana Lee

July 8, 2003

Page 2 of 2

TEC appreciates your immediate attention to this matter. If you have any questions, please contact Ms. Shelly Castro or me at (813) 641-5033.

Sincerely,

A handwritten signature in cursive script that reads "Shelly Castro". The signature is written in black ink and is positioned above the printed name and title.

Shelly Castro  
Associate Engineer - Air Programs  
Environmental Affairs

EA/bmr/SSC162

cc: Mr. Al Linero - FDEP  
Mr. Jerry Kissel - FDEP SW  
Mr. Buck Oven - FDEP  
Mr. Scott Sheplak - FDEP



TAMPA ELECTRIC

July 23, 2003

Mr. Sterlin Woodard  
Environmental Protection Commission  
of Hillsborough County  
1410 21<sup>st</sup> Street  
Tampa, Florida 33605

Via FedEx  
Airbill No. 7908 4765 0178

**Re: Tampa Electric Company  
Big Bend Station  
Permit No. 0570039-010-AV  
E.U. ID 011 - Truck/Railcar Limestone Unloading  
Receiving Hopper with Baghouse**

Dear Mr. Woodard:

This letter is a follow up to our conversation on July 17, 2003, to clarify the notification that was provided on July 8, 2003 regarding an equipment outage for the Truck/Railcar Limestone Unloading Receiving Hopper with Baghouse, emission unit identification 011 (E.U. ID 011). The equipment outage was expected to occur from July 7, 2003 through August 31, 2003. However, the baghouse was not taken off-line for maintenance. Instead, the compressor to the baghouse failed on July 16, 2003, making the baghouse inoperable. TEC immediately performed a visible emissions (VE) test on the same day. Enclosed is a copy of the VE performed on July 16, 2003.

TEC agrees to make the necessary repairs to the compressor and place it back into service as soon as possible. While the baghouse is off-line to repair the compressor, TEC agrees to perform a daily VE test and maintain copies at the facility site. This will ensure that the 5% opacity requirement is being met.

Given the moisture content of the limestone and other mitigating factors, TEC will be requesting to remove the baghouse from this emission unit from the Big Bend Station Title V Air Operating Permit during a clean up of the Title V Operating Permit this fall.


Mr. Sterlin Woodard

July 23, 2003

Page 2 of 2

TEC appreciates your attention to this matter. If you have any questions, please contact Ms. Shelly Castro or me at (813) 641-5033.

Sincerely,



Laura Crouch  
Manager - Air Programs  
Environmental Affairs

EA/bmr/SSC164

Enclosure

cc: Mr. Al Linero - FDEP  
Mr. Jerry Kissel - FDEP SW  
Mr. Buck Oven - FDEP  
Mr. Scott Sheplak - FDEP

**VISIBLE EMISSION OBSERVATION**

E-101 R 10/83

SOURCE NAME		SOURCE LOCATION		OBSERVATION DATE		START TIME		STOP TIME	
TRUCK UNLOADING - LSTH001		BIG BEND ST - CAN		7-16-03		9:00		9:30	
TYPE OF FACILITY		SEC.		MIN		SEC		MIN	
COAL POWER PLANT		0		15		30		45	
DISTANCE FROM OBSERVER		1		2		3		4	
40'		0		0		0		0	
KEY CONDITIONS/PLUME BACKGROUND		5		6		7		8	
Scattered / metal structure		0		0		0		0	
SOURCE LAYOUT SKETCH		9		10		11		12	
DRAW NORTH ARROW		0		0		0		0	
		13		14		15		16	
SUN ← WIND →		17		18		19		20	
AVERAGE OPACITY		21		22		23		24	
- 0 -		0		0		0		0	
WIND SPEED (EST.)		25		26		27		28	
LS		0		0		0		0	
WIND DIRECTION (EST.)		29		30		31		32	
SSE		0		0		0		0	
OBSERVER'S NAME (PRINT)		33		34		35		36	
B.S. KATZARAS		0		0		0		0	
OBSERVER'S SIGNATURE		37		38		39		40	
<i>B.S. Katzaras</i>		0		0		0		0	
DATE		41		42		43		44	
7-16-03		0		0		0		0	
COMMENTS		45		46		47		48	
Limbo is wet. No dust		0		0		0		0	
5 TRUCKS UNLOADED		49		50		51		52	
# 20073, 41295, 41299, 40968, 41185, +UNK		0		0		0		0	
		53		54		55		56	
		0		0		0		0	
		57		58		59		60	
		0		0		0		0	
		61		62		63		64	
		0		0		0		0	
		65		66		67		68	
		0		0		0		0	
		69		70		71		72	
		0		0		0		0	
		73		74		75		76	
		0		0		0		0	
		77		78		79		80	
		0		0		0		0	

**COPY OF VISIBLE EMISSIONS CERTIFICATION CARD**

**BILL KATZARAS**  
has completed the STATE OF FLORIDA visible emissions evaluation training and is a qualified observer of visible emissions as specified by EPA Reference Method 9.

8/20/2003  
FIELD EXPIRATION DATE

303835  
CERTIFICATION NUMBER

TMPF04  
LECTURE EXPIRATION DATE

*B.S. Katzaras*  
BEARER'S SIGNATURE



**TAMPA ELECTRIC**

September 2, 2003

Mr. Sterlin Woodard  
Environmental Protection Commission  
of Hillsborough County  
1410 21<sup>st</sup> Street  
Tampa, Florida 33605

**Via FedEx**  
**Airbill No. 7923 1944 7407**

**Re: Tampa Electric Company  
Big Bend Station  
Permit No. 0570039-010-AV  
E.U. ID 011 - Truck/Railcar Limestone Unloading  
Receiving Hopper with Baghouse**

Dear Mr. Woodard:

This is a follow up letter to notify you that the repairs to the compressor were made and the equipment was placed back into service on August 7, 2003. While the baghouse was off-line to repair the compressor, TEC performed daily visible emission (VE) test and the records are at the facility site. The VE tests were performed to ensure that the 5% opacity requirement was met. . Enclosed are copies of the VE tests performed while the baghouse was out of service.

Initially, a notification that was provided on July 8, 2003 regarding an equipment outage for the Truck/Railcar Limestone Unloading Receiving Hopper with Baghouse, emission unit identification 011 (E.U. ID 011). The equipment outage was expected to occur from July 7, 2003 through August 31, 2003. However, the baghouse was not taken off-line for maintenance. Instead, the compressor to the baghouse failed on July 16, 2003, making the baghouse inoperable. TEC immediately performed a visible emissions (VE) test on the same day.

Given the moisture content of the limestone and other mitigating factors, TEC will be requesting to remove the baghouse from this emission unit from the Big Bend Station Title V Air Operating Permit during a clean up of the Title V Operating Permit this fall.



Mr. Sterlin Woodard  
September 2, 2003  
Page 2 of 2

If you have any questions, please contact Ms. Shelly Castro or me at (813) 641-5033.

Sincerely,



Laura R. Crouch  
Manager - Air Programs  
Environmental Affairs

EA/bmr/SSC167

cc: Mr. Al Linero - FDEP  
Mr. Jerry Kissel - FDEP SW  
Mr. Buck Oven - FDEP  
Mr. Scott Sheplak - FDEP

[https://www.fedex.com/cgi-bin/ship\\_it/interNetShip](https://www.fedex.com/cgi-bin/ship_it/interNetShip)

9/2/2003

# EPA VISIBLE EMISSION OBSERVATION FORM 1

Used (Circle One)  
Method 9      203A      2038      Other: \_\_\_\_\_

Company Name Tampa Electric  
 Facility Name Big Bend Station  
 Street Address \_\_\_\_\_  
 City \_\_\_\_\_ State \_\_\_\_\_ Zip \_\_\_\_\_

Process Coal Fired Power Plant Unit # \_\_\_\_\_ Operating Mode \_\_\_\_\_  
 Control Equipment \_\_\_\_\_ Operating Mode \_\_\_\_\_

Describe Emission Point  
Truck Dump bed over chute grating

Height of Emiss. Pt.		Height of Emiss. Pt. Rel. to Observer	
Start	End	Start	End
Distance to Emiss. Pt.		Direction to Emiss. Pt. (Degrees)	
Start	End	Start	End


Vertical Angle to Obs. Pt.		Direction to Obs. Pt. (Degrees)	
Start	End	Start	End
Distance and Direction to Observation Point from Emission Point			
Start	End		

Describe Emissions

Start	End	Water Droplet Plume
Emission Color		Attached <input type="checkbox"/> Detached <input type="checkbox"/> None <input type="checkbox"/>

Describe Plume Background

Start	End	Sky Conditions
Background Color		Start <u>Partly cloudy</u> End <u>partly cloudy</u>
Start	End	Wind Direction
Wind Speed		Start <u>W</u> End <u>W</u>
Start <u>5-7</u>	End <u>5-7</u>	Wet Bulb Temp.
Ambient Temp.		RH Percent
Start	End	



Additional Information  
25560 Lbs Tax  
73260 Gross Lbs

Form Number \_\_\_\_\_ Page \_\_\_\_\_ Of \_\_\_\_\_  
 Continued on VEO Form Number \_\_\_\_\_

Min	Time Zone				Comments
	Sec	0	15	30	
Observation Date <u>7-18-03</u> Start Time <u>1405</u> End Time <u>1435</u>					
1	0	0	0	0	
2	0	0	0	0	
3	0	0	0	0	
4	0	0	0	0	
5	0	0	0	0	
6	0	0	0	0	
7	0	0	0	0	
8	0	0	0	0	
9	0	0	0	0	
10	0	0	0	0	* Last Truck
11					unloaded @ 1435
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					

**BILL KLOOSTERMAN**

has completed the STATE OF FLORIDA visible emissions evaluation training and is a qualified observer of visible emissions as specified by EPA Reference Method 9.

8/20/2003      TMPS06

FIELD EXPIRATION DATE      LECTURE EXPIRATION DATE




**FLORIDA**

303837

*Bill Kloosterman*

**VISIBLE EMISSION OBSERVATION**

E-496 R 10/85

SOURCE NAME LST-001 Lester Truck Unloading		SOURCE LOCATION BIG BEND STATION			OBSERVATION DATE 7-21-03		START TIME 10:05		STOP TIME 10:35	
TYPE OF FACILITY COAL POWER GENERATION					SEC.					
DISTANCE FROM OBSERVER 40'					MIN	0	15	30	45	SEC
SKY CONDITIONS/PLUME BACKGROUND Scattered Buildings					1	0	0	0	0	31
SOURCE LAYOUT SKETCH DRAW NORTH ARROW 					2	0	0	0	0	32
					3	0	0	0	0	33
SUN → WIND →					4	0	0	0	0	34
AVERAGE OPACITY 0					5	0	0	0	0	35
WIND SPEED (EST.) 5-10		WIND DIRECTION (EST.) SW			6	0	0	0	0	36
OBSERVER'S NAME (PRINT) B.S. KATZARAS					7	0	0	0	0	37
OBSERVER'S SIGNATURE 		DATE 7-21-03			8	0	0	0	0	38
COMMENTS Truck #15					9	0	0	0	0	39
40073, 40660, 808077, 20077					10	0	0	0	0	40
808066, 41170, 20059, 40221					11	0	0	0	0	41
20030, 20008					12	0	0	0	0	42
Limestone is wet - no dust					13	0	0	0	0	43
COPY OF VISIBLE EMISSIONS CERTIFICATION CARD					14	0	0	0	0	44
					15	0	0	0	0	45
					16	0	0	0	0	46
					17	0	0	0	0	47
					18	0	0	0	0	48
					19	0	0	0	0	49
					20	0	0	0	0	50
					21	0	0	0	0	51
					22	0	0	0	0	52
					23	0	0	0	0	53
					24	0	0	0	0	54
					25	0	0	0	0	55
					26	0	0	0	0	56
					27	0	0	0	0	57
					28	0	0	0	0	58
					29	0	0	0	0	59
					30	0	0	0	0	60

**VISIBLE EMISSION OBSERVATION**

E-496 R 10/85

SOURCE NAME: EST-001  
 SOURCE LOCATION: 816 BEND STATION


OBSERVATION DATE: 7-22-03  
 START TIME: 9:23  
 STOP TIME: 9:53

TYPE OF FACILITY: COAL POWER GENERATION

SEC.	MIN	0	15	30	45	SEC	MIN	0	15	30	45
1	0	0	0	0	0	31					
2	0	0	0	0	0	32					
3	0	0	0	0	0	33					
4	0	0	0	0	0	34					
5	0	0	0	0	0	35					
6	0	0	0	0	0	36					
7	0	0	0	0	0	37					
8	0	0	0	0	0	38					
9	0	0	0	0	0	39					
10	0	0	0	0	0	40					
11	0	0	0	0	0	41					
12	0	0	0	0	0	42					
13	0	0	0	0	0	43					
14	0	0	0	0	0	44					
15	0	0	0	0	0	45					
16	0	0	0	0	0	46					
17	0	0	0	0	0	47					
18	0	0	0	0	0	48					
19	0	0	0	0	0	49					
20	0	0	0	0	0	50					
21	0	0	0	0	0	51					
22	0	0	0	0	0	52					
23	0	0	0	0	0	53					
24	0	0	0	0	0	54					
25	0	0	0	0	0	55					
26	0	0	0	0	0	56					
27	0	0	0	0	0	57					
28	0	0	0	0	0	58					
29	0	0	0	0	0	59					
30	0	0	0	0	0	60					

DISTANCE FROM OBSERVER: 40'

SKY CONDITIONS/PLUME BACKGROUND: Scattered / Buildings



AVERAGE OPACITY: -1-

WIND SPEED (EST.): 5-10 WIND DIRECTION (EST.): SE

OBSERVER'S NAME (PRINT): B.S. KATZARAS

OBSERVER'S SIGNATURE: [Signature] DATE: 7-22-03

COMMENTS: 4000 ID # 15  
20074, 40979, 20059, 608998,  
20057, 20156, 41299, 622420

COPY OF VISIBLE EMISSIONS CERTIFICATION CARD

**BILL KATZARAS**  
 has completed the STATE OF FLORIDA visible emissions evaluation training and is a qualified observer of visible emissions as specified by EPA Reference Method 9.




8/20/2003 FIELD EXPIRATION DATE  
 303835 CERTIFICATION NUMBER

TMPF04 LECTURE EXPIRATION DATE  
[Signature] BEARER'S SIGNATURE

SEC.	MIN	0	15	30	45	SEC	MIN	0	15	30	45
1	0	0	0	0	0	31					
2	0	0	0	0	0	32					
3	0	0	0	0	0	33					
4	0	0	0	0	0	34					
5	0	0	0	0	0	35					
6	0	0	0	0	0	36					
7	0	0	0	0	0	37					
8	0	0	0	0	0	38					
9	0	0	0	0	0	39					
10	0	0	0	0	0	40					
11	0	0	0	0	0	41					
12	0	0	0	0	0	42					
13	0	0	0	0	0	43					
14	0	0	0	0	0	44					
15	0	0	0	0	0	45					
16	0	0	0	0	0	46					
17	0	0	0	0	0	47					
18	0	0	0	0	0	48					
19	0	0	0	0	0	49					
20	0	0	0	0	0	50					
21	0	0	0	0	0	51					
22	0	0	0	0	0	52					
23	0	0	0	0	0	53					
24	0	0	0	0	0	54					
25	0	0	0	0	0	55					
26	0	0	0	0	0	56					
27	0	0	0	0	0	57					
28	0	0	0	0	0	58					
29	0	0	0	0	0	59					
30	0	0	0	0	0	60					

**VISIBLE EMISSION OBSERVATION**

E-496 R 10/85

SOURCE NAME LSH-021		SOURCE LOCATION RIG BEND STATION				OBSERVATION DATE 7-23-03				START TIME 8:05				STOP TIME 8:48					
TYPE OF FACILITY COAL POWER GENERATION										SEC.					SEC.				
DISTANCE FROM OBSERVER 40'										MIN	0	15	30	45	MIN	0	15	30	45
SKY CONDITIONS/PLUME BACKGROUND Scattered / Building										1	0	0	0	0	31				
SOURCE LAYOUT SKETCH DRAW NORTH ARROW 										2	0	0	0	0	32				
										3	0	0	10	0	33				
SUN-O WIND->										4	0	0	0	0	34				
										5	0	0	0	0	35				
AVERAGE OPACITY - 1 -										6	0	0	0	0	36				
WIND SPEED (EST.) 5-10					WIND DIRECTION (EST.) S					7	0	0	0	0	37				
OBSERVER'S NAME (PRINT) B.S. KATZARAS										8	0	0	0	0	38				
OBSERVER'S SIGNATURE 					DATE 7-23-03					9	0	0	0	0	39				
COMMENTS 40176, 41021, 40590, 40852 41136, 40079 Note Time Period was actually 43 minutes <del>Site</del> (waited for trucks for measurements)										10	0	0	0	0	40				
COPY OF VISIBLE EMISSIONS CERTIFICATION CARD 										11	0	0	0	5	41				
										12	0	0	0	0	42				
										13	0	0	0	0	43				
										14	0	0	0	0	44				
										15	0	0	0	0	45				
										16	0	0	0	0	46				
										17	0	0	0	0	47				
										18	0	0	0	0	48				
										19	0	0	0	0	49				
										20	0	0	0	0	50				
										21	0	0	0	0	51				
										22	0	0	0	0	52				
										23	0	0	0	0	53				
										24	0	0	0	0	54				
										25	0	0	20	10	55				
										26	0	0	0	0	56				
										27	0	0	0	0	57				
										28	0	0	0	0	58				
										29	0	0	0	0	59				
										30	0	0	0	0	60				

**VISIBLE EMISSION OBSERVATION**

E-496 R 10/85

SOURCE NAME: LSH-001  
LODGE TRUCK UNLOAD  
 TYPE OF FACILITY: COAL POWER GENERATION

SOURCE LOCATION: B16 BEND STATION


OBSERVATION DATE: 7-24-03

START TIME: 8:27

STOP TIME: 8:57

DISTANCE FROM OBSERVER: 421'

SKY CONDITIONS/PLUME BACKGROUND: CLEAR / BUILDING



AVERAGE OPACITY: - 0 -

WIND SPEED (EST.): 5-10

WIND DIRECTION (EST.): SSE

OBSERVER'S NAME (PRINT): B. S. KATZARAS

OBSERVER'S SIGNATURE: [Signature]

DATE: 7/24/03

COMMENTS: 41273, 20074, 40968, 41299,  
40590, 40979

COPY OF VISIBLE EMISSIONS CERTIFICATION CARD

**BILL KATZARAS**

has completed the STATE OF FLORIDA visible emissions evaluation training and is a qualified observer of visible emissions as specified by EPA Reference Method 9.

8/20/2003 FIELD EXPIRATION DATE

303835 CERTIFICATION NUMBER

TMPF04 LECTURE EXPIRATION DATE

[Signature] BEARER'S SIGNATURE

SEC.	MIN				SEC	MIN			
	0	15	30	45		0	15	30	45
1	0	0	0	0	31				
2	0	0	0	0	32				
3	0	0	0	0	33				
4	0	0	0	0	34				
5	0	0	0	0	35				
6	0	0	0	0	36				
7	0	0	0	0	37				
8	0	0	0	0	38				
9	0	0	0	0	39				
10	0	0	0	0	40				
11	0	0	0	0	41				
12	0	0	0	0	42				
13	0	0	0	0	43				
14	0	0	0	0	44				
15	0	0	0	0	45				
16	0	0	0	0	46				
17	0	0	0	0	47				
18	0	0	0	0	48				
19	0	0	0	0	49				
20	0	0	0	0	50				
21	0	0	0	0	51				
22	0	0	0	0	52				
23	0	0	0	0	53				
24	0	0	0	0	54				
25	0	0	0	0	55				
26	0	0	0	0	56				
27	0	0	0	0	57				
28	0	0	0	0	58				
29	0	0	0	0	59				
30	0	0	0	0	60				

SOURCE NAME: LSH-001  
SOURCE LOCATION: BIG BEND STATION

OBSERVATION DATE: 7-25-03  
START TIME: 7:55  
STOP TIME: 9:27

TYPE OF FACILITY: COAL POWER GENERATION


SEC.	MIN				SEC			
	0	15	30	45	0	15	30	45

DISTANCE FROM OBSERVER: 40'

1	0	0	0	0	31				
---	---	---	---	---	----	--	--	--	--

SKY CONDITIONS/PLUME BACKGROUND: clear / Building

2	0	0	0	0	32				
---	---	---	---	---	----	--	--	--	--



3	0	0	0	0	33				
---	---	---	---	---	----	--	--	--	--

AVERAGE OPACITY: 0

4	0	0	0	0	34				
---	---	---	---	---	----	--	--	--	--

WIND SPEED (EST.): 5-10  
WIND DIRECTION (EST.): SE

5	0	0	0	0	35				
---	---	---	---	---	----	--	--	--	--

OBSERVER'S NAME (PRINT): B.S. KATZARAS

6	0	0	0	0	36				
---	---	---	---	---	----	--	--	--	--

OBSERVER'S SIGNATURE: [Signature]  
DATE: 7/25/03

7	0	0	0	0	37				
---	---	---	---	---	----	--	--	--	--

COMMENTS: 73922, 20074, 40873, 40590  
41149, 41065, 41021, 40982  
(extended time due to truck traffic)

8	0	0	0	0	38				
---	---	---	---	---	----	--	--	--	--

COPY OF VISIBLE EMISSIONS CERTIFICATION CARD

9	0	0	0	0	39				
---	---	---	---	---	----	--	--	--	--

COPY OF VISIBLE EMISSIONS CERTIFICATION CARD

10	0	0	0	0	40				
----	---	---	---	---	----	--	--	--	--

COPY OF VISIBLE EMISSIONS CERTIFICATION CARD

11	0	0	0	0	41				
----	---	---	---	---	----	--	--	--	--

COPY OF VISIBLE EMISSIONS CERTIFICATION CARD

12	0	0	0	0	42				
----	---	---	---	---	----	--	--	--	--

COPY OF VISIBLE EMISSIONS CERTIFICATION CARD

13	0	0	0	0	43				
----	---	---	---	---	----	--	--	--	--

COPY OF VISIBLE EMISSIONS CERTIFICATION CARD

14	0	0	0	0	44				
----	---	---	---	---	----	--	--	--	--

COPY OF VISIBLE EMISSIONS CERTIFICATION CARD

15	0	0	0	0	45				
----	---	---	---	---	----	--	--	--	--

COPY OF VISIBLE EMISSIONS CERTIFICATION CARD

16	0	0	0	0	46				
----	---	---	---	---	----	--	--	--	--

COPY OF VISIBLE EMISSIONS CERTIFICATION CARD

17	0	0	0	0	47				
----	---	---	---	---	----	--	--	--	--

COPY OF VISIBLE EMISSIONS CERTIFICATION CARD

18	0	0	0	0	48				
----	---	---	---	---	----	--	--	--	--

COPY OF VISIBLE EMISSIONS CERTIFICATION CARD

19	0	0	0	0	49				
----	---	---	---	---	----	--	--	--	--

COPY OF VISIBLE EMISSIONS CERTIFICATION CARD

20	0	0	0	0	50				
----	---	---	---	---	----	--	--	--	--

COPY OF VISIBLE EMISSIONS CERTIFICATION CARD

21	0	0	0	0	51				
----	---	---	---	---	----	--	--	--	--

COPY OF VISIBLE EMISSIONS CERTIFICATION CARD

22	0	0	0	0	52				
----	---	---	---	---	----	--	--	--	--

COPY OF VISIBLE EMISSIONS CERTIFICATION CARD

23	0	0	0	0	53				
----	---	---	---	---	----	--	--	--	--

24	0	0	0	0	54				
----	---	---	---	---	----	--	--	--	--

25	0	0	0	0	55				
----	---	---	---	---	----	--	--	--	--

26	0	0	0	0	56				
----	---	---	---	---	----	--	--	--	--

27	0	0	0	5	57				
----	---	---	---	---	----	--	--	--	--

28	0	0	0	0	58				
----	---	---	---	---	----	--	--	--	--

29	0	0	0	0	59				
----	---	---	---	---	----	--	--	--	--

30	0	0	0	0	60				
----	---	---	---	---	----	--	--	--	--

**VISIBLE EMISSION OBSERVATION**

E-496 R 10/85


SOURCE NAME LH5001 SOURCE LOCATION Big Bend Station  
Stone Truck Wash

OBSERVATION DATE 7-28-03 START TIME 0839 STOP TIME 0916

NAME OF FACILITY Coal Power Generation Station  
 DISTANCE FROM OBSERVER 40'

SEC.	MIN	0	15	30	45	SEC	MIN	0	15	30	45
1	0	0	0	0	0	31	0	0	0	0	0
2	0	0	0	0	0	32	0	0	0	0	0
3	0	0	0	0	0	33	0	0	0	0	0
4	0	5	0	0	0	34	0	0	0	0	0
5	0	0	0	0	0	35	0	0	0	0	0
6	0	0	0	0	0	36	0	0	0	0	0
7	0	0	0	0	0	37	0	0	0	0	0
8	0	0	5	0	0	38	0	0	0	0	0
9	0	0	0	0	0	39					
10	0	0	0	0	0	40					
11	0	0	0	0	0	41					
12	0	0	0	0	0	42					
13	0	0	0	0	0	43					
14	0	0	0	0	0	44					
15	0	0	0	0	0	45					
16	0	0	0	0	0	46					
17	0	0	0	0	0	47					
18	0	0	0	0	0	48					
19	0	0	0	0	0	49					
20	0	0	0	0	0	50					
21	0	0	0	0	0	51					
22	0	0	0	0	0	52					
23	0	0	0	0	0	53					
24	0	0	0	0	0	54					
25	0	0	0	0	0	55					
26	0	0	0	0	0	56					
27	0	0	0	0	0	57					
28	0	0	0	0	0	58					
29	0	0	0	0	0	59					
30	0	0	0	0	0	60					

SKY CONDITIONS/PLUME BACKGROUND Clear Building



AVERAGE OPACITY - 0

WIND SPEED (EST.) 5-7 WIND DIRECTION (EST.) S

OBSERVER'S NAME (PRINT) Bill R Kloosterman

OBSERVER'S SIGNATURE Bill R Kloosterman DATE 7-28-03

COMMENTS 20008, 41573, 41180, 40929  
(Truck #)

COPY OF VISIBLE EMISSIONS CERTIFICATION CARD

**BILL-KLOOSTERMAN**

has completed the STATE OF FLORIDA visible emissions evaluation training and is a qualified observer of visible emissions as specified by EPA Reference Method 9.

8/20/2003 FIELD EXPIRATION DATE  
 TMPS06 LECTURE EXPIRATION DATE

303837 CERTIFICATION NUMBER  
Bill R Kloosterman BEARER'S SIGNATURE



**VISIBLE EMISSION OBSERVATION**

E-496 R 1085

SOURCE NAME *LHS-001* SOURCE LOCATION *Big Bend Station*


OBSERVATION DATE *7-29-03* START TIME *0812/0840* STOP TIME *0821/0848*

TYPE OF FACILITY *Coal Power Generation Station*

SEC.	0	15	30	45	SEC.	0	15	30	45
1	0	0	0	0	31				
2	0	0	0	0	32				
3	0	0	0	0	33				
4	0	0	0	0	34				
5	0	0	0	0	35				
6	0	0	0	0	36				
7	0	0	0	0	37				
8	5	0	0	0	38				
9	0	0	0	0	39				
10	0	0	0	0	40				
11					41				
12	0	0	0	0	42				
13	0	0	0	0	43				
14	0	0	0	0	44				
15	0	0	0	0	45				
16	0	0	0	0	46				
17	0	0	0	0	47				
18	0	0	0	0	48				
19	0	0	0	0	49				
20	0	0	0	0	50				
21					51				
22					52				
23					53				
24					54				
25					55				
26					56				
27					57				
28					58				
29					59				
30					60				

DISTANCE FROM OBSERVER *40'*

SKY CONDITIONS/PLUME BACKGROUND *Clear / Building*



AVERAGE OPACITY *0*

WIND SPEED (EST.) *1-5* WIND DIRECTION (EST.) *W*

OBSERVER'S NAME (PRINT) *Bill R. Kloosterman*

OBSERVER'S SIGNATURE *Bill R. Kloosterman* DATE *7-29-03*

COMMENTS *40590, 40260, 20074*

*(Truck #'s) split Time*

COPY OF VISIBLE EMISSIONS CERTIFICATION CARD

**BILL KLOOSTERMAN**

has completed the STATE OF FLORIDA visible emissions evaluation training and is a qualified observer of visible emissions as specified by EPA Reference Method 9.

8/20/2003 TMPS06

FIELD EXPIRATION DATE LECTURE EXPIRATION DATE

**FLORIDA**

303837 BEARER'S SIGNATURE *Bill R. Kloosterman*

SEC.	0	15	30	45	SEC.	0	15	30	45
1	0	0	0	0	31				
2	0	0	0	0	32				
3	0	0	0	0	33				
4	0	0	0	0	34				
5	0	0	0	0	35				
6	0	0	0	0	36				
7	0	0	0	0	37				
8	5	0	0	0	38				
9	0	0	0	0	39				
10	0	0	0	0	40				
11					41				
12	0	0	0	0	42				
13	0	0	0	0	43				
14	0	0	0	0	44				
15	0	0	0	0	45				
16	0	0	0	0	46				
17	0	0	0	0	47				
18	0	0	0	0	48				
19	0	0	0	0	49				
20	0	0	0	0	50				
21					51				
22					52				
23					53				
24					54				
25					55				
26					56				
27					57				
28					58				
29					59				
30					60				

**VISIBLE EMISSION OBSERVATION**


E-498 R 1085

SOURCE NAME LH5001 SOURCE LOCATION Big Bend Station  
Stone Truck unloading  
 TYPE OF FACILITY Coal Power Generation Station

OBSERVATION DATE 7-30-03 START TIME 0842 STOP TIME 0904

DISTANCE FROM OBSERVER 40'

SKY CONDITIONS/PLUME BACKGROUND clear / Building



AVERAGE OPACITY 0

WIND SPEED (EST.) 5-7 WIND DIRECTION (EST.) SW

OBSERVER'S NAME (PRINT) Bill R Kloosterman

OBSERVER'S SIGNATURE Bill R. Kloosterman DATE 7-30-03

COMMENTS  
41021, H30, 20074  
(Truck #)

COPY OF VISIBLE EMISSIONS CERTIFICATION CARD

**BILL-KLOOSTERMAN**  
 has completed the STATE OF FLORIDA visible emissions evaluation training and is a qualified observer of visible emissions as specified by EPA Reference Method 9.  
 8/20/2003 TMPS06  
 FIELD EXPIRATION DATE LECTURE EXPIRATION DATE  
**FLORIDA**  
 303837  
 CERTIFICATION NUMBER BEARER'S SIGNATURE Bill R. Kloosterman

SEC.	OBSERVATION DATE				START TIME		STOP TIME			
	MIN	0	15	30	45	MIN	0	15	30	45
1	0	0	0	0	31					
2	0	0	0	0	32					
3	0	0	0	0	33					
4	0	0	0	0	34					
5	0	5	0	0	35					
6	0	0	0	0	36					
7	0	0	0	0	37					
8	0	0	0	0	38					
9	0	0	0	0	39					
10	0	0	0	0	40					
11	0	0	0	0	41					
12	0	0	0	0	42					
13	0	0	0	0	43					
14	0	0	0	0	44					
15	0	0	0	0	45					
16	0	0	0	0	46					
17	0	0	0	0	47					
18	0	0	0	0	48					
19	0	0	0	0	49					
20	0	0	0	0	50					
21	0	0	0	0	51					
22	0	0	0	0	52					
23					53					
24					54					
25					55					
26					56					
27					57					
28					58					
29					59					
30					60					

**VISIBLE EMISSION OBSERVATION**

E-496 R 10/85

SOURCE NAME		SOURCE LOCATION			OBSERVATION DATE				START TIME				STOP TIME					
Limestone Truck Unloading		Big Bend Station			7/31/03				0700				0730					
TYPE OF FACILITY					SEC.				SEC.									
Coal Powered Generation					MIN	0	15	30	45	MIN	0	15	30	45				
DISTANCE FROM OBSERVER					1	0	0	0	0	31								
45'					2	0	0	0	0	32								
SKY CONDITIONS/PLUME BACKGROUND					3	0	0	0	0	33								
Clear					4	0	0	0	0	34								
SOURCE LAYOUT SKETCH					5	0	0	0	0	35								
DRAW NORTH ARROW					6	0	0	0	0	36								
<p>X EMISSION POINT</p> <p>OBSERVERS POSITION</p> <p>SUN LOCATION LINE</p> <p>140°</p> <p>SUN ← WIND →</p>					7	0	0	0	0	37								
AVERAGE OPACITY					8	0	0	0	0	38								
0					9	0	0	0	0	39								
WIND SPEED (EST.)		WIND DIRECTION (EST.)			10	0	0	0	0	40								
1-5		SE			11	0	0	0	0	41								
OBSERVER'S NAME (PRINT)					12	0	0	0	0	42								
Troy Mussetter					13	0	0	0	0	43								
OBSERVER'S SIGNATURE		DATE			14	0	0	0	0	44								
<i>Troy L. Mussetter</i>		7/31/03			15	0	0	0	0	45								
COMMENTS					16	0	0	0	0	46								
Truck #'s 20074, 40176, 40221,					17	0	0	0	0	47								
# 41149					18	0	0	0	0	48								
					19	0	0	0	0	49								
					20	0	0	0	0	50								
					21	0	0	0	0	51								
COPY OF VISIBLE EMISSIONS CERTIFICATION CARD					22	0	0	0	0	52								
<p>TROY MUSSETTER</p> <p>has completed the STATE OF FLORIDA visible emissions evaluation training and is a qualified observer of visible emissions as specified by EPA Reference Method 9.</p> <p>8/20/2003      TMPS06</p> <p>FIELD EXPIRATION DATE      LECTURE EXPIRATION DATE</p> <p>303836      <i>Troy L. Mussetter</i></p> <p>CERTIFICATION NUMBER      BEARER'S SIGNATURE</p>					23	0	0	0	0	53								
					24	0	0	0	0	54								
					25	0	0	0	0	55								
					26	0	0	0	0	56								
					27	0	0	0	0	57								
					28	0	0	0	0	58								
					29	0	0	0	0	59								
					30	0	0	0	0	60								

**VISIBLE EMISSION OBSERVATION**  
E-496 R 10/85

SOURCE NAME: Stone Truck Unloading Big Bend Station  
SOURCE LOCATION: Big Bend Station  
TYPE OF FACILITY: Coal Powered Generation


OBSERVATION DATE: 8/1/03 START TIME: 0645 STOP TIME: 0715

DISTANCE FROM OBSERVER: 45'

SEC.	MIN	0	15	30	45	SEC	MIN	0	15	30	45
1	0	0	0	0	0	31					
2	0	0	0	0	0	32					
3	0	0	0	0	0	33					
4	0	0	0	0	0	34					
5	0	0	0	0	0	35					
6	0	0	0	0	0	36					
7	0	0	0	0	0	37					
8	0	0	0	0	0	38					
9	0	0	0	0	0	39					
10	0	0	0	0	0	40					
11	0	0	0	0	0	41					
12	0	0	0	0	0	42					
13	0	0	0	0	0	43					
14	0	0	0	0	0	44					
15	0	0	0	0	0	45					
16	0	0	0	0	0	46					
17	0	0	0	0	0	47					
18	0	0	0	0	0	48					
19	0	0	0	0	0	49					
20	0	0	0	0	0	50					
21	0	0	0	0	0	51					
22	0	0	0	0	0	52					
23	0	0	0	0	0	53					
24	0	0	0	0	0	54					
25	0	0	0	0	0	55					
26	0	0	0	0	0	56					
27	0	0	0	0	0	57					
28	0	0	0	0	0	58					
29	0	0	0	0	0	59					
30	0	0	0	0	0	60					

SKY CONDITIONS/PLUME BACKGROUND: Clear

SOURCE LAYOUT SKETCH DRAW NORTH ARROW



AVERAGE OPACITY: 0

WIND SPEED (EST.): 1-2 WIND DIRECTION (EST.): S

OBSERVER'S NAME (PRINT): Troy Mussetter

OBSERVER'S SIGNATURE: Troy L. Mussetter DATE: 8/1/03

COMMENTS: #1028 Truck #'s

Material is damp ∴ No Dust

COPY OF VISIBLE EMISSIONS CERTIFICATION CARD

**TROY MUSSETTER**  
has completed the STATE OF FLORIDA visible emissions evaluation training and is a qualified observer of visible emissions as specified by EPA Reference Method 9.

8/20/2003 TMPS06  
FIELD EXPIRATION DATE LECTURE EXPIRATION DATE

303836 Troy L. Mussetter  
CERTIFICATION NUMBER BEARER'S SIGNATURE

SEC.	MIN	0	15	30	45	SEC	MIN	0	15	30	45
1	0	0	0	0	0	31					
2	0	0	0	0	0	32					
3	0	0	0	0	0	33					
4	0	0	0	0	0	34					
5	0	0	0	0	0	35					
6	0	0	0	0	0	36					
7	0	0	0	0	0	37					
8	0	0	0	0	0	38					
9	0	0	0	0	0	39					
10	0	0	0	0	0	40					
11	0	0	0	0	0	41					
12	0	0	0	0	0	42					
13	0	0	0	0	0	43					
14	0	0	0	0	0	44					
15	0	0	0	0	0	45					
16	0	0	0	0	0	46					
17	0	0	0	0	0	47					
18	0	0	0	0	0	48					
19	0	0	0	0	0	49					
20	0	0	0	0	0	50					
21	0	0	0	0	0	51					
22	0	0	0	0	0	52					
23	0	0	0	0	0	53					
24	0	0	0	0	0	54					
25	0	0	0	0	0	55					
26	0	0	0	0	0	56					
27	0	0	0	0	0	57					
28	0	0	0	0	0	58					
29	0	0	0	0	0	59					
30	0	0	0	0	0	60					

**VISIBLE EMISSION OBSERVATION**


E-496 R 1085

SOURCE NAME: LSH-001  
 SOURCE LOCATION: FROM TRUCK UNLOADING BIG BEND STATION  
 TYPE OF FACILITY: COAL POWER GENERATION

OBSERVATION DATE: 8-4-03  
 START TIME: 0800  
 STOP TIME: 0830

DISTANCE FROM OBSERVER: 401

SKY CONDITIONS/PLUME BACKGROUND: SCATTERED / BUILDING



AVERAGE OPACITY: - 3 -

WIND SPEED (EST.): 5-10  
 WIND DIRECTION (EST.): SE

OBSERVER'S NAME (PRINT): B.S. KATZARAS

OBSERVER'S SIGNATURE: [Signature]  
 DATE: 8-4-03

COMMENTS: 40112 / 41187 / 20073 / 40221 / 40112 /

SEC.	0	15	30	45	SEC.	0	15	30	45
1	0	0	0	5	31				
2	0	0	0	0	32				
3	0	0	0	0	33				
4	0	0	0	0	34				
5	0	0	25	5	35				
6	0	0	0	0	36				
7	0	0	0	0	37				
8	0	0	0	0	38				
9	0	0	0	0	39				
10	0	0	0	0	40				
11	0	0	0	0	41				
12	0	30	30	0	42				
13	0	0	0	0	43				
14	0	0	0	0	44				
15	0	0	0	0	45				
16	0	5	0	0	46				
17	0	0	0	0	47				
18	0	0	0	0	48				
19	0	0	0	0	49				
20	0	0	0	0	50				
21	0	0	0	0	51				
22	0	0	0	0	52				
23	0	0	0	0	53				
24	0	0	0	0	54				
25	0	0	0	0	55				
26	0	0	0	0	56				
27	0	0	0	0	57				
28	0	0	0	0	58				
29	0	0	0	0	59				
30	0	0	0	0	60				

COPY OF VISIBLE EMISSIONS CERTIFICATION CARD

**ENVIRONMENTAL PROTECTION**  
**BILL KATZARAS**

has completed the STATE OF FLORIDA visible emissions evaluation training and is a qualified observer of visible emissions as specified by EPA Reference Method 9.

8/20/2003  
 FIELD EXPIRATION DATE

TMPF04  
 LECTURE EXPIRATION DATE

FLORIDA  
 303835  
 CERTIFICATION NUMBER

[Signature]  
 BEARER'S SIGNATURE






**ATTACHMENT G**

**MODIFICATIONS TO**

**CONDITIONS OF CERTIFICATION**





Jeb Bush  
Governor

# Department of Environmental Protection

Marjory Stoneman Douglas Building  
3900 Commonwealth Boulevard  
Tallahassee, Florida 32399-3000


David B. Struhs  
Secretary

July 29, 2003

**- CERTIFIED MAIL - RETURN RECEIPT REQUESTED -**

Laura R. Crouch  
Manager, Air Programs  
Tampa Electric Company  
Post Office Box 111  
Tampa, Florida 33601-0111

**RE: Tampa Electric Company Big Bend Unit 4  
Modification to Conditions of Certification  
DEP Case Number PA 79-12L  
OGC Case Number 03-0413**



## ORDER MODIFYING CONDITIONS OF CERTIFICATION

Dear Ms Crouch:

On July 26, 2001, the Department issued Final Title V Operation Permit Revision No. 0570039-010-AV for the Tampa Electric Company Big Bend Unit 4. That permit revision authorized Big Bend Unit 4 to include petroleum coke as a fuel with limitations on the vanadium content and ash content of the petroleum coke. The permit revision also included revised operating, monitoring and reporting conditions to reflect the use of petroleum coke. Pursuant to Rule 62-17.211(4), Florida Administrative Code (F.A.C.) the Department proposes to modify the Conditions of Certification for this facility to conform them to the Title V Permit.

On June 9, 2003, all parties to the certification proceeding were provided with notice by certified mail of the Department's intent to modify the Conditions of Certification for this facility, along with a copy of the proposed Order Modifying Conditions of Certification. Additionally, on June 27, 2003, notice of the Department's intent to modify the Conditions of Certification for this facility was published in the Florida Administrative Weekly ("FAW"), and on the Department's internet home page at <http://www.dep.state.fl.us/> under the link or button titled "Official Notices." Those notices specified that pursuant to Section 403.516, Florida Statutes ("F.S."), and Rule 62-17.211, F.A.C., all parties to the certification proceeding have 45 days from the issuance of the notice by mail to such party's last address of record in which file a written objection to the modification; that any person who is not already a party to the certification proceeding and whose substantial interests will be affected by the requested modification has 30 days from the date of publication of the public notice in the FAW to object

in writing; that failure to act within the time frame constitutes a waiver of the right to become a party; and that the Department will issue a Final Order Modifying the Conditions of Certification for this facility if no written objections are received by the Department.

No objections to the modification have been received by the Department. The Conditions of Certification for the Tampa Electric Company Big Bend Unit 4 are hereby modified as follows:

I. Air

The construction and operation of Big Bend Unit 4 at the Tampa Electric Company steam electric power plant site shall be in accordance with all applicable provisions of Chapters 62-4, 62-210, 62-212, 62-213, 62-214, 62-256, 62-257, 62-296, 62-297, 62-302, and 62-701, Florida Administrative Code. In addition to the foregoing, the permittee shall comply with the following conditions of certification:

A. Emission Limitations

1. Based on a maximum heat input of 4,330 million BTU per hour, stack emissions from Big Bend Unit 4 (Emission Unit 004) shall not exceed the following when burning coal or a coal/petroleum coke blend:

a. ~~SO<sub>2</sub> - 1.2 lb. per million BTU heat input, maximum two hour average, 0.84 lb/MMBtu on a 30-day rolling average.~~ Sulfur dioxide emissions from Unit No. 4 when combusting solid fuel shall not exceed 0.82 lb/million Btu heat input and 10 percent of the potential combustion concentration (90 percent reduction). Based upon a heat input of 4330 million Btu/hour, SO<sub>2</sub> emissions shall not exceed 3551 lb/hr. Compliance with sulfur dioxide emission limitations and percent reduction requirements is determined on a 30-day rolling average basis. The sulfur dioxide emission standards apply at all times except during periods of startup, shutdown, or when both emergency conditions exist and the following procedures in specific condition I.A.15. are implemented.

b. NO<sub>x</sub> - 0.60 lb. per million BTU heat input. Nitrogen dioxide emissions from Unit No. 4 when combusting bituminous or anthracite coal, or a coal/petroleum coke blend, shall not exceed 0.60 lb/million Btu heat input. Based upon a heat input of 4330 million Btu/hour, NO<sub>x</sub> emissions shall not exceed 2598 lb/hr. These emission limits are based on a 30-day rolling average. These standards apply at all times except during periods of startup, shutdown, or malfunction.

c. Particulates - 0.03 lb. per million BTU heat input. This standard applies at all times except during periods of startup, shutdown, or malfunction. Based on the maximum permitted heat input rate listed in Specific Condition I.A.1., particulate matter emissions from Unit No. 4 shall not exceed 129.9 lbs/hour, 3118 lbs/day, and 569.0 tons/year.

d. No change

e. Carbon monoxide (CO) emissions from Unit No. 4 shall not exceed 0.029 lb/million Btu heat input, and shall not exceed 124 lb/hr.

2. through 9. No change

10. Operation Coal should not be burned in the unit unless both electrostatic precipitator and limestone scrubber are operating properly.

11. Coal burned in the unit should be washed before it is transported to the plant site.

12. Fuels fired shall consist of coal or a coal/petroleum coke blend containing a maximum of 20.0 percent petroleum coke by weight. The sulfur content of the petroleum coke shall not exceed 6.0 percent by weight (dry basis). Vanadium content of the mineral ash from the petroleum coke fired shall not exceed 35.0 percent by weight (ignited basis).

a. Normal operation: The only fuels fired in Unit No. 4 shall be coal or a coal/petroleum coke blend containing a maximum of 20.0% petroleum coke by weight. The vanadium content of the petroleum coke fired shall not exceed 2660 ppm. The ash content of the petroleum coke fired shall not exceed 0.76% by weight on a dry basis. The permittee shall maintain and submit to the Department, and to the Environmental Protection Commission of Hillsborough County, on an annual basis for the years 2001, 2002, 2003, 2004, and 2005 data demonstrating that removal of the sulfur content limit and the revision of the vanadium content limit in the petroleum coke fired did not result in a significant increase in the representative actual annual emissions of any regulated pollutant.

b. Other operation: In addition to the fuels allowed to be burned during normal operation, Unit No. 4 may also burn new No. 2 fuel oil during startup, shutdown, flame stabilization and during the start of an additional solid fuel crusher on an already operating unit. Evaporation of up to 150,000 gallons per year, total at the facility, is allowed of non-hazardous, but potentially HAP-emitting, mineral acid solution boiler chemical cleaning waste which was generated on site.

c. Coal shall not be burned in Unit No. 4 unless both the electrostatic precipitator and limestone scrubber are operating properly.

d. No change

e. TEC shall maintain a daily log of the amounts and types of fuels used and copies of fuel analyses containing information on sulfur content, ash content and heating values.

11. Tampa Electric Company is allowed to divert and integrate all of the flue gas from Unit No. 3 for purposes of treating that flue gas in the existing Unit No. 4 flue gas desulfurization (FGD) system.

12. Unit No. 4 is allowed to operate continuously, i.e., 8760 hours/year.

13. and 14. No change.

15. During emergency conditions in the principal company, an affected facility with a malfunctioning flue gas desulfurization system may be operated if sulfur dioxide emissions are minimized by:

a. No change

b. Bypassing flue gases around only those flue gas desulfurization system modules that have been taken out of operation because they were incapable of any sulfur dioxide emission reduction or which would have suffered significant physical damage if they had remained in operation, and

c. Operating a spare flue gas desulfurization system module. The Department or EPCHC may at their discretion require TEC within 60 days of notification to demonstrate spare module capability. To demonstrate this capability, the owner or operator must demonstrate compliance with the appropriate requirements of specific conditions I.A.1.a. and I.A.1.c. for any period of operation lasting from 24 hours to 30 days when:

(1) Any one flue gas desulfurization module is not operated,

(2) The affected facility is operating at the maximum heat input rate,

(3) The fuel fired during the 24-hour to 30-day period is representative of the type and average sulfur content of fuel used over a typical 30-day period, and

(4) TEC has given the Department or EPCHC at least 30 days notice of the date and period of time over which the demonstration will be performed.

#### B. Air Monitoring Program

1. ~~The permittee shall install and operate continuously monitoring devices for the Unit 4 boiler exhausts for sulfur dioxide, nitrogen dioxide, oxygen and/or carbon dioxide, and opacity. The monitoring devices shall meet the applicable requirements of Section 62-214, F.A.C., 40 CFR 60.47a, and 40 CFR 75. The opacity monitor may be placed in the ductwork between the electrostatic precipitator and the FGD scrubber.~~

a. When Units 3 and 4 are operating in the integrated mode (Unit 3 flue gasses routed through the Unit 4 FGD system), the continuous monitoring system will measure sulfur dioxide emissions at the inlet and outlet of the Unit 4 FGD system and from the Unit 3 stack, while emissions of nitrogen dioxides, oxygen and/or carbon dioxide, and opacity shall be measured in the Unit 4 duct prior to the FGD system.

b. When Units 3 and 4 are not operating in the integrated mode, the continuous monitoring system will measure only Unit 4's inlet duct and stack for SO<sub>2</sub> emissions. The emissions of nitrogen oxides, oxygen and/or carbon dioxide, and opacity shall be measured in the Unit 4 duct prior to the FGD system.

2. through 5. No change

6. TEC shall calibrate, maintain, and operate a continuous monitoring system, and record the output of the system, for measuring the opacity of emissions discharged to the atmosphere. If opacity interference due to water droplets exists in the stack (for example, from the use of an FGD system), the opacity is monitored upstream of the interference (at the inlet to the FGD system). If opacity interference is experienced at all locations (both at the inlet and outlet of the sulfur dioxide control system), alternate parameters indicative of the particulate matter control system's performance are monitored (subject to the approval of the Department and the Environmental Protection Commission of Hillsborough County [EPCHC]).

7. TEC shall calibrate, maintain, and operate a continuous monitoring system, and record the output of the system, for measuring sulfur dioxide emissions as follows:

a. Sulfur dioxide emissions are monitored at both the inlet and outlet of the sulfur dioxide control device.

b. An "as fired" fuel monitoring system (upstream of coal pulverizers) meeting the requirements of Method 19, Determination of Sulfur Dioxide Removal Efficiency and Particulate Matter, Sulfur Dioxide, and Nitrogen Oxides Emission Rates, may be used to determine potential sulfur dioxide emissions in place of a continuous sulfur dioxide emission monitor at the inlet to the sulfur dioxide control device as required in the preceding specific condition I.B.7.a.

8. TEC shall calibrate, maintain, and operate a continuous monitoring system, and record the output of the system, for measuring nitrogen oxides emissions discharged to the atmosphere.

9. TEC shall calibrate, maintain, and operate a continuous monitoring system, and record the output of the system, for measuring the oxygen and/or carbon dioxide content of the flue gases at each location where sulfur dioxide or nitrogen oxides emissions are monitored. The sulfur dioxide, nitrogen dioxide, oxygen and/or carbon dioxide, and opacity

monitoring devices shall meet the applicable requirements of Section 62-214, F.A.C., 40 CFR 60.47a., and 40 CFR 75. ). The opacity monitor shall be placed in the duct work between the electrostatic precipitator and the FGD scrubber. When Units 3 and 4 are operating in the integrated mode (Unit 3 flue gases routed through the Unit 4 FGD system), the continuous monitoring system will measure sulfur dioxide emissions at the inlet and outlet of the Unit 4 FGD system and from the Unit 3 stack (CS002), while emissions of nitrogen oxides, oxygen and/or carbon dioxide, and opacity shall be measured in the Unit 4 duct prior to the FGD system. When Units 3 and 4 are not operating in the integrated mode, the continuous monitoring system will measure only Unit 4's inlet duct and stack for SO<sub>2</sub> emissions. The emissions of nitrogen oxides, oxygen and/or carbon dioxide, and opacity shall be measured in the Unit 4 duct prior to the FGD system.

10. The continuous monitoring systems required in specific conditions B.7., B.8., and B.9., shall be operated and record data during all periods of operation of Unit No. 4 including periods of startup, shutdown, malfunction or emergency conditions, except for continuous monitoring system breakdowns, repairs, calibration checks, and zero and span adjustments.

11. TEC shall obtain emission data for at least 18 hours in at least 22 out of 30 successive boiler operating days. If this minimum data requirement cannot be met with a continuous monitoring system, TEC shall supplement emission data with other monitoring systems approved by the Department or the EPCHC, or the reference methods and procedures as described in Specific Condition B.13.

12. The 1-hour averages required under 40 CFR 60.13(h), *Monitoring Requirements*, are expressed in lbs/million Btu heat input and used to calculate the average emission rates required in specific conditions B.13. and B.14. The 1-hour averages are calculated using the data points required under 40 CFR 60.13(b), *Monitoring Requirements*. At least two data points must be used to calculate the 1-hour averages.

13. When it becomes necessary to supplement continuous monitoring system data to meet the minimum data requirements in specific condition B.21., TEC shall use the following reference methods and procedures. Acceptable alternative methods and procedures are given in specific condition B.25.

a. Method 6 shall be used to determine the SO<sub>2</sub> concentration at the same location as the SO<sub>2</sub> monitor. Samples shall be taken at 60-minute intervals. The sampling time and sample volume for each sample shall be at least 20 minutes and 0.020 dscm (0.71 dscf). Each sample represents a 1-hour average.

b. Method 7 shall be used to determine the NO<sub>x</sub> concentration at the same location as the NO<sub>x</sub> monitor. Samples shall be taken at 30-minute intervals. The arithmetic average of two consecutive samples represents a 1-hour average.

c. The emission rate correction factor, integrated bag sampling and analysis procedure of Method 3B shall be used to determine the O<sub>2</sub> or CO<sub>2</sub> concentration at the same location as the O<sub>2</sub> or CO<sub>2</sub> monitor. Samples shall be taken for at least 30 minutes in each hour. Each sample represents a 1-hour average.

d. The procedures in Method 19 shall be used to compute each 1-hour average concentration in lb/million Btu heat input.

14. TEC shall use the following methods and procedures to conduct the monitoring system performance evaluations required under 40 CFR 60.13(c), *Monitoring Requirements*, and the calibration checks required under 40 CFR 60.13(d), *Monitoring Requirements*. Acceptable alternative methods and procedures are given in specific condition B.25.

a. Methods 6, 7, and 3B, as applicable, shall be used to determine O<sub>2</sub>, SO<sub>2</sub>, and NO<sub>x</sub> concentrations.

b. SO<sub>2</sub> or NO<sub>x</sub> (NO), as applicable, shall be used for preparing the calibration gas mixtures (in N<sub>2</sub>, as applicable) under 40 CFR 60 Appendix B, *Performance Specification 2*.

c. The span value for a continuous monitoring system for measuring opacity is between 60 and 80 percent and for a continuous monitoring system measuring nitrogen oxides is determined as follows.

<u>Fossil Fuel</u>	<u>Span value for nitrogen oxides (ppm)</u>
<u>Solid</u>	<u>1,000</u>

d. Reserved

e. For affected facilities burning fossil fuel alone or in combination with non-fossil fuel, the span value of the sulfur dioxide continuous monitoring system at the inlet to the sulfur dioxide control device is 125 percent of the maximum estimated hourly potential emissions of the fuel fired, and the outlet of the sulfur dioxide control device is 50 percent of maximum estimated hourly potential emissions oil fuel, alone or in combination with non-fossil fuel, the span value of the fuel fired. [Rule 62-204.800(7)(b)2., F.A.C.; 40 CFR 60.47a(i); 40 CFR 60.13; 40 CFR 60 Appendix A, Methods 3B, 6, and 7; 40 CFR 60 Appendix B, *Performance Specification 2*.]

15. TEC may use the following as alternatives to the reference methods and procedures specified in conditions B.23. and B.24.

a. For Method 6, Method 6A or 6B (whenever Methods 6 and 3 or 3B data are used) or 6C may be used. Each Method 6B sample obtained over 24 hours represents 24

1-hour averages. If Method 6A or 6B is used under Condition I.B.24., the conditions under 40 CFR 60.46(d)(1) apply; these conditions do not apply under condition I.B.23.

b. For Method 7, Method 7A, 7C, 7D or 7E may be used. If Method 7C, 7D, or 7E is used, the sampling time for each run shall be 1 hour.

c. For Method 3, Method 3A or 3B may be used if the sampling time is 1 hour.

d. No change.

[Rule 62-204.800(7)(b)2., F.A.C.; 40 CFR 60.47a(j); 40 CFR 60.46(d)(1), 40 CFR 60 Appendix A, Methods 3, 3A, 3B, 6, 6A, 6B, 6C, 7, 7A, 7C, 7D, and 7E]

16. In conducting the performance tests required in 40 CFR 60.8, the owner or operator shall use as reference methods and procedures the methods in appendix A of 40 CFR 60 or the methods and procedures as specified in conditions B.17. through B.20., except as provided in 40 CFR 60.8(b). 40 CFR 60.8(f) does not apply to specific conditions B.18 and B.19. for SO<sub>2</sub> and NO<sub>x</sub>. Acceptable alternative methods are given in specific condition B.20.

[Rule 62-204.800(7)(b)2., F.A.C.; 40 CFR 60.48a(a); 40 CFR 60.8]

17. TEC shall determine compliance with the particulate matter standards in specific condition B.5. as follows:

a. The dry basis F factor (O<sub>2</sub>) procedures in Method 19 shall be used to compute the emission rate of particulate matter.

b. For the particulate matter concentration, Method 5B shall be used after wet FGD systems.

(1) The sampling time and sample volume for each run shall be at least 120 minutes and 1.70 dscm (60 dscf). The probe and filter holder heating system in the sampling train may be set to provide an average gas temperature of no greater than 160±14 °C (320±25 °F).

(2) For each particulate run, the emission rate correction factor, integrated or grab sampling and analysis procedures of Method 3B shall be used to determine the O<sub>2</sub> concentration. The O<sub>2</sub> sample shall be obtained simultaneously with, and at the same traverse points as, the particulate run. If the particulate run has more than 12 traverse points, the O<sub>2</sub> traverse points may be reduced to 12 provided that Method 1 is used to locate the 12 O<sub>2</sub> traverse points. If the grab sampling procedure is used, the O<sub>2</sub> concentration for the run shall be the arithmetic mean of all the individual O<sub>2</sub> concentrations at each traverse point.

c. Method 9 and the procedures in 40 CFR 60.11 shall be used to determine opacity.



[Rule 62-204.800(7)(b)2., F.A.C.; 40 CFR 60.48a(b); 40 CFR 60.11, 40 CFR 60 Appendix A, Methods 1, 3B, 5B, 9, and 19]

18. TEC shall determine compliance with the SO<sub>2</sub> standards in specific condition I.A.1.a. as follows:

a. The percent of potential SO<sub>2</sub> emissions (%P<sub>s</sub>) to the atmosphere shall be computed using the following equation:

$$\%P_s = [(100 - \%R_f)(100 - \%R_g)]/100$$

where:

%P<sub>s</sub> = percent of potential SO<sub>2</sub> emissions, percent.

%R<sub>f</sub> = percent reduction from fuel pretreatment, percent.

%R<sub>g</sub> = percent reduction by SO<sub>2</sub> control system, percent.

b. The procedures in Method 19 may be used to determine percent reduction (%R<sub>f</sub>) of sulfur by such processes as fuel pretreatment (physical coal cleaning, hydrodesulfurization of fuel oil, etc.), coal pulverizers, and bottom and flyash interactions. This determination is optional.

c. The procedures in Method 19 shall be used to determine the percent SO<sub>2</sub> reduction (%R<sub>g</sub>) of any SO<sub>2</sub> control system. Alternatively, a combination of an "as fired" fuel monitor and emission rates measured after the control system, following the procedures in Method 19, may be used if the percent reduction is calculated using the average emission rate from the SO<sub>2</sub> control device and the average SO<sub>2</sub> input rate from the "as fired" fuel analysis for 30 successive boiler operating days.

d. The appropriate procedures in Method 19 shall be used to determine the emission rate.

e. The continuous monitoring systems specified in conditions B.17. and B.19. shall be used to determine the concentrations of SO<sub>2</sub> and CO<sub>2</sub> or O<sub>2</sub>. [Rule 62-204.800(7)(b)2., F.A.C.; 40 CFR 60.48a (c); 40 CFR 60 43a; 40 CFR 60.47a(b) and (d); 40 CFR 60 Appendix A, Method 19]

19. TEC shall determine compliance with the NO<sub>x</sub> standards in specific condition I.A.1.b. as follows:

a. The appropriate procedures in Method 19 shall be used to determine the emission rate of NO<sub>x</sub>.

b. The continuous monitoring systems specified in specific conditions B.18. and B.19. shall be used to determine the concentrations of NO<sub>x</sub> and CO<sub>2</sub> or O<sub>2</sub>. [Rule 62-

204.800(7)(b)2., F.A.C.; 40 CFR 60.48a(d); 40 CFR 60.44a; 40 CFR 60.47a(c); 40 CFR 60.47a(d)]

20. TEC may use the following as alternatives to the reference methods and procedures specified in condition B.17:

a. For Method 5 or 5B, Method 17 may be used at Unit No. 4 if the stack temperature at the sampling location does not exceed an average temperature of 160 °C (320 °F). The procedures of sections 2.1 and 2.3 of Method 5B may be used in Method 17 only if it is used after wet FGD systems. Method 17 shall not be used after wet FGD systems if the effluent is saturated or laden with water droplets.

b. The F<sub>c</sub> factor (CO<sub>2</sub>) procedures in Method 19 may be used to compute the emission rate of particulate matter under the stipulations of 40 CFR 60.46(d)(1). The CO<sub>2</sub> shall be determined in the same manner as the O<sub>2</sub> concentration. [Rule 62-204.800(7)(b)2., F.A.C.; 40 CFR 60.48a(e); 40 CFR 60.46(d)(1); 40 CFR 60 Appendix A, Methods 5, 5B, 17, and 19]

21. For sulfur dioxide, nitrogen oxides, and particulate matter emissions, the performance test data from the initial performance test and from the performance evaluation of the continuous monitors (including the transmissometer) shall be submitted to the Department and the EPCHC. [Rule 62-204.800(7)(b)2., F.A.C.; 40 CFR 60.49a(a)]

22. For sulfur dioxide and nitrogen oxides the following information shall be reported to the Department and the EPCHC for each 24-hour period.

a. Calendar date.

b. The average SO<sub>2</sub> and NO<sub>x</sub> emission rates (lb/ million Btu heat input) for each 30 successive boiler operating days, ending with the last 30-day period in the quarter; reasons for non-compliance with the standard; and, description of corrective actions taken.

c. Percent reduction of the potential combustion concentration of sulfur dioxide for each 30 successive boiler operating days, ending with the last 30-day period in the quarter; reasons for non-compliance with the standard; and, description of corrective actions taken.

d. Identification of the boiler operating days for which pollutant or diluent data have not been obtained by an approved method for at least 18 hours of operation of the facility; justification or not obtaining sufficient data; and description of corrective actions taken.

e. Identification of the times when emissions data have been excluded from the calculation of average emission rates because of startup, shutdown, malfunction (NO<sub>x</sub> only), emergency conditions (SO<sub>2</sub> only), or other reasons, and justification for excluding data for reasons other than startup, shutdown, malfunction, or emergency conditions.

f. Identification of "F" factor used for calculations, method of determination, and type of fuel combusted.

g. Identification of times when hourly averages have been obtained based on manual sampling methods.

h. Identification of the times when the pollutant concentration exceeded full span of the continuous monitoring system.

i. Description of any modifications to the continuous monitoring system which could affect the ability of the continuous monitoring system to comply with 40 CFR 60 Appendix B, Performance Specifications 2 or 3.

[Rule 62-204.800(7)(b)2., F.A.C.; 40 CFR 60.49a(b); 40 CFR 60 Appendix B]

23. If the minimum quantity of emission data, as required by the emission monitoring specific conditions B.6. through B.15., is not obtained for any 30 successive boiler operating days, the following information obtained under the requirements of specific condition B.5. shall be reported to the DEP for that 30-day period:

a. The number of hourly averages available for outlet emission rates ( $n_o$ ) and inlet emission rates ( $n_i$ ) as applicable.

b. The standard deviation of hourly averages for outlet emission rates ( $s_o$ ) and inlet emission rates ( $s_i$ ) as applicable.

c. The lower confidence limit for the mean outlet emission rate ( $E_o^*$ ) and the upper confidence limit for the mean inlet emission rate ( $E_i^*$ ) as applicable.

d. The applicable potential combustion concentration.

e. The ratio of the upper confidence limit for the mean outlet emission rate ( $E_o^*$ ) and the allowable emission rate ( $E_{std}$ ) as applicable.

[Rule 62-204.800(7)(b)2., F.A.C.; 40 CFR 60.49a(c); 40 CFR 60 Appendix A, Method 19]

24. If any sulfur dioxide standards under specific condition I.A.1.a. is exceeded during emergency conditions because of control system malfunction, the owner or operator of the affected facility shall submit a signed statement:

a. Indicating if emergency conditions existed and requirements under specific condition B.14. were met during each period, and

b. Listing the following information:

(1) Time periods the emergency condition existed;

(2) Electrical output and demand on the owner or operator's electric utility system and the affected facility;

(3) Amount of power purchased from interconnected neighboring utility companies during the emergency period;

(4) Percent reduction in emissions achieved;

(5) Atmospheric emission rate (ng/J or lb/MMBtu) of the pollutant discharged; and

(6) Actions taken to correct control system malfunction.  
[Rule 62-204.800(7)(b)2., F.A.C.; 40 CFR 60.49a(d); 40 CFR 60.43a; 40 CFR 60.46a(d)]

25. If fuel pretreatment credit is claimed toward the sulfur dioxide emission standards in specific condition B.7. TEC shall submit a signed statement:

a. Indicating what percentage cleaning credit was taken for the calendar quarter, and whether the credit was determined in accordance with the provisions of specific condition B.28. and Method 19 (Appendix A of 40 CFR 60); and

b. Listing the quantity, heat content, and date each pretreated fuel shipment was received during the previous quarter; the name and location of the fuel pretreatment facility; and the total quantity and total heat content of all fuels received at the affected facility during the previous quarter.

[Rule 62-204.800(7)(b)2., F.A.C.; 40 CFR 60.49a(e), 40 CFR 60.48a(c)]

26. For any periods for which opacity, sulfur dioxide or nitrogen oxides emissions data are not available, the owner or operator of the affected facility shall submit a signed statement indicating if any changes were made in operation of the emission control system during the period of data unavailability. Operations of the control system and affected facility during periods of data unavailability are to be compared with operation of the control system and affected facility before and following the period of data unavailability.

[Rule 62-204.800(7)(b)2., F.A.C.; 40 CFR 60.49a(f)]

27. The owner or operator of the affected facility shall submit a signed statement indicating whether:

a. The required continuous monitoring system calibration, span, and drift checks or other periodic audits have or have not been performed as specified.

b. The data used to show compliance was or was not obtained in accordance with approved methods and procedures of these conditions and is representative of plant performance.

c. The minimum data requirements have or have not been met; or, the minimum data requirements have not been met for errors that were unavoidable.

d. Compliance with the standards has or has not been achieved during the reporting period.

[Rule 62-204.800(7)(b)2., F.A.C.; 40 CFR 60.49a(g)]

28. For the purposes of the reports required under 40 CFR 60.7, periods of excess emissions are defined as all 6-minute periods during which the average opacity exceeds the applicable opacity standards under specific condition B.6. Opacity levels in excess of the applicable opacity standard and the date of such excesses are to be submitted to the Administrator each calendar quarter.

[Rule 62-204.800(7)(b)2., F.A.C.; 40 CFR 60.49a(h)]

29. The owner or operator of an affected facility shall submit the written reports required under this section and subpart A to the Department and the EPCHC for every calendar quarter. All quarterly reports shall be postmarked by the 30th day following the end of each calendar quarter.

[Rule 62-204.800(7)(b)2., F.A.C.; 40 CFR 60.49a(i)]

30. Gravimetric instrument data verifying that the 20.0% maximum petroleum coke content by weight has not been exceeded shall be maintained for five years and submitted to the Department and the EPCHC with each annual operating report. Also to be maintained and available for inspection shall be a daily record of operation showing the date, fuel used, mode of operation (integrated/non-integrated), and the duration of all startups, shutdowns and malfunctions. TEC shall maintain copies of fuel analyses containing information on sulfur content, ash content, and heating values.

[PSD-FL-040; Rules 62-4.070(3), 62-213.440(1)(b)2.b., F.A.C., and Power Plant Siting Certification PA 79-12]

31. Pursuant to Rule 62-212.200(2)(d), F.A.C., the actual emissions of the No. 4 Unit shall equal the representative actual emissions as defined in 40 CFR

