

# Department of Environmental Protection

Jeb Bush  
Governor

Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

Colleen M. Castille  
Secretary

## NOTICE OF ADMINISTRATIVE PERMIT CORRECTION

In the Matter of an Administrative Permit Correction:

Ms. Karen Sheffield General Manager Tampa Electric Company P.O. Box 111 Tampa, FL 33601-0111	FINAL Permit Renewal No. <b>0570039-017-AV</b> Administrative Permit Correction No. <b>0570039-021-AV</b> <b>Big Bend Station</b>
--	---

The Florida Department of Environmental Protection has determined that a minor correction to information contained in FINAL Permit Renewal Number **0570039-017-AV** is required. The change corrects the calendar year dates listed in the Acid Rain Part of the current Title V Permit Renewal. This Administrative Permit Correction is processed as project number **0570039-021-AV**, pursuant to Rule 62-210.360, F.A.C. The correction is as noted below.

- Specific Condition 2. of the Phase II Acid Rain Part is corrected, as follows:
2. Sulfur dioxide (SO<sub>2</sub>) allowance allocations and nitrogen oxide (NO<sub>x</sub>) requirements for each Acid Rain unit are as follows:

E.U. ID No.	EPA ID		Year				
			2005	2006	2007	2008	2009
-001	<b>BB01</b>	SO <sub>2</sub> allowances, under Table 2 of 40 CFR 73	12132*	12132*	12132*	12132*	12132*
		NO <sub>x</sub> limit**	<p>Note: The applicable emission limitation, under 40 CFR 76.6(a)(3), is <b>0.84 lb/mmBtu</b>.</p> <p><b>2.a.</b> Pursuant to 40 CFR 76.11, the Florida Department of Environmental Protection approves the NO<sub>x</sub> emissions averaging plan submitted on 6/28/04 for this unit. Under the plan, this unit's NO<sub>x</sub> emissions shall not exceed the annual average alternative contemporaneous emission limitation of <b>0.74 lb/MMBtu</b>. In addition, this unit shall have an annual heat input of limit <b>35,364,120 MMBtu</b>.</p>				

"More Protection, Less Process"

Printed on recycled paper.

NOTICE OF ADMINISTRATIVE PERMIT CORRECTION  
 FINAL Permit Renewal No. 0570039-017-AV  
 Administrative Permit Correction No. 0570039-021-AV

E.U. ID No.	EPA ID		Year				
			2005	2006	2007	2008	2009
-002	BB02	SO <sub>2</sub> allowances, under Table 2 of 40 CFR 73	12196*	12196*	12196*	12196*	12196*
		NO <sub>x</sub> limit**	Note: The applicable emission limitation, under 40 CFR 76.6(a)(3), is 0.84 lb/mmBtu.  2.b. Pursuant to 40 CFR 76.11, the Florida Department of Environmental Protection approves the NO <sub>x</sub> emissions averaging plan submitted on 6/28/04 for this unit. Under the plan, this unit's NO <sub>x</sub> emissions shall not exceed the annual average alternative contemporaneous emission limitation of 0.74 lb/MMBtu. In addition, this unit shall have an annual heat input limit of 35,004,960 MMBtu.				
-003	BB03	SO <sub>2</sub> allowances, under Table 2 of 40 CFR 73	11444*	11444*	11444*	11444*	11444*
		NO <sub>x</sub> limit**	Note: The applicable emission limitation, under 40 CFR 76.6(a)(3), is 0.84 lb/mmBtu.  2.c. Pursuant to 40 CFR 76.11, the Florida Department of Environmental Protection approves the NO <sub>x</sub> emissions averaging plan submitted on 6/28/04 for this unit. Under the plan, this unit's NO <sub>x</sub> emissions shall not exceed the annual average alternative contemporaneous emission limitation of 0.53 lb/MMBtu. In addition, this unit shall have an annual heat input limit of 36,047,400 MMBtu.				

NOTICE OF ADMINISTRATIVE PERMIT CORRECTION  
 FINAL Permit Renewal No. **0570039-017-AV**  
 Administrative Permit Correction No. **0570039-021-AV**

Page 3 of 4

E.U. ID No.	EPA ID		Year				
			2005	2006	2007	2008	2009
-004	BB04	SO <sub>2</sub> allowances, under Table 2 of 40 CFR 73	8780*	8780*	8780*	8780*	8780*
		NO <sub>x</sub> limit**	Note: The applicable emission limitation, under 40 CFR 76.5(a)(1), is <b>0.45 lb/mmBtu</b> .  <b>2.d.</b> Pursuant to 40 CFR 76.11, the Florida Department of Environmental Protection approves the NO <sub>x</sub> emissions averaging plan submitted on 6/28/04 for this unit. Under the plan, this unit's NO <sub>x</sub> emissions shall not exceed the annual average alternative contemporaneous emission limitation of <b>0.44 lb/MMBtu</b> . In addition, this unit shall have an annual heat input limit of <b>36,047,400 MMBtu</b> .				


\*The number of allowances held by an Acid Rain source in a unit account may differ from the number allocated by the USEPA under Table 2 of 40 CFR 73. "Allowance" means an authorization by the USEPA Administrator under the federal Acid Rain Program to emit up to one ton of sulfur dioxide during a specified calendar year.

\*\* Based on the Phase II NO<sub>x</sub> applications.

This permit correction corrects and is a part of FINAL Permit Renewal Number **0570039-017-AV**. This permit correction is issued pursuant to Chapter 403, Florida Statutes.

Any party to this order (permit) has the right to seek judicial review of the permit pursuant to Section 120.68, F.S., by the filing of a Notice of Appeal pursuant to Rule 9.110, Florida Rules of Appellate Procedure, with the Clerk of the Department in the Legal Office; and by filing a copy of the Notice of Appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal. The Notice of Appeal must be filed within 30 (thirty) days from the date this Notice is filed with the Clerk of the permitting authority.

Executed in Tallahassee, Florida.



Trina L. Vielhauer, Chief  
 Bureau of Air Regulation

NOTICE OF ADMINISTRATIVE PERMIT CORRECTION  
FINAL Permit Renewal No. 0570039-017-AV  
Administrative Permit Correction No. 0570039-021-AV

Page 4 of 4

**CERTIFICATE OF SERVICE**

The undersigned duly designated deputy agency clerk hereby certifies that this NOTICE OF ADMINISTRATIVE PERMIT CORRECTION was sent by certified mail (\*) and copies were mailed by U.S. Mail before the close of business on 2/28/05 to the person(s) listed or as otherwise noted:

Ms. Karen Sheffield\*  
Ms. Alice Harmon, EPCHC  
Mr. Jerry Kissel, Southwest District Office  
U.S.EPA, Region 4 (INTERNET E-mail Memorandum)

Clerk Stamp

**FILING AND ACKNOWLEDGMENT FILED**, on this date, pursuant to §120.52(7), Florida Statutes, with the designated Department Clerk, receipt of which is hereby acknowledged.

Barbara J. Friday 2/28/05  
(Clerk) (Date)

**U.S. Postal Service**  
**CERTIFIED MAIL RECEIPT**  
*(Domestic Mail Only; No Insurance Coverage Provided)*

7000 2870 0000 7028 0054

Ms. Karen Sheffield, General Manager U S E

Postage	\$	Postmark Here
Certified Fee		
Return Receipt Fee (Endorsement Required)		
Restricted Delivery Fee (Endorsement Required)		
<b>Total Postage &amp; Fees</b>	<b>\$</b>	

**Sent To**  
 Ms. Karen Sheffield, General Manager  
 -----  
**Street, Apt. No.; or PO Box No.**  
 P.O. Box 111  
 -----  
**City, State, ZIP+4**  
 Tampa, Florida 33601-0111