

Z 333 618 112

US Postal Service  
**Receipt for Certified Mail**

No Insurance Coverage Provided.

Do not use for International Mail (See reverse)

Sent to <i>Gregory Nelson</i>	
Street & Number <i>TECO</i>	
Post Office, State, & ZIP Code <i>Jampa FI</i>	
Postage	\$
Certified Fee	
Special Delivery Fee	
Restricted Delivery Fee	
Return Receipt Showing to Whom & Date Delivered	
Return Receipt Showing to Whom, Date, & Addressee's Address	
TOTAL Postage & Fees	\$
Postmark or Date	<i>7-20-99</i>
<i>0570039-003-AC</i>	
<i>+ 004-AC</i>	

PS Form 3800, April 1995

Is your RETURN ADDRESS completed on the reverse side?

**SENDER:**

- Complete items 1 and/or 2 for additional services.
- Complete items 3, 4a, and 4b.
- Print your name and address on the reverse of this form so that we can return this card to you.
- Attach this form to the front of the mailpiece, or on the back if space does not permit.
- Write "Return Receipt Requested" on the mailpiece below the article number.
- The Return Receipt will show to whom the article was delivered and the date delivered.

I also wish to receive the following services (for an extra fee):

- 1.  Addressee's Address
- 2.  Restricted Delivery

Consult postmaster for fee.

3. Article Addressed to:  
*Gregory M. Nelson*  
*Jampa Electric Co*  
*P O Box 111*  
*Jampa, FI 33601-0111*

5. Received By: (Print Name)  
*[Signature]*

6. Signature: (Addressee or Agent)  
*X*

4a. Article Number  
*2 333 618 112*

4b. Service Type  
 Registered       Certified  
 Express Mail       Insured  
 Return Receipt for Merchandise       COD

7. Date of Delivery  
*JUL 22 1999*

8. Addressee's Address (Only if requested and fee is paid)

Thank you for using Return Receipt Service.

PS Form 3811, December 1994

102595-98-B-0229 Domestic Return Receipt

**DEPARTMENT OF ENVIRONMENTAL PROTECTION  
NOTICE OF ADMINISTRATIVE PERMIT CORRECTION**

In the Matter of an Application for Administrative Permit Correction:

Mr. Gregory M. Nelson  
Manager – Environmental Planning  
Tampa Electric Company  
PO Box 111  
Tampa, Florida 33601-0111

DEP File No.: 0570039-003-AC & -004-AC  
Big Bend Station FGD System for Units 1 and 2  
Emissions Unit 021

The Department has determined that a minor correction to information contained in permit number 0570039-003-AC and 0570039-004-AC are required. This correction is related to a typographical error and is minor in nature and does not alter, modify or revise any permit requirement. This Administrative Permit Correction was processed as project number 0570039-005-AC, pursuant to Rule 62-210.360, F.A.C. The final permit omitted language that specifically allows the applicant to comply with a visible emissions limit of 5% opacity in lieu of conducting initial and regular particulate matter tests for emissions unit 021 (Silo C), although that was the Department's intent. The Department discovered this error and initiated this correction. The Department notified the applicant as required by Rule 62-210.360(3), F.A.C., via a telephone call between Joseph Kahn of the Department and James Hunter of Tampa Electric Company on July 13, 1999. The correction is:

Specific Condition 18 of Section III shall read:

18. Visible Emissions Tests in Lieu of Stack Tests: For emissions unit 020, after passing the initial test required by specific condition 21 of this section, the owner or operator is permitted to comply with the visible emission limit of specific condition 16 and the testing requirement of specific condition 17 of this section in lieu of regularly demonstrating compliance with the limitations of 40 CFR 60.672(a)(1) and (2) and the particulate matter limitation of specific condition 16 of this section. If the Department has reason to believe that the particulate weight emission limit of 40 CFR 60.672(a)(1) or the particulate matter limitation of specific condition 16 of this section is not being met, it shall require compliance be demonstrated by the test method specified by 40 CFR 60.675.


For emissions unit 021, the owner or operator is permitted to comply with the visible emission limit of specific condition 16 and the testing requirement specific condition 17 of this section in lieu of regularly demonstrating compliance with the particulate matter limitation of specific condition 16 of this section. No initial particulate matter test is required for emissions unit 021. If the Department has reason to believe that the particulate matter limitation of specific condition 16 of this section is not being met, it shall require compliance be demonstrated by test using EPA Method 5.

[Rules 62-4.070(3) and 62-297.620(4), F.A.C.]

This permit correction corrects and is a part of permit number 0570039-003-AC and 0570039-004-AC. This permit correction is issued pursuant to Chapter 403, Florida Statutes.

Any party to this order (permit correction) has the right to seek judicial review of it under section 120.68 of the Florida Statutes, by filing a notice of appeal under Rule 9.110 of the Florida Rules of Appellate Procedure with the clerk of the Department of Environmental Protection in the Office of General Counsel, Mail Station #35, 3900 Commonwealth Boulevard, Tallahassee, Florida, 32399-3000, and by filing a copy of the notice of appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal. The notice must be filed within thirty days after this order is filed with the clerk of the Department.

Executed in Tallahassee, Florida.

  
C. H. Fancy, P.E., Chief  
Bureau of Air Regulation

