From: Velasco, Robert A.
To: McWade, Tammy
Subject: Revised Emission Calculations No. 2
Date: Monday, June 17, 2013 9:04:30 AM
Attachments: Big Bend Igniter PSD Applicability Emissions - 06_17_13.pdf

---

Tammy:

As previously discussed, the revised PSD applicability emission rates for the igniter project are attached. Emission rates were revised to include CO2e on each table and to reduce the VOC emission increase from 39.9 to 39.0 tpy on Table 4. For co-firing and low load operation (Table 4), reduced the amount of natural gas (heat input) for co-firing for each unit slightly to reduce the VOC emission increase to 39.0 tpy. Revised co-firing natural gas heat input rates for each unit are as follows:

Unit ID	Natural Gas Heat Input Cap (MMBtu/yr)
1	5,015,495
2	4,295,353
3	5,029,622
4	5,534,935

Heat input for low load firing stays the same. Please review and contact me if you have any questions.

Best Regards,

(Rob) Robert A. Velasco, P.E., BCEE, QEP
EHS Air Programs
Tampa Electric Company
P.O. Box 111
Tampa, FL 33601
Phone: (813) 228-4232
Cell: (813) 417-9524
Fax: (813) 228-1308
www.tampaelectric.com/environmental/

NOTICE: This email is intended only for the individual(s) to whom it is addressed and may contain confidential information. If you have received this email by mistake, please notify the sender immediately, delete this email from your system and do not copy or disclose it to anyone else. Although we take precautions to protect against viruses, we advise you to take your own precautions to protect against viruses as we accept no liability for any which remain.