



TAMPA ELECTRIC

September 21, 2001

RECEIVED

SEP 25 2001

BUREAU OF AIR REGULATION

Mr. Jeffery F. Koerner, P.E.  
New Source Review Section  
Florida Department of Environmental Protection  
111 South Magnolia Avenue, Suite 4  
Tallahassee, Florida 32301

Via FedEx  
Airbill No. 7901 6445 6623

**Re: Requests for Additional Information  
Bayside Power Station (Gannon Repowering Project)**

Dear Mr. Koerner:

Tampa Electric Company (TEC) has received the Department's request for additional information regarding the particulate matter emission factors and stack parameters for F.J. Gannon Station, and the requested data is enclosed.

TEC appreciates the opportunity to provide the additional information contained in this correspondence. If you have any questions, please call Shannon Todd or me at (813) 641-5125.

Sincerely,

Karen Sheffield  
General Manager-Bayside Power Station  
Tampa Electric Company

EP\gm\SKT275

Enclosure

c/enc: Mr. Jerry Kissel, FDEP - SWD  
Mr. Jerry Campbell, EPCHC  
Mr. John Bunyak, NPS  
Mr. Gregg Worley, EPA Region 4  
Ms. Katy Forney, EPA Region 4

Table 1. F.J. Gannon and Bayside Power Station Stack Parameters

Emission Source	Height		Diameter		Temperature		Velocity		Stack Area (ft <sup>2</sup> )	Flow Rate (ft <sup>3</sup> /min)
	(ft)	(m)	(ft)	(m)	(°F)	(K)	(ft/sec)	(m/sec)		
<b>F. J. Gannon Station (1973)</b>										
Unit 1	200.0	61.0	14.1	4.30	309.0	427.0	26.5	8.1	156.15	248,271
Unit 2	250.0	76.2	10.0	3.05	309.0	427.0	55.9	17.0	78.54	263,423
Unit 3	250.0	76.2	10.6	3.23	266.0	403.2	65.5	20.0	88.25	346,812
Unit 4	235.0	71.6	9.6	2.93	286.0	414.3	46.2	14.1	72.38	200,644
Unit 5	230.0	70.1	14.6	4.45	288.0	415.4	56.7	17.3	167.42	569,547
Unit 6	306.0	93.3	17.6	5.36	291.0	417.0	54.3	16.6	243.28	792,622
<b>F. J. Gannon Station (1974)</b>										
Unit 1	200.0	61.0	14.1	4.30	309.0	427.0	27.3	8.3	156.15	255,766
Unit 2	250.0	76.2	10.0	3.05	309.0	427.0	56.1	17.1	78.54	264,365
Unit 3	250.0	76.2	10.6	3.23	266.0	403.2	48.1	14.7	88.25	254,682
Unit 4	235.0	71.6	9.6	2.93	286.0	414.3	48.2	14.7	72.38	209,330
Unit 5	230.0	70.1	14.6	4.45	288.0	415.4	46.9	14.3	167.42	471,107
Unit 6	306.0	93.3	17.6	5.36	291.0	417.0	52.7	16.1	243.28	769,267
<b>Bayside Station</b>										
CT1A - CT4B	150.0	45.7	19.0	5.79	212.0	373.2	59.9	18.3	283.53	1,019,002
(Per CT @ 100% Load, 59°F)										

Sources: ECT, 2001.  
TEC, 2001.


Table 2. F.J. Gannon and Bayside Power Station PM Emission Rates

Emission Source	1973		1974		1975		1976	
	PM		PM		PM		PM	
	(lb/hr)	(g/s)	(lb/hr)	(g/s)	(lb/hr)	(g/s)	(lb/hr)	(g/s)
<b>F. J. Gannon Station</b>								
Unit 1	190	23.9	206	26.0	204	25.7	191	24.1
Unit 2	220	27.7	107	13.5	99	12.5	214	27.0
Unit 3	330	41.6	248	31.2	313	39.4	32	4.0
Unit 4	464	58.5	568	71.6	56	7.1	84	10.6
Unit 5	840	105.8	669	84.3	677	85.2	42	5.3
Unit 6	2,170	273.4	44	5.5	38	4.8	51	6.4
Totals	4,214	531.0	1,842	232	1,387	175	614	77
<b>Bayside Station (Future)</b>								
CT1A - CT4B (Per CT @ 100% Load, 59°F)	20.3	2.6	N/A	N/A	N/A	N/A	N/A	N/A
Totals (11 CTs)	223.30	28.1	N/A	N/A	N/A	N/A	N/A	N/A

Notes:

1. F.J. Gannon Station PM emissions based on EPA Reference Method 17 (front half only).
2. Bayside PM emissions based on EPA Reference Methods 201 and 202 (front and back half).

Sources: ECT, 2001.  
TEC, 2001.



TAMPA ELECTRIC

September 10, 2001

RECEIVED

SEP 10 2001

BUREAU OF AIR REGULATION

Mr. Jeffery F. Koerner, P.E.  
New Source Review Section  
Florida Department of Environmental Protection  
111 South Magnolia Avenue, Suite 4  
Tallahassee, Florida 32301

Via FedEx  
Airbill No. 7901 5518 4035

**Re: Requests for Additional Information  
Bayside Power Station (Gannon Repowering Project)**

Dear Mr. Koerner:

Tampa Electric Company (TEC) has received your requests for additional information dated August 20, 2001 addressing the proposed repowering of F.J. Gannon Station to Bayside Power Station. The original requests were sent via email to Mr. Tom Davis of ECT. TEC has noted that within the two requests, there are a total of five additional questions or requests by the Florida Department of Environmental Protection (FDEP). For your convenience, TEC has restated each point and provided a response below each specific issue.

**FDEP Issue 1**

**The application indicates the 1998 AP-42 emission factor as the reference for sulfuric acid mist emissions from the coal-fired units. What is the emission factor? Please note any assumptions.**

**TEC Response**

*The emission factor used for sulfuric acid mist for coal fired units varies depending on the sulfur content of the fuel. According to AP-42, in a coal fired unit, one can expect 0.7% of the fuel bound sulfur to be emitted as sulfur trioxide. As shown in Enclosure 1, this factor is used to calculate the sulfur trioxide formation resulting from coal combustion. Then, the stoichiometric relationship between sulfur trioxide, water and sulfuric acid mist is used to calculate the amount of sulfuric acid mist formed as a result of the reaction between sulfur trioxide and water. Finally, as mandated by the EPA Consent Decree, TEC calculated the emissions of sulfuric acid mist from Gannon Station had BACT level controls been applied to Units 3 through 6. These BACT level controls were assumed to be wet limestone flue gas desulfurization systems, which have the ability to remove approximately 35% of incoming sulfuric acid mist.*

**FDEP Issue 2**

**Cleve had sent a letter in July regarding the PSD increment for PM. I did not see the response for this item in your last submittal. Please let me know the status of this item.**

**TEC Response**

*TEC is currently performing the above referenced analysis, and will provide it to the Department upon completion.*

TAMPA ELECTRIC COMPANY  
P. O. BOX 111 TAMPA, FL 33601-0111

(813) 228-4111

AN EQUAL OPPORTUNITY COMPANY  
HTTP://WWW.TAMPAELECTRIC.COM

CUSTOMER SERVICE:  
HILLSBOROUGH COUNTY (813) 223-0800  
OUTSIDE HILLSBOROUGH COUNTY 1 (888) 223-0800

**FDEP Issue 3**

**Please submit the emission factors used to estimate past actual coal-firing emissions.**

**TEC Response**

*The requested emission factors are included as Enclosure 2.*

**FDEP Issue 4**

**Your most recent submittal indicates a net increase in VOC emissions of 21.5 TPY, which is below the 40 TPY PSD significant emission rate for VOC. However, based on TEC's annual operating reports, I estimate a 64.3 TPY increase. This makes the project subject to PSD for this pollutant, similar to the Bayside Units 1 and 2 project. Therefore, the Department will be making a BACT determination for VOC emissions. Please submit a proposal for BACT controls.**

**TEC Response**

*In our August 10, 2001 response to the Department's July 17, 2001 incompleteness letter TEC inadvertently used VOC emission factors applicable to cyclone fired boilers for all four Gannon boilers in the revised PSD netting analysis. Gannon Units 5 and 6 are Riley Stoker turbo, wet bottom fired units, and the VOC emission factor for these units differs from that used for Units 3 and 4. As such, the netting analysis has been adjusted to use the correct VOC emission factor for Gannon Units 5 and 6 as well as only natural gas firing for Bayside Units 1 and 2.*

*Based on the adjusted netting analysis, TEC calculates a net increase in VOC emissions of 56.8 tons per year. This differs from the values submitted by TEC in annual operating reports because the VOC emission factors for PC- fired, wet bottom boilers changed from 0.07 lb VOC/ton coal to 0.04 lb VOC/ton coal in 1998. TEC believes that it is appropriate to use the most recent emission factors for the purpose of performing this netting analysis.*

*Since this project results in a net increase of 56.8 tons of VOC emissions per year, TEC has enclosed a BACT analysis for VOC emissions (Enclosure 3). Based on this analysis, TEC has concluded that firing natural gas and good combustion practice is BACT for this project. This is consistent with other recently issued permits for similar facilities by FDEP.*

**FDEP Issue 5**

**There were discussions near the end of the last project indicating that TEC may not fire oil at all for this project. The current application for Bayside Units 3 and 4 indicates that these units will fire only natural gas. Please indicate whether or not Bayside Units 1 and 2 will fire distillate oil as a backup fuel.**

**TEC Response**

*Although the Bayside Units 1 and 2 were designed with provisions to fire distillate oil as a backup fuel, TEC is requesting to remove the oil firing permit conditions from the Bayside 1 and 2 Air Construction permit. Although these units have been designed to accommodate future oil firing, TEC has elected to fire natural gas as the only fuel. If the decision is made to fire distillate oil in Bayside Units 1 and 2 in the future, TEC will apply for a modification of the appropriate permits at that time.*

Mr. Jeffery F. Koerner, P.E.

September 10, 2001

Page 3 of 3

TEC appreciates the opportunity to provide the additional information contained in this correspondence. If you have any questions, please call Shannon Todd or me at (813) 641-5125.

Sincerely,



Karen Sheffield  
General Manager-Bayside Power Station  
Tampa Electric Company

EP\gm\SKT273

Enclosures

c: Mr. Jerry Kissel, FDEP - SWD  
Mr. Jerry Campbell, EPCHC  
Mr. John Bunyak, NPS  
Mr. Gregg Worley, EPA Region 4  
Ms. Katy Forney, EPA Region 4

# Enclosure 1

**TECO F.J. Gannon Station**  
**Derivation of H<sub>2</sub>SO<sub>4</sub> Emission Rates**

**Procedure References:**

Coal: Per AP-42 (9/98), Section 1.1, Table 1.1-3, Footnote b, 0.7% of fuel sulfur is emitted as SO<sub>3</sub>.

No. 2 Oil: Per AP-42 (9/98), Section 1.3, Table 1.3-1, boilers <100 MMBtu/hr (oil-firing), SO<sub>3</sub> emission factor is (2 x %S) lb SO<sub>3</sub> / 1,000 gallons oil.

Retroactive BACT control efficiency for H<sub>2</sub>SO<sub>4</sub> = 35%

SO<sub>3</sub> + H<sub>2</sub>O = H<sub>2</sub>SO<sub>4</sub>  
(one mole of SO<sub>3</sub> and one mole of H<sub>2</sub>O react to form one mole of H<sub>2</sub>SO<sub>4</sub>)

**H<sub>2</sub>SO<sub>4</sub> Calculation Equations:**

Coal:  
(lb S / 100 lb coal) x (ton coal / yr) x (2000 lb coal / ton coal) x (0.7 lb SO<sub>3</sub> / 100 lb S)  
x (1 lb-mole H<sub>2</sub>SO<sub>4</sub> / 1 lb-mole SO<sub>3</sub>) x (lb-mole SO<sub>3</sub> / 80 lb SO<sub>3</sub>)  
x (98 lb H<sub>2</sub>SO<sub>4</sub> / lb-mole H<sub>2</sub>SO<sub>4</sub>) x (ton H<sub>2</sub>SO<sub>4</sub> / 2000 lb H<sub>2</sub>SO<sub>4</sub>)  
x (1 - (Retroactive BACT Control Efficiency / 100))

Oil:  
(2 lb SO<sub>3</sub> / 1,000 gallon oil) x (% S oil) x (gallon oil / yr)  
x (1 lb-mole H<sub>2</sub>SO<sub>4</sub> / 1 lb-mole SO<sub>3</sub>) x (lb-mole SO<sub>3</sub> / 80 lb SO<sub>3</sub>)  
x (98 lb H<sub>2</sub>SO<sub>4</sub> / lb-mole H<sub>2</sub>SO<sub>4</sub>) x (ton H<sub>2</sub>SO<sub>4</sub> / 2000 lb H<sub>2</sub>SO<sub>4</sub>)  
x (1 - (Retroactive BACT Control Efficiency / 100))

**Example: 1996, Unit 3**

Coal Usage: 298,202 ton/yr  
Coal Sulfur Content: 1.12 weight percent sulfur  
No. 2 Oil Usage: 311,000 gal/yr  
No. 2 Oil Sulfur Content: 0.030 weight percent sulfur

Coal:  
(1.12 lb S / 100 lb coal) x (298,202 ton coal / yr) x (2000 lb coal / ton coal)  
x (0.7 lb SO<sub>3</sub> / 100 lb S) x (1 lb-mole H<sub>2</sub>SO<sub>4</sub> / 1 lb-mole SO<sub>3</sub>)  
x (lb-mole SO<sub>3</sub> / 80 lb SO<sub>3</sub>) x (98 lb H<sub>2</sub>SO<sub>4</sub> / lb-mole H<sub>2</sub>SO<sub>4</sub>)  
x (ton H<sub>2</sub>SO<sub>4</sub> / 2000 lb H<sub>2</sub>SO<sub>4</sub>) x (1 - (35 / 100))  
= 18.62 ton/yr H<sub>2</sub>SO<sub>4</sub>

Oil:  
(2 lb SO<sub>3</sub> / 1,000 gallon oil) x (0.030 S oil) x (311,000 gallon oil / yr)  
x (1 lb-mole H<sub>2</sub>SO<sub>4</sub> / 1 lb-mole SO<sub>3</sub>) x (lb-mole SO<sub>3</sub> / 80 lb SO<sub>3</sub>)  
x (98 lb H<sub>2</sub>SO<sub>4</sub> / lb-mole H<sub>2</sub>SO<sub>4</sub>) x (ton H<sub>2</sub>SO<sub>4</sub> / 2000 lb H<sub>2</sub>SO<sub>4</sub>)  
x (1 - (35 / 100))  
= 0.074 ton/yr H<sub>2</sub>SO<sub>4</sub>

**Total = 18.62 (coal) + 0.074 (oil) = 18.69 ton/yr H<sub>2</sub>SO<sub>4</sub>**



# Enclosure 2

**TECO F.J. Gannon Station  
Derivation of Actual Coal-Firing Emission Rates**

**Procedure References:**

Tampa Electric Company 1996 – 2000 Annual Operating Reports (AORs)

**VOC Emission Factors:**

Coal: Per AP-42 (9/98), Section 1.1, Table 1.1-19, TNMOC emission factor is 0.11 lb TNMOC / ton coal for cyclone furnaces (Units 3 & 4)

Coal: Per AP-42 (9/98), Section 1.1, Table 1.1-19, TNMOC emission factor is 0.04 lb TNMOC / ton coal for PC-fired, wet bottom furnaces (Units 5 & 6)

No. 2 Oil: Per AP-42 (9/98), Section 1.3, Table 1.3-3, Distillate fuel oil, NMTOC emission factor is 0.2 lb NMTOC / 1,000 gallons oil.

Retroactive BACT emission rate for  $\text{NO}_x = 0.10 \text{ lb NO}_x / \text{MMBtu}$

Retroactive BACT emission rate for  $\text{PM/PM}_{10} = 0.010 \text{ lb PM/PM}_{10} / \text{MMBtu}$

Retroactive BACT control efficiency  $\text{SO}_2 = 95.0 \text{ lb } \%$

---

---

**$\text{NO}_x$  Calculation:**

(Annual Heat Input [MMBtu/yr] From AOR) x (0.10 lb  $\text{NO}_x$  / MMBtu)

**Example: 2000, Unit 5**

Coal Usage: 418,667 ton/yr

Coal Heat Content: 24 MMBtu/ton

No. 2 Oil Usage: 101,569,000 gal/yr

No. 2 Oil Heat Content: 138,000 Btu/gal

**Heat Input Coal:**

(418,667 ton coal) x (24 MMBtu / ton coal)

= 10,048,008 MMBtu/yr

**Heat Input Oil:**

(10,156,900 gallon oil) x (138,000 Btu / gal) x (MMBtu / 1,000,000)

= 1,401,652 MMBtu/hr

**Total Annual Heat Input = 10,048,008 (coal) + 1,401,652 (oil) = 11,449,660 MMBtu/yr**

$\text{NO}_x = (11,449,660 \text{ MMBtu/yr}) \times (0.10 \text{ lb NO}_x / \text{MMBtu}) \times (1 \text{ ton} / 2,000 \text{ lb})$

**$\text{NO}_x = 572.5 \text{ ton/yr}$**

---

---

**TECO F.J. Gannon Station**  
**Derivation of Actual Coal-Firing Emission Rates**

**PM/PM<sub>10</sub> Calculations:**

(Annual Heat Input [MMBtu/yr] From AOR) x (0.010 lb NO<sub>x</sub> / MMBtu)

**Example: 1999, Unit 4**

Coal Usage: 409,995 ton/yr  
Coal Heat Content: 20 MMBtu/ton  
No. 2 Oil Usage: 397,000 gal/yr  
No. 2 Oil Heat Content: 138,000 Btu/gal

Heat Input Coal:  
(409,995 ton coal) x (20 MMBtu / ton coal)  
= 8,199,900 MMBtu/yr

Heat Input Oil:  
(397,000 gallon oil) x (138,000 Btu / gal) x (MMBtu / 1,000,000)  
= 54,786 MMBtu/hr

**Total Annual Heat Input = 8,199,900 (coal) + 54,786 (oil) = 8,254,686 MMBtu/yr**

PM/PM<sub>10</sub> = (8,254,686 MMBtu/yr) x (0.010 lb NO<sub>x</sub> / MMBtu) x (1 ton / 2,000 lb)

**PM/PM<sub>10</sub> = 41.2 ton/yr**

---

---

**SO<sub>2</sub> Calculation:**

(Annual Emissions [ton/yr] From AOR) x (x (1 - (Retroactive BACT Control Efficiency / 100)))

**Example: 1996, Unit 3**

Coal - SO<sub>2</sub>: 6,400 ton/yr  
Oil - SO<sub>2</sub>: 6.5 ton/yr

SO<sub>2</sub> = (6,400 + 6.5 ton/yr SO<sub>2</sub>) x (1 - (95 / 100))  
SO<sub>2</sub> = (6,406.5 ton/yr SO<sub>2</sub>) x (0.05)

**SO<sub>2</sub> = 320.3 ton/yr**

---

---

**CO Calculation:**

(Annual Emissions [ton/yr] From AOR)

**Example: 1997, Unit 4**

Coal - CO: 142 ton/yr  
Oil - CO: 1 ton/yr

CO = (142 + 1 ton/yr CO)

**CO = 143 ton/yr**

**TECO F.J. Gannon Station**  
**Derivation of Actual Coal-Firing Emission Rates**

**VOC Calculation:**

Coal:

$(0.11 \text{ lb VOC} / \text{ton coal}) \times (\text{ton coal} / \text{yr}) \times (\text{ton VOC} / 2000 \text{ lb VOC})$

Oil:

$(0.2 \text{ lb VOC} / 1,000 \text{ gallon oil}) \times (\text{gallon oil} / \text{yr}) \times (\text{ton VOC} / 2000 \text{ lb VOC})$

**Example: 1998, Unit 4**

Coal Usage: 486,831 ton/yr

No. 2 Oil Usage: 598,990 gal/yr

Coal VOC =  $(486,831 \text{ ton/yr}) \times (0.11 \text{ lb VOC} / \text{ton coal}) \times (1 \text{ ton} / 2,000 \text{ lb})$

Coal VOC = 26.7 ton/yr

Oil VOC =  $(598,990 \text{ gallon oil/yr}) \times (0.2 \text{ lb VOC} / 1,000 \text{ gallon oil}) \times (1 \text{ ton} / 2,000 \text{ lb})$

Oil VOC = 0.06 ton/yr

**Total VOC = 26.7 (coal) + 0.06 (oil) = 26.8 ton/yr**

---

---

# Enclosure 3

**REVISED PSD NETTING ANALYSIS  
GANNON UNITS 3 – 6 / BAYSIDE UNITS 1 – 4  
(ADJUSTED FOR RETROACTIVE BACT)**

Table 3. Bayside Station Units 1, 2, 3 and 4

Revised 8/23/01

Netting Analysis - F.J. Gannon Station Unit 5 Historical Emissions

	1996	1997	1998	1999	2000	96 - 00, 5 Yr Avg	98, 99 Avg
Coal Usage (tons)	574,584	450,802	556,487	541,559	418,667	508,420	549,023
Wt % Ash	7.47	8.26	8.15	7.58	6.95	7.68	7.87
Heat Content (10 <sup>6</sup> Btu/ton)	24.65	23.96	24.00	24.00	24.00	24.12	24.00
Wt % S	1.19	1.16	1.21	1.17	1.22	1.19	1.19
Oil Usage (10 <sup>3</sup> gal)	311.0	600.9	599.0	397.0	10,156.9	2,413.0	498.0
Heat Content (10 <sup>6</sup> Btu/10 <sup>3</sup> gal)	138.556	137.989	138.551	138.000	138.000	138.219	138.276
Wt % S	0.30	0.15	0.28	0.41	0.42	0.31	0.35
Total Heat Input (10 <sup>6</sup> Btu/yr)	14,208,885	10,884,135	13,438,679	13,052,202	11,449,660	12,606,712	13,245,440
NO <sub>x</sub> <sup>(a)</sup>	710.4	544.2	671.9	652.6	572.5	630.3	662.3
CO AOR	173.0	135.0	140.0	136.4	105.7	138.0	138.2
SO <sub>2</sub> <sup>(b)</sup>	648.4	537.7	685.1	630.1	538.6	608.0	657.6
H <sub>2</sub> SO <sub>4</sub> <sup>(c)</sup> AP-42 (1998)	38.2	29.2	37.7	35.4	31.9	34.5	36.6
PM <sub>10</sub> <sup>(d)</sup>	71.0	54.4	67.2	65.3	57.2	63.0	66.2
PM <sup>(d)</sup>	71.0	54.4	67.2	65.3	57.2	63.0	66.2
Pb AOR	3.8	3.0	3.7	3.6	0.1	2.8	3.4
VOC AP-42 (1998)	11.5	9.1	11.2	10.9	9.4	10.4	10.3

(a) Actual emissions based on 0.10 lb/MMBtu emission rate per EPA/TEC Consent Decree.

(b) Actual emissions reduced by 95% per EPA/TEC Consent Decree.

(c) Actual emissions reduced by 35% to reflect retroactive BACT.

(d) Actual emissions based on 0.010 lb/MMBtu emission rate per EPA/TEC Consent Decree.

Sources: ECT, 2001.  
TEC, 2001.

Table 4. Bayside Station Units 1, 2, 3 and 4

Revised 8/23/01

## Netting Analysis - F.J. Gannon Station Unit 6 Historical Emissions

	1996	1997	1998	1999	2000	96 - 00, 5 Yr Avg	97, 98 Avg
Coal Usage (tons)	892,742	920,526	860,597	693,039	391,079	751,597	890,562
Wt % Ash	7.48	8.79	8.41	7.28	7.18	7.83	8.60
Heat Content (10 <sup>6</sup> Btu/ton)	24.85	24.28	24.01	24.00	16.00	22.63	24.15
Wt % S	1.19	1.18	1.22	1.13	1.10	1.16	1.20
Oil Usage (10 <sup>3</sup> gal)	311.0	639.9	599.0	362.0	6,587.5	1,699.9	619.4
Heat Content (10 <sup>6</sup> Btu/10 <sup>3</sup> gal)	138,556	137,989	138,551	138,000	138,000	138,219	138,270
Wt % S	0.30	0.15	0.28	0.41	0.42	0.31	0.22
Total Heat Input (10 <sup>6</sup> Btu/yr)	22,229,515	22,438,664	20,745,925	16,682,892	7,166,339	17,852,667	21,592,294
NO <sub>x</sub> <sup>(a)</sup>	1,111.5	1,121.9	1,037.3	834.1	358.3	892.6	1,079.6
CO AOR	269.0	278.0	216.0	174.2	98.5	207.1	247.0
SO <sub>2</sub> <sup>(b)</sup>	1,015.4	1,141.5	1,185.2	801.5	465.5	921.8	1,163.3
H <sub>2</sub> SO <sub>4</sub> <sup>(c)</sup> AP-42 (1998)	59.3	60.6	58.7	43.8	26.2	49.7	59.6
PM <sub>10</sub> <sup>(d)</sup>	111.1	112.2	103.7	83.4	35.8	89.3	108.0
PM <sup>(d)</sup>	111.1	112.2	103.7	83.4	35.8	89.3	108.0
Pb AOR	5.9	6.1	5.7	4.6	0.1	4.5	5.9
VOC AP-42 (1998)	17.9	18.5	17.3	13.9	8.5	15.2	17.9

(a) Actual emissions based on 0.10 lb/MMBtu emission rate per EPA/TEC Consent Decree.

(b) Actual emissions reduced by 95% per EPA/TEC Consent Decree.

(c) Actual emissions reduced by 35% to reflect retroactive BACT.

(d) Actual emissions based on 0.010 lb/MMBtu emission rate per EPA/TEC Consent Decree.

Sources: ECT, 2001.  
TEC, 2001.



Table 5. Bayside Station

Revised 8/23/010

## Bayside Units 1 - 4/F.J. Gannon Units 3 - 6 Emissions Netting Analysis

	F. J. Gannon Units 3, 4, 5 & 6 (tpy)					Units 3 & 4 2 Yr <sup>(a)</sup> Avg	Units 5 & 6 2 Yr <sup>(b)(c)</sup> Avg	Units 3 - 6 2 Yr <sup>(a)(b)(c)</sup> Avg	CT 1A-4B (tpy)	Net Change (tpy)	PSD Threshold (tpy)	PSD Review (Y/N)
	1996	1997	1998	1999	2000							
Coal Usage (tons)	2,252,402	2,348,406	2,345,753	2,074,717	1,746,108	888,241	1,439,585	2,327,825	N/A	N/A	N/A	N/A
Wt % Ash	7.08	7.70	7.54	7.17	7.09	7.01	8.23	15.24	N/A	N/A	N/A	N/A
Heat Content (10 <sup>6</sup> Btu/ton)	23.79	22.29	21.81	22.25	20.00	20.25	24.07	44.32	N/A	N/A	N/A	N/A
Wt % S	1.15	1.13	1.04	1.05	1.01	0.90	1.20	2.10	N/A	N/A	N/A	N/A
Oil Usage (10 <sup>3</sup> gal)	1,244.0	2,457.5	2,396.0	1,553.0	37,058.2	10,553.9	1,117.4	11,671.3	N/A	N/A	N/A	N/A
Heat Content (10 <sup>6</sup> Btu/10 <sup>3</sup> gal)	138.556	137.989	138.551	138.000	138.000	138.000	138.273	276.273	N/A	N/A	N/A	N/A
Wt % S	0.30	0.15	0.28	0.41	0.42	0.41	0.28	0.69	N/A	N/A	N/A	N/A
Total Heat Input (10 <sup>6</sup> Btu/yr)	54,357,901	53,475,548	52,585,549	47,078,210	40,146,544	19,436,830	34,837,734	54,274,565	N/A	N/A	N/A	N/A
NO <sub>x</sub> <sup>(d)</sup>	2,717.9	2,673.8	2,629.3	2,353.9	2,007.3	971.8	1,741.9	2,713.7	1,113.0	-1,600.8	40.0	N
CO AOR	679.0	709.0	590.0	522.6	440.4	224.1	385.2	609.3	1,382.8	773.5	100.0	Y
SO <sub>2</sub> <sup>(e)</sup>	2,476.9	2,686.9	2,720.8	2,177.9	1,763.1	752.7	1,820.9	2,573.6	486.5	-2,087.1	40.0	N
H <sub>2</sub> SO <sub>4</sub> <sup>(f)</sup> AP-42 (1998)	145.5	149.7	141.6	123.7	109.4	47.9	96.2	144.1	89.4	-54.7	7.0	N
PM <sub>10</sub> <sup>(g)</sup>	271.8	267.4	262.9	235.4	200.7	97.2	174.2	271.4	978.1	706.7	15.0	Y
PM <sup>(g)</sup>	271.8	267.4	262.9	235.4	200.7	97.2	174.2	271.4	978.1	706.7	25.0	Y
Pb AOR	15.0	15.6	15.6	13.8	0.4	2.9	9.3	12.2	1.4	-10.9	0.6	N
VOC AP-42 (1998)	72.7	81.4	79.7	71.1	71.4	49.9	28.2	78.1	134.9	56.8	40.0	Y

(a) 1999, 2000 average for Units 3 and 4.

(b) 1998, 1999 average for Unit 5.

(c) 1997, 1998 average for Unit 6.

(d) Actual emissions based on 0.10 lb/MMBtu emission rate per EPA/TEC Consent Decree.

(e) Actual emissions reduced by 95% per EPA/TEC Consent Decree.

(f) Actual emissions reduced by 35% to reflect retroactive BACT.

(g) Actual emissions based on 0.010 lb/MMBtu emission rate per EPA/TEC Consent Decree.

Sources: ECT, 2001.

TEC, 2001.

**VOC BACT ANALYSIS  
BAYSIDE UNITS 3 AND 4**

## 4.0A BEST AVAILABLE CONTROL TECHNOLOGY ANALYSIS FOR VOLATILE ORGANIC COMPOUNDS

### 4.1A METHODOLOGY

The VOC BACT analysis was performed using the methodology previously described in Section 4.1 of the June 2001 Air Construction Permit Application.

### 4.2A FEDERAL AND FLORIDA EMISSION STANDARDS

Pursuant to Rule 62-212.400(5)(b), F.A.C., BACT emission limitations must be no less stringent than any applicable NSPS (40 CFR Part 60), NESHAP (40 CFR Parts 61 and 63), and FDEP emission standards (Chapter 62-296, F.A.C., *Stationary Sources—Emission Standards*).

On the federal level, emissions from gas turbines are regulated by NSPS Subpart GG. Subpart GG establishes emission limits for gas turbines that were constructed after October 3, 1977, and that meet any of the following criteria:

- Electric utility stationary gas turbines with a heat input at peak load of greater than 100 MMBtu/hr based on the LHV of the fuel.
- Stationary gas turbines with a heat input at peak load between 10 and 100 MMBtu/hr based on the fuel LHV.
- Stationary gas turbines with a manufacturer's rated base load at International Standards Organization (ISO) standard day conditions of 30 MW or less.

The electric utility stationary gas turbine NSPS applicability criterion applies to stationary gas turbines that sell more than one-third of their potential electric output to any utility power distribution system. The Bayside Units 3 and 4 CTs qualify as electric utility stationary gas turbines and, therefore, are subject to the NO<sub>x</sub> and SO<sub>2</sub> emission limitations of NSPS 40 CFR 60, Subpart GG, § 60.332(a)(1) and § 60.333, respectively. However, NSPS Subpart GG does not include any VOC emission limitations.

FDEP emission standards for stationary sources are contained in Chapters 62-296, F.A.C., *Stationary Sources—Emission Standards*. Visible emissions are limited to a maximum of 20 percent opacity pursuant to Rule 62-296.320(4)(b), F.A.C. Sections 62-296.401 through 62-296.417, F.A.C., specify emission standards for 17 categories of sources; none of these categories are applicable to CTs. Rule 62-204.800(7), F.A.C. incorporates the federal NSPS by reference, including Subpart GG.

Emission standards applicable to sources located in ozone nonattainment and maintenance areas are contained in Section 62-296.500, F.A.C. As mentioned in Section 3.0 of this report, all of Hillsborough County is classified as an Air Quality Maintenance Area for ozone.

The Bayside Power Station will be located at the existing F.J. Gannon Station south of downtown Tampa in Hillsborough County and therefore is situated within the Hillsborough County ozone Air Quality Maintenance Area. Sections 62-296.501 through 62-296.516, F.A.C., specify VOC emission standards for 16 categories of sources; none of these categories are applicable to CTs. In addition, these VOC emission standards are not applicable to modified VOC-emitting sources, such as Bayside Units 3 and 4, which will be subject to 40 CFR 52.21 (i.e., PSD NSR). Accordingly, there are no ozone Air Quality Maintenance Area VOC emission limits that are applicable to Bayside Units 3 and 4.

Section 62-204.800, F.A.C., adopts federal NSPS and NESHAP, respectively, by reference. As noted previously, NSPS Subpart GG, *Stationary Gas Turbines* is applicable to the Bayside Unit 3 and 4 CTs. However, Subpart GG does not contain any VOC emission limitations. There are no applicable NESHAP requirements.

In summary, there are no federal or state VOC emission limitations applicable to Bayside Units 3 and 4.

#### **4.3A BACT ANALYSIS FOR VOC**

VOC emissions result from the incomplete combustion of carbon and organic compounds. Factors affecting VOC emissions include firing temperatures, residence time in

the combustion zone, and combustion chamber mixing characteristics. Because higher combustion temperatures will increase oxidation rates, emissions of VOCs will generally increase during turbine partial load conditions when combustion temperatures are lower. Decreased combustion zone temperature due to the injection of water or steam for NO<sub>x</sub> control will also result in an increase in VOC emissions. An increase in combustion zone residence time and improved mixing of fuel and combustion air will increase oxidation rates and cause a decrease in VOC emission rates. Emissions of NO<sub>x</sub> and VOC are inversely related; i.e., decreasing NO<sub>x</sub> emissions will result in an increase in VOC emissions. Accordingly, combustion turbine vendors have had to consider the competing factors involved in NO<sub>x</sub> and VOC formation in order to develop units that achieve acceptable emission levels for both pollutants.

#### **4.3.1A POTENTIAL CONTROL TECHNOLOGIES**

There are two available technologies for controlling VOCs from gas turbines and duct burners: (1) combustion process design and (2) oxidation catalysts.

##### **Combustion Process Design**

Combustion process controls involve combustion chamber designs and operation practices that improve the oxidation process and minimize incomplete combustion. Due to the high combustion efficiency of CTs, approximately 99 percent, VOC emissions are inherently low. During normal operations, VOC exhaust concentrations from the Bayside Unit 3 and 4 GE 7FA CTs are projected to be only 1.3 parts per million by volume, dry (ppmvd), corrected to 15-percent oxygen (O<sub>2</sub>).

##### **Oxidation Catalysts**

Noble metal (commonly platinum or palladium) oxidation catalysts are used to promote oxidation of VOCs to carbon dioxide (CO<sub>2</sub>) and water at temperatures lower than would be necessary for oxidation without a catalyst. The operating temperature range for oxidation catalysts is between 650 and 1,150°F.

Efficiency of VOC oxidation varies with inlet temperature. Control efficiency will increase with increasing temperature for VOCs up to a temperature of approximately

1,100°F; further temperature increases will have little effect on control efficiency. Temperatures on the order of 900°F are needed to oxidize VOCs. Inlet temperature must also be maintained below 1,350 to 1,400°F to prevent thermal aging of the catalyst which will reduce catalyst activity and pollutant removal efficiencies. Removal efficiency will also vary with gas residence time which is a function of catalyst bed depth. Increasing bed depth will increase removal efficiencies but will also cause an increase in pressure drop across the catalyst bed. VOC removal efficiency will vary with the species of hydrocarbon. In general, unsaturated hydrocarbons such as ethylene are more reactive with oxidation catalysts than saturated species such as ethane. A typical VOC control efficiency range using an oxidation catalyst control system is 30- to 50-percent. However, CTs with low uncontrolled VOC emission rates, such as the GE 7FA units, would be expected to have VOC control efficiencies on the low end of this range.

Oxidation catalysts are susceptible to deactivation due to impurities present in the exhaust gas stream. Arsenic, iron, sodium, phosphorous, and silica will all act as catalyst poisons causing a reduction in catalyst activity and pollutant removal efficiencies.

Oxidation catalysts are nonselective and will oxidize other compounds in addition to VOCs. The nonselectivity of oxidation catalysts is important in assessing applicability to exhaust streams containing sulfur compounds. Sulfur compounds that have been oxidized to SO<sub>2</sub> in the combustion process will be further oxidized by the catalyst to sulfur trioxide (SO<sub>3</sub>). SO<sub>3</sub> will, in turn, combine with moisture in the gas stream to form H<sub>2</sub>SO<sub>4</sub> mist.

### **Technical Feasibility**

Both CT combustor design and oxidation catalyst control systems are considered to be technically feasible for Bayside Units 3 and 4. Information regarding energy, environmental, and economic impacts and proposed BACT limits for VOC are provided in the following sections.

#### **4.3.2A ENERGY AND ENVIRONMENTAL IMPACTS**

There are no significant adverse energy or environmental impacts associated with the use of good combustor designs and operating practices to minimize VOC emissions.

The use of oxidation catalysts will, as previously noted, result in excessive H<sub>2</sub>SO<sub>4</sub> mist emissions if applied to combustion devices fired with fuels containing sulfur. Increased H<sub>2</sub>SO<sub>4</sub> mist emissions will also occur, on a smaller scale, from CTs fired with natural gas.

Because VOC emission rates from CTs are inherently low, further reductions through the use of oxidation catalysts will result in minimal air quality improvements; i.e., negligible reductions in ambient VOC/ozone levels. The location of Bayside Units 3 and 4 (Hillsborough County, Florida) is classified attainment for all criteria pollutants.

The application of oxidation catalyst technology to a gas turbine will result in an increase in back pressure on the CT due to a pressure drop across the catalyst bed. The increased back pressure will, in turn, constrain turbine output power thereby increasing the unit's heat rate. An oxidation catalyst system for the Bayside Units 3 and 4 CTs is projected to have a pressure drop across the catalyst bed of approximately 1.2 inch of water (H<sub>2</sub>O). This pressure drop will result in a 0.24 percent energy penalty due to reduced turbine output power. The reduction in turbine output power (lost power generation) will result in an energy penalty of 3,574,080 kilowatt-hours (kwh) (12,195 MMBtu) per year at base load (170-MW) operation and 100 percent capacity factor per CT. This energy penalty is equivalent to the use of 46.5 million cubic feet (ft<sup>3</sup>) of natural gas annually based on a natural gas heating value of 1,050 British thermal units per cubic foot (Btu/ft<sup>3</sup>) for all four CTs. The lost power generation energy penalty, based on a power cost of \$0.030/kwh, is \$428,890 per year for all four CTs.

#### **4.3.3A ECONOMIC IMPACTS**

An economic evaluation of an oxidation catalyst system was performed using the OAQPS factors previously summarized in Table 4-1 and project-specific economic factors provided

in Table 4-2A. Specific capital and annual operating costs for the oxidation catalyst control system are summarized in Tables 4-3A and 4-4A.

The base case Bayside Units 3 and 4 (i.e., for all four CT/HRSG units) annual VOC emission rate is 49.1 tpy. The controlled annual VOC emission rate, based on a 50 percent control efficiency, is 24.5 tpy. Base case and controlled VOC emission rates are summarized in Table 4-5A.

The cost effectiveness of oxidation catalyst for VOC emissions was determined to be \$60,378 per ton of VOC removed. Based on the high control costs, use of oxidation catalyst technology to control VOC emissions is not considered to be economically feasible. Results of the oxidation catalyst economic analysis are summarized in Table 4-5A.

#### **4.3.4A PROPOSED BACT EMISSION LIMITATIONS**

The use of oxidation catalyst to control VOCs from CTs is typically required only for facilities located in ozone nonattainment areas. BACT VOC limits obtained from the RBLC database for natural gas-fired CTs are provided in Table 4-6A. A summary of recent FDEP VOC BACT determinations for natural gas-fired combustion turbines is provided in Table 4-7A.

The use of oxidation catalysts will, as previously noted, result in excessive H<sub>2</sub>SO<sub>4</sub> mist emissions if applied to combustion devices fired with fuels containing appreciable amounts of sulfur. Increased H<sub>2</sub>SO<sub>4</sub> mist emissions will also occur, on a smaller scale, from CTs fired with natural gas and low sulfur distillate fuel oil. Because VOC emission rates from CTs are inherently low, further reductions through the use of oxidation catalysts will result in only minor improvement in air quality, i.e., negligible reductions in ambient VOC/ozone levels.

Use of state-of-the-art combustor design and good operating practices to minimize incomplete combustion are proposed as BACT for VOCs. These control techniques have been considered by FDEP to represent BACT for VOCs for all CT projects permitted



Table 4-2A. Economic Cost Factors

Factor	Units	Value
Interest rate	%	7.0*
Control system life	Years	15
Oxidation catalyst life	Years	5
VOC control efficiency	%	50*
Electricity cost	\$/kwh	0.030*
Labor costs (base rates)	\$/hour	
Operator		22.00
Maintenance		22.00

\* Per FDEP request.

Sources: ECT, 2001.  
TEC, 2001.

Table 4-3A. Capital Costs for Oxidation Catalyst System, Four CTs

Item	Dollars	OAQPS Factor
<b>Direct Costs</b>		
Purchased equipment	2,680,000	A
Sales tax	160,800	0.06 x A
Freight	134,000	0.05 x A
Instrumentation	268,000	0.10 x A
<b>Subtotal Purchased Equipment Cost</b>	<b>3,242,800</b>	<b>B</b>
<b>Installation</b>		
Foundations and supports	259,424	0.08 x B
Handling and erection	453,992	0.14 x B
Electrical	129,712	0.04 x B
Piping	64,856	0.02 x B
Insulation for ductwork	32,428	0.01 x B
Painting	32,428	0.01 x B
<b>Subtotal Installation Cost</b>	<b>972,840</b>	
<b>Subtotal Direct Costs</b>	<b>4,215,640</b>	
<b>Indirect Costs</b>		
Engineering	324,280	0.10 x B
Construction and field expenses	162,140	0.05 x B
Contractor fees	324,280	0.10 x B
Startup	64,856	0.02 x B
Performance test	32,428	0.01 x B
Contingency	97,284	0.03 x B
<b>Subtotal Indirect Costs</b>	<b>1,005,268</b>	
<b>TOTAL CAPITAL INVESTMENT</b>	<b>5,220,908</b>	<b>(TCI)</b>

Source: Engelhard, 2001.  
ECT, 2001.

Table 4-4A. Annual Operating Costs for Oxidation Catalyst System, Four CTs

Item	Dollars	Basis
<u>Direct Costs</u>		
Catalyst costs		
Replacement (materials and labor)	2,668,224	
Credit for used catalyst	(360,000)	15% credit
Subtotal Catalyst Costs	2,308,224	
<b>Annualized Catalyst Costs</b>	<b>562,954</b>	5 yr @ 7.0%
Energy Penalties		
Turbine backpressure	428,890	0.24% penalty
<b>Subtotal Direct Costs</b>	<b>991,844</b>	(TDC)
<u>Indirect Costs</u>		
Administrative charges	104,418	0.02 x TCI
Property taxes	52,209	0.01 x TCI
Insurance	52,209	0.01 x TCI
Capital recovery	280,271	15 yr @ 7.0%
<b>Subtotal Indirect Costs</b>	<b>489,107</b>	
<b>TOTAL ANNUAL COST</b>	<b>1,480,951</b>	

Sources: Engelhard, 2001.  
 ECT, 2001.  
 TEC, 2001.

Table 4-5A. Summary of VOC BACT Analysis

Control Option	Emission Impacts			Economic Impacts			Energy Impacts	Environmental Impacts	
	Emission Rates		Emission Reduction	Installed Capital Cost	Total Annualized Cost	Cost Effectiveness Over Baseline	Increase Over Baseline	Toxic Impact	Adverse Envir. Impact
	(lb/hr)	(tpy)	(tpy)	(\$)	(\$/yr)	(\$/ton)	(MMBtu/yr)	(Y/N)	(Y/N)
Oxidation catalyst	5.6	24.5	24.5	5,220,908	1,480,951	60,378	48,781	N	Y
Baseline	11.2	49.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Basis: Four GE PG7241 (FA) CTs, 100-percent load, natural gas-firing for 8,760 hr/yr.

Sources: ECT, 2001.  
 GE, 2001.  
 TEC, 2001.

Table 4-6A. RBLC VOC Summary for Natural Gas Fired CTGs

RBLC ID	Facility Name	City	Permit Dates		Process Description	Thruput Rate	Emission Limit	Control System Description	Basis
			Issuance	Update					
AL-0128	ALABAMA POWER COMPANY - THEODORE COGEN	THEODORE	3/16/99	6/23/99	TURBINE, WITH DUCT BURNER	170.0 MW			
CA-0768	NORTHERN CALIFORNIA POWER AGENCY	LODI	10/2/97	3/16/98	GE FRAME 5 GAS TURBINE	325.0 MMBTU/HR	0.016 LB/MMBTU	EFFICIENT COMBUSTION	BACT-PSD
CA-0810	SACRAMENTO COGENERATION AUTHORITY P&G	SACRAMENTO	8/19/94	8/31/99	TURBINE, GAS, COMBINED CYCLE LM6000	421.4 MMBTU/HR	8 LB/HR	NATURAL GAS AS PRIMARY FUEL	LAER
CA-0810	SACRAMENTO COGENERATION AUTHORITY P&G	SACRAMENTO	8/19/94	8/31/99	TURBINE, GAS, COMBINED CYCLE LM6000	421.4 MMBTU/HR	1.1 LB/H	OXIDATION CATALYST	BACT
CA-0810	SACRAMENTO COGENERATION AUTHORITY P&G	SACRAMENTO	8/19/94	8/31/99	TURBINE, GAS, COMBINED CYCLE LM6000	421.4 MMBTU/HR	1.1 LB/H	OXIDATION CATALYST	BACT
CA-0813	SEPCO	RIO LINDA	10/5/94	8/31/99	TURBINE, SIMPLE CYCLE LM6000 GAS	421.4 MMBTU/HR	1.1 LB/H	OXIDATION CATALYST	BACT
CA-0853	KERN FRONT LIMITED	BAKERSFIELD	11/4/86	8/5/99	TURBINE, GAS COMBINED CYCLE GE MODEL 7	920.0 MMBTU/HR	3.7 LB/H	OXIDATION CATALYST	BACT
CA-0855	CROCKETT COGENERATION - C&H SUGAR	CROCKETT	10/5/93	4/19/99	TURBINE, GAS, GENERAL ELECTRIC LM-2500	25.0 MW	3.12 LB/H	OXIDATION CATALYST	BACT
CA-0858	BEAR MOUNTAIN LIMITED	BAKERSFIELD	9/28/99	9/28/99	TURBINE, GE, COGENERATION, 48 MW	240.0 MW	352.6 LB/D	OXIDATION CATALYST, VOC IS SHOWN AS CH4.	BACT-OTHER
CO-0017	THERMO INDUSTRIES, LTD.	FT. LUYTON	2/19/92	3/24/95	TURBINE, GE, COGENERATION, 48 MW	48.0 MW	0.6 PPMVD @ 15% O2	OXIDATION CATALYST	BACT-OTHER
CO-0018	BRUSH COGENERATION PARTNERSHIP	BRUSH	7/20/94	7/20/94	TURBINE, GAS FIRED, 5 EACH	246.0 MMBTU/HR	16.7 LB/H		OTHER
CO-0019	COLORADO POWER PARTNERSHIP	BRUSH	7/20/94	7/20/94	TURBINE, GAS FIRED, 5 EACH	350.0 MMBTU/HR	26.7 T/YR		OTHER
CO-0024	PUBLIC SERVICE OF COLO. FORT ST VRAIN	PLATTEVILLE	5/1/96	5/19/98	TURBINES, 2 NAT GAS & 2 DUCT BURNERS	385.0 MMBTU/HR	35.2 T/YR		OTHER
CO-0039	FULTON COGENERATION ASSOC., L.P.	BRUSH	8/23/99	12/11/00	COMBINED CYCLE TURBINES (2), NATURAL	471.0 MW	1.4 PPMVD, SMPL CY	GOOD COMBUSTION CONTROL PRACTICES.	BACT-PSD
CT-0073	PRATT & WHITNEY, UTC.	MIDDLETOWN	7/7/89	4/30/90	ELECTRIC GENERATION, TURBINES, NATURAL GAS	142.0 MW	3 PPMVD @ 15% O2	COMBUSTION CONTROLS	BACT-PSD
CT-0139	PDC EL PASO MILFORD LLC	MILFORD	4/16/99	6/17/99	ENGINE, GAS TURBINE	238.0 MMBTU/HR	0.014 LB/MMBTU		BACT-PSD
CT-0140	PDC EL PASO MILFORD LLC	MILFORD	4/16/99	6/17/99	TURBINE, COMBUSTION, ABB GT-24, #1	2.0 MMCF/H	3 LB/H NAT GAS	COMBUSTION CONTROLS	BACT
FL-0042	ORLANDO UTILITIES COMMISSION	TITUSVILLE	9/1/88	5/14/93	TURBINE, COMBUSTION, ABB GT-24E, #2	2.0 MMCF/H	3 LB/H NAT GAS	COMBUSTION CONTROLS	BACT
FL-0052	FLORIDA POWER AND LIGHT	NORTH PALM BEACH	6/5/91	3/24/95	TURBINE, 2 EA	35.0 MW	7 PPM @ 15% O2	COMBUSTION CONTROL	BACT-PSD
FL-0052	FLORIDA POWER AND LIGHT	NORTH PALM BEACH	3/3/94	3/24/95	TURBINE, CG, 4 EACH	400.0 MW	9 PPM @ 15% O2	COMBUSTION CONTROL	BACT-PSD
FL-0053	FLORIDA POWER AND LIGHT	LAVOGROME REPOWER	3/14/91	3/24/95	TURBINE, GAS, 4 EACH	400.0 MW	1.6 PPM @ 15% O2	COMBUSTION CONTROL	BACT-PSD
FL-0056	ORLANDO UTILITIES COMMISSION	TITUSVILLE	11/5/91	5/14/93	TURBINE, GAS, 4 EACH	240.0 MW	1 PPM @ 15% O2	COMBUSTION CONTROL	BACT-PSD
FL-0068	ORANGE COGENERATION LP	BARTOW	12/30/93	11/13/95	TURBINE, NATURAL GAS, 2	35.0 MW	7 PPM @ 15% O2	COMBUSTION CONTROL	BACT-PSD
FL-0080	AUBURNDALE POWER PARTNERS, LP	AUBURNDALE	12/14/92	1/13/95	TURBINE, GAS	388.3 MMBTU/HR	10 PPMVD	GOOD COMBUSTION	BACT-PSD
FL-0082	FLORIDA POWER CORPORATION POLK COUNTY SITE	AUBURNDALE	2/25/94	1/13/95	TURBINE, NATURAL GAS (2)	1,214.0 MMBTU/HR	6 LB/H	GOOD COMBUSTION PRACTICES	BACT-PSD
GA-0052	SAVANNAH ELECTRIC AND POWER CO.	BARTOW	2/12/92	3/24/95	TURBINE, NATURAL GAS (2)	1,510.0 MMBTU/HR	7 PPMVW	GOOD COMBUSTION PRACTICES	BACT-PSD
GA-0063	MID-GEORGIA COGEN	KATHLEEN	4/3/96	8/19/96	TURBINES, 8	1,032.0 MMBTU/HR, NAT GAS	0.003 LB/MMBTU	FUEL SPEC: LOW SULFUR FUEL OIL	BACT-PSD
GA-0069	TENUSKA GEORGIA PARTNERS, L.P.	FRANKLIN	12/18/98	6/23/99	COMBUSTION TURBINE (2), NATURAL GAS	116.0 MW	6 PPMVD	COMPLETE COMBUSTION	BACT-PSD
GA-0069	TENUSKA GEORGIA PARTNERS, L.P.	FRANKLIN	12/18/98	6/23/99	TURBINE, COMBUSTION, SIMPLE CYCLE, 6	160.0 MW EA	0.03 LB/MMBTU	VOC EMISSION IS BECAUSE OF NATURAL GAS	BACT-PSD
LA-0086	INTERNATIONAL PAPER	MANSFIELD	2/24/94	4/17/95	TURBINE, COMBUSTION, SIMPLE CYCLE, 6	160.0 MW EA	0.0055 LB/MMBTU	VOC EMISSION IS BECAUSE OF NO.2 FUEL OIL	BACT-PSD
LA-0118	OCCIDENTAL CHEMICAL CORPORATION	HAMHVILLE	3/19/99	3/19/01	TURBINE, HRSG, GAS COGEN	338.0 MM BTU/HR TURBINE	3.6 LB/HR COMBINED	COMBUSTION CONTROLS, FUEL SELECTION	BACT
MA-0023	DIGHTON POWER ASSOCIATE, LP	DIGHTON	10/6/97	4/19/99	GAS TURBINES (3 UNITS)	170.0 MW	3 LB/H	DLN COMBINATION WITH OTHER TECHNOLOGIES	BACT-PSD
ME-0018	WESTBROOK POWER LLC	WESTBROOK	12/4/98	4/19/99	TURBINE, COMBUSTION, ABB GT11N2	1,327.0 MMBTU/HR	5.1 LB/H	DRY LOW NOX COMBUSTION TECHNOLOGY WITH	BACT-PSD
ME-0019	CHAMPION INTERNATL CORP & CHAMP. CLEAN ENERGY	BUCKSPORT	9/14/98	4/19/99	TURBINE, COMBINED CYCLE, TWO	528.0 MW TOTAL	0.4 PPM @ 15% O2		BACT-PSD
ME-0020	CASCO RAY ENERGY CO	VEAZIE	7/13/98	4/19/99	TURBINE, COMBINED CYCLE, NATURAL GAS	175.0 MW	3 LB/H GAS		BACT-PSD
MI-0245	SOUTHERN ENERGY, INC	ZEELAND	3/16/00	8/22/00	TURBINE, COMBINED CYCLE, NATURAL GAS, TWO	170.0 MW EACH	1 PPM	LOW NOX BURNER	BACT-PSD
NC-0055	DUKE POWER CO. LINCOLN COMBUSTION TURBINE	LOWESVILLE	12/20/91	3/24/95	COMBINED CYCLE TURBINE	9,000.0 GIGAJOULES	0.008 LB/MMBTU	PER CT. GOOD COMBUSTION PRACTICE	BACT-PSD
NJ-0013	LAKEWOOD COGENERATION, L.P.	LAKEWOOD TOWNSHIP	4/1/91	5/29/95	TURBINE, COMBUSTION	1,313.0 MM BTU/HR	2 LB/HR	COMBUSTION CONTROL	BACT-PSD
NJ-0017	NEWARK BAY COGENERATION PARTNERSHIP, L.P.	NEWARK	6/9/93	5/29/95	TURBINES (NATURAL GAS) (2)	1,190.0 MMBTU/HR (EACH)	0.0046 LB/MMBTU	TURBINE DESIGN	BACT-PSD
NM-0021	WILLIAMS FIELD SERVICES CO. - EL CEDRO	BLANCO	10/29/93	3/2/94	TURBINES, COMBUSTION, NATURAL GAS-FIRED (2)	617.0 MMBTU/HR (EACH)	4 PPMOV	TURBINE DESIGN	OTHER
NM-0028	SOUTHWESTERN PUBLIC SERVICE CO/CUNNINGHAM	HOBBS	11/4/96	12/30/96	TURBINE, GAS-FIRED	11,257.0 HP	25 PPM @ 15% O2	COMBUSTION CONTROL	BACT-PSD
NM-0029	SOUTHWESTERN PUBLIC SERVICE COMPANY	HOBBS	2/15/97	3/31/97	COMBUSTION TURBINE, NATURAL GAS	100.0 MW	0 SEE P2	GOOD COMBUSTION PRACTICES	BACT-PSD
NY-0036	ONEIDA COGENERATION FACILITY	ONEIDA	2/26/90	5/18/90	COMBUSTION TURBINE, NATURAL GAS	100.0 MW	0		BACT-PSD
NY-0038	EMPIRE ENERGY - NIAGARA COGENERATION CO.	LOCKPORT	5/2/89	5/18/90	TURBINE, GE FRAME 6	417.0 MMBTU/HR	0.013 LB/MMBTU	COMBUSTION CONTROL	OTHER
NY-0039	FULTON COGENERATION ASSOCIATES	FULTON	1/29/90	5/18/90	TURBINE, GR FRAME 6, 3 EA	416.0 MMBTU/HR	0.012 LB/MMBTU	COMBUSTION CONTROL	BACT-PSD
NY-0040	JMC SELKIRK, INC	SELKIRK	11/21/89	5/18/90	TURBINE, GE LM5000, GAS FIRED	500.0 MMBTU/HR	5 LB/H	COMBUSTION CONTROL	BACT-PSD
NY-0046	SARANAC ENERGY COMPANY	PLATTSBURGH	7/31/92	9/13/94	TURBINE, GE FRAME 7, GAS FIRED	80.0 MW	7 PPM	COMBUSTION CONTROL	BACT-PSD
OH-0218	CNG TRANSMISSION	WASHINGTON CRT HSE	8/12/92	4/5/95	TURBINES, COMBUSTION (2) (NATURAL GAS)	1,123.0 MMBTU/HR (EACH)	0.0045 LB/MMBTU	OXIDATION CATALYST	BACT-OTHER
PA-0083	NORTHERN CONSOLIDATED POWER	NORTH EAST	5/3/91	7/20/94	TURBINE (NATURAL GAS) (3)	5,500.0 HP (EACH)	0.1 G/HP-HR	FUEL SPEC: USE OF NATURAL GAS	OTHER
PA-0099	FLEETWOOD COGENERATION ASSOCIATES	FLEETWOOD	4/22/94	11/22/94	TURBINES, GAS, 2	34.8 KW EACH	105 PPM @ 15% O2	OXIDATION CATALYST	OTHER
PA-0148	BLUE MOUNTAIN POWER, LP	RICHLAND	7/31/96	1/12/99	NG TURBINE (GE LM6000) WITH WASTE HEAT BOILER	360.0 MMBTU/HR	4.4 LB/HR	GOOD COMBUSTION PRACTICES	BACT-OTHER
PA-0149	BUCKNELL UNIVERSITY	LEWISBURG	11/26/97	11/30/97	COMBUSTION TURBINE WITH HEAT RECOVERY BOILER	153.0 MW	4 PPM @ 15% O2	OXIDATION CATALYST WHEN FIRING NO. 2 OIL	LAER
PR-0004	ECOELECTRICA, L.P.	PENUELAS	10/1/96	5/6/98	NG FIRED TURBINE, SOLAR TAURUS T-7300S	5.0 MW	25 PPMV @ 15% O2	GOOD COMBUSTION	BACT-OTHER
RI-0008	PAWTUCKET POWER	PAWTUCKET	10/1/96	5/6/98	TURBINES, COMBINED-CYCLE COGENERATION	461.0 MW	5 PPMOV	COMBUSTION CONTROLS	BACT-PSD
RI-0010	NARRAGANSETT ELECTRIC/NEW ENGLAND POWER CO.	PROVIDENCE	1/30/89	3/31/91	TURBINE/DUCT BURNER	533.0 MMBTU/HR	19 PPM @ 15% O2, GAS		BACT-PSD
RI-0012	ALGONQUIN GAS TRANSMISSION CO.	BURRILLVILLE	4/13/92	5/31/92	TURBINE, GAS AND DUCT BURNER	360.0 MMBTU/HR EACH	5 PPM @ 15% O2		BACT-PSD
RI-0018	TIVERTON POWER ASSOCIATES	TIVERTON	2/13/98	2/8/99	TURBINE, GAS, 2	49.0 MMBTU/HR	0.016 LB/MMBTU	GOOD COMBUSTION PRACTICES	BACT-OTHER
SC-0031	BMW MANUFACTURING CORPORATION	GREER	1/7/94	8/12/96	COMBUSTION TURBINE, NATURAL GAS	265.0 MW	2 PPM @ 15% O2	GOOD COMBUSTION	BACT-PSD
TN-0077	TN VALLEY AUTHORITY LAGOON CREEK COMBUS TURB	BROWNSVILLE	4/26/00	8/16/00	TURBINE, NAT GAS FIRED (3-1 SPARE) AND 2 BOILERS	54.5 MM BTU/HR TURBINES	77.86 LBS/DAY		LAER
TX-0231	WEST CAMPUS COGENERATION COMPANY	COLLEGE STATION	5/2/94	10/31/94	COMBUSTION TURBINE	194,400.0 MMBTU/HR	1.4 PPM @ 15% O2	ANNUAL PRODUCTION LIMITS	BACT-PSD
VA-0163	VIRGINIA POWER		9/7/89	4/30/90	GAS TURBINES	75.3 MW (TOTAL POWER)	38 TPY	INTERNAL COMBUSTION CONTROLS	BACT
VA-0177	DOSWELL LIMITED PARTNERSHIP		5/4/90	3/24/95	TURBINE, GAS	1,308.0 MMBTU/HR	2 LB/H/UNIT NAT GAS FI		BACT-PSD
VA-0180	COMMONWEALTH GAS PIPELINE CORPORATION	GOOCHLAND	9/30/90	3/24/95	TURBINE, COMBUSTION	1,261.0 MMBTU/HR	4.4 LB/H	COMBUSTOR DESIGN & OPERATION, GAS	OTHER
VA-0184	BERMUDA HUNDRED ENERGY LIMITED PARTNERSHIP	CHESTERFIELD	3/3/92	5/7/97	TURBINES, GAS FIRED, SINGLE CYCLE, 5	14.5 MMBTU/HR EACH	0	EQUIPMENT DESIGN & OPERATION	BACT-PSD
VA-0238	COMMONWEALTH CHESAPEAKE CORPORATION	NEW CHURCH	5/21/96	7/21/97	TURBINE, COMBUSTION	1,175.0 MMBTU/HR NAT. GAS	2.3 LB/H/UNIT	FURNACE DESIGN	BACT-PSD
					3 COMBUSTION TURBINES (OIL-FIRED)	6,000.0 HRS/YR	38.9 TPY	GOOD COMBUSTION OPERATING PRACTICES	BACT/INSPS

Source: RBLC 2001.

MAXIMUM	105.0 PPM @ 15% O2
MINIMUM	0.4 PPM @ 15% O2
MEDIAN	5.0 PPM @ 15% O2

Table 4-7A. Florida BACT VOC Summary—Natural Gas-Fired CTGs

Permit Date	Source Name	Turbine Size (MW)	VOC Emission Limit (ppmvd @ 15% O <sub>2</sub> )	Control Technology
03/07/95	Orange Cogeneration, L.P.	39	10.0	Good combustion
07/10/98	City of Lakeland McIntosh Unit 5	250	4.0	Good combustion
09/29/98	Florida Power Corporation Hines Energy Complex	165	7.0	Good combustion
11/25/98	Florida Power & Light Fort Myers Repowering	170	1.4	Good combustion
12/04/98	Santa Rosa Energy, LLC	167	1.4	Good combustion
10/8/99	Tampa Electric Company – Polk Power Station	165	1.4	Good combustion
7/23/99	Seminole Electric Cooperative, Inc., Payne Creek	158	5.0	Good combustion
9/20/99	Lake Worth Generating	170	1.4	Good combustion
10/18/99	Vandolah Power Project	170	1.4	Good combustion
12/28/99	Osceola Power Project	170	3.7	Good combustion
1/13/00	Shady Hills Generating Station	170	1.4	Good combustion
2/00	Kissimmee Utility – Cane Island Unit 3	167	1.4	Good combustion
2/22/00	Reliant Energy Osceola	170	1.5	Good combustion
2/24/00	Gainesville Regional Utilities	83	1.4	Good combustion
7/31/00	Gulf Power – Smith Unit 3	170	4.0	Good combustion
2/6/01 (Draft)	Calpine Blue Heron	170	1.2	Good combustion
3/30/01	Tampa Electric Company – Bayside Units 1 & 2	170	1.3	Good combustion
7/5/01	Calpine Osprey	170	2.3	Good combustion
8/15/01	Ft. Pierce Re-Powering	180	2.2	Good combustion

Source: FDEP, 2001.

within the past 5 years. Maximum natural gas-firing VOC exhaust concentrations from the CT/HRSG units will be less than or equal to 1.3 ppmvd at 15 percent oxygen. This VOC exhaust concentration is consistent with recent FDEP VOC BACT determinations for CT/HRSG units; e.g., City of Tallahassee Purdom Unit 8 and Lakeland Utilities McIntosh Unit 5. VOC BACT emission limits proposed for Bayside Units 3 and 4 are provided in Table 4-8A.

Table 4-8A. Proposed VOC BACT Emission Limits

Emission Source	Proposed VOC BACT Emission Limits	
	ppmvd at 15 percent oxygen	lb/hr
GE PG7241 (FA) CT/HRSGs (Per CT/HRSG Unit)		
VOC (Natural Gas)	1.3	3.0

Sources: ECT, 2001.  
TEC, 2001.



## **Adams, Patty**

---

**From:** Koerner, Jeff  
**Sent:** Monday, August 20, 2001 9:44 AM  
**To:** Tom Davis (E-mail)  
**Cc:** Shannon Todd (E-mail)  
**Subject:** TEC Bayside - SAM Emission Factor, Coal-Fired Boilers

Tom,

1. The application indicates the 1998 AP-42 emission factor as the reference for sulfuric acid mist emissions from the coal-fired units. What is the emission factor? Please note any assumptions.
2. Cleve had sent a letter in July regarding the PSD increment for PM. I did not see the response for this item in your last submittal. Please let me know the status of this item.

Thanks!

Jeff Koerner  
New Source Review Section  
850/921-9536

**Adams, Patty**

---

**From:** Koerner, Jeff  
**Sent:** Monday, August 20, 2001 11:05 AM  
**To:** Tom Davis (E-mail)  
**Cc:** Shannon Todd (E-mail)  
**Subject:** TEC Bayside - Emission Factors, VOC Emissions and Oil Firing

Tom,

1. Please submit the emission factors used to estimate past actual coal-firing emissions.
2. Your most recent submittal indicates a net increase in VOC emissions of 21.5 TPY, which is below the 40 TPY PSD significant emission rate for VOC. However, based on TEC's annual operating reports, I estimate a 64.3 TPY increase. This makes the project subject to PSD for this pollutant, similar to the Bayside Units 1 and 2 project. Therefore, the Department will be making a BACT determination for VOC emissions. Please submit a proposal for BACT controls.
3. There were discussions near the end of the last project indicating that TEC may not fire oil at all for this project. The current application for Bayside Units 3 and 4 indicates that these units will fire only natural gas. Please indicate whether or not Bayside Units 1 and 2 will fire distillate oil as a backup fuel.

Thanks!

Jeff Koerner  
New Source Review Section  
850/921-9536



TAMPA ELECTRIC

October 11, 2002

Mr. Al Linero, P.E.  
Acting Bureau Chief  
Florida Department of Environmental Protection  
111 South Magnolia Drive, Suite 4  
Tallahassee, FL 32301

RECEIVED  
OCT 14 2002  
BUREAU OF AIR REGULATION

Via FedEx  
Airbill No. 7901 0888 6579

Re: Tampa Electric Company  
Bayside Power Station  
Project No. 0570040-015-AC  
Air Permit No. PSD-FL-301A  
Permitting Exemption

Dear Mr. Linero:

Tampa Electric Company (TEC) would like to courtesy notify the Florida Department of Environmental Protection (FDEP) that a temporary package boiler will be utilized on-site at Bayside Power Station. Bayside Unit 1 and 2 are under construction and the package boiler will be used to heat water for the cleaning of steam pipes and associated equipment in preparation for the startup of Bayside Unit 1 and 2. The package boiler will have a maximum of 600 horsepower. This is will have a maximum heat input capacity of 1.5 MMBtu per hour with a fuel usage of 70 gallons per hour of 0.5 percent sulfur, No.2 fuel oil. TEC believes that this package boiler is exempt from permitting under FDEP categorical exemption in the regulations 62-210.300(3)(a)1. F.A.C.

*" One or more fossil fuel steam generators and hot water generating units located within a single facility; collectively having a total rated heat input equaling 100 million BTU per hour or less; and collectively burning annually no more than 145,000 gallons of fuel oil containing no more than 1.0 percent sulfur, or no more than 290,000 gallons of fuel oil containing no more than 0.5 percent sulfur, or an equivalent prorated amount of fuel oil if multiple fuels are used, provided none of the generators or hot water generating units is subject to the Federal Acid Rain Program or any standard or requirement under 42 U.S.C. section 7411 or 7412."*

The package boiler will be brought on-site for Bayside Unit 1 in October and will remain on-site for a duration of approximately five (5) weeks. TEC requests FDEP confirmation of this exemption from permitting. TEC appreciates your cooperation in this matter and if you have any questions, please call me at (813) 641-5034.

Sincerely,

*Laura R. Crouch*

Laura R. Crouch  
Manager Air Programs  
Environmental Affairs

EA/bmr/DNL133

cc: Mr. Scott Sheplak (FDEP)  
Mr. Sterlin Woodard (EPCHC)  
Mr. Jerry Kissel (FDEP)

*Advised Ms. Latchman by phone that we disagree. She will submit exemption claim on different rule basis  
Ray 10/16*

TAMPA ELECTRIC COMPANY  
P. O. BOX 111 TAMPA, FL 33601-0111

(813) 228-4111

AN EQUAL OPPORTUNITY COMPANY  
HTTP://WWW.TAMPAELECTRIC.COM

CUSTOMER SERVICE:  
HILLSBOROUGH COUNTY (813) 223-0800  
OUTSIDE HILLSBOROUGH COUNTY 1 (888) 223-0800



TAMPA ELECTRIC

August 10, 2001

RECEIVED

AUG 13 2001

BUREAU OF AIR REGULATION

Mr. Jeffery F. Koerner, P.E.  
New Source Review Section  
Florida Department of Environmental Protection  
111 South Magnolia Avenue, Suite 4  
Tallahassee, Florida 32301

Via FedEx  
Airbill No. 7901 2705 9498

**Re: Request for Additional Information  
Project No. 0570040-015-AC  
Bayside Units 3 and 4 Re-powering Project**

Dear Mr. Koerner:

Tampa Electric Company (TEC) has received your letter of incompleteness dated July 17, 2001 addressing the proposed repowering of F.J. Gannon Station Units 3 and 4 to Bayside Power Station Units 3 and 4. This correspondence is intended to provide a response to each specific issue raised by the Department. For your convenience, TEC has restated each point and provided a response below each specific issue.

FDEP Issue 1

In March of 2001, the Department issued a final permit for Bayside Units 1 and 2, which will re-power the steam turbines for existing Gannon Units 5 and 6. The application to re-power the steam turbines for existing Gannon Units 3 and 4 was submitted only three months later. The Department believes that this application is the second phase of the Gannon re-powering project. Please revise PSD netting analysis to include the following:

- Specify the PSD contemporaneous period as defined in Rule 62-212.400(2)(e)3, F.A.C.
- Include all emissions increases that have occurred or will occur during the contemporaneous period from all projects.
- Include all of the emissions decreases that have occurred or will occur during the contemporaneous period from all projects.
- Update the net emissions changes and PSD applicability accordingly.

TEC Response

**The requested analysis is enclosed as attachment 1. Please note that Tampa Electric does not agree with the Department's position that the repowering of Gannon 3 and 4 is not a separate project from the repowering of Gannon 5 and 6.**

Mr. Jeffery F. Koerner, P.E.

August 10, 2001

Page 2 of 5

FDEP Issue 2

Has TEC considered re-powering the existing steam turbines for Gannon Units 1 and 2? Has TEC contracted for any work involving the re-powering of these remaining steam turbines? Please submit a revised construction schedule for all units to be re-powered showing the planned startup date for each Bayside Unit and the shutdown date for each Gannon Unit.

TEC Response

At this time, TEC has no intention of repowering the existing steam turbines serving Gannon Units 1 and 2, nor has it contracted for any work involving the repowering of these two units. However, if TEC elects to repower these two steam turbines in the future, TEC will submit a permit application to the Department requesting permission to do so as outlined in Paragraph 27 of the EPA Consent Decree.

The proposed schedule for the repowering of the Gannon units 3-6 is provided below. This schedule is subject to change during the construction of the units. TEC will notify the Department of any significant deviation from this schedule.

<u>Event</u>	<u>Estimated Date</u>
Shutdown of Gannon 5	2/08/03
Startup of BPS 1	5/1/03*
Shutdown of Gannon 6	10/01/03
Startup of BPS 2	5/01/04*
Shutdown of Gannon 3	1/29/04
Startup of BPS 3	5/1/04*
Shutdown of Gannon 4	1/29/04
Startup of BPS 4	5/1/04*

\*This is the expected date of commercial operation.

FDEP Issue 3

Is TEC requesting any emissions standards, operational constraints, monitoring provisions, etc. that are different from those contained in the final permit issued for Bayside Units 1 and 2?

TEC Response

TEC is not requesting any emissions standards, operational constraints, monitoring provisions, etc. that are different from those contained in the final permit issued for Bayside Units 1 and 2.

FDEP Issue 4

Page 1-2 of the application states, "Following installation and commercial operation of Bayside Unit 3, existing coal fired operation at F.J. Gannon Station Unit 3 will permanently cease. Following installation and commercial operation of Bayside Unit 4, existing coal fired operation at F.J. Gannon Station Unit 4 will permanently cease." The Department notes that, for an emissions decrease to be enforceable, each existing unit must be completely shutdown and rendered incapable of operation prior to startup of the corresponding new unit. Please comment.

TEC Response

Page 1-2 of the application should read, "Prior to the commencement of commercial operation of Bayside Unit 3, existing coal fired operation at F.J. Gannon Station Unit 3 will permanently cease.

Mr. Jeffery F. Koerner, P.E.

August 10, 2001

Page 3 of 5

**Prior to the commencement of commercial operation of Bayside Unit 4, existing coal fired operation at F.J. Gannon Station Unit 4 will permanently cease."**

FDEP Issue 5

Each new "Bayside Unit" will consist of two combined cycle units described as:

Each unit consists of a General Electric Model PG7241(FA) gas turbine-electrical generator set, an automated gas turbine control system, an inlet air filtration system, an evaporative inlet air cooling system, an unfired heat recovery steam generator (HRSG), a single exhaust stack that is 150 feet tall and 19.0 feet in diameter and associated support equipment. The project also includes electric fuel heaters and cooling towers. Natural gas is the exclusive fuel.

**Controls:** Emissions of CO, PM/PM<sub>10</sub>, SAM, SO<sub>2</sub>, and VOC are minimized by the efficient combustion of natural gas at high temperatures. NO<sub>x</sub> emissions are reduced by a Selective Catalytic Reduction (SCR) system combined with dry low-NO<sub>x</sub> (DLN) combustion technology when firing natural gas.

**Heat Input:** At a compressor inlet air temperature of 59° F and firing 1842 mmBTU (HHV) per hour of natural gas, each unit produces approximately 169 MW. Exhaust gases exit the stack with a volumetric flow rate of approximately 1,020,000 acfm at 215° F.

**Generating Capacity:** Bayside Units 3A and 3B will supply steam to a single steam electrical generator (formerly serving Gannon Unit 3) with a nameplate rating of 180 MW. Bayside Units 4A and 4B will supply steam to a single steam electrical generator (formerly serving Gannon Unit 4) with a nameplate rating of 188 MW of electrical power. Bayside Unit 3 is designed to produce a nominal 512 MW and Bayside Unit 4 is designed to produce a nominal 520 MW of electrical power. Is this an accurate description?

TEC Response

**Based on the continued development and design of the Bayside Units 3 and 4 repowering project, some of the above description should be changed. Below is the suggested revised text, changed from the original using the strikethrough and underline convention.**

Each new "Bayside Unit" will consist of two combined cycle units described as:

Each unit consists of a General Electric Model PG7241(FA) gas turbine-electrical generator set, an automated gas turbine control system, an inlet air filtration system, an evaporative inlet air cooling system, an unfired heat recovery steam generator (HRSG), a single exhaust stack that is 150 feet tall and 19.0 feet in diameter and associated support equipment. The project also includes electric fuel heaters and cooling towers. Natural gas is the exclusive fuel.

**Controls:** Emissions of CO, PM/PM<sub>10</sub>, SAM, SO<sub>2</sub>, and VOC are minimized by the efficient combustion of natural gas at high temperatures. NO<sub>x</sub> emissions are reduced by a Selective Catalytic Reduction (SCR) system combined with dry low-NO<sub>x</sub> (DLN) combustion technology when firing natural gas.

Mr. Jeffery F. Koerner, P.E.

August 10, 2001

Page 4 of 5

**Heat Input:** At a compressor inlet air temperature of 59° F and firing 1659.5 mmBTU (LHV) per hour of natural gas, each unit produces approximately 169 MW. Exhaust gases exit the stack with a volumetric flow rate of approximately 1,030,163 acfm at 220° F.

**Generating Capacity:** Bayside Units 3A and 3B will supply steam to a single steam electrical generator (formerly serving Gannon Unit 3) with a nameplate rating of 163 MW. Bayside Units 4A and 4B will supply steam to a single steam electrical generator (formerly serving Gannon Unit 4) with a nameplate rating of 170 MW of electrical power. Bayside Unit 3 is designed to produce a nominal 497 MW and Bayside Unit 4 is designed to produce a nominal 488 MW of electrical power.

#### FDEP Issue 6

The Bayside 1 and 2 re-powering project combined with the Bayside 3 and 4 re-powering project will result in total formaldehyde emissions greater than 10 tons per year and total hazardous air pollutant emissions (HAP) greater than 25 tons per year. Please submit a case-by-case MACT analysis for the Department's review. The Department will make a case-by-case MACT determination for these phased projects.

#### TEC Response

General Electric has recently completed HAP emissions testing that suggests that actual HAP emissions are lower than those developed by EPA as part of the AP-42 emission factor inventory. In the Bayside Units 1 and 2 and the Bayside Units 3 and 4 permit applications, TEC used modified AP-42 emission factors to estimate the HAP emissions from the combustion turbines associated with each project. Based on the additional research completed by General Electric, it appears that HAP emissions will be lower than those originally submitted by TEC. Consequently, TEC requests that a formal MACT determination for Bayside Units 1 through 4 be deferred until the units commence commercial operation and TEC has an opportunity to perform HAP emissions testing. Specifically, Condition 2 of the Bayside Power Station Units 1 and 2 Air Construction Permit states:

*"MACT Determination: The MACT applicability determination for this project is deferred until a combined cycle gas turbine is tested for HAP emissions in accordance with Condition No. 22 of this section. However, the permittee shall plan accordingly for the possibility of future applicable controls. If additional controls are later required, the Department shall allow the permittee a reasonable time to install equipment and conform to new or additional conditions. [Rules 62-4.080 and 62-204.800(10)(d), F.A.C.; Section 112(g), CAAA]"*

TEC requests that this language be incorporated into the Bayside Units 3 and 4 Air Construction Permit.

#### FDEP Issue 7

Please provide a new vendor's quote for this project based on 11 proposed systems firing natural gas. Revise the cost analysis if necessary.

#### TEC Response

The requested information is provided as attachment 2. Based on the quotation obtained from Engelhard, it will cost \$3,194 to remove one ton of carbon monoxide from each Bayside Unit. TEC believes that this cost exceeds that which has recently been considered to be economically feasible by the Department. It is also worth noting that this analysis is extremely conservative. Due to

Mr. Jeffery F. Koerner, P.E.

August 10, 2001

Page 5 of 5

**combustion modifications completed on Gannon 5 and 6 to control NO<sub>x</sub> emissions, actual CO emissions are likely much higher than those used as the baseline in this evaluation. As such, the actual increase in CO emissions due to this project is likely much lower than the 883.2 tons per year used in the netting calculations. This, in turn, drives up the cost to control one ton of CO.**

FDEP Issue 8

The Department reserves the right to ask for additional information regarding the air quality analysis within the 30-day period after receiving the application with sufficient fee (on or before July 26, 2001).

TEC Response

**TEC does not have any issues with the above statement.**

FDEP Issue 9

The Department will forward any comments or questions if received from EPA Region 4, the National Park Service, the Hillsborough County Environmental Protection Commission, or the Department's Southwest District Office.


TEC Response

**TEC appreciates the opportunity to comment on any questions raised by the above mentioned agencies.**

TEC understands that with the submission of this additional information, the Department will continue processing the application.

If you have any questions regarding this matter, please Shannon Todd or me at (813) 641-5125.

Sincerely,



Karen Sheffield  
General Manager- Gannon Station  
Tampa Electric Company

EP\gm\SKT270

Attachments

c: Mr. Jerry Kissel, FDEP - SWD  
Mr. Jerry Campbell, EPCHC  
Mr. John Bunyak, NPS  
Mr. Gregg Worley, EPA Region 4  
Ms. Katy Forney, EPA Region 4



# Attachment 1

### **Bayside Units 1, 2, 3 and 4 PSD Netting Analysis**

The procedures for determining applicability of the PSD NSR permitting program to modifications planned at existing major Florida facilities are specified in Rule 62-212.400(2)(d)4., F.A.C. Because the existing F.J. Gannon Station is a major facility (i.e., has potential emissions of 100 tpy or more of an air pollutant subject to regulation under Chapter 403, Florida Statutes) that would be subject to PSD preconstruction review if it were itself a proposed new facility (i.e., has potential emissions of 100 tpy or more of a pollutant regulated under the Clean Air Act and is located in an attainment area), modifications to the existing F.J. Gannon Station which result in a *significant net emissions increase* of any pollutant regulated under the Clean Air Act are subject to PSD NSR.

The term “significant net emission increase” is defined by Rule 62-212.400(2)(e), F.A.C. For each regulated pollutant, the net emission increase for a modification project is equal to the sum of the increases in emissions associated with the proposed project plus all facility-wide creditable, contemporaneous emission increases minus all facility-wide creditable, contemporaneous emission decreases. If this net emissions increase is equal to or greater than the applicable Table 212.400-2, F.A.C. Regulated Pollutants—Significant Emission Rates, then the net emission increase is considered to be “significant” and the modification will be subject to PSD NSR for that particular regulated pollutant.

In accordance with Rule 62-212.400(2)(e)3., F.A.C., the “contemporaneous” period for a modification project begins five years prior to the date of submittal of a complete permit application and ends when the new or modified emission units are estimated to begin operation.

In accordance with Rule 62-212.400(2)(e)4., F.A.C., contemporaneous emission increases and decreases are “creditable” if:

- (1) the emission increase or decrease will affect PSD increment consumption; i.e., will consume or expand the available increment;
- (2) The emission increase or decrease was not previously considered in the issuance of a PSD NSR permit (to avoid "double counting"); and
- (3) The FDEP has not relied on the emission increase or decrease in attainment or reasonable further progress demonstrations.

Contemporaneous emission increases and decreases are based on *actual* emission rates. The term "actual emissions" is defined by Rule 62-210.200(12), F.A.C. For new emission units, including new electric utility steam generating units, actual emissions are equal to potential emissions. For changes to existing emission units, actual emissions are generally the actual average emission rates, in tpy, for the two year period preceding the change and which are representative of normal operations. The Department may allow the use of a different time period if it is determined that the other time period is more representative of the normal operation of an emissions unit.

For emission decreases, the old level of actual or allowable emissions (whichever is lower) must be greater than the new level of actual emissions. The actual emission decrease must also take place on or before the date that emissions from the modification project first occur and must be federally enforceable on and after the date the Department issues a construction permit for the modification project.

For Bayside Units 1, 2, 3 and 4, the contemporaneous period is projected to begin in September 1995 and end in June 2005. Creditable emission decreases that will occur within this contemporaneous period consist of the actual emissions associated with the cessation of coal-fired operations of F.J. Gannon Station Units 3, 4, 5 and 6. Creditable emission increases consist of those associated with Bayside Units 1, 2, 3 and 4. There are no other permanent creditable emission increases that have occurred or will occur at the F.J. Gannon Station during the September 1995 through June 2005 contemporaneous period.

Summaries of historical, actual emission rates for F.J. Gannon Station Units 1, 2, 3 and 4 for the 1996 – 2000 five year period are provided on Tables 1 through 4, respectively.

Table 5 provides an analysis of PSD NSR applicability for Bayside Units 1, 2, 3 and 4. Contemporaneous, creditable emission decreases were determined based on the average actual emissions for F.J. Gannon Station Units 3 and 4 for the 1999/2000 two-year period, F.J. Gannon Station Unit 5 for the 1998/1999 two-year period, and F.J. Gannon Station Unit 6 for the 1997/1998 two-year period. These actual emission rates reflect the retroactive application of NO<sub>x</sub>, SO<sub>2</sub>, and PM BACT in accordance with provisions of the EPA/TEC Consent Decree. The net emission rate changes due to the increase in potential emissions for Bayside Units 1, 2, 3 and 4, minus the two-year average actual emissions for F.J. Gannon Station Units 3, 4, 5 and 6 are all below the applicable Table 212.400-2, F.A.C. Regulated Pollutants—Significant Emission Rates with the exception of CO and PM/PM<sub>10</sub>. For most regulated pollutants, there will be a substantial reduction in emissions; e.g., approximately 1,300 and 1,800 tpy for SO<sub>2</sub> and NO<sub>x</sub>, respectively. Reductions in real actual emission rates (i.e., excluding adjustments for the retroactive application of NO<sub>x</sub>, SO<sub>2</sub>, and PM BACT) will be considerably higher. Accordingly, Bayside Units 1, 2, 3 and 4 are subject to PSD NSR for CO and PM/PM<sub>10</sub> only.

**Table 1. Bayside Station Units 1, 2, 3 and 4  
Netting Analysis - F.J. Gannon Station Unit 3 Historical Emissions**

	1996	1997	1998	1999	2000	96-00, 5 Yr Avg	99,00 Avg
Coal Usage (tons)	298,202	502,172	441,838	431,164	474,944	429,664	453,054
Wt % Ash	6.60	6.88	6.79	6.87	7.09	6.85	6.98
Heat Content (10 <sup>6</sup> Btu/ton)	23.31	20.06	19.19	21.00	20.00	20.71	20.50
Wt % S	1.12	1.15	0.87	0.95	0.85	0.99	0.90
Oil Usage (10 <sup>3</sup> gal)	311.0	639.9	599.0	397.0	10,156.9	2,420.7	5,277
Heat Content (10 <sup>6</sup> Btu/10 <sup>3</sup> gal)	138.556	137.989	138.551	138.000	138.000	138.219	138.000
Wt % S	0.30	0.15	0.28	0.41	0.42	0.31	0.42
Total Heat Input (10 <sup>6</sup> Btu/yr)	6,994,776	10,161,863	8,561,862	9,109,230	10,900,532	9,145,653	10,004,881
NO <sub>x</sub> <sup>(a)</sup>	349.7	508.1	428.1	455.5	545.0	457.3	500.2
CO AOR	90.0	153.0	111.0	108.8	119.8	116.5	114.3
SO <sub>2</sub> <sup>(b)</sup>	320.3	488.6	372.9	372.9	367.5	384.4	370.2
H <sub>2</sub> SO <sub>4</sub> <sup>(c)</sup> AP-42 (1998)	18.7	32.3	21.6	23.0	25.9	24.3	24.4
PM <sub>10</sub> <sup>(d)</sup>	35.0	50.8	42.8	45.5	54.5	45.7	50.0
PM <sup>(d)</sup>	35.0	50.8	42.8	45.5	54.5	45.7	50.0
Pb AOR	2.0	3.3	2.9	2.9	0.1	2.2	1.5
VOC AP-42 (1998)	16.4	27.7	24.4	23.8	27.1	23.9	25.4

- (a) Actual emissions based on 0.10 lb/MMBtu emission rate per EPA/TEC Consent Decree.  
(b) Actual emissions reduced by 95% per EPA/TEC Consent Decree.  
(c) Actual emissions reduced by 35% to reflect retroactive BACT.  
(d) Actual emissions based on 0.010 lb/MMBtu emission rate per EPA/TEC Consent Decree.

Sources: ECT, 2001.  
TEC, 2001.

**Table 2. Bayside Station Units 1, 2, 3 and 4  
Netting Analysis - F.J. Gannon Station Unit 4 Historical Emissions**

	1996	1997	1998	1999	2000	96-00, 5 Yr Avg	99,00 Avg
Coal Usage (tons)	486,874	474,906	486,831	408,955	461,418	463,797	435,187
Wt % Ash	6.75	6.85	6.79	6.95	7.13	6.89	7.04
Heat Content (10 <sup>6</sup> Btu/ton)	22.35	20.87	20.04	20.00	20.00	20.65	20.00
Wt % S	1.08	1.04	0.87	0.94	0.86	0.96	0.90
Oil Usage (10 <sup>3</sup> gal)	311.0	576.9	599.0	397.0	10,156.9	2,408.1	5,277
Heat Content (10 <sup>6</sup> Btu/10 <sup>3</sup> gal)	138.556	137.989	138.551	138.000	138.000	138.219	138.000
Wt % S	0.30	0.15	0.28	0.41	0.41	0.31	0.41
Total Heat Input (10 <sup>6</sup> Btu/yr)	10,924,725	9,990,887	9,839,084	8,233,886	10,630,012	9,923,719	9,431,949
NO <sub>x</sub> <sup>(a)</sup>	546.2	499.5	492.0	411.7	531.5	496.2	471.6
CO AOR	147.0	143.0	123.0	103.2	116.4	126.5	109.8
SO <sub>2</sub> <sup>(b)</sup>	492.8	519.2	477.7	373.5	391.6	450.9	382.5
H <sub>2</sub> SO <sub>4</sub> <sup>(c)</sup> AP-42 (1998)	29.4	27.6	23.7	21.6	25.4	25.5	23.5
PM <sub>10</sub> <sup>(d)</sup>	54.6	50.0	49.2	41.2	53.2	49.6	47.2
PM <sup>(d)</sup>	54.6	50.0	49.2	41.2	53.2	49.6	47.2
Pb AOR	3.2	3.2	3.2	2.7	0.1	2.5	1.4
VOC AP-42 (1998)	26.8	26.2	26.8	22.5	26.4	25.7	24.5

(a) Actual emissions based on 0.10 lb/MMBtu emission rate per EPA/TEC Consent Decree.

(b) Actual emissions reduced by 95% per EPA/TEC Consent Decree.

(c) Actual emissions reduced by 35% to reflect retroactive BACT.

(d) Actual emissions based on 0.010 lb/MMBtu emission rate per EPA/TEC Consent Decree.

Sources: ECT, 2001.  
TEC, 2001.

**Table 3. Bayside Station Units 1, 2, 3 and 4  
Netting Analysis - F.J. Gannon Station Unit 5 Historical Emissions**

	1996	1997	1998	1999	2000	96 - 00, 5 Yr Avg	98, 99 Avg
Coal Usage (tons)	574,584	450,802	556,487	541,559	418,667	508,420	549,023
Wt % Ash	7.47	8.26	8.15	7.58	6.95	7.68	7.87
Heat Content (10 <sup>6</sup> Btu/ton)	24.65	23.96	24.00	24.00	24.00	24.12	24.00
Wt % S	1.19	1.16	1.21	1.17	1.22	1.19	1.19
Oil Usage (10 <sup>3</sup> gal)	311.0	600.9	599.0	397.0	10,156.9	2,413.0	498.0
Heat Content (10 <sup>6</sup> Btu/10 <sup>3</sup> gal)	138.556	137.989	138.551	138.000	138.000	138.219	138.276
Wt % S	0.30	0.15	0.28	0.41	0.42	0.31	0.35
Total Heat Input (10 <sup>6</sup> Btu/yr)	14,208,885	10,884,135	13,438,679	13,052,202	11,449,660	12,606,712	13,245,440
NO <sub>x</sub> <sup>(a)</sup>	710.4	544.2	671.9	652.6	572.5	630.3	662.3
CO AOR	173.0	135.0	140.0	136.4	105.7	138.0	138.2
SO <sub>2</sub> <sup>(b)</sup>	648.4	537.7	685.1	630.1	538.6	608.0	657.6
H <sub>2</sub> SO <sub>4</sub> <sup>(c)</sup> AP-42 (1998)	38.2	29.2	37.7	35.4	31.9	34.5	36.6
PM <sub>10</sub> <sup>(d)</sup>	71.0	54.4	67.2	65.3	57.2	63.0	66.2
PM <sup>(d)</sup>	71.0	54.4	67.2	65.3	57.2	63.0	66.2
Pb AOR	3.8	3.0	3.7	3.6	0.1	2.8	3.4
VOC AP-42 (1998)	31.6	24.9	30.7	29.8	24.0	28.2	28.2

(a) Actual emissions based on 0.10 lb/MMBtu emission rate per EPA/TEC Consent Decree.

(b) Actual emissions reduced by 95% per EPA/TEC Consent Decree.

(c) Actual emissions reduced by 35% to reflect retroactive BACT.

(d) Actual emissions based on 0.010 lb/MMBtu emission rate per EPA/TEC Consent Decree.

Sources: ECT, 2001.  
TEC, 2001.

**Table 4. Bayside Station Units 1, 2, 3 and 4  
Netting Analysis - F.J. Gannon Station Unit 6 Historical Emissions**

	1996	1997	1998	1999	2000	96 - 00, 5 Yr Avg	97, 98 Avg
Coal Usage (tons)	892,742	920,526	860,597	693,039	391,079	751,597	890,562
Wt % Ash	7.48	8.79	8.41	7.28	7.18	7.83	8.60
Heat Content (10 <sup>6</sup> Btu/ton)	24.85	24.28	24.01	24.00	16.00	22.63	24.15
Wt % S	1.19	1.18	1.22	1.13	1.10	1.16	1.20
Oil Usage (10 <sup>3</sup> gal)	311.0	639.9	599.0	362.0	6,587.5	1,699.9	619.4
Heat Content (10 <sup>6</sup> Btu/10 <sup>3</sup> gal)	138,556	137,989	138,551	138,000	138,000	138,219	138,270
Wt % S	0.30	0.15	0.28	0.41	0.42	0.31	0.22
Total Heat Input (10 <sup>6</sup> Btu/yr)	22,229,515	22,438,664	20,745,925	16,682,892	7,166,339	17,852,667	21,592,294
NO <sub>x</sub> <sup>(a)</sup>	1,111.5	1,121.9	1,037.3	834.1	358.3	892.6	1,079.6
CO AOR	269.0	278.0	216.0	174.2	98.5	207.1	247.0
SO <sub>2</sub> <sup>(b)</sup>	1,015.4	1,141.5	1,185.2	801.5	465.5	921.8	1,163.3
H <sub>2</sub> SO <sub>4</sub> <sup>(c)</sup> AP-42 (1998)	59.3	60.6	58.7	43.8	26.2	49.7	59.6
PM <sub>10</sub> <sup>(d)</sup>	111.1	112.2	103.7	83.4	35.8	89.3	108.0
PM <sup>(d)</sup>	111.1	112.2	103.7	83.4	35.8	89.3	108.0
Pb AOR	5.9	6.1	5.7	4.6	0.1	4.5	5.9
VOC AP-42 (1998)	49.1	50.7	47.4	38.2	22.2	41.5	49.0

(a) Actual emissions based on 0.10 lb/MMBtu emission rate per EPA/TEC Consent Decree.

(b) Actual emissions reduced by 95% per EPA/TEC Consent Decree.

(c) Actual emissions reduced by 35% to reflect retroactive BACT.

(d) Actual emissions based on 0.010 lb/MMBtu emission rate per EPA/TEC Consent Decree.

Sources: ECT, 2001.  
TEC, 2001.



**Table 5. Bayside Station  
Bayside Units 1 - 4/F.J. Gannon Units 3 - 6 Emissions Netting Analysis**

	F. J. Gannon Units 3, 4, 5 & 6 (tpy)					Units 3 & 4 2 Yr <sup>(a)</sup> Avg	Units 5 & 6 2 Yr <sup>(b)(c)</sup> Avg	Units 3 - 6 2 Yr <sup>(b)(c)</sup> Avg	CT 1A-4B (tpy)	Net Change (tpy)	PSD Threshold (tpy)	PSD Review (Y/N)
	1996	1997	1998	1999	2000							
Coal Usage (tons)	2,252,402	2,348,406	2,345,753	2,074,717	1,746,108	888,241	1,439,585	2,327,825	N/A	N/A	N/A	N/A
Wt % Ash	7.08	7.70	7.54	7.17	7.09	7.01	8.23	15.24	N/A	N/A	N/A	N/A
Heat Content (10 <sup>6</sup> Btu/ton)	23.79	22.29	21.81	22.25	20.00	20.25	24.07	44.32	N/A	N/A	N/A	N/A
Wt % S	1.15	1.13	1.04	1.05	1.01	0.90	1.20	2.10	N/A	N/A	N/A	N/A
Oil Usage (10 <sup>3</sup> gal)	1,244.0	2,457.5	2,396.0	1,553.0	37,058.2	10,553.9	1,117.4	11,671.3	N/A	N/A	N/A	N/A
Heat Content (10 <sup>6</sup> Btu/10 <sup>3</sup> gal)	138,556	137,989	138,551	138,000	138,000	138,000	138,273	276,273	N/A	N/A	N/A	N/A
Wt % S	0.30	0.15	0.28	0.41	0.42	0.41	0.28	0.69	N/A	N/A	N/A	N/A
Total Heat Input (10 <sup>6</sup> Btu/yr)	54,357,901	53,475,548	52,585,549	47,078,210	40,146,544	19,436,830	34,837,734	54,274,565	N/A	N/A	N/A	N/A
NO <sub>x</sub> <sup>(d)</sup>	2,717.9	2,673.8	2,629.3	2,353.9	2,007.3	971.8	1,741.9	2,713.7	1,422.9	-1,290.8	40.0	N
CO AOR	679.0	709.0	590.0	522.6	440.4	224.1	385.2	609.3	1,492.5	883.2	100.0	Y
SO <sub>2</sub> <sup>(e)</sup>	2,476.9	2,686.9	2,720.8	2,177.9	1,763.1	752.7	1,820.9	2,573.6	757.1	-1,816.5	40.0	N
H <sub>2</sub> SO <sub>4</sub> <sup>(f)</sup> AP-42 (1998)	145.5	149.7	141.6	123.7	109.4	47.9	96.2	144.1	129.9	-14.2	7.0	N
PM <sub>10</sub> <sup>(g)</sup>	271.8	267.4	262.9	235.4	200.7	97.2	174.2	271.4	1,077.1	805.7	15.0	Y
PM <sup>(g)</sup>	271.8	267.4	262.9	235.4	200.7	97.2	174.2	271.4	1,077.1	805.7	25.0	Y
Pb AOR	15.0	15.6	15.6	13.8	0.4	2.9	9.3	12.2	1.6	-10.6	0.6	N
VOC AP-42 (1998)	124.0	129.4	129.3	114.3	99.7	49.9	77.3	127.2	148.7	21.5	40.0	N

- (a) 1999, 2000 average for Units 3 and 4.
- (b) 1998, 1999 average for Unit 5.
- (c) 1997, 1998 average for Unit 6.
- (d) Actual emissions based on 0.10 lb/MMBtu emission rate per EPA/TEC Consent Decree.
- (e) Actual emissions reduced by 95% per EPA/TEC Consent Decree.
- (f) Actual emissions reduced by 35% to reflect retroactive BACT.
- (g) Actual emissions based on 0.010 lb/MMBtu emission rate per EPA/TEC Consent Decree.

Sources: ECT, 2001.  
TEC, 2001.

# **Attachment 2**

# ENGELHARD

101 WOOD AVENUE  
ISELIN, NJ 08830

ENGELHARD CORPORATION  
2205 CHEQUERS COURT  
BEL AIR, MD 21015  
PHONE 410-569-0297  
FAX 410-569-1841  
E-Mail fred.booth@engelhard.com

---

DATE: August 1, 2001 NO. PAGES 3  
TO: ECT via e-mail  
ATTN: Tom Davis

---

ATTN: ENGELHARD  
Nancy Ellison

---

FROM: Fred Booth Ph 410-569-0297 // FAX 410-569-1841

---

RE: TECO - Gannon  
CO Oxidation System Components  
Engelhard Budgetary Proposal EPB00385

We provide Engelhard Proposal EPB00385 for Engelhard Camet® metal substrate CO oxidation system per your e-mail request of July 31, 2001.

Our Proposal is based on:

- Given data for GE 7FA Gas Turbine operating in unfired combined cycle mode;
- CO Catalyst for 90% CO Reduction;
- Advise VOC reduction - inlet levels not provided. VOC Composition assumed Non-Methane / Non-Ethane – 50% Saturated.
- Assumed HRSG inside liner dimensions of 67 ft H x 26 ft W.
- Three (3) Year Performance Guarantee;

We request the opportunity to work with you on this project.

Sincerely yours,

ENGELHARD CORPORATION



Frederick A. Booth  
Senior Sales Engineer

**ENGELHARD CORPORATION**  
**CAMET® CO OXIDATION SYSTEMS**

**Scope of Supply:** The equipment supplied is installed by others in accordance with the Engelhard design and installation instructions.

- Engelhard CAMET® CO Oxidation Catalyst Modules;
- Internal support structures for catalyst modules (frame). Frame design allows adding one more layer.
- Technical Service during installation and Start-Up;

**Excluded from Scope of Supply:**

Any internally insulated reactor ductwork to house catalysts

Any transitions to and from reactor

Any monorails and hoists for handling modules

Electrical grounding equipment

Foundations

All other items not specifically listed in Scope of Supply

Structural support

Any interconnecting field piping or wiring

Utilities

All Monitors

**PRICES:** fob, plant gate, job site **See Below**

**WARRANTY AND GUARANTEE:**

Mechanical Warranty:

One year of operation\* or 1.5 years after catalyst delivery, whichever occurs first.

Performance Guarantee:

Three (3) years of operation or 3.5 years after catalyst delivery, whichever occurs first.

Catalyst warranty is prorated over the guaranteed life

**DOCUMENT / MATERIAL DELIVERY SCHEDULE**

Drawings / Documentation – 2-3 weeks after notice to proceed and Engelhard receipt of all engineering specifications and details

Material Delivery

CO Modules

20 - 24 weeks after approval and release for fabrication

---

**CO SYSTEM DESIGN BASIS:**

Gas Flow from:

GE 7FA Combustion Turbine - Combined Cycle – NO duct burner

Gas Flow:

Horizontal

Fuel:

Natural Gas

Gas Flow Rate (At catalyst face):

See Performance data

Temperature (At catalyst face):

See Performance data

CO Concentration (At catalyst face):

See Performance Data

CO Reduction:

90% CO Reduction

CO Pressure Drop:

See Performance data

VOC Concentration (At catalyst face):

Not Provided

VOC Reduction:

Advise

VOC Composition

Assumed Non-Methane / Non-Ethane – 50% Saturated

---

### Performance Data and Budget Pricing

GIVEN / CALCULATED DATA		CASE	1	2
	AMBIENT		18	93
	FUEL		NG	NG
	TURBINE EXHAUST FLOW, lb/hr		3,811,000	2,302,000
	TURBINE EXHAUST GAS ANALYSIS, % VOL. - N <sub>2</sub>		75.09	73.45
			O <sub>2</sub> 12.52	12.79
			CO <sub>2</sub> 3.88	3.53
			H <sub>2</sub> O 7.71	9.36
			Ar 0.80	0.87
	GIVEN TURBINE CO, ppmvd @ 15% O <sub>2</sub>		7.2	7.8
	GIVEN TURBINE CO, lb/hr		31.0	18.6
	GIVEN TURBINE VOC, ppmvd @ 15% O <sub>2</sub>		N / A	N / A
	GIVEN TURBINE VOC, lb/hr		N / A	N / A
	CALC. GAS MOL. WT.		28.46	28.26
	ASSUMED GAS TEMP. @ CO CATALYST, °F (+/-25)		650	600
	DESIGN REQUIREMENTS CO OUT, ppmvd @ 15% O <sub>2</sub>		0.72	0.78
	VOC OUT, ppmvd @ 15% O <sub>2</sub>		Advise	Advise
	CO PRESSURE DROP - "WG MAX.		Advise	Advise
	GUARANTEED PERFORMANCE DATA			
	CO CONVERSION, % - Min.		90.0%	90.0%
	CO OUT, lb/hr - Max.		3.1	1.9
	CO OUT, ppmvd @ 15% O <sub>2</sub>		0.7	0.8
	SO <sub>2</sub> -> SO <sub>3</sub> CONVERSION, % - Max.		10%	7%
	VOC** CONVERSION, % - Min.		42%	44%
	VOC** OUT, lb/hr		N / A	N / A
	VOC** OUT, ppmvd @ 15% O <sub>2</sub>		N / A	N / A
	** VOC - NON-METHANE / NON-ETHANE - 50% SATURATED			
	CO PRESSURE DROP, "WG - Max.		1.2	0.6
	<b>CO SYSTEM - \$\$</b>		<b>\$670,000</b>	
	<b>REPLACEMENT CO CATALYST MODULES - \$\$</b>		<b>\$600,000</b>	

### Dimensions:

Inside Liner Width (A) 26 ft  
 Inside Liner Height (B) 67 ft  
 Frame Depth (C) 18 in




Table 4-4. Capital Costs for Oxidation Catalyst System, Eleven CT/HRSGs

Item	Dollars	OAQPS Factor
<u>Direct Costs</u>		
Purchased equipment	7,370,000	A
Sales tax	442,200	0.06 x A
Instrumentation	737,000	0.10 x A
Freight	368,500	0.05 x A
<b>Subtotal Purchased Equipment</b>	<b>8,917,700</b>	<b>B</b>
Installation		
Foundations and support	713,416	0.08 x B
Handling and erection	1,248,478	0.14 x B
Electrical	356,708	0.04 x B
Piping	178,354	0.02 x B
Insulation for ductwork	89,177	0.01 x B
Painting	89,177	0.01 x B
<b>Subtotal Installation Cost</b>	<b>2,675,310</b>	
<b>Total Direct Costs (TDC)</b>	<b>11,593,010</b>	
<u>Indirect Costs</u>		
Engineering	891,770	0.01 x B
Construction and field expense	445,885	0.05 x B
Contractor fees	891,770	0.10 x B
Startup	178,354	0.02 x B
Performance test	89,177	0.01 x B
Contingency	267,531	0.03 x B
<b>Total Indirect Costs (TIC)</b>	<b>2,764,487</b>	
<b>TOTAL CAPITAL INVESTMENT (TCI)</b>	<b>14,357,497</b>	TDC + TIC

Source: ECT, 2001.

Table 4-5. Annual Operating Costs for Oxidation Catalyst System, Eleven CT/HRSGs

Item	Dollars	OAQPS Factor
<u>Direct Costs</u>		
Catalyst costs		
Replacement (materials and labor)	7,337,616	
Credit for used catalyst	(990,000)	15% credit
<b>Annualized Catalyst Cost</b>	<b>1,548,124</b>	
Energy Penalties		
Turbine backpressure	1,081,159	0.2% penalty
<b>Total Direct Costs (TDC)</b>	<b>2,629,284</b>	
<u>Indirect Costs</u>		
Administrative charges	287,150	0.02 x TCI
Property taxes	143,575	0.01 x TCI
Insurance	143,575	0.01 x TCI
Capital recovery	770,745	15 yrs @ 7.0%
<b>Total Indirect Costs (TIC)</b>	<b>1,345,045</b>	
<b>TOTAL ANNUAL COST (TAC)</b>	<b>3,974,329</b>	TDC + TIC

Source: ECT, 2001.

Table 4-6. Summary of CO BACT Analysis (Revised August 2001)

Control Option	<u>Emission Impacts</u>		<u>Economic Impacts</u>			<u>Energy Impacts</u>	<u>Environmental Impacts</u>		
	<u>Emission Rates</u>		Emission Reduction	Installed Capital Cost	Total Annualized Cost	Cost Effectiveness Over Baseline	Increase Over Baseline	Toxic Impact	Adverse Envir. Impact
	(lb/hr)	(tpy)	(tpy)	(\$)	(\$/yr)	(\$/ton)	(MMBtu/yr)	(Y/N)	(Y/N)
Oxidation catalyst	31.6	138.3	1,244.4	14,357,497	3,974,329	3,194	122,969	N	Y
Baseline	315.7	1,382.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Basis: Eleven GE PG7241 (FA) CTs, 100-percent load, natural gas-firing for 8,760 hr/yr.

Sources: ECT, 2001.  
 GE, 2001.  
 TEC, 2001.





Jeb Bush  
Governor

# Department of Environmental Protection

Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

David B. Struhs  
Secretary

July 26, 2001

CERTIFIED MAIL - RETURN RECEIPT REQUESTED

Ms Karen Sheffield, General Manager  
Tampa Electric Company – Bayside Power Station  
Port Sutton Road  
Tampa, FL 33619

Re: Request for Additional Information  
Project No. 0570040-015-AC  
Bayside Units 3 and 4 Repowering Project

Dear Ms. Sheffield:


On June 26, 2001, the Department received the above referenced application. The modeling information in the application is incomplete. Rule 62-212.400(5)(d) requires a PSD Class I and Class II increment analysis for  $PM_{10}$ . This analysis was not provided. In order to continue processing your application, the Department will need this information

Any additional comments from EPA and the U.S. Fish and Wildlife Service will be forwarded to you after we receive them.

The Department will resume processing this application after receipt of the requested information. Rule 62-4.050(3), F.A.C. requires that all applications for a Department permit must be certified by a professional engineer registered in the State of Florida. This requirement also applies to responses to Department requests for additional information of an engineering nature. A new certification statement by the authorized representative or responsible official must accompany any material changes to the application. Rule 62-4.055(1), F.A.C. now requires applicants to respond to requests for information within 90 days.

We will be happy to meet and discuss the details with you and your staff. You may discuss the modeling requirements with Mr. Cleve Holladay at 850/921-8689.

Sincerely,

  
A.A. Linero, P.E. Administrator  
New Source Review Section

AAL/sa

cc: G. Worley, EPA  
J. Bunyak, NPS  
B. Thomas, DEP-SWD  
T. Davis, Ph.D., ECT

"More Protection, Less Process"

Printed on recycled paper.

SENDER: COMPLETE THIS SECTION	COMPLETE THIS SECTION ON DELIVERY
<ul style="list-style-type: none"> <li>Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.</li> <li>Print your name and address on the reverse so that we can return the card to you.</li> <li>Attach this card to the back of the mailpiece, or on the front if space permits.</li> </ul>	<p>A. Received by (Please Print Clearly) <i>A. Noel</i>      B. Date of Delivery <i>7-28-01</i></p> <p>C. Signature <i>X Alphaeus Noel</i>      <input type="checkbox"/> Agent  <input type="checkbox"/> Addressee</p> <p>D. Is delivery address different from item 1? <input type="checkbox"/> Yes  If YES, enter delivery address below: <input type="checkbox"/> No</p>
<p>1. Article Addressed to:</p> <p>Ms. Karen Sheffield, Gen. Mgr.  Tampa Electric Company  Bayside Power Station  Port Sutton Road  Tampa, FL 33619</p>	<p>3. Service Type</p> <input checked="" type="checkbox"/> Certified Mail <input type="checkbox"/> Express Mail <input type="checkbox"/> Registered <input type="checkbox"/> Return Receipt for Merchandise <input type="checkbox"/> Insured Mail <input type="checkbox"/> C.O.D. <p>4. Restricted Delivery? (Extra Fee)      <input type="checkbox"/> Yes</p>
<p>2. Article Number (Copy from service label)  7000 0600 0026 4129 9242</p>	

PS Form 3811, July 1999

Domestic Return Receipt


102595-99-M-1789

**U.S. Postal Service**  
**CERTIFIED MAIL RECEIPT**  
(Domestic Mail Only; No Insurance Coverage Provided)

---

**TAMPA FL 33619**

Postage	\$	<b>\$0.34</b>
Certified Fee		<b>\$2.10</b>
Return Receipt Fee (Endorsement Required)		<b>\$1.50</b>
Restricted Delivery Fee (Endorsement Required)		<b>\$0.00</b>
<b>Total Postage &amp; Fees</b>	<b>\$</b>	<b>\$3.94</b>



0682  
04 Postmark Here  
07/26/2001

Recipient's Name (Please Print Clearly) (to be completed by mailer)  
**Ms. Karen Sheffield**

Street, Apt. No., or PO Box No.  
**Port Sutton Rd.**

City, State, ZIP+4  
**Tampa, FL 33619**

PS Form 3800, February 2000      See Reverse for Instructions

7000 0600 0026 4129 9242



Jeb Bush  
Governor

# Department of Environmental Protection

Twin Towers Office Building  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

David B. Struhs  
Secretary

July 17, 2001

CERTIFIED MAIL - RETURN RECEIPT REQUESTED

Ms. Karen Sheffield, General Manager  
Tampa Electric Company – Bayside Power Station  
Port Sutton Road  
Tampa, FL 33619

Re: **Request for Additional Information**  
Project No. 0570040-015-AC  
Bayside Units 3 and 4 Re-powering Project

Dear Ms. Sheffield:

On June 26, 2001, the Department received your application and sufficient fee for an air construction permit to re-power the steam turbines for existing Gannon Units 3 and 4 with four combined cycle gas turbines to become part of the new Bayside Power Station. The application is incomplete. In order to continue processing your application, the Department will need the additional information requested below. Should your response to any of the below items require new calculations, please submit the new calculations, assumptions, reference material and appropriate revised pages of the application form.

1. Revised PSD Netting Analysis: In March of 2001, the Department issued a final permit for Bayside Units 1 and 2, which will re-power the steam turbines for existing Gannon Units 5 and 6. The application to re-power the steam turbines for existing Gannon Units 3 and 4 was submitted only three months later. The Department believes that this application is the second phase of the Gannon re-powering project. Please revise PSD netting analysis to include the following:
  - Specify the PSD contemporaneous period as defined in Rule 62-212.400(2)(e)3, F.A.C.
  - Include all emissions increases that have occurred or will occur during the contemporaneous period from all projects.
  - Include all of the emissions decreases that have occurred or will occur during the contemporaneous period from all projects.
  - Update the net emissions changes and PSD applicability accordingly.
2. Other Re-powering: Has TEC considered re-powering the existing steam turbines for Gannon Units 1 and 2? Has TEC contracted for any work involving the re-powering of these remaining steam turbines? Please submit a revised construction schedule for all units to be re-powered showing the planned startup date for each Bayside Unit and the shutdown date for each Gannon Unit.
3. Comparison of Bayside 1-2 with 3-4: Is TEC requesting any emissions standards, operational constraints, monitoring provisions, etc. that are different from those contained in the final permit issued for Bayside Units 1 and 2?

*"More Protection, Less Process"*

*Printed on recycled paper.*

4. Emissions Decreases: Page 1-2 of the application states, "Following installation and commercial operation of Bayside Unit 3, existing coal fired operation at F.J. Gannon Station Unit 3 will permanently cease. Following installation and commercial operation of Bayside Unit 4, existing coal fired operation at F.J. Gannon Station Unit 4 will permanently cease." The Department notes that, for an emissions decrease to be enforceable, each existing unit must be completely shutdown and rendered incapable of operation prior to startup of the corresponding new unit. Please comment.

5. Unit Description: Each new "Bayside Unit" will consist of two combined cycle units described as:

Each unit consists of a General Electric Model PG7241(FA) gas turbine-electrical generator set, an automated gas turbine control system, an inlet air filtration system, an evaporative inlet air cooling system, an unfired heat recovery steam generator (HRSG), a single exhaust stack that is 150 feet tall and 19.0 feet in diameter and associated support equipment. The project also includes electric fuel heaters and cooling towers. Natural gas is the exclusive fuel.

**Controls**: Emissions of CO, PM/PM<sub>10</sub>, SAM, SO<sub>2</sub>, and VOC are minimized by the efficient combustion of natural gas at high temperatures. NO<sub>x</sub> emissions are reduced by a Selective Catalytic Reduction (SCR) system combined with dry low-NO<sub>x</sub> (DLN) combustion technology when firing natural gas.

**Heat Input**: At a compressor inlet air temperature of 59° F and firing 1842 mmBTU (HHV) per hour of natural gas, each unit produces approximately 169 MW. Exhaust gases exit the stack with a volumetric flow rate of approximately 1,020,000 acfm at 215° F.

**Generating Capacity**: Bayside Units 3A and 3B will supply steam to a single steam electrical generator (formerly serving Gannon Unit 3) with a nameplate rating of 180 MW. Bayside Units 4A and 4B will supply steam to a single steam electrical generator (formerly serving Gannon Unit 4) with a nameplate rating of 188 MW of electrical power. Bayside Unit 3 is designed to produce a nominal 512 MW and Bayside Unit 4 is designed to produce a nominal 520 MW of electrical power.

Is this an accurate description?

6. HAP Emissions: The Bayside 1 and 2 re-powering project combined with the Bayside 3 and 4 re-powering project will result in total formaldehyde emissions greater than 10 tons per year and total hazardous air pollutant emissions (HAP) greater than 25 tons per year. Please submit a case-by-case MACT analysis for the Department's review. The Department will make a case-by-case MACT determination for these phased projects.

7. Catalytic Oxidation System: Please provide a new vendor's quote for this project based on 11 proposed systems firing natural gas. Revise the cost analysis if necessary.


8. Air Quality Analysis: The Department reserves the right to ask for additional information regarding the air quality analysis within the 30-day period after receiving the application with sufficient fee (on or before July 26, 2001).

9. Other Reviews: The Department will forward any comments or questions if received from EPA Region 4, the National Park Service, the Hillsborough County Environmental Protection Commission, or the Department's Southwest District Office.

The Department will resume processing your application after receipt of the requested information. Rule 62-4.050(3), F.A.C. requires that all applications for a Department permit must be certified by a professional engineer registered in the State of Florida. This requirement also applies to responses to Department requests for additional information of an engineering nature. For any material changes to the application, please include a new certification statement by the authorized representative or responsible official. You are reminded that Rule 62-4.055(1), F.A.C. now requires applicants to respond to requests for information within 90 days or provide a written request for an additional period of time to submit the information.

If you have any questions regarding this matter, please call me at 850/921-9536.

Sincerely,



Jeffery F. Koerner  
New Source Review Section

AAL/jfk

cc: Mr. Patrick Shell, TEC  
Mr. Shannon Todd, TEC  
Mr. Tom Davis, ECT  
Mr. Jerry Campbell, HCEPC  
Mr. Gerald Kissel, SWD  
Mr. Gregg Worley, EPA Region 4  
Mr. John Bunyak, NPS

SENDER: COMPLETE THIS SECTION	COMPLETE THIS SECTION ON DELIVERY		
<ul style="list-style-type: none"> <li>■ Complete items 1, 2, and 3. Also complete, item 4 if Restricted Delivery is desired.</li> <li>■ Print your name and address on the reverse so that we can return the card to you.</li> <li>■ Attach this card to the back of the mailpiece, or on the front if space permits.</li> </ul>	<table border="1"> <tr> <td>A. Received by (Please Print Clearly) <b>Joseph Hernandez</b></td> <td>B. Date of Delivery <b>7-19-07</b></td> </tr> </table>	A. Received by (Please Print Clearly) <b>Joseph Hernandez</b>	B. Date of Delivery <b>7-19-07</b>
A. Received by (Please Print Clearly) <b>Joseph Hernandez</b>	B. Date of Delivery <b>7-19-07</b>		
<p>1. Article Addressed to:</p> <p>Ms. Karen Sheffield, Gen. Mgr. Tampa Electric Company Bayside Power Station Port Sutton Road Tampa, FL 33619</p>	<p>C. Signature <b>X</b> <i>[Signature]</i> <input type="checkbox"/> Agent <input type="checkbox"/> Addressee</p> <p>D. Is delivery address different from item 1? <input type="checkbox"/> Yes <input type="checkbox"/> No If YES, enter delivery address below:</p>		
<p>2. Article Number (Copy from service label) 7000 0600 0026 4129 9150</p>	<p>3. Service Type  <input checked="" type="checkbox"/> Certified Mail <input type="checkbox"/> Express Mail  <input type="checkbox"/> Registered <input type="checkbox"/> Return Receipt for Merchandise  <input type="checkbox"/> Insured Mail <input type="checkbox"/> C.O.D.</p> <p>4. Restricted Delivery? (Extra Fee) <input type="checkbox"/> Yes</p>		

PS Form 3811, July 1999

Domestic Return Receipt

102595-99-M-1789

<b>U.S. Postal Service</b> <b>CERTIFIED MAIL RECEIPT</b> <i>(Domestic Mail Only; No Insurance Coverage Provided)</i>							
7000 0600 0026 4129 9150	<div style="border: 1px solid black; height: 35px;"></div>						
Postage \$	<div style="border: 1px solid black; height: 20px;"></div>						
Certified Fee	<div style="border: 1px solid black; height: 20px;"></div>						
Return Receipt Fee <small>(Endorsement Required)</small>	<div style="border: 1px solid black; height: 25px;"></div>						
Restricted Delivery Fee <small>(Endorsement Required)</small>	<div style="border: 1px solid black; height: 25px;"></div>						
<b>Total Postage &amp; Fees</b> \$	<div style="border: 1px solid black; height: 25px;"></div>						
<table border="1"> <tr> <td colspan="2"> <b>Recipient's Name</b> <small>(Please Print Clearly) (to be completed by mailer)</small>  <b>Ms. Karen Sheffield, Gen. Mgr.</b> </td> </tr> <tr> <td colspan="2"> <small>Street, Apt. No., or PO Box No.</small>  <b>Port sutton Rd.</b> </td> </tr> <tr> <td colspan="2"> <small>City, State, ZIP+4</small>  <b>Tampa, FL 33619</b> </td> </tr> </table>		<b>Recipient's Name</b> <small>(Please Print Clearly) (to be completed by mailer)</small> <b>Ms. Karen Sheffield, Gen. Mgr.</b>		<small>Street, Apt. No., or PO Box No.</small> <b>Port sutton Rd.</b>		<small>City, State, ZIP+4</small> <b>Tampa, FL 33619</b>	
<b>Recipient's Name</b> <small>(Please Print Clearly) (to be completed by mailer)</small> <b>Ms. Karen Sheffield, Gen. Mgr.</b>							
<small>Street, Apt. No., or PO Box No.</small> <b>Port sutton Rd.</b>							
<small>City, State, ZIP+4</small> <b>Tampa, FL 33619</b>							
PS Form 3800, February 2000	See Reverse for Instructions						