

RECEIVED

SEP 21 2000

BUREAU OF AIR REGULATION

**BAYSIDE POWER STATION
AIR CONSTRUCTION
PERMIT APPLICATION**

Prepared for:



TAMPA ELECTRIC

Prepared by:

ECT

Environmental Consulting & Technology, Inc.

*3701 Northwest 98th Street
Gainesville, Florida 32606*

ECT No. 991060-0100

September 2000



Department of Environmental Protection

Division of Air Resources Management

APPLICATION FOR AIR PERMIT - TITLE V SOURCE

See Instructions for Form No. 62-210.900(1)

I. APPLICATION INFORMATION

Identification of Facility

1. Facility Owner/Company Name: Tampa Electric Company	
2. Site Name: F.J. Gannon/Bayside Power Station	
3. Facility Identification Number: 0570040 [] Unknown	
4. Facility Location: Street Address or Other Locator: Port Sutton Road City: Tampa County: Hillsborough Zip Code: 33619	
5. Relocatable Facility? [] Yes [<input checked="" type="checkbox"/>] No	6. Existing Permitted Facility? [<input checked="" type="checkbox"/>] Yes [] No

Application Contact

1. Name and Title of Application Contact: Patrick Shell Administrator – Air Programs, Environmental Affairs	
2. Application Contact Mailing Address: Organization/Firm: Tampa Electric Company Street Address: 6499 U.S. Highway 41 North City: Apollo Beach State: FL Zip Code: 3572-9200	
3. Application Contact Telephone Numbers: Telephone: (813) 641 – 5210 Fax: (813) 641-5081	

Application Processing Information (DEP Use)

1. Date of Receipt of Application:	<i>9-21-00</i>
2. Permit Number:	<i>0570040-013-AC</i>
3. PSD Number, (if applicable):	<i>PSD-FL-301</i>
4. Siting Number (if applicable):	

Purpose of Application

Air Operation Permit Application

This Application for Air Permit is submitted to obtain: (Check one)

- Initial Title V air operation permit for an existing facility which is classified as a Title V source.
- Initial Title V air operation permit for a facility which, upon start up of one or more newly constructed or modified emissions units addressed in this application, would become classified as a Title V source.

Current construction permit number: _____

- Title V air operation permit revision to address one or more newly constructed or modified emissions units addressed in this application.

Current construction permit number: _____

Operation permit number to be revised: _____

- Title V air operation permit revision or administrative correction to address one or more proposed new or modified emissions units and to be processed concurrently with the air construction permit application. (Also check Air Construction Permit Application below.)

Operation permit number to be revised/corrected: _____

- Title V air operation permit revision for reasons other than construction or modification of an emissions unit. Give reason for the revision; e.g., to comply with a new applicable requirement or to request approval of an "Early Reductions" proposal.

Operation permit number to be revised: _____

Reason for revision: _____

Air Construction Permit Application

This Application for Air Permit is submitted to obtain: (Check one)

- Air construction permit to construct or modify one or more emissions units.
- Air construction permit to make federally enforceable an assumed restriction on the potential emissions of one or more existing, permitted emissions units.
- Air construction permit for one or more existing, but unpermitted, emissions units.

4. Professional Engineer Statement:

I, the undersigned, hereby certify, except as particularly noted herein, that:*

(1) To the best of my knowledge, there is reasonable assurance that the air pollutant emissions unit(s) and the air pollution control equipment described in this Application for Air Permit, when properly operated and maintained, will comply with all applicable standards for control of air pollutant emissions found in the Florida Statutes and rules of the Department of Environmental Protection; and

(2) To the best of my knowledge, any emission estimates reported or relied on in this application are true, accurate, and complete and are either based upon reasonable techniques available for calculating emissions or, for emission estimates of hazardous air pollutants not regulated for an emissions unit addressed in this application, based solely upon the materials, information and calculations submitted with this application.

If the purpose of this application is to obtain a Title V source air operation permit (check here [], if so), I further certify that each emissions unit described in this Application for Air Permit, when properly operated and maintained, will comply with the applicable requirements identified in this application to which the unit is subject, except those emissions units for which a compliance schedule is submitted with this application.

If the purpose of this application is to obtain an air construction permit for one or more proposed new or modified emissions units (check here [], if so), I further certify that the engineering features of each such emissions unit described in this application have been ~~designed or~~ examined by me or individuals under my direct supervision and found to be in conformity with sound engineering principles applicable to the control of emissions of the air pollutants characterized in this application.

If the purpose of this application is to obtain an initial air operation permit or operation permit revision for one or more newly constructed or modified emissions units (check here [], if so), I further certify that, with the exception of any changes detailed as part of this application, each such emissions unit has been constructed or modified in substantial accordance with the information given in the corresponding application for air construction permit and with all provisions contained in such permit.

Signature

Date

(Seal)

* Attach any exception to certification statement.

Scope of Application

Emissions Unit ID	Description of Emissions Unit	Permit Type	Processing Fee
019	Bayside Combustion Turbine Unit No. 1-A	AC1A	\$7,500
020	Bayside Combustion Turbine Unit No. 1-B	AC1A	N/A
021	Bayside Combustion Turbine Unit No. 1-C	AC1A	N/A
022	Bayside Combustion Turbine Unit No. 2-A	AC1A	N/A
023	Bayside Combustion Turbine Unit No. 2-B	AC1A	N/A
024	Bayside Combustion Turbine Unit No. 2-C	AC1A	N/A
025	Bayside Combustion Turbine Unit No. 2-D	AC1A	N/A

Application Processing Fee

Check one: [] Attached - Amount: \$ 7,500 [] Not Applicable

Note: PSD review fee per Rule 62-4.050(4)(a)1., F.A.C.

Construction/Modification Information

1. Description of Proposed Project or Alterations:

TEC is proposing to repower Units 5 and 6 at the F.J. Gannon Station by installing seven General Electric (GE) 7FA combustion turbine (CT)/heat recovery steam generator (HRSG) units that will operate in conjunction with the existing Units 5 and 6 steam turbines (STs). The seven new CT/HRSG units will be grouped into two units designated as Bayside Power Station (Bayside) Units 1 and 2. Bayside Units 1 and 2 will repower F.J. Gannon Station Units 5 and 6, respectively. Bayside Unit 1 will include three CT/HRSGs designated as CT-1A, CT-1B, and CT-1C. Bayside Unit 2 will include four CT/HRSGs designated as CT-2A, CT-2B, CT-2C, and CT-2D. The CTs will be fired using pipeline quality natural gas as the primary fuel source with low-sulfur, distillate fuel oil serving as a backup fuel. The new combined-cycle CT/HRSGs will operate at annual capacity factors up to 100 and 10 percent for natural gas and oil firing, respectively.

2. Projected or Actual Date of Commencement of Construction: **May 2001**

3. Projected Date of Completion of Construction: **March 2003 (Unit 1), March 2004 (Unit 2)**

Application Comment

Facility Regulatory Classifications

Check all that apply:

1. <input type="checkbox"/> Small Business Stationary Source?	<input type="checkbox"/> Unknown
2. <input checked="" type="checkbox"/> Major Source of Pollutants Other than Hazardous Air Pollutants (HAPs)?	
3. <input type="checkbox"/> Synthetic Minor Source of Pollutants Other than HAPs?	
4. <input checked="" type="checkbox"/> Major Source of Hazardous Air Pollutants (HAPs)?	
5. <input type="checkbox"/> Synthetic Minor Source of HAPs?	
6. <input checked="" type="checkbox"/> One or More Emissions Units Subject to NSPS?	
7. <input type="checkbox"/> One or More Emission Units Subject to NESHAP?	
8. <input type="checkbox"/> Title V Source by EPA Designation?	
9. Facility Regulatory Classifications Comment (limit to 200 characters):	

List of Applicable Regulations

Previously submitted – see Title V permit application.	

B. FACILITY POLLUTANTS

List of Pollutants Emitted

1. Pollutant Emitted	2. Pollutant Classif.	3. Requested Emissions Cap		4. Basis for Emissions Cap	5. Pollutant Comment
		lb/hour	tons/year		
NOX	A	N/A	N/A	N/A	
SO2	A	N/A	N/A	N/A	
CO	A	N/A	N/A	N/A	
PM10	A	N/A	N/A	N/A	
PM	A	N/A	N/A	N/A	
SAM	A	N/A	N/A	N/A	
VOC	A	N/A	N/A	N/A	
PB	B	N/A	N/A	N/A	
HAPS	A	N/A	N/A	N/A	
H106 (HCl)	A	N/A	N/A	N/A	
H107 (HF)	A	N/A	N/A	N/A	

C. FACILITY SUPPLEMENTAL INFORMATION

Supplemental Requirements

1. Area Map Showing Facility Location: <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable <input checked="" type="checkbox"/> Waiver Requested
2. Facility Plot Plan: <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable <input checked="" type="checkbox"/> Waiver Requested
3. Process Flow Diagram(s): <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable <input checked="" type="checkbox"/> Waiver Requested
4. Precautions to Prevent Emissions of Unconfined Particulate Matter: <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable <input checked="" type="checkbox"/> Waiver Requested
5. Fugitive Emissions Identification: <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable <input checked="" type="checkbox"/> Waiver Requested
6. Supplemental Information for Construction Permit Application: <input checked="" type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable Air Construction Permit Application
7. Supplemental Requirements Comment: Items 1, 2, 3, 4, and 5 above previously submitted - see F.J. Gannon Station Title V permit application.

Additional Supplemental Requirements for Title V Air Operation Permit Applications

8. List of Proposed Insignificant Activities: <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable
9. List of Equipment/Activities Regulated under Title VI: <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Equipment/Activities On site but Not Required to be Individually Listed <input type="checkbox"/> Not Applicable
10. Alternative Methods of Operation: <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable
11. Alternative Modes of Operation (Emissions Trading): <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable
12. Identification of Additional Applicable Requirements: <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable
13. Risk Management Plan Verification: <input type="checkbox"/> Plan previously submitted to Chemical Emergency Preparedness and Prevention Office (CEPPO). Verification of submittal attached (Document ID: _____) or previously submitted to DEP (Date and DEP Office: _____) <input type="checkbox"/> Plan to be submitted to CEPPO (Date required: _____) <input type="checkbox"/> Not Applicable
14. Compliance Report and Plan: <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable
15. Compliance Certification (Hard-copy Required): <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable

Items 8. through 15. above previously submitted – see F.J. Gannon Station Title V permit application.

III. EMISSIONS UNIT INFORMATION

A separate Emissions Unit Information Section (including subsections A through J as required) must be completed for each emissions unit addressed in this Application for Air Permit. If submitting the application form in hard copy, indicate, in the space provided at the top of each page, the number of this Emissions Unit Information Section and the total number of Emissions Unit Information Sections submitted as part of this application.

**A. GENERAL EMISSIONS UNIT INFORMATION
(All Emissions Units)**

Emissions Unit Description and Status

<p>1. Type of Emissions Unit Addressed in This Section: (Check one)</p> <p><input checked="" type="checkbox"/> This Emissions Unit Information Section addresses, as a single emissions unit, a single process or production unit, or activity, which produces one or more air pollutants and which has at least one definable emission point (stack or vent).</p> <p><input type="checkbox"/> This Emissions Unit Information Section addresses, as a single emissions unit, a group of process or production units and activities which has at least one definable emission point (stack or vent) but may also produce fugitive emissions.</p> <p><input type="checkbox"/> This Emissions Unit Information Section addresses, as a single emissions unit, one or more process or production units and activities which produce fugitive emissions only.</p>			
<p>2. Regulated or Unregulated Emissions Unit? (Check one)</p> <p><input checked="" type="checkbox"/> The emissions unit addressed in this Emissions Unit Information Section is a regulated emissions unit.</p> <p><input type="checkbox"/> The emissions unit addressed in this Emissions Unit Information Section is an unregulated emissions unit.</p>			
<p>3. Description of Emissions Unit Addressed in This Section (limit to 60 characters): Emission unit consists of one General Electric (GE) 7241 FA combined-cycle combustion turbine generator (CT) having a nominal rating of 166 megawatts (MW). The CT will be fired primarily using pipeline quality natural gas with low-sulfur distillate fuel oil serving as a back-up fuel.</p>			
<p>4. Emissions Unit Identification Number: <input checked="" type="checkbox"/> No ID ID: 019 (CT 1-A) <input type="checkbox"/> ID Unknown</p>			
<p>5. Emissions Unit Status Code: C</p>	<p>6. Initial Startup Date:</p>	<p>7. Emissions Unit Major Group SIC Code: 49</p>	<p>8. Acid Rain Unit? <input checked="" type="checkbox"/></p>
<p>9. Emissions Unit Comment: (Limit to 500 Characters)</p> 			

Emissions Unit Control Equipment

1. Control Equipment/Method Description (Limit to 200 characters per device or method):

NO_x Controls

Dry low-NO_x combustors (natural gas-firing)

Water injection (distillate fuel-oil firing)

Selective Catalytic Reduction (SCR)

2. Control Device or Method Code(s): **025 (dry low-NO_x), 028 (water injection),
065 (catalytic reduction)**

Emissions Unit Details

1. Package Unit:
Manufacturer: **General Electric** Model Number: **PG7241(FA)**

2. Generator Nameplate Rating: **166 MW**

3. Incinerator Information:
Dwell Temperature: °F
Dwell Time: seconds
Incinerator Afterburner Temperature: °F

**B. EMISSIONS UNIT CAPACITY INFORMATION
(Regulated Emissions Units Only)**

Emissions Unit Operating Capacity and Schedule

1. Maximum Heat Input Rate:	1,940 (LHV)	mmBtu/hr
2. Maximum Incineration Rate:	lb/hr	tons/day
3. Maximum Process or Throughput Rate:		
4. Maximum Production Rate:		
5. Requested Maximum Operating Schedule:		
	24	7
	hours/day	days/week
	52	8,760
	weeks/year	hours/year
6. Operating Capacity/Schedule Comment (limit to 200 characters):		
<p>Maximum heat input is lower heating value (LHV) at 100 percent load, 18°F, fuel oil-firing operating conditions. Heat input will vary with load, fuel type, and ambient temperature.</p>		

**D. EMISSION POINT (STACK/VENT) INFORMATION
(Regulated Emissions Units Only)**

Emission Point Description and Type

1. Identification of Point on Plot Plan or Flow Diagram? CT 1-A		2. Emission Point Type Code: 1	
3. Descriptions of Emission Points Comprising this Emissions Unit for VE Tracking (limit to 100 characters per point): N/A			
4. ID Numbers or Descriptions of Emission Units with this Emission Point in Common: N/A			
5. Discharge Type Code: V	6. Stack Height: 150 feet	7. Exit Diameter: 19.0 feet	
8. Exit Temperature: 212 °F	9. Actual Volumetric Flow Rate: 1,018,786 acfm	10. Water Vapor: %	
11. Maximum Dry Standard Flow Rate: dscfm		12. Nonstack Emission Point Height: feet	
13. Emission Point UTM Coordinates: Zone: East (km): North (km):			
14. Emission Point Comment (limit to 200 characters): Stack temperature and flow rate are at 100 percent load, 59°F, and natural gas-firing operating conditions. Stack temperature and flow rate will vary with load, fuel type, and ambient temperature.			

E. SEGMENT (PROCESS/FUEL) INFORMATION
(All Emissions Units)

Segment Description and Rate: Segment 1 of 2

1. Segment Description (Process/Fuel Type) (limit to 500 characters): Combustion turbine fired with pipeline quality natural gas.		
2. Source Classification Code (SCC): 20100201		3. SCC Units: Million Cubic Feet Burned
4. Maximum Hourly Rate: 1.869	5. Maximum Annual Rate: 16,372.4	6. Estimated Annual Activity Factor:
7. Maximum % Sulfur:	8. Maximum % Ash:	9. Million Btu per SCC Unit: 919
10. Segment Comment (limit to 200 characters): Fuel heat content (Field 9) represents lower heating value (LHV).		

Segment Description and Rate: Segment 2 of 2

1. Segment Description (Process/Fuel Type) (limit to 500 characters): Combustion turbine fired with distillate fuel oil.		
2. Source Classification Code (SCC): 20100101		3. SCC Units: Thousand Gallons Burned
4. Maximum Hourly Rate: 14.522	5. Maximum Annual Rate: 12,720.9	6. Estimated Annual Activity Factor:
7. Maximum % Sulfur: 0.05	8. Maximum % Ash: 0.01	9. Million Btu per SCC Unit: 134
10. Segment Comment (limit to 200 characters): Fuel heat content (Field 9) represents lower heating value (LHV).		

Emissions Unit Information Section 1 of 7

**F. EMISSIONS UNIT POLLUTANTS
(All Emissions Units)**

1. Pollutant Emitted	2. Primary Control Device Code	3. Secondary Control Device Code	4. Pollutant Regulatory Code
1 - NOX	025, 028	065	EL
2 - CO			EL
3 - PM			EL
4 - PM10			EL
5 - SO2			EL
6 - SAM			EL
7 - VOC			EL

G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units -
Emissions-Limited and Preconstruction Review Pollutants Only)

Potential/Fugitive Emissions

1. Pollutant Emitted: NOX	2. Total Percent Efficiency of Control:
3. Potential Emissions: 132.3 lb/hour	4. Synthetically Limited? [<input checked="" type="checkbox"/>] 145.5 tons/year
5. Range of Estimated Fugitive Emissions: [] 1 [] 2 [] 3 _____ to _____ tons/year	
6. Emission Factor: 132.3 lb/hr Reference: Sargent & Lundy	7. Emissions Method Code: 2
8. Calculation of Emissions (limit to 600 characters): Hourly emission rate based on S&L data for 100 percent load, 18°F, fuel oil-firing case. Annual emissions based on 23.1 lb/hr (100 percent load, 59°F, natural gas-firing case) for 7,884 hrs/yr and 124.2 lb/hr (100 percent load, 59°F, distillate fuel oil-firing case) for 876 hrs/yr.	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):	

Allowable Emissions Allowable Emissions 1 of 2

1. Basis for Allowable Emissions Code: Other	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: 3.5 ppmvd @ 15% O₂	4. Equivalent Allowable Emissions: 24.7 lb/hour N/A tons/year
5. Method of Compliance (limit to 60 characters): EPA Reference Method 20 (initial), NO_x CEMS	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): FDEP/EPA Consent Agreement. Unit is also subject to less stringent NO_x limits of 40 CFR Part 60, Subpart GG (NSPS). Limit applicable for natural gas-firing.	

Emissions Unit Information Section 1 of 7

Pollutant Detail Information Page 2 of 14

Allowable Emissions Allowable Emissions 2 of 2

1. Basis for Allowable Emissions Code: Other	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: 16.4 ppmvd @ 15% O₂	4. Equivalent Allowable Emissions: 132.3 lb/hour N/A tons/year
5. Method of Compliance (limit to 60 characters): EPA Reference Method 20 (initial), NO_x CEMS	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): FDEP/EPA Consent Agreement. Unit is also subject to less stringent NO_x limits of 40 CFR Part 60, Subpart GG (NSPS). Limit applicable for distillate fuel oil-firing.	

G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units -
Emissions-Limited and Preconstruction Review Pollutants Only)

Potential/Fugitive Emissions

1. Pollutant Emitted: CO	2. Total Percent Efficiency of Control:
3. Potential Emissions: 81.3 lb/hour	4. Synthetically Limited? [<input checked="" type="checkbox"/>] 141.4 tons/year
5. Range of Estimated Fugitive Emissions: [] 1 [] 2 [] 3 _____ to _____ tons/year	
6. Emission Factor: 81.3 lb/hr Reference: Sargent & Lundy	7. Emissions Method Code: 2
8. Calculation of Emissions (limit to 600 characters): Hourly emission rate based on S&L data for 50 percent load, 93°F, fuel oil-firing case. Annual emissions based on 28.70 lb/hr (100 percent load, 59°F, natural gas-firing case) for 7,884 hrs/yr and 64.5 lb/hr (100 percent load, 59°F, distillate fuel oil-firing case) for 876 hrs/yr.	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):	

Allowable Emissions Allowable Emissions 1 of 2

1. Basis for Allowable Emissions Code: Other	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: 7.8 ppmvd @ 15% O₂	4. Equivalent Allowable Emissions: 31.1 lb/hour N/A tons/year
5. Method of Compliance (limit to 60 characters): EPA Reference Method 10	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): Limit applicable for natural gas-firing.	

Emissions Unit Information Section 1 of 7

Pollutant Detail Information Page 4 of 14

Allowable Emissions Allowable Emissions 2 of 2

1. Basis for Allowable Emissions Code: Other	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: 30.3 ppmvd @ 15% O₂	4. Equivalent Allowable Emissions: 81.3 lb/hour N/A tons/year
5. Method of Compliance (limit to 60 characters): EPA Reference Method 10	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): Limit applicable for distillate fuel oil-firing.	

G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units -
Emissions-Limited and Preconstruction Review Pollutants Only)

Potential/Fugitive Emissions

1. Pollutant Emitted: PM	2. Total Percent Efficiency of Control:
3. Potential Emissions: 53.8 lb/hour	4. Synthetically Limited? [<input checked="" type="checkbox"/>] 103.1 tons/year
5. Range of Estimated Fugitive Emissions: [] 1 [] 2 [] 3 _____ to _____ tons/year	
6. Emission Factor: 53.8 lb/hr Reference: Sargent & Lundy	7. Emissions Method Code: 2
8. Calculation of Emissions (limit to 600 characters): Hourly emission rate based on S&L data for 100 percent load, 18°F, fuel oil-firing case. Annual emissions based on 20.3 lb/hr (100 percent load, 59°F, natural gas-firing case) for 7,884 hrs/yr and 52.6 lb/hr (100 percent load, 59°F, distillate fuel oil-firing case) for 876 hrs/yr.	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters): PM emissions data represents "front- and back-half" particulate matter as measured by EPA Reference Methods 201 and 202. PM and PM₁₀ emissions are assumed to be equal.	

Allowable Emissions Allowable Emissions 1 of 2

1. Basis for Allowable Emissions Code: Other	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: 10% opacity	4. Equivalent Allowable Emissions: 20.5 lb/hour N/A tons/year
5. Method of Compliance (limit to 60 characters): EPA Reference Method 9	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): Limit applicable for natural gas-firing.	

Emissions Unit Information Section 1 of 7

Pollutant Detail Information Page 6 of 14

Allowable Emissions Allowable Emissions 2 of 2

1. Basis for Allowable Emissions Code: Other	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: 10 % opacity	4. Equivalent Allowable Emissions: 53.8 lb/hour N/A tons/year
5. Method of Compliance (limit to 60 characters): EPA Reference Method 9	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): Limit applicable for distillate fuel oil-firing.	

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units -
Emissions-Limited and Preconstruction Review Pollutants Only)**

Potential/Fugitive Emissions

1. Pollutant Emitted: PM10		2. Total Percent Efficiency of Control:	
3. Potential Emissions: 53.8 lb/hour		4. Synthetically Limited? [<input checked="" type="checkbox"/>] 103.1 tons/year	
5. Range of Estimated Fugitive Emissions: [] 1 [] 2 [] 3 _____ to _____ tons/year			
6. Emission Factor: 53.8 lb/hr Reference: Sargent & Lundy		7. Emissions Method Code: 2	
8. Calculation of Emissions (limit to 600 characters): Hourly emission rate based on S&L data for 100 percent load, 18°F, fuel oil-firing case. Annual emissions based on 20.3 lb/hr (100 percent load, 59°F, natural gas-firing case) for 7,884 hrs/yr and 52.6 lb/hr (100 percent load, 59°F, distillate fuel oil-firing case) for 876 hrs/yr.			
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters): PM emissions data represents “front- and back-half” particulate matter as measured by EPA Reference Methods 201 and 202. PM and PM₁₀ emissions are assumed to be equal.			

Allowable Emissions Allowable Emissions 1 of 2

1. Basis for Allowable Emissions Code: Other		2. Future Effective Date of Allowable Emissions:	
3. Requested Allowable Emissions and Units: 10% opacity		4. Equivalent Allowable Emissions: 20.5 lb/hour N/A tons/year	
5. Method of Compliance (limit to 60 characters): EPA Reference Method 9			
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): Limit applicable for natural gas-firing.			

Emissions Unit Information Section 1 of 7

Pollutant Detail Information Page 8 of 14

Allowable Emissions Allowable Emissions 2 of 2

1. Basis for Allowable Emissions Code: Other	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: 10 % opacity	4. Equivalent Allowable Emissions: 53.8 lb/hour N/A tons/year
5. Method of Compliance (limit to 60 characters): EPA Reference Method 9	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): Limit applicable for distillate fuel oil-firing.	

G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units -
Emissions-Limited and Preconstruction Review Pollutants Only)

Potential/Fugitive Emissions

1. Pollutant Emitted: SO₂	2. Total Percent Efficiency of Control:
3. Potential Emissions: 104.6 lb/hour	4. Synthetically Limited? [<input checked="" type="checkbox"/>] 82.3 tons/year
5. Range of Estimated Fugitive Emissions: [] 1 [] 2 [] 3 _____ to _____ tons/year	
6. Emission Factor: 104.6 lb/hr Reference: Sargent & Lundy	7. Emissions Method Code: 2
8. Calculation of Emissions (limit to 600 characters): $(0.05 \text{ lb S}/100 \text{ lb oil}) \times (104,555 \text{ lb oil/hr}) \times (2 \text{ lb SO}_2/\text{lb S}) = 104.6 \text{ lb/hr SO}_2$ <p>Annual emissions based on 10.0 lb/hr (100 percent load, 59°F, natural gas-firing case) for 7,884 hrs/yr and 98.2 lb/hr (100 percent load, 59°F, distillate fuel oil-firing case) for 876 hrs/yr.</p>	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):	

Allowable Emissions Allowable Emissions 1 of 2

1. Basis for Allowable Emissions Code: Other	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: 2.0 gr S/100 scf	4. Equivalent Allowable Emissions: 10.7 lb/hour N/A tons/year
5. Method of Compliance (limit to 60 characters): Fuel analysis for sulfur content	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): Limit applicable for natural gas-firing.	

Emissions Unit Information Section 1 of 7

Pollutant Detail Information Page 10 of 14

Allowable Emissions Allowable Emissions 2 of 2

1. Basis for Allowable Emissions Code: Other	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: 0.05 weight % S	4. Equivalent Allowable Emissions: 104.6 lb/hour N/A tons/year
5. Method of Compliance (limit to 60 characters): Fuel analysis for sulfur content	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): Limit applicable for distillate fuel oil-firing.	

G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units -
Emissions-Limited and Preconstruction Review Pollutants Only)

Potential/Fugitive Emissions

1. Pollutant Emitted: SAM	2. Total Percent Efficiency of Control:
3. Potential Emissions: 16.0 lb/hour 13.8 tons/year	4. Synthetically Limited? [<input checked="" type="checkbox"/>]
5. Range of Estimated Fugitive Emissions: [] 1 [] 2 [] 3 _____ to _____ tons/year	
6. Emission Factor: 16.0 lb/hr Reference: Sargent & Lundy	7. Emissions Method Code: 2
8. Calculation of Emissions (limit to 600 characters): Annual emissions based on 1.8 lb/hr (100 percent load, 59°F, natural gas-firing case) for 7,884 hrs/yr and 15.0 lb/hr (100 percent load, 59°F, distillate fuel oil-firing case) for 876 hrs/yr.	
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):	

Allowable Emissions Allowable Emissions 1 of 2

1. Basis for Allowable Emissions Code: Other	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: 2.0 gr S/100 scf	4. Equivalent Allowable Emissions: 2.0 lb/hour N/A tons/year
5. Method of Compliance (limit to 60 characters): Fuel analysis for sulfur content	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): Limit applicable for natural gas-firing.	

Emissions Unit Information Section 1 of 7

Pollutant Detail Information Page 12 of 14

Allowable Emissions Allowable Emissions 2 of 2

1. Basis for Allowable Emissions Code: Other	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: 0.05 weight % S	4. Equivalent Allowable Emissions: 16.0 lb/hour N/A tons/year
5. Method of Compliance (limit to 60 characters): Fuel analysis for sulfur content	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): Limit applicable for distillate fuel oil-firing.	

**G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION
(Regulated Emissions Units -
Emissions-Limited and Preconstruction Review Pollutants Only)**

Potential/Fugitive Emissions

1. Pollutant Emitted: VOC		2. Total Percent Efficiency of Control:	
3. Potential Emissions: 7.8 lb/hour		4. Synthetically Limited? [<input checked="" type="checkbox"/>]	
		14.2 tons/year	
5. Range of Estimated Fugitive Emissions: [] 1 [] 2 [] 3 _____ to _____ tons/year			
6. Emission Factor: 7.8 lb/hr Reference: Sargent & Lundy		7. Emissions Method Code: 2	
8. Calculation of Emissions (limit to 600 characters): Hourly emission rate based on S&L data for 100 percent load, 18°F, fuel oil-firing case. Annual emissions based on 2.8 lb/hr (100 percent load, 59°F, natural gas-firing case) for 7,884 hrs/yr and 7.3 lb/hr (100 percent load, 59°F, distillate fuel oil-firing case) for 876 hrs/yr.			
9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters):			

Allowable Emissions Allowable Emissions 1 of 2

1. Basis for Allowable Emissions Code: Other		2. Future Effective Date of Allowable Emissions:	
3. Requested Allowable Emissions and Units: 1.3 ppmvd @ 15% O₂		4. Equivalent Allowable Emissions: 3.0 lb/hour N/A tons/year	
5. Method of Compliance (limit to 60 characters): EPA Reference Method 18, 25, or 25A.			
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): Limit applicable for natural gas-firing.			

Emissions Unit Information Section 1 of 7

Pollutant Detail Information Page 14 of 14

Allowable Emissions Allowable Emissions 2 of 2

1. Basis for Allowable Emissions Code: Other	2. Future Effective Date of Allowable Emissions:
3. Requested Allowable Emissions and Units: 3.0 ppmvd @ 15% O₂	4. Equivalent Allowable Emissions: 7.8 lb/hour N/A tons/year
5. Method of Compliance (limit to 60 characters): EPA Reference Method 18, 25, or 25A.	
6. Allowable Emissions Comment (Desc. of Operating Method) (limit to 200 characters): Limit applicable for distillate fuel oil-firing.	

H. VISIBLE EMISSIONS INFORMATION
(Only Regulated Emissions Units Subject to a VE Limitation)

Visible Emissions Limitation: Visible Emissions Limitation 1 of 2

1. Visible Emissions Subtype: VE10	2. Basis for Allowable Opacity: <input type="checkbox"/> Rule <input checked="" type="checkbox"/> Other
3. Requested Allowable Opacity: Normal Conditions: 10 % Exceptional Conditions: % Maximum Period of Excess Opacity Allowed: min/hour	
4. Method of Compliance: EPA Reference Method 9	
5. Visible Emissions Comment (limit to 200 characters):	

Visible Emissions Limitation: Visible Emissions Limitation 2 of 2

1. Visible Emissions Subtype:	2. Basis for Allowable Opacity: <input checked="" type="checkbox"/> Rule <input type="checkbox"/> Other
3. Requested Allowable Opacity: Normal Conditions: % Exceptional Conditions: 100 % Maximum Period of Excess Opacity Allowed: 60 min/hour	
4. Method of Compliance: EPA Reference Method 9	
5. Visible Emissions Comment (limit to 200 characters): Excess emissions resulting from startup, shutdown, or malfunction not-to-exceed 2 hours in any 24 hour period unless authorized by FDEP for a longer duration. Rule 62-210.700(1), F.A.C.	

**J. EMISSIONS UNIT SUPPLEMENTAL INFORMATION
(Regulated Emissions Units Only)**

Supplemental Requirements

1. Process Flow Diagram <input checked="" type="checkbox"/> Attached, Document ID: <u>Fig. 2-4</u> <input type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
2. Fuel Analysis or Specification <input checked="" type="checkbox"/> Attached, Document ID: <u>Att. A-2</u> <input type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
3. Detailed Description of Control Equipment <input checked="" type="checkbox"/> Attached, Document ID: <u>Att. B</u> <input type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
4. Description of Stack Sampling Facilities To be provided <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
5. Compliance Test Report <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Previously submitted, Date: _____ <input checked="" type="checkbox"/> Not Applicable
6. Procedures for Startup and Shutdown <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
7. Operation and Maintenance Plan <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable <input type="checkbox"/> Waiver Requested
8. Supplemental Information for Construction Permit Application See permit application <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable
9. Other Information Required by Rule or Statute <input type="checkbox"/> Attached, Document ID: _____ <input checked="" type="checkbox"/> Not Applicable
10. Supplemental Requirements Comment:

Emissions Unit Information Section 1 of 7

Additional Supplemental Requirements for Title V Air Operation Permit Applications

11. Alternative Methods of Operation <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable
12. Alternative Modes of Operation (Emissions Trading) <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable
13. Identification of Additional Applicable Requirements <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable
14. Compliance Assurance Monitoring Plan <input type="checkbox"/> Attached, Document ID: _____ <input type="checkbox"/> Not Applicable
15. Acid Rain Part Application (Hard-copy Required) <input type="checkbox"/> Acid Rain Part - Phase II (Form No. 62-210.900(1)(a)) Attached, Document ID: _____ <input type="checkbox"/> Repowering Extension Plan (Form No. 62-210.900(1)(a)1.) Attached, Document ID: _____ <input type="checkbox"/> New Unit Exemption (Form No. 62-210.900(1)(a)2.) Attached, Document ID: _____ <input type="checkbox"/> Retired Unit Exemption (Form No. 62-210.900(1)(a)3.) Attached, Document ID: _____ <input type="checkbox"/> Phase II NOx Compliance Plan (Form No. 62-210.900(1)(a)4.) Attached, Document ID: _____ <input type="checkbox"/> Phase NOx Averaging Plan (Form No. 62-210.900(1)(a)5.) Attached, Document ID: _____ <input type="checkbox"/> Not Applicable

Above items previously submitted, see F.J. Gannon Station Title V permit application.

NOTE:

EMISSION UNITS CT-1A, CT-1B, CT-1C, CT-2A, CT-2B, CT-2C, AND CT-2D ARE IDENTICAL UNITS.

SECTION III. EMISSIONS UNIT INFORMATION PROVIDED FOR EU 019 (CT-1A) IS ALSO APPLICABLE TO EU 020 (CT-1B), EU 021 (CT-1-C), EU 022 (CT-2A), EU 023 (CT-2B), EU 024 (CT-2C), AND EU 025 (CT-2D).

EMISSIONS UNIT INFORMATION SECTIONS 2 THROUGH 7 ARE IDENTICAL TO SECTION 1, WITH THE EXCEPTION OF IDENTIFICATION NUMBERS.

TABLE OF CONTENTS

<u>Section</u>	<u>Page</u>
1.0 INTRODUCTION AND SUMMARY	1-1
1.1 <u>INTRODUCTION</u>	1-1
1.2 <u>SUMMARY</u>	1-3
2.0 DESCRIPTION OF THE PROPOSED FACILITY	2-1
2.1 <u>PROJECT DESCRIPTION, AREA MAP, AND PLOT PLAN</u>	2-1
2.2 <u>PROCESS DESCRIPTION AND PROCESS FLOW DIAGRAMS</u>	2-3
2.3 <u>EMISSION AND STACK PARAMETERS</u>	2-9
3.0 AIR QUALITY STANDARDS AND NEW SOURCE REVIEW APPLICABILITY	3-1
3.1 <u>NATIONAL AND STATE AAQS</u>	3-1
3.2 <u>NONATTAINMENT NSR APPLICABILITY</u>	3-3
3.3 <u>PSD NSR APPLICABILITY</u>	3-3
4.0 BEST AVAILABLE CONTROL TECHNOLOGY	4-1
4.1 <u>METHODOLOGY</u>	4-1
4.2 <u>FEDERAL AND FLORIDA EMISSION STANDARDS</u>	4-3
4.3 <u>BACT ANALYSIS FOR VOC</u>	4-4
4.3.1 POTENTIAL CONTROL TECHNOLOGIES	4-5
4.3.2 ENERGY AND ENVIRONMENTAL IMPACTS	4-6
4.3.3 ECONOMIC IMPACTS	4-7
4.3.4 PROPOSED BACT EMISSION LIMITATIONS	4-11
5.0 AMBIENT IMPACT ANALYSIS METHODOLOGY	5-1
5.1 <u>GENERAL APPROACH</u>	5-1
5.2 <u>POLLUTANTS EVALUATED</u>	5-1
5.3 <u>MODEL SELECTION AND USE</u>	5-1
5.4 <u>NO₂ AMBIENT IMPACT ANALYSIS</u>	5-2
5.5 <u>DISPERSION OPTION SELECTION</u>	5-2
5.6 <u>TERRAIN CONSIDERATION</u>	5-3
5.7 <u>GOOD ENGINEERING PRACTICE STACK HEIGHT/ BUILDING WAKE EFFECTS</u>	5-4
5.8 <u>RECEPTOR GRIDS</u>	5-7
5.9 <u>METEOROLOGICAL DATA</u>	5-7
5.10 <u>MODELED EMISSION INVENTORY</u>	5-10

TABLE OF CONTENTS
(Continued, Page 2 of 2)

<u>Section</u>	<u>Page</u>
6.0 AMBIENT IMPACT ANALYSIS RESULTS	6-1
ATTACHMENTS	
ATTACHMENT A—APPLICATION FOR AIR PERMIT—TITLE V SOURCE	
A-1—REGULATORY APPLICABILITY ANALYSES	
A-2—FUEL ANALYSES OR SPECIFICATIONS	
ATTACHMENT B—NITROGEN OXIDES CONTROL SYSTEM	
DESCRIPTIONS	
ATTACHMENT C—EMISSION RATE CALCULATIONS	
ATTACHMENT D—PSD NETTING ANALYSIS	
ATTACHMENT E—DISPERSION MODELING FILES	

LIST OF TABLES

<u>Table</u>		<u>Page</u>
2-1	Maximum Criteria Pollutant Emission Rates—Natural Gas	2-10
2-2	Maximum Criteria Pollutant Emission Rates—Distillate Fuel Oil	2-11
2-3	Maximum H ₂ SO ₄ Pollutant Emission Rates for Three Loads and Four Ambient Temperatures (Per CT/HRSG)	2-12
2-4	Maximum Noncriteria Pollutant Emission Rates—Natural Gas	2-13
2-5	Maximum Noncriteria Pollutant Emission Rates—Distillate Fuel Oil	2-14
2-6	Maximum Annual Emission Rates	2-16
2-7	Net Annual Change in Emission Rates	2-17
2-8	Stack Parameters—Natural Gas	2-18
2-9	Stack Parameters—Distillate Fuel Oil	2-19
3-1	National and Florida Air Quality Standards	3-2
3-2	Repowering Projected Emissions Compared to PSD Significant Emission Rates	3-4
4-1	Capital and Annual Operating Cost Factors	4-2
4-2	Economic Cost Factors	4-8
4-3	Capital Costs for Oxidation Catalyst System, Seven CTs	4-9
4-4	Annual Operating Costs for Oxidation Catalyst System, Seven CTs	4-10
4-5	Summary of VOC BACT Analysis	4-12
4-6	RBLC VOC Summary for Natural Gas-Fired CTs	4-13
4-7	RBLC VOC Summary for Distillate Fuel Oil-Fired CTs	4-14
4-8	Florida BACT VOC Summary—Natural Gas-Fired CTs	4-15
4-9	Florida BACT VOC Summary—Distillate Fuel Oil-Fired CTs	4-16
4-10	Proposed VOC BACT Emission Limits	4-17
5-1	Building/Structure Dimensions	5-6
6-1	Air Quality Impact Analysis Summary	6-2

LIST OF FIGURES

<u>Figure</u>		<u>Page</u>
2-1	F.J. Gannon Station Location and Surroundings	2-2
2-2	Bayside Units 1 and 2 Plot Plan	2-4
2-3	Bayside Unit 2 - Profile	2-5
2-4	Bayside Unit 1 Process Flow Diagram	2-6
2-5	Bayside Unit 2 Process Flow Diagram	2-7
5-1	Receptor Locations (within 1,500 meters)	5-8
5-2	Receptor Locations (from 1,500 meters to 12 km)	5-9

1.0 INTRODUCTION AND SUMMARY

1.1 INTRODUCTION

Tampa Electric Company (TEC) is planning to repower its existing F.J. Gannon Station located on Port Sutton Road in Tampa, Hillsborough County, Florida.

The TEC F.J. Gannon Station consists of six steam boilers (Units 1 through 6), six steam turbines, one simple-cycle combustion turbine (CT-1), a once-through cooling water system, storage and handling of solid fuels, fluxing material, fly ash, and slag, fuel oil storage tanks and ancillary support equipment. Units 1 and 2 each have a nominal generation capacity of 125 megawatts (MW). Units 3, 4, 5, and 6 each have a nominal generation capacity of 180, 188, 239, and 414 MW, respectively. CT-1 has a nominal generation capacity of 14 MW. Units 1 through 6 are all fired with solid fuels; CT-1 is fired with No. 2 distillate fuel oil.

TEC is proposing to repower Units 5 and 6 at the F.J. Gannon Station by installing seven General Electric (GE) 7FA combustion turbine (CT)/heat recovery steam generator (HRSG) units that will operate in conjunction with the existing Units 5 and 6 steam turbines (STs). The seven new CT/HRSG units will be grouped into two units designated as Bayside Power Station (Bayside) Units 1 and 2. Bayside Units 1 and 2 will repower F.J. Gannon Station Units 5 and 6, respectively. Bayside Unit 1 will include three CT/HRSGs designated as CT-1A, CT-1B, and CT-1C. Bayside Unit 2 will include four CT/HRSGs designated as CT-2A, CT-2B, CT-2C, and CT-2D.

The HRSGs included with each CT will be unfired; i.e., the HRSGs will not include provisions for supplemental duct burner firing. The CT/HRSG units will not include HRSG by-pass stacks. The CTs will be equipped with evaporative coolers and will be fired primarily with pipeline-quality natural gas. Low-sulfur No. 2 fuel oil will serve as a supplemental, back-up fuel source. Ancillary equipment associated with Bayside Units 1 and 2 include a 5.85 million gallon No. 2 fuel oil storage tank, cooling towers, and two anhydrous ammonia storage tanks.

Bayside Units 1 and 2 will operate at annual capacity factors up to 100 and 10.0 percent for natural gas and oil firing, respectively. At base load operation, these annual capacity factors are equivalent to 8,760 and 876 hours per year (hr/yr) operation for natural gas and oil firing, respectively.

Following installation and commercial operation of Bayside Unit 1, existing F.J. Gannon Station Unit 5 will permanently cease coal-fired operation. Following installation and commercial operation of Bayside Unit 2, existing F.J. Gannon Station Unit 6 will permanently cease coal-fired operation. All Bayside Units 1 and 2 CT/HRSG units will be equipped with selective catalytic reduction (SCR) technology to control emissions of nitrogen oxides (NO_x). As an alternative to SCR, one CTG/HRSG unit may be equipped with SCONO_xTM control technology. With the exception of volatile organic compounds (VOCs), there will be a substantial net reduction in emissions of all pollutants subject to review under the Prevention of Significant Deterioration (PSD) New Source Review (NSR) permitting program due to the repowering of F.J. Gannon Station Units 5 and 6 with Bayside Units 1 and 2. The net increase in VOC emissions due to the repowering of F.J. Gannon Station Units 5 and 6 with Bayside Units 1 and 2 will exceed the PSD significant emission rate for this pollutant. Accordingly, Bayside Units 1 and 2 are subject to the PSD NSR requirements of Section 62-212.400, Florida Administrative Code (F.A.C.) for VOC emissions.

Operation of the proposed Bayside Units 1 and 2 will result in airborne emissions. Therefore, a permit is required prior to the beginning of facility construction, per Rule 62-212.300(1)(a), Florida Administrative Code (F.A.C.). This report, including the required permit application forms and supporting documentation included in the attachments, constitutes TEC's application for authorization to commence construction in accordance with the Florida Department of Environmental Protection (FDEP) permitting rules contained in Chapter 62-212, F.A.C.

Bayside Units 1 and 2 will be located in an attainment area and will have a VOC net emissions increase in excess of 40 tons per year (tpy). Consequently, Bayside Units 1 and 2 qualify as a major modification to an existing major facility and are subject to the PSD

NSR requirements of Rule 62-212.400, F.A.C. for VOCs. Therefore, this report and application is also submitted to satisfy the permitting requirements contained in the FDEP PSD rules and regulations.

This report is organized as follows:

- Section 1.2 provides an overview and summary of the key regulatory determinations.
- Section 2.0 describes the proposed facility and associated air emissions.
- Section 3.0 describes national and state air quality standards and discusses applicability of NSR procedures to the proposed project.
- Section 4.0 provides an analysis of best available control technology (BACT) for VOCs.
- Sections 5.0 (Dispersion Modeling Methodology) and 6.0 (Dispersion Modeling Results) address ambient air quality impacts.

Attachments A through D provide the FDEP Application for Air Permit—Long Form, NO_x control system descriptions, emission rate calculations, and PSD netting analysis, respectively. All dispersion modeling input and output files for the ambient impact analysis are provided in Attachment E.

1.2 SUMMARY

Bayside Units 1 and 2 will consist of seven combined-cycle CT/HRSG units. The CTs will be fired primarily with pipeline-quality natural gas containing no more than 2.0 grains of total sulfur per one hundred standard cubic feet (gr S/100 scf). Low sulfur fuel oil (containing no more than 0.05 weight percent sulfur [wt%S]) will serve as a back-up fuel source.

The planned construction start date for Bayside Units 1 and 2 is May 2001. The planned construction completion dates for Bayside Units 1 and 2 are March 2003 and March 2004, respectively.

Based on an evaluation of the anticipated worst-case annual operating scenario, Bayside Units 1 and 2 will have the potential to emit 1,018.2 tpy of nitrogen oxides (NO_x), 989.7 tpy of carbon monoxide (CO), 721.4 tpy of particulate matter/particulate matter less than or equal to 10 micrometers (PM/PM₁₀), 576.3 tpy of sulfur dioxide (SO₂), 99.6 tpy of volatile organic compounds (VOCs), and 1.07 tpy of lead. Regarding noncriteria pollutants, Bayside Units 1 and 2 will potentially emit 96.7 tpy of sulfuric acid (H₂SO₄) mist and trace amounts of heavy metals and organic compounds.

As presented in this report, the analyses required for this permit application resulted in the following conclusions:

- The net increase in emissions following the repowering of F.J. Gannon Station Units 5 and 6 with Bayside Units 1 and 2 will be below the Table 212.400-2 F.A.C. Significant Emission Rates for all regulated air pollutants, with the exception of VOCs. Accordingly, Bayside Units 1 and 2 are subject to the PSD NSR requirements of Section 62-212.400, F.A.C. for VOCs only. Based on actual historical emission rates, the repowering of F.J. Gannon Station Unit 5 and 6 with new Bayside Units 1 and 2 will result in a net decrease of 14,659.8 tpy of nitrogen oxides (NO_x), 35,841.2 tpy of sulfur dioxide (SO₂), 4,399.9 tpy of carbon monoxide (CO), 378.2 tpy of particulate matter (PM/PM₁₀), 8.5 tpy of lead (Pb), and a net increase of 70.7 tpy of VOCs.
- Emissions of PM/PM₁₀, SO₂, and H₂SO₄ will be controlled by the use of natural gas and low sulfur, low ash distillate fuel oil. Bayside Units 1 and 2 will be fired primarily with natural gas. Use of distillate fuel oil will be limited to a capacity factor of no more than 10 percent. At base load operation, this annual capacity factor is equivalent to 876 hr/yr.
- NO_x emissions will be controlled by the use of dry low-NO_x (DLN) combustors and the use of SCR or SCONO_xTM (for one CTG/HRSG as an alternative to SCR) control technology. Controlled NO_x CT/HRSG exhaust concentrations will be 3.5 and 16.4 parts per million by volume corrected to 15 percent oxygen (ppmvd @ 15 percent O₂) for natural gas and distillate fuel oil-firing, respectively.

- Advanced burner design and good operating practices to minimize incomplete combustion will be employed to control CO emissions. At base load operations, CO CT/HRSG exhaust concentrations will be 7.2 and 14.2 ppmvd @ 15 percent O₂ for natural gas and distillate fuel oil-firing, respectively.
- Advanced burner design and good operating practices to minimize incomplete combustion will be employed to control VOC emissions. At baseload operation during natural gas and distillate fuel oil firing, CT/HRSG VOC exhaust concentrations are projected to be 1.2 and 2.8 ppmvd @ 15 percent O₂, respectively. Cost effectiveness of a VOC oxidation catalyst control system was determined to be \$82,150 per ton of VOC. Due to the high control costs, installation of a VOC oxidation catalyst control system is considered to be economically infeasible.
- Bayside Units 1 and 2 will each have potential emissions of hazardous air pollutants (HAPS) less than the major source thresholds of 10 tpy for any individual HAP and 25 tpy for total HAPs. Bayside Units 1 and 2 are therefore not subject to the case-by-case maximum achievable control technology (MACT) requirements of Section 112(g)(2)(B) of the 1990 Clean Air Act Amendments.
- Analysis of the ambient air quality impacts due to operation of Bayside Units 1 and 2 demonstrates that maximum impacts will be well below all state and federal air quality standards.

2.0 DESCRIPTION OF THE PROPOSED FACILITY

2.1 PROJECT DESCRIPTION, AREA MAP, AND PLOT PLAN

Bayside Units 1 and 2 will be located at the existing Tampa Electric Company F.J. Gannon Station. The F.J. Gannon Station is situated on Port Sutton Road in Tampa, Hillsborough County, Florida. Figure 2-1 provides portions of a U.S. Geological Survey (USGS) topographical map showing the F.J. Gannon Station site location and nearby prominent geographical features.

Bayside Units 1 and 2 will consist of seven, combined-cycle GE PG7241 (FA) CTs. Each CT will be capable of producing a nominal 166 MW of electricity. The three Bayside Unit 1 combined-cycle CTs (designated as CT-1A, CT-1B, and CT-1C) will repower F.J. Gannon Unit 5. Bayside Unit 1, including the repowered F.J. Gannon Station Unit 5 steam turbine (ST), will have a nominal generation capacity of 753 MW. The four Bayside Unit 2 combined-cycle CTs (designated as CT-2A, CT-2B, CT-2C, and CT-2D) will repower F.J. Gannon Unit 6. Bayside Unit 2, including the repowered F.J. Gannon Station Unit 6 ST, will have a nominal generation capacity of 975 MW. The CTs will be fired primarily with pipeline quality natural gas. Low-sulfur distillate fuel oil will serve as a back-up fuel source.

Bayside Units 1 and 2 will operate at annual capacity factors up to 100 and 10 percent for natural gas and oil firing, respectively. Capacity factor is defined as the ratio of the CT's actual annual electric output (in units of megawatts electrical per hour [MWe-hr]) to the unit's nameplate capacity times 8,760 hours. At baseload operation, these annual capacity factors are equivalent to 8,760 and 876 hours per year (hr/yr) for natural gas and oil firing, respectively. Maximum annual CT oil firing operating hours will increase with lower load operations. For example, at 50 percent load each CT could burn fuel oil up to 1,752 hours per year. The CTs will normally operate between 50- and 100-percent load.

Combustion of natural gas and distillate fuel oil in the CTs will result in emissions of PM/PM₁₀, SO₂, NO_x, CO, VOCs, and H₂SO₄ mist. Emission control systems proposed for the combined-cycle CTs include the use of DLN combustors and SCR control technology




FIGURE 2-1.

F.J. GANNON STATION LOCATION AND SURROUNDINGS

Source: ECT, 2000.

ECT
Environmental Consulting & Technology, Inc.

for abatement of NO_x; good combustion practices for control of CO and VOCs; and use of clean, low-sulfur, low-ash natural gas and distillate fuel oil to minimize PM/PM₁₀, SO₂, and H₂SO₄ mist emissions. As an alternative to SCR, one CT/HRSG may be equipped with SCONO_xTM control technology.


Figure 2-2 provides a plot plan of the Bayside Power Station showing the Bayside Units 1 and 2 layout, major process equipment and structures, and the new CT/HRSG emission points. A profile view of Bayside Unit 1 is provided on Figure 2-3; the profile for Bayside Unit 2 will be same but with the addition of one more CT/HRSG unit. Primary access to the Bayside Power Station will be from Port Sutton Road on the south side of the site. The Bayside Power Station entrance will have security to control site access.

2.2 PROCESS DESCRIPTION AND PROCESS FLOW DIAGRAMS

Bayside Units 1 and 2 will include seven nominal 166-MW CTs operating in combined-cycle mode. Figures 2-4 and 2-5 present process flow diagrams for Bayside Units 1 and 2, respectively.

CTs are heat engines that convert latent fuel energy into work using compressed hot gas as the working medium. CTs deliver mechanical output by means of a rotating shaft used to drive an electrical generator, thereby converting a portion of the engine's mechanical output to electrical energy. Ambient air is first filtered and then compressed by the CT compressor. On warm days, the CT inlet air may be conditioned by the use of evaporative coolers. The CT compressor increases the pressure of the combustion air stream and also raises its temperature. The compressed combustion air is then combined with natural gas or distillate fuel oil and burned in the CT's high-pressure combustor to produce hot exhaust gases. These high-pressure, hot gases next expand and turn the CT's turbine to produce rotary shaft power, which is used to drive an electric generator as well as the CT combustion air compressor.

The exhaust gases from each CT will then flow to a HRSG for the production of low-, intermediate-, and high-pressure steam. Steam produced by the three Bayside Unit 1 CT/HRSG units will be used to repower the existing F.J. Gannon Station Unit 5 ST. The



NEW PIPE RACK

NEW CTs & HRSGs



GRAPHIC SCALE
0 40 80 160
SCALE IN FEET

- EXISTING STRUCTURES KEY:
- A. PLANT OFFICE
 - B. WAREHOUSE
 - C. CONCRETE ENCASED ELECTRICAL CONDUITS
 - D. CITY WATER TANKS
 - E. CITY WATER PUMP HOUSE
 - F. COMBUSTION TURBINE/GENERATOR
 - G. FUEL OIL PUMP HOUSE
 - H. REVERSE OSMOSIS BUILDING
 - I. SLUMP PIT
 - J. ELECTRICAL BUILDING
 - K. RECYCLE WATER TANK
 - L. BOILER SHOP
 - M. SHOP/STORAGE
 - N. GUARD HOUSE
 - O. MOVY LOAD CENTER
 - P. UNIT 6 PRECIPITATOR

- NEW STRUCTURES KEY:
- 1. GETTA COMBUSTION TURBINE GENERATOR
 - 2. GETTA AIR INLET FILTER
 - 3. GETTA MAINTENANCE ACCESS AREA FOR MOBILE CRANE
 - 4. HEAT RECOVERY STEAM GENERATOR (HRSG)
 - 5. HRSG MAINTENANCE ACCESS AREA
 - 6. GENERATOR STEP-UP TRANSFORMER (GSU)
 - 7. GE ACCESSORY MODULE
 - 8. CT ELECTRICAL BUILDING
 - 9. COMMON ELECTRICAL BUILDING (UNIT 1C & 2A)
 - 10. STATION SERVICE TRANSFORMER
 - 11. CONDENSATE POLISHING BUILDING (55' X 85')
 - 12. AMMONIA TANKS
 - 13. PIPE RACK
 - 14. FLOOD WALL
 - 15. FUEL OIL TANK (DUAL WALL) 5.85M GAL
 - 16. H2 BULK AREA
 - 17. CO2 STORAGE
 - 18. GAS LINE TIE-IN
 - 19. GAS COMPRESSORS
 - 20. DEMINERALIZED WATER TANK 5.5M GAL
 - 21. CONSTRUCTION LAYDOWN
 - 22. CONSTRUCTION PARKING


- NEW STRUCTURES KEY (CONTINUED):
- 24. ELECTRICAL CABLE TRENCH
 - 25. HOOKUP FOR PORTABLE KAYTON UNIT
 - 26. GAS CONDENSING SPOD (1 PER CT)
 - 27. C.E.M. ENCLOSURE (1 PER HRSG)
 - 28. SAMPLE/OVEN FEED BUILDING (1 PER UNIT)
 - 29. L.A. COMPRESSORS W/DRIVERS & RECEIVERS
 - 30. CONSTRUCTION OFFICE/WAREHOUSE (50' X 175')
 - 31. CONTROL/ADMINISTRATION BUILDING (70' X 80')
 - 32. CONDENSATE SURGE TANKS W/BOOSTER PUMPS
 - 33. CCM COOLING TOWERS
 - 34. DEMINERALIZED WATER TRAILERS
 - 35. CONSTRUCTION POWER TRANSFORMER
 - 36. CONSTRUCTION POWER DISCONNECT SWITCH
 - 37. STAR TOWER TO HRSG & ISOLATION VALVES
 - 38. DRAINAGE SUMPS (5 TOTAL)
 - 39. RELOCATED BRIVY TRANSMISSION LINE
 - 40. PERSONNEL ACCESS DOOR THROUGH FLOOD WALL
 - 41. CRUSH PROTECTION BARRIER
 - 42. PEDEC
 - 43. HRSG ELECTRICAL BUILDING
 - 44. BAC
 - 45. LCI (1 PER UNIT)
 - 46. PULSHER WASTE WATER TANK

- NOTES:
- 1. MAIN PIPE RACK FROM EXISTING STATION TO NEW UNITS (INCLUDING STRUCTURES FOR THERMAL EXPANSION LOOPS) ARE TWO LEVELS.
 - 2. ANCILLARY PIPE RACKS AT EACH HRSG ARE ONE LEVEL.
 - 3. EXISTING SITE ELEVATION IS 8'-8" (APPROX.). THE AREA WITHIN THE NEW CT/HRSG ISLAND TO BE RAISED TO ELEVATION 12'-8". TRANSITION RAMPS INDICATED.
 - 4. CT/HRSG SPACING @ 150'-0" O.C.

FIGURE 2-2.
BAYSIDE UNITS 1 AND 2 PLOT PLAN

Source: Sargent & Lundy, 2000.






GRAPHIC SCALE

0 12.5 25 50



SCALE IN FEET

SECTION (LOOKING NORTH FROM MAIN PIPE RACK) (LAYS 2A, 2B & 2C SHOWN)




SECTION A-A (LOOKING WEST)

0 02-17-2000 D.SADROUET REFERENCE

FIGURE 2-3. BAYSIDE UNIT 1 PROFILE

Source: Sargent & Lundy, 2000.







LEGEND
 EMISSION POINT

FIGURE 2-4.
 PROCESS FLOW DIAGRAM - BAYSIDE UNIT 1

Source: TEC, 2000; ECT, 2000.





LEGEND
 (Symbol: Diamond with 'EM' and 'CT-1') EMISSION POINT

FIGURE 2-5.
 PROCESS FLOW DIAGRAM - BAYSIDE UNIT 2

Source: TEC, 2000; ECT, 2000.



Unit 5 ST, in turn, will drive an existing electric generator having a nominal generation capacity of 239-MW. Steam produced by the four Bayside Unit 2 CT/HRSG units will be used to repower the existing F.J. Gannon Station Unit 6 ST. The Unit 6 ST will drive an existing electric generator having a nominal generation capacity of 414-MW. The HRSGs will be unfired; i.e., the units will not include the capability of supplemental duct burner firing. Following reuse of the CTs exhaust waste heat by the HRSGs, the exhaust gases are vented to the atmosphere.

Normal operation is expected to consist of all Bayside Units 1 and 2 CT/HRSGs firing natural gas at base load. Alternate operating modes include reduced load (i.e., between 50 and 100-percent of baseload) operation for one or more of the CT/HRSG units depending on power demands, CT inlet air evaporative cooling, and use of back-up distillate fuel oil. CT/HRSG CO and VOC exhaust concentrations are expected to remain essentially constant from 50- to 100-percent load. However, it is possible that CO and VOC exhaust concentrations will also remain essentially unchanged at lower loads (e.g., 45-percent load). For this reason, TEC requests a permit condition authorizing lower load operations based on actual CT/HRSG tested emissions. As noted previously, the combined-cycle CT/HRSGs may operate at annual capacity factors up to 100 and 10 percent for natural gas and oil firing, respectively.

Vendor information indicates that the Bayside Unit 1 and 2 7FA CTs will have a heat input of 1,779.4 and 1,928.0 million British thermal units power hour (MMBtu/hr), higher heating value (HHV) at base load and 59°F ambient temperature for natural gas and distillate fuel oil firing, respectively. However, CT vendors typically include a margin in guaranteed heat rates and therefore actual heat inputs could be somewhat higher than provided on the vendor expected performance data sheets. TEC therefore requests a permit condition that would allow for a higher maximum heat input rate based on actual performance tests.

Rule 62-210.700(1), F.A.C., allows for excess emissions due to start-up, shut-down, or malfunction for no more than 2 hours in any 24-hour period unless specifically authorized by FDEP for a longer duration. Because CT/HRSG warm and cold start periods will last for 180 and 240 minutes, respectively, excess emissions for up to 4 hours in any

24-hour period are requested for the new CT/HRSGs. CT/HRSG start-up/shut-down is defined as that period of time from initiation of CT/HRSG firing until the unit reaches steady-state load operation. Steady-state operation is reached when the CT/HRSG reaches minimum load (i.e., 50-percent load). A warm start is defined as a start-up that occurs when a CT/HRSG has been down for more than 2 hours and less than or equal to 24 hours. A cold start is defined as a start-up that occurs when a CT/HRSG has been down for more than 24 hours. Due to metal temperature limitations of the repowered steam turbines, excess emissions for up to 18 hours per cold startup of the steam turbine systems for each Bayside Unit are requested.

The CTs will utilize DLN combustion technology and SCR to control NO_x air emissions. As an alternative to SCR, one CT/HRSG may be equipped with SCONO_xTM control technology. The use of low-sulfur natural gas and distillate fuel oil in the CTs will minimize PM/PM₁₀, SO₂, and H₂SO₄ mist air emissions. High efficiency combustion practices will be employed to control CO and VOC emissions.

2.3 EMISSION AND STACK PARAMETERS

Tables 2-1 and 2-2 provide maximum hourly criteria pollutant CT/HRSG emission rates (per CT/HRSG unit) for natural gas and distillate fuel oil firing, respectively. Maximum hourly H₂SO₄ emission rates for natural gas and distillate fuel oil firing are summarized in Table 2-3. Maximum hourly noncriteria pollutant rates for natural gas and distillate fuel oil firing are provided in Tables 2-4 and 2-5, respectively. The highest hourly emission rates for each pollutant are shown, taking into account load and ambient temperature to develop maximum hourly emission estimates for each CT/HRSG.

Maximum hourly emission rates for all pollutants (with the exception of CO), in units of pounds per hour (lb/hr), are projected to occur for CT/HRSG operations at base load and low ambient temperature (i.e., 18°F), and fuel oil firing. For CO, maximum hourly emissions in lb/hr are projected to occur for CT/HRSG operations at 50-percent load, 93°F ambient temperature, and fuel oil firing. The bases for these emission rates are provided in Attachment C.

Table 2-1. Maximum Criteria Pollutant Emission Rates for Three Unit Loads and Four Temperatures (Per CT/HRGS)—Natural Gas

Unit Load (%)	Ambient Temperature (°F)	PM/PM ₁₀ *		SO ₂		NO _x		CO		VOC		Lead	
		lb/hr	g/s	lb/hr	g/s	lb/hr	g/s	lb/hr	g/s	lb/hr	g/s	lb/hr	g/s
100	18	20.5	2.58	10.7	1.35	24.7	3.11	31.1	3.92	3.0	0.38	0.030	0.0038
	59	20.3	2.56	10.0	1.26	23.1	2.91	28.7	3.62	2.8	0.35	0.028	0.0035
	72	20.3	2.56	9.8	1.23	22.6	2.85	27.8	3.50	2.7	0.34	0.027	0.0034
	93	20.2	2.55	9.5	1.19	21.9	2.76	26.9	3.39	2.7	0.34	0.027	0.0033
75	18	20.0	2.52	8.7	1.09	19.9	2.51	24.6	3.10	2.4	0.30	0.024	0.0031
	59	19.9	2.51	8.2	1.03	18.7	2.36	23.5	2.96	2.3	0.29	0.023	0.0029
	72	19.8	2.49	7.9	1.00	18.2	2.29	22.8	2.87	2.2	0.28	0.022	0.0028
	93	19.7	2.48	7.5	0.95	17.2	2.17	21.9	2.76	2.2	0.28	0.021	0.0027
50	18	19.6	2.47	7.0	0.88	15.8	1.99	20.4	2.57	2.0	0.25	0.020	0.0025
	59	19.5	2.46	6.5	0.82	14.8	1.86	19.5	2.46	1.9	0.24	0.018	0.0023
	72	19.5	2.46	6.4	0.80	14.4	1.81	19.1	2.41	1.8	0.23	0.018	0.0022
	93	19.4	2.44	6.0	0.76	13.7	1.73	18.6	2.34	1.8	0.23	0.017	0.0021

Note: g/s = gram per second.
lb/hr = pound per hour.

*As measured by EPA Reference Methods 201 and 202.

Sources: ECT, 2000.
S&L, 2000.

2-10

Table 2-2 Maximum Criteria Pollutant Emission Rates for Three Unit Loads and Four Temperatures (Per CT/HRGS)—Distillate Fuel Oil

Unit Load (%)	Ambient Temperature (°F)	PM/PM ₁₀ *		SO ₂		NO _x		CO		VOC		Lead	
		lb/hr	g/s	lb/hr	g/s	lb/hr	g/s	lb/hr	g/s	lb/hr	g/s	lb/hr	g/s
100	18	53.8	6.78	104.6	13.17	132.3	16.67	70.0	8.82	7.8	0.98	0.104	0.0131
	59	52.6	6.63	98.2	12.38	124.2	15.65	64.5	8.13	7.3	0.92	0.098	0.0123
	72	52.2	6.58	96.0	12.10	121.6	15.32	62.5	7.88	7.1	0.89	0.096	0.0121
	93	51.6	6.50	92.9	11.70	117.6	14.82	60.4	7.61	6.9	0.87	0.093	0.0117
75	18	50.0	6.30	84.3	10.62	105.6	13.31	64.6	8.14	6.0	0.76	0.084	0.0106
	59	49.1	6.19	79.4	10.00	99.4	12.52	59.3	7.47	5.8	0.73	0.079	0.0100
	72	48.7	6.14	77.4	9.75	96.9	12.21	58.1	7.32	5.7	0.72	0.077	0.0097
	93	47.9	6.04	73.5	9.25	91.9	11.58	56.1	7.07	5.5	0.69	0.073	0.0092
50	18	46.7	5.88	66.9	8.43	83.1	10.47	74.1	9.34	5.0	0.63	0.067	0.0084
	59	46.0	5.80	63.2	7.97	78.5	9.89	71.4	9.00	4.8	0.60	0.063	0.0079
	72	45.7	5.76	61.5	7.75	76.3	9.61	74.6	9.40	4.8	0.60	0.061	0.0077
	93	45.1	5.68	58.3	7.35	72.2	9.10	81.3	10.24	4.7	0.59	0.058	0.0073

Note: g/s = gram per second.
lb/hr = pound per hour.

*As measured by EPA Reference Methods 201 and 202.

Sources: ECT, 2000.
S&L, 2000.

Table 2-3. Maximum H₂SO₄ Pollutant Emission Rates for Three Loads and Four Ambient Temperatures (Per CT/HRSG)

Unit Load (%)	Ambient Temperature (°F)	Natural Gas H ₂ SO ₄		Distillate Fuel Oil H ₂ SO ₄	
		lb/hr	g/s	lb/hr	g/s
100	18	2.0	0.25	16.0	2.02
	59	1.8	0.23	15.0	1.90
	72	1.8	0.23	14.7	1.85
	93	1.7	0.22	14.2	1.79
75	18	1.6	0.20	12.9	1.63
	59	1.5	0.19	12.2	1.53
	72	1.5	0.18	11.8	1.49
	93	1.4	0.17	11.2	1.42
50	18	1.3	0.16	10.3	1.29
	59	1.2	0.15	9.7	1.22
	72	1.2	0.15	9.4	1.19
	93	1.1	0.14	8.9	1.13

Sources: ECT, 2000.
S&L, 2000.

Table 2-4. Maximum Noncriteria Pollutant Emission Rates for 100 Percent Load and Three Temperatures (Per CT/HRSG)—Natural Gas

Unit Load (%)	Ambient Temp. (°F)	1,3-Butadiene		Acetaldehyde		Acrolein		Benzene		Ethylbenzene		Formaldehyde	
		lb/hr	g/s	lb/hr	g/s	lb/hr	g/s	lb/hr	g/s	lb/hr	g/s	lb/hr	g/s
100	18	0.00012	1.51E-05	0.082	1.03E-02	0.011	1.39E-03	0.035	4.41E-03	0.043	5.42E-03	0.217	2.73E-02
	59	0.00011	1.39E-05	0.077	9.70E-03	0.010	1.26E-03	0.033	4.16E-03	0.041	5.17E-03	0.203	2.56E-02
	93	0.00010	1.26E-05	0.073	9.20E-03	0.009	1.13E-03	0.031	3.91E-03	0.038	4.79E-03	0.192	2.42E-02

Unit Load (%)	Ambient Temp. (°F)	Mercury		Naphthalene		Polycyclic Aromatic Hydrocarbons		Propylene Oxide		Toluene		Xylene	
		lb/hr	g/s	lb/hr	g/s	lb/hr	g/s	lb/hr	g/s	lb/hr	g/s	lb/hr	g/s
100	18	1.5E-06	1.89E-07	0.0012	1.51E-04	0.00090	1.13E-04	0.055	6.93E-03	0.130	1.64E-02	0.124	1.56E-02
	59	1.4E-06	1.76E-07	0.0011	1.39E-04	0.00084	1.06E-04	0.051	6.43E-03	0.121	1.52E-02	0.116	1.46E-02
	93	1.3E-06	1.64E-07	0.0011	1.39E-04	0.00080	1.01E-04	0.048	6.05E-03	0.115	1.45E-02	0.110	1.39E-02

Note: g/s = gram per second.
 lb/hr = pound per hour.

Source: ECT, 2000.

Table 2-5. Maximum Noncriteria Pollutant Emission Rates for 100 Percent Load and Three Temperatures (Per CT/HRSG)—Distillate Fuel Oil

Unit Load (%)	Ambient Temp. (°F)	1,3-Butadiene		Arsenic		Benzene		Beryllium		Cadmium		Chromium	
		lb/hr	g/s	lb/hr	g/s	lb/hr	g/s	lb/hr	g/s	lb/hr	g/s	lb/hr	g/s
100	18	0.033	4.16E-03	0.023	2.90E-03	0.113	1.42E-02	0.00064	8.06E-05	0.0100	1.26E-03	0.023	2.90E-03
	59	0.031	3.91E-03	0.021	2.65E-03	0.106	1.34E-02	0.00060	7.56E-05	0.0093	1.17E-03	0.021	2.65E-03
	93	0.029	3.65E-03	0.020	2.52E-03	0.100	1.26E-02	0.00057	7.18E-05	0.0088	1.11E-03	0.020	2.52E-03

Unit Load (%)	Ambient Temp. (°F)	Formaldehyde		Manganese		Mercury		Naphthalene		Nickel		Polycyclic Aromatic Hydrocarbons	
		lb/hr	g/s	lb/hr	g/s	lb/hr	g/s	lb/hr	g/s	lb/hr	g/s	lb/hr	g/s
100	18	0.575	7.25E-02	1.621	2.04E-01	0.0025	3.15E-04	0.072	9.07E-03	0.0094	1.18E-03	0.082	1.03E-02
	59	0.540	6.80E-02	1.523	1.92E-01	0.0023	2.90E-04	0.067	8.44E-03	0.0089	1.12E-03	0.077	9.70E-03
	93	0.510	6.43E-02	1.440	1.81E-01	0.0022	2.77E-04	0.064	8.06E-03	0.0084	1.06E-03	0.073	9.20E-03

Unit Load (%)	Ambient Temp. (°F)	Selenium	
		lb/hr	g/s
100	18	0.051	6.43E-03
	59	0.048	6.05E-03
	95	0.046	5.80E-03

Note: g/s = gram per second.
 lb/hr = pound per hour.
 Neg. = negligible

Source: ECT, 2000.

2-14

Table 2-6 presents projected maximum annual criteria and noncriteria emissions for Bayside Units 1 and 2. The maximum annualized rates were conservatively estimated assuming base load operation for 7,884 hr/yr (natural gas firing), base load operation for 876 hr/yr (fuel oil firing), and an ambient temperature of 59°F. As noted previously, existing F.J. Gannon Station Units 5 and 6 will cease coal-fired operation following commercial operation of Bayside Units 1 and 2. The net annual change in emissions associated with the F.J. Gannon Station repowering project are shown in Table 2-7.

Stack parameters for the CT/HRSG units are provided in Table 2-8 and 2-9 for natural gas and distillate fuel oil firing, respectively.

Table 2-6. Maximum Annual Emission Rates (tpy)

Pollutant	Bayside Units 1 and 2 (Both Units)
NO _x	1,018.2
CO	989.7
PM/PM ₁₀ *	721.4
SO ₂	576.3
VOC	99.6
H ₂ SO ₄ mist	96.7
1,3-Butadiene	0.098
Acetaldehyde	2.351
Acrolein	0.306
Arsenic	0.065
Benzene	1.224
Beryllium	0.002
Cadmium	0.028
Chromium	0.065
Ethylbenzene	1.244
Formaldehyde	7.253
Lead	1.07
Manganese	4.67
Mercury	0.0071
Naphthalene	0.238
Nickel	0.027
Polycyclic Aromatic Hydrocarbons	0.260
Propylene Oxide	1.560
Selenium	0.148
Toluene	3.710
Xylene	3.552

*As measured by EPA Reference Methods 201 and 202.

Sources: ECT, 2000.
TEC, 2000.
S&L, 2000.

Table 2-7. Net Annual Change in Emission Rates (tpy)

Pollutant	F.J. Gannon Station Units 5 & 6 Repowering Project
NO _x	-14,659.8
CO	-4,399.9
PM/PM ₁₀	-378.2
SO ₂	-35,841.2
VOC	70.7
H ₂ SO ₄ mist	-51.3
Pb	-8.5

Sources: ECT, 2000.
TEC, 2000.
S&L, 2000.

Table 2-8. Stack Parameters for Three Unit Loads and Four Ambient Temperatures—Natural Gas (Per CT/HRSG)

Unit Load (%)	Ambient Temperature (°F)	Stack Height		Stack Exit Temperature		Stack Exit Velocity		Stack Diameter	
		ft	meters	°F	K	ft/sec	m/sec	ft	meters
100	18	150	45.7	233	385	66.3	20.2	19.0	5.8
	59	150	45.7	212	373	59.9	18.3	19.0	5.8
	72	150	45.7	215	375	59.0	18.0	19.0	5.8
	93	150	45.7	216	375	57.6	17.6	19.0	5.8
75	18	150	45.7	215	375	51.1	15.6	19.0	5.8
	59	150	45.7	212	373	49.0	14.9	19.0	5.8
	72	150	45.7	214	374	48.2	14.7	19.0	5.8
	93	150	45.7	215	375	46.5	14.2	19.0	5.8
50	18	150	45.7	201	367	41.5	12.6	19.0	5.8
	59	150	45.7	211	373	40.5	12.3	19.0	5.8
	72	150	45.7	213	374	40.1	12.2	19.0	5.8
	93	150	45.7	213	374	39.2	12.0	19.0	5.8

Note: K = Kelvin.
 ft/sec = foot per second.
 m/sec = meter per second.

Sources: ECT, 2000.
 S&L, 2000.

2-18

Table 2-9. Stack Parameters for Three Unit Loads and Four Ambient Temperatures—Distillate Fuel Oil (Per CT/HRSG)

Unit Load (%)	Ambient Temperature (°F)	Stack Height		Stack Exit Temperature		Stack Exit Velocity		Stack Diameter	
		ft	meters	°F	K	ft/sec	m/sec	ft	meters
100	18	150	45.7	285	414	74.4	22.7	19.0	5.8
	59	150	45.7	274	408	68.2	20.8	19.0	5.8
	72	150	45.7	276	409	66.8	20.4	19.0	5.8
	93	150	45.7	276	409	64.9	19.8	19.0	5.8
75	18	150	45.7	285	414	57.2	17.4	19.0	5.8
	59	150	45.7	274	408	54.2	16.5	19.0	5.8
	72	150	45.7	275	408	53.5	16.3	19.0	5.8
	93	150	45.7	275	408	51.7	15.8	19.0	5.8
50	18	150	45.7	285	414	47.2	14.4	19.0	5.8
	59	150	45.7	271	406	44.9	13.7	19.0	5.8
	72	150	45.7	272	406	44.5	13.6	19.0	5.8
	93	150	45.7	272	406	43.5	13.3	19.0	5.8

Note: K = Kelvin.
 ft/sec = foot per second.
 m/sec = meter per second.

Sources: ECT, 2000.
 S&L, 2000.

3.0 AIR QUALITY STANDARDS AND NEW SOURCE REVIEW APPLICABILITY

3.1 NATIONAL AND STATE AAQS

As a result of the 1977 Clean Air Act (CAA) Amendments, the U.S. Environmental Protection Agency (EPA) has enacted primary and secondary NAAQS for six air pollutants (40 CFR 50). Primary NAAQS are intended to protect the public health, and secondary NAAQS are intended to protect the public welfare from any known or anticipated adverse effects associated with the presence of pollutants in the ambient air. Florida has also adopted AAQS; reference Section 62-204.240, F.A.C. Table 3-1 presents the current national and Florida AAQS.

Areas of the country in violation of AAQS are designated as nonattainment areas, and new sources to be located in or near these areas may be subject to more stringent air permitting requirements. The F.J. Gannon Station is located south of downtown Tampa in Hillsborough County. Hillsborough County is presently designated in 40 CFR §81.310 as unclassifiable (for total suspended particulates [TSPs]; that portion of Hillsborough County which falls within the area of a circle having a centerpoint at the intersection of U.S. 41 South and State Road 60 and a radius of 12 km, for SO₂, and for lead; the area encompassed within a radius of five km centered on UTM coordinates: 364.0 km East, 3093.5 km North, zone 17, in the City of Tampa), unclassifiable/attainment (for CO), and unclassifiable or better than national standards (for nitrogen dioxide [NO₂]). EPA had previously revoked the 1-hour ozone standard for all areas of Florida in June 1998 due to adoption of a new eight-hour ozone standard. However, due to litigation involving the new eight-hour ozone standard, on July 5, 2000 EPA reinstated the 1-hour ozone standard for all counties in Florida. Presently, 40 CFR §81.310 designates all counties in Florida, including Hillsborough County, as unclassifiable/attainment with respect to the 1-hour ozone standard.

Hillsborough County is designated attainment (for ozone, CO, and NO₂) and unclassifiable (for SO₂, PM₁₀ and lead) by Section 62-204.340, F.A.C. Hillsborough County is also

Table 3-1. National and Florida Air Quality Standards (micrograms per cubic meter [$\mu\text{g}/\text{m}^3$] unless otherwise stated)

Pollutant (units)	Averaging Periods	National Standards		Florida Standards
		Primary	Secondary	
SO ₂ (ppmv)	3-hour ¹		0.5	0.5
	24-hour ¹	0.14		0.1
	Annual ²	0.030		0.02
SO ₂	3-hour ¹			1,300
	24-hour ¹			260
	Annual ²			60
PM ₁₀ ¹³	24-hour ³	150	150	
	Annual ⁴	50	50	
PM ₁₀	24-hour ⁵			150
	Annual ⁶			50
PM _{2.5} ^{11,12}	24-hour ⁷	65	65	
	Annual ⁸	15	15	
CO (ppmv)	1-hour ¹	35		35
	8-hour ¹	9		9
CO	1-hour ¹			40,000
	8-hour ¹			10,000
Ozone (ppmv)	1-hour ⁹	0.12		0.12
	8-hour ^{10,11}	0.08	0.08	
NO ₂ (ppmv)	Annual ²	0.053	0.053	0.05
	Annual ²			100
Lead	Calendar Quarter Arithmetic Mean	1.5	1.5	1.5

¹Not to be exceeded more than once per calendar year.

²Arithmetic mean.

³Standard attained when the 99th percentile is less than or equal to the standard, as determined by 40 CFR 50, Appendix N.

⁴Arithmetic mean, as determined by 40 CFR 50, Appendix N.

⁵Not to be exceeded more than once per year, as determined by 40 CFR 50, Appendix K.

⁶Standard attained when the expected annual arithmetic mean is less than or equal to the standard, as determined by 40 CFR 50, Appendix K.

⁷Standard attained when the 98th percentile is less than or equal to the standard, as determined by 40 CFR 50, Appendix N.

⁸Arithmetic mean, as determined by 40 CFR 50, Appendix N.

⁹Standard attained when the expected number of days per calendar year with maximum hourly average concentrations above the standard is equal to or less than 1, as determined by 40 CFR 50, Appendix H.

¹⁰Standard attained when the average of the annual 4th highest daily maximum 8-hour average concentration is less than or equal to the standard, as determined by 40 CFR 50, Appendix I.

¹¹The U.S. Court of Appeals for the District of Columbia Circuit (Circuit Court) held that these standards are not enforceable. *American Trucking Association v. U.S.E.P.A.*, 1999 WL300618 (Circuit Court).

¹²The Circuit Court may vacate standards following briefing. *Id.*

¹³The Circuit Court held PM₁₀ standards vacated upon promulgation of effective PM_{2.5} standards.

Sources: 40 CFR 50.

Section 62-204.240, F.A.C.

classified as an Air Quality Maintenance Area for ozone (entire county), for PM (that portion of Hillsborough County which falls within the area of a circle having a center-point at the intersection of U.S. 41 South and State Road 60 and a radius of 12 km), and for lead (the area encompassed within a radius of five km centered on UTM coordinates: 364.0 km East, 3093.5 km North, zone 17) by Section 62-204.340, F.A.C.

3.2 NONATTAINMENT NSR APPLICABILITY

The Bayside Power Station will be located in Hillsborough County. As noted above, Hillsborough County is presently designated as either better than national standards or unclassifiable/attainment for all criteria pollutants. Accordingly, Bayside Units 1 and 2 are not subject to the nonattainment NSR requirements of Section 62-212.500, F.A.C.

3.3 PSD NSR APPLICABILITY

The existing F.J. Gannon Station is classified as a major facility. A modification to a major facility which has potential net emissions equal to or exceeding the significant emission rates indicated in Section 62-212.400, Table 212.400-2, F.A.C., is subject to PSD NSR.

Net emission rates for the F.J. Gannon Station Units 5 and 6 repowering project will be below the significant emission rate thresholds, with the exception of VOCs. Comparisons of estimated potential annual emission rates for the F.J. Gannon Units 5 and 6 repowering project and the PSD significant emission rate thresholds are provided in Table 3-2. As shown in this table, potential emissions of all regulated PSD pollutants, with the exception of VOCs, are projected to be below the applicable PSD significant emission rate levels. Therefore, Bayside Units 1 and 2 qualify as a major modification to a major facility and are subject to the PSD NSR requirements of Section 62-212.400, F.A.C. for VOCs only. Attachment D provides a detailed PSD netting analysis for the repowering project.

Table 3-2. Repowering Projected Emissions Compared to PSD Significant Emission Rates

Pollutant	Repowering Project Net Emissions Increase (tpy)	PSD Significant Emission Rate (tpy)	PSD Applicability
NO _x	-14,659.8	40	No
CO	-4,399.9	100	No
PM	-378.2	25	No
PM ₁₀	-378.2	15	No
SO ₂	-35,841.2	40	No
Ozone/VOC	70.7	40	Yes
Lead	-8.5	0.6	No
Mercury	Negligible	0.1	No
Total fluorides	Negligible	3	No
H ₂ SO ₄ mist	-51.3	7	No
Total reduced sulfur (including hydrogen sulfide)	Not Present	10	No
Reduced sulfur compounds (including hydrogen sulfide)	Not Present	10	No
Municipal waste combustor acid gases (measured as SO ₂ and hydrogen chloride)	Not Present	40	No
Municipal waste combustor metals (measured as PM)	Not Present	15	No
Municipal waste combustor organics (measured as total tetra-through octa-chlorinated dibenzo-p-dioxins and dibenzofurans)	Not Present	3.5 × 10 ⁻⁶	No

Sources: Section 62-212.400, Table 212.400-2, F.A.C. ECT, 2000.

4.0 BEST AVAILABLE CONTROL TECHNOLOGY

4.1 METHODOLOGY

The VOC BACT analysis was performed in accordance with the EPA top-down method. The first step in the top-down BACT procedure is the identification of all available control technologies. Alternatives considered included process designs and operating practices that reduce the formation of emissions, post-process stack controls that reduce emissions after they are formed, and combinations of these two control categories. Sources of information which were used to identify control alternatives include:

- EPA reasonably available control technology (**RACT**)/**BACT**/lowest achievable emission rate (**LAER**) Clearinghouse (**RBLC**) via the RBLC Information System database.
- EPA NSR web site.
- EPA Control Technology Center (**CTC**) web site.
- Recent FDEP BACT determinations for similar facilities.
- Vendor information.
- Environmental Consulting & Technology, Inc. (**ECT**), experience for similar projects.

Following the identification of available control technologies, the next step in the analysis is to determine which technologies may be technically infeasible. Technical feasibility was evaluated using the criteria contained in Chapter B of the draft *EPA NSR Workshop Manual* (EPA, 1990a). The third step in the top-down BACT process is the ranking of the remaining technically feasible control technologies from high to low in order of control effectiveness.

An assessment of energy, environmental, and economic impacts is then performed. The economic analysis employed the procedures found in the Office of Air Quality Planning and Standards (OAQPS) *Control Cost Manual* (EPA, 1996). Specific factors used in estimating capital and annual operating costs are summarized in Table 4-1.

Table 4-1. Capital and Annual Operating Cost Factors

Cost Item	Factor
<u>Direct Capital Costs</u>	
Sales tax	0.06 x control system cost
Freight	0.05 x control system cost
Instrumentation	0.10 x control system cost
Foundations and supports	0.08 x purchased equipment cost
Handling and erection	0.14 x purchased equipment cost
Electrical	0.04 x purchased equipment cost
Piping	0.02 x purchased equipment cost
Insulation	0.01 x purchased equipment cost
Painting	0.01 x purchased equipment cost
<u>Indirect Capital Costs</u>	
Engineering	0.10 x purchased equipment cost
Construction and field expenses	0.05 x purchased equipment cost
Contractor fees	0.10 x purchased equipment cost
Start-up	0.02 x purchased equipment cost
Performance testing	0.01 x purchased equipment cost
Contingencies	0.03 x purchased equipment cost
<u>Direct Annual Operating Costs</u>	
Supervisor labor	0.15 x total operator labor cost
Maintenance labor	1.10 x operator labor direct wage
Maintenance materials	1.00 x total maintenance labor cost
<u>Indirect Annual Operating Costs</u>	
Overhead	0.60 x total of operating, supervisory, and maintenance labor and maintenance materials
Administrative charges	0.02 x total capital investment
Property taxes	0.01 x total capital investment
Insurance	0.01 x total capital investment

Source: EPA, 1996.

The fifth and final step is the selection of a BACT emission limitation or a design, equipment, work practice, operational standard, or combination thereof, corresponding to the most stringent, technically feasible control technology that was not eliminated based on adverse energy, environmental, or economic grounds.

As indicated in Section 3.3, Table 3-2, projected annual emission rates of VOCs for Bayside Units 1 and 2 exceed the PSD significance rate for this pollutant and, therefore, are subject to BACT analysis. A control technology analysis for VOCs using the five-step top-down BACT method is provided in Section 4.3.

4.2 FEDERAL AND FLORIDA EMISSION STANDARDS

Pursuant to Rule 62-212.400(5)(b), F.A.C., BACT emission limitations must be no less stringent than any applicable NSPS (40 CFR Part 60), NESHAP (40 CFR Parts 61 and 63), and FDEP emission standards (Chapter 62-296, F.A.C., *Stationary Sources—Emission Standards*).

On the federal level, emissions from gas turbines are regulated by NSPS Subpart GG. Subpart GG establishes emission limits for gas turbines that were constructed after October 3, 1977, and that meet any of the following criteria:

- Electric utility stationary gas turbines with a heat input at peak load of greater than 100 MMBtu/hr based on the LHV of the fuel.
- Stationary gas turbines with a heat input at peak load between 10 and 100 MMBtu/hr based on the fuel LHV.
- Stationary gas turbines with a manufacturer's rated base load at International Standards Organization (ISO) standard day conditions of 30 MW or less.

The electric utility stationary gas turbine NSPS applicability criterion applies to stationary gas turbines which sell more than one-third of their potential electric output to any utility power distribution system. The Bayside Units 1 and 2 CTs qualify as electric utility stationary gas turbines and, therefore, are subject to the NO_x and SO₂ emission limitations of NSPS 40 CFR 60, Subpart GG, § 60.332(a)(1) and § 60.333, respectively. However, NSPS Subpart GG does not include any VOC emission limitations.

FDEP emission standards for stationary sources are contained in Chapters 62-296, F.A.C., *Stationary Sources—Emission Standards*. Visible emissions are limited to a maximum of 20 percent opacity pursuant to Rule 62-296.320(4)(b), F.A.C. Sections 62-296.401 through 62-296.417, F.A.C., specify emission standards for 17 categories of sources; none of these categories are applicable to CTs. Rule 62-204.800(7), F.A.C. incorporates the federal NSPS by reference, including Subpart GG.

Emission standards applicable to sources located in ozone nonattainment and maintenance areas are contained in Section 62-296.500, F.A.C. As mentioned in Section 3.0 of this report, all of Hillsborough County is classified as an Air Quality Maintenance Area for ozone.

The Bayside Power Station will be located at the existing F.J. Gannon Station south of downtown Tampa in Hillsborough County and therefore is situated within the Hillsborough County ozone Air Quality Maintenance Area. Sections 62-296.501 through 62-296.516, F.A.C., specify VOC emission standards for 16 categories of sources; none of these categories are applicable to CTs. In addition, these VOC emission standards are not applicable to modified VOC-emitting sources, such as Bayside Units 1 and 2, which will be subject to 40 CFR 52.21 (i.e., PSD NSR). Accordingly, there are no ozone Air Quality Maintenance Area VOC emission limits which are applicable to Bayside Units 1 and 2.

Section 62-204.800, F.A.C., adopts federal NSPS and NESHAP, respectively, by reference. As noted previously, NSPS Subpart GG, *Stationary Gas Turbines* is applicable to the Bayside Unit 1 and 2 CTs. However, Subpart GG does not contain any VOC emission limitations. There are no applicable NESHAP requirements.

In summary, there are no federal or state VOC emission limitations applicable to Bayside Units 1 and 2.

4.3 BACT ANALYSIS FOR VOC

VOC emissions result from the incomplete combustion of carbon and organic compounds. Factors affecting VOC emissions include firing temperatures, residence time in

the combustion zone, and combustion chamber mixing characteristics. Because higher combustion temperatures will increase oxidation rates, emissions of VOCs will generally increase during turbine partial load conditions when combustion temperatures are lower. Decreased combustion zone temperature due to the injection of water or steam for NO_x control will also result in an increase in VOC emissions. An increase in combustion zone residence time and improved mixing of fuel and combustion air will increase oxidation rates and cause a decrease in VOC emission rates. Emissions of NO_x and VOC are inversely related; i.e., decreasing NO_x emissions will result in an increase in VOC emissions. Accordingly, combustion turbine vendors have had to consider the competing factors involved in NO_x and VOC formation in order to develop units which achieve acceptable emission levels for both pollutants.

4.3.1 POTENTIAL CONTROL TECHNOLOGIES

There are two available technologies for controlling VOCs from gas turbines and duct burners: (1) combustion process design and (2) oxidation catalysts.

Combustion Process Design

Combustion process controls involve combustion chamber designs and operation practices that improve the oxidation process and minimize incomplete combustion. Due to the high combustion efficiency of CTs, approximately 99 percent, VOC emissions are inherently low.

Oxidation Catalysts

Noble metal (commonly platinum or palladium) oxidation catalysts are used to promote oxidation of VOCs to carbon dioxide (CO₂) and water at temperatures lower than would be necessary for oxidation without a catalyst. The operating temperature range for oxidation catalysts is between 650 and 1,150°F.

Efficiency of VOC oxidation varies with inlet temperature. Control efficiency will increase with increasing temperature for VOCs up to a temperature of approximately 1,100°F; further temperature increases will have little effect on control efficiency. Temperatures on the order of 900°F are needed to oxidize VOCs. Inlet temperature must also

be maintained below 1,350 to 1,400°F to prevent thermal aging of the catalyst which will reduce catalyst activity and pollutant removal efficiencies. Removal efficiency will also vary with gas residence time which is a function of catalyst bed depth. Increasing bed depth will increase removal efficiencies but will also cause an increase in pressure drop across the catalyst bed. VOC removal efficiency will vary with the species of hydrocarbon. In general, unsaturated hydrocarbons such as ethylene are more reactive with oxidation catalysts than saturated species such as ethane. A typical VOC control efficiency range using an oxidation catalyst control system is 30- to 50-percent. However, CTs with low uncontrolled VOC emission rates, such as the GE 7FA units, will have VOC control efficiencies on the low end of this range.

Oxidation catalysts are susceptible to deactivation due to impurities present in the exhaust gas stream. Arsenic, iron, sodium, phosphorous, and silica will all act as catalyst poisons causing a reduction in catalyst activity and pollutant removal efficiencies.

Oxidation catalysts are nonselective and will oxidize other compounds in addition to VOCs. The nonselectivity of oxidation catalysts is important in assessing applicability to exhaust streams containing sulfur compounds. Sulfur compounds that have been oxidized to SO₂ in the combustion process will be further oxidized by the catalyst to sulfur trioxide (SO₃). SO₃ will, in turn, combine with moisture in the gas stream to form H₂SO₄ mist.

Technical Feasibility

Both CT combustor design and oxidation catalyst control systems are considered to be technically feasible for Bayside Units 1 and 2. Information regarding energy, environmental, and economic impacts and proposed BACT limits for VOC are provided in the following sections.

4.3.2 ENERGY AND ENVIRONMENTAL IMPACTS

There are no significant adverse energy or environmental impacts associated with the use of good combustor designs and operating practices to minimize VOC emissions.

The use of oxidation catalysts will, as previously noted, result in excessive H₂SO₄ mist emissions if applied to combustion devices fired with fuels containing sulfur. Increased H₂SO₄ mist emissions will also occur, on a smaller scale, from CTs fired with natural gas and low sulfur distillate fuel oil.

Because VOC emission rates from CTs are inherently low, further reductions through the use of oxidation catalysts will result in minimal air quality improvements; i.e., negligible reductions in ambient VOC/ozone levels. The location of Bayside Units 1 and 2 (Hillsborough County, Florida) is classified attainment for all criteria pollutants.

The application of oxidation catalyst technology to a gas turbine will result in an increase in back pressure on the CT due to a pressure drop across the catalyst bed. The increased back pressure will, in turn, constrain turbine output power thereby increasing the unit's heat rate. An oxidation catalyst system for the Bayside Units 1 and 2 CTs is projected to have a pressure drop across the catalyst bed of approximately 1.0 inch of water (H₂O). This pressure drop will result in a 0.2 percent energy penalty due to reduced turbine output power. The reduction in turbine output power (lost power generation) will result in an energy penalty of 2,908,320 kilowatt-hours (kwh) (9,924 MMBtu) per year at base load (166-MW) operation and 100 percent capacity factor per CT. This energy penalty is equivalent to the use of 66.2 million cubic feet (ft³) of natural gas annually based on a natural gas heating value of 1,050 British thermal units per cubic foot (Btu/ft³) for all seven CTs. The lost power generation energy penalty, based on a power cost of \$0.040/kwh, is \$814,330 per year for all seven CTs.

4.3.3 ECONOMIC IMPACTS

An economic evaluation of an oxidation catalyst system was performed using the OAQPS factors previously summarized in Table 4-1 and project-specific economic factors provided in Table 4-2. Specific capital and annual operating costs for the oxidation catalyst control system are summarized in Tables 4-3 and 4-4.

The base case Bayside Units 1 and 2 (i.e., for all seven CT/HRSG units) annual VOC emission rate is 99.6 tpy. The controlled annual VOC emission rate, based on a 33 percent

Table 4-2. Economic Cost Factors

Factor	Units	Value
Interest rate	%	9.55
Control system life	Years	15
Oxidation catalyst life	Years	5
Electricity cost	\$/kwh	0.040
Labor costs (base rates)	\$/hour	
Operator		22.00
Maintenance		22.00

Sources: ECT, 2000.
TEC, 2000.

Table 4-3. Capital Costs for Oxidation Catalyst System, Seven CTs

Item	Dollars	OAQPS Factor
<u>Direct Costs</u>		
Purchased equipment	4,474,120	A
Sales tax	268,447	0.06 x A
Freight	223,706	0.05 x A
Instrumentation	447,412	0.10 x A
Subtotal Purchased Equipment Cost	5,413,685	B
Installation		
Foundations and supports	433,095	0.08 x B
Handling and erection	757,916	0.14 x B
Electrical	216,547	0.04 x B
Piping	108,274	0.02 x B
Insulation for ductwork	54,137	0.01 x B
Painting	54,137	0.01 x B
Subtotal Installation Cost	1,624,106	
Subtotal Direct Costs	7,037,791	
<u>Indirect Costs</u>		
Engineering	541,369	0.10 x B
Construction and field expenses	270,684	0.05 x B
Contractor fees	541,369	0.10 x B
Startup	108,274	0.02 x B
Performance test	54,137	0.01 x B
Contingency	162,411	0.03 x B
Subtotal Indirect Costs	1,678,242	
TOTAL CAPITAL INVESTMENT	8,716,033	(TCI)

Source: Alstom Power Inc., 2000.
 ECT, 2000.
 S&L, 2000.

Table 4-4. Annual Operating Costs for Oxidation Catalyst System, Seven CTs

Item	Dollars	Basis
<u>Direct Costs</u>		
Catalyst costs		
Replacement (materials and labor)	4,326,191	
Credit for used catalyst	(583,622)	15% credit
Subtotal Catalyst Costs	3,742,570	
Annualized Catalyst Costs	975,956	5 yr @ 9.55%
Energy Penalties		
Turbine backpressure	814,330	0.2% penalty
Subtotal Direct Costs	1,790,286	(TDC)
<u>Indirect Costs</u>		
Administrative charges	174,321	0.02 x TCI
Property taxes	87,160	0.01 x TCI
Insurance	87,160	0.01 x TCI
Capital recovery	562,403	15 yr @ 9.55%
Subtotal Indirect Costs	911,045	
TOTAL ANNUAL COST	2,701,331	

Sources: Alstom Power Inc., 2000.
 ECT, 2000.
 S&L, 2000.
 TEC, 2000.

control efficiency, is 66.8tpy. Base case and controlled VOC emission rates are summarized in Table 4-5.

The cost effectiveness of oxidation catalyst for VOC emissions was determined to be \$82,150 per ton of VOC removed. Based on the high control costs, use of oxidation catalyst technology to control VOC emissions is not considered to be economically feasible. Results of the oxidation catalyst economic analysis are summarized in Table 4-5.

4.3.4 PROPOSED BACT EMISSION LIMITATIONS

The use of oxidation catalyst to control VOCs from CTs is typically required only for facilities located in ozone nonattainment areas. BACT VOC limits obtained from the RBLC database for natural gas- and distillate fuel oil-fired CTs are provided in Tables 4-6 and 4-7. A summary of recent FDEP VOC BACT determinations for natural gas and distillate fuel oil-fired combustion turbines is provided in Tables 4-8 and 4-9.

The use of oxidation catalysts will, as previously noted, result in excessive H₂SO₄ mist emissions if applied to combustion devices fired with fuels containing appreciable amounts of sulfur. Increased H₂SO₄ mist emissions will also occur, on a smaller scale, from CTs fired with natural gas and low sulfur distillate fuel oil. Because VOC emission rates from CTs are inherently low, further reductions through the use of oxidation catalysts will result in only minor improvement in air quality, i.e., negligible reductions in ambient VOC/ozone levels.

Use of state-of-the-art combustor design and good operating practices to minimize incomplete combustion are proposed as BACT for VOCs. These control techniques have been considered by FDEP to represent BACT for VOCs for all CT projects permitted within the past 5 years. Maximum natural gas and distillate fuel oil firing VOC exhaust concentrations from the CT/HRSG units will be less than or equal to 1.3 and 3.0 ppmvd at 15 percent oxygen, respectively. These VOC exhaust concentrations are consistent with recent FDEP VOC BACT determinations for CT/HRSG units; e.g., City of Tallahassee Purdom Unit 8 and Lakeland Utilities McIntosh Unit 5. VOC BACT emission limits proposed for Bayside Units 1 and 2 are provided in Table 4-10.

Table 4-5. Summary of VOC BACT Analysis

Control Option	Emission Impacts			Economic Impacts			Energy Impacts	Environmental Impacts	
	Emission Rates		Emission Reduction	Installed Capital Cost	Total Annualized Cost	Cost Effectiveness Over Baseline	Increase Over Baseline	Toxic Impact	Adverse Envir. Impact
	(lb/hr)	(tpy)	(tpy)	(\$)	(\$/yr)	(\$/ton)	(MMBtu/yr)	(Y/N)	(Y/N)
Oxidation catalyst	15.3	66.8	32.9	8,716,033	2,701,331	82,150	69,465	N	Y
Baseline	22.7	99.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Basis: Seven GE PG7241 (FA) CTs, 100-percent load, natural gas-firing for 7,884 hr/yr, and fuel oil-firing for 876 hr/yr.

Sources: ECT, 2000.
 GE, 2000.
 TEC, 2000

Table 4-6. RBLC VOC Summary for Natural Gas Fired CTs

RBLC ID	Facility Name	City	Permit Dates Issuance Update	Process Description	Thruput Rate	Emission Limit	Control System Description	Basis	
AL-0128	ALABAMA POWER COMPANY - THEODORE COGENERATION	THEODORE	03/16/1999	06/23/1999	TURBINE, WITH DUCT BURNER	170.0 MW	0.016 LB/MMBTU	EFFICIENT COMBUSTION	BACT-PSD
CA-0768	NORTHERN CALIFORNIA POWER AGENCY	LODI	10/02/1997	03/16/1998	GE FRAME 5 GAS TURBINE	325.0 MMBTU/HR	8.0 LB/HR	NATURAL GAS AS PRIMARY FUEL	LAER
CA-0810	SACRAMENTO COGENERATION AUTHORITY P&G	SACRAMENTO	08/19/1994	08/31/1999	TURBINE, GAS, COMBINED CYCLE LM6000	421.4 MMBTU/HR	1.1 LB/H	OXIDATION CATALYST	BACT
CA-0810	SACRAMENTO COGENERATION AUTHORITY P&G	SACRAMENTO	08/19/1994	08/31/1999	TURBINE, GAS, COMBINED CYCLE LM6000	421.4 MMBTU/HR	1.1 LB/H	OXIDATION CATALYST	BACT
CA-0810	SACRAMENTO COGENERATION AUTHORITY P&G	SACRAMENTO	08/19/1994	08/31/1999	TURBINE, SIMPLE CYCLE LM6000 GAS	421.4 MMBTU/HR	1.1 LB/H	OXIDATION CATALYST	BACT
CA-0813	SEPCO	RIO LINDA	10/05/1994	08/31/1999	TURBINE, GAS COMBINED CYCLE GE MODEL 7	920.0 MMBTU/HR	3.7 LB/H	OXIDATION CATALYST	BACT
CA-0853	KERN FRONT LIMITED	BAKERSFIELD	11/04/1995	08/05/1999	TURBINE, GAS, GENERAL ELECTRIC L4-2500	25.0 MW	3.12 LB/H	OXIDATION CATALYST, VOC IS SHOWN AS CH4	BACT-OTHER
CA-0855	CROCKETT COGENERATION - C&H SUGAR	CROCKETT	10/05/1993	04/19/1999	TURBINE, GAS, GENERAL ELECTRIC MODEL PG7221FAI	240.0 MW	35.6 LB/O	ENGELHARD OXIDATION CATALYST	BACT-OTHER
CA-0858	BEAR MOUNTAIN LIMITED	BAKERSFIELD	08/19/1994	09/28/1999	TURBINE, GE COGENERATION, 48 MW	48.0 MW	0.6 PPMVD @ 15% O2	OXIDATION CATALYST	BACT-OTHER
CO-0017	THERMO INDUSTRIES, LTD.	FT. LUPTON	02/19/1992	03/24/1995	TURBINE, GAS FIRED, 5 EACH	246.0 MMBTU/HR	16.7 LB/H		OTHER
CO-0018	BRUSH COGENERATION PARTNERSHIP	BRUSH	07/20/1994		TURBINE	350.0 MMBTU/HR	26.7 T/YR		OTHER
CO-0019	COLORADO POWER PARTNERSHIP	BRUSH	07/20/1994		TURBINES, 2 NAT GAS & 2 DUCT BURNERS	385.0 MMBTU/HR EACH TURBINE	35.2 T/YR		OTHER
CO-0024	PUBLIC SERVICE OF COLO.-FORT ST VRAIN	PLATTEVILLE	05/01/1996	05/19/1998	COMBINED CYCLE TURBINES (2), NATURAL	471.0 MW	1.4 PPMVD, SMPL CY	GOOD COMBUSTION CONTROL PRACTICES.	BACT-PSD
CT-0073	PRATT & WHITNEY, UTC	MIDDLETOWN	07/07/1989	04/30/1990	ENGINE, GAS TURBINE	238.0 MMBTU/HR	0.014 LB/MMBTU		BACT-PSD
CT-0139	POC EL PASO MILFORD LLC	MILFORD	04/16/1999	08/17/1999	TURBINE, COMBUSTION, ABB GT-24: #1 WITH 2 CHILLERS	2.0 MMBTU/HR	3.0 LB/NAT GAS	COMBUSTION CONTROLS	BACT-PSD
CT-0140	POC EL PASO MILFORD LLC	MILFORD	04/16/1999	08/17/1999	TURBINE, COMBUSTION, ABB GT-24E #2 WITH 2 CHILLERS	2.0 MMBTU/HR	3.0 LB/NAT GAS	COMBUSTION CONTROLS	BACT-PSD
FL-0042	ORLANDO UTILITIES COMMISSION	TITUSVILLE	09/01/1988	05/14/1993	TURBINE, 2 EA.	35.0 MW	7.0 PPM @ 15% O2	COMBUSTION CONTROL	BACT-PSD
FL-0052	FLORIDA POWER AND LIGHT	NORTH PALM BEACH	06/05/1991	03/24/1995	TURBINE, GAS, 4 EACH	400.0 MW	1.6 PPM @ 15% O2	COMBUSTION CONTROL	BACT-PSD
FL-0052	FLORIDA POWER AND LIGHT	NORTH PALM BEACH	06/05/1991	03/24/1995	TURBINE, CG, 4 EACH	400.0 MW	9.0 PPM @ 15% O2	COMBUSTION CONTROL	BACT-PSD
FL-0053	FLORIDA POWER AND LIGHT	LAVOGRME REPOWERING S	03/14/1991	03/24/1995	TURBINE, GAS, 4 EACH	240.0 MW	1.0 PPM @ 15% O2	COMBUSTION CONTROL	BACT-PSD
FL-0056	ORLANDO UTILITIES COMMISSION	TITUSVILLE	11/05/1991	05/14/1993	TURBINE, GAS, 4 EACH	35.0 MW	7.0 PPM @ 15% O2	COMBUSTION CONTROL	BACT-PSD
FL-0068	ORANGE COGENERATION LP	BARTOW	12/30/1993	01/31/1995	TURBINE, NATURAL GAS, 2	368.3 MMBTU/HR	10.0 PPM	GOOD COMBUSTION	BACT-PSD
FL-0089	FLORIDA POWER CORPORATION PARTNERS, LP	JURUBONDALE	12/14/1992	01/13/1995	TURBINE, GAS	1,212.0 MMBTU/HR	8.0 LB/H	GOOD COMBUSTION PRACTICES	BACT-PSD
FL-0089	FLORIDA POWER CORPORATION PARTNERS, LP	BARTOW	02/25/1994	01/13/1995	TURBINE, NATURAL GAS (2)	1,510.0 MMBTU/HR	7.0 PPMVW	GOOD COMBUSTION PRACTICES	BACT-PSD
GA-0052	SAVANNAH ELECTRIC AND POWER CO.		02/12/1992	03/24/1995	TURBINES, 8	1,032.0 MMBTU/HR, NAT. GAS	0.003 LB/MMBTU	FUEL SPEC: LOW SULFUR FUEL OIL	BACT-PSD
GA-0083	MID-GEORGIA COGEN.	KATHLEEN	04/03/1996	08/19/1996	COMBUSTION TURBINE (2), NATURAL GAS	116.0 MW	8.0 PPMVD	COMPLETE COMBUSTION	BACT-PSD
GA-0069	TENUSKA GEORGIA PARTNERS, L.P.	FRANKLIN	12/18/1998	06/23/1999	TURBINE, COMBUSTION, SIMPLE CYCLE, 6	160.0 MW EA	0.0055 LB/MMBTU	VOC EMISSION IS BECAUSE OF NO.2 FUEL OIL	BACT-PSD
GA-0069	TENUSKA GEORGIA PARTNERS, L.P.	FRANKLIN	12/18/1998	06/23/1999	TURBINE, COMBUSTION, SIMPLE CYCLE, 6	160.0 MW EA	0.03 LB/MMBTU	VOC EMISSION IS BECAUSE OF NATURAL GAS.	BACT-PSD
LA-0086	INTERNATIONAL PAPER	MANSPIELD	02/24/1994	04/17/1995	TURBINE/HSG, GAS COGEN	339.0 MM BTU/HR TURBINE	3.6 LB/HR COMBINED	COMBUSTION CONTROLS, FUEL SELECTION	BACT-PSD
MA-0023	DIGTON POWER ASSOCIATE, LP	DIGTON	10/06/1997	04/19/1999	TURBINE, COMBUSTION, ABB GT11W2	1,327.0 MMBTU/HR	5.1 LB/H	DRY LOW NOX COMBUSTION TECHNOLOGY WITH SCR.	BACT-PSD
ME-0018	WESTBROOK POWER LLC	WESTBROOK	12/04/1998	04/19/1999	TURBINE, COMBINED CYCLE, TWO	528.0 MW TOTAL	0.4 PPM @ 15% O2		BACT-PSD
ME-0019	CHAMPION INTERNATL CORP. & CHAMP. CLEAN ENERGY	BUCKSPORT	09/14/1998	04/19/1999	TURBINE, COMBINED CYCLE, NATURAL GAS	175.0 MW	3.0 LB/N GAS		BACT-OTHER
ME-0020	CASCO RAY ENERGY CO.	VEAZIE	07/13/1998	04/19/1999	TURBINE, COMBINED CYCLE, NATURAL GAS, TWO	170.0 MW EACH	1.0 PPM	LOW NOX BURNER	BACT-PSD
NC-0055	DUKE POWER CO. LINCOLN COMBUSTION TURBINE STATION	LOWESVILLE	12/20/1991	03/24/1995	TURBINE, COMBUSTION	1,313.0 MM BTU/HR	2.0 LB/HR	COMBUSTION CONTROL	BACT-PSD
NJ-0013	LAKEWOOD COGENERATION, L.P.	LAKEWOOD TOWNSHIP	04/01/1991	05/29/1995	TURBINES (NATURAL GAS) (2)	1,190.0 MMBTU/HR (EACH)	0.0046 LB/MMBTU	TURBINE DESIGN	OTHER
NJ-0017	NEWARK BAY COGENERATION PARTNERSHIP, L.P.	NEWARK	06/09/1993	05/29/1995	TURBINES, COMBUSTION, NATURAL GAS-FIRED (2)	617.0 MMBTU/HR (EACH)	4.0 PPMVD	TURBINE DESIGN	BACT-PSD
NM-0021	WILLIAMS FIELD SERVICES CO. - EL CEDRO COMPRESSOR	BLANCO	10/29/1993	03/02/1994	TURBINE, GAS-FIRED	11,257.0 HP	25.0 PPM @ 15% O2	COMBUSTION CONTROL	BACT-PSD
NM-0028	SOUTHWESTERN PUBLIC SERVICE CO/CUNNINGHAM STATION	HOBBS	11/04/1996	12/30/1996	COMBUSTION TURBINE, NATURAL GAS	100.0 MW	0	SEE P2	BACT-PSD
NM-0029	SOUTHWESTERN PUBLIC SERVICE COMPANY/CUNNINGHAM STA.	HOBBS	02/15/1997	03/31/1997	COMBUSTION TURBINE, NATURAL GAS	100.0 MW	0	GOOD COMBUSTION PRACTICES	BACT-PSD
NY-0038	ONEIDA COGENERATION FACILITY	ONEIDA	02/26/1990	05/18/1990	TURBINE, GE FRAME 6	417.0 MMBTU/HR	0.013 LB/MMBTU	COMBUSTION CDNTROL	OTHER
NY-0038	EMPIRE ENERGY - NIAGARA COGENERATION CO.	LOCKPORT	05/02/1989	05/18/1990	TURBINE, GR FRAME 6, 3 EA.	416.0 MMBTU/HR	0.012 LB/MMBTU	COMBUSTION CONTROL	BACT-PSD
NY-0039	FULTON COGENERATION ASSOCIATES	FULTON	01/29/1990	05/18/1990	TURBINE, GE LM5000, GAS FIRED	500.0 MMBTU/HR	5.0 LB/H	COMBUSTION CONTROL	BACT-PSD
NY-0040	JMC SELKIRK, INC.	SELKIRK	11/27/1989	05/18/1990	TURBINE, GE FRAME 7, GAS FIRED	80.0 MW	7.0 PPM	COMBUSTION CONTROL	BACT-PSD
NY-0046	SARANAC ENERGY COMPANY	PLATTSBURGH	07/31/1992	09/13/1994	TURBINES, COMBUSTION (2) (NATURAL GAS)	1,123.0 MMBTU/HR (EACH)	0.0045 LB/MMBTU	OXIDATION CATALYST	BACT-OTHER
OH-0218	CNG TRANSMISSION	WASHINGTON COURT HOUSE	06/12/1992	04/05/1995	TURBINE (NATURAL GAS) (3)	5,500.0 HP (EACH)	0.1 G/HP-HR	FUEL SPEC: USE OF NATURAL GAS	OTHER
PA-0083	NORTHERN CONSOLIDATED POWER	NORTH EAST	05/03/1991	07/20/1994	TURBINES, GAS, 2	34.6 KW EACH	105 PPM @ 15% O2	OXIDATION CATALYST	OTHER
PA-0099	FLEETWOOD COGENERATION ASSOCIATES	FLEETWOOD	04/22/1994	11/22/1994	NG-TURBINE (GE LM6000) WITH WASTE HEAT BOILER	360.0 MMBTU/HR	4.4 LB/HR	GOOD COMBUSTION PRACTICES	BACT-OTHER
PA-0148	BLUE MOUNTAIN POWER, LP	RICHLAND	07/31/1996	01/12/1999	COMBUSTION TURBINE WITH HEAT RECOVERY BOILER	153.0 MW	4.0 PPM @ 15% O2	OXIDATION CATALYST, OIL LIMIT = 4.4 PPMVD @ 15% O2	LAER
PA-0149	BUCKNELL UNIVERSITY	LEWISBURG	11/28/1997	11/30/1997	NG FIRED TURBINE, SOLAR-TAURUS T-7300S	5.0 MW	25.0 PPMV@15%O2	GOOD COMBUSTION	BACT-OTHER
PR-0004	ECOLELECTRICA, L.P.	PENUELAS	10/01/1998	05/06/1998	TURBINES, COMBINED-CYCLE COGENERATION	461.0 MW	5.0 PPMVD	COMBUSTION CONTROLS.	BACT-PSD
RI-0008	PANTUCKET POWER	PANTUCKET	01/30/1989	03/31/1991	TURBINE/DUCT BURNER	533.0 MMBTU/HR	19.0 PPM @ 15% O2, GAS		BACT-PSD
RI-0010	NARRAGANSETT ELECTRIC/NEW ENGLAND POWER CO.	PROVIDENCE	04/13/1992	05/31/1992	TURBINE, GAS AND DUCT BURNER	1,360.0 MMBTU/HR EACH	5.0 PPM @ 15% O2		BACT-PSD
RI-0012	ALGONQUIN GAS TRANSMISSION CO.	BURRILLVILLE	07/31/1991	05/31/1992	TURBINE, GAS, 2	49.0 MMBTU/HR	0.016 LB/MMBTU	GOOD COMBUSTION PRACTICES	BACT-OTHER
RI-0018	TIVERTON POWER ASSOCIATES	TIVERTON	02/13/1998	02/08/1999	COMBUSTION TURBINE, NATURAL GAS	285.0 MW	2.0 PPM @ 15% O2	GOOD COMBUSTION	BACT-PSD
SC-0029	SC ELECTRIC AND GAS COMPANY - HAGOOD STATION	CHARLESTON	12/11/1989	03/24/1995	INTERNAL COMBUSTION TURBINE	110.0 MEGAWATTS	10.0 LBS/HR	GOOD COMBUSTION PRACTICES	BACT-PSD
SC-0031	BMW MANUFACTURING CORPORATION	GREER	01/07/1994	08/12/1996	TURBINE, NAT. GAS FIRED (3 - 1 SPARE) AND 2 BOILERS	54.5 MM BTU/HR TURBINES	77.86 LBS/DAY	EACH OF THE 2 BOILER-TURBINE USE A COMMON STACK	LAER
TX-0231	WEST CAMPUS COGENERATION COMPANY	COLLEGE STATION	05/02/1994	10/31/1994	GAS TURBINES	75.3 MW (TOTAL POWER)	38.0 T/YR	INTERNAL COMBUSTION CONTROLS	BACT-PSD
VA-0163	VIRGINIA POWER		09/07/1989	04/30/1990	TURBINE, GAS	1,308.0 MMBTU/HR	2.0 LB/HUNIT NAT GAS FI		BACT-PSD
VA-0177	DOEWEILL LIMITED PARTNERSHIP		05/04/1990	03/24/1995	TURBINE, COMBUSTION	1,261.0 MMBTU/HR	4.0 LB/H	COMBUSTOR DESIGN & OPERATION, GAS	OTHER
VA-0179	COMMONWEALTH GAS PIPELINE CORPORATION	LOUISA STATION	08/17/1990	03/24/1995	SOLAR SATURN T-1300.3	14,400.0 CFH	2.1 LB/H		BACT-PSD
VA-0180	COMMONWEALTH GAS PIPELINE CORPORATION	GOOCHLAND	09/30/1990	03/24/1995	TURBINES, GAS FIRED, SINGLE CYCLE, 5	14.5 MMBTU/HR EACH	0	EQUIPMENT DESIGN & OPERATION	BACT-PSD

Source: RBLC 2000.

MAXIMUM	105.0 PPM @ 15% O2
MINIMUM	0.4 PPM @ 15% O2
AVERAGE	11.5 PPM @ 15% O2

Table 4-7. RBLC VOC Summary for Fuel Oil Fired CTs

RBLC ID	Facility Name	City	Permit Dates		Process Description	Throughput	Emission Limit	Control System Description	Basis
			Issuance	Update					
AL-0126	MOBILE ENERGY LLC	MOBILE	01/05/1999	04/09/1999	TURBINE, GAS, COMBINED CYCLE	168.0 MW	0.006 LB/MMBTU	3 DEGREE TIMING RETARD	BACT-PSD
FL-0052	FLORIDA POWER AND LIGHT	NORTH PALM BEACH	06/05/1991	03/24/1995	TURBINE, GAS, 4 EACH	400.0 MW	1.6 PPMVD @ 15% O2		BACT-PSD
FL-0052	FLORIDA POWER AND LIGHT	NORTH PALM BEACH	06/05/1991	03/24/1995	TURBINE, OIL, 2 EACH	400.0 MW	6.0 PPMVD @ 15% O2	COMBUSTION CONTROL	BACT-PSD
FL-0052	FLORIDA POWER AND LIGHT	NORTH PALM BEACH	06/05/1991	03/24/1995	TURBINE, CG, 4 EACH	400.0 MW	3.0 PPMVD @ 15% O2	COMBUSTION CONTROL	BACT-PSD
FL-0053	FLORIDA POWER AND LIGHT	LAVOGROME REPOWERING ST	03/14/1991	03/24/1995	TURBINE, GAS, 4 EACH	240.0 MW	1.0 PPMVD @ 15% O2	COMBUSTION CONTROL	BACT-PSD
FL-0053	FLORIDA POWER AND LIGHT	LAVOGROME REPOWERING ST	03/14/1991	03/24/1995	TURBINE, OIL, 4 EACH	0.0	6.0 PPMVD @ 15% O2	COMBUSTION CONTROL	BACT-PSD
FL-0056	ORLANDO UTILITIES COMMISSION	TITUSVILLE	11/05/1991	05/14/1993	TURBINE, GAS, 4 EACH	35.0 MW	7.0 PPMVD @ 15% O2	COMBUSTION CONTROL	BACT-PSD
FL-0056	ORLANDO UTILITIES COMMISSION	TITUSVILLE	11/05/1991	05/14/1993	TURBINE, OIL, 4 EACH	35.0 MW	7.0 PPMVD @ 15% O2	COMBUSTION CONTROL	BACT-PSD
FL-0057	FLORIDA POWER GENERATION	DEBARY	10/18/1991	03/24/1995	TURBINE, OIL, 6 EACH	92.9 MW	5.0 LB/H	COMBUSTION CONTROL	BACT-PSD
FL-0080	AUBURNDALE POWER PARTNERS, LP	AUBURNDALE	12/14/1992	01/13/1995	TURBINE, GAS	1,214.0 MMBTU/H	6.0 LB/H	COMBUSTION CONTROL	BACT-PSD
FL-0080	AUBURNDALE POWER PARTNERS, LP	AUBURNDALE	12/14/1992	01/13/1995	TURBINE, OIL	1,170.0 MMBTU/H	10.0 LB/H	GOOD COMBUSTION PRACTICES	BACT-PSD
FL-0081	TECO POLK POWER STATION	BARTOW	02/24/1994	03/24/1995	TURBINE, FUEL OIL	1,765.0 MMBTU/H	0.028 LB/MMBTU	GOOD COMBUSTION	BACT-PSD
FL-0082	FLORIDA POWER CORPORATION POLK COUNTY SITE	BARTOW	02/25/1994	01/13/1995	TURBINE, FUEL OIL (2)	1,730.0 MMBTU/H	7.0 PPMVW	GOOD COMBUSTION PRACTICES	BACT-PSD
FL-0083	FLORIDA POWER CORPORATION	INTERCESSION CITY	08/17/1992	01/13/1995	TURBINE, OIL	1,029.0 MMBTU/H	5.0 LB/H	GOOD COMBUSTION PRACTICES	BACT-PSD
FL-0083	FLORIDA POWER CORPORATION	INTERCESSION CITY	08/17/1992	01/13/1995	TURBINE, OIL	1,866.0 MMBTU/H	9.0 LB/H	GOOD COMBUSTION PRACTICES	BACT-PSD
GA-0052	SAVANNAH ELECTRIC AND POWER CO.		02/12/1992	03/24/1995	TURBINES, B	1,032.0 MMBTU/H, NAT GAS	0.003 LB/MMBTU	GOOD COMBUSTION PRACTICES	BACT-PSD
GA-0052	SAVANNAH ELECTRIC AND POWER CO.		02/12/1992	03/24/1995	TURBINES, B	972.0 MMBTU/H, #2 OIL	0.0042 LB/MMBTU	FUEL SPEC: LOW SULFUR FUEL OIL	BACT-PSD
GA-0063	MID-GEOORGIA COGEN.	KATHLEEN	04/03/1996	08/19/1996	COMBUSTION TURBINE (2), FUEL OIL	116.0 MW	20.0 PPMVD @ 15% O2	COMPLETE COMBUSTION	BACT-PSD
HI-0010	KALAELOE PARTNERS, LP		03/09/1990	03/16/1994	TURBINE, LSFO, 2	1,800.0 MMBTU/H, TOTAL	1.0 PPM AT > 80% LOAD	COMPLETE COMBUSTION	BACT-PSD
HI-0014	HAWAII ELECTRIC LIGHT CO., INC.	KEEAU	02/12/1992	03/24/1995	TURBINE, FUEL OIL #2	20.0 MW	297.6 LB/H @ 25 < 50% PKLD	COMBUSTION DESIGN	BACT-PSD
HI-0014	HAWAII ELECTRIC LIGHT CO., INC.	KEEAU	02/12/1992	03/24/1995	TURBINE, FUEL OIL #2	20.0 MW	28.1 LB/H @ 50 < 75% PKLD	COMBUSTION DESIGN	BACT-PSD
HI-0014	HAWAII ELECTRIC LIGHT CO., INC.	KEEAU	02/12/1992	03/24/1995	TURBINE, FUEL OIL #2	20.0 MW	2.6 LB/H @ 75 < 100% PKLD	COMBUSTION DESIGN	BACT-PSD
HI-0014	HAWAII ELECTRIC LIGHT CO., INC.	KEEAU	02/12/1992	03/24/1995	TURBINE, FUEL OIL #2	20.0 MW	0.8 LB/H @ 100% PEAKLD	GOOD COMBUSTION PRACTICES	BACT-PSD
HI-0015	MAUI ELECTRIC COMPANY, LTD, MAALAEA GENERATING STA	MAUI	07/28/1992	03/24/1995	TURBINE, COMBINED-CYCLE COMBUSTION	28.0 MW	0.8 LB/H	COMBUSTION DESIGN	BACT-OTHER
HI-0019	MAUI ELECTRIC COMPANY	MAALAEA	01/06/1998	06/08/1999	TURBINE, COMBUSTION, 2 EA	20.0 MW	10.0 PPMVD @ 15% O2	COMBUSTION DESIGN, INCLUDING FITR	BACT-PSD
HI-0020	HAWAII ELECTRIC LIGHT CO.	KEAHOLE	10/28/1997	06/08/1999	TURBINE, COMBUSTION, GELM 2500, 2 EA	20.0 MW	2.5 PPMVD @ 15% O2	GOOD COMBUSTION DESIGN AND OPERATION	BACT-PSD
MA-0023	DIGHTON POWER ASSOCIATE, LP	DIGHTON	10/06/1997	04/19/1999	TURBINE, COMBUSTION, ABB GT11N2	1,327.0 MMBTU/H	5.1 LB/H	DRY, LOW NOX COMBUSTION TECHNOLOGY WITH SCR	BACT-PSD
NC-0055	DUKE POWER CO, LINCOLN COMBUSTION TURBINE STATION	LOWESVILLE	12/20/1991	03/24/1995	TURBINE, COMBUSTION	1,313.0 MM BTU/H	2.0 LB/H	COMBUSTION CONTROL	BACT-PSD
NC-0055	DUKE POWER CO, LINCOLN COMBUSTION TURBINE STATION	LOWESVILLE	12/20/1991	03/24/1995	TURBINE, COMBUSTION	1,247.0 MM BTU/H	5.0 LB/H	LIMITED TO BURN DIESEL 150 HHR	BACT-PSD
NJ-0013	LAKWOOD COGENERATION, LP	LAKWOOD TOWNSHIP	04/01/1991	05/29/1995	TURBINES (42 FUEL OIL) (2)	1,190.0 MMBTU/H (EACH)	0.0073 LB/MMBTU	TURBINE DESIGN	OTHER
NJ-0029	ALGDONQUI GAS TRANSMISSION COMPANY	HANOVER	03/31/1995	02/10/1999	TURBINES COMBUSTION, TWO SOLAR CENTAUR	3.1 MW EACH	0.26 LB/H	BOILER DESIGN	BACT-PSD
NY-0072	KAMINE/BESCORP SYRACUSE LP	SOLVAY	12/10/1994	04/27/1995	SIEMENS V64.3 GAS TURBINE (EP #00001)	850.0 MMBTU/H	0.007 LB/MMBTU, 4.6 LB/H		BACT-OTHER
PR-0002	PUERTO RICO ELECTRIC POWER AUTHORITY (PREPA)	ARECIBO	07/31/1995	05/06/1998	COMBUSTION TURBINES (3), 83 MW SIMPLE-CYCLE EACH	248.0 MW	11.0 LB/H (AS METHANE)	IMPLEMENT GOOD COMBUSTION PRACTICES	BACT-PSD
PR-0002	PUERTO RICO ELECTRIC POWER AUTHORITY (PREPA)	ARECIBO	07/31/1995	05/06/1998	COMBUSTION TURBINES (3), 83 MW SIMPLE-CYCLE EACH	248.0 MW	13.0 LB/H (AS METHANE)	SCR	BACT-PSD

Source: RBLC 2000.

MAXIMUM	30.0 PPMVD @ 15% O2
MINIMUM	1.0 PPMVD @ 15% O2
AVERAGE	7.4 PPMVD @ 15% O2

Table 4-8 Florida BACT VOC Summary—Natural Gas-Fired CTGs

Permit Date	Source Name	Turbine Size (MW)	VOC Emission Limit (ppmvw)	Control Technology
03/07/95	Orange Cogeneration, L.P.	39	10.0	Good combustion
07/10/98	City of Lakeland McIntosh Unit 5	250	4.0	Good combustion
09/29/98	Florida Power Corporation Hines Energy Complex	165	7.0	Good combustion
11/25/98	Florida Power & Light Fort Myers Repowering	170	1.4	Good combustion
12/04/98	Santa Rosa Energy, LLC	167	1.4	Good combustion
10/8/99	Tampa Electric Company – Polk Power Station	165	1.4	Good combustion
7/23/99	Seminole Electric Cooperative, Inc., Payne Creek	158	5.0	Good combustion
10/18/99	Vandolah Power Project	170	1.4	Good combustion
12/28/99	Osceola Power Project	170	3.7	Good combustion
1/13/00	Shady Hills Generating Station	170	1.4	Good combustion
2/00	Kissimmee Utility – Cane Island Unit 3	167	1.4	Good combustion
2/22/00	Reliant Energy Osceola	170	1.5	Good combustion
2/24/00	Gainesville Regional Utilities	83	1.4	Good combustion
5/11/00	Calpine Osprey (Draft)	170	2.3	Good combustion
7/31/00	Gulf Power – Smith Unit 3	170	4.0	Good combustion

Source: FDEP, 2000.

4-15

Table 4-9 Florida BACT VOC Summary—Distillate Fuel Oil-Fired CTGs

Permit Date	Source Name	Turbine Size (MW)	VOC Emission Limit (ppmvw)	Control Technology
02/21/94	Polk Power Partners	126	10.0	Good combustion
07/10/98	City of Lakeland McIntosh Unit 5	250	10.0	Good combustion
09/29/98	Florida Power Corporation Hines Energy Complex	165	7.0	Good combustion
10/8/99	Tampa Electric Company – Polk Power Station	165	7.0	Good combustion
6/16/99	Hardee Power Partners – Hardee Power Station	165	4.0	Good combustion
7/23/99	Seminole Electric Cooperative, Inc., Payne Creek	158	10.0	Good combustion
10/18/99	Vandolah Power Project	170	7.0	Good combustion
12/28/99	Osceola Power Project	170	3.7	Good combustion
1/13/00	Shady Hills Generating Station	170	7.0	Good combustion
2/1/00	Kissimmee Utility – Cane Island Unit 3	167	10.0	Good combustion
2/22/00	Reliant Energy Osceola	170	3.7	Good combustion
2/24/00	Gainesville Regional Utilities	83	3.5	Good combustion
8/7/00	Granite Power Partners	170	7.5	Good combustion

Source: FDEP, 2000.

Table 4-10. Proposed VOC BACT Emission Limits

Emission Source	<u>Proposed VOC BACT Emission Limits</u>	
	ppmvd at 15 percent oxygen	lb/hr
GE PG7241 (FA) CT/HRSGs (Per CT/HRSG Unit)		
VOC (Natural Gas)	1.3	3.0
VOC (Distillate Fuel Oil)	3.0	7.8

Sources: ECT, 2000.
 S&L, 2000.
 TEC, 2000.

5.0 AMBIENT IMPACT ANALYSIS METHODOLOGY

5.1 GENERAL APPROACH

The approach used to analyze the potential impacts of the proposed facility, as described in detail in the following sections, was developed in accordance with accepted practice. Guidance contained in EPA manuals and user's guides was sought and followed.

5.2 POLLUTANTS EVALUATED

Based on an evaluation of anticipated worst-case annual operating scenarios, Bayside Units 1 and 2 will have the potential to emit 1,018.2 tpy of NO_x, 989.7 tpy of CO, 721.4 tpy of PM/PM₁₀, 576.3 tpy of SO₂, 99.6 tpy of VOCs, and 96.7 tpy of H₂SO₄ mist. Table 3-2 previously provided estimated potential annual emission rates increases for the F.J. Gannon Units 5 and 6 repowering project. As shown in that table, potential emission increases of all PSD regulated pollutants will be below the applicable PSD significant emission rate levels, with the exception of VOC/ozone. Ozone is formed in the atmosphere as a result of complex photochemical reactions. Ambient air quality assessments for ozone are performed using sophisticated photochemical pollutant dispersion models on a regional scale. Accordingly, Bayside Units 1 and 2 are not subject to the PSD NSR air quality impact analysis requirements of Rule 62-212.400(5)(d), F.A.C. In response to a request from the FDEP, an air quality impact analysis for Bayside Units 1 and 2 was nevertheless conducted for NO₂, CO, SO₂, and PM/PM₁₀.

5.3 MODEL SELECTION AND USE

For this study, air quality modeling was applied at the refined level. Refined modeling requires more detailed and precise input data than screening modeling, but is presumed to have provided more accurate estimates of source impacts.

The most recent regulatory version of the ISC3 models (EPA, 2000) is recommended and was used in this analysis for refined modeling. The ISC3 models are steady-state Gaussian plume models that can be used to assess air quality impacts over simple terrain from a wide variety of sources. The ISC3 models are capable of calculating concentrations for averaging times ranging from 1 hour to annual. For this study, the ISC3 short-term

(ISCST3) (Version 00101) model was used to calculate short-term ambient impacts with averaging times between 1 and 24 hours as well as long-term annual averages.

Procedures applicable to the ISCST3 dispersion model specified in EPA's Guideline for Air Quality Models (GAQM) were followed in conducting the refined dispersion modeling. The GAQM is codified in Appendix W of 40 CFR 51. In particular, the ISCST3 model control pathway MODELOPT keyword parameters DFAULT, CONC, RURAL, and NOCMPL were selected. Selection of the parameter DFAULT, which specifies use of the regulatory default options, is recommended by the GAQM. The CONC, RURAL, and NOCMPL parameters specify calculation of concentrations, use of rural dispersion, and suppression of complex terrain calculations, respectively. As previously mentioned, the ISCST3 model was also used to determine annual average impact predictions, in addition to short-term averages, by using the PERIOD parameter for the AVERTIME keyword. Conservatively, no consideration was given to pollutant exponential decay.

5.4 NO₂ AMBIENT IMPACT ANALYSIS

For annual NO₂ impacts, the tiered screening approach described in the GAQM, Section 6.2.3 was used. Tier 1 of this screening procedure assumes complete conversion of NO_x to NO₂. Tier 2 applies an empirically derived NO₂/NO_x ratio of 0.75 to the Tier 1 results.

5.5 DISPERSION OPTION SELECTION

Area characteristics in the vicinity of proposed emission sources are important in determining model selection and use. One important consideration is whether the area is rural or urban since dispersion rates differ between these two classifications. In general, urban areas cause greater rates of dispersion because of increased turbulent mixing and buoyancy-induced mixing. This is due to the combination of greater surface roughness caused by more buildings and structures and greater amount of heat released from concrete and similar surfaces. EPA guidance provides two procedures to determine whether the character of an area is predominantly urban or rural. One procedure is based on land use typing, and the other is based on population density. The land use typing method uses the work of Auer (Auer, 1978) and is preferred by EPA and FDEP because it is meteorologi-

cally oriented. In other words, the land use factors employed in making a rural/urban designation are also factors that have a direct effect on atmospheric dispersion. These factors include building types, extent of vegetated surface area and water surface area, types of industry and commerce, etc. Auer recommends these land use factors be considered within 3 km of the source to be modeled to determine urban or rural classifications. The Auer land use typing method was used for the ambient impact analysis.

The Auer technique recognizes four primary land use types: industrial (I), commercial (C), residential (R), and agricultural (A). Practically all industrial and commercial areas come under the heading of urban, while the agricultural areas are considered rural. However, those portions of generally industrial and commercial areas that are heavily vegetated can be considered rural in character. In the case of residential areas, the delineation between urban and rural is not as clear. For residential areas, Auer subdivides this land use type into four groupings based on building structures and associated vegetation. Accurate classification of the residential areas into proper groupings is important to determine the most appropriate land use classification for the study area.

USGS 7.5-minute series topographic maps for the area were used to identify the land use types within a 3-km radius area of the proposed site. Based on this analysis, more than 50-percent of the land use surrounding the plant was determined to be rural under the Auer land use classification technique. Therefore, rural dispersion coefficients and mixing heights were used for the ambient impact analysis.

5.6 TERRAIN CONSIDERATION

The GAQM defines flat terrain as terrain equal to the elevation of the stack base, simple terrain as terrain lower than the height of the stack top, and complex terrain as terrain above the height of the plume center line (for screening modeling, complex terrain is terrain above the height of the stack top). Terrain above the height of the stack top, but below the height of the plume center line, is defined as intermediate terrain.

USGS 7.5-minute series topographic maps were examined for terrain features in the vicinity of the Bayside Power Station (i.e., within an approximate 10-km radius). Review

of the USGS topographic maps indicates nearby terrain would be classified as ranging from flat to simple terrain. Due to the minimal amount of terrain elevation differences in the vicinity, assignment of receptor terrain elevations was not conducted (i.e., all receptors were assumed to be at the same elevation as the CT/HRSG stack bases for modeling purposes).

5.7 GOOD ENGINEERING PRACTICE STACK HEIGHT/BUILDING WAKE EFFECTS

According to EPA regulations (40 CFR 51), GEP stack height is defined as the highest of 65 meters or a height established by applying the formula:

$$H_g = H + 1.5 L$$

where: H_g = GEP stack height.

H = height of the structure or nearby structure.

L = lesser dimension (height or projected width) of the nearby structure.

Nearby is defined as a distance up to five times the lesser of the height or width dimension of a structure or terrain feature, but not greater than 800 meters. While the GEP stack height regulations require that stack heights used in modeling for determining compliance with NAAQS and PSD increments not exceed GEP stack heights, the actual stack height may be greater. Guidelines for determining GEP stack height have been issued by EPA (1985).

The stack height proposed for the Bayside CT/HRSGs (150 feet [ft]) is less than the *de minimis* GEP height of 65 meters (213 ft), and, therefore, complies with the EPA promulgated final stack height regulations (40 CFR 51).

While the GEP stack height rules address the maximum stack height that can be employed in a dispersion model analysis, stacks having heights lower than GEP stack height can potentially result in higher downwind concentrations due to building downwash effects. The ISC dispersion models contain two algorithms that assess the effect of building downwash; these algorithms are referred to as the Huber-Snyder and Schulman-Scire

methods. The following steps are employed in determining the effects of building downwash:

- A determination is made as to whether a particular stack is located in the area of influence of a building (i.e., within five times the lesser of the building's height or projected width). If the stack is not within this area, it will not be subject to downwash from that building.
- If a stack is within a building's area of influence, a determination is made as to whether it will be subject to downwash based on the heights of the stack and building. If the stack height to building height ratio is equal to or greater than 2.5, the stack will not be subject to downwash from that building.
- If both conditions in the previous two items are satisfied (i.e., a stack is within the area of influence of a building and has a stack height to building height ratio of less than 2.5), the stack will be subject to building downwash. The determination is then made as to whether the Huber-Snyder or Schulman-Scire downwash method applies. If the stack height is less than or equal to the building height plus one-half the lesser of the building height or width, the Schulman-Scire method is used. Conversely, if the stack height is greater than this criterion, the Huber-Snyder method is employed.
- The ISCST3 downwash input data consists of an array of 36 wind direction-specific building heights and projected widths for each stack. LB is defined as the lesser of the height and projected width of the building. For directionally dependent building downwash, wake effects are assumed to occur if a stack is situated within a rectangle composed of two lines perpendicular to the wind direction, one line at 5 LB downwind of the building and the other at 2 LB upwind of the building, and by two lines parallel to the wind, each at 0.5 LB away from the side of the building.

Table 5-1 provides dimensions of the building/structures evaluated for wake effects; the locations of these buildings/structures were previously provided on Figure 2-2.

Table 5-1. Building/Structure Dimensions

Building/Structure	Dimensions		
	Width (meters)	Length (meters)	Height (meters)
Boiler 1 Structure	17.1	21.0	44.8
Boiler 2 Structure	15.8	17.1	45.1
Boiler 3 Structure	17.1	22.9	45.1
Boiler 4 Structure	17.1	21.9	48.8
Boiler 5 Structure	17.1	18.9	53.0
Boiler 6 Structure	17.1	23.8	62.2
Tripper Structure	17.1	185.0	50.3
Steam Turbine Structure	27.1	191.1	29.0
CT 1A-2D HRSGs	21.3	27.4	28.9

Sources: ECT, 2000.
TEC, 2000.

5.8 RECEPTOR GRIDS

Receptors were placed at locations considered to be ambient air, which is defined as "that portion of the atmosphere, external to buildings, to which the general public has access." The entire perimeter of the F.J. Gannon Station/Bayside Power Station plant site is fenced. Therefore, the nearest locations of general public access are at the facility fence lines.



The receptor grids were formulated consistent with GAQM recommendations. Discrete receptors were placed on the restricted area boundaries. Additional discrete receptors were placed at 10 degree ($^{\circ}$) increments, beginning at 10° on rings at 250 and 500 meters if the specific polar receptor was an ambient air location. Complete rings with receptors located at 10° increments, beginning at 10° , were located at 250 meter increments from 750 to 7,000 meters, and at 8,000, 9,000, 10,000, and 12,000 meters. These receptor grids are consistent with prior dispersion modeling studies of the F.J. Gannon Station submitted to the FDEP.

Figure 5-1 illustrates a graphical representation of the receptor grids (out to a distance of 1,500 meters). A depiction of the receptor grids (from 1,500 meters to 12 km) is shown in Figure 5-2.

5.9 METEOROLOGICAL DATA

Detailed meteorological data are needed for modeling with the ISC3 dispersion models. The ISCST3 model requires a preprocessed data file compiled from hourly surface observations and concurrent twice-daily rawinsonde soundings (i.e., mixing height data).


Consistent with the GAQM and FDEP guidance, modeling should be conducted using the most recent, readily available, 5 years of meteorological data collected at a nearby observation station. In accordance with this guidance, the selected meteorological dataset consisted of St. Petersburg/Clearwater International Airport (SPG), Station ID 72211, surface data and Ruskin (RUS), Station ID 12842, upper air data. These data were obtained from the National Climatic Data Center (NCDC) for the 1992 through 1996 5-year period.



LEGEND

- * Receptor
- ★ Facility Origin
- ★ Combustion Turbine Units

FIGURE 5-1.
RECEPTOR LOCATIONS (WITHIN 1,500 m)



LEGEND
* Receptor

FIGURE 5-2.
RECEPTOR LOCATIONS (From 1,500m to 12 km)

The surface and mixing height data for each of the 5 years were processed using EPA's PCRAMMET meteorological preprocessing program to generate the meteorological data files in the format required by the ISCST3 dispersion model.

5.10 MODELED EMISSION INVENTORY

The modeled on-property emission source consisted of the seven Bayside Unit 1 and 2 combined-cycle CT/HRSGs. Refined modeling was conducted for each of the 12 operating cases. Because emissions of all pollutants are greater during the use of distillate fuel oil in comparison to natural gas-firing, all modeling analyses were based on the combustion of fuel oil.

Emission rates and stack parameters for the Bayside Units 1 and 2 CT/HRSGs during distillate fuel oil-firing were previously presented in Tables 2-2 and 2-9, respectively.

6.0 AMBIENT IMPACT ANALYSIS RESULTS

The refined ISCST3 model was used to model each of the 12 Bayside Units 1 and 2 operating scenarios during fuel oil-firing. These operating scenarios include three loads (50, 75, and 100 percent) and four ambient temperatures (18, 59, 72, and 93°F). ISCST3 model results for each year of meteorology evaluated (1992 through 1996) for SO₂, NO₂, PM/PM₁₀, and CO impacts are summarized on Table 6-1.

Maximum highest, second highest (HSH) 3- and 24-hour SO₂ impacts are projected to be 495.0 and 107.8 µg/m³, respectively. The 3-hour HSH SO₂ impact is 38.1 percent of the Federal and Florida 3-hour average Ambient Air Quality Standard (AAQS) of 1,300 µg/m³. The 24-hour HSH SO₂ impact is 29.5 and 41.5 percent of the Federal and Florida 24-hour average AAQS of 365 and 260 µg/m³, respectively. Maximum annual average SO₂ impact is projected to be 6.2 µg/m³. This impact is 7.7 and 10.3 percent of the Federal and Florida annual average AAQS of 80 and 60 µg/m³, respectively.

Maximum annual average NO₂ impact is projected to be 5.7 µg/m³. This impact is 5.7 percent of the Federal and Florida annual average AAQS of 100 µg/m³.

Maximum highest, second highest (HSH) 24-hour PM/PM₁₀ impact is projected to be 58.9 µg/m³. This impact is 39.2 percent of the 24-hour Federal and Florida AAQS of 150 µg/m³. Maximum annual average PM/PM₁₀ impact is projected to be 4.6 µg/m³. This impact is 9.2 percent of the Federal and Florida annual average AAQS of 50 µg/m³.

Maximum highest, second highest (HSH) 1- and 8-hour CO impacts are projected to be 581.1 and 170.8 µg/m³, respectively. These impacts are 1.5 and 1.7 percent of the Federal and Florida 1- and 8-hour average AAQS of 40,000 and 10,000 µg/m³, respectively.

Table 6-1. Air Quality Impact Analysis Summary
 Distillate Fuel Oil-Firing (Page 1 of 3)

	Case 1 (100% Load, 18°F Ambient)					Case 2 (75% Load, 18°F Ambient)					Case 3 (50% Load, 18°F Ambient)					Case 4 (100% Load, 59°F Ambient)				
	1992	1993	1994	1995	1996	1992	1993	1994	1995	1996	1992	1993	1994	1995	1996	1992	1993	1994	1995	1996
Nominal 10 g/s Impacts:																				
HSH, 1-Hour ($\mu\text{g}/\text{m}^3$)	393.8	408.6	407.4	358.8	404.5	473.7	470.4	482.1	466.1	432.8	520.7	525.4	511.6	512.1	527.0	418.6	438.6	439.5	382.6	431.3
HSH, 3-Hour ($\mu\text{g}/\text{m}^3$)	179.9	175.6	194.5	120.0	172.2	270.4	215.3	233.1	160.7	184.9	281.7	266.8	265.6	237.6	240.3	206.7	200.2	204.7	131.4	194.6
HSH, 8-Hour ($\mu\text{g}/\text{m}^3$)	102.3	91.5	112.1	75.2	113.6	110.3	124.4	115.0	104.7	128.3	136.4	137.4	131.8	134.8	149.1	110.1	106.7	119.9	87.5	123.3
HSH, 24-Hour ($\mu\text{g}/\text{m}^3$)	58.8	47.6	50.6	28.8	79.0	62.7	63.9	69.2	39.3	87.2	76.7	86.8	88.0	46.9	93.3	67.3	52.8	56.1	33.2	87.1
Annual ($\mu\text{g}/\text{m}^3$)	2.5	1.9	1.9	1.0	1.5	4.6	3.9	3.3	2.0	2.9	6.9	5.8	4.6	3.0	4.2	3.2	2.6	2.4	1.3	1.9
SO ₂																				
Emission Rate (g/s)	13.17	13.17	13.17	13.17	13.17	10.62	10.62	10.62	10.62	10.62	8.43	8.43	8.43	8.43	8.43	12.38	12.38	12.38	12.38	12.38
HSH, 3-Hour ($\mu\text{g}/\text{m}^3$)	237.0	231.3	256.2	158.1	226.8	287.1	228.7	247.5	495.0	196.4	237.5	224.9	223.9	431.7	202.6	255.9	247.8	253.5	162.7	240.9
HSH, 24-Hour ($\mu\text{g}/\text{m}^3$)	77.4	62.7	66.6	37.9	104.0	66.6	67.8	73.4	41.7	92.6	64.6	73.2	74.2	39.6	78.7	83.3	65.4	69.5	41.1	107.8
Annual ($\mu\text{g}/\text{m}^3$)	3.3	2.5	2.5	1.3	2.0	4.9	4.2	3.5	2.1	3.1	5.8	4.9	3.9	2.5	3.6	4.0	3.2	2.9	1.6	2.4
NO ₂																				
Emission Rate (g/s)	16.67	16.67	16.67	16.67	16.67	13.31	13.31	13.31	13.31	13.31	10.47	10.47	10.47	10.47	10.47	15.65	15.65	15.65	15.65	15.65
Tier I Annual ($\mu\text{g}/\text{m}^3$)	4.2	3.2	3.2	1.6	2.6	6.2	5.2	4.4	2.6	3.9	7.2	6.1	4.8	3.1	4.4	5.0	4.0	3.7	2.0	3.0
Tier II Annual ($\mu\text{g}/\text{m}^3$)	3.2	2.4	2.4	1.2	1.9	4.6	3.9	3.3	2.0	2.9	5.4	4.6	3.6	2.4	3.3	3.8	3.0	2.8	1.5	2.3
PM/PM ₁₀																				
Emission Rate (g/s)	6.78	6.78	6.78	6.78	6.78	6.30	6.30	6.30	6.30	6.30	5.88	5.88	5.88	5.88	5.88	6.63	6.63	6.63	6.63	6.63
HSH, 24-Hour ($\mu\text{g}/\text{m}^3$)	39.9	32.3	34.3	19.5	53.6	39.5	40.2	43.6	24.7	54.9	45.1	51.0	51.7	27.6	54.9	44.6	35.0	37.2	22.0	57.7
Annual ($\mu\text{g}/\text{m}^3$)	1.7	1.3	1.3	0.7	1.0	2.9	2.5	2.1	1.2	1.8	4.0	3.4	2.7	1.8	2.5	2.1	1.7	1.6	0.8	1.3
CO																				
Emission Rate (g/s)	8.82	8.82	8.82	8.82	8.82	8.14	8.14	8.14	8.14	8.14	9.34	9.34	9.34	9.34	9.34	8.13	8.13	8.13	8.13	8.13
HSH, 1-Hour ($\mu\text{g}/\text{m}^3$)	347.4	360.4	359.3	316.5	356.8	385.6	382.9	392.4	379.4	352.3	486.3	490.7	477.8	478.3	492.2	340.3	356.6	357.3	311.1	350.6
HSH, 8-Hour ($\mu\text{g}/\text{m}^3$)	90.2	80.7	98.9	66.3	100.2	89.8	101.3	93.6	85.2	104.4	127.4	128.3	123.1	125.9	139.2	89.5	86.7	97.5	71.1	100.3

Table 6-1. Air Quality Impact Analysis Summary
 Distillate Fuel Oil-Firing (Page 2 of 3)

	Case 5 (75% Load, 59°F Ambient)					Case 6 (50% Load, 59°F Ambient)					Case 7 (100% Load, 72°F Ambient)					Case 8 (75% Load, 72°F Ambient)				
	1992	1993	1994	1995	1996	1992	1993	1994	1995	1996	1992	1993	1994	1995	1996	1992	1993	1994	1995	1996
Nominal 10 g/s Impacts:																				
HSH, 1-Hour ($\mu\text{g}/\text{m}^3$)	493.3	496.9	481.9	492.6	469.2	544.9	553.5	544.3	510.2	555.0	423.1	443.3	445.1	394.0	436.2	496.3	482.4	475.8	496.7	474.8
HSH, 3-Hour ($\mu\text{g}/\text{m}^3$)	253.2	249.9	242.9	182.9	200.3	276.8	266.5	263.1	264.8	271.9	216.4	205.0	207.7	135.3	197.0	255.9	251.5	260.3	187.4	201.4
HSH, 8-Hour ($\mu\text{g}/\text{m}^3$)	120.1	130.7	124.2	111.1	135.8	144.3	156.1	139.9	146.3	156.9	111.4	112.1	121.4	89.8	125.2	121.7	131.8	127.1	113.0	136.8
HSH, 24-Hour ($\mu\text{g}/\text{m}^3$)	67.0	68.4	74.6	41.3	91.7	74.6	87.2	83.1	52.2	97.6	68.7	54.1	56.6	34.0	88.6	67.7	69.4	77.5	41.9	92.4
Annual ($\mu\text{g}/\text{m}^3$)	5.3	4.5	3.7	2.3	3.3	7.7	6.6	5.0	3.4	4.7	3.4	2.7	2.5	1.3	2.0	5.4	4.6	3.8	2.3	3.4
SO ₂																				
Emission Rate (g/s)	10.00	10.00	10.00	10.00	10.00	7.97	7.97	7.97	7.97	7.97	12.10	12.10	12.10	12.10	12.10	9.75	9.75	9.75	9.75	9.75
HSH, 3-Hour ($\mu\text{g}/\text{m}^3$)	253.2	249.9	242.9	182.9	200.3	220.6	212.4	209.7	406.6	216.7	261.8	248.0	251.3	476.7	238.3	249.5	245.3	253.8	484.3	196.3
HSH, 24-Hour ($\mu\text{g}/\text{m}^3$)	67.0	68.4	74.6	41.3	91.7	59.5	69.5	66.2	41.6	77.8	83.1	65.4	68.4	41.2	107.2	66.0	67.7	75.6	40.9	90.1
Annual ($\mu\text{g}/\text{m}^3$)	5.3	4.5	3.7	2.3	3.3	6.2	5.3	4.0	2.7	3.7	4.1	3.3	3.0	1.6	2.5	5.3	4.5	3.7	2.3	3.3
NO ₂																				
Emission Rate (g/s)	12.52	12.52	12.52	12.52	12.52	9.9	9.89	9.89	9.89	9.89	15.32	15.32	15.32	15.32	15.32	12.21	12.21	12.21	12.21	12.21
Tier I Annual ($\mu\text{g}/\text{m}^3$)	6.6	5.7	4.6	2.8	4.1	7.7	6.5	5.0	3.4	4.6	5.2	4.2	3.8	2.1	3.1	6.6	5.7	4.6	2.8	4.1
Tier II Annual ($\mu\text{g}/\text{m}^3$)	5.0	4.2	3.5	2.1	3.1	5.7	4.9	3.7	2.5	3.5	3.9	3.1	2.8	1.5	2.4	4.9	4.3	3.5	2.1	3.1
PM/PM ₁₀																				
Emission Rate (g/s)	6.19	6.19	6.19	6.19	6.19	5.80	5.80	5.80	5.80	5.80	6.58	6.58	6.58	6.58	6.58	6.14	6.14	6.14	6.14	6.14
HSH, 24-Hour ($\mu\text{g}/\text{m}^3$)	41.5	42.3	46.2	25.5	56.8	43.3	50.6	48.2	30.3	56.6	45.2	35.6	37.2	22.4	58.3	41.5	42.6	47.6	25.8	56.7
Annual ($\mu\text{g}/\text{m}^3$)	3.3	2.8	2.3	1.4	2.0	4.5	3.8	2.9	2.0	2.7	2.2	1.8	1.6	0.9	1.3	3.3	2.8	2.3	1.4	2.1
CO																				
Emission Rate (g/s)	7.47	7.47	7.47	7.47	7.47	9.00	9.00	9.00	9.00	9.00	7.88	7.88	7.88	7.88	7.88	7.32	7.32	7.32	7.32	7.32
HSH, 1-Hour ($\mu\text{g}/\text{m}^3$)	368.5	371.2	360.0	368.0	350.5	490.5	498.1	489.8	459.2	499.5	333.4	349.3	350.8	310.5	343.7	363.3	353.1	348.3	363.6	347.6
HSH, 8-Hour ($\mu\text{g}/\text{m}^3$)	89.7	97.7	92.8	136.6	101.4	129.8	140.5	125.9	131.7	141.2	87.8	88.3	95.6	106.6	98.6	89.1	96.5	93.1	82.7	100.2

Table 6-1. Air Quality Impact Analysis Summary
 Distillate Fuel Oil-Firing (Page 3 of 3)

	Case 9 (50% Load, 72°F Ambient)					Case 10 (100% Load, 93°F Ambient)					Case 11 (75% Load, 93°F Ambient)					Case 12 (50% Load, 93°F Ambient)					Maximums
	1992	1993	1994	1995	1996	1992	1993	1994	1995	1996	1992	1993	1994	1995	1996	1992	1993	1994	1995	1996	
Nominal 10 g/s Impacts:																					
HSH, 1-Hour ($\mu\text{g}/\text{m}^3$)	547.4	555.9	546.7	514.9	557.4	430.9	449.3	451.6	408.7	442.4	505.3	490.8	487.2	508.6	404.5	558.4	567.5	554.0	529.0	564.5	567.5
HSH, 3-Hour ($\mu\text{g}/\text{m}^3$)	280.3	270.3	264.0	267.5	275.0	228.9	211.0	215.3	139.3	200.1	263.8	256.3	265.1	201.4	172.2	292.2	281.6	267.0	275.9	284.1	292.2
HSH, 8-Hour ($\mu\text{g}/\text{m}^3$)	146.5	159.5	140.8	147.3	157.7	113.2	119.3	123.2	92.8	127.6	126.3	134.9	129.0	118.4	113.6	153.1	166.8	143.8	150.5	160.3	166.8
HSH, 24-Hour ($\mu\text{g}/\text{m}^3$)	75.5	88.0	83.7	52.7	98.1	70.7	55.7	58.4	36.0	90.5	69.7	72.5	80.5	42.9	79.0	78.1	90.5	85.3	54.5	99.4	99.4
Annual ($\mu\text{g}/\text{m}^3$)	7.8	6.7	5.1	3.5	4.7	3.6	2.9	2.6	1.4	2.2	5.8	5.0	4.0	2.5	1.5	8.1	6.9	5.2	3.6	4.8	8.1
SO ₂																					
Emission Rate (g/s)	7.75	7.75	7.75	7.75	7.75	11.69	11.70	11.70	11.70	11.70	9.25	9.25	9.25	9.25	9.25	7.35	7.35	7.35	7.35	7.35	13.2
HSH, 3-Hour ($\mu\text{g}/\text{m}^3$)	217.2	209.5	204.6	399.1	213.1	267.6	246.9	251.9	163.0	234.1	244.0	237.1	245.2	470.5	159.3	214.8	207.0	196.2	388.8	208.8	495.0
HSH, 24-Hour ($\mu\text{g}/\text{m}^3$)	58.5	68.2	64.8	40.9	76.0	82.6	65.2	68.3	42.1	105.9	64.4	67.1	74.5	39.6	73.1	57.4	66.5	62.7	40.1	73.1	107.8
Annual ($\mu\text{g}/\text{m}^3$)	6.1	5.2	3.9	2.7	3.7	4.2	3.4	3.0	1.7	2.6	5.3	4.6	3.7	2.3	1.4	6.0	5.1	3.8	2.6	3.6	6.2
NO ₂																					
Emission Rate (g/s)	9.61	9.61	9.61	9.61	9.61	14.82	14.82	14.82	14.82	14.82	11.58	11.58	11.58	11.58	11.58	9.10	9.10	9.10	9.10	9.10	16.7
Tier I Annual ($\mu\text{g}/\text{m}^3$)	7.5	6.4	4.9	3.3	4.5	5.3	4.3	3.8	2.1	3.2	6.7	5.8	4.6	2.9	1.8	7.4	6.3	4.7	3.3	4.4	7.7
Tier II Annual ($\mu\text{g}/\text{m}^3$)	5.6	4.8	3.6	2.5	3.4	4.0	3.2	2.9	1.6	2.4	5.0	4.3	3.4	2.2	1.3	5.5	4.7	3.5	2.4	3.3	5.7
PM/PM ₁₀																					
Emission Rate (g/s)	5.76	5.76	5.76	5.76	5.76	6.50	6.50	6.50	6.50	6.50	6.04	6.04	6.04	6.04	6.04	5.68	5.68	5.68	5.68	5.68	6.8
HSH, 24-Hour ($\mu\text{g}/\text{m}^3$)	43.5	50.7	48.2	30.4	56.5	45.9	36.2	38.0	23.4	58.9	42.1	43.8	48.6	25.9	47.7	44.4	51.4	48.4	31.0	56.5	58.9
Annual ($\mu\text{g}/\text{m}^3$)	4.5	3.8	2.9	2.0	2.7	2.3	1.9	1.7	0.9	1.4	3.5	3.0	2.4	1.5	0.9	4.6	3.9	2.9	2.0	2.7	4.6
CO																					
Emission Rate (g/s)	9.40	9.40	9.40	9.40	9.40	7.61	7.61	7.61	7.61	7.61	7.07	7.07	7.07	7.07	7.07	10.24	10.24	10.24	10.24	10.24	10.2
HSH, 1-Hour ($\mu\text{g}/\text{m}^3$)	514.6	522.5	513.9	484.0	524.0	327.9	341.9	343.6	311.0	336.7	357.2	347.0	344.4	359.6	286.0	571.8	581.1	567.3	541.7	578.1	581.1
HSH, 8-Hour ($\mu\text{g}/\text{m}^3$)	137.7	150.0	132.4	138.5	148.3	86.1	90.8	93.8	70.6	97.1	89.3	95.4	91.2	83.7	80.3	156.8	170.8	147.2	154.1	164.1	170.8
Project Impact Summary																					
	Project Impact	Case No.	Year	Florida AAQS	Federal NAAQS	% of AAQS Florida	% of AAQS Federal														
SO ₂																					
HSH, 3-Hour ($\mu\text{g}/\text{m}^3$)	495.0	2	1995	1,300	1,300	38.1	38.1														
HSH, 24-Hour ($\mu\text{g}/\text{m}^3$)	107.8	4	1996	260	365	41.5	29.5														
Annual ($\mu\text{g}/\text{m}^3$)	6.2	6	1992	60	80	10.3	7.7														
NO ₂																					
Tier II Annual ($\mu\text{g}/\text{m}^3$)	5.7	6	1992	100	100	5.7	5.7														
PM ₁₀																					
HSH, 24-Hour ($\mu\text{g}/\text{m}^3$)	58.9	10	1996	150	150	39.2	39.2														
Annual ($\mu\text{g}/\text{m}^3$)	4.6	12	1992	50	50	9.2	9.2														
CO																					
HSH, 1-Hour ($\mu\text{g}/\text{m}^3$)	581.1	12	1993	40,000	40,000	1.5	1.5														
HSH, 8-Hour ($\mu\text{g}/\text{m}^3$)	170.8	12	1993	10,000	10,000	1.7	1.7														

ATTACHMENT A-1
REGULATORY APPLICABILITY ANALYSES

Table A-1. Summary of Federally EPA Regulatory Applicability and Corresponding Requirements (Page 1 of 11)

Regulation	Citation	Not Applicable	Applicable Emission Units	Applicable Requirement or Non-Applicability Rationale
40 CFR Part 60 - Standards of Performance for New Stationary Sources.				
<i>Subpart A - General Provisions</i>				
Notification and Recordkeeping	§60.7(b) - (h)		CT 1A-2D	General recordkeeping and reporting requirements.
Performance Tests	§60.8		CT 1A-2D	Conduct performance tests as required by EPA or FDEP. (potential future requirement)
Compliance with Standards	§60.11(a) thru (d), and (f)		CT 1A-2D	General compliance requirements. Addresses requirements for visible emissions tests.
Circumvention	§60.12		CT 1A-2D	Cannot conceal an emission which would otherwise constitute a violation of an applicable standard.
Monitoring Requirements	§60.13(a), (b), (d), (e), and (h)		CT 1A-2D	Requirements pertaining to continuous monitoring systems.
General notification and reporting requirements	§60.19		CT 1A-2D	General procedures regarding reporting deadlines.
<i>Subpart GG - Standard of Performance for Stationary Gas Turbines</i>				
Standards for Nitrogen Oxides	§60.332(a)(1) and (b), (f), and (i)		CT 1A-2D	Establishes NO _x limit of 75 ppmv at 15% (with corrections for heat rate and fuel bound nitrogen) for electric utility stationary gas turbines with peak heat input greater than 100 MMBtu/hr.
Standards for Sulfur Dioxide	§60.333		CT 1A-2D	Establishes exhaust gas SO ₂ limit of 0.015 percent by volume (at 15% O ₂ , dry) and maximum fuel sulfur content of 0.8 percent by weight.

Table A-1. Summary of Federally EPA Regulatory Applicability and Corresponding Requirements (Page 2 of 11)

Regulation	Citation	Not Applicable	Applicable Emission Units	Applicable Requirement or Non-Applicability Rationale
<i>Subpart GG - Standard of Performance for Stationary Gas Turbines</i>				
Monitoring Requirements	§60.334(a)		CT 1A-2D	Requires continuous monitoring of fuel consumption and ratio of water to fuel being fired in the turbine. Monitoring system must be accurate to ± 5.0 percent. Applicable to CTs using water injection for NO _x control.
Monitoring Requirements	§60.334(b)(2) and (c)		CT 1A-2D	Requires periodic monitoring of fuel sulfur and nitrogen content. Defines excess emissions
Test Methods and Procedures	§60.335		CT 1A-2D	Specifies monitoring procedures and test methods.
40 CFR Part 60 - Standards of Performance for New Stationary Sources: Subparts B, C, Cb, Cc, Cd, Ce, D, Da, Db, Dc, E, Ea, Eb, Ec, F, G, H, I, J, K, Ka, Kb, L, M, N, Na, O, P, Q, R, S, T, U, V, W, X, Y, Z, AA, AAa, BB, CC, DD, EE, HH, KK, LL, MM, NN, PP, QQ, RR, SS, TT, UU, VV, WW, XX, AAA, BBB, DDD, FFF, GGG, HHH, III, JJJ, KKK, LLL, NNN, OOO, PPP, QQQ, RRR, SSS, TTT, UUU, VVV, and WWW		X		None of the listed NSPS' contain requirements which are applicable to the Bayside combined cycle CTs.
40 CFR Part 61 - National Emission Standards for Hazardous Air Pollutants: Subparts A, B, C, D, E, F, H, I, J, K, L, M, N, O, P, Q, R, T, V, W, Y, BB, and FF		X		None of the listed NESHAPS' contain requirements which are applicable to the Bayside combined cycle CTs.
40 CFR Part 63 - National Emission Standards for Hazardous Air Pollutants for Source Categories: Subparts A, B, C, D, E, F, G, H, I, L, M, N, O, Q, R, S, T, U, W, X, Y, AA, BB, CC, DD, EE, GG, HH, II, JJ, KK, LL, OO, PP, QQ, RR, SS, TT, UU, VV, WW, YY, CCC, DDD, EEE, GGG, HHH, III, JJJ, LLL, MMM, NNN, OOO, PPP, RRR, TTT, VVV, and XXX		X		None of the listed NESHAPS' contain requirements which are applicable to the Bayside combined cycle CTs.

Table A-1. Summary of Federally EPA Regulatory Applicability and Corresponding Requirements (Page 3 of 11)

Regulation	Citation	Not Applicable	Applicable Emission Units	Applicable Requirement or Non-Applicability Rationale
40 CFR Part 72 - Acid Rain Program Permits				
<i>Subpart A - Acid Rain Program General Provisions</i>				
Standard Requirements	§72.9 excluding §72.9(c)(3)(i), (ii), and (iii), and §72.9(d)		CT 1A-2D	General Acid Rain Program requirements. SO ₂ allowance program requirements start January 1, 2000 (future requirement).
<i>Subpart B - Designated Representative</i>				
Designated Representative	§72.20 - §72.24		CT 1A-2D	General requirements pertaining to the Designated Representative.
<i>Subpart C - Acid Rain Application</i>				
Requirements to Apply	§72.30(a), (b)(2)(ii), (c), and (d)		CT 1A-2D	<p>Requirement to submit a complete Phase II Acid Rain permit application to the permitting authority at least 24 months before the later of January 1, 2000 or the date on which the unit commences operation. (future requirement).</p> <p>Requirement to submit a complete Acid Rain permit application for each source with an affected unit at least 6 months prior to the expiration of an existing Acid Rain permit governing the unit during Phase II or such longer time as may be approved under part 70 of this chapter that ensures that the term of the existing permit will not expire before the effective date of the permit for which the application is submitted. (future requirement).</p>

Table A-1. Summary of Federally EPA Regulatory Applicability and Corresponding Requirements (Page 4 of 11)

Regulation	Citation	Not Applicable	Applicable Emission Units	Applicable Requirement or Non-Applicability Rationale
Permit Application Shield	§72.32		CT 1A-2D	Acid Rain Program permit shield for units filing a timely and complete application. Application is binding pending issuance of Acid Rain Permit.
<i>Subpart D - Acid Rain Compliance Plan and Compliance Options</i>				
General	§72.40(a)(1)		CT 1A-2D	General SO ₂ compliance plan requirements.
General	§72.40(a)(2)	X		General NO _x compliance plan requirements are not applicable to the Bayside combined cycle CTs.
<i>Subpart E - Acid Rain Permit Contents</i>				
Permit Shield	§72.51		CT 1A-2D	Units operating in compliance with an Acid Rain Permit are deemed to be operating in compliance with the Acid Rain Program.
<i>Subpart H - Permit Revisions</i>				
Fast-Track Modifications	§72.82(a) and (c)		CT 1A-2D	Procedures for fast-track modifications to Acid Rain Permits. (potential future requirement)
<i>Subpart I - Compliance Certification</i>				
Annual Compliance Certification Report	§72.90		CT 1A-2D	Requirement to submit an annual compliance report. (future requirement)

Table A-1. Summary of Federally EPA Regulatory Applicability and Corresponding Requirements (Page 5 of 11)

Regulation	Citation	Not Applicable	Applicable Emission Units	Applicable Requirement or Non-Applicability Rationale
40 CFR Part 75 - Continuous Emission Monitoring				
<i>Subpart A - General</i>				
Prohibitions	§75.5		CT 1A-2D	General monitoring prohibitions.
<i>Subpart B - Monitoring Provisions</i>				
General Operating Requirements	§75.10		CT 1A-2D	General monitoring requirements.
Specific Provisions for Monitoring SO ₂ Emissions	§75.11(d)(2)		CT 1A-2D	SO ₂ continuous monitoring requirements for gas- and oil-fired units. Appendix D election will be made.
Specific Provisions for Monitoring NO _x Emissions	§75.12(a) and (b)		CT 1A-2D	NO _x continuous monitoring requirements for coal-fired units, gas-fired nonpeaking units or oil-fired nonpeaking units
Specific Provisions for Monitoring CO ₂ Emissions	§75.13(b)		CT 1A-2D	CO ₂ continuous monitoring requirements. Appendix G election will be made.
<i>Subpart B - Monitoring Provisions</i>				
Specific Provisions for Monitoring Opacity	§75.14(d)		CT 1A-2D	Opacity continuous monitoring exemption for diesel-fired units.
<i>Subpart C - Operation and Maintenance Requirements</i>				
Certification and Recertification Procedures	§75.20(b)		CT 1A-2D	Recertification procedures (potential future requirement)
Certification and Recertification Procedures	§75.20(c)		CT 1A-2D	Recertification procedure requirements. (potential future requirement)
Quality Assurance and Quality Control Requirements	§75.21 except §75.21(b)		CT 1A-2D	General QA/QC requirements (excluding opacity).

Table A-1. Summary of Federally EPA Regulatory Applicability and Corresponding Requirements (Page 6 of 11)

Regulation	Citation	Not Applicable	Applicable Emission Units	Applicable Requirement or Non-Applicability Rationale
Reference Test Methods	§75.22		CT 1A-2D	Specifies required test methods to be used for recertification testing (potential future requirement).
Out-Of-Control Periods	§75.24 except §75.24(e)		CT 1A-2D	Specifies out-of-control periods and required actions to be taken when out-of-control periods occur (excluding opacity).
<i>Subpart D - Missing Data Substitution Procedures</i>				
General Provisions	§75.30(a)(3), (b), (c)		CT 1A-2D	General missing data requirements.
Determination of Monitor Data Availability for Standard Missing Data Procedures	§75.32		CT 1A-2D	Monitor data availability procedure requirements.
Standard Missing Data Procedures	§75.33(a) and (c)		CT 1A-2D	Missing data substitution procedure requirements.
<i>Subpart F - Recordkeeping Requirements</i>				
General Recordkeeping Provisions	§75.50(a), (b), (d), and (e)(2)		CT 1A-2D	General recordkeeping requirements for NO _x and Appendix G CO ₂ monitoring.
Monitoring Plan	§75.53(a), (b), (c), and (d)(1)		CT 1A-2D	Requirement to prepare and maintain a Monitoring Plan.
General Recordkeeping Provisions	§75.54(a), (b), (d), and (e)(2)		CT 1A-2D	Requirements pertaining to general recordkeeping.
General Recordkeeping Provisions for Specific Situations	§75.55(c)		CT 1A-2D	Specific recordkeeping requirements for Appendix D SO ₂ monitoring.
General Recordkeeping Provisions	§75.56(a)(1), (3), (5), (6), and (7)		CT 1A-2D	Requirements pertaining to general recordkeeping.

Table A-1. Summary of Federally EPA Regulatory Applicability and Corresponding Requirements (Page 7 of 11)

Regulation	Citation	Not Applicable	Applicable Emission Units	Applicable Requirement or Non-Applicability Rationale
General Recordkeeping Provisions	§75.56(b)(1)		CT 1A-2D	Requirements pertaining to general recordkeeping for Appendix D SO ₂ monitoring.
<i>Subpart G - Reporting Requirements</i>				
General Provisions	§75.60		CT 1A-2D	General reporting requirements.
Notification of Certification and Recertification Test Dates	§75.61(a)(1) and (5), (b), and (c)		CT 1A-2D	Requires written submittal of recertification tests and revised test dates for CEMS. Notice of certification testing shall be submitted at least 45 days prior to the first day of recertification testing. Notification of any proposed adjustment to certification testing dates must be provided at least 7 business days prior to the proposed date change.
<i>Subpart G - Reporting Requirements</i>				
Recertification Application	§75.63		CT 1A-2D	Requires submittal of a recertification application within 30 days after completing the recertification test. (potential future requirement)
Quarterly Reports	§75.64(a)(1) - (5); (b), (c), and (d)		CT 1A-2D	Quarterly data report requirements.
40 CFR Part 76 - Acid Rain Nitrogen Oxides Emission Reduction Program		X		The Acid Rain Nitrogen Oxides Emission Reduction Program only applies to coal-fired utility units that are subject to an Acid Rain emissions limitation or reduction requirement for SO ₂ under Phase I or Phase II.

Table A-1. Summary of Federally EPA Regulatory Applicability and Corresponding Requirements (Page 8 of 11)

Regulation	Citation	Not Applicable	Applicable Emission Units	Applicable Requirement or Non-Applicability Rationale
40 CFR Part 77 - Excess Emissions				
Offset Plans for Excess Emissions of Sulfur Dioxide	§77.3		CT 1A-2D	Requirement to submit offset plans for excess SO ₂ emissions not later than 60 days after the end of any calendar year during which an affected unit has excess SO ₂ emissions. Required contents of offset plans are specified (potential future requirement).
Deduction of Allowances to Offset Excess Emissions of Sulfur Dioxide	§77.5(b)		CT 1A-2D	Requirement for the Designated Representative to hold enough allowances in the appropriate compliance subaccount to cover deductions to be made by EPA if a timely and complete offset plan is not submitted or if EPA disapproves a proposed offset plan (potential future requirement).
Penalties for Excess Emissions of Sulfur Dioxide	§77.6		CT 1A-2D	Requirement to pay a penalty if excess emissions of SO ₂ occur at any affected unit during any year (potential future requirement).
40 CFR Part 82 - Protection of Stratospheric Ozone				
Production and Consumption Controls	Subpart A	X		The Bayside combined cycle CTs will not produce or consume ozone depleting substances.
Servicing of Motor Vehicle Air Conditioners	Subpart B	X		Bayside personnel will not perform servicing of motor vehicles which involves refrigerant in the motor vehicle air conditioner. All such servicing will be conducted by persons who comply with Subpart B requirements.

Table A-1. Summary of Federally EPA Regulatory Applicability and Corresponding Requirements (Page 9 of 11)

Regulation	Citation	Not Applicable	Applicable Emission Units	Applicable Requirement or Non-Applicability Rationale
Ban on Nonessential Products Containing Class I Substances and Ban on Nonessential Products Containing or Manufactured with Class II Substances	Subpart C	X		Bayside will not sell or distribute any banned nonessential substances.
The Labeling of Products Using Ozone-Depleting Substances	Subpart E	X		The Bayside combined cycle CTs will not produce any products containing ozone depleting substances.
<i>Subpart F - Recycling and Emissions Reduction</i>				
Prohibitions	§82.154	X		Bayside personnel will not maintain, service, repair, or dispose of any appliances. All such activities will be performed by independent parties in compliance with §82.154 prohibitions.
Required Practices	§82.156 except §82.156(i)(5), (6), (9), (10), and (11)	X		Contractors will maintain, service, repair, and dispose of any appliances in compliance with §82.156 required practices.

Table A-1. Summary of Federally EPA Regulatory Applicability and Corresponding Requirements (Page 10 of 11)

Regulation	Citation	Not Applicable	Applicable Emission Units	Applicable Requirement or Non-Applicability Rationale
<i>Subpart F - Recycling and Emissions Reduction</i>				
Required Practices	§82.156(i)(5), (6), (9), (10), and (11)		Appliances as defined by §82.152- any device which contains and uses a Class I or II substance as a refrigerant and which is used for household or commercial purposes, including any air conditioner, refrigerator, chiller, or freezer	Owner/operator requirements pertaining to repair of leaks.
Technician Certification	§82.161	X		Bayside personnel will not maintain, service, repair, or dispose of any appliances and therefore are not subject to technician certification requirements.
Certification By Owners of Recovery and Recycling Equipment	§82.162	X		Bayside personnel will not maintain, service, repair, or dispose of any appliances and therefore do not use recovery and recycling equipment.
Reporting and Recordkeeping Requirements	§82.166(k), (m), and (n)		Appliances as defined by §82.152	Owners/operators of appliances normally containing 50 or more pounds of refrigerant must keep servicing records documenting the date and type of service, as well as the quantity of refrigerant added.

Table A-1. Summary of Federally EPA Regulatory Applicability and Corresponding Requirements (Page 11 of 11)

Regulation	Citation	Not Applicable	Applicable Emission Units	Applicable Requirement or Non-Applicability Rationale
40 CFR Part 50 - National Primary and Secondary Ambient Air Quality Standards		X		State agency requirements - not applicable to individual emission sources.
40 CFR Part 51 - Requirements for Preparation, Adoption, and Submittal of Implementation Plans		X		State agency requirements - not applicable to individual emission sources.
40 CFR Part 52 - Approval and Promulgation of Implementation Plans		X		State agency requirements - not applicable to individual emission sources.
40 CFR Part 62 - Approval and Promulgation of State Plans for Designated Facilities and Pollutants		X		State agency requirements - not applicable to individual emission sources.
40 CFR Part 64 - Regulations on Compliance Assurance Monitoring for Major Stationary Sources		X		Exempt per §64.2(b)(1)(iii) since CTs 1A-2D will meet Acid Rain Program monitoring requirements.
40 CFR Part 68 - Provisions for Chemical Accident Prevention			Ammonia Storage	Subject to provisions of 40 CFR Part 68 due to anhydrous ammonia storage.
40 CFR Part 70 - State Operating Permit Programs		X		State agency requirements - not applicable to individual emission sources.
40 CFR Parts 49, 53, 54, 55, 56, 57, 58, 59, 62, 66, 67, 69, 71, 74, 76, 79, 80, 81, 85, 86, 87, 88, 89, 90, 91, 92, 93, 94, 95, 96, 97, 600, and 610		X		The listed regulations do not contain any requirements which are applicable to the Bayside combined cycle CTs.

Source: ECT, 2000.

Table A-2. Summary of FDEP Regulatory Applicability and Corresponding Requirements (Page 1 of 12)

Regulation	Citation	Not Applicable	Applicable: Facility-Wide	Applicable: Emission Units	Applicable Requirement or Non-Applicability Rationale
Chapter 62-4, F.A.C. - Permits: Part I General					
Scope of Part I	62-4.001, F.A.C.	X			Contains no applicable requirements.
Definitions	62-4.020, .021, F.A.C.	X			Contains no applicable requirements.
Transferability of Definitions	62-4.021, .021, F.A.C.	X			Contains no applicable requirements.
General Prohibition	62-4.030, F.A.C		X		All stationary air pollution sources must be permitted, unless otherwise exempted.
Exemptions	62-4.040, F.A.C		X		Certain structural changes exempt from permitting. Other stationary sources exempt from permitting upon FDEP insignificance determination.
Procedures to Obtain Permits	62-4.050, F.A.C.		X		General permitting requirements.
Surveillance Fees	62-4.052, F.A.C.	X			Not applicable to air emission sources.
Permit Processing	62-4.055, F.A.C.	X			Contains no applicable requirements.
Consultation	62-4.060, F.A.C.	X			Consultation is encouraged, not required.
Standards for Issuing or Denying Permits; Issuance; Denial	62-4.070, F.A.C	X			Establishes standard procedures for FDEP. Requirement is not applicable to the Bayside combined cycle CTs.
Modification of Permit Conditions	62-4.080, F.A.C	X			Application is for initial construction permit. Modification of permit conditions is not being requested.
Renewals	62-4.090, F.A.C.		X		Establishes permit renewal criteria. Additional criteria are cited at 62-213.-430(3), F.A.C. (future requirement)
Suspension and Revocation	62-4.100, F.A.C.		X		Establishes permit suspension and revocation criteria.

Table A-2. Summary of FDEP Regulatory Applicability and Corresponding Requirements (Page 2 of 12)

Regulation	Citation	Not Applicable	Applicable: Facility-Wide	Applicable: Emission Units	Applicable Requirement or Non-Applicability Rationale
Financial Responsibility	62-4.110, F.A.C.	X			Contains no applicable requirements.
Transfer of Permits	62-4.120, F.A.C.	X			A sale or legal transfer of a permitted facility is not included in this application.
Plant Operation - Problems	62-4.130, F.A.C.		X		Immediate notification is required whenever the permittee is temporarily unable to comply with any permit condition. Notification content is specified. (potential future requirement)
Review	62-4.150, F.A.C.	X			Contains no applicable requirements.
Permit Conditions	62-4.160, F.A.C.	X			Contains no applicable requirements.
Scope of Part II	62-4.2.00, F.A.C.	X			Contains no applicable requirements.
Construction Permits	62-4.210, F.A.C.	X			General requirements for construction permits.
Operation Permits for New Sources	62-4.220, F.A.C.	X			General requirements for initial new source operation permits. (future requirement)
Water Permit Provisions	62-4.240 - 250, F.A.C.	X			Contains no applicable requirements.
Chapter 62-17, F.A.C. - Electrical Power Plant Siting		X			Power Plant Siting Act provisions.
Chapter 62-102, F.A.C. - Rules of Administrative Procedure - Rule Making			X		General administrative procedures.
Chapter 62-103, F.A.C. - Rules of Administrative Procedure - Final Agency Action			X		General administrative procedures.

Table A-2. Summary of FDEP Regulatory Applicability and Corresponding Requirements (Page 3 of 12)

Regulation	Citation	Not Applicable	Applicable: Facility-Wide	Applicable: Emission Units	Applicable Requirement or Non-Applicability Rationale
Chapter 62-204, F.A.C. - State Implementation Plan					
State Implementation Plan	62-204.100, .200, .220(1)-(3), .240, .260, .320, .340, .360, .400, and .500, F.A.C.	X			Contains no applicable requirements.
Ambient Air Quality Protection	62-204.220(4), F.A.C.		X		Assessments of ambient air pollutant impacts must be made using applicable air quality models, data bases, and other requirements approved by FDEP and specified in 40 CFR Part 51, Appendix W.
State Implementation Plan	62-204.800(1) - (6), F.A.C.	X			Referenced federal regulations contain no applicable requirements.
State Implementation Plan	62-204.800(7)(a), (b)16.,(b)39., (c), (d), and (e), F.A.C.			CT 1A-2D	NSPS Subpart GG; see Table A-1 for detailed federal regulatory citations.
State Implementation Plan	62-204.800(8) - (13), (15), (17), (20), and (22) F.A.C.	X			Referenced federal regulations contain no applicable requirements.
State Implementation Plan	62-204.800 (14), (16), (18), (19), F.A.C.			CT 1A-2D	Acid Rain Program; see Table A-1 for detailed federal regulatory citations.
State Implementation Plan	62-204.800(21), F.A.C.		X		Protection of Stratospheric Ozone; see Table A-1 for detailed federal regulatory citations.
Chapter 62-210, F.A.C. - Stationary Sources - General Requirements					
Purpose and Scope	62-210.100, F.A.C.	X			Contains no applicable requirements.
Definitions	62-210.200, F.A.C.	X			Contains no applicable requirements.
Small Business Assistance Program	62-210.220, F.A.C.	X			Contains no applicable requirements.

Table A-2. Summary of FDEP Regulatory Applicability and Corresponding Requirements (Page 4 of 12)

Regulation	Citation	Not Applicable	Applicable: Facility-Wide	Applicable: Emission Units	Applicable Requirement or Non-Applicability Rationale
Permits Required	62-210.300(1) and (3), F.A.C.		X		Air construction permit required. Exemptions from permitting specified for certain facilities and sources.
Permits Required	62-210.300(2), F.A.C.		X		Air operation permit required. (future requirement)
Air General Permits	62-210.300(4), F.A.C.	X			Not applicable to the Bayside combined cycle CTs.
Notification of Startup	62-210.300(5), F.A.C.	X			Sources which have been shut down for more than one year shall notify the FDEP prior to startup.
Emission Unit Reclassification	62-210.300(6), F.A.C.		X		Emission unit reclassification (potential future requirement)
Public Notice and Comment					
Public Notice of Proposed Agency Action	62-210.350(1), F.A.C.		X		All permit applicants required to publish notice of proposed agency action.
Additional Notice Requirements for Sources Subject to Prevention of Significant Deterioration or Nonattainment Area New Source Review	62-210.350(2), F.A.C.		X		Additional public notice requirements for PSD and nonattainment area NSR applications.
Additional Public Notice Requirements for Sources Subject to Operation Permits for Title V Sources	62-210.350(3), F.A.C.		X		Notice requirements for Title V operating permit applicants (future requirement).
Public Notice Requirements for FESOPS and 112(g) Emission Sources	62-210.350(4) and (5), F.A.C.	X			Not applicable to the Bayside combined cycle CTs.
Administrative Permit Corrections	62-210.360, F.A.C.	X			An administrative permit correction is not requested in this application.

Table A-2. Summary of FDEP Regulatory Applicability and Corresponding Requirements (Page 5 of 12)

Regulation	Citation	Not Applicable	Applicable: Facility-Wide	Applicable: Emission Units	Applicable Requirement or Non-Applicability Rationale
Reports					
Notification of Intent to Relocate Air Pollutant Emitting Facility	62-210.370(1), F.A.C.	X			Project does not have any relocatable emission units.
Annual Operating Report for Air Pollutant Emitting Facility	62-210.370(3), F.A.C.		X		Specifies annual reporting requirements. (future requirement).
Stack Height Policy	62-210.550, F.A.C.		X		Limits credit in air dispersion studies to good engineering practice (GEP) stack heights for stacks constructed or modified since 12/31/70.
Circumvention	62-210.650, F.A.C.		X		An applicable air pollution control device cannot be circumvented and must be operated whenever the emission unit is operating.
Excess Emissions	62-210.700(1), F.A.C.		X		Excess emissions due to startup, shut down, and malfunction are permitted for no more than two hours in any 24 hour period unless specifically authorized by the FDEP for a longer duration. Excess emissions for up to 18 hours in a 24 hour period are specifically requested for the Bayside combined cycle CTs. See Section 2.2 of the PSD permit application for details.
Excess Emissions	62-210.700(2) and (3), F.A.C.	X			Not applicable to the Bayside combined cycle CTs.

Table A-2. Summary of FDEP Regulatory Applicability and Corresponding Requirements (Page 6 of 12)

Regulation	Citation	Not Applicable	Applicable: Facility-Wide	Applicable: Emission Units	Applicable Requirement or Non-Applicability Rationale
Excess Emissions	62-210.700(4), F.A.C.		X		Excess emissions caused entirely or in part by poor maintenance, poor operations, or any other equipment or process failure which may reasonably be prevented during startup, shutdown, or malfunction are prohibited. (potential future requirement) .
Excess Emissions	62-210.700(5), F.A.C.	X			Contains no applicable requirements.
Excess Emissions	62-210.700(6), F.A.C.		X		Excess emissions resulting from malfunctions must be reported to the FDEP in accordance with 62-4.130, F.A.C. (potential future requirement) .
Forms and Instructions	62-210.900, F.A.C.		X		Contains AOR requirements.
Notification Forms for Air General Permits	62-210.920, F.A.C.	X			Contains no applicable requirements.
Chapter 62-212, F.A.C. - Stationary Sources - Preconstruction Review					
Purpose and Scope	62-212.100, F.A.C.	X			Contains no applicable requirements.
General Preconstruction Review Requirements	62-212.300, F.A.C.		X		General air construction permit requirements.
Prevention of Significant Deterioration	62-212.400, F.A.C.		X		PSD permit required prior to construction of Project.
New Source Review for Nonattainment Areas	62-212.500, F.A.C.	X			Project is not located in a nonattainment area or a nonattainment area of influence.
Sulfur Storage and Handling Facilities	62-212.600, F.A.C.	X			Applicable only to sulfur storage and handling facilities.

Table A-2. Summary of FDEP Regulatory Applicability and Corresponding Requirements (Page 7 of 12)

Regulation	Citation	Not Applicable	Applicable: Facility- Wide	Applicable: Emission Units	Applicable Requirement or Non-Applicability Rationale
Air Emissions Bubble	62-212.710, F.A.C.	X			Not applicable to the Bayside combined cycle CTs.
Chapter 62-213, F.A.C. - Operation Permits for Major Sources of Air Pollution					
Purpose and Scope	62-213.100, F.A.C.	X			Contains no applicable requirements.
Annual Emissions Fee	62-213.205(1), (4), and (5), F.A.C.		X		Annual emissions fee and documentation requirements. (future requirement)
Annual Emissions Fee	62-213.205(2) and (3), F.A.C.	X			Contains no applicable requirements.
Title V Air General Permits	62-213.300, F.A.C.	X			No eligible facilities
Permits and Permit Revisions Required	62-213.400, F.A.C.		X		Title V operation permit required. (future requirement)
Changes Without Permit Revision	62-213.410, F.A.C.		X		Certain changes may be made if specific notice and recordkeeping requirements are met (potential future requirement) .
Immediate Implementation Pending Revision Process	62-213.412, F.A.C.		X		Certain modifications can be implemented pending permit revision if specific criteria are met (potential future requirement) .
Fast-Track Revisions of Acid Rain Parts	62-213.413, F.A.C.			CT 1A-2D	Optional provisions for Acid Rain permit revisions (potential future requirement) .
Trading of Emissions within a Source	62-213.415, F.A.C.	X			Applies only to facilities with a federally enforceable emissions cap.
Permit Applications	62-213.420(1)(a)2. and (1)(b), (2), (3), and (4), F.A.C.		X		Title V operating permit application required no later than 180 days after commencing operation. (future requirement)

Table A-2. Summary of FDEP Regulatory Applicability and Corresponding Requirements (Page 8 of 12)

Regulation	Citation	Not Applicable	Applicable: Facility-Wide	Applicable: Emission Units	Applicable Requirement or Non-Applicability Rationale
Permit Issuance, Renewal, and Revision					
Action on Application	62-213.430(1), F.A.C.	X			Contains no applicable requirements.
Permit Denial	62-213.430(2), F.A.C.	X			Contains no applicable requirements.
Permit Renewal	62-213.430(3), F.A.C.		X		Permit renewal application requirements (future requirement).
Permit Revision	62-213.430(4), F.A.C.		X		Permit revision application requirements (potential future requirement).
EPA Recommended Actions	62-213.430(5), F.A.C.	X			Contains no applicable requirements.
Insignificant Emission Units	62-213.430(6), F.A.C.	X			Contains no applicable requirements.
Permit Content	62-213.440, F.A.C.	X			Agency procedures, contains no applicable requirements.
Permit Review by EPA and Affected States	62-213.450, F.A.C.	X			Agency procedures, contains no applicable requirements.
Permit Shield	62-213.460, F.A.C.		X		Provides permit shield for facilities in compliance with permit terms and conditions. (future requirement)
Forms and Instructions	62-213.900, F.A.C.		X		Contains annual emissions fee form requirements.
Chapter 62-214—Requirements for Sources Subject to the Federal Acid Rain Program					
Purpose and Scope	§62-214.100, F.A.C.	X			Contains no applicable requirements.
Applicability	§62-214.300, F.A.C.		X		Project includes Acid Rain affected units, therefore compliance with §62-213 and §62-214, F.A.C., is required.

Table A-2. Summary of FDEP Regulatory Applicability and Corresponding Requirements (Page 9 of 12)

Regulation	Citation	Not Applicable	Applicable: Facility-Wide	Applicable: Emission Units	Applicable Requirement or Non-Applicability Rationale
Applications	§62-214.320, F.A.C.			CT 1A-2D	Acid Rain application requirements. Application for new units are due at least 24 months before the later of 1/1/2000 or the date on which the unit commences operation. (future requirement)
Acid Rain Compliance Plan and Compliance Options	§62-214.330(1)(a), F.A.C.			CT 1A-2D	Acid Rain compliance plan requirements. Sulfur dioxide requirements become effective the later of 1/1/2000 or the deadline for CEMS certification pursuant to 40 CFR Part 75. (future requirement)
Exemptions	§62-214.340, F.A.C.		X		An application may be submitted for certain exemptions (potential future requirement) .
Certification	§62-214.350, F.A.C.			CT 1A-2D	The designated representative must certify all Acid Rain submissions. (future requirement)
Department Action on Applications	§62-214.360, F.A.C.	X			Contains no applicable requirements.
Revisions and Administrative Corrections	§62-214.370, F.A.C.			CT 1A-2D	Defines revision procedures and automatic amendments (potential future requirement) ..
Acid Rain Part Content	§62-214.420, F.A.C.	X			Agency procedures, contains no applicable requirements.
Implementation and Termination of Compliance Options	§62-214.430, F.A.C.			CT 1A-2D	Defines permit activation and termination procedures (potential future requirement) .
Chapter 62-242 - Motor Vehicle Standards and Test Procedures	62-242, F.A.C.	X			Not applicable to the Bayside combined cycle CTs.

Table A-2. Summary of FDEP Regulatory Applicability and Corresponding Requirements (Page 10 of 12)

Regulation	Citation	Not Applicable	Applicable: Facility-Wide	Applicable: Emission Units	Applicable Requirement or Non-Applicability Rationale
Chapter 62-243 - Tampering with Motor Vehicle Air Pollution Control Equipment	62-243, F.A.C.	X			Not applicable to the Bayside combined cycle CTs.
Chapter 62-252 - Gasoline Vapor Control	62-252, F.A.C.	X			Not applicable to the Bayside combined cycle CTs.
Chapter 62-256 - Open Burning and Frost Protection Fires					
Declaration and Intent	62-256.100, F.A.C.	X			Contains no applicable requirements.
Definitions	62-256.200, F.A.C.	X			Contains no applicable requirements.
Prohibitions	62-256.300, F.A.C.¹		X		Prohibits open burning.
Burning for Cold and Frost Protection	62-256.450, F.A.C.	X			Limited to agricultural protection.
Land Clearing	62-256.500, F.A.C.¹		X		Defines allowed open burning for non-rural land clearing and structure demolition.
Industrial, Commercial, Municipal, and Research Open Burning	62-256.600, F.A.C.¹		X		Prohibits industrial open burning
Open Burning allowed	62-256.700, F.A.C.		X		Specifies allowable open burning activities. (potential future requirement)
Effective Date	62-256.800, F.A.C.	X			Contains no applicable requirements.
Chapter 62-257 - Asbestos Fee	62-257, F.A.C.	X			Not applicable to the Bayside combined cycle CTs.
Chapter 62-281 - Motor Vehicle Air Conditioning Refrigerant Recovery and Recycling	62-281, F.A.C.	X			Not applicable to the Bayside combined cycle CTs.

Table A-2. Summary of FDEP Regulatory Applicability and Corresponding Requirements (Page 11 of 12)

Regulation	Citation	Not Applicable	Applicable: Facility-Wide	Applicable: Emission Units	Applicable Requirement or Non-Applicability Rationale
Chapter 62-296 - Stationary Source - Emission Standards					
Purpose and Scope	62-296.100, F.A.C.	X			Contains no applicable requirements
General Pollutant Emission Limiting Standard, Volatile Organic Compounds Emissions	62-296.320(1), F.A.C.		X		Known and existing vapor control devices must be applied as required by the Department.
General Pollutant Emission Limiting Standard, Objectionable Odor Prohibited	62-296.320(2), F.A.C.		X		Objectionable odor release is prohibited.
General Pollutant Emission Limiting Standard, Industrial, Commercial, and Municipal Open Burning Prohibited	62-296.320(3), F.A.C. ¹		X		Open burning in connection with industrial, commercial, or municipal operations is prohibited.
General Particulate Emission Limiting Standard, Process Weight Table	62-296.320(4)(a), F.A.C.	X			Project does not have any applicable emission units. Combustion emission units are exempt per 62-296.320(4)(a)1a.
General Particulate Emission Limiting Standard, General Visible Emission Standard	62-296.320(4)(b), F.A.C.		X		Opacity limited to 20 percent, unless otherwise permitted. Test methods specified.
General Particulate Emission Limiting Standard, Unconfined Emission of Particulate Matter	62-296.320(4)(c), F.A.C.		X		Reasonable precautions must be taken to prevent unconfined particulate matter emission.
Specific Emission Limiting and Performance Standards	62-296.401 through 62-296.417, F.A.C.	X			None of the referenced standards are applicable to the Bayside combined cycle CTs.
Reasonably Available Control Technology (RACT) Volatile Organic Compounds (VOC) and Nitrogen Oxides (NO _x) Emitting Facilities	62-296.500 through 62-296.516, F.A.C.	X			Project is not located in an ozone nonattainment area or an ozone air quality maintenance area.

Table A-2. Summary of FDEP Regulatory Applicability and Corresponding Requirements (Page 12 of 12)

Regulation	Citation	Not Applicable	Applicable: Facility-Wide	Applicable: Emission Units	Applicable Requirement or Non-Applicability Rationale
Reasonably Available Control Technology (RACT) - Requirements for Major VOC- and NO _x -Emitting Facilities	62-296.570, F.A.C.	X			Project is not located in a specified ozone nonattainment area or a specified ozone air quality maintenance area (i.e., is not located in Broward, Dade or Palm Beach Counties)
Reasonably Available Control Technology (RACT) - Lead	62-296.600 through 62-296.605, F.A.C.	X			Project is not located in a lead nonattainment area or a lead air quality maintenance area.
Reasonably Available Control Technology (RACT)—Particulate Matter	§62-296.700 through 62-296.712, F.A.C.	X			Project is not located in a PM nonattainment area or a PM air quality maintenance area.
Chapter 62-297 - Stationary Sources - Emissions Monitoring					
Purpose and Scope	62-297.100, F.A.C.	X			Contains no applicable requirements.
General Compliance Test Requirements	62-297.310, F.A.C.		X		Specifies general compliance test requirements.
Compliance Test Methods	62-297.401, F.A.C.	X			Contains no applicable requirements.
Supplementary Test Procedures	62-297.440, F.A.C.	X			Contains no applicable requirements.
EPA VOC Capture Efficiency Test Procedures	62-297.450, F.A.C.	X			Not applicable to the Bayside combined cycle CTs.
CEMS Performance Specifications	62-297.520, F.A.C.	X			Contains no applicable requirements.
Exceptions and Approval of Alternate Procedures and Requirements	62-297.620, F.A.C.	X			Exceptions or alternate procedures have not been requested.

¹ - State requirement only; not federally enforceable.

Source: ECT, 2000.

ATTACHMENT A-2
FUEL ANALYSES OR SPECIFICATIONS

Typical Natural Gas Composition

Component	Mole Percent (by volume)
<u>Gas Composition</u>	
Hexane+	0.018
Propane	0.190
I-butane	0.010
N-butane	0.007
Pentane	0.002
Nitrogen	0.527
Methane	96.195
CO ₂	0.673
Ethane	2.379
<u>Other Characteristics</u>	
Heat content (HHV)	1,020 Btu/ft ³ with 14.73 psia, dry
Real specific gravity	0.5776
Sulfur content (maximum)	2.0 gr/100 scf

Note: Btu/ft³ = British thermal units per cubic foot.
psia = pounds per square inch absolute.
gr/100 scf = grains per 100 standard cubic foot.

Source: TEC, 2000.

Typical No. 2 Fuel Oil Analysis

Parameter	Value
Specific gravity @ 60EF (maximum)	0.876
Viscosity, saybolt (SUS) @ 100EF	
Minimum	40.2
Maximum	32.6
Flash point, EF (minimum)	100
Pour point, EF (minimum)	0
Minimum gross heating value, Btu/lb	
LHV	18,550
HHV	19,626
Water and sediment, percent by volume (maximum)	0.05
Ash, percent by weight (maximum)	0.01
Sulfur, percent by weight (maximum)	0.05
Fuel-bound nitrogen, percent by weight (maximum)	0.015
Trace constituents, ppm (maximum)	
Lead	1.0
Sodium	1.0
Vanadium	0.5

Note: SUS = Saybolt Universal Seconds.
Btu/gal = British thermal units per gallon.
LHV = lower heating value.
HHV = higher heating value.

Source: TEC, 2000.



ATTACHMENT B

**NITROGEN OXIDES
CONTROL SYSTEM DESCRIPTIONS**

NITROGEN OXIDES CONTROL SYSTEM DESCRIPTIONS

A. Selective Catalytic Reduction

Selective catalytic reduction (SCR) technology will be used to control NO_x emissions from Bayside Units 1 and 2. SCR reduces NO_x emissions by reacting ammonia (NH₃) with exhaust gas NO_x to yield nitrogen and water vapor in the presence of a catalyst. NH₃ is injected upstream of the catalyst bed where the following primary reactions take place:



The catalyst serves to lower the activation energy of these reactions, which allows the NO_x conversions to take place at a lower temperature (i.e., in the range of 600 to 750°F). Typical SCR catalysts include metal oxides (titanium oxide and vanadium), noble metals (combinations of platinum and rhodium), zeolite (alumino-silicates), and ceramics.

Reaction temperature is critical for proper SCR operation. The optimum temperature range for conventional SCR operation is 600 to 750°F. Below this temperature range, reduction reactions (1) and (2) will not proceed. At temperatures exceeding the optimal range, oxidation of NH₃ will take place resulting in an increase in NO_x emissions. Due to these temperature constraints, the SCR catalyst modules will be located in the appropriate section of the HRSGs where temperatures are suitable for proper SCR operation.

A NH₃ injection grid will be located in the HRSG downstream of the high pressure steam drum and upstream of the SCR catalyst modules. This injection grid will be utilized to inject anhydrous ammonia into the CT exhaust stream. The NH₃ and NO_x (i.e., NO and NO₂) in the exhaust stream will then be adsorbed on the surface of the SCR catalyst and react catalytically to form N₂ and H₂O per reactions (1) and (2) above. The N₂ and H₂O formed is subsequently desorbed and discharged to the atmosphere with the CT exhaust stream.

The reaction of NO_x with NH₃ theoretically requires a 1:1 molar ratio. NH₃/NO_x molar ratios greater than 1:1 are necessary to achieve high-NO_x removal efficiencies due to imperfect mixing and other reaction limitations. However, NH₃/NO_x molar ratios are typically maintained at 1:1 or lower to prevent excessive unreacted NH₃ (ammonia slip) emissions. The Bayside Units 1 and 2 SCR control systems are designed to achieve a maximum ammonia slip rate of 10 ppmvd at 15 percent O₂.

B. SCONO_xTM

As an alternative to SCR, one Bayside Unit 1 or 2 CT/HRSG unit may be equipped with SCONO_xTM technology. SCONO_xTM is a NO_x and CO control system offered by ABB Alstom Power Environmental Segment (AAP) under an exclusive license agreement with Goal Line Environmental Technologies (GLET). GLET is a partnership formed by Sunlaw Energy Corporation and Advanced Catalyst Systems, Inc.


The SCONO_xTM system employs a single catalyst to simultaneously oxidize CO to CO₂ and NO to NO₂. NO₂ formed by the oxidation of NO is subsequently absorbed onto the catalyst surface through the use of a potassium carbonate absorber coating. The SCONO_xTM oxidation/absorption cycle reactions are:



CO₂ produced by reactions (3) and (5) is released to the atmosphere as part of the CTG/HRSG exhaust stream.

As shown in reaction (5), the potassium carbonate catalyst coating reacts with NO₂ to form potassium nitrites and nitrates. Prior to saturation of the potassium carbonate coating, the catalyst must be regenerated. This regeneration is accomplished by passing a dilute hydrogen-reducing gas across the surface of the catalyst in the absence of O₂. Hydrogen in the reducing gas reacts with the nitrites and nitrates to form water and elemental nitrogen. CO₂ in the regeneration gas reacts with potassium nitrites and nitrates to form potassium carbonate; this compound is the catalyst absorber coating present on the


surface of the catalyst at the start of the oxidation/absorption cycle. The SCONO_xTM regeneration cycle reaction is:



Water vapor and elemental nitrogen are released to the atmosphere as part of the CTG/HRSG exhaust stream. Following regeneration, the SCONO_xTM catalyst has a fresh coating of potassium carbonate, allowing the oxidation/absorption cycle to begin again. There is no net gain or loss of potassium carbonate after both the oxidation/absorption and regeneration cycles have been completed.

Since the regeneration cycle must take place in an oxygen-free environment, the section of catalyst undergoing regeneration is isolated from the exhaust gas stream using a set of louvers. Each catalyst section is equipped with a set of upstream and downstream louvers. During the regeneration cycle, these louvers close and valves open allowing fresh regeneration gas to enter and spent regeneration gas to exit the catalyst section being regenerated. At any given time, 80 percent of the catalyst sections will be in the oxidation/absorption cycle, while 20 percent will be in regeneration mode. A regeneration cycle is typically set to last for 3 to 8 minutes.

The SCONO_xTM operates at a temperature range of 300 to 700°F and, therefore, must be installed in the appropriate temperature section of a HRSG. For installations below 450°F, the SCONO_xTM system uses an inert gas generator for the production of hydrogen and carbon dioxide. The regeneration gas is diluted to under 4-percent hydrogen using steam as a carrier gas; the typical system is designed for 2 percent hydrogen. The regeneration gas reaction is:



For installations above 450°F, the SCONO_xTM catalyst is regenerated by introducing a small quantity of natural gas with a carrier gas, such as steam, over a steam reforming catalyst and then to the SCONO_xTM catalyst. The reforming catalyst initiates the conversion of methane to hydrogen, and the conversion is completed over the SCONO_xTM catalyst. The reformer catalyst works to partially reform the methane gas to hydrogen

(2 percent by volume) to be used in the regeneration of the SCONO_xTM and SCOSO_xTM catalysts. The reformer converts methane to hydrogen by the steam reforming reaction as shown by the following equation:




The reformer catalyst is placed upstream of the SCONO_xTM catalyst in a steam reformer reactor. The reformer catalyst is designed for a minimum 50-percent conversion of methane to hydrogen.

A gradual decrease in catalyst temperature is indicative of sulfur masking. AAP recommends the installation of a sulfur filter to reduce the rate of catalyst masking. The sulfur filter is placed in the inlet natural gas feed prior to the regeneration production skid. The sulfur filter consists of impregnated granular activated carbon that is housed in a stainless steel vessel. Spent media is discarded as a non-hazardous waste.

The SCONO_xTM system catalyst is subject to reduced performance and deactivation due to exposure to sulfur oxides. As necessary, an additional catalytic oxidation/absorption system (SCOSO_xTM) to remove sulfur compounds is installed upstream of the SCONO_xTM catalyst. The SCOSO_xTM sulfur removal catalyst utilizes the same oxidation/absorption cycle and a regeneration cycle as the SCONO_xTM system. During regeneration of the SCOSO_xTM catalyst, either H₂SO₄ mist or SO₂ is released to the atmosphere as part of the CTG/HRSG exhaust gas stream. The absorption portion of the SCOSO_xTM process is proprietary. SCOSO_xTM oxidation/absorption and regeneration reactions are:



(below 500°F)



(above 500°F)

A programmable logic controller (PLC) controls the SCONO_xTM/ SCOSO_xTM system. The controller is programmed to control all essential SCONO_xTM/ SCOSO_xTM functions including the opening and closing of louver doors and regeneration gas inlet and outlet valves, and the maintaining of regeneration gas flow to achieve positive pressure in each section during the regeneration cycle.

Utility materials needed for the operation of the SCONO_xTM/ SCOSO_xTM control system include ambient air, natural gas, water, steam, and electricity. The primary utility material is natural gas used for regeneration gas production. Steam is used as the carrier/dilution gas for the regeneration gas. Electricity is required to operate the computer control system, control valves, and louver actuators.

Commercial experience to date with the SCONO_xTM control system is limited to several small, combined-cycle power plants located in California. Representative of these small power plants is a GE LM2500 turbine, owned by GLET partner Sunlaw Energy Corporation, equipped with water injection to control NO_x emissions to approximately 25 ppmvd. The SCONO_xTM control system was installed at the Sunlaw Energy facility in December 1996 and has achieved a NO_x exhaust concentration of 3.5 parts per million by volume (ppmv) resulting in an approximate 85-percent NO_x removal efficiency. Following a 1 year scale-up developmental program, on December 1, 1999, AAP announced the commercial availability of the SCONO_xTM for large-scale natural gas-fired CTGs, particularly F-Class units. Although considered commercially available for large natural gas-fired CTGs, there are currently no CTGs larger than 32-MW that have demonstrated successful application of the SCONO_xTM control technology.

ATTACHMENT C
EMISSION RATE CALCULATIONS

**Table 1. Bayside Station - Units 1 and 2
Operating Scenarios - General Electric PG7241 (FA) CTs**

Case	Ambient Temperature (oF)	Load (%)	CT 1A-1C CT 2A-2D Combined Cycle	Annual Profile (hr/yr)	Evaporative Cooling	Natural Gas Firing	Fuel Oil Firing
1	18	100	X			X	X
2	18	75	X			X	X
3	18	50	X			X	X
4	59	100	X	7,884 (Gas); 876 (Oil)		X	X
5	59	75	X			X	X
6	59	50	X			X	X
7	72	100	X		X	X	X
8	72	75	X			X	X
9	72	50	X			X	X
10	93	100	X		X	X	X
11	93	75	X			X	X
12	93	50	X			X	X

Sources: TEC, 2000.
ECT, 2000.

**Table 2. Bayside Station - Units 1 and 2
Hourly Emission Rates - Natural Gas-Firing
General Electric 7FA CTs (Per CT)**

Temp. (°F)	Case	Load (%)	PM/PM ₁₀ ^(a)		SO ₂ ^(b)		H ₂ SO ₄ ^(c)		Lead ^(d)	
			(lb/hr)	(g/sec)	(lb/hr)	(g/sec)	(lb/hr)	(g/sec)	(lb/hr)	(g/sec)
18	1	100	20.5	2.58	10.7	1.35	2.0	0.25	0.0299	0.00377
	2	75	20.0	2.52	8.7	1.09	1.6	0.20	0.0243	0.00306
	3	50	19.6	2.47	7.0	0.88	1.3	0.16	0.0195	0.00245
59	4	100	20.3	2.56	10.0	1.26	1.8	0.23	0.0279	0.00352
	5	75	19.9	2.51	8.2	1.03	1.5	0.19	0.0228	0.00287
	6	50	19.5	2.46	6.5	0.82	1.2	0.15	0.0183	0.00231
72	7	100	20.3	2.56	9.8	1.23	1.8	0.23	0.0273	0.00344
	8	75	19.8	2.49	7.9	1.00	1.5	0.18	0.0222	0.00280
	9	50	19.5	2.46	6.4	0.80	1.2	0.15	0.0178	0.00224
93	10	100	20.2	2.55	9.5	1.19	1.7	0.22	0.0265	0.00334
	11	75	19.7	2.48	7.5	0.95	1.4	0.17	0.0211	0.00265
	12	50	19.4	2.44	6.0	0.76	1.1	0.14	0.0169	0.00213
Maximums			20.5	2.58	10.7	1.35	2.0	0.25	0.0299	0.00377

Temp. (°F)	Case	Load (%)	NO _x			CO			VOC		
			(ppmvd) ^(e)	(lb/hr)	(g/sec)	(ppmvd) ^(e)	(lb/hr)	(g/sec)	(ppmvd) ^{(e)(f)}	(lb/hr) ^(g)	(g/sec)
18	1	100	3.5	24.7	3.11	7.2	31.1	3.92	1.2	3.0	0.38
	2	75	3.5	19.9	2.51	7.1	24.6	3.10	1.2	2.4	0.30
	3	50	3.5	15.8	1.99	7.4	20.4	2.57	1.3	2.0	0.25
59	4	100	3.5	23.1	2.91	7.2	28.7	3.62	1.2	2.8	0.35
	5	75	3.5	18.7	2.36	7.2	23.5	2.96	1.2	2.3	0.29
	6	50	3.5	14.8	1.86	7.6	19.5	2.46	1.3	1.9	0.24
72	7	100	3.5	22.6	2.85	7.1	27.8	3.50	1.2	2.7	0.34
	8	75	3.5	18.2	2.29	7.2	22.8	2.87	1.2	2.2	0.28
	9	50	3.5	14.4	1.81	7.6	19.1	2.41	1.3	1.8	0.23
93	10	100	3.5	21.9	2.76	7.1	26.9	3.39	1.2	2.7	0.34
	11	75	3.5	17.2	2.17	7.3	21.9	2.78	1.3	2.2	0.28
	12	50	3.5	13.7	1.73	7.8	18.6	2.34	1.3	1.8	0.23
Maximums			3.5	24.7	3.11	7.8	31.1	3.92	1.3	3.0	0.38

^(a) As measured by EPA Reference Methods 201 and 202..

^(b) Based on natural gas sulfur content of 2.0 gr/100 ft³.

^(c) Based on 8.0% conversion of fuel S to SO₃ (CT), 4.0% conversion of SO₂ to SO₃ (SCR), and 100% conversion of SO₃ to H₂SO₄.

^(d) AP-42, EPA, May 1998 - Draft.

^(e) Corrected to 15% O₂.

^(f) Non-methane, non-ethane.

^(g) Expressed as methane.

Sources: ECT, 2000.
S&L, 2000.

**Table 3. Bayside Station - Units 1 and 2
Hourly Emission Rates - Distillate Fuel Oil-Firing
General Electric 7FA CTs (Per CT)**

Temp. (°F)	Case	Load (%)	PM/PM ₁₀ ^(a)		SO ₂ ^(b)		H ₂ SO ₄ ^(c)		Lead ^(d)	
			(lb/hr)	(g/sec)	(lb/hr)	(g/sec)	(lb/hr)	(g/sec)	(lb/hr)	(g/sec)
18	1	100	53.8	6.78	104.6	13.17	16.0	2.02	0.104	0.0131
	2	75	50.0	6.30	84.3	10.62	12.9	1.63	0.084	0.0106
	3	50	46.7	5.88	66.9	8.43	10.3	1.29	0.067	0.0084
59	4	100	52.6	6.63	98.2	12.38	15.0	1.90	0.098	0.0123
	5	75	49.1	6.19	79.4	10.00	12.2	1.53	0.079	0.0100
	6	50	46.0	5.80	63.2	7.97	9.7	1.22	0.063	0.0079
72	7	100	52.2	6.58	96.0	12.10	14.7	1.85	0.096	0.0121
	8	75	48.7	6.14	77.4	9.75	11.8	1.49	0.077	0.0097
	9	50	45.7	5.76	61.5	7.75	9.4	1.19	0.061	0.0077
93	10	100	51.6	6.50	92.9	11.70	14.2	1.79	0.093	0.0117
	11	75	47.9	6.04	73.5	9.25	11.2	1.42	0.073	0.0092
	12	50	45.1	5.68	58.3	7.35	8.9	1.13	0.058	0.0073
Maximums			53.8	6.78	104.6	13.17	16.0	2.02	0.104	0.0131

Temp. (°F)	Case	Load (%)	NO _x			CO			VOC		
			(ppmvd) ^(e)	(lb/hr)	(g/sec)	(ppmvd) ^(e)	(lb/hr)	(g/sec)	(ppmvd) ^{(e)(f)}	(lb/hr) ^(g)	(g/sec)
18	1	100	16.4	132.3	16.67	14.2	70.0	8.82	2.8	7.8	0.98
	2	75	16.4	105.6	13.31	16.5	64.6	8.14	2.7	6.0	0.76
	3	50	16.4	83.1	10.47	24.0	74.1	9.34	2.8	5.0	0.63
59	4	100	16.4	124.2	15.65	14.0	64.5	8.13	2.8	7.3	0.92
	5	75	16.4	99.4	12.52	16.0	59.3	7.47	2.7	5.8	0.73
	6	50	16.4	78.5	9.89	24.5	71.4	9.00	2.9	4.8	0.60
72	7	100	16.4	121.6	15.32	13.8	62.5	7.88	2.8	7.1	0.89
	8	75	16.4	96.9	12.21	16.1	58.1	7.32	2.8	5.7	0.72
	9	50	16.4	76.3	9.61	26.3	74.6	9.40	2.9	4.8	0.60
93	10	100	16.4	117.6	14.82	13.9	60.4	7.61	2.8	6.9	0.87
	11	75	16.4	91.9	11.58	16.4	56.1	7.07	2.8	5.5	0.69
	12	50	16.4	72.2	9.10	30.3	81.3	10.24	3.0	4.7	0.59
Maximums			16.4	132.3	16.67	30.3	81.3	10.24	3.0	7.8	0.98

^(a) As measured by EPA Reference Methods 201 and 202..

^(b) Based on distillate fuel oil sulfur content of 0.05-percent by weight.

^(c) Based on 6.0% conversion of fuel S to SO₃ (CT), 4.0% conversion of SO₂ to SO₃ (SCR), and 100% conversion of SO₃ to H₂SO₄.

^(d) Based on 1.0 ppmw lead content of fuel oil, S&L, 2000.

^(e) Corrected to 15% O₂.

^(f) Non-methane, non-ethane.

^(g) Expressed as methane.

Sources: ECT, 2000.
S&L, 2000.

HAZARDOUS AIR POLLUTANT EMISSION FACTORS

Section 3.1 of AP-42, Stationary Gas Turbines, was revised in April 2000 to include natural gas-fired combustion turbine (CT) emission factors for eleven hazardous air pollutants (HAPs), including formaldehyde and toluene. The April 2000 AP-42 formaldehyde and toluene emission factors for natural gas-fired CTs are 7.1×10^{-4} and 1.3×10^{-4} lb/10⁶ Btu, respectively.

As stated in the introduction to AP-42, the emission factors in AP-42 are “simply averages of all available data of acceptable quality, and are generally assumed to be representative of long-term averages for all facilities in the source category (i.e., a population average)”. Accordingly, the emission factors in AP-42 are generally appropriate for use in making areawide emission inventories. Because the AP-42 emission factors represent a source category population average, the factors do not necessarily reflect the emission rates for any particular member of that source category population.

In the case of the formaldehyde emission factor for natural gas-fired CTs, the April 2000 AP-42 emission factor is based on the average of 22 CT source tests. The CTs in the 22 source test database include small CTs (9 of the 22 CTs tested, or 40% of all units tested, had a rating of less than 15 MW), aircraft-derivative CTs (5 of the 22 CTs, or 23% of all units tested, were GE LM series aircraft-derivative CTs), and frame-type CTs. The largest CT of the 22 units tested was a GE Frame 7E unit with a rating of 87.8 MW. The average rating of the 22 CTs tested is 30.2 MW. The majority of the CTs tested were equipped with wet (water or steam) injection to control NO_x emissions.

The AP-42 CT test database shows considerable variability in formaldehyde emission factors. The maximum formaldehyde emission factor (5.61×10^{-3} lb/10⁶ Btu) is 2,538 times higher than the minimum factor (2.21×10^{-6} lb/10⁶ Btu). Six of the 22 test series include runs for which there were no detectable emissions of formaldehyde.

The CTs proposed for Bayside Units 1 and 2 are GE Frame 7FA units each rated at a nominal 166 MW. During natural gas-firing, dry low-NO_x (DLN) combustor and SCR control technology will be employed to control NO_x emissions. Accordingly, the average April 2000 AP-42 formaldehyde emission factor for natural gas-fired CTs is not considered applicable to the GE 7FA CT. The GE 7FA CT is 5.5 times larger (i.e., has a rating of 166 vs. 30.6 MW) than the average CT included in the AP-42 CT database and is equipped with DLN and SCR control technology.

Evaluation of the AP-42 CT formaldehyde source test database shows that six of the units tested were large, frame-type CTs. Emission factors for these six CTs were averaged to develop a formaldehyde emission factor which is considered to be more representative of the GE 7FA units. This average factor for frame-type CTs, 1.14×10^{-4} lb/10⁶ Btu, was used to estimate emissions of formaldehyde for Bayside Units 1 and 2 during natural gas-firing.

A similar analysis was conducted with respect to the April 2000 AP-42 toluene emission factor for natural gas-fired CTs. The April 2000 AP-42 toluene emission factor is based on the average of 7 CT source tests. The CTs in the 7 source test database include small CTs (3 of the 7 CTs tested, or 43% of all units tested, had a rating of less than 15 MW), aircraft-derivative CTs (2 of the 7 CTs, or 29% of all units tested, were GE LM series aircraft-derivative CTs), and frame-type CTs. The largest CT of the 7 units tested was a GE Frame 7 unit with a rating of 75 MW. The average rating of the 7 CTs tested is 26.6 MW. The majority of the CTs tested were equipped with wet (water or steam) injection to control NO_x emissions.

The AP-42 CT test database also shows variability in toluene emission factors. The maximum toluene emission factor (7.10×10^{-4} lb/10⁶ Btu) is 67.6 times higher than the minimum factor (1.05×10^{-5} lb/10⁶ Btu). Two of the 7 test series include runs for which there were no detectable emissions of toluene.

Evaluation of the AP-42 CT toluene source test database shows that two of the units tested were large, frame-type CTs. Emission factors for these two CTs were averaged to develop a toluene emission factor which is considered to be more representative of the GE 7FA units. This average factor for frame-type CTs, 6.80×10^{-5} lb/10⁶ Btu, was used to estimate emissions of toluene for Bayside Units 1 and 2 during natural gas-firing.

Average emission factors for frame-type CTs were developed for the remaining listed HAPs for natural gas-fired CTs using the same methodology as described above for formaldehyde and toluene.

Analysis of the April 2000 AP-42 HAP emission factors for distillate oil-fired CTs shows that essentially all of the emission factors were based on test data obtained from heavy duty frame-type CTs. Accordingly, estimates of HAP emissions for Bayside Units 1 and 2 were made using the April 2000 AP-42 factors without adjustments.

**Table 4A. Bayside Station - Units 1 and 2
Natural Gas-Firing: Hazardous Air Pollutants**

Parameter	Units	Case		
		100% - 18 °F	100% - 59 °F	100% - 93 °F
Maximum Hourly Fuel Flow:	10 ⁶ Btu/hr (HHV)	1,906.2	1,779.4	1,688.1
Maximum Annual Hours:	hrs/yr	N/A	8,760	N/A

Pollutant	Emission Factor ^{(a)(b)} (lb/10 ⁶ Btu)	Emission Rates (Per CT)				Unit 1 Annual (ton/yr)	Unit 2 Annual (ton/yr)
		18 °F	59 °F	93 °F	Annual		
		(lb/hr)	(lb/hr)	(lb/hr)	(ton/yr)		
1,3-Butadiene	6.05E-08	0.00012	0.00011	0.00010	0.00047	0.0014	0.0019
Acetaldehyde	4.31E-05	0.082	0.077	0.073	0.336	1.01	1.344
Acrolein	5.60E-06	0.011	0.010	0.009	0.044	0.13	0.175
Arsenic	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Benzene	1.83E-05	0.035	0.033	0.031	0.143	0.43	0.571
Beryllium	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Cadmium	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Chromium	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Ethylbenzene	2.28E-05	0.043	0.041	0.038	0.178	0.53	0.711
Formaldehyde	1.14E-04	0.217	0.203	0.192	0.888	2.67	3.554
Lead	1.46E-05	0.028	0.026	0.025	0.114	0.34	0.454
Manganese	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mercury	7.80E-10	0.0000015	0.0000014	0.0000013	0.0000061	0.000018	0.000024
Naphthalene	6.33E-07	0.0012	0.0011	0.0011	0.0049	0.015	0.020
Nickel	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Polycyclic Aromatic Hydrocarbons	4.71E-07	0.00090	0.00084	0.00080	0.0037	0.011	0.015
Propylene Oxide	2.86E-05	0.055	0.051	0.048	0.223	0.669	0.892
Selenium	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Toluene	6.80E-05	0.130	0.121	0.115	0.530	1.590	2.120
Xylene	6.51E-05	0.124	0.116	0.110	0.507	1.522	2.029
Maximum Individual HAP		0.217	0.203	0.192	0.888	2.665	3.554
Total HAPs		0.727	0.678	0.644	2.971	8.914	11.885

^(a) - Frame Type CTs > 40 MW from EPA AP-42, Section 3.1 Database, April 2000.

^(b) - Mercury emission factor, Florida Coordinating Group (FCG), 1995.

Source: ECT, 2000.

**Table 4B. Bayside Station - Units 1 and 2
Natural Gas-Firing: Hazardous Air Pollutants**

Parameter	Units	Case		
		100% - 18 °F	100% - 59 °F	100% - 93 °F
Maximum Hourly Fuel Flow:	10 ⁶ Btu/hr (HHV)	1,906.2	1,779.4	1,688.1
Maximum Annual Hours:	hrs/yr	N/A	7,884	N/A

Pollutant	Emission Factor ^{(a)(b)} (lb/10 ⁶ Btu)	Emission Rates (Per CT)				Unit 1 Annual (ton/yr)	Unit 2 Annual (ton/yr)
		18 °F	59 °F	93 °F	Annual		
		(lb/hr)	(lb/hr)	(lb/hr)	(ton/yr)		
1,3-Butadiene	6.05E-08	0.00012	0.00011	0.00010	0.00042	0.0013	0.0017
Acetaldehyde	4.31E-05	0.082	0.077	0.073	0.302	0.91	1.209
Acrolein	5.60E-06	0.011	0.010	0.009	0.039	0.12	0.157
Arsenic	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Benzene	1.83E-05	0.035	0.033	0.031	0.128	0.39	0.513
Beryllium	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Cadmium	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Chromium	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Ethylbenzene	2.28E-05	0.043	0.041	0.038	0.160	0.48	0.640
Formaldehyde	1.14E-04	0.217	0.203	0.192	0.800	2.40	3.199
Lead	1.46E-05	0.028	0.026	0.025	0.102	0.31	0.409
Manganese	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mercury	7.80E-10	0.0000015	0.0000014	0.0000013	0.0000055	0.000016	0.000022
Naphthalene	6.33E-07	0.0012	0.0011	0.0011	0.0044	0.013	0.018
Nickel	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Polycyclic Aromatic Hydrocarbons	4.71E-07	0.00090	0.00084	0.00080	0.0033	0.010	0.013
Propylene Oxide	2.86E-05	0.055	0.051	0.048	0.201	0.602	0.802
Selenium	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Toluene	6.80E-05	0.130	0.121	0.115	0.477	1.431	1.908
Xylene	6.51E-05	0.124	0.116	0.110	0.457	1.370	1.827
Maximum Individual HAP		0.217	0.203	0.192	0.800	2.399	3.199
Total HAPs		0.727	0.678	0.644	2.674	8.022	10.697

^(a) - Frame Type CTs > 40 MW from EPA AP-42, Section 3.1 Database, April 2000.

^(b) - Mercury emission factor, Florida Coordinating Group (FCG), 1995.

Source: ECT, 2000.

**Table 5. Bayside Station - Units 1 and 2
Distillate Fuel Oil-Firing: Hazardous Air Pollutants**

Parameter	Units	Case		
		100% - 18 °F	100% - 59 °F	100% - 93 °F
Maximum Hourly Fuel Flow:	10 ⁶ Btu/hr (HHV)	2,052.0	1,928.0	1,823.0
Maximum Annual Hours:	hrs/yr	N/A	876	N/A

Pollutant	Emission Factor ^{(a)(b)} (lb/10 ⁶ Btu)	Emission Rates (Per CT)				Unit 1 Annual (ton/yr)	Unit 2 Annual (ton/yr)
		18 °F	59 °F	93 °F	Annual		
		(lb/hr)	(lb/hr)	(lb/hr)	(ton/yr)		
1,3-Butadiene	1.60E-05	0.033	0.031	0.029	0.014	0.041	0.054
Acetaldehyde	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Acrolein	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Arsenic	1.10E-05	0.023	0.021	0.020	0.009	0.028	0.037
Benzene	5.50E-05	0.113	0.106	0.100	0.046	0.139	0.186
Beryllium	3.10E-07	0.00064	0.00060	0.00057	0.00026	0.00079	0.0010
Cadmium	4.80E-06	0.010	0.0093	0.0088	0.0041	0.012	0.016
Chromium	1.10E-05	0.023	0.021	0.020	0.009	0.028	0.037
Ethylbenzene	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Formaldehyde	2.80E-04	0.575	0.540	0.510	0.236	0.709	0.946
Lead	5.90E-05	0.121	0.114	0.108	0.050	0.149	0.199
Manganese	7.90E-04	1.621	1.523	1.440	0.667	2.001	2.668
Mercury	1.20E-06	0.0025	0.0023	0.0022	0.0010	0.0030	0.0041
Naphthalene	3.50E-05	0.072	0.067	0.064	0.030	0.089	0.118
Nickel	4.60E-06	0.0094	0.0089	0.0084	0.0039	0.012	0.016
Polycyclic Aromatic Hydrocarbons	4.00E-05	0.082	0.077	0.073	0.034	0.101	0.135
Propylene Oxide	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Selenium	2.50E-05	0.051	0.048	0.046	0.021	0.063	0.084
Toluene	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Xylene	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Maximum Individual HAP		1.621	1.523	1.440	0.667	2.001	2.668
Total HAPs		2.735	2.570	2.430	1.126	3.377	4.502

^(a) - Tables 3.1-4. And 3.1-5, EPA AP-42, April 2000.

^(b) - Lead emission factor, S&L, 2000.

Source: ECT, 2000.

**Table 6A. Bayside Station
Annual Emission Rates - Unit 1**

No. of CTs	Case	Annual Operations (hrs/yr)	Emission Rates					
			NO _x		CO		VOC	
			(lb/hr)	(tpy)	(lb/hr)	(tpy)	(lb/hr)	(tpy)
3	4 - NG	7,884	69.3	273.2	86.1	339.4	8.40	33.1
3	4 - Oil	876	372.6	163.2	193.5	84.8	21.90	9.6
		Totals	N/A	436.4	N/A	424.2	N/A	42.7

No. of CTs	Case	Annual Operations (hrs/yr)	Emission Rates							
			PM/PM ₁₀		SO ₂		H ₂ SO ₄		Lead	
			(lb/hr)	(tpy)	(lb/hr)	(tpy)	(lb/hr)	(tpy)	(lb/hr)	(tpy)
3	4 - NG	7,884	60.9	240.1	29.9	117.9	5.5	21.7	0.084	0.33
3	4 - Oil	876	157.8	69.1	294.7	129.1	45.1	19.8	0.294	0.13
		Totals	N/A	309.2	N/A	247.0	N/A	41.4	N/A	0.46

1. Three CTs operating with natural gas-firing for 7,884 hours/year at base load (Case 4).
2. Three CTs operating with distillate fuel oil-firing for 876 hours/year at base load (Case 4).
3. Natural gas SO₂ rates based on natural gas sulfur content of 2.0 gr/100 ft³.
4. Fuel oil SO₂ rates based on fuel oil sulfur content of 0.05 wt. percent.
5. Natural gas H₂SO₄ rates based on 8.0% conversion of fuel S to SO₃ (CT), 4.0% conversion of SO₂ to SO₃ (SCR), and 100% conversion of SO₃ to H₂SO₄.
6. Fuel oil H₂SO₄ rates based on 6.0% conversion of fuel S to SO₃ (CT), 4.0% conversion of SO₂ to SO₃ (SCR), and 100% conversion of SO₃ to H₂SO₄.

Sources: ECT, 2000.
S&L, 2000.
TEC, 2000.

**Table 6B. Bayside Station
Annual Emission Rates - Unit 2**

No. of CTs	Case	Annual Operations (hrs/yr)	Emission Rates					
			NO _x		CO		VOC	
			(lb/hr)	(tpy)	(lb/hr)	(tpy)	(lb/hr)	(tpy)
4	4 - NG	7,884	92.4	364.2	114.8	452.5	11.20	44.2
4	4 - Oil	876	496.8	217.6	258.0	113.0	29.20	12.8
		Totals	N/A	581.8	N/A	565.5	N/A	56.9

No. of CTs	Case	Annual Operations (hrs/yr)	Emission Rates							
			PM/PM ₁₀		SO ₂		H ₂ SO ₄		Lead	
			(lb/hr)	(tpy)	(lb/hr)	(tpy)	(lb/hr)	(tpy)	(lb/hr)	(tpy)
4	4 - NG	7,884	81.2	320.1	39.9	157.2	7.3	28.9	0.112	0.44
4	4 - Oil	876	210.4	92.2	392.9	172.1	60.2	26.4	0.392	0.17
		Totals	N/A	412.2	N/A	329.3	N/A	55.2	N/A	0.61

1. Three CTs operating with natural gas-firing for 7,884 hours/year at base load (Case 4).
2. Four CTs operating with distillate fuel oil-firing for 876 hours/year at base load (Case 4).
3. Natural gas SO₂ rates based on natural gas sulfur content of 2.0 gr/100 ft³.
4. Fuel oil SO₂ rates based on fuel oil sulfur content of 0.05 wt. percent.
5. Natural gas H₂SO₄ rates based on 8.0% conversion of fuel S to SO₃ (CT), 4.0% conversion of SO₂ to SO₃ (SCR), and 100% conversion of SO₃ to H₂SO₄.
6. Fuel oil H₂SO₄ rates based on 6.0% conversion of fuel S to SO₃ (CT), 4.0% conversion of SO₂ to SO₃ (SCR), and 100% conversion of SO₃ to H₂SO₄.

Sources: ECT, 2000.
S&L, 2000.
TEC, 2000.

**Table 6C. Bayside Station
Annual Emission Rates - Units 1 and 2**

No. of CTs	Case	Annual Operations (hrs/yr)	Emission Rates					
			NO _x		CO		VOC	
			(lb/hr)	(tpy)	(lb/hr)	(tpy)	(lb/hr)	(tpy)
7	4 - NG	7,884	161.7	637.4	200.9	791.9	19.60	77.3
7	4 - Oil	876	869.4	380.8	451.5	197.8	51.10	22.4
		Totals	N/A	1,018.2	N/A	989.7	N/A	99.6

No. of CTs	Case	Annual Operations (hrs/yr)	Emission Rates							
			PM/PM ₁₀		SO ₂		H ₂ SO ₄		Lead	
			(lb/hr)	(tpy)	(lb/hr)	(tpy)	(lb/hr)	(tpy)	(lb/hr)	(tpy)
7	4 - NG	7,884	142.1	560.2	69.8	275.1	12.8	50.6	0.195	0.77
7	4 - Oil	876	368.2	161.3	687.7	301.2	105.3	46.1	0.686	0.30
		Totals	N/A	721.4	N/A	576.3	N/A	96.7	N/A	1.07

1. Seven CTs operating with natural gas-firing for 7,884 hours/year at base load (Case 4).
2. Seven CTs operating with distillate fuel oil-firing for 876 hours/year at base load (Case 4).
3. Natural gas SO₂ rates based on natural gas sulfur content of 2.0 gr/100 ft³.
4. Fuel oil SO₂ rates based on fuel oil sulfur content of 0.05 wt. percent.
5. Natural gas H₂SO₄ rates based on 8.0% conversion of fuel S to SO₃ (CT), 4.0% conversion of SO₂ to SO₃ (SCR), and 100% conversion of SO₃ to H₂SO₄.
6. Fuel oil H₂SO₄ rates based on 6.0% conversion of fuel S to SO₃ (CT), 4.0% conversion of SO₂ to SO₃ (SCR), and 100% conversion of SO₃ to H₂SO₄.

Sources: ECT, 2000.
S&L, 2000.
TEC, 2000.

**Table 7. Bayside Station - Units 1 and 2
Annual Hazardous Air Pollutants Emission Rates**

Pollutant	Unit 1 Emissions (ton/yr)	Unit 2 Emissions (ton/yr)	Units 1 & 2 Emissions (ton/yr)
1,3-Butadiene	0.042	0.056	0.098
Acetaldehyde	1.008	1.344	2.351
Acrolein	0.131	0.175	0.306
Arsenic	0.028	0.037	0.065
Benzene	0.524	0.699	1.224
Beryllium	0.001	0.001	0.002
Cadmium	0.012	0.016	0.028
Chromium	0.028	0.037	0.065
Ethylbenzene	0.533	0.711	1.244
Formaldehyde	3.108	4.144	7.253
Lead	0.456	0.608	1.064
Manganese	2.001	2.668	4.670
Mercury	0.0031	0.0041	0.0071
Naphthalene	0.102	0.136	0.238
Nickel	0.012	0.016	0.027
Polycyclic Aromatic Hydrocarbons	0.111	0.148	0.260
Propylene Oxide	0.669	0.892	1.560
Selenium	0.063	0.084	0.148
Toluene	1.590	2.120	3.710
Xylene	1.522	2.029	3.552
Maximum Individual HAP	3.108	4.144	7.253
Total HAPs	11.944	15.926	27.870

Source: ECT, 2000.

**Table 8. Bayside Station - Units 1 and 2
Stack Parameters (Per CT/HRSG)
Natural Gas-Firing**

Stack Height: 150.0 ft Stack Area: 283.5 ft²
 45.7 m 26.3 m²

Stack Diameter: 19.0 ft
 5.8 m

Case	Temperature		Flow Rate (actual)		Velocity	
	(°F)	(K)	(ft ³ /min)	(m ³ /min)	(ft/sec)	(m/s)
1	233	385	1,128,021	31,942	66.3	20.2
2	215	375	869,018	24,608	51.1	15.6
3	201	367	705,450	19,976	41.5	12.6
4	212	373	1,018,786	28,849	59.9	18.3
5	212	373	832,897	23,585	49.0	14.9
6	211	373	689,171	19,515	40.5	12.3
7	215	375	1,003,134	28,406	59.0	18.0
8	214	374	819,987	23,219	48.2	14.7
9	213	374	682,862	19,337	40.1	12.2
10	216	375	980,050	27,752	57.6	17.6
11	215	375	790,282	22,378	46.5	14.2
12	213	374	667,237	18,894	39.2	12.0

Sources: ECT, 2000.
S&L, 2000.

**Table 9. Bayside Station - Units 1 and 2
Stack Parameters (Per CT/HRSG)
Distillate Fuel Oil-Firing**

Stack Height: 150.0 ft Stack Area: 283.5 ft²
 45.7 m 26.3 m²

Stack Diameter: 19.0 ft
 5.8 m

Case	Temperature		Flow Rate (actual)		Velocity	
	(°F)	(K)	(ft ³ /min)	(m ³ /min)	(ft/sec)	(m/s)
1	285	414	1,265,177	35,826	74.4	22.7
2	285	414	973,837	27,576	57.2	17.4
3	285	414	803,630	22,756	47.2	14.4
4	274	408	1,160,252	32,855	68.2	20.8
5	274	408	921,954	26,107	54.2	16.5
6	271	406	763,102	21,609	44.9	13.7
7	276	409	1,136,053	32,169	66.8	20.4
8	275	408	910,743	25,789	53.5	16.3
9	272	406	757,869	21,460	44.5	13.6
10	276	409	1,104,779	31,284	64.9	19.8
11	275	408	880,226	24,925	51.7	15.8
12	272	406	740,394	20,966	43.5	13.3

Sources: ECT, 2000.
 S&L, 2000.

Table 10. Bayside Station Units 1 and 2
Fuel Flow Data - General Electric PG7241(FA); Per CTG

A. Natural Gas-Firing

Case	100% Load				75% Load				50% Load			
	18°F	59°F	72°F	93°F	18°F	59°F	72°F	93°F	18°F	59°F	72°F	93°F
	1	4	7	10	2	5	8	11	3	6	9	12
Heat Input - LHV (MMBtu/hr)	1,717.7	1,603.4	1,568.5	1,521.1	1,394.1	1,310.6	1,276.1	1,209.8	1,118.4	1,051.1	1,021.3	969.8
Heat Input - HHV (MMBtu/hr)	1,906.2	1,779.4	1,740.7	1,688.1	1,547.1	1,454.5	1,416.2	1,342.6	1,241.2	1,166.5	1,133.4	1,076.2
Fuel Rate ¹ (lb/hr)	82,257	76,784	75,113	72,843	66,761	62,762	61,110	57,935	53,558	50,335	48,908	46,442
Fuel Rate ² (10 ⁶ ft ³ /hr)	1.869	1.745	1.707	1.655	1.517	1.426	1.389	1.316	1.217	1.144	1.111	1.055
Fuel Rate (lb/sec)	22.849	21.329	20.865	20.234	18.545	17.434	16.975	16.093	14.877	13.982	13.586	12.901

B. Distillate Fuel Oil-Firing

Case	100% Load				75% Load				50% Load			
	18°F	59°F	72°F	93°F	18°F	59°F	72°F	93°F	18°F	59°F	72°F	93°F
	1	4	7	10	2	5	8	11	3	6	9	12
Heat Input - LHV (MMBtu/hr)	1,939.5	1,822.3	1,781.6	1,723.1	1,564.1	1,472.6	1,435.3	1,362.5	1,241.8	1,172.8	1,140.6	1,081.7
Heat Input - HHV (MMBtu/hr)	2,052.0	1,928.0	1,884.9	1,823.0	1,654.8	1,558.0	1,518.5	1,441.5	1,313.8	1,240.8	1,206.8	1,144.4
Fuel Rate ³ (lb/hr)	104,555	98,237	96,043	92,889	84,318	79,385	77,375	73,450	66,943	63,224	61,488	58,313
Fuel Rate ⁴ (10 ³ gal/hr)	14.521	13.644	13.339	12.901	11.711	11.026	10.746	10.201	9.298	8.781	8.540	8.099
Fuel Rate (lb/sec)	29.043	27.288	26.679	25.803	23.422	22.052	21.493	20.403	18.595	17.562	17.080	16.198

¹ Natural gas heat content of 20,882 Btu/lb (LHV).

² Natural gas density of 0.0440 lb/ft³.

³ Distillate fuel oil heat content of 18,550 Btu/lb (LHV).

⁴ Distillate fuel oil density of 7.20 lb/gal.

Sources: ECT, 2000.
 GE, 2000.
 TEC, 2000.

**Table 11. Bayside Station Units 1 and 2
General Electric PG7241(FA) CT
NSPS GG NO_x Limits**

Fuel	PG7241(FA) Gas Turbine ISO Heat Rate (LHV)		FBN F	NO _x Std (ppmvd)
	(Btu/kw-hr)	(kj/w-hr)		
Gas	9,465	9.986	0.0	108.1
Distillate	11,284	11.905	0.0	90.7

Sources: ECT, 2000.
GE, 2000.

ATTACHMENT D
PSD NETTING ANALYSIS

PSD Netting Analysis

The procedures for determining applicability of the PSD NSR permitting program to modifications planned at existing major Florida facilities are specified in Rule 62-212.400(2)(d)4., F.A.C. Because the existing F.J. Gannon Station is a major facility (i.e., has potential emissions of 100 tpy or more of an air pollutant subject to regulation under Chapter 403, Florida Statutes) that would be subject to PSD preconstruction review if it were itself a proposed new facility (i.e., has potential emissions of 100 tpy or more of a pollutant regulated under the Clean Air Act and is located in an attainment area), modifications to the existing F.J. Gannon Station which result in a *significant net emissions increase* of any pollutant regulated under the Clean Air Act are subject to PSD NSR.

The term “significant net emission increase” is defined by Rule 62-212.400(2)(e), F.A.C. For each regulated pollutant, the net emission increase for a modification project is equal to the sum of the increases in emissions associated with the proposed project plus all facility-wide creditable, contemporaneous emission increases minus all facility-wide creditable, contemporaneous emission decreases. If this net emissions increase is equal to or greater than the applicable Table 212.400-2, F.A.C. Regulated Pollutants—Significant Emission Rates, then the net emission increase is considered to be “significant” and the modification will be subject to PSD NSR for that particular regulated pollutant.

In accordance with Rule 62-212.400(2)(e)3., F.A.C., the “contemporaneous” period for a modification project begins five years prior to the date of submittal of a complete permit application and ends when the new or modified emission units are estimated to begin operation.

In accordance with Rule 62-212.400(2)(e)4., F.A.C., contemporaneous emission increases and decreases are “creditable” if:

- (1) the emission increase or decrease will affect PSD increment consumption; i.e., will consume or expand the available increment;
- (2) The emission increase or decrease was not previously considered in the issuance of a PSD NSR permit (to avoid "double counting"); and
- (3) The FDEP has not relied on the emission increase or decrease in attainment or reasonable further progress demonstrations.

Contemporaneous emission increases and decreases are based on *actual* emission rates. The term "actual emissions" is defined by Rule 62-210.200(12), F.A.C. For new emission units, including new electric utility steam generating units, actual emissions are equal to potential emissions. For changes to existing emission units, actual emissions are generally the actual average emission rates, in tpy, for the two year period preceding the change and which are representative of normal operations. The Department may allow the use of a different time period if it is determined that the other time period is more representative of the normal operation of an emissions unit.

For emission decreases, the old level of actual or allowable emissions (whichever is lower) must be greater than the new level of actual emissions. The actual emission decrease must also take place on or before the date that emissions from the modification project first occur and must be federally enforceable on and after the date the Department issues a construction permit for the modification project.

For Bayside Units 1 and 2, the contemporaneous period is projected to begin in September 1995 and end in March 2004. Creditable emission decreases that will occur within this contemporaneous period consist of the actual emissions associated with the cessation of coal-fired operations of F.J. Gannon Station Units 5 and 6. Creditable emission increases consist of those associated with Bayside Units 1 and 2. There are no other creditable emission increases that have occurred or will occur at the F.J. Gannon Station during the September 1995 through March 2004 contemporaneous period.

Summaries of historical, actual emission rates for F.J. Gannon Station Units 5 and 6 for the 1995 – 1999 five year period are provided on Tables 1 and 2, respectively.

Table 3 provides an analysis of PSD NSR applicability for Bayside Units 1 and 2. Contemporaneous, creditable emission decreases were determined based on the average actual emissions for F.J. Gannon Station Unit 5 for the 1998/1999 two-year period, and the average actual emissions for F.J. Gannon Station Unit 6 for the 1997/1998 two-year period. Due to an explosion which occurred at F.J. Gannon Station Unit 6 in 1999, operation of Unit 6 during 1999 is not considered to be representative of normal operations. For this reason, the 1997/1998 two-year period is considered to be more representative of normal operations for Unit 6.

The net emission rate changes due to the increase in potential emissions for Bayside Units 1 and 2, minus the two-year average actual emissions for F.J. Gannon Station Units 5 and 6 are all below the applicable Table 212.400-2, F.A.C. Regulated Pollutants—Significant Emission Rates with the exception of VOCs. For most regulated pollutants, there will be a substantial reduction in actual emissions; e.g., approximately 35,800 tpy for SO₂ and 14,700 tpy for NO_x. Accordingly, Bayside Units 1 and 2 are subject to PSD NSR for VOCs only.

**Table 1. Bayside Station Units 1 and 2
Netting Analysis - F.J. Gannon Station Unit 5 Historical Emissions**

	Unit 5 (tpy)							
	1995	1996	1997	1998	1999	95-99, 5 Yr Avg	98,99 Avg	
Coal Usage (tons)	519,780.0	574,584	450,802	556,487	541,559	528,642	549,023	
Wt % S	1.11	1.19	1.16	1.21	1.17	1.17	1.19	
Oil Usage (10 ³ gal)	332.6	311.0	600.9	599.0	397.0	448.1	498.0	
Wt % S	0.16	0.30	0.15	0.28	0.41	0.26	0.35	
NO _x AOR (CEMS Data)	8,836.0	10,630.0	4,515.0	4,706.0	4,787.0	6,694.8	4,746.5	
CO Gannon Unit 5 4/7,8/00 Stack Test Avg. = 0.295 lb/MMBtu E.F. = 7.488 lb/ton	← AOR Data →		← Stack Test Data →					
	157.0	173.0	1,687.7	2,083.4	2,027.5	1,225.7	2,055.5	
SO ₂ AOR (CEMS Data)	10,374.0	12,968.0	10,753.0	13,701.0	12,601.0	12,079.4	13,151.0	
H ₂ SO ₄ AP-42 (1998)	49.5	58.7	45.0	57.9	54.5	53.1	56.2	
PM ₁₀ AOR	193.0	212.3	392.3	273.0	196.7	253.5	234.9	
PM AOR	193.0	212.3	392.6	273.0	196.7	253.5	234.9	
Pb AOR	3.5	3.8	3.0	3.7	3.6	3.5	3.7	
VOC AP-42 (1998)	10.4	11.5	9.1	11.2	10.9	10.6	11.0	

Sources: ECT, 2000.
TEC, 2000.

**Table 2. Bayside Station Units 1 and 2
Netting Analysis - F.J. Gannon Station Unit 6 Historical Emissions**

	Unit 6 (tpy)						
	1995	1996	1997	1998	1999	95-99, 5 Yr Avg	97,98 Avg
Coal Usage (tons)	897,070.0	892,742	920,526	860,597	693,039	852,795	890,562
Wt % S	1.10	1.19	1.18	1.22	1.13	1.16	1.20
Oil Usage (10 ³ gal)	378.9	311.0	639.9	599.0	362.0	458.1	619.4
Wt % S	0.16	0.30	0.15	0.28	0.41	0.26	0.22
NO _x AOR (CEMS Data)	15,255.0	16,520.0	10,929.0	10,934.0	9,588.0	12,645.2	10,931.5
CO Gannon Unit 5 4/7,8/00 Stack Test Avg. = 0.295 lb/MMBtu E.F. = 7.488 lb/ton	← AOR Data →		← Stack Test Data →				
	270.0	269.0	3,446.3	3,221.9	2,594.6	1,960.4	3,334.1
SO ₂ AOR (CEMS Data)	18,801.0	20,307.5	22,829.0	23,704.0	16,029.0	20,334.1	23,266.5
H ₂ SO ₄ AP-42 (1998)	84.7	91.2	93.3	90.2	67.3	85.3	91.7
PM ₁₀ AOR	1,116.0	1,109.3	818.6	911.0	765.1	944.0	864.8
PM AOR	1,116.0	1,109.3	818.6	911.0	765.1	944.0	864.8
Pb AOR	6.0	5.9	6.1	5.7	4.6	5.7	5.9
VOC AP-42 (1998)	18.0	17.9	18.5	17.3	13.9	17.1	17.9

Sources: ECT, 2000.
TEC, 2000.

**Table 3. Bayside Station
Bayside Units 1 & 2/F.J. Gannon Units 5 & 6 Emissions Netting Analysis**



	Units 5 & 6 (tpy)					Unit 5 2 Yr ^(a) Avg	Unit 6 2 Yr ^(b) Avg	Total 2 Yr ^{(a), (b)} Avg	CT 1A-2D (tpy)	Net Change (tpy)	PSD Threshold (tpy)	PSD Review (Y/N)
	1995	1996	1997	1998	1999							
Coal Usage (tons)	1,416,850	1,467,326	1,371,328	1,417,084	1,234,598	549,023	890,562	1,439,585	N/A	N/A	N/A	N/A
Wt % S	1.11	1.19	1.17	1.22	1.15	1.19	1.20	1.20	N/A	N/A	N/A	N/A
Oil Usage (10 ³ gal)	711.5	1,866.0	3,639.9	3,486.4	6,303.0	498.0	619.4	1,117.4	N/A	N/A	N/A	N/A
Wt % S	0.16	0.30	0.15	0.28	0.41	0.35	0.22	0.28	N/A	N/A	N/A	N/A
NO _x AOR (CEMS Data)	24,091.0	27,150.0	15,444.0	15,640.0	14,375.0	4,746.5	10,931.5	15,678.0	1,018.2	-14,659.8	40.0	N
CO AOR & Stack Test	427.0	442.0	5,134.0	5,305.3	4,622.1	2,055.5	3,334.1	5,389.6	989.7	-4,399.9	100.0	N
SO ₂ AOR (CEMS Data)	29,175.0	33,275.5	33,582.0	37,405.0	28,630.0	13,151.0	23,266.5	36,417.5	576.3	-35,841.2	40.0	N
H ₂ SO ₄ AP-42 (1998)	134.2	150.0	138.2	148.2	121.9	56.2	91.7	148.0	96.7	-51.3	7.0	N
PM ₁₀ AOR	1,309.0	1,321.6	1,210.9	1,184.0	961.8	234.9	864.8	1,099.7	721.4	-378.2	15.0	N
PM AOR	1,309.0	1,321.6	1,211.2	1,184.0	961.8	234.9	864.8	1,099.7	721.4	-378.2	25.0	N
Pb AOR	9.4	9.8	9.1	9.4	8.2	3.7	5.9	9.6	1.1	-8.5	0.6	N
VOC AP-42 (1998)	28.4	29.4	27.6	28.5	24.8	11.0	17.9	28.9	99.6	70.7	40.0	Y

(a) Fuel data represents 1998, 1999 average for Unit 5.

(b) Fuel data represents 1997, 1998 average for Unit 6.

Sources: ECT, 2000.
TEC, 2000.

ATTACHMENT E
DISPERSION MODELING FILES



- EXISTING STRUCTURES KEY:**
- A. PLANT OFFICE
 - B. WAREHOUSE
 - C. CONCRETE ENCASED ELECTRICAL CONDUITS
 - D. CITY WATER TANKS
 - E. CITY WATER PUMP HOUSE
 - F. COMBUSTION TURBINE/GENERATOR
 - G. FUEL OIL PUMP HOUSE
 - H. REVERSE OSMOSIS BUILDING
 - I. SUMP PIT
 - J. ELECTRICAL BUILDING
 - K. RECYCLE WATER TANK
 - L. BOILER SHOP
 - M. SHOP/STORAGE
 - N. GUARD HOUSE
 - O. 480V LOAD CENTER
 - P. UNIT 6 PRECIPITATOR

- NEW STRUCTURES KEY:**
- 1. GE7FA COMBUSTION TURBINE GENERATOR
 - 2. GE7FA AIR INLET FILTER
 - 3. GE7FA MAINTENANCE ACCESS AREA FOR MOBILE CRANE
 - 4. HEAT RECOVERY STEAM GENERATOR (HRSG)
 - 5. HRSG MAINTENANCE ACCESS AREA
 - 6. GENERATOR STEP-UP TRANSFORMER (GSU)
 - 7. GE ACCESSORY MODULE
 - 8. CT ELECTRICAL BUILDING
 - 9. COMMON ELECTRICAL BUILDING (UNIT 1C & 2A)
 - 10. STATION SERVICE TRANSFORMER
 - 11. CONDENSATE POLISHING BUILDING (55' x 65')
 - 12. AMMONIA TANKS
 - 13. PIPE RACK
 - 14. FLOOD WALL
 - 15. FUEL OIL TANK (DUAL WALL) 5.85M GAL
 - 16. H2 BULK AREA
 - 17. CO2 STORAGE
 - 18. GAS LINE TIE-IN
 - 19. GAS COMPRESSORS
 - 20. DEMINERALIZED WATER TANK 5.5M GAL
 - 21. CONSTRUCTION LAYDOWN
 - 22. CONSTRUCTION PARKING



- NEW STRUCTURES KEY (CONTINUED):**
- 24. ELECTRICAL CABLE TRENCH
 - 25. HOOKUP FOR PORTABLE KAYDON UNIT
 - 26. GAS CONDITIONING SKID (1 PER CT)
 - 27. C.E.M. ENCLOSURE (1 PER HRSG)
 - 28. SAMPLE/CHEM FEED BUILDING (1 PER UNIT)
 - 29. I.A. COMPRESSORS W/DRYERS & RECEIVERS
 - 30. CONSTRUCTION OFFICE/WAREHOUSE (50' x 175')
 - 31. CONTROL/ADMINISTRATION BUILDING (70' x 80')
 - 32. CONDENSATE SURGE TANKS W/BOOSTER PUMPS
 - 33. CCW COOLING TOWERS
 - 34. DEMINERALIZED WATER TRAILERS
 - 35. CONSTRUCTION POWER TRANSFORMER
 - 36. CONSTRUCTION POWER DISCONNECT SWITCH
 - 37. STAIR TOWER TO HRSG & ISOLATION VALVES
 - 38. DRAINAGE SUMPS (5 TOTAL)
 - 39. RELOCATED 69KV TRANSMISSION LINE
 - 40. PERSONNEL ACCESS DOOR THROUGH FLOOD WALL
 - 41. CRASH PROTECTION BARRIER
 - 42. PECC
 - 43. HRSG ELECTRICAL BUILDING
 - 44. BAC
 - 45. LCI (1 PER UNIT)
 - 46. POLISHER WASTE WATER TANK

- NOTES:**
- 1. MAIN PIPE RACK FROM EXISTING STATION TO NEW UNITS (INCLUDING STRUCTURES FOR THERMAL EXPANSION LOOPS) ARE TWO LEVELS.
 - 2. ANCILLARY PIPE RACKS AT EACH HRSG ARE ONE LEVEL
 - 3. EXISTING SITE ELEVATION IS 8'-6" (APPROX.). THE AREA WITHIN THE NEW CT/HRSG ISLAND TO BE RAISED TO ELEVATION 12'-6"; TRANSITION RAMPS INDICATED.
 - 4. CT/HRSG SPACING @ 150'-0" O.C.

FIGURE 2-2.
BAYSIDE UNITS 1 AND 2 PLOT PLAN

Source: Sargent & Lundy, 2000.






0 02-17-2000 D.SKORCHET REFERENCE

FIGURE 2-3.
BAYSIDE UNIT 1 PROFILE

Source: Sargent & Lundy, 2000.






LEGEND
 EPN
 CTC-1 EMISSION POINT

FIGURE 2-4.
 PROCESS FLOW DIAGRAM - BAYSIDE UNIT 1

Source: TEC, 2000; ECT, 2000.






FIGURE 2-5. PROCESS FLOW DIAGRAM - BAYSIDE UNIT 2

Source: TEC, 2000; ECT, 2000.



Table 4-6. RBLC VOC Summary for Natural Gas Fired CTs

RBLC ID	Facility Name	City	Permit Dates		Process Description	Thruput Rate	Emission Limit	Control System Description	Basis
			Issuance	Update					
AL-0128	ALABAMA POWER COMPANY - THEODORE COGENERATION	THEODORE	03/16/1999	06/23/1999	TURBINE, WITH DUCT BURNER	170.0 MW	0.016 LB/MMBTU	EFFICIENT COMBUSTION	BACT-PSD
CA-0768	NORTHERN CALIFORNIA POWER AGENCY	LODI	10/02/1997	03/16/1998	GE FRAME 5 GAS TURBINE	325.0 MMBTU/HR	8.0 LB/HR	NATURAL GAS AS PRIMARY FUEL	LAER
CA-0810	SACRAMENTO COGENERATION AUTHORITY P&G	SACRAMENTO	08/19/1994	08/31/1999	TURBINE, GAS, COMBINED CYCLE LM6000	421.4 MMBTU/H	1.1 LB/H	OXIDATION CATALYST	BACT
CA-0810	SACRAMENTO COGENERATION AUTHORITY P&G	SACRAMENTO	08/19/1994	08/31/1999	TURBINE, GAS, COMBINED CYCLE LM6000	421.4 MMBTU/H	1.1 LB/H	OXIDATION CATALYST	BACT
CA-0810	SACRAMENTO COGENERATION AUTHORITY P&G	SACRAMENTO	08/19/1994	08/31/1999	TURBINE, SIMPLE CYCLE LM6000 GAS	421.4 MMBTU/H	1.1 LB/H	OXIDATION CATALYST	BACT
CA-0813	SEPCO	RIO LINDA	10/05/1994	08/31/1999	TURBINE, GAS COMBINED CYCLE GE MODEL 7	920.0 MMBTU/H	3.7 LB/H	OXIDATION CATALYST	BACT
CA-0853	KERN FRONT LIMITED	BAKERSFIELD	11/04/1986	08/05/1999	TURBINE, GAS, GENERAL ELECTRIC LM-2500	25.0 MW	3.12 LB/H	OXIDATION CATALYST, VOC IS SHOWN AS CH4	BACT-OTHER
CA-0855	CROCKETT COGENERATION - C&H SUGAR	CROCKETT	10/05/1993	04/19/1999	TURBINE, GAS, GENERAL ELECTRIC MODEL PG7221(FA)	240.0 MW	352.6 LB/D	ENGELHARD OXIDATION CATALYST	BACT-OTHER
CA-0858	BEAR MOUNTAIN LIMITED	BAKERSFIELD	08/19/1994	09/28/1999	TURBINE, GE, COGENERATION, 48 MW	48.0 MW	0.6 PPMVD @ 15% O2	OXIDATION CATALYST	BACT-OTHER
CO-0017	THERMO INDUSTRIES, LTD.	FT. LUPTON	02/19/1992	03/24/1995	TURBINE, GAS FIRED, 5 EACH	246.0 MMBTU/H	16.7 LB/H		OTHER
CO-0018	BRUSH COGENERATION PARTNERSHIP	BRUSH	07/20/1994		TURBINE	350.0 MMBTU/H	26.7 T/YR		OTHER
CO-0019	COLORADO POWER PARTNERSHIP	BRUSH	07/20/1994		TURBINES, 2 NAT GAS & 2 DUCT BURNERS	385.0 MMBTU/H EACH TURBINE	35.2 T/YR		OTHER
CO-0024	PUBLIC SERVICE OF COLO. FORT ST. VRAIN	PLATTEVILLE	05/01/1996	05/19/1998	COMBINED CYCLE TURBINES (2), NATURAL	471.0 MW	1.4 PPMVD, SMPL CY	GOOD COMBUSTION CONTROL PRACTICES	BACT-PSD
CT-0073	PRATT & WHITNEY, UTC	MIDDLETOWN	07/07/1989	04/30/1990	ENGINE, GAS TURBINE	238.0 MMBTU/H	0.014 LB/MMBTU		BACT-PSD
CT-0139	PDC EL PASO MILFORD LLC	MILFORD	04/16/1999	06/17/1999	TURBINE, COMBUSTION, ABB GT-24, #1 WITH 2 CHILLERS	2.0 MMBTU/H	3.0 LB/H NAT GAS	COMBUSTION CONTROLS	BACT
CT-0140	PDC EL PASO MILFORD LLC	MILFORD	04/16/1999	06/17/1999	TURBINE, COMBUSTION, ABB GT-24E, #2 WITH 2 CHILLERS	2.0 MMBTU/H	3.0 LB/H NAT GAS	COMBUSTION CONTROLS	BACT
FL-0042	ORLANDO UTILITIES COMMISSION	TITUSVILLE	09/01/1988	05/14/1993	TURBINE, 2 EA	35.0 MW	7.0 PPM @ 15% O2	COMBUSTION CONTROL	BACT-PSD
FL-0052	FLORIDA POWER AND LIGHT	NORTH PALM BEACH	06/05/1991	03/24/1995	TURBINE, GAS, 4 EACH	400.0 MW	1.6 PPM @ 15% O2	COMBUSTION CONTROL	BACT-PSD
FL-0052	FLORIDA POWER AND LIGHT	NORTH PALM BEACH	06/05/1991	03/24/1995	TURBINE, CG, 4 EACH	400.0 MW	9.0 PPM @ 15% O2	COMBUSTION CONTROL	BACT-PSD
FL-0053	FLORIDA POWER AND LIGHT	LAVOGROME REPOWERING S	03/14/1991	03/24/1995	TURBINE, GAS, 4 EACH	240.0 MW	1.0 PPM @ 15% O2	COMBUSTION CONTROL	BACT-PSD
FL-0056	ORLANDO UTILITIES COMMISSION	TITUSVILLE	11/05/1991	05/14/1993	TURBINE, GAS, 4 EACH	35.0 MW	7.0 PPM @ 15% O2	COMBUSTION CONTROL	BACT-PSD
FL-0068	ORANGE COGENERATION LP	BARTOW	12/30/1993	01/13/1995	TURBINE, NATURAL GAS, 2	368.3 MMBTU/H	10.0 PPMVD	GOOD COMBUSTION	BACT-PSD
FL-0080	AUBURNDALE POWER PARTNERS, LP	AUBURNDALE	12/14/1992	01/13/1995	TURBINE, GAS	1,214.0 MMBTU/H	6.0 LB/H	GOOD COMBUSTION PRACTICES	BACT-PSD
FL-0082	FLORIDA POWER CORPORATION POLK COUNTY SITE	BARTOW	02/25/1994	01/13/1995	TURBINE, NATURAL GAS (2)	1,510.0 MMBTU/H	7.0 PPMVV	GOOD COMBUSTION PRACTICES	BACT-PSD
GA-0052	SAVANNAH ELECTRIC AND POWER CO.		02/12/1992	03/24/1995	TURBINES, B	1,032.0 MMBTU/H, NAT GAS	0.003 LB/MMBTU	FUEL SPEC: LOW SULFUR FUEL OIL	BACT-PSD
GA-0063	MID-GEORGIA COGEN.	KATHLEEN	04/03/1996	08/19/1996	COMBUSTION TURBINE (2), NATURAL GAS	116.0 MW	6.0 PPMVD	COMPLETE COMBUSTION	BACT-PSD
GA-0069	TENUSKA GEORGIA PARTNERS, L.P.	FRANKLIN	12/18/1998	06/23/1999	TURBINE, COMBUSTION, SIMPLE CYCLE, 6	160.0 MW EA	0.0055 LB/MMBTU	VOC EMISSION IS BECAUSE OF NO.2 FUEL OIL	BACT-PSD
GA-0069	TENUSKA GEORGIA PARTNERS, L.P.	FRANKLIN	12/18/1998	06/23/1999	TURBINE, COMBUSTION, SIMPLE CYCLE, 6	160.0 MW EA	0.03 LB/MMBTU	VOC EMISSION IS BECAUSE OF NATURAL GAS.	BACT-PSD
LA-0086	INTERNATIONAL PAPER	MANSFIELD	02/24/1994	04/17/1995	TURBINE/HRSG, GAS COGEN	338.0 MM BTU/HR TURBINE	3.6 LB/HR COMBINED	COMBUSTION CONTROLS, FUEL SELECTION	BACT
MA-0023	DIGHTON POWER ASSOCIATE, LP	DIGHTON	10/06/1997	04/19/1999	TURBINE, COMBUSTION, ABB GT11N2	1,327.0 MMBTU/H	5.1 LB/H	DRY LOW NOX COMBUSTION TECHNOLOGY WITH SCR.	BACT-PSD
ME-0018	WESTBROOK POWER LLC	WESTBROOK	12/04/1998	04/19/1999	TURBINE, COMBINED CYCLE, TWO	528.0 MW TOTAL	0.4 PPM @ 15% O2		BACT-PSD
ME-0019	CHAMPION INTERNATL CORP. & CHAMP. CLEAN ENERGY	BUCKSPORT	09/14/1998	04/19/1999	TURBINE, COMBINED CYCLE, NATURAL GAS	175.0 MW	3.0 LB/H GAS		BACT-OTHER
ME-0020	CASCO RAY ENERGY CO	VEAZIE	07/13/1998	04/19/1999	TURBINE, COMBINED CYCLE, NATURAL GAS, TWO	170.0 MW EACH	1.0 PPM	LOW NOX BURNER	BACT-PSD
NC-0055	DUKE POWER CO. LINCOLN COMBUSTION TURBINE STATION	LOWESVILLE	12/20/1991	03/24/1995	TURBINE, COMBUSTION	1,313.0 MM BTU/HR	2.0 LB/HR	COMBUSTION CONTROL	BACT-PSD
NJ-0013	LAKEWOOD COGENERATION, L.P.	LAKEWOOD TOWNSHIP	04/01/1991	05/29/1995	TURBINES (NATURAL GAS) (2)	1,190.0 MMBTU/HR (EACH)	0.0046 LB/MMBTU	TURBINE DESIGN	OTHER
NJ-0017	NEWARK BAY COGENERATION PARTNERSHIP, L.P.	NEWARK	06/09/1993	05/29/1995	TURBINES, COMBUSTION, NATURAL GAS FIRED (2)	617.0 MMBTU/HR (EACH)	4.0 PPMVD	TURBINE DESIGN	BACT-PSD
NM-0021	WILLIAMS FIELD SERVICES CO. - EL CEDRO COMPRESSOR	BLANCO	10/29/1993	03/02/1994	TURBINE, GAS FIRED	11,257.0 HP	25.0 PPM @ 15% O2	COMBUSTION CONTROL	BACT-PSD
NM-0028	SOUTHWESTERN PUBLIC SERVICE CO/CUNNINGHAM STATION	HOBBS	11/04/1996	12/30/1996	COMBUSTION TURBINE, NATURAL GAS	100.0 MW	0 SEE P2	GOOD COMBUSTION PRACTICES	BACT-PSD
NM-0029	SOUTHWESTERN PUBLIC SERVICE COMPANY/CUNNINGHAM STA	HOBBS	02/15/1997	03/31/1997	COMBUSTION TURBINE, NATURAL GAS	100.0 MW	0		BACT-PSD
NY-0036	ONEIDA COGENERATION FACILITY	ONEIDA	02/26/1990	05/18/1990	TURBINE, GE FRAME 6	417.0 MMBTU/H	0.013 LB/MMBTU	COMBUSTION CONTROL	OTHER
NY-0038	EMPIRE ENERGY - NIAGARA COGENERATION CO.	LOCKPORT	05/02/1989	05/18/1990	TURBINE, GR FRAME 6, 3 EA	416.0 MMBTU/H	0.012 LB/MMBTU	COMBUSTION CONTROL	BACT-PSD
NY-0039	FULTON COGENERATION ASSOCIATES	FULTON	01/29/1990	05/18/1990	TURBINE, GE LM5000, GAS FIRED	500.0 MMBTU/H	5.0 LB/H	COMBUSTION CONTROL	BACT-PSD
NY-0040	JMC SELKIRK, INC.	SELKIRK	11/21/1989	05/18/1990	TURBINE, GE FRAME 7, GAS FIRED	80.0 MW	7.0 PPM	COMBUSTION CONTROL	BACT-PSD
NY-0046	SARANAC ENERGY COMPANY	PLATTSBURGH	07/31/1992	09/13/1994	TURBINES, COMBUSTION (2) (NATURAL GAS)	1,123.0 MMBTU/HR (EACH)	0.0045 LB/MMBTU	OXIDATION CATALYST	BACT-OTHER
OH-0218	CNG TRANSMISSION	WASHINGTON COURT HOUSE	08/12/1992	04/05/1995	TURBINE (NATURAL GAS) (3)	5,500.0 HP (EACH)	0.1 G/HP-HR	FUEL SPEC: USE OF NATURAL GAS	OTHER
PA-0083	NORTHERN CONSOLIDATED POWER	NORTH EAST	05/03/1991	07/20/1994	TURBINES, GAS, 2	34.6 KW EACH	105 PPM @ 15% O2	OXIDATION CATALYST	OTHER
PA-0099	FLEETWOOD COGENERATION ASSOCIATES	FLEETWOOD	04/22/1994	11/22/1994	NG TURBINE (GE LM6000) WITH WASTE HEAT BOILER	360.0 MMBTU/HR	4.4 LB/HR	GOOD COMBUSTION PRACTICES	BACT-OTHER
PA-0148	BLUE MOUNTAIN POWER, LP	RICHLAND	07/31/1996	01/12/1999	COMBUSTION TURBINE WITH HEAT RECOVERY BOILER	153.0 MW	4.0 PPM @ 15% O2	OXIDATION CATALYST, OIL LIMIT = 4.4 PPMVD @ 15% O2.	LAER
PA-0149	BUCKNELL UNIVERSITY	LEWISBURG	11/26/1997	11/30/1997	NG FIRED TURBINE, SOLAR TAURUS T-7300S	5.0 MW	25.0 PPMV @ 15% O2	GOOD COMBUSTION	BACT-OTHER
PR-0004	ECOELECTRICA, L.P.	PENUELAS	10/01/1996	05/06/1998	TURBINES, COMBINED-CYCLE COGENERATION	461.0 MW	5.0 PPMVD	COMBUSTION CONTROLS	BACT-PSD
RI-0008	PAWTUCKET POWER	PAWTUCKET	01/30/1989	03/31/1991	TURBINE/DUCT BURNER	533.0 MMBTU/H	19.0 PPM @ 15% O2, GAS		BACT-PSD
RI-0010	NARRAGANSETT ELECTRIC/NEW ENGLAND POWER CO.	PROVIDENCE	04/13/1992	05/31/1992	TURBINE, GAS AND DUCT BURNER	1,360.0 MMBTU/H EACH	5.0 PPM @ 15% O2		BACT-PSD
RI-0012	ALGONQUIN GAS TRANSMISSION CO.	BURRILLVILLE	07/31/1991	05/31/1992	TURBINE, GAS, 2	49.0 MMBTU/H	0.016 LB/MMBTU	GOOD COMBUSTION PRACTICES	BACT-OTHER
RI-0018	TIVERTON POWER ASSOCIATES	TIVERTON	02/13/1998	02/08/1999	COMBUSTION TURBINE, NATURAL GAS	265.0 MW	2.0 PPM @ 15% O2	GOOD COMBUSTION	BACT-PSD
SC-0029	SC ELECTRIC AND GAS COMPANY - HAGOOD STATION	CHARLESTON	12/11/1989	03/24/1995	INTERNAL COMBUSTION TURBINE	110.0 MEGAWATTS	10.0 LBS/HR	GOOD COMBUSTION PRACTICES	BACT-PSD
SC-0031	BMW MANUFACTURING CORPORATION	GREER	01/07/1994	08/12/1996	TURBINE, NAT GAS FIRED (3 - 1 SPARE) AND 2 BOILERS	54.5 MM BTU/HR TURBINES	77.86 LBS/DAY	EACH OF THE 2 BOILER-TURBINE USE A COMMON STACK	LAER
TX-0231	WEST CAMPUS COGENERATION COMPANY	COLLEGE STATION	05/02/1994	10/31/1994	GAS TURBINES	75.3 MW (TOTAL POWER)	38.0 T/Y	INTERNAL COMBUSTION CONTROLS	BACT
VA-0163	VIRGINIA POWER		09/07/1989	04/30/1990	TURBINE, GAS	1,308.0 MMBTU/H	2.0 LB/H/UNIT NAT GAS FI		BACT-PSD
VA-0177	DOSWELL LIMITED PARTNERSHIP		05/04/1990	03/24/1995	TURBINE, COMBUSTION	1,261.0 MMBTU/H	4.4 LB/H	COMBUSTOR DESIGN & OPERATION, GAS	OTHER
VA-0179	COMMONWEALTH GAS PIPELINE CORPORATION	LOUISA STATION	08/17/1990	03/24/1995	SOLAR SATURN T-1300,3	14,460.0 CF/H	2.1 LB/H		BACT-PSD
VA-0180	COMMONWEALTH GAS PIPELINE CORPORATION	GOOCHLAND	09/30/1990	03/24/1995	TURBINES, GAS FIRED, SINGLE CYCLE, 5	14.5 MMBTU/H EACH	0	EQUIPMENT DESIGN & OPERATION	BACT-PSD

Source: RBLC 2000.

MAXIMUM	105.0 PPM @ 15% O2
MINIMUM	0.4 PPM @ 15% O2
AVERAGE	11.5 PPM @ 15% O2

Table 4-7. RBLC VOC Summary for Fuel Oil Fired CTs

RBLC ID	Facility Name	City	Permit Dates		Process Description	Thruput Rate	Emission Limit	Control System Description	Basis
			Issuance	Update					
AL-0126	MOBILE ENERGY LLC	MOBILE	01/05/1999	04/09/1999	TURBINE, GAS, COMBINED CYCLE	168.0 MW	0.006 LB/MMBTU	3 DEGREE TIMING RETARD	BACT-PSD
FL-0052	FLORIDA POWER AND LIGHT	NORTH PALM BEACH	06/05/1991	03/24/1995	TURBINE, GAS, 4 EACH	400.0 MW	1.6 PPMVD @ 15% O2		BACT-PSD
FL-0052	FLORIDA POWER AND LIGHT	NORTH PALM BEACH	06/05/1991	03/24/1995	TURBINE, OIL, 2 EACH	400.0 MW	6.0 PPMVD @ 15% O2	COMBUSTION CONTROL	BACT-PSD
FL-0052	FLORIDA POWER AND LIGHT	NORTH PALM BEACH	06/05/1991	03/24/1995	TURBINE, CG, 4 EACH	400.0 MW	9.0 PPMVD @ 15% O2	COMBUSTION CONTROL	BACT-PSD
FL-0053	FLORIDA POWER AND LIGHT	LAVOGROME REPOWERING S1	03/14/1991	03/24/1995	TURBINE, GAS, 4 EACH	240.0 MW	1.0 PPMVD @ 15% O2	COMBUSTION CONTROL	BACT-PSD
FL-0053	FLORIDA POWER AND LIGHT	LAVOGROME REPOWERING S1	03/14/1991	03/24/1995	TURBINE, OIL, 4 EACH	0.0	6.0 PPMVD @ 15% O2	COMBUSTION CONTROL	BACT-PSD
FL-0056	ORLANDO UTILITIES COMMISSION	TITUSVILLE	11/05/1991	05/14/1993	TURBINE, GAS, 4 EACH	35.0 MW	7.0 PPMVD @ 15% O2	COMBUSTION CONTROL	BACT-PSD
FL-0056	ORLANDO UTILITIES COMMISSION	TITUSVILLE	11/05/1991	05/14/1993	TURBINE, OIL, 4 EACH	35.0 MW	7.0 PPMVD @ 15% O2	COMBUSTION CONTROL	BACT-PSD
FL-0057	FLORIDA POWER GENERATION	DEBARY	10/18/1991	03/24/1995	TURBINE, OIL, 6 EACH	92.9 MW	5.0 LB/H	COMBUSTION CONTROL	BACT-PSD
FL-0080	AUBURNDALE POWER PARTNERS, LP	AUBURNDALE	12/14/1992	01/13/1995	TURBINE, GAS	1,214.0 MMBTU/H	6.0 LB/H	COMBUSTION CONTROL	BACT-PSD
FL-0080	AUBURNDALE POWER PARTNERS, LP	AUBURNDALE	12/14/1992	01/13/1995	TURBINE, OIL	1,170.0 MMBTU/H	10.0 LB/H	GOOD COMBUSTION PRACTICES	BACT-PSD
FL-0081	TECO POLK POWER STATION	BARTOW	02/24/1994	03/24/1995	TURBINE, FUEL OIL	1,765.0 MMBTU/H	0.028 LB/MMBTU	GOOD COMBUSTION	BACT-PSD
FL-0082	FLORIDA POWER CORPORATION POLK COUNTY SITE	BARTOW	02/25/1994	01/13/1995	TURBINE, FUEL OIL (2)	1,730.0 MMBTU/H	7.0 PPMVW	GOOD COMBUSTION PRACTICES	BACT-PSD
FL-0083	FLORIDA POWER CORPORATION	INTERCESSION CITY	08/17/1992	01/13/1995	TURBINE, OIL	1,029.0 MMBTU/H	5.0 LB/H	GOOD COMBUSTION PRACTICES	BACT-PSD
FL-0083	FLORIDA POWER CORPORATION	INTERCESSION CITY	08/17/1992	01/13/1995	TURBINE, OIL	1,866.0 MMBTU/H	9.0 LB/H	GOOD COMBUSTION PRACTICES	BACT-PSD
GA-0052	SAVANNAH ELECTRIC AND POWER CO.		02/12/1992	03/24/1995	TURBINES, 8	1,032.0 MMBTU/H, NAT GAS	0.003 LB/MMBTU	GOOD COMBUSTION PRACTICES	BACT-PSD
GA-0052	SAVANNAH ELECTRIC AND POWER CO.		02/12/1992	03/24/1995	TURBINES, 8	972.0 MMBTU/H, #2 OIL	0.0042 LB/MMBTU	FUEL SPEC: LOW SULFUR FUEL OIL	BACT-PSD
GA-0063	MID-GEORGIA COGEN.	KATHLEEN	04/03/1996	08/19/1996	COMBUSTION TURBINE (2), FUEL OIL	116.0 MW	30.0 PPMVD @ 15% O2	COMPLETE COMBUSTION	BACT-PSD
HI-0010	KALAELOE PARTNERS, L.P.		03/09/1990	03/16/1994	TURBINE, LSF0, 2	1,800.0 MMBTU/H, TOTAL	1.0 PPM AT > 80% LOAD	COMPLETE COMBUSTION	BACT-PSD
HI-0014	HAWAII ELECTRIC LIGHT CO., INC.	KEEAU	02/12/1992	03/24/1995	TURBINE, FUEL OIL #2	20.0 MW	297.6 LB/H @ 25-50% PKLD	COMBUSTION DESIGN	BACT-PSD
HI-0014	HAWAII ELECTRIC LIGHT CO., INC.	KEEAU	02/12/1992	03/24/1995	TURBINE, FUEL OIL #2	20.0 MW	28.1 LB/H @ 50-75% PKLD	COMBUSTION DESIGN	BACT-PSD
HI-0014	HAWAII ELECTRIC LIGHT CO., INC.	KEEAU	02/12/1992	03/24/1995	TURBINE, FUEL OIL #2	20.0 MW	2.6 LB/H @ 75-100% PKLD	COMBUSTION DESIGN	BACT-PSD
HI-0014	HAWAII ELECTRIC LIGHT CO., INC.	KEEAU	02/12/1992	03/24/1995	TURBINE, FUEL OIL #2	20.0 MW	0.8 LB/HR @ 100% PEAKLD	GOOD COMBUSTION PRACTICES	BACT-PSD
HI-0015	MAUI ELECTRIC COMPANY, LTD./MAALAEA GENERATING STA	MAUI	07/28/1992	03/24/1995	TURBINE, COMBINED-CYCLE COMBUSTION	28.0 MW	0.8 LB/HR	COMBUSTION DESIGN	BACT-OTHER
HI-0019	MAUI ELECTRIC COMPANY	MAALAEA	01/06/1998	06/08/1999	TURBINE, COMBUSTION, 2 EA	20.0 MW	10.0 PPMVD @ 15% O2	COMBUSTION DESIGN, INCLUDING FITR	BACT-PSD
HI-0020	HAWAII ELECTRIC LIGHT CO.	KEAHOLE	10/28/1997	06/08/1999	TURBINE, COMBUSTION, GELM 2500, 2 EA	20.0 MW	2.5 PPMVD @ 15% O2	GOOD COMBUSTION DESIGN AND OPERATION.	BACT-PSD
MA-0023	DIGHTON POWER ASSOCIATE, LP	DIGHTON	10/06/1997	04/19/1999	TURBINE, COMBUSTION, ABB GT11N2	1,327.0 MMBTU/H	5.1 LB/H	DRY, LOW-NOX COMBUSTION TECHNOLOGY WITH SCR	BACT-PSD
NC-0055	DUKE POWER CO. LINCOLN COMBUSTION TURBINE STATION	LOWESVILLE	12/20/1991	03/24/1995	TURBINE, COMBUSTION	1,313.0 MM BTU/HR	2.0 LB/HR	COMBUSTION CONTROL	BACT-PSD
NC-0055	DUKE POWER CO. LINCOLN COMBUSTION TURBINE STATION	LOWESVILLE	12/20/1991	03/24/1995	TURBINE, COMBUSTION	1,247.0 MM BTU/HR	5.0 LB/HR	LIMITED TO BURN DIESEL 150 H/YR.	BACT-PSD
NJ-0013	LAKEWOOD COGENERATION, L.P.	LAKEWOOD TOWNSHIP	04/01/1991	05/29/1995	TURBINES (#2 FUEL OIL) (2)	1,190.0 MMBTU/HR (EACH)	0.0073 LB/MMBTU	TURBINE DESIGN	OTHER
NJ-0029	ALGONQUIN GAS TRANSMISSION COMPANY	HANOVER	03/31/1995	02/10/1999	TURBINES COMBUSTION, TWO SOLAR CENTAUR	3.1 MW EACH	0.26 LB/H	BOILER DESIGN	BACT-PSD
NY-0072	KAMINE/BESICORP SYRACUSE LP	SOLVAY	12/10/1994	04/27/1995	SIEMENS V64.3 GAS TURBINE (EP #00001)	650.0 MMBTU/HR	0.007 LB/MMBTU, 4.6 LB/HR		BACT-OTHER
PR-0002	PUERTO RICO ELECTRIC POWER AUTHORITY (PREPA)	ARECIBO	07/31/1995	05/06/1998	COMBUSTION TURBINES (3), 83 MW SIMPLE-CYCLE EACH	248.0 MW	11.0 LB/HR (AS METHANE)	IMPLEMENT GOOD COMBUSTION PRACTICES.	BACT-PSD
PR-0002	PUERTO RICO ELECTRIC POWER AUTHORITY (PREPA)	ARECIBO	07/31/1995	05/06/1998	COMBUSTION TURBINES (3), B3 MW SIMPLE-CYCLE EACH	248.0 MW	13.0 LB/HR (AS METHANE)	SCR	BACT-PSD

Source: RBLC 2000.

MAXIMUM	30.0 PPMVD @ 15% O2
MINIMUM	1.0 PPMVD @ 15% O2
AVERAGE	7.4 PPMVD @ 15% O2

Table 6-1. Air Quality Impact Analysis Summary
Distillate Fuel Oil-Firing (Page 1 of 3)

	Case 1 (100% Load, 18°F Ambient)					Case 2 (75% Load, 18°F Ambient)					Case 3 (50% Load, 18°F Ambient)					Case 4 (100% Load, 59°F Ambient)				
	1992	1993	1994	1995	1996	1992	1993	1994	1995	1996	1992	1993	1994	1995	1996	1992	1993	1994	1995	1996
Nominal 10 g/s Impacts:																				
HSH, 1-Hour ($\mu\text{g}/\text{m}^3$)	393.8	408.6	407.4	358.8	404.5	473.7	470.4	482.1	466.1	432.8	520.7	525.4	511.6	512.1	527.0	418.6	438.6	439.5	382.6	431.3
HSH, 3-Hour ($\mu\text{g}/\text{m}^3$)	179.9	175.6	194.5	120.0	172.2	270.4	215.3	233.1	160.7	184.9	281.7	266.8	265.6	237.6	240.3	206.7	200.2	204.7	131.4	194.6
HSH, 8-Hour ($\mu\text{g}/\text{m}^3$)	102.3	91.5	112.1	75.2	113.6	110.3	124.4	115.0	104.7	128.3	136.4	137.4	131.8	134.8	149.1	110.1	106.7	119.9	87.5	123.3
HSH, 24-Hour ($\mu\text{g}/\text{m}^3$)	58.8	47.6	50.6	28.8	79.0	62.7	63.9	69.2	39.3	87.2	76.7	86.8	88.0	46.9	93.3	67.3	52.8	56.1	33.2	87.1
Annual ($\mu\text{g}/\text{m}^3$)	2.5	1.9	1.9	1.0	1.5	4.6	3.9	3.3	2.0	2.9	6.9	5.8	4.6	3.0	4.2	3.2	2.6	2.4	1.3	1.9
SO ₂																				
Emission Rate (g/s)	13.17	13.17	13.17	13.17	13.17	10.62	10.62	10.62	10.62	10.62	8.43	8.43	8.43	8.43	8.43	12.38	12.38	12.38	12.38	12.38
HSH, 3-Hour ($\mu\text{g}/\text{m}^3$)	237.0	231.3	256.2	158.1	226.8	287.1	228.7	247.5	495.0	196.4	237.5	224.9	223.9	431.7	202.6	255.9	247.8	253.5	162.7	240.9
HSH, 24-Hour ($\mu\text{g}/\text{m}^3$)	77.4	62.7	66.6	37.9	104.0	66.6	67.8	73.4	41.7	92.6	64.6	73.2	74.2	39.6	78.7	83.3	65.4	69.5	41.1	107.8
Annual ($\mu\text{g}/\text{m}^3$)	3.3	2.5	2.5	1.3	2.0	4.9	4.2	3.5	2.1	3.1	5.8	4.9	3.9	2.5	3.6	4.0	3.2	2.9	1.6	2.4
NO ₂																				
Emission Rate (g/s)	16.67	16.67	16.67	16.67	16.67	13.31	13.31	13.31	13.31	13.31	10.47	10.47	10.47	10.47	10.47	15.65	15.65	15.65	15.65	15.65
Tier I Annual ($\mu\text{g}/\text{m}^3$)	4.2	3.2	3.2	1.6	2.6	6.2	5.2	4.4	2.6	3.9	7.2	6.1	4.8	3.1	4.4	5.0	4.0	3.7	2.0	3.0
Tier II Annual ($\mu\text{g}/\text{m}^3$)	3.2	2.4	2.4	1.2	1.9	4.6	3.9	3.3	2.0	2.9	5.4	4.6	3.6	2.4	3.3	3.8	3.0	2.8	1.5	2.3
PM/PM ₁₀																				
Emission Rate (g/s)	6.78	6.78	6.78	6.78	6.78	6.30	6.30	6.30	6.30	6.30	5.88	5.88	5.88	5.88	5.88	6.63	6.63	6.63	6.63	6.63
HSH, 24-Hour ($\mu\text{g}/\text{m}^3$)	39.9	32.3	34.3	19.5	53.6	39.5	40.2	43.6	24.7	54.9	45.1	51.0	51.7	27.6	54.9	44.6	35.0	37.2	22.0	57.7
Annual ($\mu\text{g}/\text{m}^3$)	1.7	1.3	1.3	0.7	1.0	2.9	2.5	2.1	1.2	1.8	4.0	3.4	2.7	1.8	2.5	2.1	1.7	1.6	0.8	1.3
CO																				
Emission Rate (g/s)	8.82	8.82	8.82	8.82	8.82	8.14	8.14	8.14	8.14	8.14	9.34	9.34	9.34	9.34	9.34	8.13	8.13	8.13	8.13	8.13
HSH, 1-Hour ($\mu\text{g}/\text{m}^3$)	347.4	360.4	359.3	316.5	356.8	385.6	382.9	392.4	379.4	352.3	486.3	490.7	477.8	478.3	492.2	340.3	356.6	357.3	311.1	350.6
HSH, 8-Hour ($\mu\text{g}/\text{m}^3$)	90.2	80.7	98.9	66.3	100.2	89.8	101.3	93.6	85.2	104.4	127.4	128.3	123.1	125.9	139.2	89.5	86.7	97.5	71.1	100.3

Table 6-1. Air Quality Impact Analysis Summary
Distillate Fuel Oil-Firing (Page 2 of 3)

	Case 5 (75% Load, 59°F Ambient)					Case 6 (50% Load, 59°F Ambient)					Case 7 (100% Load, 72°F Ambient)					Case 8 (75% Load, 72°F Ambient)				
	1992	1993	1994	1995	1996	1992	1993	1994	1995	1996	1992	1993	1994	1995	1996	1992	1993	1994	1995	1996
Nominal 10 g/s Impacts:																				
HSH, 1-Hour ($\mu\text{g}/\text{m}^3$)	493.3	496.9	481.9	492.6	469.2	544.9	553.5	544.3	510.2	555.0	423.1	443.3	445.1	394.0	436.2	496.3	482.4	475.8	496.7	474.8
HSH, 3-Hour ($\mu\text{g}/\text{m}^3$)	253.2	249.9	242.9	182.9	200.3	276.8	266.5	263.1	264.8	271.9	216.4	205.0	207.7	135.3	197.0	255.9	251.5	260.3	187.4	201.4
HSH, 8-Hour ($\mu\text{g}/\text{m}^3$)	120.1	130.7	124.2	111.1	135.8	144.3	156.1	139.9	146.3	156.9	111.4	112.1	121.4	89.8	125.2	121.7	131.8	127.1	113.0	136.8
HSH, 24-Hour ($\mu\text{g}/\text{m}^3$)	67.0	68.4	74.6	41.3	91.7	74.6	87.2	83.1	52.2	97.6	68.7	54.1	56.6	34.0	88.6	67.7	69.4	77.5	41.9	92.4
Annual ($\mu\text{g}/\text{m}^3$)	5.3	4.5	3.7	2.3	3.3	7.7	6.6	5.0	3.4	4.7	3.4	2.7	2.5	1.3	2.0	5.4	4.6	3.8	2.3	3.4
SO ₂																				
Emission Rate (g/s)	10.00	10.00	10.00	10.00	10.00	7.97	7.97	7.97	7.97	7.97	12.10	12.10	12.10	12.10	12.10	9.75	9.75	9.75	9.75	9.75
HSH, 3-Hour ($\mu\text{g}/\text{m}^3$)	253.2	249.9	242.9	182.9	200.3	220.6	212.4	209.7	406.6	216.7	261.8	248.0	251.3	476.7	238.3	249.5	245.3	253.8	484.3	196.3
HSH, 24-Hour ($\mu\text{g}/\text{m}^3$)	67.0	68.4	74.6	41.3	91.7	59.5	69.5	66.2	41.6	77.8	83.1	65.4	68.4	41.2	107.2	66.0	67.7	75.6	40.9	90.1
Annual ($\mu\text{g}/\text{m}^3$)	5.3	4.5	3.7	2.3	3.3	6.2	5.3	4.0	2.7	3.7	4.1	3.3	3.0	1.6	2.5	5.3	4.5	3.7	2.3	3.3
NO ₂																				
Emission Rate (g/s)	12.52	12.52	12.52	12.52	12.52	9.9	9.89	9.89	9.89	9.89	15.32	15.32	15.32	15.32	15.32	12.21	12.21	12.21	12.21	12.21
Tier I Annual ($\mu\text{g}/\text{m}^3$)	6.6	5.7	4.6	2.8	4.1	7.7	6.5	5.0	3.4	4.6	5.2	4.2	3.8	2.1	3.1	6.6	5.7	4.6	2.8	4.1
Tier II Annual ($\mu\text{g}/\text{m}^3$)	5.0	4.2	3.5	2.1	3.1	5.7	4.9	3.7	2.5	3.5	3.9	3.1	2.8	1.5	2.4	4.9	4.3	3.5	2.1	3.1
PM/PM ₁₀																				
Emission Rate (g/s)	6.19	6.19	6.19	6.19	6.19	5.80	5.80	5.80	5.80	5.80	6.58	6.58	6.58	6.58	6.58	6.14	6.14	6.14	6.14	6.14
HSH, 24-Hour ($\mu\text{g}/\text{m}^3$)	41.5	42.3	46.2	25.5	56.8	43.3	50.6	48.2	30.3	56.6	45.2	35.6	37.2	22.4	58.3	41.5	42.6	47.6	25.8	56.7
Annual ($\mu\text{g}/\text{m}^3$)	3.3	2.8	2.3	1.4	2.0	4.5	3.8	2.9	2.0	2.7	2.2	1.8	1.6	0.9	1.3	3.3	2.8	2.3	1.4	2.1
CO																				
Emission Rate (g/s)	7.47	7.47	7.47	7.47	7.47	9.00	9.00	9.00	9.00	9.00	7.88	7.88	7.88	7.88	7.88	7.32	7.32	7.32	7.32	7.32
HSH, 1-Hour ($\mu\text{g}/\text{m}^3$)	368.5	371.2	360.0	368.0	350.5	490.5	498.1	489.8	459.2	499.5	333.4	349.3	350.8	310.5	343.7	363.3	353.1	348.3	363.6	347.6
HSH, 8-Hour ($\mu\text{g}/\text{m}^3$)	89.7	97.7	92.8	136.6	101.4	129.8	140.5	125.9	131.7	141.2	87.8	88.3	95.6	106.6	98.6	89.1	96.5	93.1	82.7	100.2

Table 6-1. Air Quality Impact Analysis Summary
Distillate Fuel Oil-Firing (Page 3 of 3)

	Case 9 (50% Load, 72°F Ambient)					Case 10 (100% Load, 93°F Ambient)					Case 11 (75% Load, 93°F Ambient)					Case 12 (50% Load, 93°F Ambient)					Maximums
	1992	1993	1994	1995	1996	1992	1993	1994	1995	1996	1992	1993	1994	1995	1996	1992	1993	1994	1995	1996	
Nominal 10 g/s Impacts:																					
HSH, 1-Hour ($\mu\text{g}/\text{m}^3$)	547.4	555.9	546.7	514.9	557.4	430.9	449.3	451.6	408.7	442.4	505.3	490.8	487.2	508.6	404.5	558.4	567.5	554.0	529.0	564.5	567.5
HSH, 3-Hour ($\mu\text{g}/\text{m}^3$)	280.3	270.3	264.0	267.5	275.0	228.9	211.0	215.3	139.3	200.1	263.8	256.3	265.1	201.4	172.2	292.2	281.6	267.0	275.9	284.1	292.2
HSH, 8-Hour ($\mu\text{g}/\text{m}^3$)	146.5	159.5	140.8	147.3	157.7	113.2	119.3	123.2	92.8	127.6	126.3	134.9	129.0	118.4	113.6	153.1	166.8	143.8	150.5	160.3	166.8
HSH, 24-Hour ($\mu\text{g}/\text{m}^3$)	75.5	88.0	83.7	52.7	98.1	70.7	55.7	58.4	36.0	90.5	69.7	72.5	80.5	42.9	79.0	78.1	90.5	85.3	54.5	99.4	99.4
Annual ($\mu\text{g}/\text{m}^3$)	7.8	6.7	5.1	3.5	4.7	3.6	2.9	2.6	1.4	2.2	5.8	5.0	4.0	2.5	1.5	8.1	6.9	5.2	3.6	4.8	8.1
SO ₂																					
Emission Rate (g/s)	7.75	7.75	7.75	7.75	7.75	11.69	11.70	11.70	11.70	11.70	9.25	9.25	9.25	9.25	9.25	7.35	7.35	7.35	7.35	7.35	13.2
HSH, 3-Hour ($\mu\text{g}/\text{m}^3$)	217.2	209.5	204.6	399.1	213.1	267.6	246.9	251.9	163.0	234.1	244.0	237.1	245.2	470.5	159.3	214.8	207.0	196.2	388.8	208.8	495.0
HSH, 24-Hour ($\mu\text{g}/\text{m}^3$)	58.5	68.2	64.8	40.9	76.0	82.6	65.2	68.3	42.1	105.9	64.4	67.1	74.5	39.6	73.1	57.4	66.5	62.7	40.1	73.1	107.8
Annual ($\mu\text{g}/\text{m}^3$)	6.1	5.2	3.9	2.7	3.7	4.2	3.4	3.0	1.7	2.6	5.3	4.6	3.7	2.3	1.4	6.0	5.1	3.8	2.6	3.6	6.2
NO ₂																					
Emission Rate (g/s)	9.61	9.61	9.61	9.61	9.61	14.82	14.82	14.82	14.82	14.82	11.58	11.58	11.58	11.58	11.58	9.10	9.10	9.10	9.10	9.10	16.7
Tier I Annual ($\mu\text{g}/\text{m}^3$)	7.5	6.4	4.9	3.3	4.5	5.3	4.3	3.8	2.1	3.2	6.7	5.8	4.6	2.9	1.8	7.4	6.3	4.7	3.3	4.4	7.7
Tier II Annual ($\mu\text{g}/\text{m}^3$)	5.6	4.8	3.6	2.5	3.4	4.0	3.2	2.9	1.6	2.4	5.0	4.3	3.4	2.2	1.3	5.5	4.7	3.5	2.4	3.3	5.7
PM/PM ₁₀																					
Emission Rate (g/s)	5.76	5.76	5.76	5.76	5.76	6.50	6.50	6.50	6.50	6.50	6.04	6.04	6.04	6.04	6.04	5.68	5.68	5.68	5.68	5.68	6.8
HSH, 24-Hour ($\mu\text{g}/\text{m}^3$)	43.5	50.7	48.2	30.4	56.5	45.9	36.2	38.0	23.4	58.9	42.1	43.8	48.6	25.9	47.7	44.4	51.4	48.4	31.0	56.5	58.9
Annual ($\mu\text{g}/\text{m}^3$)	4.5	3.8	2.9	2.0	2.7	2.3	1.9	1.7	0.9	1.4	3.5	3.0	2.4	1.5	0.9	4.6	3.9	2.9	2.0	2.7	4.6
CO																					
Emission Rate (g/s)	9.40	9.40	9.40	9.40	9.40	7.61	7.61	7.61	7.61	7.61	7.07	7.07	7.07	7.07	7.07	10.24	10.24	10.24	10.24	10.24	10.2
HSH, 1-Hour ($\mu\text{g}/\text{m}^3$)	514.6	522.5	513.9	484.0	524.0	327.9	341.9	343.6	311.0	336.7	357.2	347.0	344.4	359.6	286.0	571.8	581.1	567.3	541.7	578.1	581.1
HSH, 8-Hour ($\mu\text{g}/\text{m}^3$)	137.7	150.0	132.4	138.5	148.3	86.1	90.8	93.8	70.6	97.1	89.3	95.4	91.2	83.7	80.3	156.8	170.8	147.2	154.1	164.1	170.8

	Project Impact	Case No.	Year	Florida AAQS	Federal NAAQS	% of AAQS Florida	% of AAQS Federal
SO ₂							
HSH, 3-Hour ($\mu\text{g}/\text{m}^3$)	495.0	2	1995	1,300	1,300	38.1	38.1
HSH, 24-Hour ($\mu\text{g}/\text{m}^3$)	107.8	4	1996	260	365	41.5	29.5
Annual ($\mu\text{g}/\text{m}^3$)	6.2	6	1992	60	80	10.3	7.7
NO ₂							
Tier II Annual ($\mu\text{g}/\text{m}^3$)	5.7	6	1992	100	100	5.7	5.7
PM ₁₀							
HSH, 24-Hour ($\mu\text{g}/\text{m}^3$)	58.9	10	1996	150	150	39.2	39.2
Annual ($\mu\text{g}/\text{m}^3$)	4.6	12	1992	50	50	9.2	9.2
CO							
HSH, 1-Hour ($\mu\text{g}/\text{m}^3$)	581.1	12	1993	40,000	40,000	1.5	1.5
HSH, 8-Hour ($\mu\text{g}/\text{m}^3$)	170.8	12	1993	10,000	10,000	1.7	1.7