

RF

STATE OF FLORIDA  
DEPARTMENT OF ENVIRONMENTAL REGULATION



SOUTHWEST DISTRICT

7601 HIGHWAY 301 NORTH  
TAMPA, FLORIDA 33610-9544

BOB GRAHAM  
GOVERNOR

VICTORIA J. TSCHINKEL  
SECRETARY

DR. RICHARD D. GARRITY  
DISTRICT MANAGER

November 6, 1984

Mr. A. Spencer Autry, Manager  
Environmental Planning  
Tampa Electric Company  
Post Office Box 111  
Tampa, FL 33601

Re: Hillsborough County - AP  
Tampa Electric Company  
Gannon Station Turbine  
A029-85099

Dear Mr. Autry:

In response to Tampa Electric Company discussions with the Department concerning Specific Condition No. 6 which established the maximum sulfur content of the fuel, the Department hereby amends permit number A029-85099 as follows:

From: Specific Condition No. 2: This unit must be fired on No. 2 fuel oil with a maximum sulfur content of 0.3%

To: Specific Condition No. 6: This unit must be fired on No. 2 fuel oil.

This letter must be attached to and becomes a part of said permit.

Sincerely,

W. C. Thomas, P.E.  
District Engineer  
Air Programs

JWE/scm

cc: HCEPC