



RECEIVED
JAN 18 1995

Department of Environmental Protection
SOUTHWEST DISTRICT
BY _____

January 16, 1995

Mr. George Richardson
Florida Department of Environmental Protection
Southwest District
3804 Coconut Palm Drive
Tampa, Florida 33612

Via Facsimile & U.S. Mail

Re: Tampa Electric Company
F.J. Gannon Station
Air Operating Permits AO29-250137, AO29-250139, and AO20-25014

Dear Mr. Richardson:

Pursuant to our meeting on January 12, 1995, TEC and DEP have agreed to the following items:

Rotoclones Permit AO29-250139 ⁴
Change Specific Condition No. ~~4~~ from:

⁴ ~~5~~ Compliance with.....
Coal Bunkers 5 and 6 shall be tested within 60 days prior to or on March 29, 1995.

To:

⁴ ~~5~~ Compliance with.....
Coal Bunkers 5 and 6 shall be tested within 90 days prior to or on March 29, 1995.

Change Specific Condition No. 7 from:

7. Testing of emissions to
Any time the permitted rate of the source is exceeded by more than 10% a compliance test shall be performed within 15 days.....

To:

7. Testing of emissions to
Any time the permitted rate of the source is exceeded by more than 10% a compliance test shall be performed within 30 days.....

Flyash Silos Permits AO29-250137 and AO29-250140

Change Specific Condition No. 8 from:

8. Testing of emissions to show compliance shall be.... *Determination of the process rate may be done by calculations, which shall be employed on a consistent basis.*

Mr. George Richardson
January 16, 1995
Page 2

To:

8. Testing of emission to show compliance shall be*Determination of the process rate will be done by operations procedures as outlined in Specific Condition No. 7 above and employed on a consistent basis.*

In addition TEC request that Specific Condition No. 4 in the flyash silos permits be changed to allow for a 90 day test window instead of a 60 day test window.

Please feel free to call Ms. Janice Taylor or me at (813) 228-4839 should you have any questions. Thank you for your attention in this matter.

Sincerely,



Patrick A. Ho, P.E.
Manager
Environmental Planning

EP\sn\JKT700

c: Mr. J. Kessel, FDEP

cc: EPC, C Gonzalez -
JRH 1/23/95