

MEMORANDUM

TO: FILE

THROUGH: BILL THOMAS, P.E.

THROUGH: JERRY KISSEL, P.E. *JK*

FROM: GEORGE RICHARDSON *GR*

DATE: JULY 13, 1994

SUBJECT: Hillsborough County - AP
Tampa Electric Company
Gannon Station Units 5 & 6 Fly Ash Silo
A029-250137

This permit is for the operation of F.J. Gannon Station Units 5 & 6 Fly Ash Silo (silo No. 1) and Pugmill with truck loading located at Port Sutton Road, Tampa, Hillsborough County.


Particulate emissions generated during the filling of the silo are controlled by a 11,300 ACFM United States Filter Corporation Mikro-Pulsaire Model 1F3-24 baghouse.

The fly ash in the silo is gravity fed by chute into enclosed tanker trucks or to a pugmill where it is "conditioned" by wetting with water and gravity fed by chute into open bed trucks.

TECO made some suggested changes to the draft permit that I sent to them on 6/30, see enclosed.

The sources are in compliance with the existing permit conditions.

I recommend this permit be issued as conditioned.



Florida Department of Environmental Regulation

Southwest District

Lawton Chiles, Governor

3804 Coconut Palm

813-744-6100

April 13, 1993

Tampa, Florida 33619

Virginia B. Wetherell, Secretary

MR LYNN ROBINSON
MGR ENV PLANNING
TAMPA ELECTRIC CO
PO BOX 111
TAMPA FL 33601-0111

Dear Permittee:

RE: Permit Expiration Letters for Non-delegated Facility in Hillsborough County

The Department recently delegated air permitting authority to the Environmental Protection Commission of Hillsborough County, except for a few non-delegated facilities, such as yours. This letter is to advise you that in the future, the Department will not continue the practice of notifying your facility of permits due to expire. This service was provided by the County in the past.

For information purposes only please note the following:

Pursuant to Rule 17-4.080(3), F.A.C., *Modification of Permit Conditions*, the permittee, may, for good cause, request that a construction permit be extended. Such a request shall be submitted to the Department at least 60 days prior to the expiration date of the permit.

Pursuant to Rule 17-4.090(1), F.A.C., *Renewals*, an application to renew an operating permit shall be submitted to the Department no later than 60 days prior to the expiration date of the permit.

Thank you for your cooperation in this matter. If you have any questions, please call Mr. J. Harry Kerns, P.E., District Air Engineer, of my staff at (813)744-6100 extension 419.

Sincerely,

W. C. Thomas, P.E.
Air Program Administrator

WCT/HK/ss

cc: Read file
EPCHC

permix.lr