




UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

REGION IV

345 COURTLAND STREET
ATLANTA, GEORGIA 30365



PERMIT TO CONSTRUCT UNDER THE RULES FOR THE
PREVENTION OF SIGNIFICANT DETERIORATION OF AIR QUALITY

PSD-FL-086

Pursuant to and in accordance with the provisions of Part C, Subpart 1 of the Clean Air Act, as amended, 42 U.S.C. §7470 et seq., and the regulations promulgated thereunder at 40 C.F.R. §52.21, as amended at 45 Fed. Reg. 52676, 52735-41 (August 7, 1980),

The City of Tampa
306 East Jackson Street
Tampa, Florida 33602

is hereby authorized to construct/modify a stationary source at the following location:

Adjacent McKay Bay
South of Florida Route 60
Tampa, Florida

UTM Coordinates: 360.0 km East, 3091.9 km North

Upon completion of this authorized construction and commencement of operation/production, this stationary source shall be operated in accordance with the emission limitations, sampling requirements, monitoring requirements and other conditions set forth in the attached Specific Conditions (Part I) and General Conditions (Part II).

JUL 2 1982

This permit shall become effective on _____

If construction does not commence within 18 months after the effective date of this permit, or if construction is discontinued for a period of 18 months or more, or if construction is not completed within a reasonable time this permit shall expire and authorization to construct shall become invalid.

This authorization to construct/modify shall not relieve the owner or operator of the responsibility to comply fully with all applicable provisions of Federal, State, and Local law.

July 2, 1982

Date Signed

Charles R. Jeter, Deputy for
Regional Administrator

SPECIFIC CONDITIONS

1. The maximum allowable emissions from the resource recovery facility no. 1 shall be:

Pollutant	Emission Limitation
Sulfur dioxide	170.0 lb/hr
Nitrogen Oxides	300.0 lb/hr
Lead	3.1 lb/hr
Fluoride	6.0 lb/hr
Mercury (vaporous and particulate)	0.6 lb/hr
Beryllium 5 grams/24-hour period	0.00046 lb/hr

2. Municipal waste only shall be burned in the facility.

Wastewater treatment plant sludges or hazardous wastes shall not be incinerated.

3. Electric output for sale to Tampa Electric Company (TECO) shall not exceed 25 MW.

4. Hours of operation for the facility shall be 24 hours per day, 7 days per week, 52 weeks per year.

5. An operation and maintenance plan shall be submitted with the state operating permit application and be made part of this permit.

6. Compliance testing for all criteria and NESHAPS pollutants shall be conducted in accordance with the methods contained in 40 CFR 60 and 61. A source testing plan shall be submitted to the Department of Environmental Regulation for approval 90 days prior to testing. The Department shall be notified of compliance testing at least 30 days prior to the testing.

7. The applicant shall record and keep on file the daily charging rate of the facility and the hours of operation of the facility and shall report this information quarterly to the permitting authority.

8. The applicant shall install and operate continuous opacity monitoring equipment.

GENERAL CONDITIONS

1. The permittee shall notify the permitting authority in writing of the beginning of construction of the permitted source within 30 days of such action and the estimated date of start-up of operation.
2. The permittee shall notify the permitting authority in writing of the actual start-up of the permitted source within 30 days of such action and the estimated date of demonstration of compliance as required in the specific conditions.
3. Each emission point for which an emission test method is established in this permit shall be tested in order to determine compliance with the emission limitations contained herein within sixty (60) days of achieving the maximum production rate but in no event later than 180 days after initial start-up of the permitted source. The permittee shall notify the permitting authority of the scheduled date of compliance testing at least thirty (30) days in advance of such test. Compliance test results shall be submitted to the permitting authority within forty-five (45) days after the complete testing. The permittee shall provide (1) sampling ports adequate for test methods applicable to such facility, (2) safe sampling platforms, (3) safe access to sampling platforms, and (4) utilities for sampling and testing equipment.
4. The permittee shall retain records for all information resulting from monitoring activities and information indicating operating parameters as specified in the specific

conditions of this permit for a minimum of two (2) years from the date of recording.

5. If, for any reason, the permittee does not comply with or will not be able to comply with the emission limitations specified in this permit, the permittee shall provide the permitting authority with the following information in writing within ten (10) business days of such conditions:

- (a) description of noncomplying emission(s).
- (b) cause of noncompliance,
- (c) anticipated time the noncompliance is expected to continue or, if corrected, the duration of the period of noncompliance,
- (d) steps taken by the permittee to reduce and eliminate the noncomplying emission,

and

- (e) steps taken by the permittee to prevent recurrence of the noncomplying emission.

Failure to provide the above information when appropriate shall constitute a violation of the terms and conditions of this permit. Submittal of this report does not constitute a waiver of the emission limitations contained within this permit.

6. Any change in the information submitted in the application regarding facility emissions or changes in the quantity or quality of materials processed that will result in new or increased emissions must be reported to the permitting authority. If appropriate, modifications to the permit

may then be made by the permitting authority to reflect any necessary changes in the permit conditions.

7. In the event of any change in control or ownership of the source described in the permit, the permittee shall notify the succeeding owner of the existence of this permit by letter and forward a copy of such letter to the permitting authority.

8. The permittee shall allow representatives of the State environmental control agency or representatives of the Environmental Protection Agency, upon the presentation of credentials:

- (a) To be allowed reasonable access to the permittee's premises, or other premises under the control of the permittee, where an air pollutant source is located or in which any records are required to be kept under the terms and conditions of the permit;
 - (b) to have access to and copy at reasonable times any records required to be kept under the terms and conditions of this permit, or the Act;
 - (c) to inspect at reasonable times any monitoring equipment of monitoring methods required in this permit;
 - (d) to sample at reasonable times any emission of pollutants;
- and
- (e) to perform at reasonable times an operation and maintenance inspection of the permitted source.

9. All correspondence required to be submitted by this permit to the permitting agency shall be mailed to:

Chief, Air Management Branch

U. S. Environmental Protection Agency

Region IV

345 Courtland Street

Atlanta, Georgia 30365

10. The conditions of this permit are severable, and if any provision of this permit, or the application of any provision of this permit to any circumstance, is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.

The emission of any pollutant more frequently or at a level in excess of that authorized by this permit shall constitute a violation of the terms and conditions of this permit.