



Barbara File

Department of Environmental Protection

Lawton Chiles
Governor

Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Virginia B. Wetherell
Secretary

NOTICE OF ADMINISTRATIVELY CORRECTED TITLE V PERMIT

In the Matter of an Application for Administrative Correction:


Mr. Rex Taylor
City Manager, Utilities Director
City of Vero Beach
PO Box 1389
Vero Beach, FL 32961-1389

Final Permit No.: 0610029-002-AV
City of Vero Beach Municipal Utilities

Enclosed are Administratively Corrected pages to Title V Final Permit Number 0610029-002-AV for the operation of the City of Vero Beach Municipal Utilities located at 100 17th Street, Vero Beach, Indian River County, issued pursuant to Chapter 403, Florida Statutes (F.S.). This Administrative Permit Correction was processed as project number 0610029-003-AV, pursuant to Rule 62-210.360, Florida Administrative Code (F.A.C.). The corrected pages of the Final Permit should be retained, along with this notice, with the Final Permit.

Any party to this order (permit) has the right to seek judicial review of the permit pursuant to Section 120.68, F.S., by the filing of a Notice of Appeal pursuant to Rule 9.110, Florida Rules of Appellate Procedure, with the Clerk of the permitting authority in the Legal Office; and by filing a copy of the Notice of Appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal. The Notice of Appeal must be filed within 30 (thirty) days from the date this Notice is filed with the Clerk of the permitting authority.

Executed in Tallahassee, Florida.


C. H. Fancy, P.E.
Chief
Bureau of Air Regulation


CERTIFICATE OF SERVICE

The undersigned duly designated deputy agency clerk hereby certifies that this NOTICE OF ADMINISTRATIVELY CORRECTED PERMIT was sent by certified mail (*) and copies were mailed by U.S. Mail before the close of business on 06-04-98 to the person(s) listed or as otherwise noted:

Mr. Rex Taylor, City Manager, Utilities Director *
Mr. Shuler W. Massey, Director of Power Resources *
Mr. Richard M. Siefert, City of Vero Beach Power Plant
Mr. Len Kozlov P.E., DEP Central District
Ms. Carla E. Pierce, USEPA, Region 4 (INTERNET E-mail Memorandum)
Ms. Yolanda Adams, USEPA, Region 4 (INTERNET E-mail Memorandum)

Clerk Stamp

FILING AND ACKNOWLEDGMENT FILED, on this date, pursuant to Section 120.52(7), Florida Statutes, with the designated agency Clerk, receipt of which is hereby acknowledged.

 06-04-98
(Clerk) (Date)

"Protect, Conserve and Manage Florida's Environment and Natural Resources"

ADMINISTRATIVE PERMIT CORRECTION

Administrative Permit Correction to Final Permit No.: 0610029-002-AV

I. Notification

Notice of minor corrections to the above Final Permit were received from Mr. Rex Taylor on May 19, 1998, pursuant to Rule 62-210.360, F.A.C. The following corrections were made to the Final Permit.

Appendix M, Custom Fuel Monitoring Schedule for Natural Gas, was revised on June 1, 1998 to add ASTM Method D5504-94 as an approved test method for sulfur in natural gas. Specifically, paragraph 2.a. of the appendix was revised, and the title of the appendix was revised to include the revision date. The revised appendix is enclosed with this notice.

II. Conclusion.

The permitting authority hereby issues the Administrative Permit Correction with the changes noted above.

**Appendix M, Custom Fuel Monitoring Schedule for Natural Gas
(Revised June 1, 1998)**

Pursuant to 40 CFR 60.334(b)(2), a custom fuel monitoring schedule shall be followed for the natural gas fired at this facility and shall be as follows:

1. Monitoring of fuel nitrogen content shall not be required when natural gas is the only fuel being fired in the turbines.
2. Sulfur Monitoring
 - a. Analysis for fuel sulfur content of the natural gas fired at this facility shall be conducted using one of the approved ASTM reference methods for the measurement of sulfur in gaseous fuels, or an approved alternate method. The reference methods approved by this permit are ASTM D5504-94, ASTM D1072-80(90), ASTM D3031-81, ASTM D3246-81 and ASTM D4084-82, as referenced in 40 CFR 60.335(b)(2).
 - b. This custom fuel monitoring schedule shall become effective on the date this permit is effective. Effective the date of this custom schedule, sulfur monitoring of natural gas fired at the facility shall be conducted twice monthly for six months. If this monitoring shows little variability in the fuel sulfur content and indicates consistent compliance with the sulfur limits of 40 CFR 60.333, then sulfur monitoring shall be conducted once per quarter for six quarters.
 - c. If, after monitoring required in item 2.b. above, the sulfur content shows little variability and, calculated as sulfur dioxide, represents consistent compliance with the sulfur dioxide emission limits specified under 40 CFR 60.333, and the fuel sulfur limits of this permit, sample analysis shall be conducted twice per year. This monitoring shall be conducted during the first and third quarters of each calendar year.
 - d. Should any sulfur analysis, as required in items 2.b. or 2.c. above indicate noncompliance with the sulfur limits of 40 CFR 60.333 or this permit, the owner or operator shall notify the Department of such excess emissions and the custom schedule shall be re-examined by the Environmental Protection Agency (EPA). Sulfur monitoring shall be conducted weekly during the interim period when this custom schedule is being re-examined.
3. If there is a change in fuel supply, the owner or operator shall notify the Department and EPA of such change for re-examination of this custom schedule. A substantial change in fuel quality shall be considered as a change in fuel supply. Sulfur monitoring shall be conducted weekly during the interim period when this custom schedule is being re-examined.
4. Records of sample analysis and fuel supply pertinent to this custom fuel monitoring schedule for natural gas shall be retained for a period of five years, and shall be available at the facility for inspection by personnel of the Department or EPA.

Is your RETURN ADDRESS completed on the reverse side?

SENDER:

- Complete items 1 and/or 2 for additional services.
- Complete items 3, 4a, and 4b.
- Print your name and address on the reverse of this form so that we can return this card to you.
- Attach this form to the front of the mailpiece, or on the back if space does not permit.
- Write "Return Receipt Requested" on the mailpiece below the article number.
- The Return Receipt will show to whom the article was delivered and the date delivered.

I also wish to receive the following services (for an extra fee):

- 1. Addressee's Address
- 2. Restricted Delivery

Consult postmaster for fee.

3. Article Addressed to:

Mr. Shuler W. Massey
Director of Power Resources
City of Vero Beach
Post Office Box 1389
Vero Beach, FL 32961-1389

4a. Article Number

Z 392 940 897

4b. Service Type

- Registered
- Express Mail
- Return Receipt for Merchandise
- Certified
- Insured
- COD

7. Date of Delivery

6-8-98

5. Received By: (Print Name)

6. Signature: (Addressee or Agent)

X *George Young*

8. Addressee's Address (Only if requested and fee is paid)

Thank you for using Return Receipt Service.

PS Form 3811, December 1994

Domestic Return Receipt

Receipt

Is your RETURN ADDRESS completed on the reverse side?

SENDER:

- Complete items 1 and/or 2 for additional services.
- Complete items 3, 4a, and 4b.
- Print your name and address on the reverse of this form so that we can return this card to you.
- Attach this form to the front of the mailpiece, or on the back if space does not permit.
- Write "Return Receipt Requested" on the mailpiece below the article number.
- The Return Receipt will show to whom the article was delivered and the date delivered.

I also wish to receive the following services (for an extra fee):

- 1. Addressee's Address
- 2. Restricted Delivery

Consult postmaster for fee.

3. Article Addressed to:

Mr. Rex Taylor
City Manager, Utilities Director
City of Vero Beach
Post Office Box 1389
Vero Beach, FL 32961-1389

4a. Article Number

Z 392 940 894

4b. Service Type

- Registered
- Express Mail
- Return Receipt for Merchandise
- Certified
- Insured
- COD

7. Date of Delivery

6-8-98

5. Received By: (Print Name)

6.

PS

Thank you for using Return Receipt Service.

Z 392 940 894

Receipt for Certified Mail



No Insurance Coverage Provided
Do not use for International Mail
(See Reverse)

Mr. Rex Taylor
City Manager, Utilities Director
City of Vero Beach
Post Office Box 1389
Vero Beach, FL 32961-1389

PS Form

Certified Fee	
Special Delivery Fee	
Restricted Delivery Fee	
Return Receipt Showing to Whom & Date Delivered	
Return Receipt Showing to Whom, Date, and Addressee's Address	
TOTAL Postage & Fees	\$
Postmark or Date	06-04-98 SW

Is your RETURN ADDRESS completed on the reverse side?

SENDER:

- Complete items 1 and/or 2 for additional services.
- Complete items 3, 4a, and 4b.
- Print your name and address on the reverse of this form so that we can return this card to you.
- Attach this form to the front of the mailpiece, or on the back if space does not permit.
- Write "Return Receipt Requested" on the mailpiece below the article number.
- The Return Receipt will show to whom the article was delivered and the date delivered.

I also wish to receive the following services (for an extra fee):

- 1. Addressee's Address
- 2. Restricted Delivery

Consult postmaster for fee.

3. Article Addressed to:

Mr. Shuler W. Massey
Director of Power Resources
City of Vero Beach
Post Office Box 1389
Vero Beach, FL 32961-1389

4a. Article Number

Z 392 940 897

4b. Service Type

- Registered
- Express Mail
- Return Receipt for Merchandise
- Certified
- Insured
- COD

7. Date of Delivery

6-8-98

5. Received By: (Print Name)

6. Signature: (Addressee or Agent)

X *George Young*

8. Addressee's Address (Only if requested and fee is paid)

Thank you for using Return Receipt Service.

Z 392 940 897

Receipt for Certified Mail



No Insurance Coverage Provided
Do not use for International Mail
(See Reverse)

Mr. Shuler W. Massey
Director of Power Resources
City of Vero Beach
Post Office Box 1389
Vero Beach, FL 32961-1389

PS Form

Certified Fee	
Special Delivery Fee	
Restricted Delivery Fee	
Return Receipt Showing to Whom & Date Delivered	
Return Receipt Showing to Whom, Date, and Addressee's Address	
TOTAL Postage & Fees	\$
Postmark or Date	06-04-98 SW