

## Scearce, Lynn

---

**From:** Koletzke, Marilyn  
**Sent:** Monday, August 15, 2011 11:50 AM  
**To:** 'Aaron Corkum'  
**Cc:** Osbourn, Scott ([Scott\\_Osbourn@golder.com](mailto:Scott_Osbourn@golder.com)); Ed Priest; Scearce, Lynn  
**Subject:** RE: Cutrale Citrus Juices USA,. Leesburg and Auburndale Facilities FACs 0690002 and 1050023

Mr. Corkum,

Thank you for your reply. As per your advice, I will remove No. 2 fuel oil as an alternate fuel source from the permits at both facilities.

Marilyn

Marilyn Koletzke, P.E.  
Engineer  
Florida Department of Environmental Protection  
Division of Air Resource Management  
Permitting and Compliance Section  
[marilyn.koletzke@dep.state.fl.us](mailto:marilyn.koletzke@dep.state.fl.us)  
Phone (850) 717-9112 FAX (850) 717-9097

---

**From:** Aaron Corkum [<mailto:acorkum@cutrale.com>]  
**Sent:** Monday, August 15, 2011 11:43 AM  
**To:** Koletzke, Marilyn  
**Cc:** Osbourn, Scott ([Scott\\_Osbourn@golder.com](mailto:Scott_Osbourn@golder.com)); Ed Priest  
**Subject:** RE: Cutrale Citrus Juices USA,. Leesburg and Auburndale Facilities FACs 0690002 and 1050023

Dear Marilyn,

The Cutrale – Leesburg and Auburndale Facilities have removed the equipment and capability of using No. 2 fuel oil for our combustion turbines, boilers and/or duct burners. We are firing natural gas only. Please let me know if you have any additional questions.

Thank you,  
Aaron P. Corkum  
Environmental Affairs Manager  
Cutrale Citrus Juices USA, Inc.

---

**From:** Koletzke, Marilyn [<mailto:Marilyn.Koletzke@dep.state.fl.us>]  
**Sent:** Friday, August 12, 2011 11:41 AM  
**To:** Aaron Corkum  
**Cc:** [sosbourn@golder.com](mailto:sosbourn@golder.com)  
**Subject:** Cutrale Citrus Juices USA,. Leesburg and Auburndale Facilities FACs 0690002 and 1050023

Mr. Corkum

On July 20, 2011, we received your application and sufficient fee for the purpose of removing fuel oil as an alternate fuel source in the concurrent air construction permit No. 0690002-015-AC for the Cutrale Citrus Juices USA, Inc., Leesburg Facility Combustion Turbine (EU-009). We also received on July 20, 2011 your application and sufficient fee for the Title V Air Operation Permit No. 0690002-026-AV for the purpose of removing fuel oil as an alternate fuel source in the

concurrent air construction permit No. 0690002-027-AC for the Cutrale Citrus Juices USA, Inc., Auburndale Facility Combustion Turbines (EU-019, and EU-020).

- Please confirm that the Leesburg facility's existing Babcock & Wilcox Model 1079 Boiler #4 (EU-004) will continue to fire No. 2 fuel oil with a maximum sulfur content of 0.1 percent, by weight.
- Likewise please confirm that the Auburndale facility's existing English Boiler and Tube Boiler No.1 (EU-018) will continue to fire No. 2 fuel oil with a maximum sulfur content of 0.1 percent, by weight.

As the 30-day clock for issuing an RFI expires on August 20, 2011, please respond to this request before Wednesday August 17 to avoid further delay and the issuance of RFIs for these projects.

Thank you

Marilyn

Marilyn Koletzke, P.E.  
Engineer  
Florida Department of Environmental Protection  
Division of Air Resource Management  
Permitting and Compliance Section  
[marilyn.koletzke@dep.state.fl.us](mailto:marilyn.koletzke@dep.state.fl.us)  
Phone (850) 717-9112 FAX (850) 717-9097

*The Department of Environmental Protection values your feedback as a customer. DEP Secretary Herschel T. Vinyard Jr. is committed to continuously assessing and improving the level and quality of services provided to you. Please take a few minutes to comment on the quality of service you received. Simply click on [this link to the DEP Customer Survey](#). Thank you in advance for completing the survey.*

**IMPORTANT NOTE:** The information contained in this message and its attachments, if any, is **CONFIDENTIAL**. If the reader of this message is not the intended recipient or an agent responsible for delivering it, you are hereby notified that you have received this communication in error, and that any dissemination, distribution, retention or copy of this communication is strictly prohibited, subject to applicable law. If you are not the intended recipient or have otherwise received this e-mail communication in error, please advise the sender by reply e-mail and immediately delete this e-mail communication from any computer and destroy all copies of same.