

Golder Associates Inc.

6241 NW 23rd Street, Suite 500
Gainesville, FL 32653-1500
Telephone (352) 336-5600
Fax (352) 336-6603



May 6, 1999

9737572-0100

Mr. C.H. Fancy, P.E., Chief
Bureau of Air Regulation
Florida Department of Environmental Protection
111 South Magnolia Drive, Suite 4
Tallahassee, Florida 32301

RECEIVED

MAY 07 1999

BUREAU OF
AIR REGULATION

Attention: Ms. Teresa Heron

RE: Inlet Foggers – Combustion Turbines 1-12
Florida Power & Light Company (FPL) Fort Myers Plant

Dear Teresa:

0710002-005-AC

This correspondence is submitted to address the Department's information request related to the installation of direct water spray fogging system to the inlet of the Fort Myers gas turbines. The information requested is presented below and in attachments to this correspondence.

1. Information Requested: Please submit additional data to support the statement that the emission rate does not change as a result of inlet fogging.

Information Submitted: As discussed in the application, the use of the direct water spray fogging systems will increase the relative humidity of the gas stream while concomitantly reducing the temperature due to adiabatic cooling of the inlet air. This effect is no different than when the turbine is operated under the same ambient conditions that occurs during the normal course of operation in any year. However, it allows the turbine to operate under such ambient conditions more frequently and thus can effect annual emissions. The influence on the emission rate of increasing the relative humidity and temperature is explained in EPA's Alternative Control Techniques Document – NO_x Emissions from Stationary Gas Turbines (EPA-453/R-93-007, January 1993). In Section 4.2.1.3 the report provides information that indicates emissions of NO_x decrease with increasing relative humidity. Also, the mass emission of NO_x decreases per mass of fuel input. This is also the same as lower emissions per amount electric power generated (since power and fuel input are directly related).

The lower NO_x emissions with increasing relative humidity and lower temperature can be shown using the equation in Section 4.2.1.3; the adjustment equation in 40 C.F.R. Part 60 Subpart GG, Section 60.335(c)(1). Table 1 presents calculation of relative NO_x concentrations for various temperatures and relative humidity. As can be seen from the table the relative NO_x concentration decreases with increasing

humidity and decreasing temperature. The combined effect can be seen in the last column. Please find attached relevant pages from the EPA cited document. This EPA information is supported by the results of the testing performed at the Putnam Plant that indicated no change in emission rate (concentration) when the fogging system was used. These data also demonstrated no statistical change in CO concentrations as well.

The potential applicability of New Source Performance Standards (NSPS) Subpart GG would be dependant on whether the installation of a fogging system is considered a modification under Section 60.14 of 40 C.F.R. 60. The determination is based on whether a physical change resulted in an increase in the emission rate that is expressed in kilograms per hour. The emission rate can be determined using AP-42, materials balance, CEMs or manual stack tests [see paragraphs (1) and (2) of Section 60.14]. The tests must be conducted under representative performance of the facility and that all operating conditions which can effect emissions must be held constant to the maximum degree feasible. As described above, the inlet foggers only change the ambient conditions that do occur during the normal operation of the turbine. Testing under the requirement to maintain all operating conditions which may effect emissions (i.e., in this case temperature and relative humidity) constant would produce the same result. Thus, the short-term emission rates do not change. Nonetheless, the fogging system does increase the long-term emissions for which a limit on the operation of the fogging system has been requested to keep the increase below the PSD significant emission rate.

2. Information Requested: In reference to Table 1. Emission Estimates of the Ft. Myers Simple Cycle Combustion Turbines indicate the nominal values for power out, heat rate and heat input.

Information Submitted: The information presented in Table 1 presents the *rate of change* of power, heat rate and heat input for the turbine. The basis of the information is the attached performance curves. As noted from the curves the performance (fuel input and power) is a linear function of inlet temperature. The primary purpose of using the performance curves is to determine the increase in heat rate as a function of temperature. This was determined from the performance curves as 2 mmBtu per °F shown in Table 1. This was then used with the hours of operation to calculate the tons per year. As an example: $2 \text{ mmBtu} / ^\circ\text{F} \times 0.038 \text{ lb/mmBtu} \times 8 \text{ } ^\circ\text{F}/\text{hour} \times 500 \text{ hours} \times 1 \text{ ton}/2,000 \text{ lb} = 0.15 \text{ tons/year}$ for particulate matter. The 2 mmBtu / °F was determined as follows: At 59 °F the relative fuel consumption is 1 as shown in the performance curve. The heat input is 717.8 mmBtu/hr based on low heating value (LHV). This is multiplied by 1.06 to convert to high heating value (HHV) which gives $717.8 \text{ mmBtu/hr} \times 1.06 = 760.9 \text{ mmBtu/hr}$ at 59 °F. At 80 °F, the fuel consumption is 95% of the 59 °F inlet rating or $0.95 \times 760.9 \text{ mmBtu/hr} = 722.8 \text{ mmBtu/hr}$. The difference is 38.1 mmBtu/hr ($760.9 - 722.8$) over 21 °F ($80 - 59$) or 1.81 mmBtu / °F; this value was rounded up to 2 mmBtu / °F.

3. Information Requested: Submit the heat input curves for these units.

Information Submitted: The heat input curve for the unit is attached.


Your prompt review of the application is appreciated. If there are any further questions, please call.

Sincerely,

GOLDER ASSOCIATES INC.



Kennard F. Kosky, P.E.
Principal
Professional Engineer No. 14996

SEAL 

KFK/jkk

Enclosures

cc: Rich Piper, Repowering Licensing Manager
William Reichel, Fort Myers Plant General Manager

G:\DATA\DP\PROJECTS\97\9737\9737572\F3\#02ltr.doc

Table 1. Relative NO_x Concentrations as a Function of Turbine Inlet Temperature and Relative Humidity using NSPS Equation^a

Temperature (°F)	Relative Humidity (RH) (percent)	Water (grains) per pound of dry Air	Water (grams) per gram of dry Air	Relative NO _x Emission of RH	Temperature (°K)	Relative NO _x Emission of Temp.	Relative NO _x Emission of RH & Temp.
95	40	100	0.0143	0.8597	308	1.1082	0.9527
95	60	150	0.0214	0.7506	308	1.1082	0.8318
95	80	200	0.0286	0.6553	308	1.1082	0.7262
95	100	250	0.0357	0.5722	308	1.1082	0.6341
75	40	64	0.0091	0.9480	297	1.0476	0.9931
75	60	78	0.0111	0.9126	297	1.0476	0.9561
75	80	119	0.0170	0.8165	297	1.0476	0.8554
75	100	130	0.0186	0.7925	297	1.0476	0.8302
59	40	30	0.0043	1.0396	288	1.0000	1.0396
59	60	44	0.0063	1.0008	288	1.0000	1.0008
59	80	60	0.0086	0.9583	288	1.0000	0.9583
59	100	72	0.0103	0.9276	288	1.0000	0.9276
40	40	15	0.0021	1.0828	277	0.9445	1.0227
40	60	23	0.0033	1.0595	277	0.9445	1.0007
40	80	30	0.0043	1.0396	277	0.9445	0.9819
40	100	36	0.0051	1.0228	277	0.9445	0.9660

^a As provided in 40 C.F.R Part 60, Section 60.335(c)(1)

Note: water content (mass) per mass of dry air obtained from standard psychrometric chart.

**Alternative Control
Techniques Document--
NO_x Emissions from Stationary
Gas Turbines**

Emission Standards Division

**U. S. ENVIRONMENTAL PROTECTION AGENCY
Office of Air and Radiation
Office of Air Quality Planning and Standards
Research Triangle Park, North Carolina 27711
January 1993**

REPRODUCED BY
U.S. DEPARTMENT OF COMMERCE
NATIONAL TECHNICAL
INFORMATION SERVICE
SPRINGFIELD, VA 22161

substantially lower thermal NO_x emissions than natural gas or DF-2.¹⁸ For fuels containing FBN, the fuel NO_x production increases with increasing levels of FBN.

4.2.1.3 Ambient Conditions. Ambient conditions that affect NO_x formation are humidity, temperature, and pressure. Of these ambient conditions, humidity has the greatest effect on NO_x formation.¹⁹ The energy required to heat the airborne water vapor has a quenching effect on combustion temperatures, which reduces thermal NO_x formation. At low humidity levels, NO_x emissions increase with increases in ambient temperature. At high humidity levels, the effect of changes in ambient temperature on NO_x formation varies. At high humidity levels and low ambient temperatures, NO_x emissions increase with increasing temperature. Conversely, at high humidity levels and ambient temperatures above 10°C (50°F), NO_x emissions decrease with increasing temperature. This effect of humidity and temperature on NO_x formation is shown in Figure 4-4. A rise in ambient pressure results in higher pressure and temperature levels entering the combustor and so NO_x production levels increase with increases in ambient pressure.¹⁹

The influence of ambient conditions on measured NO_x emission levels can be corrected using the following equation:²⁰

$$NO_x = (NO_{xO}) (P_r/P_o)^{0.5} e^{19(H_o - 0.00633)} (288^\circ K/T_a)^{1.53}$$

where:

NO_x = emission rate of NO_x at 15 percent O₂ and International Standards Organization (ISO) ambient conditions, volume percent;

NO_{xO} = observed NO_x concentration, parts per million by volume (ppmv) referenced to 15 percent O₂;

P_r = reference compressor inlet absolute pressure at 101.3 kilopascals ambient pressure, millimeters mercury (mm Hg);

P_o = observed compressor inlet absolute pressure at test, mm Hg;




Figure 4-4. Influence of relative humidity and ambient temperature on NO_x formation. 19

H_o = observed humidity of ambient air, g H_2O /g air;

e = transcendental constant, 2.718; and

T_a = ambient temperature, K.

At least two manufacturers state that this equation does not accurately correct NO_x emissions for their turbine models.^{8,12} It is expected that these turbine manufacturers could provide corrections to this equation that would more accurately correct NO_x emissions for the effects of ambient conditions based on test data for their turbine models.

4.2.1.4 Operating Cycles. Emissions from identical turbines used in simple and cogeneration cycles have similar NO_x emissions levels, provided no duct burner is used in heat recovery applications. The NO_x emissions are similar because, as stated in Section 4.2, NO_x is formed only in the turbine combustor and remains at this level regardless of downstream temperature reductions. A turbine operated in a regenerative cycle produces higher NO_x levels, however, due to increased combustor inlet temperatures present in regenerative cycle applications.²¹

4.2.1.5 Power Output Level. The power output level of a gas turbine is directly related to the firing temperature, which is directly related to flame temperature. Each gas turbine has a base-rated power level and corresponding NO_x level. At power outputs below this base-rated level, the flame temperature is lower, so NO_x emissions are lower. Conversely, at peak power outputs above the base rating, NO_x emissions are higher due to higher flame temperature. The NO_x emissions for a range of firing temperatures are shown in Figure 4-3 for one manufacturer's gas turbine.¹⁷

4.2.2 NO_x Emissions From Duct Burners

In some cogeneration and combined cycle applications, the exhaust heat from the gas turbine is not sufficient to produce the desired quantity of steam from the HRSG, and a supplemental burner, or duct burner, is placed in the exhaust duct between the

GENERAL ELECTRIC MODEL PG7821; 65,600 KW GAS TURBINE PACKAGE POWER PLANT

ESTIMATED PERFORMANCE


COMPRESSOR INLET TEMPERATURE 69°F BAROMETRIC PRESSURE 14.7 PSIA

FUEL		NATURAL GAS	
DESIGN OUTPUT	KW	65,600	
DESIGN HEAT RATE (LHV)	BTU/KW-HR	10,900	
DESIGN FUEL CONSUMPTION (LHV)	BTU/HR	726.8×10^6	
HEATING VALUE RATIO	HHV/LHV	1.11	
DESIGN AIR FLOW	LBS/HR		
DESIGN SHAFT SPEED	RPM		

DISTILLATE OIL
65,200
11,010
 717.8×10^6
1.065

BY: R. ROENBECK
DATE: 6/15/72
REV:

MODE: PEAK



NOTES:

1. ALTITUDE CORRECTION ON CURVE 416HA662.
2. EFFECT OF COMPRESSOR INLET TEMPERATURE ON MAXIMUM OUTPUT, AIRFLOW AND HEAT RATE ON CURVE 416HA1291.
3. PLANT PERFORMANCE IS NET AT THE GENERATOR TERMINALS AND INCLUDES ALLOWANCES FOR PRESSURE DROPS AND FOR AUXILIARIES.

GENERATOR OUTPUT - PERCENT

416HA1290



Jeb Bush
Governor

Department of Environmental Protection

Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

David B. Struhs
Secretary

April 16, 1999

CERTIFIED MAIL - RETURN RECEIPT REQUESTED

Mr. Richard Piper
Repowering Licensing Manager
Florida Power & Light Company
Post Office Box 14000
Juno Beach, Florida 33408

Re: Inlet Foggers – Ft. Myers Plant Combustion Turbines 1-12


Dear Mr. Piper:

The Department received your application for the installation of the direct water spray fogging system at the Ft. Myers Plant. Based on a technical review, the application is incomplete. Pursuant to Rules 62-4, 62-204, 62-210, 62-212, 62-296 and 62-297, F.A.C., please submit the following information, including all relevant reference materials and calculations:

1. Please submit additional data to support the statement that the emission rate does not change as a result of inlet fogging.
2. In reference to Table 1. Emissions Estimates of the Ft. Myers Simple Cycle Combustion Turbines, indicate the nominal values for power output, heat rate and heat input increase.
3. Submit the heat input curves for these units.

Please contact Teresa Heron at 850/921-9529 if you have any questions.

Sincerely,


for C. H. Fancy, P.E., Chief
Bureau of Air Regulation.

cc: Ken Kosky, P.E
Phil Barbaccia, SWD

Is your RETURN ADDRESS completed on the reverse side?

SENDER:
 ■ Complete items 1 and/or 2 for additional services.
 ■ Complete items 3, 4a, and 4b.
 ■ Print your name and address on the reverse of this form so that we can return this card to you.
 ■ Attach this form to the front of the mailpiece, or on the back if space does not permit.
 ■ Write "Return Receipt Requested" on the mailpiece below the article number.
 ■ The Return Receipt will show to whom the article was delivered and the date delivered.

I also wish to receive the following services (for an extra fee):
 1. Addressee's Address
 2. Restricted Delivery
 Consult postmaster for fee.

3. Article Addressed to:
 Richard Piper
 Repowering Licensing Trng
 FP+L
 PO Box 14000
 Juno Beach, FL 33408

5. Received By: (Print Name)
 R. Napsich


6. Signature: (Addressee or Agent)
 X

4a. Article Number
 2333 618 097

4b. Service Type
 Registered
 Express Mail
 Return Receipt for Merchandise

7. Date of Delivery

8. Addressee's Address (Only if requested and fee is paid)



Thank you for using Return Receipt Service.

Z 333 618 097

US Postal Service
Receipt for Certified Mail
 No Insurance Coverage Provided.
 Do not use for International Mail (See reverse)

Sent to Richard Piper	
Street & Number FP+L	
Post Office, State, & ZIP Code Juno Beach FL	
Postage	\$
Certified Fee	
Special Delivery Fee	
Restricted Delivery Fee	
Return Receipt Showing to Whom & Date Delivered	
Return Receipt Showing to Whom, Date, & Addressee's Address	
TOTAL Postage & Fees	\$
Postmark or Date	4-15-99
Ft. Myers Plant	

PS Form 3800, April 1995