

Sheplak, Scott

From: Sheplak, Scott
Sent: Wednesday, July 01, 2009 10:51 AM
To: 'Washington, Kevin'
Cc: Vielhauer, Trina; Satyal, Ajaya
Subject: RE: EMERGENCY GENERATORS - FT. MYERS POWER PLANT

Re: Permit No. 0710002-016-AV

-file-

Thank you for the notification. They are most likely "insignificant." A copy of this e-mail will be kept on file here with the subject permit.

From: Washington, Kevin [mailto:Kevin.Washington@fpl.com]
Sent: Wednesday, July 01, 2009 10:12 AM
To: Vielhauer, Trina; Sheplak, Scott; Satyal, Ajaya
Subject: EMERGENCY GENERATORS - FT. MYERS POWER PLANT

Trina, Scott, & A.J.,

Emergency Generators have been installed at the location referenced above as part of FPL's Hurricane Hardening program. The generators were installed after the Title V Permit renewal process was completed. The generators provide power to a small "safe room" constructed for operating employees to use in the event of a significant storm. Each safe room has two generators; a primary and a back up. The generators are fueled by propane stored in four 120-gallon tanks.

Location	Make	Model	Ignition	HP	Rated KW	Year Built
RPM	Rule Applicability					
Ft. Myers	Guardian,	004725	Spark	34	25	2006
3600	None					
	by Generac					

The generators are categorically exempt from permitting as provided by Rule 62-210.300(3)(a). They are also exempt from 40 CFR Part 60 Subparts JJJJ due to their manufacture date (2006), and from ZZZZ due to their size (<500 Hp).

The next time the Title V permit is opened for renewal, both generator packages will be added as insignificant or unregulated sources.

If you have any questions or require additional information feel free to contact me via return E:mail, or at (561) 691-2877.

Thank you,

Kevin Washington
 Project Manager
 FPL Environmental Services
 (561) 691-2877
kevin_washington@fpl.com

7/1/2009