



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

REGION 4
ATLANTA FEDERAL CENTER
61 FORSYTH STREET
ATLANTA, GEORGIA 30303-8960

July 11, 2003

4 APT-APB

Mr. A. A. Linero, P.E.
Florida Department of Environmental Protection
Mail Station 5500
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

RECEIVED

JUL 14 2003

BUREAU OF AIR REGULATION

Dear Mr. Linero:

Thank you for your letter dated June 12, 2003, and the accompanying revised prevention of significant deterioration (PSD) draft PSD permit (and supporting materials) for a proposed modification of the Lee County Resource Recovery Facility. The proposed modification consists primarily of adding a third municipal waste combustor.

We have no additional comments on the revised draft permit or on the technical evaluation and preliminary best available control technology determination accompanying the draft permit. Regarding the applicability of certain federal new performance standards in 40 CFR part 60, our opinion is that subpart Db, subpart E, and subpart Cb are not applicable to the proposed municipal waste combustor.

If you have any questions concerning the comments in this letter, please call Jim Little at 404-562-9118.

Sincerely,

A handwritten signature in black ink, appearing to read "Joel W. Huey".

Joel W. Huey
Acting Chief
Air Permits Section