

Sheplak, Scott

From: Dunbar, Kirk [Kirk.Dunbar@hdrinc.com]
Sent: Thursday, January 19, 2012 11:47 AM
To: Sheplak, Scott
Cc: sampsolj@leegov.com; Castro, Don
Subject: RE: Lee County RRF Title V and PSD Permits

Scott – Thanks for bringing that to my attention. My comment in the December 16, 2011 letter was erroneous. The limit should be 0.080 mg/dscm.

Thanks for clarifying and sorry for my prior error.

Kirk

M. KIRK DUNBAR

HDR Engineering
Air Quality Section Manager

701 Xenia Avenue South, Suite 600 | Minneapolis, MN 55416
phone: 763-591-5476 | fax: 763-591-5413
kirk.dunbar@hdrinc.com | hdrinc.com

From: Sheplak, Scott [<mailto:Scott.Sheplak@dep.state.fl.us>]
Sent: Thursday, January 19, 2012 10:34 AM
To: Dunbar, Kirk
Subject: FW: Lee County RRF Title V and PSD Permits

See the comments on the Title v permit on page 5. Title V Air Operation Permit No. 0710119-007-AV - Specific Condition III.B.38. Permitting Note. The comment was that the current federal Hg limit for MWC Unit 3 is 0.050 mg/dscm.

It should be 0.080 mg/dscm?

Please take a few minutes to share your comments on the service you received from the department by clicking on this link. [DEP Customer Survey](#).

From: Sampson, Lindsey [<mailto:LSampson@leegov.com>]
Sent: Friday, December 16, 2011 3:13 PM
To: Sheplak, Scott
Cc: Dunbar, Kirk; Gorrie,Jason; Huffman,Tyler; Duff,Michael; Castro, Don
Subject: Lee County RRF Title V and PSD Permits

Dear Scott,

Attached please find our comments and requests related to the draft Title V permit and the draft modifications to the PSD permit for the subject facility.

A hard copy original is in the mail.

Lindsey J. Sampson
Lee County Solid Waste Division