

CERTIFIED MAIL-RETURN RECEIPT REQUESTED August 27, 2002

RECEIVED

AUG 29 2002

BUREAU OF AIR REGULATION

Mr. C. H. Fancy, P.E., Chief Bureau of Air Regulation Florida Department of Environmental Protection Twin Towers Office Building Mail Station #5505 2600 Blair Stone Road Tallahassee, Florida 32399-2400

Attn: Mr. Ed Svec, P.E.

RE: Application for Air Permit for Replacement of Gas Turbine

Facility ID #0810007, Emissions Unit ID #016

Dear Mr. Fancy:

Enclosed please find four copies of our Application for an Air Permit for the replacement of the existing natural gas fired General Electric (GE) LM 5000 gas turbine with a natural gas fired GE LM 6000 gas turbine.

Please call me at 941-742-2748 if there are any questions.

Sincerely,

Douglas Foster

Director, Corporate Environmental & Safety

D543/jb

cc:

(letter only)

Ken Kosky, P.E., Golder Associates Scott Sheplak, FDEP, Tallahassee

Michael Haycock, TPI



DESIGNATION OF DOCUMENT SIGNATORY

I, James E. Dwyer, Jr., hereby certify that I am the President and Chief Executive Officer of Tropicana Products, Inc., ("Tropicana") and as such I am authorized to designate employees to prepare and sign documents and to certify on behalf of said company the accuracy and completeness of information in such documents.

Pursuant to the power vested in me, I hereby designate the person listed below to prepare and sign reports to the United States Environmental Protection Agency, the United Stated Department of Labor, Occupational Safety and Health, the Florida Department of Environmental Protection, the Southwest Florida Water Management District, and the County of Manatee, State of Florida, pertinent to the operation of the Tropicana plant located in Bradenton, Florida.

This designation is effective until revoked in writing.

Designated Signatory

Michael W. Haycock Vice President, Engineering & Bradenton Manufacturing 1001 13th Avenue East Bradenton, FL 34208

Dated:___

James E. Dwyer, Vr. President and CEO

RECLIVED

AUG 29 2002

BUREAU OF AIR REGULATION

RECEIVED

AUG 29 2002

BUREAU OF AIR REGULATION

APPLICATION FOR AIR PERMIT REPLACEMENT OF GAS TURBINE FOR TROPICANA PRODUCTS, INC. BRADENTON CITRUS PROCESSING FACILITY

.....

Prepared For:

Tropicana Products, Inc. Bradenton Citrus Processing Plant 1001 13th Avenue, East Bradenton, Florida 34208

Prepared By:

Golder Associates Inc. 6241 NW 23rd Street, Suite 500 Gainesville, Florida 32653-1500

> July 2002 0237563

DISTRIBUTION:

- 4 Copies FDEP
- 2 Copies Tropicana Products, Inc.
- 1 Copy Golder Associates Inc.

TABLE OF CONTENTS

| <u>SECTION</u> | PAGE |
|----------------|--|
| PART I: APPL | ICATION FOR AIR PERMIT |
| PART II: SUPI | PORTING INFORMATION |
| 1.0 INTRO | DDUCTION1 |
| 1.1 | EXISTING FACILITY1 |
| 1.2 | LM 6000 GAS TURBINE2 |
| 1.3 | APPLICABLE REQUIREMENTS AND PERMITTING CONDITIONS2 |
| LIST OF TAB | <u>LES</u> |
| Table I | Design Information and Stack Parameters for Tropicana Products, Inc., LM 6000 Gas Turbine, Natural Gas, Baseload |
| Table 2 | Maximum Emissions for Criteria Pollutants for Tropicana Products, Inc., LM 6000 Gas Turbine, Natural Gas, Baseload |
| Table 3 | Net Emissions Increases Associated with Tropicana Products LM 6000 Project at Bradenton Citrus Processing Facility |
| LIST OF ATT | <u>ACHMENTS</u> |
| ATTACHMEN | VT A TITLE V PERMIT CONDITIONS FOR COGENERATION FACILITY |

PART I

APPLICATION FOR AIR PERMIT LONG FORM



Department of RECEIVED Environmental Protection Division of Air Resources Management $s_{UREAUOFA/RREGULATION}$

APPLICATION FOR AIR PERMIT - TITLE V SOURCE

I. APPLICATION INFORMATION

| Facility Owner/Company Name: Tropicana Products, Inc. | |
|--|---------------------------------------|
| 2. Site Name: | |
| Bradenton Citrus Processing Facility | |
| 3. Facility Identification Number: 081000 | 7 [] Unknown |
| 4. Facility Location: Street Address or Other Locator: 1001 13th | n Avenue |
| | Manatee Zip Code: 34208 |
| 5. Relocatable Facility? | 6. Existing Permitted Facility? |
| [] Yes [X] No | [X] Yes [] No |
| Application Contact | |
| 1. Name and Title of Application Contact: | |
| Douglas E. Foster, Director, Corporate Envi | ironmental & Safety |
| 2. Application Contact Mailing Address: | · · · · · · · · · · · · · · · · · · · |
| Organization/Firm: Tropicana Products, | Inc. |
| Street Address: P.O. Box 338 | |
| City: Bradenton | State: FL Zip Code: 34206 |
| 3. Application Contact Telephone Numbers: | |
| Telephone: (941) 742 - 2748 | Fax: (941) 742-3768 |
| Application Processing Information (DEP U | Jse) |
| 1. Date of Receipt of Application: | 4-29-02 |
| 2. Permit Number: | 0810007-011-AC |
| 3. PSD Number (if applicable): | |
| 4. Siting Number (if applicable): | |
| | - |

Effective: 2/11/99

Purpose of Application

Air Operation Permit Application

| Th | is | Application for Air Permit is submitted to obtain: (Check one) |
|-----|-----|---|
| [|] | Initial Title V air operation permit for an existing facility which is classified as a Title V source. |
| [|] | Initial Title V air operation permit for a facility which, upon start up of one or more newly constructed or modified emissions units addressed in this application, would become classified as a Title V source. |
| | | Current construction permit number: |
| [|] | Title V air operation permit revision to address one or more newly constructed or modified emissions units addressed in this application. |
| | | Current construction permit number: |
| | | Operation permit number to be revised: |
| [|] | Title V air operation permit revision or administrative correction to address one or more proposed new or modified emissions units and to be processed concurrently with the air construction permit application. (Also check Air Construction Permit Application below.) |
| | | Operation permit number to be revised/corrected: |
| [|] | Title V air operation permit revision for reasons other than construction or modification of an emissions unit. Give reason for the revision; e.g., to comply with a new applicable requirement or to request approval of an "Early Reductions" proposal. |
| | | Operation permit number to be revised: |
| | | Reason for revision: |
| Ai | r (| Construction Permit Application |
| Th | is | Application for Air Permit is submitted to obtain: (Check one) |
| [X |] | Air construction permit to construct or modify one or more emissions units. |
| [|] | Air construction permit to make federally enforceable an assumed restriction on the potential emissions of one or more existing, permitted emissions units. |
| [|] | Air construction permit for one or more existing, but unpermitted, emissions units. |

Owner/Authorized Representative or Responsible Official

| | Michael Haycock, Vice President, Manufacturing |
|----|--|
| 1. | Name and Title of Owner/Authorized Representative or Responsible Official: |

2. Owner/Authorized Representative or Responsible Official Mailing Address:

Organization/Firm: Tropicana Products, Inc.

Street Address: P.O. Box 338

City: Bradenton

State: FL

Zip Code: **34206**

3. Owner/Authorized Representative or Responsible Official Telephone Numbers:

Telephone: (941) 742 - 3349

Fax: (941) 749 - 2049

4. Owner/Authorized Representative or Responsible Official Statement:

I, the undersigned, am the owner or authorized representative *(check here [X], if so) or the responsible official (check here [], if so) of the Title V source addressed in this application, whichever is applicable. I hereby certify, based on information and belief formed after reasonable inquiry, that the statements made in this application are true, accurate and complete and that, to the best of my knowledge, any estimates of emissions reported in this application are based upon reasonable techniques for calculating emissions. The air pollutant emissions units and air pollution control equipment described in this application will be operated and maintained so as to comply with all applicable standards for control of air pollutant emissions found in the statutes of the State of Florida and rules of the Department of Environmental Protection and revisions thereof. I understand that a permit, if granted by the Department, cannot be transferred without authorization from the Department, and I will promptly notify the Department upon sale or legal transfer of any permitted emissions unit.

Signature

8/24/02

Professional Engineer Certification

1. Professional Engineer Name: Kennard F. Kosky

Registration Number: 14996

2. Professional Engineer Mailing Address:

Organization/Firm: Golder Associates Inc.*

Street Address: 6241 NW 23rd Street, Suite 500

City: Gainesville

State: FL

Zip Code: **32653-1500**

3. Professional Engineer Telephone Numbers:

Telephone: (352) 336 - 5600

Fax: (352) 336 - 6603

^{*} Attach letter of authorization if not currently on file.

^{*} Board of Professional Engineers Certificate of Authorization # 00001670

4. Professional Engineer Statement:

I, the undersigned, hereby certify, except as particularly noted herein*, that:

- (1) To the best of my knowledge, there is reasonable assurance that the air pollutant emissions unit(s) and the air pollution control equipment described in this Application for Air Permit, when properly operated and maintained, will comply with all applicable standards for control of air pollutant emissions found in the Florida Statutes and rules of the Department of Environmental Protection; and
- (2) To the best of my knowledge, any emission estimates reported or relied on in this application are true, accurate, and complete and are either based upon reasonable techniques available for calculating emissions or, for emission estimates of hazardous air pollutants not regulated for an emissions unit addressed in this application, based solely upon the materials, information and calculations submitted with this application.

If the purpose of this application is to obtain a Title V source air operation permit (check here [], if so), I further certify that each emissions unit described in this Application for Air Permit, when properly operated and maintained, will comply with the applicable requirements identified in this application to which the unit is subject, except those emissions units for which a compliance schedule is submitted with this application.

If the purpose of this application is to obtain an air construction permit for one or more proposed new or modified emissions units (check here [X], if so), I further certify that the engineering features of each such emissions unit described in this application have been designed or examined by me or individuals under my direct supervision and found to be in conformity with sound engineering principles applicable to the control of emissions of the air pollutants characterized in this application.

If the purpose of this application is to obtain an initial air operation permit or operation permit revision for one or more newly constructed or modified emissions units (check here [], if so), I further certify that, with the exception of any changes detailed as part of this application, each such emissions unit has been constructed or modified in substantial accordance with the information given in the corresponding application for air construction permit and with all provisions contained in such permit.

 $\frac{2 \sin \left(\frac{1}{2} \right) - \frac{8}{23} \cos \left(\frac{3}{23} \right)}{2}$ Signature
Date

* Attach any exception to certification statement.

Scope of Application

| Emissions Unit ID | Description of Emissions Unit | Permit Type | Processing Fee |
|----------------------|--|----------------|-------------------|
| Ome ID | Description of Emissions Circ | Туре | rec |
| 016 | Gas Turbine with HRSG and Duct Burners | AC1D | NA |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | <u> </u> | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | 1 | | |
| ····• | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |

Application Processing Fee

| Check one: [| Attached - Amount: \$: | ſx | 1 Not | Applicable |
|--------------|------------------------|----|--------|------------|
| Check one. | j Anachea - Amount, φ | | 1 1106 | Applicable |

Construction/Modification Information

1. Description of Proposed Project or Alterations:

Replacement of the existing natural gas fired, General Electric (GE) LM 5000 gas turbine (GT) with a natural gas fired, GE LM 6000 GT. The GT will also comply with 403.08725 F.S.

- 2. Projected or Actual Date of Commencement of Construction: 1 Sept 2002
- 3. Projected Date of Completion of Construction: 1 Mar 2003

Application Comment

The replacement unit is addressed as EU16 and includes the following changes:

- 1) The replacement of the LM5000 GT with an LM6000 GT.
- 2) Modifying heat input, fuel usage, and emission rates that will comply with 403.08725 F.S.
- 3) There will be no change in the duct burner system installed in the heat recovery steam generator.

II. FACILITY INFORMATION

A. GENERAL FACILITY INFORMATION

Facility Location and Type

| 1. | Facility UTM Coor | ·dinatae: | | | | | | |
|----|----------------------|----------------------------|-------------------|----------------------------|--|--|--|--|
| 1. | Zone: 17 | East (km) | · 561.4 Nort | th (km): 3056.5 | | | | |
| | | | . 301:4 | (Kiii). 3030:3 | | | | |
| 2. | Facility Latitude/Lo | _ | | | | | | |
| | Latitude (DD/MM/ | SS): 27/37/52 | Longitude (DD/MN | M/SS): 80 / 22 / 33 | | | | |
| 3. | Governmental | 4. Facility Status | 5. Facility Major | 6. Facility SIC(s): | | | | |
| | Facility Code: | Code: | Group SIC Code: | | | | | |
| | 0 | A | 20 | 2037, 2653, 3221 | | | | |
| | | | | | | | | |
| 7. | Facility Comment (| (limit to 500 characters): | | | | | | |
| | | | | | | | | |
| | See Attachment Par | rt II. | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |

Facility Contact

| 1. | Name | and | Title | of | Facilit | y Contact: |
|----|------|-----|-------|----|---------|------------|
|----|------|-----|-------|----|---------|------------|

Mr. George Cassady, Manager, Environmental Operations

2. Facility Contact Mailing Address:

Organization/Firm: Tropicana Products, Inc.

Street Address: P.O. Box 338

City: Bradenton State: FL

Zip Code: **34206**

3. Facility Contact Telephone Numbers:

Telephone: (941) 742 - 2677 Fax: (941) 742-2698

0237563/4/4.3/4.3.2 LM6000/CONST Effective: 2/11/99 7 8/23/02

Facility Regulatory Classifications

Check all that apply:

| 1. | [] Small Business Stationary Source? [] Unknown |
|----|--|
| 2. | [X] Major Source of Pollutants Other than Hazardous Air Pollutants (HAPs)? |
| 3. | [] Synthetic Minor Source of Pollutants Other than HAPs? |
| 4. | [X] Major Source of Hazardous Air Pollutants (HAPs)? |
| 5. | [] Synthetic Minor Source of HAPs? |
| 6. | [X] One or More Emissions Units Subject to NSPS? |
| 7. | [] One or More Emission Units Subject to NESHAP? |
| 8. | [] Title V Source by EPA Designation? |
| 9. | Facility Regulatory Classifications Comment (limit to 200 characters): |
| | NSPS Subpart GG does not apply to the gas turbine since it is not an electric utility stationary gas turbine. Subpart Db applies to the HRSG duct burners. |

List of Applicable Regulations

| This application will not change any applicable regulations for the facility. | | | |
|---|--|--|--|
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |

B. FACILITY POLLUTANTS

List of Pollutants Emitted

| 1. Pollutant Emitted | 2. Pollutant Classif. | 3. Requested Emissions Cap | | 4. Basis for Emissions | 5. Pollutant Comment |
|-------------------------|--------------------------|----------------------------|---------------------------------------|------------------------|----------------------|
| | | lb/hour | tons/year | Cap | Comment |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | ; |
| | | | | | |
| | | | | | |
| | | | *** | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | · · · · · · · · · · · · · · · · · · · | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |

C. FACILITY SUPPLEMENTAL INFORMATION

Supplemental Requirements

| 1. | Area Map Showing Facility Location: [] Attached, Document ID: | [X] Not Applicable [] Waiver Requested |
|----|--|---|
| 2. | Facility Plot Plan: [] Attached, Document ID: | [X] Not Applicable [] Waiver Requested |
| 3. | Process Flow Diagram(s): [] Attached, Document ID: | [X] Not Applicable [] Waiver Requested |
| 4. | Precautions to Prevent Emissions of Un [] Attached, Document ID: | confined Particulate Matter: [X] Not Applicable [] Waiver Requested |
| 5. | Fugitive Emissions Identification: [] Attached, Document ID: | [X] Not Applicable [] Waiver Requested |
| 6. | Supplemental Information for Construct [X] Attached, Document ID Part II | |
| 77 | | |
| 7. | Supplemental Requirements Comment: | |
| /. | Supplemental Requirements Comment: | |
| | Supplemental Requirements Comment: | |

Additional Supplemental Requirements for Title V Air Operation Permit Applications

| 8. List of Proposed Insignificant Activities: |
|---|
| [] Attached, Document ID: [X] Not Applicable |
| O List of Equipment/Activities Pagulated under Title VI: |
| 9. List of Equipment/Activities Regulated under Title VI: |
| [] Attached, Document ID: |
| [] Equipment/Activities On site but Not Required to be Individually Listed |
| [X] Not Applicable |
| 10. Alternative Methods of Operation: |
| [] Attached, Document ID: [X] Not Applicable |
| 11. Alternative Modes of Operation (Emissions Trading): |
| [] Attached, Document ID: [X] Not Applicable |
| |
| 12. Identification of Additional Applicable Requirements: |
| [] Attached, Document ID: [X] Not Applicable |
| 13. Risk Management Plan Verification: |
| [] Plan previously submitted to Chemical Emergency Preparedness and Prevention |
| Office (CEPPO). Verification of submittal attached (Document ID:) or |
| previously submitted to DEP (Date and DEP Office:) |
| [] Plan to be submitted to CEPPO (Date required:) |
| [X] Not Applicable |
| [A] Troct approach |
| 14. Compliance Report and Plan: |
| [] Attached, Document ID: [X] Not Applicable |
| 15. Compliance Certification (Hard-copy Required): |
| [] Attached, Document ID: [X] Not Applicable |
| [] Attached, Bootanent IB [X] Not Applicable |

| LM6000 | Gas 1 | Turbine |
|--------|-------|---------|
|--------|-------|---------|

| Emissions Unit Information Section 1 | of |
|--------------------------------------|----|
|--------------------------------------|----|

III. EMISSIONS UNIT INFORMATION

A separate Emissions Unit Information Section (including subsections A through J as required) must be completed for each emissions unit addressed in this Application for Air Permit. If submitting the application form in hard copy, indicate, in the space provided at the top of each page, the number of this Emissions Unit Information Section and the total number of Emissions Unit Information Sections submitted as part of this application.

A. GENERAL EMISSIONS UNIT INFORMATION (All Emissions Units)

Emissions Unit Description and Status

| 1. | Type of Emissions Unit Addressed in This Section: (Check one) | | | |
|------------|--|---------------------------|--|-------------------------|
| [X | This Emissions Unit Information Section addresses, as a single emissions unit, a single process or production unit, or activity, which produces one or more air pollutants and which has at least one definable emission point (stack or vent). | | | |
| [| process or prod | | n addresses, as a single emis s which has at least one defin gitive emissions. | 0 . |
| [| | | n addresses, as a single emis s which produce fugitive em | |
| 2. | Regulated or Unr | egulated Emissions Unit | ? (Check one) | |
| [X | The emissions unit. | unit addressed in this Em | nissions Unit Information Sec | ction is a regulated |
| [| The emissions unit. | unit addressed in this Em | hissions Unit Information Sec | ction is an unregulated |
| 3. | Description of Emissions Unit Addressed in This Section (limit to 60 characters): | | | |
| | Gas turbine with heat recovery steam generator (HRSG) and duct burners (cogeneration unit) | | | |
| 4. | Emissions Unit Identification Number: [] No ID | | | |
| | ID: 016 | T | <u>, </u> | [] ID Unknown |
| 5. | Emissions Unit | 6. Initial Startup | 7. Emissions Unit Major | 8. Acid Rain Unit? |
| | Status Code: | Date: | Group SIC Code: 49 | [] |
| 9. | Emissions Unit C | Comment: (Limit to 500 C | Characters) | |
| | The cogeneration units consists of a natural gas turbine with a maximum design heat input capacity of 434 MMBtu per hour, and a natural gas-fired duct burner with a maximum design heat input capacity of 104 MMBtu per hour. The cogeneration facility will have an electric generation capacity of 49.9 MW. The HRSG duct burner is subject to Federal NSPS (40 CFR 60 Subpart Db). | | | |

LM6000 Gas Turbine

Emissions Unit Control Equipment

| 1. | Control Equipment/Method Description (Limit to 200 characters per device or method): |
|----|--|
| | Low NO _x Burner – Gas |

2. Control Device or Method Code(s): 25

Incinerator Afterburner Temperature:

Emissions Unit Details

| Package Unit: Manufacturer: General Electric | Model Number: LM6000 |
|--|----------------------|
| 2. Generator Nameplate Rating: | 49.9 MW |
| 3. Incinerator Information: | |
| Dwell Temperature: | °F |
| Dwell Time: | seconds |

DEP Form No. 62-210.900(1) - Form Effective: 2/11/99

٥F

| Emissions Unit Information Section | 1 ol | f 1 |
|---|------|-----|
|---|------|-----|

LM6000 Gas Turbine

B. EMISSIONS UNIT CAPACITY INFORMATION (Regulated Emissions Units Only)

Emissions Unit Operating Capacity and Schedule

| 1. | Maximum Heat Input Rate: | | 456 | mmBtu/hr |
|----|---|--------------------------|-------------------------|------------------------|
| 2. | Maximum Incineration Rate: | lb/hr | · | tons/day |
| 3. | Maximum Process or Throughp | out Rate: | | |
| 4. | Maximum Production Rate: | | | |
| 5. | Requested Maximum Operating | Schedule: | | |
| | 24 | hours/day | 7 | days/week |
| | 52 | weeks/year | 8,760 | hours/year |
| 6. | Operating Capacity/Schedule C | omment (limit to 200 cha | aracters): | |
| | Maximum heat input rate based to 49.9 MW. | on 52°F, baseload, and H | HV. The ca _i | pacity will be limited |

| Emissions Unit Information Section | 1 | of | 1 | LM6000 Gas Turbine |
|------------------------------------|---|----|---|--------------------|
|------------------------------------|---|----|---|--------------------|

C. EMISSIONS UNIT REGULATIONS (Regulated Emissions Units Only)

List of Applicable Regulations

| Proposed LM6000 does not change applicable regulations in Title V Permit. | |
|---|--|
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |

Emissions Unit Information Section __1_ of __1 LM6000 Gas Turbine

D. EMISSION POINT (STACK/VENT) INFORMATION (Regulated Emissions Units Only)

Emission Point Description and Type

| 1. | Identification of Point on Pl Flow Diagram? | 2. Emission Point Type Code:1 | | | | | | |
|-----|---|--|------------------------------|---------------------|--|--|--|--|
| 3. | Descriptions of Emission Policy 100 characters per point): | oints Comprising | g this Emissions I | Unit for VE Trackin | g (limit to | | | |
| | Gases from the CT/HRSG exhaust through a single stack. | | | | | | | |
| 4. | 4. ID Numbers or Descriptions of Emission Units with this Emission Point in Common: | | | | | | | |
| | Emission Unit 016 | | | | | | | |
| 5. | Discharge Type Code: v | 6. Stack Heig | ht: 67 feet | 7. Exit Diameter: | 12 feet | | | |
| 0 | F. it T | O Astusl Val | | 10 Water Vener | | | | |
| δ. | Exit Temperature: 268 °F | 1 | umetric Flow 343,880 acfm | 10. Water Vapor: | % | | | |
| 11. | . Maximum Dry Standard Flo | ow Rate: dscfm | 12. Nonstack Er | mission Point Heigh | it: feet | | | |
| 13. | . Emission Point UTM Coord | linates: | | | ······································ | | | |
| | Zone: E | ast (km): | North (km): | | | | | |
| 14 | . Emission Point Comment (l | imit to 200 char | acters): | | | | | |
| | Based on exhaust from GT/HRSG at 49.9 MW. | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |
| | | | | | | | | |

| Emissions Unit Information Section | 1 | of | 1 |
|------------------------------------|---|----|---|
|------------------------------------|---|----|---|

| LM6000 | Gas | Turbine |
|--------|-----|---------|
| | | |

E. SEGMENT (PROCESS/FUEL) INFORMATION (All Emissions Units)

| Se | Segment Description and Rate: Segment 1 of 1 | | | | | | |
|-------------|--|---------------------------|---------------|---------------------------------------|--|--|--|
| 1. | 1. Segment Description (Process/Fuel Type) (limit to 500 characters): | | | | | | |
| | Internal Combustion Engines – Commercial / Institutional – Natural Gas - Turbine | | | | | | |
| 2. | Source Classification Code 2-03-002-02 | e (SCC): | 3. SCC Units: | ic Feet Burned | | | |
| 4. | Maximum Hourly Rate: 0.432 | 5. Maximum . 3,580 | i . | 6. Estimated Annual Activity Factor: | | | |
| 7. | Maximum % Sulfur: | 8. Maximum | % Ash: | 9. Million Btu per SCC Unit: 1,054.5 | | | |
| 10. | . Segment Comment (limit t | o 200 characters |): | | | | |
| <u>Se</u> ; | Maximum hourly rate based on 434 MMBtu/hr maximum heat input rate (HHV) at 49.9 MW baseload, and minimum fuel heat content. Maximum annual rate based on 8,760 hours per year at 70°F. Segment Description and Rate: Segment of Segment Description (Process/Fuel Type) (limit to 500 characters): | | | | | | |
| 2. | | | | | | | |
| | | : (SCC). | 3. SCC Units | · · · · · · · · · · · · · · · · · · · | | | |
| 4. | Maximum Hourly Rate: | 5. Maximum | Annual Rate: | 6. Estimated Annual Activity Factor: | | | |
| 7. | 7. Maximum % Sulfur: 8. Maximum % Ash: 9. Million Btu per SCC Unit: | | | | | | |
| 10. | 10. Segment Comment (limit to 200 characters): | | | | | | |

F. EMISSIONS UNIT POLLUTANTS (All Emissions Units)

| 1. Pollutant Emitted | 2. Primary Control | 3. Secondary Control | 4. Pollutant |
|----------------------|--------------------|----------------------|-----------------|
| | Device Code | Device Code | Regulatory Code |
| РМ | | | EL |
| SO ₂ | | | EL |
| NO _x | 025 | | EL |
| со | | | EL |
| PM ₁₀ | | | EL |
| voc | | | EL |
| | | | |
| | | | |
| ; | | | |
| | | | |
| | | | |
| | | | - |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |

| Emissions Unit Information Section | 1 | of | 1 | LM6000 Gas Turbine |
|---|---|----|---|----------------------------|
| Pollutant Detail Information Page | 1 | of | 6 | Particulate Matter - Total |

G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION (Regulated Emissions Units -

Emissions-Limited and Preconstruction Review Pollutants Only)

Potential/Fugitive Emissions

| | tential/1 ugitive Dimissions | | | | |
|----------|--|--------------|------------------|---------------------|--|
| 1. | Pollutant Emitted: | 2. Tota | l Percent Effi | ciency of Control: | |
| | РМ | | | | |
| 3. | Potential Emissions: | | | 4. Synthetically | |
| | 3 lb/hour | 13.1 | tons/year | Limited? [] | |
| 5. | Range of Estimated Fugitive Emissions: | | | | |
| | [] 1 [] 2 [] 3 | | to | tons/year | |
| 6. | Emission Factor: 3 lb/hr | | | 7. Emissions | |
| | Reference: GE, 2002. | | | Method Code: | |
| 8. | | | <u> </u> | 2 | |
| 0. | Calculation of Emissions (limit to 600 chara | cters): | | | |
| | See Part II, Appendix A. | | | | |
| | • | | | | |
| | | | | | |
| İ | | | | | |
| | | | | | |
| | | | | | |
| 9. | 9. Pollutant Potential/Fugitive Emissions Comment (limit to 200 characters): | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| Al | lowable Emissions Allowable Emissions | <u>1</u> of_ | 1 | | |
| 1. | Basis for Allowable Emissions Code: | 2. Fut | ure Effective l | Date of Allowable | |
| <u> </u> | OTHER | Em | issions: | | |
| 3. | Requested Allowable Emissions and Units: | 4. Equ | iivalent Allow | able Emissions: | |
| | 3 lb/hr | | 3 lb/hour | 13.1 tons/year | |
| 5. | Method of Compliance (limit to 60 character | rs): | | | |
| | | | | | |
| | None required | | | | |
| 6. | Allowable Emissions Comment (Desc. of OI | perating l | Method) (limit | to 200 characters): | |
| | Con Doub II | | | | |
| | See Part II. | | | | |
| | | | | | |
| | | | | | |

| Emissions Unit Information Section | 1 | of | 1 | LM6000 Gas Turbine |
|------------------------------------|---|----|---|--------------------|
| Pollutant Detail Information Page | 2 | of | 6 | Sulfur Dioxides |

G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION (Regulated Emissions Units -

Emissions-Limited and Preconstruction Review Pollutants Only)

| Pote | ential | /Fug | itive | Emi | issions |
|------|--------|------|-------|-----|---------|
| | | | | | |

| 1. | Pollutant Emitted: | 2. | Tota | Percent Effici | ency | of Control: |
|-----|--|-------|-------|--------------------|-------|----------------|
| | SO₂ | | | | | |
| 3. | Potential Emissions: | | | | 4. | Synthetically |
| | 1.3 lb/hour | | 5.2 | tons/year | | Limited? [] |
| 5. | Range of Estimated Fugitive Emissions: | - | | | | |
| | []1 []2 []3 | _ | | to to | ons/y | ear |
| 6. | Emission Factor: 1 grain S/100 cf | | | | 7. | |
| | Reference: Permit Limit* | | | | | Method Code: 2 |
| 8. | Calculation of Emissions (limit to 600 chara | cters |): | | | - |
| | See Part II, Appendix A. | | | | | |
| | occ rarrii, Appendix A. | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| 9. | Pollutant Potential/Fugitive Emissions Comi | ment | (lim | it to 200 charac | cters |): |
| | - | | | | | |
| | *AC41-157745/PSD-FL-136/0810007-003-AV. The use of natural gas not limited pursuant to | ~ 40° | 0.072 | E E C | | |
| | The use of hatural gas not milited pursuant to | J 403 | .0072 | .o r.o. | | |
| | | | | | | |
| All | owable Emissions Allowable Emissions | 1 | of_ | 1 | | |
| 1. | Basis for Allowable Emissions Code: | 2. | Futu | re Effective D | ate (| of Allowable |
| | OTHER | | | ssions: | | |
| 3. | Requested Allowable Emissions and Units: | 4. | Equ | ivalent Allowa | ble F | Emissions: |
| | 1 grain S/100cf | | | 1.3 lb/hour | | 5.2 tons/year |
| 5. | Method of Compliance (limit to 60 character | rs): | | | - | |
| | Pipeline Natural gas | | | | | |
| 6. | Allowable Emissions Comment (Desc. of Op | perat | ing N | lethod) (limit t | o 20 | 0 characters): |
| | See Part II. | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |

| Emissions Unit Information Section | 1 | of _ | 1 | LM6000 Gas Turbine |
|------------------------------------|---|------|---|--------------------|
| Pollutant Detail Information Page | 3 | of | 6 | Nitrogen Oxides |

G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION (Regulated Emissions Units -**Emissions-Limited and Preconstruction Review Pollutants Only)**

Potential/Fugitive Emissions

| 1. Pollutant Emitted: | 2. Total Percent Efficiency of Control: |
|--|--|
| NO _x | |
| 3. Potential Emissions: 39.7 lb/hour | 4. Synthetically Limited? [] |
| 5. Range of Estimated Fugitive Emissions: [] 1 [] 2 [] 3 | totons/year |
| 6. Emission Factor: 25 ppmvd @ 15% O ₂ | 7. Emissions |
| Reference: GE, 2002 . | Method Code: |
| 8. Calculation of Emissions (limit to 600 char | racters): |
| See Part II, Appendix A. | |
| , , , , , , , , , , , , , , , , , , , | |
| | |
| | |
| | |
| 9. Pollutant Potential/Fugitive Emissions Cor | nment (limit to 200 characters): |
| | |
| | |
| | |
| Allowable Emissions Allowable Emissions | 1 of 1 |
| Basis for Allowable Emissions Code: OTHER | 2. Future Effective Date of Allowable Emissions: |
| 3. Requested Allowable Emissions and Units | 4. Equivalent Allowable Emissions: |
| 25 ppmvd @ 15% O₂ | 39.7 lb/hour 164.6 tons/year |
| 5. Method of Compliance (limit to 60 charact | ers): |
| Annual compliance test, EPA Method 7E | |
| 6. Allowable Emissions Comment (Desc. of Comment | Operating Method) (limit to 200 characters): |
| See Part II. | |
| | |
| | |

| Emissions Unit Information Section | 1 | of _ | 1 | LM6000 Gas Turbine |
|---|---|------|---|--------------------|
| Pollutant Detail Information Page | 4 | of | 6 | Carbon Monoxide |

G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION (Regulated Emissions Units -

Emissions-Limited and Preconstruction Review Pollutants Only)

Potential/Fugitive Emissions

| 1. | Pollutant Emitted: | 2. Total Percent Efficie | ency of Control: |
|-----|--|-----------------------------------|-------------------------------|
| | со | | Ž |
| 3. | Potential Emissions: 28.5 lb/hour | 119.2 tons/year | 4. Synthetically Limited? [] |
| 5. | Range of Estimated Fugitive Emissions: | toto | ns/year |
| 6. | Emission Factor: 30 ppmvd @ 15% O ₂ | | 7. Emissions |
| | Reference: GE, 2002 | | Method Code: |
| 8. | Calculation of Emissions (limit to 600 chara | cters): | |
| | See Part II, Appendix A. | | · |
| | Pollutant Potential/Fugitive Emissions Com | ment (mint to 200 charac | iers). |
| All | owable Emissions Allowable Emissions | <u>1</u> of <u>1</u> | |
| 1. | Basis for Allowable Emissions Code: OTHER | 2. Future Effective Da Emissions: | te of Allowable |
| 3. | Requested Allowable Emissions and Units: | 4. Equivalent Allowab | ole Emissions: |
| | 30 ppmvd @ 15% O ₂ | 28.5 lb/hour | 119.2 tons/year |
| 5. | Method of Compliance (limit to 60 character | rs): | |
| | None Required | | |
| 6. | Allowable Emissions Comment (Desc. of Op | perating Method) (limit to | 200 characters): |
| | See Part II. | | |

DEP Form No. 62-210.900(1) - Form

| Emissions Unit Information Section | 1 | of | 1 | LM6000 Gas Turbine |
|------------------------------------|---|----|---|---------------------------------------|
| Pollutant Detail Information Page | 5 | of | 6 | Particulate Matter - PM ₁₀ |

G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION (Regulated Emissions Units -

Emissions-Limited and Preconstruction Review Pollutants Only)

Potential/Fugitive Emissions

| Pollutant Emitted: | 2. Total Percent Efficiency of Control: |
|---|--|
| PM ₁₀ | |
| 3. Potential Emissions: | 4. Synthetically |
| 3 lb/hour | 13.1 tons/year Limited? [] |
| 5. Range of Estimated Fugitive Emissions: | |
| | totons/year |
| 6. Emission Factor: 3 lb/hr | 7. Emissions Method Code: |
| Reference: GE, 2002 . | 2 |
| 8. Calculation of Emissions (limit to 600 ch. | aracters): |
| | |
| See Part II, Appendix A. | |
| | |
| | |
| | |
| | |
| 9. Pollutant Potential/Fugitive Emissions Co | omment (limit to 200 characters): |
| | |
| | |
| | |
| | |
| Allowable Emissions Allowable Emissions | of |
| Basis for Allowable Emissions Code: | 2. Future Effective Date of Allowable |
| OTHER | Emissions: |
| 3. Requested Allowable Emissions and Unit | s: 4. Equivalent Allowable Emissions: |
| 3 lb/hr | 3 lb/hour 13.1 tons/year |
| 5. Method of Compliance (limit to 60 charac | cters): |
| | |
| None Required | |
| 6. Allowable Emissions Comment (Desc. of | Operating Method) (limit to 200 characters): |
| _ | |
| See Part II. | |
| | |
| | |

| Emissions Unit Information Section | 1 | of | 1 | LM6000 Gas Turbine |
|---|---|----|---|----------------------------|
| Pollutant Detail Information Page | 6 | of | 6 | Volatile Organic Compounds |

G. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION

(Regulated Emissions Units -

Emissions-Limited and Preconstruction Review Pollutants Only)

Potential/Fugitive Emissions

| 1. | Pollutant Emitted: | 2. Total Percent Efficiency of Control: | | | |
|----------|--|---|--|--|--|
| | voc | | | | |
| 3. | Potential Emissions: | 4. Synthetically | | | |
| <u> </u> | 3.1 lb/hour | 12.9 tons/year Limited? [] | | | |
| 5. | Range of Estimated Fugitive Emissions: | | | | |
| | | totons/year | | | |
| 6. | Emission Factor: 5 ppmvw | 7. Emissions Method Code: | | | |
| | Reference: GE, 2002. | 0 | | | |
| 8. | Calculation of Emissions (limit to 600 chara- | acters): | | | |
| | See Part II, Appendix A. | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| - | Pollutant Potential/Fugitive Emissions Com | ment (limit to 200 characters): | | | |
| J. | Foliutant Fotential/Fugitive Emissions Com | ment (mint to 200 characters). | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| All | Allowable Emissions 1 of 1 | | | | |
| 1. | Basis for Allowable Emissions Code: | 2. Future Effective Date of Allowable | | | |
| <u> </u> | OTHER Parastal Allamabla Emissions and Maite. | Emissions: | | | |
| 3. | • | 4. Equivalent Allowable Emissions: | | | |
| <u> </u> | 5 ppmvw | 3.1 lb/hour 12.9 tons/year | | | |
| 5. | Method of Compliance (limit to 60 character | rs): | | | |
| | None Required | | | | |
| 6. | Allowable Emissions Comment (Desc. of Op | perating Method) (limit to 200 characters): | | | |
| | See Part II. | | | | |
| | occ r aren. | | | | |
| | | | | | |

| Emissions | Unit | Information | Section | 1 | of | 1 |
|------------------|-------|------------------|---------|---|----|---|
| 131111001010110 | CHILL | IIII OI III CIOI | Decidie | | O. | |

LM6000 Gas Turbine

H. VISIBLE EMISSIONS INFORMATION (Only Regulated Emissions Units Subject to a VE Limitation)

| <u>Vi</u> | sible Emissions Limitation: Visible Emissi | ons Limitation 1 of 1 | | | | |
|-----------|--|---|--|--|--|--|
| 1. | Visible Emissions Subtype: VE10 | Basis for Allowable Opacity: X Rule Other | | | | |
| 3. | 1 1 2 | ceptional Conditions: 100 % | | | | |
| 4. | Method of Compliance: | | | | | |
| | Annual VE Test EPA Method 9 | | | | | |
| 5. | Visible Emissions Comment (limit to 200 c | haracters): | | | | |
| | VE of 10% proposed for gas firing. | | | | | |
| | Excess opacity based on Rule 62-210.700(1) for startup/shutdown/malfunction for 2 hrs/24 hrs. | | | | | |
| | VE limit complies with 403.08725 F.S. | | | | | |
| <u>Co</u> | I. CONTINUOUS MONITOR INFORMATION (Only Regulated Emissions Units Subject to Continuous Monitoring) Continuous Monitoring System: Continuous Monitor of | | | | | |
| 1. | Parameter Code: | 2. Pollutant(s): | | | | |
| 3. | CMS Requirement: | [] Rule [] Other | | | | |
| 4. | Monitor Information: Manufacturer: Model Number: | Serial Number: | | | | |
| 5. | Installation Date: | 6. Performance Specification Test Date: | | | | |
| 7. | Continuous Monitor Comment (limit to 200 | characters): | | | | |

DEP Form No. 62-210.900(1) - Form

0237563/4/4.3/4.3.2 LM6000/CONST Effective: 2/11/99 20 8/23/02

| Emissions Unit Information Section 1 of 1 LM6000 Gas Tur | Emissions Unit Information Section | 1 | of | 1 | LM6000 Gas Turbine |
|--|------------------------------------|---|----|---|--------------------|
|--|------------------------------------|---|----|---|--------------------|

J. EMISSIONS UNIT SUPPLEMENTAL INFORMATION (Regulated Emissions Units Only)

Supplemental Requirements

| 1. | Process Flow Diagram |
|----|--|
| | [] Attached, Document ID: [X] Not Applicable [] Waiver Requested |
| 2. | Fuel Analysis or Specification |
| | [] Attached, Document ID: [X] Not Applicable [] Waiver Requested |
| 3. | Detailed Description of Control Equipment |
| | [X] Attached, Document ID: Part II [] Not Applicable [] Waiver Requested |
| 4. | Description of Stack Sampling Facilities |
| | [] Attached, Document ID: [X] Not Applicable [] Waiver Requested |
| 5. | Compliance Test Report |
| | [] Attached, Document ID: |
| | [] Previously submitted, Date: |
| | [X] Not Applicable |
| 6. | Procedures for Startup and Shutdown |
| | [] Attached, Document ID: [X] Not Applicable [] Waiver Requested |
| 7. | Operation and Maintenance Plan |
| | [] Attached, Document ID: [X] Not Applicable [] Waiver Requested |
| 8. | Supplemental Information for Construction Permit Application |
| | [X] Attached, Document ID: Part II [] Not Applicable |
| 9. | Other Information Required by Rule or Statute |
| | [] Attached, Document ID: [X] Not Applicable |
| 10 | . Supplemental Requirements Comment: |
| | |
| | |
| | |
| | |
| | |
| ľ | |

DEP Form No. 62-210.900(1) - Form

| Emissions | Unit | Information | Section | 1 | of | 1 | |
|-----------|------|-------------|---------|---|----|---|--|
| | | | | | | | |

LM6000 Gas Turbine

Additional Supplemental Requirements for Title V Air Operation Permit Applications

| 11. Alternative Methods of Operation | |
|--|--|
| [] Attached, Document ID: [X] Not Applicable | |
| 12. Alternative Modes of Operation (Emissions Trading) | |
| [] Attached, Document ID: [X] Not Applicable | |
| 13. Identification of Additional Applicable Requirements | |
| [] Attached, Document ID: [X] Not Applicable | |
| 14. Compliance Assurance Monitoring Plan | |
| [] Attached, Document ID: [X] Not Applicable | |
| 15. Acid Rain Part Application (Hard-copy Required) | |
| [] Acid Rain Part - Phase II (Form No. 62-210.900(1)(a)) Attached, Document ID: | |
| [] Repowering Extension Plan (Form No. 62-210.900(1)(a)1.) Attached, Document ID: | |
| [] New Unit Exemption (Form No. 62-210.900(1)(a)2.) Attached, Document ID: | |
| [] Retired Unit Exemption (Form No. 62-210.900(1)(a)3.) Attached, Document ID: | |
| Phase II NOx Compliance Plan (Form No. 62-210.900(1)(a)4.) Attached, Document ID: | |
| [] Phase NOx Averaging Plan (Form No. 62-210.900(1)(a)5.) Attached, Document ID: | |
| [X] Not Applicable | |

PART II

SUPPORTING INFORMATION

1.0 INTRODUCTION

Tropicana Products, Inc. is proposing to replace the General Electric (GE) LM 5000 gas turbine, associated with the cogeneration facility, with a GE LM 6000 at the existing Bradenton Citrus Processing Plant. The gas turbine was part of the cogeneration facility permitted by the Florida Department of Environmental Protection (FDEP) on May 30, 1989 pursuant to permit numbers AC41-157745 and PSD-FL-136. Prevention for Significant Deterioration (PSD) review was required for nitrogen oxides and carbon monoxide. Attachment A presents the existing Title V permit conditions for the cogeneration unit that includes the gas turbine.

The cogeneration unit currently consists of a General Electric LM 5000 gas turbine with a 45.4 megawatt (MW) electric generator, an associated heat recovery steam generator (HRSG) with a duct burner system. The steam produced by the turbine exhaust and duct burners is used as process steam in the Tropicana plant and replaced the steam previously generated by six boilers. These boilers were shut down after the cogeneration unit became operational. The existing gas turbine is being replaced due to the availability of parts for the LM 5000 and due to the fact that the LM 6000 is a more efficient gas turbine. GE no longer manufacturers the LM 5000. The LM 6000 will have a maximum generating capability of 49.9 MW.

Tropicana is seeking a minor source air construction permit for this project.

1.1 EXISTING FACILITY

The Tropicana facility is located at 1001 13th Avenue East, Bradenton, Florida. The existing industrial complex includes glass manufacturing and citrus processing that includes juice extracting, processing, packaging, warehousing, and distribution. Fruit is graded and carried to an extractor room where the juice is removed and pumped to either carton filling, glass filling, plastic filling, block freezing, aseptic storage, or to evaporators for concentrate production.

The plant contains three citrus feed mills, four citrus pellet mills (including two pellet coolers and associated pellet, bulk cooling reels, and Ross coolers), one glass plant (one glass plant was closed in 2000), cogeneration facility [including combustion turbine, HRSG, duct burner, auxiliary boiler, and a sanitary process steam boiler (used to produce 5-fold citrus oil)], and a wastewater treatment system (including a package steam boiler and an anaerobic reactor with a biogas flare).

The facility operates under a Title V permit issued by FDEP on February 27, 2000 (Final Permit No. 0810007-003-AV).

1.2 LM 6000 GAS TURBINE

The project will consist of replacing the existing LM 5000 with a LM 60000. Design information and stack parameters for the LM 6000 are presented in Table 1. The maximum heat input for the LM 6000 is 456 million British thermal units per hour (MMBtu/hr) on a high heating value (HHV) basis. The current maximum heat input that is authorized for the LM 5000 is 425.5 MMBtu/hr.

The potential hourly and annual criteria pollutant emissions associated with the LM 6000 are provided in Table 2. The maximum hourly emissions are based on the maximum heat input rate of 456 MMBtu/hr at a capacity of 49.9 MW. The maximum potential emissions of nitrogen oxides (NO_x) and volatile organic compounds (VOCs) from the LM 6000 will be lower than those authorized for the LM 5000. For NO_x, the maximum potential emissions from the LM 6000 will be 39.7 pounds per hour (lb/hr) [25 parts per million by volume dry (ppmvd) corrected to 15-percent oxygen (O₂)] compared to the LM 5000 of 62.6 lb/hr (42 ppmvd corrected to 15-percent O₂). Maximum VOC emissions from the LM 6000 will be 3.07 lb/hr compared to the currently authorized 3.6 lb/hr for the LM 5000. Emissions of sulfur dioxide (SO₂), particulate matter (PM) [including PM less than ten microns (PM₁₀), and carbon monoxide (CO) from the LM 6000 will be higher than that authorized for the LM 5000. For SO₂, the maximum potential emissions from the LM 6000 will be 1.3 lb/hr compared to that authorized for the LM 5000 of 1.2 lb/hr. Maximum PM/PM₁₀ emissions from the LM 6000 will be 3.0 lb/hr compared to the currently authorized 1.5 lb/hr for the LM 5000. The maximum potential emissions for CO will increase from the 9.1 lb/hr currently authorized for the LM 5000 to 28.5 lb/hr for the LM 6000. The emission increase for CO is an artifact of the lower NO_x emissions for the LM 6000 as compared to the LM 5000.

1.3 <u>APPLICABLE REQUIREMENTS AND PERMITTING CONDITIONS</u>

The proposed project is a modification and the PSD requirements in Rule 62-212.400 Florida Administrative Code (F.A.C.) may be applicable. PSD review would potentially apply for a modification to the Bradenton facility if the increase in the emissions from the "Project" exceed the PSD thresholds. A modification is defined in Rule 62-210.200 F.A.C. as any physical change in, addition to or change in, the method of operation of a facility which would result in an increase in the actual emissions of any air pollutant subject to regulation under the Clean Air Act. A physical

change or a change in the method of operation does not include routine replacement, repair or replacement of component parts of an emission unit. The substitution of the LM 6000 for the LM 5000 is not a routine replacement since the entire gas turbine will be a different and larger gas turbine. A modification to a major source of air pollution, such as the Tropicana Bradenton Citrus Processing Plant, may be subject to review under the Department's PSD rules codified in Rule 62-212.400 F.A.C. However, if the potential emissions of the project, which includes the decreases in actual emissions afforded by the removal of the LM 5000 are less than the significant emission rates, then PSD review would not otherwise apply. Table 3 presents the potential emission of the LM 6000 along with the actual decreases in emissions from the LM 5000. The project consisting of the potential emissions of the LM 6000 minus the actual emissions of the LM 5000 is below the significant emission rates for all pollutants. Therefore, PSD is not applicable for the project.

Table 1. Design Information and Stack Parameters for Tropicana Products, Inc. LM6000 Gas Turbine, Natural Gas, Baseload

| | Turbine Inlet Temperature | | | | | |
|--|---------------------------|-----------|-----------|---------|--|--|
| Parameter | 52°F | 60°F | 70°F | 90°F | | |
| Combustion Turbine Performance | | | | | | |
| Power output (MW) | 49.9 | 48.4 | 46.4 | 42.5 | | |
| Heat rate (Btu/kWh, LHV) | 8,235 | 8,281 | 8,374 | 8,559 | | |
| (Btu/kWh, HHV) | 9,141 | 9,192 | 9,295 | 9,500 | | |
| Heat Input (MMBtu/hr, LHV) | 411 | 401 | 389 | 364 | | |
| (MMBtu/hr, HHV) | 456 | 445 | 431 | 403 | | |
| Fuel heating value (Btu/lb, LHV) | 19,000 | 19,000 | 19,000 | 19,000 | | |
| (Btw/lb, HHV) | 21,090 | 21,090 | 21,090 | 21,090 | | |
| (HHV/LHV) | 1.110 | 1.110 | 1.110 | 1.110 | | |
| Steam Injection (lb/hr) | 34,956 | 32,999 | 32,999 | 25,588 | | |
| CT Exhaust Flow | 1,073,600 | 1,053,720 | 1,027,100 | 973,080 | | |
| Mass Flow (lb/hr)- with no margin | 1,073,600 | 1,053,720 | 1,027,100 | 973,080 | | |
| - provided | 814 | 816 | 819 | 825 | | |
| Temperature (°F) | 11.46 | 11.54 | 11.81 | 12.34 | | |
| Moisture (% Vol.) | 13.19 | 13.21 | 13.18 | 13.14 | | |
| Oxygen (% Vol.) | 27.99 | 27.98 | 27.95 | 27.89 | | |
| Molecular Weight | | | | | | |
| Fuel Usage | | | | | | |
| Fuel usage (lb/hr) = Heat Input (MMBtu/hr) x 1,000,0 | 411 | 401 | 389 | 364 | | |
| Heat input (MMBtu/hr, LHV) | 19,000 | 19,000 | 19,000 | 19,000 | | |
| Heat content (Btu/lb, LHV) | 21,630 | 21,099 | 20,447 | 19,132 | | |
| Fuel usage (lb/hr)- calculated | | | | | | |
| Turbine Flow Conditions | | | | | | |
| Turbine Flow (acfm) = {(Mass Flow (lb/hr) x 1,545 x | 1,073,600 | 1,053,720 | 1,027,100 | 973,080 | | |
| Mass flow (lb/hr) | 814 | 816 | 819 | 825 | | |
| Temperature (°F) | 27.99 | 27.98 | 27.95 | 27.89 | | |
| Molecular weight | 601,790 | 591,812 | 578,854 | 552,198 | | |
| Volume flow (acfm)- calculated | 89 | 87 | 85 | 81 | | |
| Velocity (ft/s)- calculated | | | | | | |
| HRSG Stack | 67 | 67 | 67 | 67 | | |
| Stack height (ft) | 12 | 12 | 12 | 12 | | |
| Diameter (ft) | 268 | 268 | 268 | 268 | | |
| Temperature (°F) | 343,880 | 337,648 | 329,481 | 312,841 | | |
| Volume flow (acfm)- calculated | 545,000 | 50 | 49 | 46 | | |
| Velocity (ft/s)- calculated | 51 | 50 | 49 | 46 | | |
| · · · · · · · · · · · · · · · · · · · | ٠. | 50 | 7, | -70 | | |

Note: Universal gas constant = 1,545 ft-lb(force)/°R; atmospheric pressure = 2,090.9 lb(force)/ft²; 14.52 lb/in² A margin of 5% was added to heat rate.

Source: GE, 2002.

Table 2. Maximum Emissions for Criteria Pollutants for Tropicana Products Inc. LM6000 Gas Turbine, Natural Gas, Baseload

| | Turbine Inlet Temperature | | | | |
|--|---|--|---|---|--|
| Parameter | 52°F | 60°F | 70°F | 90° | |
| Hours of Operation | 8,760 | 8,760 | 8,760 | 8,76 | |
| Particulate (lb/hr) = Emission rate (lb/hr) from ma | inufacturer (filterable) | | | | |
| Basis (excludes H ₂ SO ₄), lb/hr | 3.00 | 3.00 | 3.00 | 3 00 | |
| CT Emission rate (lb/hr) | 3.0 | 3.0 | 3.0 | 3.0 | |
| (ГРҮ) | 13.1 | 13.1 | 13.1 | 13.1 | |
| Sulfur Dioxide (lb/ltr) = Natural gas (cf/hr) x sulf | ur content(gr/100 cf) x 1 lbs | /7000 gr x (lb SO ₂ : | 4b S) /100 | | |
| Fuel density (lb/cf) | 0.0489 | 0 0489 | 0.0489 | 0.0489 | |
| Fuel use (cf/hr) | 442,032 | 431,190 | 417,863 | 390,985 | |
| Sulfur content (grains/ 100 cf) | 1 | 1 | 1 | 1 | |
| fb SO ₂ /lb S (64/32) Emission rate (fb/hr) | 2 1.3 | 2 1.2 | 2 1.2 | | |
| (TPY) | 5.53 | 5.40 | 5.23 | 1.1 4.89 | |
| Nitrogen Oxides (lb/hr) = NO _x (ppm) x {[20.9 x (| | | | | |
| 46 (mole wgt NO _x) x 60 min/hr / | [1545 x (CT temp.(°F) + 46 | 60°F) x 5.9 x 1,000 |),000 (adj. for ppm | 1) [| |
| CT, ppmvd @15% O2 | 25 | 25 | 25 | 25 | |
| Moisture (%) | 11.46 | 11.54 | 11.81 | 12.34 | |
| Oxygen (%) | 13.2 | 13.2 | 13.2 | 13.1 | |
| Turbine Flow (acfm) | 601,790 | 591,812 | 578,854 | 552,198 | |
| Turbine Exhaust Temperature (°F) | 814 | 816 | 819 | 825 | |
| CT Enussion rate (lb/hr) (TPY) | 39.7 174.1 | 38.8 169.7 | 37.6 164.6 | 35.3 154.4 | |
| Carbon Monoxide (lh/hr) = $CO(ppm) \times \{1 - Moist\}$ | ure(%)/100] x 2090.9 lb/ft | 2 x Volume flow (a | cfm) x | | |
| 28 (mole. wgt CO) x 60 min/hr / [| 1545 x (CT temp.(°F) + 466 | 0°F) x 1,000,000 (| ndj. for ppm)} | | |
| Basis, ppmvd | 30 | 30 | 30 | 30 | |
| | | | • | | |
| Basis, ppmvd @ 15% O2- calculated | 29.5 | 29.7 | 29.7 | | |
| Basis, ppmvd @ 15% O ₂ - calculated Moisture (%) | | 29.7 11.54 | 29.7 11.81 | 29.9 | |
| Moisture (%) Oxygen (%) | 29.5 | | | 29.9 12 34 | |
| Moisture (%) Oxygen (%) Turbine Flow (acfm) | 29.5 11.46 13.2 601,790 | 11.54 13.2 591,812 | 11.81 13.2 578,854 | 29.9 12 34 13.1 | |
| Moisture (%) Oxygen (%) Turbine Flow (acfm) Turbine Exhaust Temperature (°F) | 29.5 11.46 13.2 601,790 814 | 11.54 13.2 591,812 816 | 11.81 13.2 578,854 819 | 29.9 12 34 13.1 552,198 825 | |
| Moisture (%) Oxygen (%) Turbine Flow (acfm) | 29.5 11.46 13.2 601,790 | 11.54 13.2 591,812 | 11.81 13.2 578,854 | 29.9 12 34 13.1 552,198 | |
| Moisture (%) Oxygen (%) Turbine Flow (acfm) Turbine Exhaust Temperature (°F) CT Emission rate (fb/hr) (TPY) VOCs (lb/hr) = VOC(ppmvw) x 2090.9 lb/ft² x V | 29.5 11.46 13.2 601,790 814 28.5 125.0 | 11.54 13.2 591.812 816 28 0 122.6 | 11.81 13.2 578,854 819 27.2 119.2 | 29.9 12.34 13.1 552,198 825 25.7 | |
| Moisture (%) Oxygen (%) Turbine Flow (acfm) Turbine Exhaust Temperature (°F) CT Emission rate (fb/hr) (TPY) | 29.5 11.46 13.2 601,790 814 28.5 125.0 | 11.54 13.2 591.812 816 28 0 122.6 | 11.81 13.2 578,854 819 27.2 119.2 | 29.9 12.34 13.1 552,198 825 25.7 | |
| Moisture (%) Oxygen (%) Turbine Flow (acfm) Turbine Exhaust Temperature (°F) CT Emission rate (lb/hr) (TPY) VOCs (lb/hr) = VOC(ppmvw) x 2090.9 lb/ft² x V 16 (mole. weight as methane) x 60 min/hr Basis, ppmvw | 29.5 11.46 13.2 601,790 814 28.5 125.0 | 11.54 13.2 591.812 816 28 0 122.6 | 11.81 13.2 578,854 819 27.2 119.2 | 29.9 12.34 13.1 552,198 825 25.7 112.5 | |
| Moisture (%) Oxygen (%) Turbine Flow (acfm) Turbine Exhaust Temperature (°F) CT Emission rate (lb/hr) (TPY) VOCs (lb/hr) = VOC(ppmvw) x 2090.9 lb/ft² x V 16 (mole. weight as methane) x 60 min/ht Basis, ppmvw Basis, ppmvd @ 15% O ₂ -calculated | 29.5 11.46 13.2 601,790 814 28.5 125.0 olume flow (acfm) x -/ [1545 x (CT temp.(°F) + | 11.54 13.2 591,812 816 28 0 122.6 460°F) x 1,000,00 | 11.81 13.2 578,854 819 27.2 119.2 | 29.9 12.34 13.1 552,198 825 25.7 112.5 | |
| Moisture (%) Oxygen (%) Turbine Flow (acfm) Turbine Exhaust Temperature (°F) CT Emission rate (llv/tr) (TPY) VOCs (llv/hr) = VOC(ppmvw) x 2090.9 lb/ft² x V 16 (mole. weight as methane) x 60 min/hr Basis, ppmvw Basis, ppmvd @ 15% O ₂ - calculated Moisture (%) | 29.5 11.46 13.2 601,790 814 28.5 125.0 olume flow (acfm) x -/ [1545 x (CT temp.(°F) + | 11.54 13.2 591,812 816 28 0 122.6 460°F) x 1,000,00 | 11.81 13.2 578,854 819 27.2 119.2 00 (adj. for ppm)} 5 5 6 11.81 | 29.9 12.34 13.1 552,198 825 25.7 112.5 | |
| Moisture (%) Oxygen (%) Turbine Flow (acfm) Turbine Exhaust Temperature (°F) CT Emission rate (llx/tr) (TPY) VOCs (lbx/hr) = VOC(ppmvw) x 2090.9 lbx/tt² x V 16 (mole. weight as methane) x 60 min/hr Basis, ppmvw Basis, ppmvd @ 15% O ₂ - calculated Moisture (%) Oxygen (%) | 29.5 11.46 13.2 601,790 814 28.5 125.0 olume flow (acfm) x // [1545 x (CT temp.(°F) + 5 5.5 11.46 13.2 | 11.54 13.2 591.812 816 28 0 122.6 460°F) x 1,000,00 | 11.81 13.2 578,854 819 27.2 119.2 00 (adj. for ppm)} 5 5 6 11.81 13.2 | 29.9 12 34 13.1 552,198 825 25.7 112.5 | |
| Moisture (%) Oxygen (%) Turbine Flow (acfm) Turbine Exhaust Temperature (°F) CT Emission rate (lb/hr) (TPY) VOCs (lb/hr) = VOC(ppmvw) x 2090.9 lb/tt² x V 16 (mole. weight as methane) x 60 min/ht Basis, ppmvw Basis, ppmvd @ 15% O ₂ - calculated Moisture (%) Oxygen (%) Turbine Flow (acfm) | 29.5 11.46 13.2 601,790 814 28.5 125.0 colume flow (acfm) x -/ [1545 x (CT temp.(°F) + 5 5.5 11.46 13.2 601,790 | 11.54 13.2 591,812 816 28 0 122.6 460°F) x 1,000,00 5 5.6 11.54 13.2 591,812 | 11.81 13.2 578,854 819 27.2 119.2 90 (adj. for ppm)} 5 5 6 11.81 13.2 578,854 | 29.9 12 34 13.1 552,198 825 25.7 112.5 5 5.7 12.34 13.1 552,198 | |
| Moisture (%) Oxygen (%) Turbine Flow (acfm) Turbine Exhaust Temperature (°F) CT Emission rate (fb/hr) (TPY) VOCs (fb/hr) = VOC(ppmvw) x 2090.9 lb/ft² x V 16 (mole. weight as methane) x 60 min/hr Basis, ppmvw Basis, ppmvd @ 15% O ₂ - calculated Moisture (%) Oxygen (%) Turbine Flow (acfm) Turbine Exhaust Temperature (°F) | 29.5 11.46 13.2 601,790 814 28.5 125.0 olume flow (acfm) x -/ [1545 x (CT temp.(°F) + 5 5.5 11.46 13.2 601,790 814 | 11.54 13.2 591,812 816 28 0 122.6 460°F) x 1,000,00 5 5.6 11.54 13.2 591,812 816 | 11.81 13.2 578,854 819 27.2 119.2 90 (adj. for ppm)} 5 5 6 11.81 13.2 578,854 819 | 29.9 12 34 13.1 552,198 825 25.7 112.5 5 5.7 12.34 13.1 552,198 | |
| Moisture (%) Oxygen (%) Turbine Flow (acfm) Turbine Exhaust Temperature (°F) CT Emission rate (fb/hr) (TPY) VOCs (lb/hr) = VOC(ppmvw) x 2090.9 lb/ft² x V 16 (mole. weight as methane) x 60 min/ht Basis, ppmvw Basis, ppmvd @ 15% O ₂ - calculated Moisture (%) Oxygen (%) Turbine Flow (acfm) | 29.5 11.46 13.2 601,790 814 28.5 125.0 colume flow (acfm) x -/ [1545 x (CT temp.(°F) + 5 5.5 11.46 13.2 601,790 | 11.54 13.2 591,812 816 28 0 122.6 460°F) x 1,000,00 5 5.6 11.54 13.2 591,812 | 11.81 13.2 578,854 819 27.2 119.2 90 (adj. for ppm)} 5 5 6 11.81 13.2 578,854 | 29.9 12.34 13.1 552,198 825 25.7 112.5 | |
| Moisture (%) Oxygen (%) Turbine Flow (acfm) Turbine Exhaust Temperature (°F) CT Emission rate (lb/hr) (TPY) VOCs (lb/hr) = VOC(ppmvw) x 2090.9 lb/ft² x V 16 (mole. weight as methane) x 60 min/hi Basis, ppmvw Basis, ppmvw Basis, ppmvd @ 15% O ₂ - calculated Moisture (%) Oxygen (%) Turbine Flow (acfm) Turbine Exhaust Temperature (°F) CT Emission rate (lb/hr) (TPY) | 29.5 11.46 13.2 601,790 814 28.5 125.0 colume flow (acfm) x -/[1545 x (CT temp.(°F) + 5 5.5 11.46 13.2 601,790 814 3.07 | 11.54 13.2 591,812 816 28 0 122.6 460°F) x 1,000,00 5 5.6 11.54 13.2 591,812 816 3.01 | 11.81 13.2 578,854 819 27.2 119.2 00 (adj. for ppm)} 5 5 6 11.81 13.2 578,854 819 2.94 | 29.9 12 34 13.1 552,198 825 25.7 112.5 5 5,7 12.34 13.1 552,198 825 2.79 | |
| Moisture (%) Oxygen (%) Turbine Flow (acfm) Turbine Exhaust Temperature (°F) CT Emission rate (lb/hr) (TPY) VOCs (lb/hr) = VOC(ppmvw) x 2090.9 lb/ft² x V 16 (mole. weight as methane) x 60 min/hi Basis, ppmvw Basis, ppmvw Basis, ppmvd @ 15% O ₂ - calculated Moisture (%) Oxygen (%) Turbine Flow (acfm) Turbine Exhaust Temperature (°F) CT Emission rate (lb/hr) (TPY) | 29.5 11.46 13.2 601,790 814 28.5 125.0 colume flow (acfm) x -/[1545 x (CT temp.(°F) + 5 5.5 11.46 13.2 601,790 814 3.07 | 11.54 13.2 591,812 816 28 0 122.6 460°F) x 1,000,00 5 5.6 11.54 13.2 591,812 816 3.01 | 11.81 13.2 578,854 819 27.2 119.2 00 (adj. for ppm)} 5 5 6 11.81 13.2 578,854 819 2.94 | 29.9 12 34 13.1 552,198 825 25.7 112.5 5 5.7 12.34 13.1 552,198 825 2.79 12.2 | |
| Moisture (%) Oxygen (%) Turbine Flow (acfm) Turbine Exhaust Temperature (°F) CT Emission rate (lb/hr) (TPY) VOCs (lb/hr) = VOC(ppmvw) x 2090.9 lb/tt² x V 16 (mole. weight as methane) x 60 min/hr Basis, ppmvw Basis, ppmvd @ 15% O ₂ - calculated Moisture (%) Oxygen (%) Turbine Flow (acfm) Turbine Exhaust Temperature (°F) CT Emission rate (lb/hr) (TPY) Lead (lb/hr)= NA | 29.5 11.46 13.2 601,790 814 28.5 125.0 olume flow (acfm) x //[1545 x (CT temp.(°F) + 5 5.5 11.46 13.2 601,790 814 3.07 13.4 | 11.54 13.2 591,812 816 28 0 122.6 460°F) x 1,000,00 5 5.6 11.54 13.2 591,812 816 3.01 13.2 | 11.81 13.2 578,854 819 27.2 119.2 90 (adj. for ppm)} 5 5 6 11.81 13.2 578,854 819 2.94 12.9 | 29.9 12 34 13.1 552,198 825 25.7 112.5 5 5,7 12.34 13.1 552,198 825 2.79 | |

Note: ppmvd= parts per million, volume dry, ppmvw= parts per million, volume wet; O2= oxygen.

Source: GE, 2002; Golder Associates, 2002.

Table 3. Net Emissions Increases Associated with Tropicana Products LM 6000 Project at Bradenton Citrus Processing Facility

| | Emissions (tons/year) | | | | |
|--|-----------------------|-----------------|------------------|-----------------|------|
| | CO | NO _x | PM ₁₀ | SO ₂ | VOC |
| LM 5000 Actual Emissions ^a | | - | | | _ |
| Year 2000 | 31.9 | 144.9 | 5.3 | 0.5 | 12.6 |
| Year 2001 | 24.6 | 113.1 | 4.1 | 0.4 | 9.8 |
| 2-year Average | 28.2 | 129.0 | 4.7 | 0.4 | 11.2 |
| LM 6000 Potential Emissions ^b | 119.2 | 164.6 | 13.1 | 5.2 | 12.9 |
| Project Net Emissions: | 91.0 | 35.6 | 8.4 | 4.8 | 1.7 |
| PSD SERs | 100.0 | 40.0 | 15.0 | 40.0 | 40.0 |
| PSD Applicable? | No | No | No | No | No |

^a from Annual Operating Reports for Air Pollutant Emitting Facility

Note: SERs = Significant Emission Rates

^b from Table 2 for a turbine inlet temperature of 70 degrees F

ATTACHMENT A

TITLE V PERMIT CONDITIONS FOR DUCT BURNER
AND
MANUFACTURER INFORMATION FOR

THE DUCT BURNER AND CONTROL SYSTEM

Tropicana Products, Inc.
Bradenton Citrus Processing Plant
Page D1 of D4

FINAL Permit No.: 0810007-003-AV

Subsection D. This section addresses the following emissions unit(s).

<u>E.U.</u>

ID No. Brief Description

-016 Gas Turbine

The natural gas fired General Electric (GE) LM 5000 gas turbine (GT) has a maximum design heat input capacity of 425.5 MMBtu per hour, and a natural gas fired Heat Recovery Steam Generator (HRSG) with a maximum design heat input capacity of 104 MMBtu per hour. The cogeneration project has an electric generation capacity of 45.4 MW.

{Permitting note(s): This emission unit is regulated under NSPS - 40 CFR 60 Subpart Db - Standards of Performance for Industrial-Commercial-Institutional Steam Generating Units, adopted and incorporated by reference in Rule 62-204.800(7)(b)3, F.A.C.; NSPS - 40 CFR 60 Subpart GG - Standards of Performance for Stationary Gas Turbines, adopted and incorporated by reference in Rule 62-204.800(7)(b)39, F.A.C.; and Rule 62-296.405, F.A.C., Fossil Fuel Steam Generators with more than 250 Million Btu per Hour Heat Input. The gas turbine is subject to and shall meet all the applicable requirements of 40 CFR 60 Subpart GG. Based on the heat input capacity of the turbine and the fact that it is not an electric utility stationary gas turbine, the nitrogen oxides standards of 40 CFR 60 Subpart GG do not apply to this source. The heat recovery steam generator duct burner is subject to 40 CFR 60 Subpart Db.}

The following specific conditions apply to the emissions unit(s) listed above:

Essential Potential to Emit (PTE) Parameters

D.1. Capacity.

- a. The maximum heat input to the Gas Turbine shall not exceed 425.5 MMBtu per hour (405.3 MCF/hr of natural gas).
- b. The maximum heat input to the Heat Recovery Steam Generator shall not exceed 104 MMBtu per hour (99 MCF/hr of natural gas).
- c. Heat input to the Heat Recovery Steam Generator shall not exceed 91 MMBtu per hour on a 30 day rolling average basis.

[Rules 62-4.160(2) and 62-210.200(PTE), F.A.C.; Air Construction Permit AC41-157745]

D.2. Methods of Operation - (i.e., Fuels) The Gas Turbine/Heat Recovery Steam Generator shall fire natural gas only. The sulfur content of the fuel (natural gas) used in the Gas Turbine shall not exceed 0.8% by weight.

FINAL Permit No.: 0810007-003-AV

[Rules 62-4.160(2), 62-204.800(7)(b)39, and 62-213.440(1), F.A.C.; 40 CFR 60.333(b); Air Construction Permit AC41-157745]

Emission Limitations and Standards

D.3. Visible emissions from the Gas Turbine and Heat Recovery Steam Generator shall not exceed 10% opacity.

[Air Construction Permit AC41-157745]

- **D.4.** Carbon monoxide (CO) emissions shall not exceed the following:
 - a. 10 ppm (corrected to 15% O₂), dry basis, for the Gas Turbine;
- b. 0.14 pounds/MMBtu for the Heat Recovery Steam Generator. [BACT Determination of May 29, 1989 in accordance with Rule 62-212.400, F.A.C.]
- **D.5.** Nitrogen oxides (NOx) emissions shall not exceed the following:
 - a. 42 ppm (corrected to 15% O₂), dry basis, for the Gas Turbine;
- b. 0.1 pounds/MMBtu for the Heat Recovery Steam Generator. [BACT Determination of May 29, 1989 in accordance with Rule 62-212.400, F.A.C.] { Permitting Note: Compliance with this BACT limit will also satisfy the less stringent requirements of Subpart Db 40 CFR 60.44b(a)(4)(i) which specifies a NOx limit of 0.2 lb/MMBtu for duct burners used in a combined cycle system.}
- **D.6.** Emissions from the Gas Turbine and Heat Recovery Steam Generator shall not exceed any of the following:

| | Gas Turbine | | Heat Recovery Steam Generator | | |
|---------------------|--------------------|------------------|----------------------------------|-------------------------------|--|
| Pollutant | Pounds per Hour | Tons per Year | Pounds per Hour | Tons per Year ¹ | |
| NOx | 62.6 | 274.6 | 10.4 | 39.9 | |
| CO | 9.1 | 39.8 | 14.56 | 55.8 | |
| PM/PM ₁₀ | 1.5 | 6.6 | 0.25 | 0.95 | |
| SO ₂ | 1.2 | 2.63 | 0.29 | 0.60 | |
| VOC | 3.6 | 15.9 | 4.16 | 15.9 | |

¹Note: Heat Recovery Steam Generator lb/hr emissions are based on 104 MMBtu/hr maximum heat input rate, while the tons/yr emissions are based on the 91 MMBtu/hr maximum 30 day rolling average heat input rate.

[Air Construction Permit AC41-157745 as amended May 20, 1992]

Tropicana Products, Inc.
Bradenton Citrus Processing Plant
Page D3 of D4

FINAL Permit No.: 0810007-003-AV

Test Methods and Procedures

- **D.7.** Test the Gas Turbine/Heat Recovery Steam Generator for emissions of the following pollutants annually on or during the 60 day period prior to March 1.
 - a. Visible emissions (VE)
 - b. Nitrogen Oxides (NOx)
 - c. Sulfur Dioxide (SO₂)

[Air Construction Permit AC41-157745/PSD-FL-136]

{Permitting Notes: (1) A fuel analysis, including sulfur content, of a representative fuel sample and a calculation of the sulfur dioxide emission rate based on the fuel analysis may be submitted in lieu of the required sulfur oxides emission test. (2) Although CO, PM, and VOC are limited in Condition D.6, the referenced construction permit specified that testing for these pollutants shall be conducted upon initial operation only. (3) The compliance test due date is for planning purposes only. Rule 62-297.310(7)(a)4, F.A.C. allows the permittee to conduct a formal compliance test any time during the federal fiscal year (October 1 – September 30).}

- **D.8.** Compliance with the emission limitations of Conditions D.3 through D.6 shall be determined using the following EPA Methods contained in 40 CFR 60, Appendix A and adopted by reference in Chapter 62-297, F.A.C.
 - a. EPA Method 5, 5B, or 17 for PM
 - b. EPA Method 201 or 201A for PM₁₀ (recommended)
 - c. EPA Method 7/20 or 7E for NOx
 - d. EPA Method 9 for VE
 - e. EPA Method 10 for CO
 - f. EPA Method 25A for VOC

The minimum requirements for stationary point source emission test procedures and reporting shall be in accordance with 40 CFR 60 Appendix A and Chapter 62-297, F.A.C. [Chapter 62-297, F.A.C.; Air Construction Permit AC41-157745]

- **D.9.** The visible emissions tests shall be conducted by a certified observer and be a minimum of sixty (60) minutes in duration. The test observation period shall include the period during which the highest opacity emissions can reasonably be expected to occur. [Rule 62-297.310(4)(a), F.A.C.]
- **D.10.** Testing of emissions must be conducted during operation of the Gas Turbine at a heat input rate within 95-100% of the maximum capacity achievable for the average ambient temperature during the compliance tests (or at a heat input rate between 90-100% of the maximum permitted heat input rate of 425 MMBTU per hour) and operation of the Heat Recovery Steam Generator at a heat input rate within 90 to 100% of the maximum

Tropicana Products, Inc.
Bradenton Citrus Processing Plant
Page D4 of D4

permitted rate of 104 MMBTU per hour. The turbine manufacturer's capacity vs. ambient temperature curve shall be included with the test report. A compliance test submitted at operating rates less than those specified above will automatically constitute

FINAL Permit No.: 0810007-003-AV

an amended permit at the lesser rates until another test showing compliance at higher rates is submitted. Failure to submit the operating (heat input) rates or operation at conditions that do not represent normal operating conditions may invalidate the test. [Rule 62-4.070(3), F.A.C.]

Operating Conditions

D.11. The sale of electrical output generated by the Gas Turbine/Heat Recovery Steam Generator unit shall not exceed one third (33.3%) of the total annual electrical output based on a 12 month rolling average. (This limitation is necessary to insure that this source (emission unit) is not considered an electric utility gas turbine under Subpart GG - 40 CFR 60.331(q).)

[Rule 62-204.800(7)(b)39, F.A.C.; 40 CFR 60.331(q)]

Recordkeeping and Reporting Requirements

D.12. In order to document compliance with the limitations of Condition D.2 and D.6, the permittee shall maintain records of the sulfur content in the natural gas as supplied by the pipeline company. The Department may require the permittee to independently verify the sulfur content of the natural gas whenever the Department does not have reasonable assurance that the sulfur content information provided by the natural gas supplier accurately represents the sulfur content in the natural gas combusted in this source (emission unit). Compliance with the sulfur content standards shall be in accordance with the requirements of Subpart GG - 40 CFR 60.335(d). Proof of compliance with the annual SO₂ limitation (including calculations) shall be submitted along with the annual operating report each year.

[Air Construction Permit AC41-159485 as amended May 20, 1992; Rule 62-204.800(7)(b)39, F.A.C.; 40 CFR 60.335(d)]

- **D.13.** The permittee shall keep records of total electrical generation output and electrical output sold such that compliance with Condition D.11 can be determined. [Rule 62-213.440, F.A.C.]
- **D.14.** The permittee shall submit quarterly SO₂ excess emission reports in accordance with 40 CFR 60.7(c) and Subpart GG 40 CFR 60.334(c)(2). If there are no excess emissions during a calendar quarter the permittee shall submit a report stating that no excess emissions occurred during the reporting period. [Rule 62-204.800(7)(b)39, F.A.C.; 40 CFR 60.334(c)(2)]

Tropicana Products, Inc. Bradenton Citrus Processing Plant Page D5 of D4

40 CFR 60 shall be submitted to the Air Compliance

FINAL Permit No.: 0810007-003-AV

D.15. All reports required by 40 CFR 60 shall be submitted to the Air Compliance Sections of the MCEMD and Southwest District Office of the Department. All quarterly reports shall be postmarked by the 30th day following the end of each calendar quarter. [Rule 62-213.440, F.A.C.]