




Memorandum

Florida Department of Environmental Protection

TO: Michael G. Cooke

THRU: Trina Vielhauer 
Jeff Koerner 

FROM: Michael P. Halpin 

DATE: June 27, 2005

SUBJECT: Florida Power & Light Company
Manatee Plant Reburn Project
DEP File No. 0810010-010-AC

Attached is the final permit for the Manatee Plant Reburn Project to be completed on Units 1 and 2. This is an existing oil/gas fired facility located in Parrish, Manatee County.

This construction permit is being issued in order for FPL to comply with the settlement agreement reached between FDEP and FPL on September 19, 2002. Public Notice was made on June 6, 2005 in The [Bradenton] Herald. Comments were received solely from FPL, and each comment was accommodated, in the manner requested by the applicant.

I recommend your approval.

Attachments

/mph

FINAL DETERMINATION

Florida Power & Light Company
Manatee Plant Reburn Project
DEP File No. 0810010-010-AC, PA02-44

The Department distributed a public notice package on May 26, 2005 to allow the applicant to construct and commence operation of a reburn system on Units 1 and 2 at its Manatee Power Plant, located at 19050 State Road 62 in Parrish, Manatee County. The Public Notice of Intent to Issue concerning the Draft Permit was published in the Bradenton Herald on June 6, 2005.

COMMENTS/CHANGES

No comments were received by the Department from the public.

No comments were received from EPA.

Five comments were received from the applicant by letter dated June 16, 2005. Four of the comments recommended wording changes to four separate conditions and one comment requested that a condition be stricken in its entirety.

DEPARTMENT ACTION

Each of the three comments related to wording changes within the conditions are acceptable. These changes related to the following condition numbers: Specific Conditions I.5, I.9 and II.

Regarding the comment related to the striking of Condition I.2., the subject (draft) condition is listed below as well as the argument which was made by the applicant:

Beginning March 31, 2006, the permittee shall be responsible for submitting semi-annual summary reports. These reports will outline the status of construction, each test program conducted and a summary of any test program results. Proprietary or confidential data, documents or information submitted or disclosed to FDEP shall be identified as such by the Permittee and shall be maintained as such pursuant to applicable Florida law. The semi-annual summary reports will be sent to the DEP Southwest District Office and the Bureau of Air Regulation. The first summary will be due March 31, 2006 and will cover all construction, tests and results from such tests conducted between the issuance date of this permit and December 31, 2005. In a like manner, a similar summary shall be submitted for each 180 day period thereafter.

FPL COMMENT: FPL previously agreed with the Department to submit a report summarizing the 18 month program designed to evaluate the nitrogen oxides emission rates, boiler performance and Unit operation outlined in Paragraph 7 of the Reburn Agreement (September 2002). Providing the Department with semi-annual reports summarizing the status of construction, test programs conducted, and test program results as required by Specific Condition 2 of the Draft AC permit was not addressed in the terms of the agreement and is inconsistent with the many AC permits that FPL has acquired. The additional reporting created by this Specific Condition is burdensome and will take already limited Plant resources from the critical tasks associated with commissioning and optimizing the potentially complex application of a Reburn technology on Manatee Units 1 & 2. FPL requests that this Specific Condition is deleted in its entirety, as there is no regulatory basis for this condition, and, reporting terms and conditions were previously established in the "Agreement".

RESPONSE: The Department notes that Rule 62-4.070 provides the Department with broad authority to require conditions within permits, and that the Agreement was entered into "... for the exclusive purpose of ensuring compliance with the ambient air quality standards for ozone as provided for by Section 366.8255(1)(d)7, Florida Statutes (2002)". However, the permit condition will be simplified/clarified as follows:

FINAL DETERMINATION

Florida Power & Light Company
Manatee Plant Reburn Project
DEP File No. 0810010-010-AC, PA02-44

Beginning March 31, 2006, the permittee shall submit semi-annual reports providing a brief summary of the following: scope of construction completed, a schedule for upcoming construction, a general description of the NO_x test program conducted and a summary of the NO_x test program results. Proprietary or confidential data, documents or information submitted or disclosed to FDEP shall be identified as such by the Permittee and shall be maintained as such pursuant to applicable Florida law. The semi-annual summary reports will be sent to the DEP Southwest District Office and the Bureau of Air Regulation. The first summary will be due March 31, 2006 and will cover the period between the issuance date of this permit and December 31, 2005. In a like manner, a similar summary shall be submitted for each 180 day period thereafter.

Regarding the comment related to the reduction of requirements with Specific Condition I.3., the subject (draft) condition is listed below as well as the argument which was made by the applicant:

For the duration of the project, once the permittee has established any test program which involves stack testing (formal or informal), a Scope of Work shall be sent by fax to the DEP Southwest District Office as soon as possible and in advance of the planned commencement of the test program. This Scope of Work will give general descriptions of processes, work planned, dates of the tests and general objectives of the tests. Proprietary or confidential data, documents or information submitted or disclosed to FDEP shall be identified as such by the Permittee and shall be maintained as such pursuant to applicable Florida law.


FPL COMMENT: Due to the many different configurations, variables, and scheduling perturbations anticipated with the commissioning the Reburn system, providing notice to the Department of "any test program which involves stack testing (formal or informal)" as required by Specific Condition 3 is unprecedented in any FPL permit, and places undue burdens on both the Manatee Plant and the DEP Southwest District Office. FPL suggests the following language replace the existing language of Specific Condition 3: "FPL shall notify the DEP Southwest District, at least 15 days prior to the date on which each formal compliance test is to begin, of the date, time, and place of each such test, and the test contact person who will be responsible for coordinating and having such test conducted for the owner or operator as provided by Rule 62-297.310."

RESPONSE: The Department accepts (in part) FPL's suggestion, but will additionally require notice of major changes to the construction schedule as follows:

FPL shall notify the DEP Southwest District, at least 15 days prior to the date on which each formal compliance test is to begin, of the date, time, and place of each such test, and the test contact person who will be responsible for coordinating and having such test conducted for the owner or operator as provided by Rule 62-297.310. FPL shall promptly notify the DEP Southwest District Office and the Bureau of Air Regulation of substantial changes to the construction schedule.

CONCLUSION

The final action of the Department is to issue the permit with the changes described above.



Jeb Bush
Governor

Department of Environmental Protection

Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Colleen M. Castille
Secretary

July 1, 2005

CERTIFIED MAIL - RETURN RECEIPT REQUESTED

Mr. Paul Plotkin
General Manager, Manatee Plant
Florida Power & Light Company
19050 State Road 62
Parrish, FL 34219-9220

Re: DEP File No. 0810010-010-AC
Reburn Technology Project

Dear Mr. Plotkin:

In September 2002, FPL and FDEP entered into an agreement ("Agreement") for the purpose of ensuring compliance with the ambient air quality standards for ozone in the Tampa Bay region. This agreement, among other things, called for the installation of reburn technology for Units 1 and 2, designed to achieve a nitrogen oxides (NO_x) emission rate of 0.20 lb/MMBtu on a 30-day rolling average.

The Department has reviewed your request for an air construction permit for the purpose of installing reburn technology on Manatee Units 1 and 2 as required by the Agreement. As a result of this review, the Department has concluded that construction may be authorized. It is the Department's expectation that construction, start-up and optimization will occur according to the following parameters (Conditions 3 through 7 of the Agreement):

3. FPL shall commence installation of reburn technology in one of the existing Manatee Units (either Unit 1 or Unit 2) no later than 18 months after receiving all required state, federal or local environmental permits. FPL shall commence installation of reburn technology on the other unit no later than 12 months after installation has commenced on the first Unit. Installation of reburn technology in each Unit shall be completed no later than 12 months after commencement of installation in that Unit. The reburn technology will consist of a combustion modification process that utilizes fuel (either oil or natural gas) and air staging within the boilers to reduce nitrogen oxides emissions. In addition, overfire air (OFA) may be injected above the reburn zone within the boilers of Manatee Units 1 and 2 to reduce overall nitrogen oxides emissions.

4. The reburn technology installed in Manatee Units 1 and 2 shall be designed to achieve a nitrogen oxides emissions goal of 0.20 pounds per million BTU heat input on a 30-day rolling average. It is anticipated that achievement of this emissions goal will be achieved by utilizing the reburn when operating the Unit at greater than or equal to 350 megawatts.

5. Upon completion of installation of the reburn technology in each Unit, FPL shall optimize the operation of that Unit with reburn technology. After this optimization period has been completed for a Unit, or after a six month period, whichever occurs first, the reburn technology shall be utilized to minimize nitrogen oxides emissions when that Unit is in operation.

6. After completion of the optimization period for each Unit described in Paragraph 5, a nitrogen oxides emissions limit of 0.25 pounds per million BTU (30-day rolling average) shall apply to that Unit. This nitrogen oxides emissions limit shall apply during the data collection, testing and evaluation program described in Paragraph 7 and shall be incorporated into the Manatee Plant's Title V permit at the time of the next renewal.

"More Protection, Less Process"

Printed on recycled paper.

7. Beginning upon completion of the optimization period for the first of the Manatee Units in which reburn technology is installed, FPL shall conduct an 18 month program designed to evaluate nitrogen oxides emissions rates, boiler performance and Unit operation with the goal of identifying and implementing the lowest emissions rate possible for Manatee Units 1 and 2. This program shall include collection and analysis of data on nitrogen oxides emissions, boiler operating parameters, Unit performance characteristics and emissions of other pollutants, as well as projections of emissions rates assuming alternative, non-tested operating parameters and scenarios, including variations in fuels fired, Unit load and load-changing conditions, boiler and burner performance and any other factors relevant in evaluating possible changes to the nitrogen oxides emissions limit for Manatee Units 1 and 2. At the end of the 18 month period, FPL shall submit a report to FDEP summarizing the results of the program and addressing whether any further change in the applicable nitrogen oxides emissions limit is possible under tested and other alternative operating scenarios. Following receipt of the report, FDEP and FPL shall meet to discuss whether any further change in the applicable nitrogen oxides emissions limit for Manatee Units 1 and 2 is possible. If FPL and FDEP mutually agree on a change in the nitrogen oxides emissions limit for Manatee Units 1 and 2, FPL shall submit a Title V application for the Manatee Plant's Title V permit to incorporate the new, agreed upon limit. If FPL and FDEP do not agree on any new nitrogen oxides emissions limit for Manatee Units 1 and 2, the limit established in Paragraph 6 shall remain applicable.

Authorized Construction for Units 1 and 2:

- The top row of burners (8) and the existing overfire air ports (16) will be removed.
- The remaining 3 burner rows (24) will be replaced with Zink Dynaswirl burners.
- The windbox and associated ductwork will be modified so as to incorporate secondary air and gas injection, turning vanes and baffles, as necessary.
- A booster fan and associated ductwork will be installed downstream of the existing GI fan.
- A new overfire air system will be installed (including air flow metering and control components) which will comprise approximately 30 percent of the combustion air capacity.
- Fuel piping for natural gas and fuel oil will be installed (including fuel flow metering and control components) which will comprise approximately 25 percent of the heat input capacity.
- A full (DCS) control system will be installed and integrated with existing controls as necessary.
- Ancillary utilities will be involved, including air, steam and electric.

I. Conditions of Construction - The project shall be subject to the following conditions:

1. The permittee shall notify the DEP Southwest District and the Bureau of Air Regulation, in writing, at least seven days prior to beginning construction. Notification shall also occur within seven days, in writing, of completion of construction activities.
2. Beginning March 31, 2006, the permittee shall submit semi-annual reports providing a brief summary of the following: scope of construction completed, a schedule for upcoming construction, a general description of the NO_x test program conducted and a summary of the NO_x test program results. Proprietary or confidential data, documents or information submitted or disclosed to FDEP shall be identified as such by the Permittee and shall be maintained as such pursuant to applicable Florida law. The semi-annual summary reports will be sent to the DEP Southwest District Office and the Bureau of Air Regulation. The first summary will be due March 31, 2006 and will cover the period between the issuance date of this permit and December 31, 2005. In a like manner, a similar summary shall be submitted for each 180 day period thereafter.
3. FPL shall notify the DEP Southwest District, at least 15 days prior to the date on which each formal compliance test is to begin, of the date, time, and place of each such test, and the test contact person who will be responsible for coordinating and having such test conducted for the owner or operator as provided by Rule 62-297.310. FPL shall promptly notify the DEP Southwest District Office and the Bureau of Air Regulation of substantial changes to the construction schedule.
4. Stack emissions shall not exceed any limit within existing permits.
5. All compliance tests shall be conducted using EPA Reference Methods, as contained in 40 CFR 60 (Standards of Performance for New Stationary Sources) or any other method approved by the Department, in writing, in accordance with Chapter 62-297, F.A.C.
6. The project shall not result in the release of objectionable odors pursuant to Rule 62-296.320(2), F.A.C.
7. Testing shall cease as soon as possible if the boiler operations are not in accordance with the conditions within existing permits, or this authorization protocol. Such testing shall not resume until appropriate measures to correct the problem(s) have been implemented.
8. This Department action is only to authorize the reburn construction and operation. Notification shall occur within 30 days, in writing, upon completion of each optimization period as well as the eighteen month study.
9. Upon completion of the study, FPL shall submit a written report to the Department as indicated by the "Agreement". Such report shall be prepared and certified by a Florida licensed Professional Engineer and include pertinent equipment specifications. "As-built" drawings shall be made available at the plant for Department inspection.
10. The "Agreement" signed by FPL and FDEP on September 19, 2002, is incorporated herein.

II. Fugitive Construction Dust Emissions - Reasonable precautions to control fugitive dust emissions shall be in accordance with the existing Title V permit.

III. General Conditions - Appendix GC (attached)

This construction permit is issued pursuant to Chapter 403, Florida Statutes. No other changes to the permit are authorized by this action. A copy of this letter shall be filed with permit No. 0810010-009-AV and shall become part of the permit. Any party to this order has the right to seek judicial review of it under Section 120.68, F.S., by the filing of a Notice of Appeal under Rule 9.110 of the Florida Rules of Appellate Procedure with the Clerk of the Department of Environmental Protection in the Office of General Counsel, Mail Station 35, 3900 Commonwealth Boulevard, Tallahassee, Florida, 32399-3000, and by filing a copy of the Notice of Appeal accompanied by the applicable filing fees with the appropriate District Court of Appeal. The Notice of Appeal must be filed within (thirty) days after this Notice is filed with the Clerk of the Department.

Executed in Tallahassee, Florida.

Sincerely,



Michael G. Cooke, Director
Division of Air Resource
Management

CERTIFICATE OF SERVICE


The undersigned duly designated deputy agency clerk hereby certifies that this Notice of Final Permit (including the Final permit) was sent by certified mail (*) and copies were mailed by U.S. Mail before the close of business on 7/5/05 to the person(s) listed:

Paul Plotkin, FPL*
Clarence Troxell*
Chair, Manatee County Commissioners*
President, Manatee County Citizens Against Pollution (MCAP)*
Manatee County Environmental Management Department
Kevin Washington, FPL

Mary Maxwell, FPL
Ken Kosky, Golder
Joel Smolen, SWD
Hamilton Oven, DEP Siting Office
Gregg Worley, EPA Region 4
John Bunyak, NPS

Clerk Stamp

FILING AND ACKNOWLEDGMENT FILED, on this date, pursuant to §120.52, Florida Statutes, with the designated Department Clerk, receipt of which is hereby acknowledged.


(Clerk)

7/5/05
(Date)

AGREEMENT
FOR THE PURPOSE OF
ENSURING COMPLIANCE WITH
AMBIENT AIR QUALITY STANDARDS FOR OZONE

This Agreement is entered into between the Florida Department of Environmental Protection ("FDEP") and Florida Power & Light Company ("FPL") to reduce emissions of nitrogen oxides from an existing electrical generating facility for the exclusive purpose of ensuring compliance with the ambient air quality standards for ozone, as provided for by Section 366.8255(1)(d)7, Florida Statutes (2002).

WHEREAS:

I. The Florida Legislature enacted Chapter 2002-276, Laws of Florida, to allow agreements between electric utilities and FDEP for the purpose of ensuring compliance with ozone ambient air quality standards, and further to provide for the recovery of costs and expenses prudently incurred by an electric utility pursuant to such an agreement entered into prior to October 1, 2002;

II. FDEP has the statutory duty and authority, pursuant to Chapter 403, Florida Statutes, and rules adopted under Chapter 62, Florida Administrative Code, to protect and maintain Florida's air quality, including ensuring compliance with ambient air quality standards for ozone;

III. The U.S. Environmental Protection Agency ("U.S. EPA") has promulgated a new ambient air quality standard for ozone that establishes a permissible limit on the level of ozone during any 8-hour period;

IV. Manatee County is located in the vicinity of the Tampa Bay Airshed, which has experienced recent episodes of elevated ozone levels higher than the U.S. EPA's new ambient air quality standard for ozone on at least 15 separate days in the past four years;

V. Nitrogen oxides emissions from electrical generating facilities owned by electric utilities can contribute to the formation of ozone in the vicinity of an electrical generating facility;

Based upon the best available information, including ambient air quality monitoring data, it is not clear whether the Tampa Bay Airshed will be in compliance with the 8-hour ozone standard in 2004/2005.

FPL is an electric utility that owns and operates an electrical generating facility known as the Manatee Plant, located in unincorporated Manatee County, Florida, comprised of two 800 megawatt class fossil fuel-fired generating units known as Manatee Units 1 and 2 or jointly as "the facility";

FPL is regulated by the Florida Public Service Commission, and the Manatee Plant provides electric power to consumers in FPL's service area;

Manatee Units 1 and 2 emit nitrogen oxides, a precursor to regional ozone formation, into the atmosphere of Manatee County and surrounding areas, including the Tampa Bay Airshed;

X. The Manatee Plant, together with other regional power plants, commercial and industrial activities, and transportation, are the main sources of nitrogen oxides affecting regional ozone formation in the Tampa Bay Airshed;

XI. FPL has identified a nitrogen oxides emissions control technology known as "reburn" that is a "pollution prevention" system, which can reduce nitrogen oxides emissions from Manatee Units 1 and 2 without the use of reagents, catalysts, pollution collection or removal equipment;

XII. Use of the proposed reburn emissions control technology in Manatee Units 1 and 2 will require FPL to incur certain costs and expenses to install, operate and maintain that control technology; and,

XIII. Installation of reburn technology in FPL's Manatee Units 1 and 2 and the

achievement of an emissions rate of no greater than 0.25 pounds per million BTU on a 30-day rolling average basis will help to ensure that the Tampa Bay Airshed will comply with the ozone ambient air quality standards established by U.S. EPA and by FDEP.

NOW THEREFORE, in consideration of the premises and mutual agreements contained herein, and intending to be legally bound, FDEP and FPL hereby agree as follows:

1. This Agreement is entered into by FDEP and FPL for the exclusive purpose of ensuring compliance with ozone ambient air quality standards.
2. This Agreement is in full force and effect upon the signature of both parties unless the Florida Public Service Commission (FPSC) does not issue a final order authorizing FPL to recover the costs incurred pursuant to this Agreement through the Environmental Cost Recovery Clause within 120 days of the execution of the Agreement at which time the parties may mutually agree, in writing, to extend the Agreement. In the event the FPSC does not issue a final order within 120 days of the execution of the Agreement and the parties do not mutually agree to extend the Agreement, the Agreement becomes null and void. A final order is one that is no longer subject to review or appeal by a court of competent jurisdiction. FPL will exercise good faith in seeking approval of such cost recovery from the FPSC in a timely manner. FDEP agrees to support FPL's request for such approval by the FPSC. FDEP and FPL agree that installation of reburn technology in Manatee Units 1 and 2, in conjunction with the achievement of an emissions rate of no greater than 0.25 pounds per million BTU on a 30-day rolling average, will reduce nitrogen oxides emissions from the facility in a potential ozone nonattainment area.
3. FPL shall commence installation of reburn technology in one of the existing Manatee Units (either Unit 1 or Unit 2) no later than 18 months after receiving all required state, federal or local environmental permits. FPL shall commence installation of reburn technology on the other unit no later than 12 months after installation has commenced on the first Unit. Installation of reburn technology in each Unit shall be completed no later than 12 months after commencement of installation in that Unit. The reburn technology will consist of a combustion

modification process that utilizes fuel (either oil or natural gas) and air staging within the boilers to reduce nitrogen oxides emissions. In addition, overfire air (OFA) may be injected above the reburn zone within the boilers of Manatee Units 1 and 2 to reduce overall nitrogen oxides emissions.

4. The reburn technology installed in Manatee Units 1 and 2 shall be designed to achieve a nitrogen oxides emissions goal of 0.20 pounds per million BTU heat input on a 30-day rolling average. It is anticipated that achievement of this emissions goal will be achieved by utilizing the reburn when operating the Unit at greater than or equal to 350 megawatts.

5. Upon completion of installation of the reburn technology in each Unit, FPL shall optimize the operation of that Unit with reburn technology. After this optimization period has been completed for a Unit, or after a six month period, whichever occurs first, the reburn technology shall be utilized to minimize nitrogen oxides emissions when that Unit is in operation.

6. After completion of the optimization period for each Unit described in Paragraph 5, a nitrogen oxides emissions limit of 0.25 pounds per million BTU (30-day rolling average) shall apply to that Unit. This nitrogen oxides emissions limit shall apply during the data collection, testing and evaluation program described in Paragraph 7 and shall be incorporated into the Manatee Plant's Title V permit at the time of the next renewal.

7. Beginning upon completion of the optimization period for the first of the Manatee Units in which reburn technology is installed, FPL shall conduct an 18 month program designed to evaluate nitrogen oxides emissions rates, boiler performance and Unit operation with the goal of identifying and implementing the lowest emissions rate possible for Manatee Units 1 and 2. This program shall include collection and analysis of data on nitrogen oxides emissions, boiler operating parameters, Unit performance characteristics and emissions of other pollutants, as well as projections of emissions rates assuming alternative, non-tested operating parameters and scenarios, including variations in fuels fired, Unit load and load-changing conditions, boiler and burner performance and any other factors relevant in evaluating possible changes to the nitrogen

oxides emissions limit for Manatee Units 1 and 2. At the end of the 18 month period, FPL shall submit a report to FDEP summarizing the results of the program and addressing whether any further change in the applicable nitrogen oxides emissions limit is possible under tested and other alternative operating scenarios. Following receipt of the report, FDEP and FPL shall meet to discuss whether any further change in the applicable nitrogen oxides emissions limit for Manatee Units 1 and 2 is possible. If FDEP and FPL mutually agree on a change in the nitrogen oxides emissions limit for Manatee Units 1 and 2, FPL shall submit a Title V application for the Manatee Plant's Title V permit to incorporate the new, agreed-upon limit. If FDEP and FPL do not agree on any new nitrogen oxides emissions limit for Manatee Units 1 and 2, the limit established in Paragraph 6 shall remain applicable.

8. In the event state or federal law changes to require a change in nitrogen oxides emissions or the Tampa Bay Airshed is declared non-attainment for ozone, any reduction requirements would be in accordance with all applicable state and federal requirements. FDEP concurs that the changes contemplated by this Agreement will not constitute "modifications" that trigger New Source Review. In addition, although Florida currently has no state statute providing for nitrogen oxides trading or credits, FPL shall be entitled to retain all nitrogen oxides reduction credits and trading rights that may be authorized by Florida law in the future.

9. FDEP concurs that the steps and changes described in paragraphs 3 through 7, above, are prudent for purposes of (a) ensuring that FPL's Manatee Plant located within the Tampa Bay Airshed supports the area's compliance with the 8-hour ozone ambient air quality standard and (b) authorizing related cost recovery pursuant to Section 366.8255(1)(d), Florida Statutes, as amended by the Florida Legislature in its 2002 session and signed into law by the Governor of the State of Florida.

10. FDEP shall process in a timely manner any permit applications or requests for approvals necessary to implement this Agreement.

11. This Agreement is not and shall not be construed to be a permit issued or required pursuant to any federal, state or local law, rule or regulation including those of FDEP and Manatee County.

12. FPL shall be entitled to relief from the time requirements of this Agreement in the event of a *force majeure*, which includes, but is not limited to, delays in regulatory approvals, construction, labor, material, or equipment delays, fuel supply delays, acts of God or other similar events that are beyond the control of FPL and do not result from its own actions, for the length of time necessarily imposed by any such delay.

13. There shall be no modifications or amendments of this Agreement without the written agreement of all parties to this Agreement.

14. This Agreement shall apply to and be binding upon FDEP and FPL and their successors and assigns. Each person signing this Agreement certifies that he or she is authorized to execute this Agreement and to legally bind the party on whose behalf he or she signs this Agreement.

By their signatures affixed below, the parties agree to be bound by the terms and conditions of this Agreement.

DEPARTMENT OF ENVIRONMENTAL
PROTECTION

9-19-02
Date

BY: 
Allan Bedwell, Deputy Secretary

FLORIDA POWER & LIGHT COMPANY

9-19-02
Date

BY: 
Randall LaBauve, Vice President
Environmental Services

FINAL DETERMINATION
Florida Power & Light Company
Manatee Plant Reburn Project
DEP File No. 0810010-010-AC, PA02-44

The Department distributed a public notice package on May 26, 2005 to allow the applicant to construct and commence operation of a reburn system on Units 1 and 2 at its Manatee Power Plant, located at 19050 State Road 62 in Parrish, Manatee County. The Public Notice of Intent to Issue concerning the Draft Permit was published in the Bradenton Herald on June 6, 2005.

COMMENTS/CHANGES

No comments were received by the Department from the public.

No comments were received from EPA.

Five comments were received from the applicant by letter dated June 16, 2005. Four of the comments recommended wording changes to four separate conditions and one comment requested that a condition be stricken in its entirety.

DEPARTMENT ACTION

Each of the three comments related to wording changes within the conditions are acceptable. These changes related to the following condition numbers: Specific Conditions I.5, I.9 and II.

Regarding the comment related to the striking of Condition I.2., the subject (draft) condition is listed below as well as the argument which was made by the applicant:

Beginning March 31, 2006, the permittee shall be responsible for submitting semi-annual summary reports. These reports will outline the status of construction, each test program conducted and a summary of any test program results. Proprietary or confidential data, documents or information submitted or disclosed to FDEP shall be identified as such by the Permittee and shall be maintained as such pursuant to applicable Florida law. The semi-annual summary reports will be sent to the DEP Southwest District Office and the Bureau of Air Regulation. The first summary will be due March 31, 2006 and will cover all construction, tests and results from such tests conducted between the issuance date of this permit and December 31, 2005. In a like manner, a similar summary shall be submitted for each 180 day period thereafter.

FPL COMMENT: FPL previously agreed with the Department to submit a report summarizing the 18 month program designed to evaluate the nitrogen oxides emission rates, boiler performance and Unit operation outlined in Paragraph 7 of the Reburn Agreement (September 2002). Providing the Department with semi-annual reports summarizing the status of construction, test programs conducted, and test program results as required by Specific Condition 2 of the Draft AC permit was not addressed in the terms of the agreement and is inconsistent with the many AC permits that FPL has acquired. The additional reporting created by this Specific Condition is burdensome and will take already limited Plant resources from the critical tasks associated with commissioning and optimizing the potentially complex application of a Reburn technology on Manatee Units 1 & 2. FPL requests that this Specific Condition is deleted in its entirety, as there is no regulatory basis for this condition, and, reporting terms and conditions were previously established in the "Agreement".

RESPONSE: The Department notes that Rule 62-4.070 provides the Department with broad authority to require conditions within permits, and that the Agreement was entered into "... for the exclusive purpose of ensuring compliance with the ambient air quality standards for ozone as provided for by Section 366.8255(1)(d)7, Florida Statutes (2002)". However, the permit condition will be simplified/clarified as follows:

FINAL DETERMINATION

Florida Power & Light Company
Manatee Plant Reburn Project
DEP File No. 0810010-010-AC, PA02-44

Beginning March 31, 2006, the permittee shall submit semi-annual reports providing a brief summary of the following: scope of construction completed, a schedule for upcoming construction, a general description of the NO_x test program conducted and a summary of the NO_x test program results. Proprietary or confidential data, documents or information submitted or disclosed to FDEP shall be identified as such by the Permittee and shall be maintained as such pursuant to applicable Florida law. The semi-annual summary reports will be sent to the DEP Southwest District Office and the Bureau of Air Regulation. The first summary will be due March 31, 2006 and will cover the period between the issuance date of this permit and December 31, 2005. In a like manner, a similar summary shall be submitted for each 180 day period thereafter.

Regarding the comment related to the reduction of requirements with Specific Condition I.3., the subject (draft) condition is listed below as well as the argument which was made by the applicant:

For the duration of the project, once the permittee has established any test program which involves stack testing (formal or informal), a Scope of Work shall be sent by fax to the DEP Southwest District Office as soon as possible and in advance of the planned commencement of the test program. This Scope of Work will give general descriptions of processes, work planned, dates of the tests and general objectives of the tests. Proprietary or confidential data, documents or information submitted or disclosed to FDEP shall be identified as such by the Permittee and shall be maintained as such pursuant to applicable Florida law.




FPL COMMENT: Due to the many different configurations, variables, and scheduling perturbations anticipated with the commissioning the Reburn system, providing notice to the Department of "any test program which involves stack testing (formal or informal)" as required by Specific Condition 3 is unprecedented in any FPL permit, and places undue burdens on both the Manatee Plant and the DEP Southwest District Office. FPL suggests the following language replace the existing language of Specific Condition 3: "FPL shall notify the DEP Southwest District, at least 15 days prior to the date on which each formal compliance test is to begin, of the date, time, and place of each such test, and the test contact person who will be responsible for coordinating and having such test conducted for the owner or operator as provided by Rule 62-297.310."

RESPONSE: The Department accepts (in part) FPL's suggestion, but will additionally require notice of major changes to the construction schedule as follows:

FPL shall notify the DEP Southwest District, at least 15 days prior to the date on which each formal compliance test is to begin, of the date, time, and place of each such test, and the test contact person who will be responsible for coordinating and having such test conducted for the owner or operator as provided by Rule 62-297.310. FPL shall promptly notify the DEP Southwest District Office and the Bureau of Air Regulation of substantial changes to the construction schedule.

CONCLUSION

The final action of the Department is to issue the permit with the changes described above.

		2ND		Parcels: 1/1
Front DEP AIR RESOURCE MGMT P. Adams DIRECTOR OFFICE STE 23 111 S MAGNOLIA DR TALLAHASSEE, FL 32301 UNITED STATES Tel: 850-921-9505 To: National Park Service Mr. John Bunyak 12795 W. Alameda Parkway Air Division Lakewood, CO 80228 UNITED STATES				
Tel: 303-966-2818				
POSTCODE: 80228				
Sender's ref: 37550201000 A7 SP255				
ORIGINAL TLH				
Description: books		Weight: 2 lbs for 1 pcs Date: 2005-05-13		
DHL standard terms and conditions apply.		Day 17TU		
		EGEH 8E OOH		
(ZL)US80228				
WAYBILL: 26263612351 (Non-Negotiable)				

▲ PEEL HERE

PEEL HERE ▲

Please fold or cut in half
DO NOT PHOTOCOPY

Using a photocopy could delay the delivery of your package and will result in additional shipping charge

SENDER'S RECEIPT

Waybill #: 26263612351

To (Company):
 National Park Service
 Air Division
 12795 W. Alameda Parkway

Lakewood, CO 80228
 UNITED STATES

Attention To: Mr. John Bunyak
 Phone #: 303-966-2818

Sent By: P. Adams
 Phone #: 850-921-9505

Rate Estimate: 5.15
 Protection: Not Required
 Description: books

Weight (lbs.): 2
 Dimensions: 0 x 0 x 0

Ship Ref: 37550201000 A7 SP255
 Service Level: 2nd Day (2nd
 business day by 5 PM)

Special Svc:

Date Printed: 5/13/2005
 Bill Shipment To: Sender
 Bill To Acct: 778941286

DHL Signature (optional) _____ Route _____ Date _____ Time _____

For Tracking, please go to www.dhl-usa.com or call 1-800-225-5345




Thank you for shipping with DHL

Create new shipment 

► View pending shipments

Print waybill 

DHL
 EXPRESS

		EXP	Parcels: 1/1
From: DEP AIR RESOURCE MGMT P. Adams DIRECTOR OFFICE STE 23 111 S MAGNOLIA DR TALLAHASSEE, FL 32301 UNITED STATES Tel: 850-921-9505		ORIGIN: TLH Sender's ref: 37550201000 A7 AP255	
To: U.S. EPA Region 4 Mr. Gregg M. Worley 61 Forsyth Street Air Permits Section Atlanta, GA 30303 UNITED STATES		POSTCODE: 30303 Tel: 404-562-9141	
Description: books Weight: 2 lbs for 1 pcs Date: 2005-05-13 DHL standard terms and conditions apply.			
 (2L)US30303		HARB 6V ATT	
 WAYBILL: 26263701155 (Non-Negotiable)			

▲ PEEL HERE

PEEL HERE ▲

Please fold or cut in half

DO NOT PHOTOCOPY

Using a photocopy could delay the delivery of your package and will result in additional shipping charge

SENDER'S RECEIPT

Waybill #: 26263701155

 To (Company):
 U.S. EPA Region 4
 Air Permits Section
 61 Forsyth Street

 Atlanta, GA 30303
 UNITED STATES

 Attention To: Mr. Gregg M. Worley
 Phone #: 404-562-9141

 Sent By:
 Phone #: P. Adams
 850-921-9505

 Rate Estimate:
 Protection:
 Description:

 6
 Not Required
 books

 Weight (lbs.):
 Dimensions:

 2
 0 x 0 x 0

 Ship Ref:
 Service Level:
 business day by 12 PM

 37550201000 A7 AP255
 Next Day 12:00 (Next)

Special Svc:

 Date Printed: 5/13/2005
 Bill Shipment To: Sender
 Bill To Acct: 776941286

DHL Signature (optional)

Route _____ Date _____ Time _____

For Tracking, please go to www.dhl-usa.com or call 1-800-225-5345

Thank you for shipping with DHL

Create new shipment ▶

▶ View pending shipments

Print waybill ▶



EXPRESS

U.S. Postal Service
CERTIFIED MAIL RECEIPT
(Domestic Mail Only; No Insurance Coverage Provided)

7001 0320 0001 3692 2817

Postage	\$
Certified Fee	
Return Receipt Fee (Endorsement Required)	
Restricted Delivery Fee (Endorsement Required)	

Postmark
Here

Mr. Clarence Troxell
 3321 Lakeside Circle
 Parrish, Florida 34219

St.
St.
St.
St.

PS Form 3800, January 2001

See Reverse for Instructions

U.S. Postal Service
CERTIFIED MAIL RECEIPT
(Domestic Mail Only; No Insurance Coverage Provided)

7001 0320 0001 3692 2794

Postage	\$
Certified Fee	
Return Receipt Fee (Endorsement Required)	
Restricted Delivery Fee (Endorsement Required)	

Postmark
Here

Total

Dan Kumarich, President
 Manatee Citizens Against Pollution
 P.O. Box 660
 Parrish, FL 34219

Sent To
Street
or P.O.
City, S

PS Form 3800, January 2001

See Reverse for Instructions

SENDER: COMPLETE THIS SECTION

- Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:

Mr. Ron Getman, Chairman
Manatee County Board of
Commissioners
Post Office Box 1000
Bradenton, Florida 34206-1000

COMPLETE THIS SECTION ON DELIVERY**A. Signature**

Terry L. Tarnham Agent
☐ Addressee

B. Received by (Printed Name)

Terry L. Tarnham C. Date of Delivery

D. Is delivery address different from item 1? ☐ Yes
If YES, enter delivery address below: ☒ No**3. Service Type**

- ☒ Certified Mail ☐ Registered ☐ Return Receipt for Merchandise
☐ Insured Mail ☐ C.O.D.

4. Restricted Delivery? (Extra Fee) ☐ Yes**2. Article Number**

(Transfer from service label)

7001 0320 0001 3692 2800

PS Form 3811, February 2004

Domestic Return Receipt

102595-02-M-1540

U.S. Postal Service**CERTIFIED MAIL RECEIPT**

(Domestic Mail Only; No Insurance Coverage Provided)

0002 2800
2692 3692
1000 0001
0320 7001

Postage \$

Certified Fee

Return Receipt Fee
(Endorsement Required)

Restricted Delivery Fee
(Endorsement Required)

Postmark
Here

Mr. Ron Getman, Chairman
Manatee County Board of
Commissioners
Post Office Box 1000
Bradenton, Florida 34206-1000

PS Form 3800, January 2001

See Reverse for Instructions

SENDER: COMPLETE THIS SECTION

- Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:

Mr. Paul Plotkin, General Manager
 Manatee Plant
 Florida Power & Light Company
 19050 State Road 62
 Parrish, Florida 34219-9220

2. Article Number

(Transfer from service label)

7001 0320 0001 3692 2824

PS Form 3811, February 2004

Domestic Return Receipt

102595-02-M-1540

COMPLETE THIS SECTION ON DELIVERY
A. Signature

X *Gale Kinne*

☐ Agent

☐ Addressee

B. Received by (Printed Name)

GALE KINNE

C. Date of Delivery

7-7-05

D. Is delivery address different from item 1?

☐ Yes

If YES, enter delivery address below:

☐ No

3. Service Type

☒ Certified Mail ☐ Express Mail

☐ Registered ☐ Return Receipt for Merchandise

☐ Insured Mail ☐ C.O.D.

4. Restricted Delivery? (Extra Fee)

☐ Yes

U.S. Postal Service
CERTIFIED MAIL RECEIPT

(Domestic Mail Only; No Insurance Coverage Provided)

7001 0320 0001 3692 2824

Postage

\$

Certified Fee

Return Receipt Fee
(Endorsement Required)

Restricted Delivery Fee
(Endorsement Required)

Postmark
Here

Mr. Paul Plotkin, General Manager
 Manatee Plant
 Florida Power & Light Company
 19050 State Road 62
 Parrish, Florida 34219-9220

PS Form 3800, January 2001

See Reverse for Instructions