

Mr. Hamilton S. Oven
Siting Coordination Office
Department of Environmental Protection
2600 Blair Stone Road, MS 48
Twin Towers Building, Suite 649
Tallahassee, FL 32399-2400

RECEAUGUSTE 1006

AUG 14 2006

BUREAU OF AIR REGULATION

Re:

Florida Power & Light Company Manatee Unit 3 Expansion Project

Power Plant Site Certification No. PA 02-44

**Emergency Diesel Generators** 

Dear Mr. Oven:

Please accept this letter and the attachments as an update to the Florida Power & Light Company's (FPL) original Site Certification Application (SCA) for the Manatee Expansion Project in Manatee County, Florida. This information is being provided regarding the installation and operation of two emergency diesel generators and associated switchgear within the Certified area. Attachment 1 is a site plan showing the location of the emergency diesel generators.

The loss of the electrical grid in the Northeast during the summer of 2003 caused a significant blackout in several states. In addition, in the last two years, Florida has experienced an increase in the frequency and strength of hurricanes that make landfall, requiring many of our units to be shut down and be restarted once conditions are safe. During these types of events the plants could be without external power, limiting the safe shut down and start up of many of our units. The emergency diesel generators being installed at the Manatee site will allow the new Unit 3 to be safely shutdown and to remain in a mode ready for restart.

There is one existing emergency diesel generator at the Manatee Plant site that burns less than 14,000 gallons of fuel per year for maintenance and testing. The new generators combined will burn less than 13,000 gallons per year. Therefore, the generators fall under a categorical exemption per FDEP Rule 62-210.300(3), F.A.C., which exempts emergency units that collectively burn less than 32,000 gallons per year. (Attachment 2 contains the relevant excerpts of Rule 62-210.300(3), F.A.C.) The new emergency diesel generators to be installed were ordered by FPL in December 2004, and therefore will not be subject to the proposed NSPS IIII issued July 11, 2005. No air construction permit is required for these generators. They will be included in the Title V operating permit in the future, as a matter of course.

We are currently planning to startup the new diesel generators in early December and to connect them to the operating plant during a previously scheduled plant outage in mid-December. If you have any questions, or if you require additional information, please call me at 561-691-7065.

Sincerely,

Stacy Foster

Sr. Environmental Specialist

cc: Mr. Al Linero, FDEP Bureau of Air Regulation

#### **CERTIFICATE OF SERVICE**

I HEREBY CERTIFY that a copy of the foregoing has been furnished to the following:

By U.S. Mail to the following on this 11<sup>th</sup> day of August, 2006:

James V. Antista, Esq. Fish and Wildlife Conservation Commission 620 South Meridian Street Tallahassee, FL 32399-1600

Craig Varn, Esq.
Department of Community Affairs
2555 Shumard Oak Boulevard
Tallahassee, FL 32399-2100

Tedd N. Williams, Esq.
County Attorney
Manatee County
Post Office Box 1000
Bradenton, Florida 34206-1000


Hamilton S. Oven, Siting Coordinator Department of Environmental Protection 2600 Blair Stone Road Tallahassee, FL 32399

Roger Tucker, Esquire Tampa Bay Regional Planning Council 9455 Koger Blvd., Suite 219 St. Petersburg, Fl. 33702-2491

Martha A. Moore, Esquire Southwest Florida Water Management District 2379 Broad Street Brooksville, Fl. 34604-6899 Sheauching Yu, Esq. Department of Transportation Haydon Burns Building 605 Suwannee Street, MS 58 Tallahassee, FL 32399-0450

Mary Ann Helton, Esq. Florida Public Service Commission Gerald Gunter Building 2450 Shumard Oak Blvd. Tallahassee, FL 32399-0850

Scott A. Goorland, Esq. Sr. Assistant General Counsel Dept of Environmental Protection 3900 Commonwealth Blvd., M.S. 35 Tallahassee, FL 32399-3000



. . .

### <u>ATTACHMENT 2</u>

### Excerpts from FDEP Rule 62-210.300(3) Florida Administrative Code:

- "(3) Exemptions. A facility, emissions unit or pollutant-emitting activity shall be exempt from the permitting requirements of this chapter, Chapter 62-212, F.A.C., and Chapter 62-4, F.A.C., if it satisfies the applicable criteria of Rule 62-210.300(3)(a) or (b) F.A.C., or if it has been exempted from permitting pursuant to Rule 62-4.040, F.A.C....Emissions units and pollutant-emitting activities exempt from permitting under this rule shall not be exempt from the permitting requirements of Chapter 62-213, F.A.C., if they are contained within a Title V source; however, such emissions units and activities shall be considered insignificant for Title V purposes provided they also meet the criteria of Rule 62-213.300(2)(a)1. or 62-213.430(6)(b), F.A.C. Any proposed new emissions unit or activity that would be exempt from permitting under this rule shall not be required to obtain an air construction permit pursuant to this chapter, Chapter 62-212, F.A.C., or Chapter 62-4, F.A.C., even if such unit or activity would be contained within a Title V source...
  - (a) Categorical Exemptions.
    - 20. One or more emergency generators located within a single facility provided:
      - a. None of the emergency generators is subject to the Federal Acid Rain Program; and
      - b. Total fuel consumption by all such emergency generators within the facility is limited to 32,000 gallons per year of diesel fuel, 4,000 gallons per year of gasoline, 4.4 million standard cubic feet per year of natural gas or propane, or an equivalent prorated amount if multiple fuels are used."

#### Heron, Teresa

From:

Stacy\_Foster@fpl.com

Sent:

Friday, September 29, 2006 11:27 AM

To:

Heron, Teresa

Cc:

Mary Archer@fpl.com

Subject:

Re: FW: Information for the Diesel Generators at Manatee

Attachments:

Attachment 1.pdf; Attachment 2.pdf; Attachment 3.pdf







(370 KB)

Attachment 1.pdf Attachment 2.pdf Attachment 3.pdf (66 KB)

(159 KB)

Ms. Heron,

Below are the responses to your questions regarding the Emergency Diesel Generators at the FPL Manatee Plant.

- 1) Proof of order date:
- Please see attachment 1, which is a scanned copy of the purchase order. I was told by the purchasing agent that all the were ordered in 2004. generators
- 2) Define type of engine:
- Please see attachment 2, which is a scanned copy of the а. performance data.
- 3) Provide the rationale for non-applicability of NESHAP Subpart ZZZZ: After review of the standard our analysis showed that our stationary RICE is subject to the initial notification requirements of 40 CFR 63.6645(d). The RICE however, is not subject to any other requirements of this subpart (40 CFR subpart ZZZZ) or the general provisions (40 CFR part 63, subpart A).
- Please see attachment 3, which is the scanned Applicability Flowchart for NESHAP for Reciprocating Internal Combustion (RICE) 40 CFR part 63, subpart ZZZZ. The flowchart Engines states out stationary RICE must meet the initial notification 40 CFR 63.6645(d). The emergency RICE requirements of is not subject to any other requirements of this subpart or the General Provisions (40 CFR part 63, subpart A)
- 63.6645(d) states if you are required to submit an Initial Notification but are otherwise not affected by the requirements subpart in accordance with 63.6590(b) your of this notification should include the following information in 63.9(b)(2)(i) through (v), and a statement that your stationary RICE has no additional requirements and explain the basis of the exclusion (for example that it operates exclusively as an emergency stationary RICE). 40 CFR 63.6675 defines Emergency Diesel Generator as applicable to subpart ZZZZ.

I will be forwarding a letter to the department with the initial notification as required by 63.9(b)(2)(i) through (v) Per 63.6645(c) which states, if you start up your new or restructure your stationary RICE on or after August 16, 2004 you must submit an initial notification not later than 120 days after you become subject to this subpart.

Could you please give me the address in which to send the initial notification letter. Also if there are additional people other than yourself that need to be notified could you please let me know who they are.

If you have any questions, or if you require additional information, please call me at 561-691-7065.

(See attached file: Attachment 1.pdf) (See attached file: Attachment 2.pdf) (See attached file: Attachment 3.pdf)

Thank You,

Stacy Foster
FPL Environmental Services
W 561-691-7065
C 772-285-5653

"Heron, Teresa"

<Teresa.Heron@dep.s

tate.fl.us>

To: sta

stacy foster@fpl.com

cc:

Subject: FW: Information for the Diesel

Generators at Manatee

09/13/2006 09:05 AM

From: Heron, Teresa

Sent: Wednesday, September 13, 2006 9:04 AM

To: 'stacey\_foster@fpl.com'

Subject: Information for the Diesel Generators at Manatee

Stacey:

Re: Emergency Diesel Generators

It was nice talking to you this afternoon. As I explained to you, we need the following additional information:

Proof of order date
Define type of engine
Provide rationale for non-applicability of NESHAP Subpart ZZZZ

Thanks, Teresa Heron, Engineer Permitting South Section Bureau of Air Regulation Phone 850/921-9529 teresa.heron@dep.state.fl.us



### Page 1 of 5 **Purchase Order**

DATE:

Address

Phone: 561-691-2119

conditions.

RING POWER CORP RING LIFT POWER SYS SE CRANE CAT RE 8050 PHILLIPS HIGHWAY JACKSONVILLE FL 32256

Ship To: FLÖRIDA POWER & LIGHT CO. See Item Text For Delivery Instruct PO Number 4500238508 Date 12/02/2004 Attention Scott B. Wilcox Phone (407) 855-6195 Fax 9042810831 Validity End Date 12/31/2007 Incoterms Not Applicable

Tax Code: 50 - Exempt per FI Statute 212.08 Payment Terms

Net 45 Days

### **DESCRIPTION OF WORK** This Purchase Document is your authority to supply three (3) generators and paralleling switchgear at Florida Power & Light Company's Ft Myers Plant, two (2) generator units at Martin Unit 8 Plant, two (2) generator units at Martin 3 and 4 Plant, and two (2) generator units at Manatee 3 Plant. Supplier shall furnish FOB destinations, and will support startup and commissioning of the diesel generator replacement systems. FPL will be using a separate General Contractor to support demolition and installation work for the new diesel generators. **COMPANY REPRESENTATVE** All work is subject to the approval and acceptance of our Mr. Ron Bartnick, (561) 691-7664 who is the FPL Company Representative. Supplier's representative for this Purchase Order is Mr. Scott B. Wilcox, (407) 855-6195. **TERMS & CONDITIONS** All work shall be performed in accordance with the attached Conformed Specifications for FPL Black Plant Diesel Generator Systems, Rev. 5, dated November 24, 2004 and FPLS Negotiated Terms and Conditions for Materials Between FPL and Ring Power dated 8/2/04. h .arther information is required call **AUTHORIZED** Agent: TIM LINNAN

This Purchase Order is subject to the attached, or previously provided, terms and conditions. Shipment of the

goods or commencement of work by the supplier will constitute acceptance of all of these terms and

SIGNATURE:





# Purchase Order

	Tunor Or	7E11 00111	
Wether Description of the second seco		iver enter:	
Following terms and conditions take precedence to attached FPL Services Negotiated Terms and Conditions for Materials Between FPL Services and Ring Power:			
Freight is FOB Destination.			
Payment Terms:			
Net 45			į
1. Base scope with three (3) generators and paralleling switchgear at Ft Myers Plant, two (2) generator units at Martin Unit 8 Plant, two (2) generator units at Martin 3 and 4 Plant, and two (2) generators at Manatee 3 Plant.  Invoice 60% of PO value on issuance of Purchase Order. 25% on delivery of undamaged equipment.  Balance on Final Acceptance not to exceed 120 days from delivery.			
2. Additive Option No. 1: Furnish up to eight (8) additional generators for delivery during Calendar Year 2006 (or earlier) at a Fiorida Plant location to be determined. Scope includes generator units only and no paralleling switchgear. Generators shall be identical in size and configuration as unit furnished for Ft Myers Plant. FPL retains right to purchase Additive Option No. 1 at fixed price identified on Purchase Order at any time after initial Contract Award through December 31, 2006.			
Payments per attached FPL Services Negotiated Terms and Conditions for Materials Between FPL Services and Ring Power.			
3. Additive Option No. 2: Furnish up to two (2) additional generators for delivery during Calendar Year 2007 (or earlier) at Florida Plant locations to be determined. Scope includes generator units only and no paralleling switchgear. Generators shall be identical in size and configuration as unit furnished for Ft Myers Plant. FPL retains right to purchase Option No. 2 at fixed price identified on Purchase Order at any time after initial Contract Award through December 31, 2007.			
Payments per attached FPL Services Negotiated Terms and Conditions for Materials Between FPL Services and			
i de la companya de	!	l	



Page 3 of 5

# **Purchase Order**

iii≛ îi	Trendfelliven pron	Waterith Call	Professional	Part Teinic	
	Ring Power.				٦
	4. FPL retains right to make this Contract and fixed price Additive Options "assignable" to an authorized agent of FPL, such as a Sub-Contractor.  Sub-Contractor subject to Ring Power Credit approval, which will not be unreasonably withheld. Upon assignment of this Contract, Supplier shall re-negotiate a separate contract with FPL authorized agent with identical fixed price scope of supply and fixed price Additive Options as identified on FPL Purchase Order to Supplier.				
	This Purchase Document and its attachments constitute the entire agreement between the parties.				
	INSURANCE REQUIREMENTS (On-site work only) It is understood and agreed that any owner provided insurance program does NOT cover Supplier. If specifically requested by FPL, Supplier must provide proof of insurance via an ACORD form or other certificate of insurance before commencement of on-site work.				
	AUTHORIZATION FOR WORK INSTRUCTIONS This Purchase Document also serves as the Notice to Proceed and authorizes Supplier to commence work. Contact Mr. Ron Bartnick, (561) 691-7664 for exact start date and times.				
	SAFETY & ENVIRONMENTAL REQUIREMENTS The attached Safe and Secure Workplace for Suppliers (9/9/98) is hereby incorporated into this Purchase Document.				
	OUT-OF-SCOPE WORK INSTRUCTIONS Changes in the scope of this Purchase Document will be performed only upon receipt of an authorized Purchase Document Change.				
	SALES TAX INSTRUCTIONS The diesel generators qualify for a sales tax exemption under Section 212.08(5)@, Florida Statutes. In addition, all the materials utilized or installed with this equipment qualify for the exemption too. A copy of FPL's Direct Payment Authority Certificate (number TPP-0001) is attached. FPL's sales tax registration is 80-23-002234-84 (effective 7/1/02 through 6/30/07).				
Ì					



Page 4 of 5

# **Purchase Order**

			Market	ारक किल्लामिक है
	SCHEDULE OF COST Base Bid			
	Fort Myers Plant (Three (3) - Caterpillar generator units and Russelectric switchgear) \$2,150,750			
	Six (6) additional Caterpillar generator units as identified in Appendix F - \$2,227,500  Base bid includes 5 year preventative service and 5 years warrantee. Base bid only.			
	Bid Additive Option 1			
	Eight (8) additional Caterpillar generator units.  Locations to be determined. Delivery of units within 25 weeks of Contract Change Order. – \$349,000 (Each unit)			
	BID ADDITIVE OPTION 1 IS NOT INCLUCED IN THIS PURCHASE ORDER.			
	Bid Additive Option 2			
ï	Two (2) additional Caterpillar generator units. Locations to be determined. Delivery of units within 25 weeks of Contract Change Order. – \$359,000 (Each unit)			
	BID ADDITIVE OPTION 2 IS NOT INCLUCED IN THIS PURCHASE ORDER.	ļ		
	5 Year Preventative Service & Warranty for Russelectric Switchgear			ļ
	5 Year preventative service and extended warranty for Ft. Myers Plant Russelectric Switchgear. — \$80,000			
	Ground test device			
	Four (4) Electrical type ground testing devices for Ft. Myers. \$113,000			
	Grand Total This PO \$4,571,250			
	Early Termination:			



Page 5 of 5

# Purchase Order

至	Natarahitesi pilak ja	iousauser Un		August 1
	Owner may terminate the 6 generator units identified in Appendix F prior to January 31, 2005. A early termination fee of \$75,000 will apply. No provision for early termination after January 31, 2005.			
	Base Bid Delivery Dates:			
	Ft. Myers Plant-June 15, 2005			
	Six (6) additional Caterpillar generator units as identified in Appendix F -October 3, 2005			
	INVOICE INSTRUCTIONS Mail invoice to: Florida Power & Light Company 9001 Ellis Road - DAC/ML3 West Melbourne, FL 32904 ATTN: Mr. Ed Lynch			
	Altered involces will not be processed			<b>;</b>
	Attachment(s) Acknowledgment Copy			
	Conformed Specifications for FPL Black Plant Diesel Generator Systems, Rev. 5, dated November 24, 2004 FPLS Negotiated Terms and Conditions for Materials Between FPL and Ring Power dated 8/2/04 Safe and Secure Workplace for Suppliers (9/9/98) FPL's Direct Payment Authority Certificate (number TPP-0001)			
	cc: Ron Bartnick (DAC/JB)		:	
	TL/amt 12/2/04			
1	FPL Black Plant Diesel Gen \$5.700,000 Included in RFP for FPL Black Plant Dies	1 LE		
ĺ				

# Specifications for the MANATES EMERGENCY DIESEL GENERATOR

### GEN SET PACKAGE PERFORMANCE DATA [516DE1P]

### NOVEMBER 04, 2004

Performance Number: DM7047	Change Level: 00
----------------------------	------------------

Sales Model: 3516BDITA

Combustion: DI

Aspr: IA

Engine Power:

2250 W/F EKW 2310 W/O F EKW

Speed: 1,800 RPM

After Cooler: SCAC

3,210 HP

Manifold Type: DRY

Governor Type: ADEM

After Cooler Temp(F): 140

Turbo Quantity: 4

Engine App: GP

Turbo Arrangement: Parallel

Hertz: 60

**Engine Rating: PGS** 

Strategy:

Rating Type: SIANDBY

Certification: N-C 1970 - 2100

#### General Performance Data


GEN W/F EKW	PERCENT LOAD	ENGINE POWER BHP	ENGINE BMEP PSI	FUEL RATE LB/BHP- HR	FUEL RATE GPH	INTAKE MFLD TEMP DEG F	INTAKE MFLD P IN HG	INTAKE AIR FLOW CFM	EXH MFLD TEMP DEG F	EXH STACK TEMP DEG F	EXH GAS FLOW CFM
2,250.0	100	3,196.1	334	0.341	155.5	187.5	88.5	6,452.0	1,269.3	927.0	17,381 9
2,025 0	90	2,878 6	301	0.334	137.5	181 2	81.0	6,144.8	1,173.4	852.3	15,626 8
1,800.0	80	2,563.8	268	0 332	121.8	175.3	72.9	5,774.0	1,101.4	804.4	14,125.9
1,687.5	75	2,407.0	251	0 333	114.6	172 2	688	5,576.2	1,073.8	788.4	13,451.4
1,575.0	70	2,250.2	235	0.336	1079	<b>169</b> .7	64.7	5,374.9	1,051.3	775.0	12,833 4
1,350.0	60	1,938.4	203	0.342	94.6	165.4	56.4	4,937.0	1,009.2	756 5	11,597 3
1,125.0	50	1,627.7	170	0 348	<b>8</b> 0 8	160.3	45.8	4,350.8	968 0	748.2	10,184.8
900.0	40	1,323.1	138	0.355	67.1	155.3	35.4	3,771.6	927.5	740.1	8,719.2
675.0	30	1,013 9	106	0.366	53.0	151.0	25.1	3,181.9	863 4	714.7	7,165.4
562.5	25	857.7	90	0374	45.8	149.0	20.0	2,881.7	821.5	693 9	6,377.8
450.0	20	700 4	73	0 386	38 6	147 4	15.0	2,581.5	772.9	667.8	5,586.8
225.0	. 10	382 3	40	0 442	24 2	145.6	7.6	2,041_2	624 2	561 9	4,001.2

#### **Heat Rejection Data**

GEN W/F EKW	PERCENT LOAD	REJ TO JW BTU/MN	REJ TO ATMOS BTU/MN	REJ TO EXHAUST BTU/MN	EXH RCOV TO 350F BTU/MN	FROM OIL CLR BTU/MN	FROM AFT CLR BTU/MN	WORK ENERGY BTU/MN	LHV ENERGY BTU/MN	HHV ENERGY BTU/MN
2,250.0	100	47,884	9,497	127,843	70,576	16,663	34,065	135,521	333,144	354,868
2,025.0	90	43,904	8,360	110,612	57,894	14,729	29,231	122,100	294,927	314,149
1,800 0	80	40,264	7,621	97,361	48,851	13,080	24,795	108,735	261,772	278,833
1,687.5	75	38,558	7,393	91,731	45,325	12,284	22,748	102,081	246,417	262,511
1,575.0	70	36,795	7,222	86,442	42,311	11,601	20,644	95,428	231,460	246,588
1,350.0	60	33,383	6,824	76,035	36,965	10,123	16,663	82,177	201,945	215,139
1,125.0	50	29,800	6,483	65,628	31,847	8,644	12,796	69,040	172,429	183,690
900 0	40	26,103	6,085	55,391	26,956	7,222	9,156	56,131	143,426	152,809
675.0	30	22,009	5,687	44,643	21,155	5,687	5,801	42,994	113,740	121,133
562 5	25	19,791	5,516	39,070	18,028	4,891	4,265	36,397	98,612	105,039
450.0	20	17,516	5,289	33,439	14,843	4,152	2,843	29,686	83,314	88,717
225 0	10	12,511	4,777	21,440	7,677	2,616	398	16,208	51,979	55,334

## Applicability Flowchart for National Emission Standards for Hazardous Air Pollutants (NESHAP) for **Reciprocating Internal Combustion Engines (RICE)** 40 CFR part 63, subpart ZZZZ

NOTE: MACT requirements for RICE must be evaluated for individual engines Therefore, at a given facility, some engines may be subject to MACT requirements and others will not. You should apply this flowchart to each engine at your facility.




a Special non-aggregation provisions apply to oil and natural gas production and natural gas transmission and storage facilities – refer to the definitions for "Major source" and "potential to emit" in subpart ZZZZ.

b If your area source increases emissions it may become a major source, and those facilities will become subject. EPA will conduct a future rulemaking for engines located at area sources- proposal expected 10/31/06 and promulgation expected 12/20/07.

c Engines less than or equal to 500 bhp and located at major-source facilities will be addressed by EPA in a future rulemaking - proposal expected 10/31/06 and promulgation expected 12/20/07.

### **NESHAP for Existing Stationary RICE**

NOTE: This page only refers to requirements for existing stationary RICE. If your stationary RICE is new or reconstructed, refer to step 3 of this flowchart



### **NESHAP** for New or Reconstructed Stationary RICE

NOTE: This page only refers to requirements for new or reconstructed stationary RICE If your stationary RICE is existing, refer to step 2 of this flowchart.

