TerisA



RECEIVED

OCT 15 2013

DIVISION OF AIR RESOURCE MANAGEMEN

APPLICATION FOR AIR CONSTRUCTION PERMIT Module

Florida Power & Light Company **Manatee Power Plant**

Rogert NO 08 10010 -020-4C

Prepared For: Florida Power & Light Company

700 Universe Boulevard Juno Beach, FL 33408

Submitted By: Golder Associates Inc.

6026 NW 1st Place

Gainesville, FL 32607 USA

Distribution: 4 copies - FDEP

2 copies - FPL

1 copy - Golder Associates Inc.

October 2013

A world of capabilities delivered locally



133-87568B

APPLICATION FOR AIR PERMIT
LONG FORM



Department of Environmental Protection

RECEIVED

OCT 15 2013

DIVISION OF AIR RESOURCE MANAGEMENT

Division of Air Resource Management APPLICATION FOR AIR PERMIT - LONG FORM

I. APPLICATION INFORMATION

Air Construction Permit – Use this form to apply for an air construction permit:

- For any required purpose at a facility operating under a federally enforceable state air operation permit (FESOP) or Title V air operation permit;
- For a proposed project subject to prevention of significant deterioration (PSD) review, nonattainment new source review, or maximum achievable control technology (MACT);
- To assume a restriction on the potential emissions of one or more pollutants to escape a requirement such as PSD review, nonattainment new source review, MACT, or Title V; or
- To establish, revise, or renew a plantwide applicability limit (PAL).

Air Operation Permit – Use this form to apply for:

- An initial federally enforceable state air operation permit (FESOP); or
- An initial, revised, or renewal Title V air operation permit.

To ensure accuracy, please see form instructions.

Identification of Facility

	1. Facility Owner/Company Name: Florida Power & Light Company (FPL)				
2.	Site Name: Manatee Power Plant				
3.	Facility Identification Number: 0810010				
4.	Facility Location				
	Street Address or Other Locator: 19050 S	tate Road 62			
			7' 0 1 2424 222		
	City: Parrish County:	Manatee 	Zip Code: 34219-9920		
5.	Relocatable Facility?	6. Existing Titl	e V Permitted Facility?		
	☐ Yes ⊠No	⊠ Yes	□ No		
Ar	plication Contact				
1.	Application Contact Name: Kevin Washing	iton, Project Manag	ger		
2.	Application Contact Mailing Address				
	Organization/Firm: Florida Power & Light Company				
	Street Address: 700 Universe Blvd.				
	City: Juno Beach St	ate: FL	Zip Code: 33408		
3.	Application Contact Telephone Numbers				
	Telephone: (561) 691-2877 ext.	Fax: (561) 69	1-7049		
4.	4. Application Contact E-mail Address:				
Application Processing Information (DEP Use)					
1.	1. Date of Receipt of Application: 10 - 15-17 3. PSD Number (if applicable):				
	Project Number(s): AR 100 LO - 620				

Purpose of Application

This	application for air permit is being submitted to obtain: (Check one)
	Construction Permit Air construction permit. Air construction permit to establish, revise, or renew a plantwide applicability limit (PAL). Air construction permit to establish, revise, or renew a plantwide applicability limit (PAL), and separate air construction permit to authorize construction or modification of one or
Air (Operation Permit initial Title V air operation permit.
I 🗆 I	Fitle V air operation permit revision. Fitle V air operation permit renewal. Initial federally enforceable state air operation permit (FESOP) where professional engineer (PE) certification is required.
e	nitial federally enforceable state air operation permit (FESOP) where professional engineer (PE) certification is not required. Construction Permit and Revised/Renewal Title V Air Operation Permit
1	ncurrent Processing)
	Air construction permit and Title V permit revision, incorporating the proposed project. Air construction permit and Title V permit renewal, incorporating the proposed project.
	Note: By checking one of the above two boxes, you, the applicant, are requesting concurrent processing pursuant to Rule 62-213.405, F.A.C. In such case, you must also check the following box:
	☐ I hereby request that the department waive the processing time requirements of the air construction permit to accommodate the processing time frames of the Title V air operation permit.
N G	lication Comment Minor source air construction permit application to improve the performance of existing General Electric (GE) Model PG7241(7FA.03) CTs associated with Units 3A, 3B, 3C, and ED at the Manatee Power Plant with GE 7FA.04 components.

DEP Form No. 62-210.900(1) – Form Effective: 03/11/2010

Scope of Application

Emissions		Air	Air Permit
Unit ID	Description of Emissions Unit	Permit	Processing
Number		Type	Fee
005	Unit 3A - 170 MW gas turbine with supplementary-fired HRSG	AC1B	N/A
006	Unit 3B - 170 MW gas turbine with supplementary-fired HRSG	AC1B	N/A
007	Unit 3C - 170 MW gas turbine with supplementary-fired HRSG	AC1B	N/A
008	Unit 3D - 170 MW gas turbine with supplementary-fired HRSG	AC1B	N/A

Application Processing Fee	olication Processing Fee	
Check one: Attached - Amount:	Not Applicable	

3

Owner/Authorized Representative Statement

Complete if applying for an air construction permit or an initial FESOP.

- 1. Owner/Authorized Representative Name:
 - Paul Plotkin, Plant General Manager
- 2. Owner/Authorized Representative Mailing Address... Organization/Firm: Florida Power & Light Company

Street Address: 19050 SR 62

City: Parrish

State: FL

Zip Code: 34219

3. Owner/Authorized Representative Telephone Numbers...

Telephone: (941) 776-5211

ext. Fax: ()

- 4. Owner/Authorized Representative E-mail Address: pplotkin@fpl.com
- 5. Owner/Authorized Representative Statement:

I, the undersigned, am the owner or authorized representative of the corporation, partnership, or other legal entity submitting this air permit application. To the best of my knowledge, the statements made in this application are true, accurate and complete, and any estimates of emissions reported in this application are based upon reasonable techniques for calculating emissions. I understand that a permit, if granted by the department, cannot be transferred without authorization from the department.

Signature

10-11-2013

DEP Form No. 62-210.900(1) - Form Effective: 03/11/2010

/2013

Application Responsible Official Certification

Complete if applying for an initial, revised, or renewal Title V air operation permit or concurrent processing of an air construction permit and revised or renewal Title V air operation permit. If there are multiple responsible officials, the "application responsible official" need not be the "primary responsible official."

1 1
1. Application Responsible Official Name:
2. Application Responsible Official Qualification (Check one or more of the following options, as applicable):
For a corporation, the president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy or decision-making functions for the corporation, or a duly authorized representative of such person if the representative is responsible for the overall operation of one or more manufacturing, production, or operating facilities applying for or subject to a permit under Chapter 62-213, F.A.C.
For a partnership or sole proprietorship, a general partner or the proprietor, respectively.
For a municipality, county, state, federal, or other public agency, either a principal executive officer or ranking elected official.
☐ The designated representative at an Acid Rain source or CAIR source.
3. Application Responsible Official Mailing Address
Organization/Firm: Street Address:
City: State: Zip Code:
4. Application Responsible Official Telephone Numbers
Telephone: ext. Fax:
5. Application Responsible Official E-mail Address:
6. Application Responsible Official Certification:
I, the undersigned, am a responsible official of the Title V source addressed in this air permit application. I hereby certify, based on information and belief formed after reasonable inquiry, that the statements made in this application are true, accurate and complete and that, to the best of my knowledge, any estimates of emissions reported in this application are based upon reasonable techniques for calculating emissions. The air pollutant emissions units and air pollution control equipment described in this application will be operated and maintained so as to comply with all applicable standards for control of air pollutant emissions found in the statutes of the State of Florida and rules of the Department of Environmental Protection and revisions thereof and all other applicable requirements identified in this application to which the Title V source is subject. I understand that a permit, if granted by the department, cannot be transferred without authorization from the department, and I will promptly notify the department upon sale or legal transfer of the facility or any permitted emissions unit. Finally, I certify that the facility and each emissions unit are in compliance with all applicable requirements to which they are subject, except as identified in compliance plan(s) submitted with this application.
Signature Date

DEP Form No. 62-210.900(1) – Form Effective: 03/11/2010

Y:\Projects\2013\133-87568B FPL Manatee\FPL-FI.docx

/2013

Professional Engineer Certification

1.	Professional Engineer Name: Kennard F. Kosky			
	Registration Number: 14996			
2.	Professional Engineer Mailing Address			
	Organization/Firm: Golder Associates Inc.**			
	Street Address: 6026 NW 1st Place			
	City: Gainesville State: FL Zip Code: 32607			
3.	Professional Engineer Telephone Numbers			
	Telephone: (352) 336-5600 ext. 21156 Fax: (352) 336-6603			
4.	Professional Engineer E-mail Address: Ken_Kosky@golder.com			
5.	Professional Engineer Statement:			
	I, the undersigned, hereby certify, except as particularly noted herein*, that:			
	(1) To the best of my knowledge, there is reasonable assurance that the air pollutant emissions unit(s) and the air pollution control equipment described in this application for air permit, when properly operated and maintained, will comply with all applicable standards for control of air pollutant emissions found in the Florida Statutes and rules of the Department of Environmental Protection; and			
	(2) To the best of my knowledge, any emission estimates reported or relied on in this application are true, accurate, and complete and are either based upon reasonable techniques available for calculating emissions or, for emission estimates of hazardous air pollutants not regulated for an emissions unit addressed in this application, based solely upon the materials, information and calculations submitted with this application.			
	(3) If the purpose of this application is to obtain a Title V air operation permit (check here \square , if so), I further certify that each emissions unit described in this application for air permit, when properly operated and maintained, will comply with the applicable requirements identified in this application to which the unit is subject, except those emissions units for which a compliance plan and schedule is submitted with this application.			
	(4) If the purpose of this application is to obtain an air construction permit (check here \boxtimes , if so) or concurrently process and obtain an air construction permit and a Title V air operation permit revision or renewal for one or more proposed new or modified emissions units (check here \square , if so), I further certify that the engineering features of each such emissions unit described in this application have been designed or examined by me or individuals under my direct supervision and found to be in conformity with sound engineering principles applicable to the control of emissions of the air pollutants characterized in this application.			
	(5) If the purpose of this application is to obtain an initial air operation permit or operation permit revision or renewal for one or more newly constructed or modified emissions units (check here, if so), I further certify that, with the exception of any changes detailed as part of this application, each such emissions unit has been constructed or modified in substantial accordance with the information given in the corresponding application for air construction permit and with all provisions contained in such permit.			
	(seal))			

* Attachany exception to certification statement.

** Board of Professional Engineers Certificate of Authorization # 00001670

DEP Form No. 62-210-900 (18) Form

Effective: 03/11/2010 (19) 6

/2013 /2013

II. FACILITY INFORMATION

A. GENERAL FACILITY INFORMATION

Facility	Location	and Ty	vne

1. Facility UTM Coordinates Zone 17 East (km) 367.25 North (km) 3054.15		2. Facility Latitude/Longitude Latitude (DD/MM/SS) 27° 36' 21" Longitude (DD/MM/SS) 82° 20' 44"		
3. Governmental Facility Code:	4. Facility Status Code:	5. Facility Major Group SIC Code: 49	6. Facility SIC(s):	
7. Facility Comment:				

Facility Contact

1.	Facility Contact Name:				
	Mary Maxwell, Senior Environment	ntal Spec	cialist		
2.	Facility Contact Mailing Address	5			
	Organization/Firm: Florida Power	er & Ligh	t Company		
	Street Address: 19050 SR 62;	5 miles	NE of Parrish		
	City: Parrish		State: FL	Zip Code:	34219-9220
3.	Facility Contact Telephone Num	bers:			
	Telephone: (941) - 776- 5278	ext.	Fax: (941)-776-5219		
4.	Facility Contact E-mail Address:	mary.m	axwell@fpl.com		

Facility Primary Responsible Official

Complete if an "application responsible official" is identified in Section I that is not the facility "primary responsible official."

1	inty primary responsible offi		
1.	Facility Primary Responsible C	Official Name:	
2.	Facility Primary Responsible C	Official Mailing Address	
	Organization/Firm:	5	
	Street Address:		
	City:	State:	Zip Code:
3.	Facility Primary Responsible C	Official Telephone Numbers	
	Telephone: () - ext.	Fax: () -	
4.	Facility Primary Responsible C	Official E-mail Address:	

DEP Form No. 62-210.900(1) – Form

Effective: 03/11/2010

/2013

Facility Regulatory Classifications

Check all that would apply *following* completion of all projects and implementation of all other changes proposed in this application for air permit. Refer to instructions to distinguish between a "major source" and a "synthetic minor source."

1. ☐ Small Business Stationary Source ☐ Unknown
2. Synthetic Non-Title V Source
3. ⊠ Title V Source
4. Major Source of Air Pollutants, Other than Hazardous Air Pollutants (HAPs)
5. Synthetic Minor Source of Air Pollutants, Other than HAPs
6. Major Source of Hazardous Air Pollutants (HAPs)
7. Synthetic Minor Source of HAPs
8. ☑ One or More Emissions Units Subject to NSPS (40 CFR Part 60)
9. One or More Emissions Units Subject to Emission Guidelines (40 CFR Part 60)
10. ⊠One or More Emissions Units Subject to NESHAP (40 CFR Part 61 or Part 63)
11. Title V Source Solely by EPA Designation (40 CFR 70.3(a)(5))
12. Facility Regulatory Classifications Comment:

DEP Form No. 62-210.900(1) – Form Effective: 03/11/2010

/2013

List of Pollutants Emitted by Facility

1. Pollutant Emitted	2. Pollutant Classification	3. Emissions Cap [Y or N]?
PM/PM10	Α	N N
СО	A	N
VOC	A	N
SO2	Α	N
NOx	Α	N
HAPS	A	N
Pb	В	N
SAM	A	N

B. EMISSIONS CAPS

Facility-Wide or Multi-Unit Emissions Caps

1. Pollutant Subject to Emissions	2. Facility- Wide Cap [Y or N]?	3. Emissions Unit ID's Under Cap	4. Hourly Cap (lb/hr)	5. Annual Cap (ton/yr)	6. Basis for Emissions Cap
Cap	(all units)	(if not all units)			
		_			
					_
7. Facility-Wi	7. Facility-Wide or Multi-Unit Emissions Cap Comment:				

C. FACILITY ADDITIONAL INFORMATION

Additional Requirements for All Applications, Except as Otherwise Stated

1.	Facility Plot Plan: (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought) Attached, Document ID: \omega Previously Submitted, Date: July 2008
2.	Process Flow Diagram(s): (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought) Attached, Document ID: Previously Submitted, Date: July 2008
3.	Precautions to Prevent Emissions of Unconfined Particulate Matter: (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought) Attached, Document ID: Previously Submitted, Date: July 2008
Ac	Iditional Requirements for Air Construction Permit Applications
1.	Area Map Showing Facility Location: ☐ Attached, Document ID: ☐ Not Applicable (existing permitted facility)
2.	Description of Proposed Construction, Modification, or Plantwide Applicability Limit (PAL): Attached, Document ID: Part II
3.	Rule Applicability Analysis:
4.	List of Exempt Emissions Units: ☐ Attached, Document ID: ☐ Not Applicable (no exempt units at facility)
5.	Fugitive Emissions Identification: ☐ Attached, Document ID: ☐ Not Applicable
6.	Air Quality Analysis (Rule 62-212.400(7), F.A.C.): ☐ Attached, Document ID: Not Applicable
	Source Impact Analysis (Rule 62-212.400(5), F.A.C.): ☐ Attached, Document ID: ☐ Not Applicable
8.	Air Quality Impact since 1977 (Rule 62-212.400(4)(e), F.A.C.): ☐ Attached, Document ID: ☐ Not Applicable
9.	Additional Impact Analyses (Rules 62-212.400(8) and 62-212.500(4)(e), F.A.C.): ☐ Attached, Document ID: ☐ Not Applicable
10.	. Alternative Analysis Requirement (Rule 62-212.500(4)(g), F.A.C.): ☐ Attached, Document ID: ☐ Not Applicable

DEP Form No. 62-210.900(1) - Form

Y:\Projects\2013\133-87568B FPL Manatee\FPL-Fl.docx Effective: 03/11/2010 11 10/2013

/2013

C. FACILITY ADDITIONAL INFORMATION (CONTINUED)

Additional Requirements for FESOP Applications -- NA

1.	List of Exempt Emissions Units: Attached, Document ID: Not Applicable (no exempt units at facility)
<u>A</u> (Iditional Requirements for Title V Air Operation Permit Applications NA
1.	List of Insignificant Activities: (Required for initial/renewal applications only) Attached, Document ID: Not Applicable (revision application)
2.	Identification of Applicable Requirements: (Required for initial/renewal applications, and for revision applications if this information would be changed as a result of the revision being sought) Attached, Document ID:
	☐ Not Applicable (revision application with no change in applicable requirements)
3.	Compliance Report and Plan: (Required for all initial/revision/renewal applications) Attached, Document ID:
	Note: A compliance plan must be submitted for each emissions unit that is not in compliance with all applicable requirements at the time of application and/or at any time during application processing. The department must be notified of any changes in compliance status during application processing.
4.	List of Equipment/Activities Regulated under Title VI: (If applicable, required for initial/renewal applications only) Attached, Document ID:
	☐ Equipment/Activities Onsite but Not Required to be Individually Listed ☐ Not Applicable
5.	Verification of Risk Management Plan Submission to EPA: (If applicable, required for initial/renewal applications only) Attached, Document ID:
6.	Requested Changes to Current Title V Air Operation Permit: Attached, Document ID:

12

C. FACILITY ADDITIONAL INFORMATION (CONTINUED)

Additional Requirements for Facilities Subject to Acid Rain, CAIR, or Hg Budget Program

		_
1.	Acid Rain Program Forms:	
	Acid Rain Part Application (DEP Form No. 62-210.900(1)(a)):	
	☐ Attached, Document ID: ☐ ☐ Previously Submitted, Date: May 2013	
	☐ Not Applicable (not an Acid Rain source)	
	Phase II NO _X Averaging Plan (DEP Form No. 62-210.900(1)(a)1.):	
	☐ Attached, Document ID: ☐ Previously Submitted, Date:	
	Not Applicable ■	
	New Unit Exemption (DEP Form No. 62-210.900(1)(a)2.):	
	☐ Attached, Document ID: ☐ Previously Submitted, Date:	
	☑ Not Applicable	
2.	CAIR Part (DEP Form No. 62-210.900(1)(b)):	
	☐ Attached, Document ID: ☐ Previously Submitted, Date: May 2013	
	☐ Not Applicable (not a CAIR source)	
		_
<u>A</u> (dditional Requirements Comment	
		7
	· ·	
		- 1

13

Section [1] Units 3A, 3B, 3C, and 3D Gas Turbines

III. EMISSIONS UNIT INFORMATION

Title V Air Operation Permit Application - For Title V air operation permitting only, emissions units are classified as regulated, unregulated, or insignificant. If this is an application for an initial, revised or renewal Title V air operation permit, a separate Emissions Unit Information Section (including subsections A through I as required) must be completed for each regulated and unregulated emissions unit addressed in this application. Some of the subsections comprising the Emissions Unit Information Section of the form are optional for unregulated emissions units. Each such subsection is appropriately marked. Insignificant emissions units are required to be listed at Section II, Subsection C.

Air Construction Permit or FESOP Application - For air construction permitting or federally enforceable state air operation permitting, emissions units are classified as either subject to air permitting or exempt from air permitting. The concept of an "unregulated emissions unit" does not apply. If this is an application for an air construction permit or FESOP, a separate Emissions Unit Information Section (including subsections A through I as required) must be completed for each emissions unit subject to air permitting addressed in this application for air permit. Emissions units exempt from air permitting are required to be listed at Section II, Subsection C.

Air Construction Permit and Revised/Renewal Title V Air Operation Permit Application – Where this application is used to apply for both an air construction permit and a revised or renewal Title V air operation permit, each emissions unit is classified as either subject to air permitting or exempt from air permitting for air construction permitting purposes, and as regulated, unregulated, or insignificant for Title V air operation permitting purposes. A separate Emissions Unit Information Section (including subsections A through I as required) must be completed for each emissions unit addressed in this application that is subject to air construction permitting and for each such emissions unit that is a regulated or unregulated unit for purposes of Title V permitting. (An emissions unit may be exempt from air construction permitting but still be classified as an unregulated unit for Title V purposes.) Emissions units classified as insignificant for Title V purposes are required to be listed at Section II, Subsection C.

If submitting the application form in hard copy, the number of this Emissions Unit Information Section and the total number of Emissions Unit Information Sections submitted as part of this application must be indicated in the space provided at the top of each page.

DEP Form No. 62-210.900(1) – Form Effective: 03/11/2010

Y:\Projects\2013\133-87568B FPL Manatee\FPL-EU1 kfk.docx 10/2013

Section [1]

Units 3A, 3B, 3C, and 3D Gas Turbines

A. GENERAL EMISSIONS UNIT INFORMATION

<u>Title V</u> <u>Air Operation Permit Emissions Unit Classification</u>

	•	gulated Emissions Unit? air operation permit. Sl only.)				
	 ☑ The emissions unit addressed in this Emissions Unit Information Section is a regulated emissions unit. ☑ The emissions unit addressed in this Emissions Unit Information Section is an unregulated emissions unit. 					
Em	issions Unit Descr	ription and Status				
1.	Type of Emissions □ This Emissions single process pollutants and □ This Emissions of process or point (stack or	s Unit Addressed in this s Unit Information Section production unit, or act which has at least one dos Unit Information Section units and activation but may also production Unit Information Section Unit Information	on addresses, as a single tivity, which produces of efinable emission point on addresses, as a single vities which has at least uce fugitive emissions.	one or more air (stack or vent). e emissions unit, a group one definable emission		
	Description of Em	issions Unit Addressed i	n this Section:			
		entification Number: 06 (Unit 3B), EU 007 (Uni	t 3C), EU 008 (Unit 3D)			
4.	Emissions Unit Status Code:	5. Commence Construction Date:	6. Initial Startup Date:	7. Emissions Unit Major Group SIC Code: 49		
ı	Federal Program A Acid Rain Unit	applicability: (Check all CAIR Unit	that apply)			
1						
\vdash	Generator Namepl					
	turbine-electrical (generator with a to	cycle system will consist generator sets and one tal nominal capacity of 1 s: 10-Dec-04 (Unit 3A), 1	nominal 470 MW stea ,150 MW fired only with	am turbine-electrical natural gas.		

DEP Form No. 62-210.900(1) - Form

Section [1]

Units 3A, 3B, 3C, and 3D Gas Turbines

Emissions Unit Control Equipment/Method: Control 1 of 2

1. Control Equipment/Method Description:

Low NOx Burners - Dry low-NOx combustors

2. Control Device or Method Code: 205

Emissions Unit Control Equipment/Method: Control 2 of 2

1. Control Equipment/Method Description:

SCR (Selective Catalytic Reduction) - SCR system to reduce NOx emissions

2. Control Device or Method Code: 139

Emissions Unit Control Equipment/Method: Control of

1. Control Equipment/Method Description:

2. Control Device or Method Code:

Section [1] Units 3A, 3B, 3C, and 3D Gas Turbines

B. EMISSIONS UNIT CAPACITY INFORMATION

(Optional for unregulated emissions units.)

Emissions Unit Operating Capacity and Schedule

1.	Maximum	Process or	Throughput Rate:

2. Maximum Production Rate:

Nominal power output for the combined-cycle unit - 1,150 MW

3. Maximum Heat Input Rate: 6,400 MMBtu/hr (LHV)

4. Maximum Incineration Rate: pounds/hr

tons/day

5. Requested Maximum Operating Schedule:

24 hours/day

7 days/week

52 weeks/year

8,760 hours/year

6. Operating Capacity/Schedule Comment:

Maximum heat input and power outputs are for the 4-on-1 combined cycle system based on 59 °F ambient temperature.

Nominal power outputs for each turbine - 170 MW

Maximum heat input rate for each turbine: 1,600 MMBtu/hr/LHV)

HRSG duct burners have heat input of 495 MMBtu/hr (LHV)

DEP Form No. 62-210.900(1) – Form Effective: 03/11/2010

 $\begin{tabular}{ll} $\text{Y:Projects} \ 2013 \ 133-87568B FPL Manatee \ FPL-EU1 kfk.docx \\ 10/2013 \end{tabular}$

Section [1] Units 3A, 3B, 3C, and 3D Gas Turbines

C. EMISSION POINT (STACK/VENT) INFORMATION

(Optional for unregulated emissions units.)

Emission Point Description and Type

Identification of Point on Plot Plan or Flow Diagram: 3A-3D HRSG STACK		2. Emission Point 7	Гуре Code:	
Descriptions of Emission ID Numbers or Description				
5. Discharge Type Code:	6. Stack Height		7. Exit Diameter:	
V	120 feet	•	19 feet	
8. Exit Temperature: 202°F	9. Actual Volumetric Flow Rate: 1,004,200 acfm		10. Water Vapor:	
11. Maximum Dry Standard F Dscfm	low Rate:	12. Nonstack Emission Point Height: feet		
13. Emission Point UTM Coo Zone: East (km):		14. Emission Point Latitude/Longitude Latitude (DD/MM/SS)		
North (km) 15. Emission Point Comment:		Longitude (DD/MM/SS)		
Stack parameters (comb application dated May 2013	ined-cycle opera	ition) based on Tit	le V permit renewal	

Section [1]

Units 3A, 3B, 3C, and 3D Gas Turbines

D. SEGMENT (PROCESS/FUEL) INFORMATION

Internal Combustion Engines; Electric Generation; Natural Gas Turbine

<u>Segment Description and Rate:</u> Segment <u>1</u> of <u>1</u>

1. Segment Description (Process/Fuel Type):

2.	2. Source Classification Code (SCC): 2-01-002-01		3. SCC Units Million cub	: ic feet burned
4.	Maximum Hourly Rate: 7.10	5. Maximum 62,196	Annual Rate:	6. Estimated Annual Activity Factor:
7.	Maximum % Sulfur:	8. Maximum	% Ash:	9. Million Btu per SCC Unit: 1,000 (HHV)
10	. Segment Comment:		•	
	COMBUSTION TURBINES:	:		
	Hourly rate = 1,600 MMBtu = 7.10 MMft ³ /hr Annual rate = 7.10 x 10 ⁶ ft ³ Note: Does not include du total heat input limit of 5,7	/hr x 8,760 hrs/yr	= 62,196 MMft ³ /y	of 495 MMBtu/hr (LHV) and
Se	gment Description and Ra	ate: Segment_c	of _	3333.
1.	Segment Description (Pro	cess/Fuel Type):		
2.	Source Classification Cod	e (SCC):	3. SCC Units	:
4.	Maximum Hourly Rate:	5. Maximum	Annual Rate:	6. Estimated Annual Activity Factor:
7.	Maximum % Sulfur:	8. Maximum	% Ash:	9. Million Btu per SCC Unit:
10.	Segment Comment:	,		

Section [1] Units 3A, 3B, 3C, and 3D Gas Turbines

E. EMISSIONS UNIT POLLUTANTS

List of Pollutants Emitted by Emissions Unit

	1		
1. Pollutant Emitted	2. Primary Control	3. Secondary Control	4. Pollutant
	Device Code	Device Code	Regulatory Code
NOx	205, 139		EL
СО			EL
PM/PM ₁₀			WP
VOC		·	EL
SO ₂			WP
NH ₃			EL

Section [1] Units 3A, 3B, 3C, and 3D Gas Turbines

POLLUTANT DETAIL INFORMATION Page [1] of [6] Nitrogen Oxide - NO_x

F1. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION – POTENTIAL/ESTIMATED FUGITIVE EMISSIONS

(Optional for unregulated emissions units.)

Complete a Subsection F1 for each pollutant identified in Subsection E if applying for an air construction permit or concurrent processing of an air construction permit and a revised or renewal Title V operation permit. Complete for each emissions-limited pollutant identified in Subsection E if applying for an air operation permit.

Potential, Estimated Fugitive and Baseline & Projected Actual Emissions 1. Pollutant Emitted: 2. Total Percent Efficiency of Control: NOx 4. Synthetically Limited? 3. Potential Emissions ☐ Yes \square No lb/hour tons/year Range of Estimated Fugitive Emissions (as applicable): to tons/year **Emission Factor: Emissions** Method Code: Reference: 8.b. Baseline 24-month Period: 8.a. Baseline Actual Emissions (if required): 247.85 tons/year From: 1/1/2008 To: 12/31/2009 9.a. Projected Actual Emissions (if required): 9.b. Projected Monitoring Period: 253.86 \boxtimes 5 years \square 10 years tons/year 10. Calculation of Emissions: See Table 9 of Part II. 11. Potential, Fugitive, and Actual Emissions Comment:

Section [1] Units 3A, 3B, 3C, and 3D Gas Turbines

POLLUTANT DETAIL INFORMATION Page [1] of [6] Nitrogen Oxide – NO_x

F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION - ALLOWABLE EMISSIONS

Complete Subsection F2 if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.

Allowable Emissions 1 of 6

1.	Basis for Allowable Emissions Code: RULE	2.	Future Effective Date of Allowable Emissions:
3.	Allowable Emissions and Units: 9.0 ppmvd @ 15% O₂	4.	Equivalent Allowable Emissions: 58.7 lb/hour tons/year
5.	Method of Compliance: CEMS (24-hr Block Average) or Stack test (3-i	run a	average) using EPA Method 7E or 20
6.	CEMS (24-hr Block Average) or Stack test (3-run average) using EPA Method 7E or 20 Allowable Emissions Comment (Description of Operating Method): Based on simple-cycle operation at 100% load and 59 F. Equivalent allowable emissions rates are for each turbine Based on PSD-FL-328 and Permit No. 0810010-019-AV.		

Allowable Emissions 2 of 6

1.	Basis for Allowable Emissions Code: RULE	2.	Future Effective Date of All Emissions:	owable
3.	Allowable Emissions and Units: 12.0 ppmvd @ 15% O ₂	4.	Equivalent Allowable Emiss 76.2 lb/hour to	sions: ns/year
5.	Method of Compliance: CEMS (24-hr Block Average) or Stack test (3-	run	everage) using EPA Method 7	E or 20
6.	Allowable Emissions Comment (Description Based on simple-cycle operation at Power Au Equivalent emissions rates are for each turbing Based on PSD-FL-328 and Permit No. 081001	ıgm ne.	entation mode at 100% load ar	nd 59 F.

Allowable Emissions 3 of 6

1.	Basis for Allowable Emissions Code: RULE	2.	Future Effective Date of Allowable Emissions:		
3.	Allowable Emissions and Units: 15.0 ppmvd @ 15% O ₂	4.	Equivalent Allowable Emissions: 95.3 lb/hour tons/year		
5.	Method of Compliance:				
	CEMS (24-hr Block Average) or Stack test (3-	run a	iverage) using EPA Method 7E or 20		
6.	. Allowable Emissions Comment (Description of Operating Method):				
	Based on simple-cycle operation at Peaking Mode at 100% load and 59 F.				
l					
ı	Equivalent emissions rates are for each turbi-				
	Equivalent emissions rates are for each turbing Based on PSD-FL-328 and Permit No. 081001				

Section [1] Units 3A, 3B, 3C, and 3D Gas Turbines

POLLUTANT DETAIL INFORMATION

Page [1] of [6] Nitrogen Oxide - NO_x

F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION - ALLOWABLE EMISSIONS

Complete Subsection F2 if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.

Allowable Emissions Allowable Emissions 4 of 6

1.	Basis for Allowable Emissions Code: OTHER	2.	Future Effective Date of Allowable Emissions:
3.	Allowable Emissions and Units: 2.5 ppmvd @ 15% O ₂	4.	Equivalent Allowable Emissions: 16.3 lb/hour tons/year
5.	Method of Compliance: CEMS (24-hr Block Average) or Stack test (3-hr)	run a	average) using EPA Method 7E or 20
6.	Allowable Emissions Comment (Description of Operating Method): Based on combined-cycle operation with SCR control at 100% load and 59 F. Equivalent emissions rates are based on post turbine improvement (GE data) and for each turbine. Based on PSD-FL-328 and Permit No. 0810010-019-AV.		

Allowable Emissions 5 of 6

Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:		
3. Allowable Emissions and Units: 2.5 ppmvd @ 15% O ₂	4. Equivalent Allowable Emissions: 23.6 lb/hour tons/year		
5. Method of Compliance: CEMS (24-hr Block Average) or Stack test (3-run average) using EPA Method 7E or 20			
6. Allowable Emissions Comment (Description of Operating Method): Based on combined-cycle operation with SCR control and duct firing at 100% load and 59°F. Equivalent emissions rates are for each turbine. Duct burner emission rate = (23.6-16.3) lb/hr (Permit No. 0810010-014-AV) = 7.3 lb/hr Rate after turbine improvement = 16.8 lb/hr (GE data) + 7.3 lb/hr = 24.1 lb/hr CT with SCR control at all modes limited to 2.5 ppmvd @ 15% O ₂ Based on PSD-FL-338 and Permit No. 0810010-019-AV.			

Allowable Emissions Allowable Emissions 6 of 6

1.	Basis for Allowable Emissions Code: OTHER	2. Future Effective Date of Allowable Emissions:	
3.	Allowable Emissions and Units: 2.5 ppmvd @ 15% O ₂	4. Equivalent Allowable Emissions: 16.8 lb/hour tons/year	
5.	Method of Compliance:		
	Stack test (3-run average) using EPA Method	7E or 20	
6.	Allowable Emissions Comment (Description of Operating Method):		
	Based on combined-cycle operation at 100% load and 59°F.		
	Equivalent emissions rates are based on post turbine improvement = 16.8 lb/hr (GE data) and for each turbine. Based on PSD-FL-338 and Permit No. 0810010-019-AV.		

Section [1] Units 3A, 3B, 3C, and 3D Gas Turbines

POLLUTANT DETAIL INFORMATION

Page [2] of [6] Carbon Monoxide – CO

F1. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION – POTENTIAL/ESTIMATED FUGITIVE EMISSIONS

(Optional for unregulated emissions units.)

Complete a Subsection F1 for each pollutant identified in Subsection E if applying for an air construction permit or concurrent processing of an air construction permit and a revised or renewal Title V operation permit. Complete for each emissions-limited pollutant identified in Subsection E if applying for an air operation permit.

Potential, Estimated Fugitive and Baseline & Projected Actual Emissions Pollutant Emitted: 2. Total Percent Efficiency of Control: CO 4. Synthetically Limited? 3. Potential Emissions ☐ Yes □ No lb/hour tons/year Range of Estimated Fugitive Emissions (as applicable): to tons/year Emission Factor: 7. Emissions Reference: Method Code: 8.a. Baseline Actual Emissions (if required): 8.b. Baseline 24-month Period: 30.31 tons/year From: 1/1/2008 To: 12/31/2009 9.a. Projected Actual Emissions (if required): 9.b. Projected Monitoring Period: \boxtimes 5 years \square 10 years 31.14 tons/year 10. Calculation of Emissions: See Table 9 of Part II. 11. Potential, Fugitive, and Actual Emissions Comment:

Section [1] Units 3A, 3B, 3C, and 3D Gas Turbines

POLLUTANT DETAIL INFORMATION

Page [2] of [6] Carbon Monoxide – CO

F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION - ALLOWABLE EMISSIONS

Complete Subsection F2 if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.

Allowable Emissions 1 of 3

1.	Basis for Allowable Emissions Code: RULE	2.	Future Effective Date Emissions:	te of Allow	able
3.	Allowable Emissions and Units:	4.	Equivalent Allowab		
	7.4 ppmvd @ 15% O ₂		27.5 lb/hour	tons/	year
5.	Method of Compliance: Stack test (3-hr average) using EPA Method 10				
6.	Allowable Emissions Comment (Description of Operating Method): Based on gas-firing simple cycle or combined-cycle normal operation at 100% load and 59 °F. Equivalent emissions rates are for each turbine. Based on PSD-FL-328 and Permit No. 0810010-019-AV.				

Allowable Emissions Allowable Emissions 2 of 3

1.	Basis for Allowable Emissions Code: RULE	2.	Future Effective Date of Allowable Emissions:
3.	Allowable Emissions and Units: 12.0 ppmvd @ 15% O₂	4.	Equivalent Allowable Emissions: 45.0 lb/hour tons/year
5.	Method of Compliance: Stack test (3-hr average) using EPA Method	10 o	r CEMS (24-hr Block Average)
6.	Allowable Emissions Comment (Description of Operating Method): Based on natural gas-firing simple-cycle operation at Power Augmentation mode at 100% load and 59 °F. Equivalent emissions rates are for each turbine. Based on PSD-FL-328 and Permit No. 0810010-019-AV.		

Allowable Emissions 3 of 3

1.	Basis for Allowable Emissions Code: RULE	2.	Future Effective Da Emissions:	ate of Allowable
3.	Allowable Emissions and Units:	4.	Equivalent Allowa	ble Emissions:
	10.0 ppmvd @ 15% O₂		lb/hour	tons/year
5.	Method of Compliance: CEMS (24-hr Block Average)			
6.	Allowable Emissions Comment (Description of Operating Method): Based on natural Gas-firing combined-cycle normal operation at all modes at 100% load and 59 °F.			
	Equivalent emissions rates are for each turbine.			

Section [1] Units 3A, 3B, 3C, and 3D Gas Turbines

POLLUTANT DETAIL INFORMATION

Page [3] of [6] Volatile Organic Compounds-VOC

F1. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION – POTENTIAL/ESTIMATED FUGITIVE EMISSIONS

(Optional for unregulated emissions units.)

Complete a Subsection F1 for each pollutant identified in Subsection E if applying for an air construction permit or concurrent processing of an air construction permit and a revised or renewal Title V operation permit. Complete for each emissions-limited pollutant identified in Subsection E if applying for an air operation permit.

Potential, Estimated Fugitive and Baseline & Projected Actual Emissions Pollutant Emitted: 2. Total Percent Efficiency of Control: VOC 4. Synthetically Limited? 3. Potential Emissions ☐ Yes □ No lb/hour tons/year Range of Estimated Fugitive Emissions (as applicable): to tons/year Emission Factor: 7. Emissions Reference: Method Code: 8.a. Baseline Actual Emissions (if required): 8.b. Baseline 24-month Period: From: 1/1/2008 To: 12/31/2009 22.18 tons/year 9.a. Projected Actual Emissions (if required): 9.b. Projected Monitoring Period: S years □ 10 years 22.71 tons/year 10. Calculation of Emissions: See Table 9 of Part II. 11. Potential, Fugitive, and Actual Emissions Comment:

Section [1] Units 3A, 3B, 3C, and 3D Gas Turbines

POLLUTANT DETAIL INFORMATION Page [3] of [6] Volatile Organic Compounds-VOC

F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION - ALLOWABLE EMISSIONS

Complete Subsection F2 if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.

Allowable Emissions 1 of 2

1.	Basis for Allowable Emissions Code: OTHER	2.	Future Effective Date of Allowable Emissions:
3.	Allowable Emissions and Units:	4.	Equivalent Allowable Emissions:
	1.3 ppmvd @ 15% O ₂		2.8 lb/hour tons/year
5.	Method of Compliance:		
	Stack test using EPA Methods 25A or 18 (3-ru	ın av	verage)
6.	Allowable Emissions Comment (Description	of (Operating Method):
	Based on simple or combined-cycle normal operation		
	Equivalent emissions rates are for each turbine.		
	Based on PSD-FL-328 and Permit No. 0810010	0-019	9-AV.

Allowable Emissions Allowable Emissions 2 of 2

1.	Basis for Allowable Emissions Code: OTHER	2.	Future Effective Date of Allowable Emissions:
3.	Allowable Emissions and Units: 4.0 ppmvd @ 15% O2	4.	Equivalent Allowable Emissions: 10.5 lb/hour tons/year
5.	Method of Compliance:		
	Stack test using EPA Methods 25A or 18 (3-re	un a	verage)
6.	6. Allowable Emissions Comment (Description of Operating Method): Based on combined-cycle with duct firing and/or Peak Augmentation mode. Equivalent emissions rates are for each turbine. Based on PSD-FL-328 and Permit No. 0810010-019-AV.		

Allowable Emissions _ of _

1.	Basis for Allowable Emissions Code:	2.	Future Effective Date of Allowable Emissions:	
3.	Allowable Emissions and Units:	4.	Equivalent Allowable Emissions: lb/hour tons/year	
5.	Method of Compliance:			
6.	6. Allowable Emissions Comment (Description of Operating Method):			

Section [1] Units 3A, 3B, 3C, and 3D Gas Turbines

POLLUTANT DETAIL INFORMATION

Page [4] of [6] Particulate Matter-PM/PM10

F1. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION – POTENTIAL/ESTIMATED FUGITIVE EMISSIONS

(Optional for unregulated emissions units.)

Complete a Subsection F1 for each pollutant identified in Subsection E if applying for an air construction permit or concurrent processing of an air construction permit and a revised or renewal Title V operation permit. Complete for each emissions-limited pollutant identified in Subsection E if applying for an air operation permit.

Potential, Estimated Fugitive and Baseline & Projected Actual Emissions Pollutant Emitted: 2. Total Percent Efficiency of Control: PM/PM10 4. Synthetically Limited? Potential Emissions 3. ☐ Yes ☐ No 1b/hour tons/year Range of Estimated Fugitive Emissions (as applicable): to tons/year **Emission Factor:** 7. Emissions Method Code: Reference: 8.b. Baseline 24-month Period: 8.a. Baseline Actual Emissions (if required): From: 1/1/2008 0.16 To: 12/31/2009 tons/year 9.a. Projected Actual Emissions (if required): 9.b. Projected Monitoring Period: \boxtimes 5 years \square 10 years 0.17 tons/year 10. Calculation of Emissions: See Table 9 of Part II. 11. Potential, Fugitive, and Actual Emissions Comment:

EMISSIONS UNIT INFORMATION Section [1] Units 3A, 3B, 3C, and 3D Gas Turbines

POLLUTANT DETAIL INFORMATION Page [4] of [6]

PM/PM10

F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION - ALLOWABLE EMISSIONS

Complete Subsection F2 if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.

Allowable Emissions 1 of 1

1.	Basis for Allowable Emissions Code: OTHER	2.	Future Effective Date of Allowable Emissions:
3.	Allowable Emissions and Units: ≤ 10% Opacity	4.	Equivalent Allowable Emissions: lb/hour tons/year
5.	Method of Compliance: EPA Method 9		
6.	Allowable Emissions Comment (Description of Operating Method): Based on simple or combined-cycle operation on a 6-minute block average. Emissions rates are for each turbine. Based on PSD-FL-328 and Permit No. 0810010-019-AV.		

Allowable Emissions _ of _

1.	Basis for Allowable Emissions Code:	2.	Future Effective Date of Allowable Emissions:
3.	Allowable Emissions and Units:	4.	Equivalent Allowable Emissions:
			lb/hour tons/year
5.	Method of Compliance:		
6.	Allowable Emissions Comment (Description	of (Operating Method):

Allowable Emissions _ of _

1. Basis for Allowable Emissions Code:	2. Future Effective Date of Allowable Emissions:	
3. Allowable Emissions and Units:	4. Equivalent Allowable Emissions: lb/hour tons/year	
5. Method of Compliance:		
6. Allowable Emissions Comment (Description of Operating Method):		

EMISSIONS UNIT INFORMATION Section [1] Units 3A, 3B, 3C, and 3D Gas Turbines

POLLUTANT DETAIL INFORMATION

Page [5] of [6]

Sulfur Dioxide – SO₂

F1. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION – POTENTIAL/ESTIMATED FUGITIVE EMISSIONS

(Optional for unregulated emissions units.)

Complete a Subsection F1 for each pollutant identified in Subsection E if applying for an air construction permit or concurrent processing of an air construction permit and a revised or renewal Title V operation permit. Complete for each emissions-limited pollutant identified in Subsection E if applying for an air operation permit.

Potential, Estimated Fugitive and Baseline & Projected Actual Emissions Pollutant Emitted: 2. Total Percent Efficiency of Control: **SO2** 4. Synthetically Limited? 3. Potential Emissions ☐ Yes \square No lb/hour tons/year Range of Estimated Fugitive Emissions (as applicable): to tons/year **Emission Factor: Emissions** Reference: Method Code: 8.a. Baseline Actual Emissions (if required): 8.b. Baseline 24-month Period: 14.70 tons/year From: 1/1/2008 To: 12/31/2009 9.a. Projected Actual Emissions (if required): 9.b. Projected Monitoring Period: \boxtimes 5 years \square 10 years 15.05 tons/year 10. Calculation of Emissions: See Table 9 of Part II. 11. Potential, Fugitive, and Actual Emissions Comment:

Section [1] Units 3A, 3B, 3C, and 3D Gas Turbines

POLLUTANT DETAIL INFORMATION Page [5] of

Sulfur Dioxide - SO2

F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION -**ALLOWABLE EMISSIONS**

Complete Subsection F2 if the pollutant identified in Subsection F1 is or would be subject

to a numerical emissions limitation. Allowable Emissions 1 of 1					
1.	Basis for Allowable Emissions Code: OTHER	2.	Future Effective Date of Allowable Emissions:		
3.	Allowable Emissions and Units: 2 gr S/100 scf	4.	Equivalent Allowable Emissions: lb/hour tons/year		
5.	Method of Compliance: Fuel Analysis	_			
6.	Allowable Emissions Comment (Description of Operating Method): Based on simple or combined cycle mode of operation Based on PSD-FL-328 and Permit No. 0810010-019-AV.				
Allowable Emissions _ of _					
1.	Basis for Allowable Emissions Code:	2.	Future Effective Date of Allowable Emissions:		
3.	Allowable Emissions and Units:	4.	Equivalent Allowable Emissions: lb/hour tons/year		
5.	Method of Compliance:				
6.	6. Allowable Emissions Comment (Description of Operating Method):				
Allowable Emissions Allowable Emissions of_					
1.	Basis for Allowable Emissions Code:	2.	Future Effective Date of Allowable Emissions:		
3.	Allowable Emissions and Units:	4.	Equivalent Allowable Emissions: lb/hour tons/year		
5.	Method of Compliance:				
6.	Allowable Emissions Comment (Description	of (Operating Method):		

Section [1]
Units 3A, 3B, 3C, and 3D Gas Turbines

POLLUTANT DETAIL INFORMATION Page [6] of [6] Ammonia – NH₃

F1. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION – POTENTIAL/ESTIMATED FUGITIVE EMISSIONS

(Optional for unregulated emissions units.)

Complete a Subsection F1 for each pollutant identified in Subsection E if applying for an air construction permit or concurrent processing of an air construction permit and a revised or renewal Title V operation permit. Complete for each emissions-limited pollutant identified in Subsection E if applying for an air operation permit.

Potential, Estimated Fugitive and Baseline & Projected Actual Emissions Pollutant Emitted: 2. Total Percent Efficiency of Control: Ammonia - NH3 4. Synthetically Limited? 3. Potential Emissions ☐ Yes \square No lb/hour tons/year Range of Estimated Fugitive Emissions (as applicable): to tons/year **Emission Factor: Emissions** Method Code: Reference: 8.b. Baseline 24-month Period: 8.a. Baseline Actual Emissions (if required): tons/year From: To: 9.b. Projected Monitoring Period: 9.a. Projected Actual Emissions (if required): tons/year \square 5 years \square 10 years 10. Calculation of Emissions: 11. Potential, Fugitive, and Actual Emissions Comment:

Section [1] Units 3A, 3B, 3C, and 3D Gas Turbines

POLLUTANT DETAIL INFORMATION Page [6] of [6]

Ammonia - NH3

F2. EMISSIONS UNIT POLLUTANT DETAIL INFORMATION - ALLOWABLE EMISSIONS

Complete Subsection F2 if the pollutant identified in Subsection F1 is or would be subject to a numerical emissions limitation.

Allowable Emissions Allowable Emissions 1 of 1

1.	Basis for Allowable Emissions Code: OTHER	2.	Future Effective Date of Allowable Emissions:		
3.	Allowable Emissions and Units: 5 ppmvd @ 15% O2	4.	Equivalent Allowable Emissions: lb/hour tons/year		
5.	Method of Compliance: Stack test using EPA Method CTC-027				
6.	Allowable Emissions Comment (Description Based on Combined cycle operation with SCI				
Allowable Emissions _ of _					
1.	Basis for Allowable Emissions Code:	2.	Future Effective Date of Allowable Emissions:		
3.	Allowable Emissions and Units:	4.	Equivalent Allowable Emissions: lb/hour tons/year		
5.	Method of Compliance:				
6.	Allowable Emissions Comment (Description	of (Operating Method):		
Allowable Emissions _ of _					
1.	Basis for Allowable Emissions Code:	2.	Future Effective Date of Allowable Emissions:		
3.	Allowable Emissions and Units:	4.	Equivalent Allowable Emissions: lb/hour tons/year		
5.	Method of Compliance:				
6.	Allowable Emissions Comment (Description	of (Operating Method):		

Section [1] Units 3A, 3B, 3C, and 3D Gas Turbines

G. VISIBLE EMISSIONS INFORMATION

Complete Subsection G if this emissions unit is or would be subject to a unit-specific visible emissions limitation.

<u>Visible Emissions Limitation:</u> Visible Emissions Limitation **1** of **2** 2. Basis for Allowable Opacity: Visible Emissions Subtype: **VE10 X** Other ☐ Rule 3. Allowable Opacity: Normal Conditions: 20 % 10 % **Exceptional Conditions:** min/hour Maximum Period of Excess Opacity Allowed: 4. Method of Compliance: EPA Method 9 5. Visible Emissions Comment: During startup, shutdown, and malfunction, visible emissions in excess of 10% are authorized for up to ten, 6-minute averaging periods per 24 hr period. Also used as a surrogate standard for minimizing PM/PM10 emissions. **<u>Visible Emissions Limitation:</u>** Visible Emissions Limitation 2 of 2 Visible Emissions Subtype: 2. Basis for Allowable Opacity: **VE99** X Rule ☐ Other 3. Allowable Opacity: Normal Conditions: % Exceptional Conditions: 100% 60 min/hour Maximum Period of Excess Opacity Allowed: 4. Method of Compliance: None 5. Visible Emissions Comment: Per 62-210.700(1), excess emissions during startup, shutdown, or malfunction limited to 2 hours per 24 hour period.

DEP Form No. 62-210.900(1) – Form Effective: 03/11/2010

Section [1]

Units 3A, 3B, 3C, and 3D Gas Turbines

H. CONTINUOUS MONITOR INFORMATION

Complete Subsection H if this emissions unit is or would be subject to continuous monitoring.

Continuous Monitoring System: Continuous Monitor 1 of 3

	Continuous Monitoring System. Continuous	3 Monitor 1 or 2
1.	Parameter Code: O ₂ - Oxygen	2. Pollutant(s):
3.	CMS Requirement:	X Rule Other
4.	Monitor Information Manufacturer: SERVOMEX Model Number: 1440D	
	Serial Number: 3A: 01440D1/4704, 3B: 014 3D: 01440D1/4707	440D1/4705, 3C: 01440D1/4706,
5.	Installation Date: 3A-3D: Feb 2013	6. Performance Specification Test Date: 3A-3D: Feb 2013
7.	Continuous Monitor Comment: CEM required pursuant to 40 CFR 75.	
Co	ntinuous Monitoring System: Continuous	s Monitor <u>2</u> of <u>3</u>
1.	Parameter Code: EM - EMISSION	2. Pollutant(s):
3	CMS Requirement:	X Rule Other
4.	Monitor Information Manufacturer: HORIBA Model Number: 48	
	Serial Number: 3A: 0335003686/ 3B:033500	03687/ 3C:0335003688/ 3D:0335003689
3A:	Installation Date: : 22-MAY-05/ 3B: 26-MAY-05/ 3C: 23-MAY-05/ : 27-MAY-05	6. Performance Specification Test Date: 3A: 22-MAY-05/ 3B: 26-MAY-05/ 3C: 23-MAY-05/ 3D: 27-MAY-05
7.	Continuous Monitor Comment: CEM required pursuant to 40 CFR 75.	·

Section [1] Units 3A, 3B, 3C, and 3D Gas Turbines

H. CONTINUOUS MONITOR INFORMATION

Complete Subsection H if this emissions unit is or would be subject to continuous monitoring.

Continuous Monitoring System: Continuous Monitor 3 of 3

Parameter Code: EM - EMISSION	2. Pollutant(s): NO _x
3. CMS Requirement:	x Rule
4. Monitor Information Manufacturer: TECO	
Model Number: 421-LS	
Serial Number: 3A: 1233555755/ 3B: 12335	55756/ 3C: 1233555757/ 3D: 1233555758
5. Installation Date:	6. Performance Specification Test Date:
3A-3D: Feb 2013	3A-3D: Feb 2013
7. Continuous Monitor Comment:	
CEM required pursuant to 40 CFR 75.	
Continuous Monitoring System: Continuous	Monitor _ of _
1. Parameter Code:	2. Pollutant(s):
3. CMS Requirement:	x Rule Other
4. Monitor Information	
Manufacturer:	
Model Number:	
Serial Number:	
5. Installation Date:	6. Performance Specification Test Date:
7. Continuous Monitor Comment:	
	•

Section [1] Units 3A, 3B, 3C, and 3D Gas Turbines

I. EMISSIONS UNIT ADDITIONAL INFORMATION

Additional Requirements for All Applications, Except as Otherwise Stated

1.	Process Flow Diagram: (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought) Attached, Document ID: Previously Submitted, Date July, 2008
2.	Fuel Analysis or Specification: (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought) Attached, Document ID: Previously Submitted, Date July, 2008
3.	Detailed Description of Control Equipment: (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought) Attached, Document ID: Previously Submitted, Date July, 2008
4.	Procedures for Startup and Shutdown: (Required for all operation permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought) Attached, Document ID: Previously Submitted, Date Not Applicable (construction application)
5.	Operation and Maintenance Plan: (Required for all permit applications, except Title V air operation permit revision applications if this information was submitted to the department within the previous five years and would not be altered as a result of the revision being sought) Attached, Document ID: Previously Submitted, Date Not Applicable
6.	Compliance Demonstration Reports/Records: Attached, Document ID: Test Date(s)/Pollutant(s) Tested: Previously Submitted, Date: Test Date(s)/Pollutant(s) Tested: To be Submitted, Date (if known): Test Date(s)/Pollutant(s) Tested: Not Applicable Note: For FESOP applications, all required compliance demonstration records/reports must be
	submitted at the time of application. For Title V air operation permit applications, all required compliance demonstration reports/records must be submitted at the time of application, or a compliance plan must be submitted at the time of application.
7.	Other Information Required by Rule or Statute: Attached, Document ID: Not Applicable

DEP Form No. 62-210.900(1) – Form Effective: 03/11/2010

Section [1] Units 3A, 3B, 3C, and 3D Gas Turbines

I. EMISSIONS UNIT ADDITIONAL INFORMATION (CONTINUED)

Additional Requirements for Air Construction Permit Applications

1.	Control Technology Review and Analysis (Rules 62-212.400(10) and 62-212.500(7), F.A.C.; 40 CFR 63.43(d) and (e)):
	Attached, Document ID: Not Applicable
2.	Good Engineering Practice Stack Height Analysis (Rules 62-212.400(4)(d) and 62-212.500(4)(f),
	F.A.C.): Attached, Document ID: Not Applicable
3.	Description of Stack Sampling Facilities: (Required for proposed new stack sampling facilities
	only) Attached, Document ID: Not Applicable
Ad	Iditional Requirements for Title V Air Operation Permit Applications – N/A
1.	Identification of Applicable Requirements: Attached, Document ID: Not Applicable
2.	Compliance Assurance Monitoring: Attached, Document ID: Not Applicable
3.	Alternative Methods of Operation: Attached, Document ID: Not Applicable
4.	Alternative Modes of Operation (Emissions Trading): Attached, Document ID: Not Applicable
Ad	ditional Requirements Comment
	ı

DEP Form No. 62-210.900(1) – Form Effective: 03/11/2010

PART II

PART II

APPLICATION FOR MINOR SOURCE AIR CONSTRUCTION PERMIT FOR IMPROVING MANATEE UNITS 3A, 3B, 3C, AND 3D (EU IDS 005, 006, 007, AND 008)

EXECUTIVE SUMMARY

Florida Power & Light Company (FPL) is seeking authorization from the Florida Department of Environmental Protection (FDEP) to improve the performance of the General Electric (GE) Model PG7241 gas turbines (7FA.03) associated with Units 3A through 3D (EU IDs 005, 006, 007, and 008) at the FPL Manatee Power Plant. The purpose of the project is to improve the performance of the GE Model PG7241 turbines with 7FA.04 components. The components being replaced are typically those requiring routine replacement due to normal operation. However, replacing the 7FA.03 components with 7FA.04 components results in higher efficiency and provides approximately a four percent increase in output power per turbine with an approximate two percent decrease in heat rate (heat input/output power) per turbine.

The 7FA.04 components have a projected design heat input capacity approximately two percent higher than the 7FA.03. As a result, there will be an expected increase in the design fuel flow for the units compared to same turbine inlet temperature based on manufacturer information. In addition, hourly emissions of air pollutants regulated under FDEP and federal Prevention of Significant Deterioration (PSD) program that are directly related to fuel, such as sulfur dioxide (SO₂), sulfuric acid mist (SAM), and particulate matter (PM), including PM with aerodynamic diameter equal to or less than 10 or 2.5 microns (PM₁₀/PM_{2.5}), will also potentially increase. Based on GE data for the 7FA.04 components, there will be no increase in hourly mass emissions of carbon monoxide (CO) or volatile organic compounds (VOCs), and a small increase in the hourly mass emission rate of nitrogen oxides (NO_x), which will be controlled by the downstream SCR. Based on the current actual-to-projected actual annual emissions test, the turbine improvement project will not result in a net increase of any regulated pollutant, nor of greenhouse gases (GHGs) regulated under the Tailoring Rule, above the PSD significant emission rates.

INTRODUCTION

The Manatee Power Plant is located at 19050 State Road 62 of Parrish City in Manatee County, Florida. The facility is currently operating under Title V Permit No. 0810010-014-AV (draft Proposed Title V issued July 19, 2013).

Golder Associates Inc. (Golder) was contracted to prepare and submit the necessary air permit application seeking authorization for the installation of 7FA.04 components and assist with any FDEP questions and additional information requests. This air permit application consists of the appropriate application form [Part I; DEP Form 62-210.900(1)], a technical description of the project, rule applicability



for the project, and emissions calculations demonstrating that the proposed project will not result in a significant net emissions increase.

Manatee Power Plant Unit 3's four gas turbines are permitted to fire only natural gas. The current design heat input rate for the turbines are 1,552 million British thermal units per hour (MMBtu/hr) [75 degrees Fahrenheit (°F) ambient temperature, PSD permit application dated September 2003]. There will be no change in the type of permitted fuel as a result of the project. The design heat input rates for natural gasfiring will increase by 39 MMBtu/hr (2.5 percent), based on GE data on 7FA.04 turbines at 75°F ambient temperature. Data from the National Climatic Data Center (NCDC) indicates the 30-year (1983 to 2012) average temperature for Tampa is 73°F (median 73.6°F). As a result, GE data for an ambient temperature of 75°F represent annual operating conditions and were used in the calculation.

The current permitted emissions limits for the Unit 3 gas turbines are listed in Condition No. B.10 of Title V Permit No. 0810010-014-AV (Title V Permit No. 0810010-019-AV). The improved 7FA.04 model turbines will guarantee the same concentration-base emissions limits for NO_x , CO, and VOC. There will also be no increase in hourly mass emission rates for CO and VOC. However, the potential hourly mass emission rate of NO_x will increase by 0.5 pound per hour (lb/hr) (at 75°F) for natural gas-firing.

There are currently no mass based emissions limits for SO₂, SAM, or PM/PM₁₀/PM_{2.5}. Since emissions of these pollutants are directly proportional to fuel flow and the proposed project will increase the design fuel flow capacity of the turbines, the potential hourly mass emission rates of these pollutants will also increase. Due to the improved efficiency and higher output of the installation of the 7FA.04 components, potential emissions of all pollutants will decrease on a per megawatt-hour (MW-hr) basis.

There are currently no post-combustion control technologies for emissions of CO, VOC, SO_2 , SAM_1 or $PM/PM_{10}/PM_{2.5}$. Emissions of NO_x are controlled by Dry Low- NO_x (DLN) combustion technology, and a selective catalytic reduction (SCR) system. The installation of the 7FA.04 components will rely on the same existing control technologies.

PROJECT DESCRIPTION

Manatee Power Plant Unit 3 consists of four gas turbine electrical generator sets, which include GE Model PG7241 turbines/generators, heat recovery steam generators, and a steam electric generator. The proposed project will replace component parts normally associated with maintenance outages for the GE PG7241, 7FA.03 turbine with 7FA.04 components, which offer greater output and greater efficiency without sacrificing reliability, availability, or operational flexibility. The 7FA.04 components will increase the output power by approximately four percent (baseload with natural gas-firing at 75°F). As a result of the greater output, mass emission rates of all criteria pollutants will decrease on a per MW-hr basis.



The project will include installation of new hot gas path components, new combustion liners and flow sleeves, and new control software to increase firing temperature. The advanced gas path of 7FA.04 uses less air for cooling the parts. As a result, more air is available for combustion and power generation. The turbines will remain equipped with the DLN 2.6 combustion system, which is GE's latest evolution of Dry Low-NO_x combustion technology.

The current schedule for the project has the installation for Units 3A-3D to be completed by Spring of 2014.

RULE APPLICABILITY

PSD/New Source Review (NSR)

Under Federal and State of Florida PSD review requirements, all major new or modified sources of air pollutants regulated under the Clean Air Act (CAA) must be reviewed and a pre-construction permit issued. The U.S. Environmental Protection Agency (EPA) has approved Florida's State Implementation Plan (SIP), which contains PSD regulations. The applicable PSD rules in Florida are found in Rule 62-212.400, Florida Administrative Code (F.A.C.).

A "major facility" is defined as any 1 of 28 named source categories that have the potential to emit 100 tons per year (TPY) or more, or any other stationary facility that has the potential to emit 250 TPY or more, of any pollutant regulated under the CAA. "Potential to emit" means the capability, at maximum design capacity, to emit a pollutant after the application of control equipment. Once a new source is determined to be a "major facility" for a particular pollutant, any pollutant emitted in amounts greater than the PSD significant emission rates is subject to PSD review.

The Manatee Power Plant is an existing major facility under PSD rules. For an existing major facility for which a project is proposed, the project is subject to PSD review if the net increase in emissions due to the project is greater than the PSD significant emission rates for any applicable pollutant. A "modification" is defined in FDEP Rule 62-210.200(205), F.A.C., as "any physical change in, change in the method of operation of, or addition to a facility which would result in an increase in the actual emissions of any pollutant subject to regulation under the [Clean Air] Act, including any not previously emitted, from any emission unit or facility". Because there is a physical change and the hourly mass emission rates will potentially increase, the project is a potential modification as defined in Rules 62-210.200 and 62-212.400 (PSD), F.A.C.

To demonstrate that the proposed project is not a major modification under the Department's PSD rules, an emissions comparison between baseline actual emissions and projected actual emissions was conducted pursuant to FDEP Rule 62-212.400(2)(1), F.A.C., for Manatee Power Plant Unit 3 (Units 3A,



3B, 3C, and 3D). The baseline, or current, actual emissions are the emissions over a consecutive 24-month period within the 5 years immediately preceding the date that a complete application is submitted. The use of different consecutive 24-month periods for each pollutant is allowed. Projected actual emissions are maximum annual rate, in tons per year, at which the existing emission unit is projected to emit a PSD pollutant in any of the 5 years following the date the unit resumes regular operation.

Table 1 presents the total actual heat input from natural gas reported in the Annual Operating Reports (AORs) as well as the actual operating hours for the period 2008 through 2012 for Units 3A through 3D.

Table 2 summarizes the annual emissions reported in the AORs for each calendar year in the period 2008 through 2012. The carbon dioxide (CO₂) emission rates in Table 2 were obtained from EPA's Acid Rain database.

Since emissions of nitrous oxide (N_2O) and methane (CH_4) were not reported in the AORs, they were calculated based on the actual annual heat input and emission factors from Title 40, Part 98 of the Code of Federal Regulations (40 CFR 98), Subpart C. These emissions are summarized in Table 3, which also shows the CO_2 equivalent (CO_2e) rates for these pollutants.

Table 4 presents the average emissions for each consecutive 2-year period based on the calendar year emissions in Tables 2 and 3. The annual average emissions for each consecutive 2-year period are consistent with the definition of baseline actual emissions for fossil fuel-fired steam electric generating units.

The actual hourly emission rates were calculated based on the reported annual emission rates and operating hours in the AORs, which are summarized in Table 5.

The actual emission factors in pounds per million British thermal units heat input (lb/MMBtu) were calculated in Table 6 for each calendar year in the period 2008 through 2012. The factors are calculated by dividing the total annual emissions by the total annual heat input.

The projected increases in annual emissions for each turbine are presented in Table 7. The emission increases are calculated based on the maximum actual emission factors (lb/MMBtu) for each pollutant shown in Table 6 and the maximum annual increase in design heat input rate. The maximum annual increase in design heat input rate was calculated using the hourly increase in design heat input rate for each fuel at 75°F ambient temperature and projected operating hours for each fuel. The calculation considers the projected annual operating hours of 8,104 hours per year (hr/yr) for natural gas, which is based on maximum actual operation on natural gas for any of the four turbines in the period 2008 to 2012 (see Table 1).



Table 8 presents the projected annual emissions, which were calculated by adding the projected annual increase in emissions from Table 7 to the baseline emissions. The baseline emissions are based on maximum 2-year average emissions from Table 4.

Table 9 compares baseline actual emissions and projected actual emissions for Units 3A, 3B, 3C, and 3D. The baseline 2-year average emissions from Table 4 and the projected actual emissions from Table 8 are used to calculate the increase in emissions as a result of the project. These increases are the same as the increases calculated in Table 8. The projected annual emissions increases were based on an operation of 8,104 hr/yr, which are based on the maximum operating hours for any CT for Unit 3 during the baseline period. The installation of the 7FA.04 components result in a slight increase in the energy output while improving the heat rate. Any difference between the hours of operation associated with the baseline actual emissions and hours associated with projected actual emissions are a result of the growth in projected demand. Pursuant to Rule 62-210.200(249)(c), F.A.C., any emissions associated with the demand growth are excluded from the definition of projected actual emissions.

The projected increase in GHG emissions as total CO_2e is also shown in Table 9. As shown, the projected increase in all regulated pollutants including GHGs is less than the PSD significant emission rates in the EPA Tailoring Rule. As a result, the proposed project is not subject to PSD review. A minor source air construction permit application is applicable to the project.

While there is a slight project increase in GHG emissions, there is an overall reduction in heat rate (Btu/kWh) that reduces the amount of emissions for each megawatt-hour (MWh) generated. For example, there is an approximate 2 percent decrease in heat rate as a result of the project. As shown in Table 9, the baseline actual CO₂e emissions are approximately 2.9 million tons/year. With a 2 percent reduction in heat rate for the project, the CO₂e emissions for the same amount of generation as 2008-2009 would be approximately 58,000 tons lower. Since the proposed project will increase power output, on a lb CO₂e/MWh basis, Manatee Power Plant Unit 3 will have less CO₂e emissions than it currently does. The output based emissions for other air emissions will also decrease on a lb/MWh basis.

NSPS

Manatee Power Plant Units 3A through 3D are currently subject to 40 CFR 60 Subpart GG, Standard of Performance for Stationary Gas Turbines. For the purpose of New Source Performance Standards (NSPS) applicability, 40 CFR 60.14 defines modification as any physical or operational change to an existing facility that results in an increase in the emission rate to the atmosphere of any pollutant to which a standard applies. 40 CFR 60.14 also states that the emission rate shall be expressed as kilograms per hour (kg/hr). NO_x and SO₂ are regulated under NSPS for Stationary Gas Turbines. Since the hourly emission rates for these pollutants may potentially increase, the proposed project is a potential modification according to the rules for NSPS. As a result, the improved Unit 3 turbines may be subject to



40 CFR 60 Subpart KKKK, the revised Standard of Performance for Stationary Combustion Turbines, which applies to stationary combustion turbines with a heat input at peak load equal to greater than 10 MMBtu/hr that commence construction, modification, or reconstruction after February 18, 2005.

Moreover, Manatee Power Plant Unit 3 was approved with several operating modes that could produce higher or equivalent emissions as the 7FA.04 project. In addition, after the energy improvement, the turbines will comply with the same concentration-based NO_x emissions standards they are currently subject to, which are 2.5 parts per million, dry volume basis, at 15-percent oxygen (ppmvd @ 15% O_2) for natural gas-firing, during combined-cycle operation.

NSPS Subpart KKKK limits NO_x emissions to 15 ppmvd @ 15% O_2 for natural gas-firing for turbines with heat input rate greater than 850 MMBtu/hr (high heating value). NSPS Subpart KKKK also limits NO_x emissions to 0.43 pound per megawatt-hour (lb/MWh) for natural gas-firing. Based on the current design gross power output of the CT of 175 megawatts (MW) (at 59°F), output-based current emissions limits are 0.093 lb/MWh (using 16.3 lb/hr with SCR control). After the improvement, these emission rates will be 0.090 lb/MWh (based on 184 MW at 59°F).

Finally, the 7FA.04 improvement decreases the exhaust mass flow of the combustion turbine slightly. As a result, there is not expected to be any increase in kg/hr emissions of NO_x based on the use of SCR.

For these reasons, it is believed no increase in kg/hr NO_x emissions will occur from the project. It is proposed that the CEMs data post the upgrades be reviewed to determine if an increase has occurred. In any event, the 7FA.04 project will comply with, and be much less than, the emission limiting standards of Subpart KKKK for NO_x .

NSPS Subpart KKKK limits SO₂ emissions by limiting the sulfur in the fuel (0.06 lb/MMBtu) or based on the output (0.9 lb/MWh). Based on AOR data for the period 2008 – 2012, the current actual maximum SO₂ emission rate is 0.00061 lb/MMBtu. The potential heat input rate for the turbines will increase by approximately two percent. SO₂ emissions are directly proportional to heat input for the same sulfur content of fuel and the lb/MMBtu rate is expected to remain the same. Since natural gas is the only permitted fuel, the amount of sulfur will vary slightly. As a result, the projected minor increase in heat input may not increase emissions based on the normal variability of sulfur in natural gas. Indeed, Section 60.14(2) of 40 CFR 60 recognizes the potential for statistical variability in determining an increase in kg/hr (i.e., Appendix C of 40 CFR 60). For this reason, future sulfur content data post upgrades will be reviewed to determine if an increase in kg/hr SO₂ emissions has occurred. In any event, the 7FA.04 project will comply with the emission limiting standards of Subpart KKKK for SO₂.



PROPOSED CHANGES TO EXISTING PERMIT CONDITIONS

The Manatee Power Plant is currently operating under Title V air operating permit No. 0810010-014-AV. Condition No. B.10 of Title V permit lists the emissions limitations and standards for Units 3A through 3D. NO_x , CO, and VOC are the three pollutants with concentration-based and mass emissions limits, which are based on GE performance data for base load operation at 59°F ambient temperature. Based on GE data, the improved turbines will achieve the same concentration-based emissions and same mass emission rates for CO and VOC. Therefore, FPL is requesting no change to the existing emissions limits for CO and VOC (concentrations and mass based), and the same concentration-based limits for NO_x . Based on GE data, the mass emission rate potential for NO_x will slightly increase. The proposed mass emissions limits for NO_x at a turbine inlet temperature of 59°F are presented below:

Fuel	Method of Operation	Current	Proposed
Natural gas-firing	Combined-cycle with SCR	16.3 lb/hr	16.8 lb/hr
	Combined-cycle with SCR and duct firing	23.6 lb/hr	24.1 lb/hr

The proposed rates are based on GE performance data for 7FA.04 improvement at 59°F ambient temperature. It should be noted that the mass emissions are used only for comparison with annual emissions tests. Compliance is based on 2.5 ppmvd corrected to 15 percent oxygen. As a result, actual hourly emissions on a kg/hr are not expected to increase.

FPL also requests that the gas turbine heat input rates in permit No. 0810010-019-AV be revised from 1,600 MMBtu/hr (LHV) to 1,659 MMBtu/hr (LHV) at the compressor inlet air temperature of 59°F.



TABLES

Table 1. Manatee Power Plant Unit 3 Annual Heat Inputs and Operating Hours, 2008 - 2012

UNIT 3

	Total Actual Heat Input from Natural Gas (MMBtu/yr)											
Year	Unit 3A	Unit 3B	Unit 3C	Unit 3D	Total							
2012	11,159,000	12,349,000	11,449,000	12,366,000	47,323,000							
2011	9,839,089	9,989,000	10,276,000	10,126,000	40,230,089							
2010	10,336,000	11,847,000	11,093,000	10,324,000	43,600,000							
2009	12,377,000	12,145,000	12,878,000	12,904,000	50,304,000							
2008	12,034,000	11,932,000	12,739,000	12,613,000	49,318,000							

UNIT 3

		Total Actual Operating Hours (hr/yr)												
Year	Unit 3A	Unit 3B	Unit 3C	Unit 3D	Total									
2012	7,094	7,683	7,261	7,677	29,715									
2011	6,300	6,190	6,604	6,389	25,483									
2010	6,567	7,482	6,970	6,562	27,581									
2009	7,670	7,517	7,920	7,928	31,035									
2008	7,681	7,615	8,104	8,016	31,416									

Note: All values are based on annual operating reports for the period 2008 - 2012.



Table 2. Annual Emissions Reported in 2008-2012 Annual Operating Reports and Acid Rain Database for Unit 3

		Unit 3A	Unit 3B	Unit 3C	Unit 3D	Total
Year	Pollutant	(tons)	(tons)	(tons)	(tons)	(tons)
2012	NO _x	59.6	63.2	54.9	57.3	234.9
2012	CO	6.2	6.2	5.2	6.9	24.5
	SO₂	3.4	3.7	3.5	3.8	1 4 .4
	VOC	7.24	3.69	6.53	3.38	20.8
	PM	0.037	0.041	0.038	0.041	0.16
	PM ₁₀			0.038	0.041	0.16
		0.037	0.041			
	SAM ^a			-		2.2
	CO ₂	670,075.1	741,465.6	687,505.9	743,851.6	2,842,898.2
2011	NO _x	47.8	43.2	47.5	50.6	189.1
	CO	5.8	6.1	4.1	7.1	23.2
	SO₂	2.8	3.0	3.0	3.0	1 1.8
	VOC	6.43	2.97	5.94	2.81	18.2
	PM	0.032	0.033	0.034	0.033	0.13
	PM ₁₀	0.032	0.033	0.034	0.033	0.13
	SAM ⁸					1.8
	CO ₂	584,725.4	593,634.4	610,707.2	601,775.9	2,390,842.8
2010	NO _x	56.9	61.7	48.1	58.1	224.8
	co	6.0	7.4	4.4	7.3	25.1
	SO₂	3.0	3.5	3.3	3.0	12.8
	voc	6.70	3.59	6.27	2.89	19.4
	PM	0.034	0.039	0.037	0.034	0.14
	PM ₁₀	0.034	0.039	0.037	0.034	0.14
	SAM ^a					2.0
	CO ₂	604,753.1	702,666.0	641,828.6	600,286.2	2,549,533.9
2009	NO _x	66.3	64.5	61.8	62.2	254.8
2000	CO	5.3	5.2	7.6	7.6	25.7
	SO₂	3.6	3.6	3.7	3.9	14.8
	VOC	7.82	3.61	7.13	3.49	22.0
	PM	0.041	0.040	0.042	0.043	0.2
	PM ₁₀	0.041	0.040	0.042	0.043	0.2
	SAM ⁸					2.3
	CO ₂	 733,562.1	 724,253.1	 746,786.6	 760,908.1	2,965,509.9
	552	700,002.1	. 24,200.1	740,700.0	. 00,000	2,000,000.0
2008	NO _x	58.8	61.9	57.5	62.7	240.9
	CO	9.6	8.4	7.7	9.2	34.9
	SO ₂	3.6	3.5	3.7	3.8	14.6
	VOC	7.83	3.66	7.29	3.53	22.3
	PM	0.040	0.039	0.042	0.042	0.16
	PM ₁₀	0.040	0.039	0.042	0.042	0.16
	SAM ^a					2.2
	CO ₂	706,165.4	696,361.5	732,475.6	736,636.0	2,871,638.5

 $^{^{\}rm a}$ Not reported in AORs - based on assuming 10% of SO $_{\rm 2}$ converts to SO $_{\rm 3}$, all of which converts to SAM.

Source: Annual Operating Report (AOR) for Manatee Power Plant, 2008 - 2012; EPA's Acid Rain database.



October 2013

Table 3. Actual Annual Emissions of N_2O and CH_4 for the Period 2008 - 2012 Units 3 CT Improvement Project

	Actual		N₂O Em	issions		CH₄ Emissions						
	Annual	Emission			CO₂e °	Emission			CO₂e °			
	Heat Input ^a	Factor b	Annual E	missions	Rate	Factor ^b	Annual E	missions	Rate (TPY)			
Unit	(MMBtu/yr)	(lb/MMBtu)	(lb/yr)	(TPY)	(TPY)	(lb/MMBtu)	(lb/yr)	(TPY)				
Init 3 - Natu	ral Gas-Firing											
2012	47,323,000	2.20E-04	10,430.0	5.2	1,616.6	2.2E-03	104,299.9	52.1	1,095.1			
2011	40,230,089	2.20E-04	8,866.7	4.4	1,374.3	2.2E-03	88,667.1	44.3	931.0			
2010	43,600,000	2.20E-04	9,609.4	4.8	1,489.5	2.2E-03	96,094.4	48.0	1,009.0			
2009	50,304,000	2.20E-04	11,087.0	5.5	1,718.5	2.2E-03	110,870.0	55.4	1,164.1			
2008	49,318,000	2.20E-04	10,869.7	5.4	1,684.8	2.2E-03	108,696.9	54.3	1,141.3			
<u>otal</u>												
2012				5.2	1,616.6			52.1	1,095.1			
2011				4.4	1,374.3			44.3	931.0			
2010				4.8	1,489.5			48.0	1,009.0			
2009				5.5	1,718.5			55.4	1,164.1			
2008				5.4	1,684.8			54.3	1,141.3			

^a Based on AOR data - see Table 1.



^b Table C-2, Subpart C, 40 CFR 98. Emission factors in kg/MMBtu were converted to lb/MMBtu by multiplying by 2.204.

 $^{^{\}rm c}$ N $_{\rm 2}$ O and CH $_{\rm 4}$ are multiplied by a factor of 310 and 21, respectively, to determine CO $_{\rm 2}$ equivalence.

Table 4. Annual Average Emissions for Manatee Power Plant Unit 3 for Each Consecutive Two-Year Period, 2008-2012

		Annual	Emissions for	or Unit 3		Two-Year Average Emissions							
	2012	2011	2010	2009	2008	2012-2011	2011-2010	2010-2009	2009-2008				
Pollutant						(tons)	(tons)	(tons)	(tons)				
NO _x	234.9	189.1	224.8	254.8	240.9	212.0	207.0	239.8	247.9				
co	24.5	23.2	25.1	25.7	34.9	23.9	24.1	25.4	30.3				
SO ₂	14.4	11.8	12.8	14.8	14.6	13.1	12.3	13.8	14.7				
VOC	20.8	18.2	19.4	22.0	22.3	19.5	18.8	20.7	22.2				
PM	0.2	0.1	0.1	0.2	0.2	0.14	0.14	0.15	0.16				
PM ₁₀	0.2	0.1	0.1	0.2	0.2	0.14	0.14	0.15	0.16				
PM _{2.5} ^a	0.2	0.1	0.1	0.2	0.2	0.14	0.14	0.15	0.16				
SAM ^b	2.2	1.8	2.0	2.3	2.2	2.0	1.9	2.1	2.3				
CO ₂	2,842,898.2	2,390,842.8	2,549,533.9	2,965,509.9	2,871,638.5	2,616,870.5	2,470,188.4	2,757,521.9	2,918,574.2				
N ₂ O ^c (CO ₂ e)	1,616.6	1,374.3	1,489.5	1,718.5	1,684.8	1,495.5	1,431.9	1,604.0	1,701.6				
CH ₄ ^c (CO ₂ e)	1,095.1	931.0	1,009.0	1,164.1	1,141.3	1,013.1	970.0	1,086.6	1,152.7				

^a Assuming equal to PM₁₀ emissions.

Source: Annual Operating Report (AOR) for Manatee Power Plant, 2008 - 2012; EPA's Acid Rain database.

^b Not reported in AORs - based on assuming 10% of SO₂ converts to SO₃, all of which converts to SAM.

^c Calculated based on actual annual heat input - see Table 3.

Table 5. Actual Hourly Emission Rates, FPL Manatee Power Plant Units 3A, 3B, 3C, and 3D

		A	nnual Emiss	sions ^a (tor	ıs)		Operatin	g Hours ^a		Ho	urly Emissio	n Rates (Ib	/hr)	Maximum
Pollutant	Year	Unit 3A	Unit 3B	Unit 3C	Unit 3D	Unit 3A	Unit 3B	Unit 3C	Unit 3D	Unit 3A	Unit 3B	Unit 3C	Únit 3D	Rate (lb//hr)
NO _x	2012	59.6	63.2	54.9	57.3	7,094	7,683	7,261	7,677	16.8	16.4	15.1	14.9	
	2011	47.8	43.2	47.5	50.6	6,300	6,190	6,604	6,389	15.2	14.0	14.4	15.8	
	2010	56.9	61.7	48.1	58.1	6,567	7,482	6,970	6,562	17.3	16.5	13.8	17.7	
	2009	66.3	64.5	61.8	62.2	7,670	7,517	7,920	7,928	17.3	17.2	15.6	15.7	
	2008	58.8	61.9	57.5	62.7	7,681	7,615	8,104	8,016	15.3	16.3	14.2	15.6	
						.,	1,2.2	-,	Maximum =	17.3	17.2	15.6	17.7	17.71
co	2012	6.2	6.2	5.2	6.9	7,094	7,683	7,261	7,677	1.7	1.6	1.4	1.8	
	2011	5.8	6.1	4.1	7.1	6,300	6,190	6.604	6,389	1.8	2.0	1.3	2.2	
	2010	6.0	7.4	4.4	7.3	6,567	7,482	6,970	6,562	1.8	2.0	1.3	2.2	
	2009	5.3	5.2	7.6	7.6	7,670	7,517	7,920	7,928	1.4	1.4	1.9	1.9	
	2008	9.6	8.4	7.7	9.2	7,681	7,615	8,104	8,016	2.5	2.2	1.9	2.3	
					•	,,,	.,	5,75	Maximum =	2.5	2.2	1.9	2.3	2.50
voc	2012	7.236	3.688	6.535	3.378	7,094	7.683	7,261	7,677	2.0	1.0	1.8	0.9	
	2011	6.426	2.971	5.944	2.811	6,300	6,190	6,604	6,389	2.0	1.0	1.8	0.9	
	2010	6.698	3.591	6.273	2.887	6,567	7,482	6,970	6,562	2.0	1.0	1.8	0.9	
	2009	7.823	3.608	7.128	3.488	7,670	7,517	7,920	7,928	2.0	1.0	1.8	0.9	
	2008	7.835	3.655	7.294	3.527	7,681	7,615	8,104	8,016	2.0	1.0	1.8	0.9	
						.,	,,,,,,	0,101	Maximum =	2.0	1.0	1.8	0.9	2.04
SO₂	2012	3.4	3.7	3.5	3.8	7,094	7,683	7,261	7,677	1.0	1.0	1.0	1.0	
٠.	2011	2.8	3.0	3.0	3.0	6,300	6,190	6,604	6,389	0.9	1.0	0.9	0.9	
	2010	3.0	3.5	3.3	3.0	6,567	7,482	6,970	6,562	0.9	0.9	0.9	0.9	
	2009	3.6	3.6	3.7	3.9	7,670	7,517	7,920	7,928	0.9	1.0	0.9	1.0	
	2008	3.6	3.5	3.7	3.8	7,681	7,615	8,104	8,016	0.9	0.9	0.9	0.9	
	2000	0.0	0.0	0.1	0.0	.,001	1,010	0,101	Maximum =	1.0	1.0	1.0	1.0	0.98
PM/PM ₁₀ /PM _{2.5}	2012	0.0	0.0	0.0	0.0	7,094	7.683	7,261	7,677	0.0	0.0	0.0	0.0	
10 2,0	2011	0.03	0.03	0.03	0.03	6,300	6,190	6,604	6.389	0.0	0.0	0.0	0.0	
	2010	0.0	0.0	0.0	0.0	6,567	7,482	6,970	6,562	0.0	0.0	0.0	0.0	
	2009	0.04	0.04	0.04	0.04	7,670	7,517	7,920	7,928	0.0	0.0	0.0	0.0	
	2008	0.0	0.0	0.0	0.0	7,681	7,615	8,104	8,016	0.0	0.0	0.0	0.0	
	2000	0.0	0.0	0.0	0.0	,,001	,,,,,,	0,104	Maximum =	0.0	0.0	0.0	0.0	0.01

^a Reported in AORs for the period 2008 - 2012.



October 2013

Table 6. Manatee Power Plant Unit 3 Actual Emissions as a Function of Heat Input, 2008 - 2012

Actual Annual Heat Input (MMBtu/yr) a						Units 3A, 3B, 3C, & 3D Total Actual Emissions (TPY) b								Emissions per Unit Heat Input ^c (Ib/MMBtu)						
Year	Unit 3A	Unit 3B	Unit 3C	Unit 3D	Total	NO _X	СО	VOC	SO ₂	PM/PM ₁₀	SAM	CO ₂	NO _x	СО	VOC	SO ₂	PM/PM ₁₀	SAM	CO2	
2012	11,159,000	12,349,000	11,449,000	12,366,000	47,323,000	234.9	24.5	20.8	14.4	0.2	2.2	2,842,898.2	0.0099	0.0010	0.0009	0.00061	0.000007	0.0001	120.1	
2011	9,839,089	9,989,000	10,276,000	10,126,000	40,230,089	189.1	23.2	18.2	11.8	0.1	1.8	2,390,842.8	0.0094	0.0012	0.0009	0.00059	0.000007	0.0001	118.	
2010	10,336,000	11,847,000	11,093,000	10,324,000	43,600,000	224.8	25.1	19.4	12.8	0.1	2.0	2,549,533.9	0.0103	0.0012	0.0009	0.00059	0.000007	0.0001	117.	
2009	12,377,000	12,145,000	12,878,000	12,904,000	50,304,000	254.8	25.7	22.0	14.8	0.2	2.3	2,965,509.9	0.0101	0.0010	0.0009	0.00059	0.0000066	0.0001	117.	
2008	12,034,000	11,932,000	12,739,000	12,613,000	49,318,000	240.9	34.9	22.3	14.6	0.2	2.2	2,871,638.5	0.0098	0.0014	0.0009	0.00059	0.000007	0.0001	116.	
				Maximum =	50,304,000							Maximum =	0.0103	0.0014	0.00090	0.00061	0.000007	0.000093	120.	

^a Based on AOR data, see Table 1.



^b Based on AOR data, see Table 2.

^c Total actual emissions divided by total heat input.

Table 7. Projected Increase in Annual Emissions for Each CT, FPL Manatee Power Plant Units 3A, 3B, 3C, and 3D (EU IDs 005, 006, 007, and 008)

		Current Design Heat Input ^b	Future Design Heat Input ^c	Max Increase in Design Heat Input	Projected Operating ^d	Annual Increase in Design Heat Input	Increase in Annual Emissions	
Pollutant	Emission Factor ^a (lb/MMBtu)	(MMMBtu/hr, HHV) NG-Firing	(MMMBtu/hr, HHV) NG-Firing	(MMBtu/hr, HHV) NG-Firing	Hours (hr/yr) NG-Firing	(MMMBtu/yr)	(TPY)	
NO _x	0.0103	1,722.4	1,758.4	36.0	8,104	291,452.3	1.50	
co	0.0014	1,722.4	1,758.4	36.0	8,104	291,452.3	0.206	
SO₂	0.00061	1,722.4	1,758.4	36.0	8,104	291,452.3	0.088	
VOC	0.0009	1,722.4	1,758.4	36.0	8,104	291,452.3	0.132	
PM	0.000007	1,722.4	1,758.4	36.0	8,104	291,452.3	0.001	
PM ₁₀	0.000007	1,722.4	1,758.4	36.0	8,104	291,452.3	0.001	
PM _{2.5}	0.000007	1,722.4	1,758.4	36.0	8,104	291,452.3	0.001	
SAM	0.000093	1,722.4	1,758.4	36.0	8,104	291,452.3	0.014	
<u>GHGs</u>								
CO ₂	120.1	1,722.4	1,758.4	36.0	8,104	291,452.3	17,509	
N₂O	2.20E-04	1,722.4	1,758.4	36.0	8,104	291,452.3	0.032	
CH₄	2.20E-03	1,722.4	1,758.4	36.0	8,104	291,452.3	0.32	

^a Maximum actual emission factor for the period 2008-2012 - see Table 6.



^b Based on GE data for 7FA.03 turbines at 75 F for NG firing. Heat input rate at HHV = Heat input rate (LHV) x 1.11

[°] Based on GE data for improved 7FA.04 turbines, at 75°F.

^d Highest fuel usage for all four CTs during baseline actual period. See Table 1.

Table 8. Projected Annual Emissions and PSD Applicability for Manatee Unit 3 GE 7FA.04 Improvements

Pollutant	Baseline (Maximum 2-Year Average Actual) Emissions ^a (TPY)	Projected Increase for One CT ^b (TPY)	Projected Increase for Four CTs ^b (TPY)	Projected Annual Emission (TPY)		
NO _x	247.85	1.50	6.0	253.86		
co	30.31	0.21	0.8	31.14		
SO₂	14.70	0.09	0.35	15.05		
VOC	22.18	0.13	0.5	22.71		
PM	0.16	9.62E-04	3.85E-03	0.17		
PM ₁₀	. 0.16	9.62E-04	3.85E-03	0.17		
PM _{2.5}	0.16	9.62E-04	3.85E-03	0.17		
SAM	2.25	0.014	0.05	2.31		
CO ₂	2,918,574	17,509	70,035	2,988,609		
N ₂ O (CO ₂ e)	1,701.64	9.96	39.8	1,741		
CH₄ (CO₂e)	1,152.73	6.74	27.0	1,180		

^a Maximum 2-Year average emissions - see Table 4.



^b Projected increase in emissions due to the project - see Table 7.

Table 9. PSD Applicability - Manatee Power Plant Unit 3 GE 7FA.04 Improvements

Pollutant	Baseline (Maximum 2-Year Average Actual) Emissions ^a (TPY)	Projected Actual Emissions ^b (TPY)	Increase/Decrease in Annual Emissions ^c (TPY)	PSD Significant Emission Rates (TPY)
NO_x	247.85	253.86	6.0	40
co	30.31	31.14	0.82	100
SO ₂	14.70	15.05	0.35	40
VOC	22.18	22.71	0.53	40
PM	0.16	0.17	3.85E-03	25
PM ₁₀	0.16	0.17	3.85E-03	15
PM _{2.5}	0.16	0.17	3.85E-03	10
SAM	2.25	2.31	0.054	7
<u>GHGs</u>				
CO ₂	2,918,574.21	2,988,609.42	70,035.2	d
N_2O (CO_2e)	1,701.64	1,741.47	39.8	d
CH₄ (CO₂e)	1,152.73	1,179.71	27.0	d
otal GHGs (CO₂e)	2,921,428.6	2,991,530.6	70,102.0	 75,000

^a Maximum 2-Year average emissions - see Tables 4.



^b Projected actual annual emissions for Manatee Unit 3 - see Table 8.

^c Projected actual emissions minus baseline actual emissions.

^d Does not take into account heat rate.

APPENDIX A

Appendix A Manatee Power Plant Summary of AOR Data for Unit 3 (EU IDs 005, 006, 007, 008)

Unit 3A - 170 MW gas turi	bine with gas-fired HRSG		-	<u>Unit 3B - 170 MW gas</u>	turbine with gas-fired HRS	<u>G</u>	
2012	Natural Gas TPY	Total TPY	Haven	2040	Natural Gas	Total	
NOx		59.61	Hours	2012	TPY	TPY	H
	59.61		7094	NOx	63,16	63.16	7
CO	6.20143	6.20		CO	6.23826	6.24	
SO2	3.38	3.38		SO2	3.74	3.74	
VOC	7.23588	7.24		VOC	3.68784	3.69	
PM	0.036825	0.04		PM	0.040752	0.04	
PM10	0.036825	0.04		PM10	0.040752	0.04	
Unit 3A - 170 MW gas turi	bine with gas-fired HRSG		-	Unit 3B - 170 MW gas	turbine with gas-fired HRS	<u>G</u>	
	Natural Gas	Total			Natural Gas	Total	
2011	TPY	TPY	Hours	2011	TPY	TPY	Н
NOx	47.8	47.80	6300	NOx	43.2	43.20	6
CO	5.796	5.80		co	6.1281	6.13	
SO2	2.8	2.80		SO2	3	3.00	
VOC	6.426	6.43		VOC	2,9712	2.97	
PM	0.032469	0.03		PM	0.032964	0.03	
PM10	0.032469	0.03		PM10	0.032964	0.03	
Unit 3A - 170 MW gas tur	bine with gas-fired HRSG		_	Unit 3B - 170 MW gas	turbine with gas-fired HRS	G ·	
	Natural Gas	Total			Natural Gas	Total	
2010	TPY	TPY	_ Hours	2010	TPY	TPY	He
NOx	56.9	56.90	6567	NOx	·61.7	61.70	7
co	6.04164	6.04		CO	7.40718	7.41	
SO2	3	3.00		SO2	3.5	3.50	
VOC	6.69834	6.70		voc	3.59136	3.59	
PM	0.034109	0.03		PM	0.039095	0.04	
PM10	0.034109	0.03		PM10	0.039095	0.04	
Unit 3A - 170 MW gas tur	bine with gas-fired HRSG		_	<u>Unit 3B</u> - 170 MW gas	turbine with gas-fired HRS	G	
	Natural Gas	Total			Natural Gas	Total	
2009	TPY	TPY	Hours	2009	TPY	TPY	Ho
NOx	66.3	66.30	7670	NOx	64.5	64.50	7
CO	5.33065	5.33		co	5 18673	5.19	•
SO2	3.6	3.60		SO2	3.6	3.60	
VOC	7.8234	7.82		VOC	3.60816	3.61	
PM	0.040844	0.04		PM	0.040079	0.04	
PM10	0.040844	0.04		PM10	0.040079	0.04	
Unit 3A - 170 MW gas tur	bine with gas-fired HRSG		_	<u>Unit 3B</u> - 170 MW gas	turbine with gas-fired HRS	G	
	Natural Gas	Total			Natural Gas	Total	
2008	TPY	TPY	Hours	2008	TPY	TPY	H
NOx	58.8	58.80	7681	NOx	61.9	61.90	7
CO	9.60125	9.60		CO	8.3765	8.38	•
SO2	3.6	3.60		SO2	3.5	3.50	
VOC	7.83462	7.83		VOC	3,6552	3.66	
PM	0.039712 0.039712	0.04 0.04		PM PM10	0.039376 0.039376	0.04 0.04	
PM10							



October 2013

Appendix A
Manatee Power Plant
Summary of AOR Data for Unit 3 (EU IDs 005, 006, 007, 008)

Emission Unit 007	as turbine with gas-fired h	1860		Emission Unit 008	s turbine with gas-fired H	BSC		
OTHE SC - 170 WWY GE	Natural	11.30	-	0111(3D - 170 MVV ga	is turbine with gas-lifeu n	KSG_	_	
2012	Gas	Total TPY	Hours	2012	Natural Gas TPY	Total TPY	н	
NOx	54.85	54.85	7261	NOx	57.3	57.30	- ;	
CO	5.20588	5.21	, 20 1	CO	6.88426	6.88	•	
SO2	3 47	3.47		SO2	3.76	3.76		
VOC	6.5349	6.53		VOC	3.37788	3.78		
PM	0.037782	0.04		PM	0.040808			
PM10	0.037782	0.04		PM10	0.040808	0.04 0.04		
Unit 3C - 170 MW ga	s turbine with gas-fired H	HRSG	_	Unit 3D - 170 MW ga	as turbine with gas-fired H	RSG	_	
	Natural Gas	Total		-	Natural Gas	Total	_	
2011	TPY	TPY	Harra	2011	TPY	TPY		
NOx	47.5	47.50	Hours				_ +	
			6604	NOx	50.6	50.60	6	
CO	4.1275	4.13		co	7.12374	7.12		
SO2	3	3.00		SO2	3	3.00		
VOC	5.9436	5.94		VOC	2.81116	2.81		
PM	0.033912	0.03		PM .	0.033416	0.03		
PM10	0.033912	0.03		PM10	0.033416	0.03		
Unit 3C - 170 MW ga	as turbine with gas-fired h	HRSG	_	Unit 3D - 170 MW ga	as turbine with gas-fired H	RSG	_	
	Natural							
****	Gas	Total			Natural Gas	Total		
2010	TPY	TPY	_ Hours	2010	TPY	TPY	_ н	
NOx	48.1	48.10	6970	NOx	58.1	58.10	•	
CO	4.35625	4.36		CO	7.31663	7.32		
SO2	3.3	3.30		SO2	3	3.00		
VOC	6.273	6.27		VOC	2.88728	2.89		
PM	0.036607	0.04		PM	0.034069	0.03		
PM10	0.036607	0.04	•	PM10	0.034069	0.03		
Unit 3C - 170 MW as	as turbine with gas-fired h	- PSG		Unit 3D - 170 MW/or	as turbine with gas-fired H	PSG		
Onit 30 - 170 HIVY go	Natural	11.00	_	OTILL SEE - 170 MIVV GE	as turbine with gas-med th	11.50	_	
	Gas	Total			Natural Gas	Total		
2009	TPY	TPY	Hours	2009	TPY	TPY		
							_ 별	
NOx	61.8	61.80	7920	NOx	62.2	62.20	7	
CO	7.6032	7.60		CO	7.61088	7.61		
SO2	3.7	3.70		SO2	3.9	3.90		
VOC	7.128	7.13		VOC	3.48832	3.49		
PM	0.042497	0.04		PM	0.042583	0.04		
PM10	0.042497	0.04		PM10	0.042583	0.04		
Linit 3C - 170 MW/or	as turbine with gas-fired h	HRSG		Unit 3D - 170 MW gas turbine with gas-fired HRSG				
OTHE SC - 170 WIVY GO	Natural						_	
OTHE SC - 170 WIVE GO	Hatalai				Natural Gas	Total		
Offic SC - 170 MIVV ge	Gas	Total		0000	TPY	TPY	н	
2008		Total TPY	Hours	2008				
2008	Gas TPY	TPY	Hours 8104	2008 NOx				
2008 NOx	Gas TPY 57.5	TPY 57.50	Hours 8104	NOx	62.7	62.70		
2008 NOx CO	Gas TPY 57.5 7.6988	TPY 57.50 7.70		NOx CO	62.7 9.2184	62.70 9.22		
2008 NOx CO SO2	Gas TPY 57.5 7.6988 3.7	TPY 57.50 7.70 3.70		NOx CO SO2	62.7 9.2184 3.8	62.70 9.22 3.80		
2008 NOx CO SO2 VOC	Gas TPY 57.5 7.6988 3.7 7.2936	TPY 57.50 7.70 3.70 7.29		NOx CO SO2 VOC	62.7 9.2184 3.8 3.52704	62.70 9.22 3.80 3.53		
2008 NOx CO SO2	Gas TPY 57.5 7.6988 3.7	TPY 57.50 7.70 3.70		NOx CO SO2	62.7 9.2184 3.8	62.70 9.22 3.80	- 7	



Appendix A
Manatee Power Plant
Summary of AOR Data for Unit 3 (EU IDs 005, 006, 007, 008)

Fuel Usage		Fuc	el Heat Content	Heat Input per Year				
	Natural Gas		Natural Gas	_	Natural Gas Total			
	MMft3/yr		MMBtu/MMft3		MMBtu/yr MMBtu/yr			
nit 3A - 170 MW gas turbi	ne with gas-fired HRSG	Unit 3A - 170 MW gas turbii	ne with gas-fired HRSG	Unit 3A - 170 MW gas	turbine with gas-fired HRSG			
2012	11159	2012	1000	2012	11159000 11159000			
2011	9839	2011	1000	2011	9839089 9839089			
2010	10336	2010	1000	2010	10336000 10336000			
2009	12377	2009	1000	2009	12377000 12377000			
2008	12034	2008	1000	2008	12034000 12034000			
nit 3B - 170 MW gas turbi	ne with gas-fired HRSG	Unit 3B - 170 MW gas turbii	ne with gas-fired HRSG	Unit 3B - 170 MW gas turbine with gas-fired HRSG				
2012	12349	2012	1000	2012	12349000 12349000			
2011	9989	2011	1000	2011	9989000 9989000			
2010	11847	2010	1000	2010	11847000 11847000			
2009	12145	2009	1000	2009	12145000 12145000			
2008	11932	2008	1000	2008	11932000 11932000			
Jnit 3C - 170 MW gas turbi	ne with gas-fired HRSG	Unit 3C - 170 MW gas turbi	ne with gas-fired HRSG	Unit 3C - 170 MW gas	turbine with gas-fired HRSG			
2012	11449	2012	1000	2012	11449000 11449000			
2011	10276	2011	1000	2011	10276000 10276000			
2010	11093	2010	1000	2010	11093000 11093000			
2009	12878	2009	1000	2009	12878000 12878000			
2008	12739	2008	1000	2008	12739000 12739000			
Init 3D - 170 MW gas turbi	ne with gas-fired HRSG	Unit 3D - 170 MW gas turbi	ne with gas-fired HRSG	Unit 3D - 170 MW gas turbine with gas-fired HRSG				
2012	12366	2012	1000	2012	12366000 12366000			
2011	10126	2011	1000	2011	10126000 10126000			
2010	10324	2010	1000	2010	10324000 10324000			
2009	12904	2009	1000	2009	12904000 12904000			
2008	12613	2008	1000	2008	12613000 12613000			



APPENDIX B

October 2013

Appendix B CEM Reports from Acid Rain Database Annual Reports

	•												_				
					NUN	_											
	EAOULT)	001001				NTHS_										SECONDAR'	Y CAPACITY
CTATE	FACILITY_	ORISPL_	OP_YEA		COD SUM_OP REP								HEAT_	UNIT_TYPE_	PRIMARY_FUEL_IN		_
STATE	NAME	CODE UNITID	R	STACKS E	_TIME D		GLOAD	SO2_MASS					INPUT	INFO	FO	FUEL_INFO	
FL	Manatee Power Plant	6042 MTCT3A			7628.4	12	1104724.9			0128	58.9010	706165.4110		,	le Pipeline Natural Gas		1910
FL	Manatee Power Plant	6042 MTCT3B			7546.1	12	1076395.4	3.515		0.014	61.923	696361.501			l∈Pipeline Natural Gas		1910
FL FL	Manatee Power Plant	6042 MTCT3C			8068.2	12	1161059.1	3.698		0.011	57.541	732475.648			le Pipeline Natural Gas		1910
FL	Manatee Power Plant	6042 MTCT3D	2008	S ARP	7982.3	12_		3.719	C	0.012	62.589	736635.971	12395336.4	51 Combined cyc	le Pipeline Natural Gas	Diesel Oil	1910
					31224.9		4486322.8				240.95						
FL	Manatee Power Plant	6042 MTCT3A	2009	ARP	7588.4	12	1161188.9	3.703	0	0.015	66.401	733562.146	12343569.1	19 Combined cyc	le Pipeline Natural Gas	Diesel Oil	1910
FL	Manatee Power Plant	6042 MTCT3B	2009	ARP	7439.0	12	1132457.3	3.656	0	0.015	64.520	724253.055	12187003.0	07 Combined cyc	le Pipeline Natural Gas	Diesel Oil	1910
FL	Manatee Power Plant	6042 MTCT3C	2009	ARP	7877.0	12	1194003.5	3.770	0	0.012	61.783	746786.625	12566125.1	59 Combined cycl	l∈Pipeline Natural Gas	Diesel Oil	1910
FL	Manatee Power Plant	6042 MTCT3D	2009	ARP	7895.7	12	1199140.8	3.841	0	0.011	62.166	760908.054	12803683.3	14 Combined cyc	le Pipeline Natural Gas	Diesel Oil	1910
					30800.1		4686790.5				254.87						
FL	Manatee Power Plant	6042 MTCT3A	2010	ARP	6479.5	12	948689.8	3.053	0	0.017	56.938	604753.121	10176112.3	03 Combined cyc	le Pipeline Natural Gas	Diesel Oil	1910
FL	Manatee Power Plant	6042 MTCT3B	2010	ARP	7414.3	12	1093069.7	3.547	0	0.014	61.745	702665.968	11823711.5	93 Combined cycl	l∈Pipeline Natural Gas	Diesel Oil	1910
FL	Manatee Power Plant	6042 MTCT3C	2010	ARP	6937.2	12	1022546.0	3.240	0	0.011	48.124	641828.609	10799917.5	00 Combined cycl	le Pipeline Natural Gas	Diesel Oil	1910
FL	Manatee Power Plant	6042 MTCT3D	2010	ARP	6454.1	12_	940295.3	3.030	0).017	58.125	600286.239	10100961.6	39 Combined cycl	le Pipeline Natural Gas	Diesel Oil	1910
					27285.0		4004600.9				224.93						
FL	Manatee Power Plant	6042 MTCT3A	2011	ARP	6242.8	12	1406180.0	2.952	0	0.013	47.750	584725.360	9839089.8	07 Combined cycl	le Pipeline Natural Gas	Diesel Oil	1910
FL	Manatee Power Plant	6042 MTCT3B	2011	ARP	6176.6	12	899977.2	2.997	0	0.009	43.245	593634.430			le Pipeline Natural Gas		1910
FL	Manatee Power Plant	6042 MTCT3C	2011	ARP	6545.6	12	1497410.7	3.083	0	0.012	47.455	610707.173	10276334.1	60 Combined cycl	le Pipeline Natural Gas	Diesel Oil	1910
FL	Manatee Power Plant	6042 MTCT3D	2011	ARP	6347.7	12	1452071.1	3.038	0	0.012	50.575	601775.863	10125988.2	85 Combined cycl	le Pipeline Natural Gas	Diesel Oil	1910
					25312.6	_	5255639.0	-			189.03			·	·		
FL	Manatee Power Plant	6042 MTCT3A	2012	ARP	6953.7	12	1659546.2	3.383	0	0.017	59.612	670075.057	11275321.1	23 Combined cvcl	∈ Pipeline Natural Gas	Diesel Oil	1910
FL	Manatee Power Plant	6042 MTCT3B	2012	ARP	7597.2	12	1824602.4	3.743		0.013	63.157	741465.624		,	e Pipeline Natural Gas		1910
FL	Manatee Power Plant	6042 MTCT3C	2012	ARP	7171.1	12	1716553.8	3.471	0	.013	54.846	687505.875			e Pipeline Natural Gas		1910
F L	Manatee Power Plant	6042 MTCT3D	2012	ARP	7618.2	12	1845964.4	3.755	0	.011	57.302	743851.642			e Pipeline Natural Gas		1910
					29340.1		7046666.8				234.92			•			



At Golder Associates we strive to be the most respected global group of companies specializing in ground engineering and environmental services. Employee owned since our formation in 1960, we have created a unique culture with pride in ownership, resulting in long-term organizational stability. Golder professionals take the time to build an understanding of client needs and of the specific environments in which they operate. We continue to expand our technical capabilities and have experienced steady growth with employees now operating from offices located throughout Africa, Asia, Australasia, Europe, North America and South America.

Africa + 27 11 254 4800
Asia + 852 2562 3658
Australasia + 61 3 8862 3500
Europe + 356 21 42 30 20
North America + 1 800 275 3281
South America + 55 21 3095 9500

solutions@golder.com www.golder.com

Golder Associates Inc. 6026 NW 1st Place Gainesville, FL 32607 USA

Tel: (352) 336-5600 Fax: (352) 336-6603

