



RTP ENVIRONMENTAL ASSOCIATES INC.®

AIR · WATER · SOLID WASTE CONSULTANTS

239 U.S. Highway 22 East
Green Brook, New Jersey 08812-1909
(rtpnj@rtp-environmental.com)

(732) 968-9600
Fax: (732) 968-9603

RECEIVED

APR 16 1998

**BUREAU OF
AIR REGULATION**

April 13, 1998

Mr. Brian Beals
USEPA - Region IV
100 Alabama Street, S.W.
Atlanta, Georgia 30303

Dear Mr. Beals:


As discussed, I've enclosed copies of the materials from the recent Orimulsion hearings that relate to the calculation of historical NO_x emissions. These include excerpts from the January hearing testimony, rebuttal, and surrebuttal, as well as recommended changes to the Conditions of Certification.

We still believe that the historical NO_x calculations have been done incorrectly and that the subsequent back-up by the applicant, submitted to the agency on January 22nd and 23rd and provided to us on April 3, 1998 is deficient. We responded to this issue separately in an April 8, 1998 letter, which is also enclosed. Additionally, it is my understanding that Administrator Hankinson was sent a full copy of our overall comments by Thomas W. Reese, Esq. on March 30, 1998.

Should you wish to discuss these attachments or our other comments, please feel free to contact me at the above telephone number.

Sincerely,

RTP ENVIRONMENTAL ASSOCIATES, INC.®


Donald F. Elias
Principal

DFE/mpj

cc: G. Worley/C. Fancy/L. Curtin/W. Corbin/Proj. File: HKOR

239 U.S. Highway 22 East • Green Brook, New Jersey 08812

$$= (732) \ 968 - 9600 =$$

LETTER OF TRANSMITTAL

TO Mr. Clair Fancy
FDEP-Bureau of Air Regulation
111 South Magnolia, Suite 4
Tallahassee, FL 32301

Date: 04-14-98 **Proj. ID:** HKOR

WE ARE SENDING YOU: ☒ Attached ☐ Under separate cover

VIA: ☐ 1st Class Mail ☒ Federal Express ☐ Hand Delivery ☐ Other_____

THE FOLLOWING ITEMS: 2nd Day

[illegible]

THESE ARE TRANSMITTED AS CHECKED BELOW:

☐ For approval ☐ For review and comment ☐ Resubmit ____ copies for approval
☒ For your use ☐ Copies returned after loan ☐ For signature
☐ As requested ☐ Returned for corrections

REMARKS _____

COPY TO: _____

SIGNED: _____

If enclosures are not as noted, kindly notify us at once.

RECEIVED

APR 16 1998

BUREAU OF
AIR REGULATION

TABLE OF CONTENTS

1. EXCERPTS FROM KENNARD KOSKY TESTIMONY REGARDING HISTORICAL NO_x EMISSIONS
2. EXCERPTS FROM DONALD F. ELIAS TESTIMONY REGARDING HISTORICAL NO_x EMISSIONS
3. EXCERPTS FROM KENNARD KOSKY REBUTTAL REGARDING HISTORICAL NO_x EMISSIONS
4. EXCERPTS FROM WRITTEN PROFFER OF DONALD F. ELIAS SURREBUTTAL REGARDING HISTORICAL NO_x EMISSIONS
5. CSX RECOMMENDED CHANGES TO CONDITIONS OF CERTIFICATION
6. MARCH 17, 1998 LETTER TO BRIAN BEALS REGARDING ADDITIONAL WRITTEN INFORMATION CONCERNING RTP'S COMMENTS
7. APRIL 3, 1998 FACSIMILE FROM MR. CLAIR H. FANCY OF FDEP WITH THE JANUARY 22 and 23, 1998 CORRESPONDENCE
8. APRIL 8, 1998 LETTER TO MR. CLAIR H. FANCY OF FDEP REGARDING JANUARY 22 AND 23, 1998 MEMOS FROM MR. KENNARD KOSKY

PAGE 17 SHEET 5

493

Q Would you please briefly summarize the revised and additional conditions in Attachment A to the order of remand that are related to air emissions.

A There were two substantial changes involving air emissions in the remand. The first involved lowering the PM emission rates from that considered at the 1995 hearing.

The second one was lowering the emissions of nitrogen oxides again from that considered in the 1995 hearing.

(FP&L Exhibit No. R-132 marked for identification.)

(FP&L Exhibit No. R-133 marked for identification.)

BY MR. CUNNINGHAM:

Q Mr. Kosku, have you prepared a chart showing particulate matter emissions from the Manatee Plant and comparing historical emissions with those contemplated during the 1995 hearing and the currently proposed emission rates?

A Yes, I have.

Q Is this document that is marked as FP&L R-132 a copy of the chart you prepared?

A Yes, it is. This is an exhibit of particulate matter emission rates that I prepared.

PAGE 18

494

Q If you would, Mr. Kosku, using the enlarged version of this exhibit to your right, please explain the particulate matter emission rates that are depicted.

A This particular exhibit has four columns. The far left column shows emission rates in pounds per million BTU, or mass per input in tons per year.

Three columns that I have supplied information are the historical emissions when firing oil. Historically the pounds per million BTU rate is 0.125 pounds per million BTU. That's a maximum rate for the facility.

Historical 1993-'94 emission rates which are representative of actual historical emissions and, as I have testified previously, were greater than 1.768 tons per year. The actual permitted rate for the facility, the maximum as a cap, is actually close to 9,589.

In the 1995 hearing, proposed maximum emission rate for the facility was 0.83 pounds per million BTU, or about an 80 percent decrease from what was historical operating norms.

The 1995 hearing, the maximum cap of emissions in tons a year was equivalent to a conservative estimate of the historical emissions, that is low estimate of historical emissions of 1.768.

VOLUME 5
PAGE 19

495

What's considered today is an emission rate a maximum of 0.82 pounds per million BTU for particulate matter and an emissions cap of 858 tons a year, which is about half of that considered in the 1995 hearing.

Q Have you prepared a chart showing nitrogen oxide emissions from the Manatee Plant comparing historical emissions with those contemplated during the 1995 hearing and the currently proposed emission limits?

A Yes, I have.

Q I show you document marked as FP&L R-133 and ask you if that is the chart you prepared?

A Yes, it is. This is a chart of the NOx or nitrogen oxides emission rates that I prepared.

Q Again, if you could step to the enlarged version and perhaps slide it out.

A What I might do is put it here, this chart.

Q Using that version, if you could please explain the nitrogen oxide emissions rates depicted.

A This chart is similar to the chart on particulate matter emission rates in that there are four columns. The only exception, we added another row for tons per day. I will explain the emission rates basis.

PAGE 20

496

The pounds per million BTU on this chart represents a 30-day rolling average. What a 30-day rolling average is if today is a day and you want to calculate that, you take 29 previous days and you average that to get a 30-day rolling average. Now tomorrow, you would drop off maybe one of those days and collect 29 days. So each day you effectively have a new 30-day rolling average that has to be calculated. When this is used as a compliance mechanism, essentially a plant has to comply each day with this 30-day rolling average.

In the chart I also have tons per day during the ozone season as well as tons per year.

Historically, on oil — and again, the maximum emission rate for the plant on a 30-day rolling average is .3 pounds per million BTU.

The actual average emissions during the ozone season historically for the plant during high ozone days is 34.6 tons a day.

The 1993-'94, representative actual historical emissions is 7.318 tons a year. This is in contrast to the actual permitted rate of 22.788 tons a year.

In the 1995 hearing, the emission rates contemplated were 0.83 pounds per million BTU on a

PAGE 21 SHEET 6

497

1 30-day rolling average, a maximum ton per day of 42.2
2 and a maximum cap of NOx emissions of 13,418 tons a
3 year.

4 Today, what's being contemplated is an
5 emission rate of 0.15 pounds per million BTU, about
6 half the rate currently at the plant firing oil, an
7 emissions cap of historical emissions that represent
8 high ozone days of 34.6 tons a day, and the maximum cap
9 per year is kept at the historical rate of 7,318 tons.

10 MR. CUNNINGHAM: At this time we would
11 offer these two exhibits, FP&L R-132 and FP&L
12 R-133.

13 MR. CURTIN: No objection.

14 THE COURT: They are both received.
15 (FP&L Exhibit R-132 received in evidence.)
16 (FP&L Exhibit R-133 received in evidence.)

17 BY MR. CUNNINGHAM:

18 Q Mr. Kosky, is there any fundamental
19 difference in the NOx control technology now proposed
20 for the Manatee Orisulson conversion project from that
21 contemplated during the 1995 certification hearing?

22 A No. There is no difference in the air
23 pollution control technology contemplated at the 1995
24 hearing when low NOx burners and reburn were
25 considered.

PAGE 22

498

1 In fact, I testified at the 1995 hearing
2 that emission rates could be lower than 0.23 pounds per
3 million BTU.

4 The only question at that time was how much
5 lower emission rates could be.

6 MR. CURTIN: I would object to the
7 monologue. I think Mr. Cunningham asked if there
8 was any difference in the technology between the
9 1995 hearing and now. He is explaining. I think,
10 his emissions calculations, et cetera.

11 THE COURT: All right. You may ask your
12 next question.

13 BY MR. CUNNINGHAM:

14 Q Mr. Kosky, was there a question during the
15 1995 hearing regarding whether the technology proposed
16 to achieve emission rate lower than 0.23 pounds per
17 million BTU rate which was proposed as a permit limit?

18 A Yes, there was.

19 Q What was that question?

20 A The question was whether or not lower rates
21 could be achieved.

22 Q Was there some provision made in the
23 conditions at that time to assess that question?

24 A Yes, there was. There was a NOx reduction
25 team that was included in the conditions, providing

VOLUME 5
PAGE 23

499

1 engineering consensus on how low the emission rate
2 should be.

3 Q And what is your understanding of whether
4 there has been any progress made, despite the fact that
5 the project was not approved and therefore, the NOx
6 reduction team was not able to do what was contemplated
7 but what was your -- what is your understanding what
8 progress has been made towards analyzing that question
9 of how low the proposed technology could get at the
10 Manatee Plant?

11 A In 1995, the design process was only in
12 initial stages. Since that time, over two years ago,
13 there has been additional developmental work that has
14 provided assurance on what the actual emission rates
15 could be. In fact, the vendors have optimized low NOx
16 burner and reburn configuration to provide that
17 assurance.

18 Q Mr. Kosky, in your opinion, is the annual
19 cap on NOx emissions which is now proposed of 7,318
20 tons per year scientifically and technically achievable
21 with the NOx control technology proposed for the
22 project, assuming the Manatee Plant operates at an 87
23 percent annual capacity factor?

24 A Yes, it is.

25 Q What is the basis of your opinion?

PAGE 24

500

1 A My opinion is based on the information
2 supplied by ICL and EER, that I have concluded that an
3 annual average emission rate of 0.125 pounds per
4 million BTU can be achieved. At this emission rate, 87
5 percent capacity factor for the plant will equate to
6 7,318 tons a year.

7 My conclusion was reached based on the
8 Orisulson test burns, information supplied by the
9 Department of Energy and EPA on reburn technology, the
10 data supplied in performance estimates made by ICL and
11 EER as well as an actual demonstration of Orisulson
12 reburn at the Hennepin plant.

13 Q You mentioned that you reviewed information
14 supplied by ICL. Did that include technical guarantees
15 regarding NOx emissions?

16 A Yes, it did.

17 Q What is your understanding of the
18 willingness of ICL's successor ABB to provide such
19 guarantees?

20 A My understanding is that they have
21 reconfirmed their technical guarantee of 0.24 pounds
22 per million BTU.

23 Q In your opinion, is the NOx emission rate of
24 0.15 pounds per million BTU on a 30-day rolling average
25 scientifically and technically achievable with the NOx

PAGE 25 SHEET 7

581

1 control technology proposed for the project?

2 A Yes, it is.

3 Q What is the basis of that opinion?

4 A The basis is the case information that was

5 supplied by ICL and EER. The 30-day rolling average

6 has a higher emission limit because of the shorter

7 averaging time. This accounts for any operational

8 variabilities that may occur in the operation of the

9 plant.

10 Q When you refer to a shorter averaging time,

11 what are you comparing the 30-day rolling average to?

12 A An annual average, for example, you have 30

13 days compared to an annual period.

14 Q Mr. Kosky, in your opinion, is the daily cap

15 on NOx emissions in the ozone season of 34.6 tons per

16 day scientifically and technically achievable with the

17 NOx control technology proposed for the project?

18 A Yes, it is.

19 Q What is the basis for your opinion?

20 A Again, the basis is the ICL and EER

21 information that I had cited earlier. The cap is

22 equivalent to 0.188 pounds per million BTU. If the

23 plant were to operate at 24 hours a day at 100 percent

24 load, the technology can clearly meet this emission

25 limit.

PAGE 26

582

1 Q Turning to particulate matter, is there any

2 fundamental difference in the particulate matter

3 control technology now proposed for the project from

4 that contemplated during the 1995 certification

5 hearing?

6 A No.

7 Q And how would you characterize whatever

8 changes had been made with respect to that control

9 technology since the December 1995 hearing?

10 A The control technology considered at the

11 1995 hearing, as is today, is what's called

12 electrostatic precipitators or ESP. The only change

13 has been the efficiency of the ESP has been increased

14 to 94 percent from that originally contemplated of 90

15 percent.

16 In more practical terms, an ESP, an

17 important parameter of the ESP is the surface area.

18 That has been increased by about 20 percent.

19 The amount in more common terms originally

20 was contemplated to have about 17 acres per unit of

21 collection area. Now it's close to 21 acres of

22 collection area. This can achieve the emission rate of

23 .02 pounds per million BTU.

24 Q Mr. Kosky, let me show you what was marked as

25 Exhibit FP&L R-53 and ask you first if you can identify

VOLUME 5
PAGE 27

583

1 this document.

2 A Yes, I can. This shows the emissions on

3 Drimulsion, annual emissions of particulate matter, and

4 I prepared this exhibit.

5 (FP&L Exhibit No. R-53 marked for

6 identification.)

7 BY MR. CUNNINGHAM:

8 Q I believe we have an enlarged version up in

9 the front. If you can unveil that and use that, please

10 explain what is shown.

11 A This shows the annual emissions of

12 particulate matter from the boiler. I have broken down

13 the particulate matter into two components, total

14 particulate matter and the particulate matter that is

15 shown here as PM 2.5.

16 PM 2.5 is particulate matter with an

17 aerodynamic diameter of 2.5 microns or less. It's a

18 smaller subset of the total particulate matter.

19 The emission rate on an annual basis of .3

20 pounds per million BTU is reduced by the ESP by 94

21 percent. This results in an emission rate of less than

22 .02 pounds per million BTU.

23 The gas stream with particulate then goes to

24 the flue-gas desulfurization system. Although the

25 flue-gas desulfurization system's primary purpose is

PAGE 28

584

1 sulfur dioxide control, it also removes particulate

2 matter.

3 I have conservatively estimated that 20

4 percent of the total particulate matter would be

5 removed by the FGD system. That results in an emission

6 rate of .0144 actually, and on annual basis, at 87

7 percent capacity factor, results in emissions of 840

8 tons per year.

9 Q Mr. Kosky, in your opinion, are particulate

10 matter emission rates of 0.2 pounds per million BTU and

11 840 tons per year from the Manatee Plant stacks

12 scientifically and technically achievable with the

13 pollution control technology proposed for the project?

14 A Yes.

15 Q And what is the basis of your opinion?

16 A The basis of my opinion is information

17 supplied by the ESP vendor, Pure Air, and I have

18 concluded that emission rate of .02 pounds per million

19 BTU can be achieved.

20 This is based on specific design information

21 that has been provided, the configuration of the ESP

22 and the resulting efficiency.

23 Within that information is information

24 supplied by Mitsubishi Heavy Industries, or MHI, the

25 actual designer of the ESP who has actually experienced

PAGE 33 SHEET 9

509

1 Q Mr. Kosky, what is your opinion regarding
2 whether there would be an increase in the emission of
3 small particulate submitted by the Manatee Plant firing
4 Orimulsion compared with those historically emitted by
5 the plant?

6 A There would be a decrease of small
7 particulates.

8 MR. CUNNINGHAM: We would move exhibits FP&L
9 R-53 and FP&L R-54.

10 THE COURT: They are received.
11 (FP&L Exhibit R-53 received in evidence.)
12 (FP&L Exhibit R-54 received in evidence.)

13 BY MR. CUNNINGHAM:

14 Q Mr. Kosky, apart from what you just
15 testified about, will there be any other reductions in
16 PM 2.5 levels in the ambient air as a direct result of
17 the Manatee project?

18 A Yes, there will be.

19 Q Can you explain your answer.

20 A The ambient PM 10 (sic) concentrations are
21 made up, to a large degree, by particles formed from
22 gases emitted from air pollution sources. One of those
23 gases is sulfur dioxide. In fact, 40 to 50 percent of
24 the PM 2.5 in the atmosphere is particulate sulfates or
25 particles formed from the emissions of SO₂, sulfur

PAGE 34

510

1 dioxide.

2 Q Let me interrupt you, just because I believe
3 you may have said that you were referring to PM 10. Is
4 that what you intended?

5 A PM 2.5, the small particles. These small
6 particles are formed from gases, and as a result of the
7 project, there is going to be a decrease in the amount
8 of sulfur dioxide emissions emitted. In fact, as I
9 testified in the 1995 hearing, there is about 13,000
10 tons of sulfur dioxide less than historical emissions.

11 This would result in about 2,000 tons per
12 year less PM 2.5 in the Tampa Bay region as a result of
13 that decrease in sulfur dioxide emissions.

14 When combined with the decrease of solid
15 particles as well as the decrease of gaseous emissions,
16 the environment will see a substantial reduction in PM
17 2.5 emissions as a result of the project.

18 Q Mr. Kosky, have the characteristics of
19 particles emitted from the Manatee Plant firing
20 Orimulsion, other than particle size, been evaluated?

21 A Yes, they have.

22 Q And what evaluation are you aware of?

23 A In the 1995 hearing, I had previously
24 testified that at a higher emission rate of .03 pounds
25 per million BTU, there would be a decrease in metals

VOLUME 5
PAGE 35

511

1 which make up a portion of the particulate matter.
2 With more particulate control for the project and less
3 particulate emissions, those metals will decrease.

4 This important constituent of fly ash will
5 be beneficial as a result of the project.

6 Q In the 1995 certification hearing you
7 assumed that prevention of significant deterioration
8 review was applicable for two pollutants, NO_x and
9 carbon monoxide under FDEP's air rules. Is that still
10 a valid assumption?

11 A No.

12 Q What not?

13 A The emissions of nitrogen oxides back in
14 1995, as I have shown on one of my exhibits,
15 increased. With the consideration of going to 7,318
16 tons a year as a federally enforceable limit of the
17 permit, there will be no net increase in emissions.

18 The emissions of nitrogen oxides, in fact,
19 would not require PSD review since there is no
20 increase.

21 It would also not require the consideration
22 of what I had previously testified as Best Available
23 Control Technology, which is part of PSD review.

24 However, even though BACT does not apply,
25 the emission rates proposed today are consistent with

PAGE 36

512

1 and, in fact, lower than BACT limits on brand-new
2 sources that have been operating in Florida. In fact,
3 the emission rates are lower than several brand-new
4 plants that have been operating in the 1990s at
5 emission rates of .17 pounds per million BTU.

6 MR. CUNNINGHAM: We have no further
7 questions at this time and would tender the
8 witness for cross-examination.

9 MR. BEASON: Your Honor, the Department has
10 some questions. I was wondering as to the
11 protocol. Should we follow Mr. Cunningham?

12 THE COURT: Yes, I think so.

13 CROSS-EXAMINATION

14 BY MR. BEASON:

15 Q My understanding from your direct
16 examination is that you provided the Department with a
17 professional engineer's statement with regard to the
18 pending permit application.

19 A Yes, I did.

20 Q And it's my understanding -- or was that
21 professional engineer's statement, was it signed and
22 sealed by you in your capacity as a registered Florida
23 professional engineer?

24 A Yes, it was.

25 Q As a registered Florida professional

PAGE 37 SHEET 18

513

1 engineer, do you have an opinion as to whether the
2 permit application that's presently pending provides
3 the Department with reasonable assurance that the FPL
4 facility can comply with the proposed emission rate for
5 particulate matter of .82 pounds per million BTU?

6 A Yes, I do.

7 Q Could you tell the Judge what your opinion
8 is?

9 A We have provided information regarding the
10 designs of both the reburn as well as the ESP. We have
11 supplied intents for guarantees to the Department. We
12 had discussions with the Department as well as the PE
13 certification.

14 Q Again, with particulate matter, do you have
15 an opinion as to whether the proposed Oxidation
16 conversion project, whether the permit application
17 provides reasonable assurance that the facility can
18 comply with the 858 ton per year limit on particulate
19 matter?

20 A Yes.

21 Q What's your opinion?

22 A My opinion is we have supplied design
23 information, calculations; we supplied the intent to
24 guarantee as well as a professional engineering
25 statement and had discussions with the Department and

VOLUME 5
PAGE 39

515

1 If implemented, could comply with the 7,318 tons per
2 year limit on emissions?

3 A Yes, I do.

4 Q And your opinion?

5 A My opinion is that we provided that
6 assurance in terms of intents from the vendors.
7 engineering information and PE certification.

8 MR. BEASON: No further questions, Your
9 Honor.

10 THE COURT: Mr. Curtin.

11 CROSS-EXAMINATION

12 BY MR. CURTIN:

13 Q Mr. Kosku, is any of the information that
14 you have been discussing today in the site
15 certification application?

16 A No.

17 Q It's not?

18 What is reasonable assurance? Is that an
19 engineering term?

20 A I would say that's both a regulatory and
21 engineering term.

22 Q You indicated, I think, in response to
23 several questions that you provided a professional
24 engineering stamp. I guess you would call it, or seal
25 on the changes to the project of air changes; is that

PAGE 38

514

1 their staff.

2 Q Moving now to the NOx emission rates for
3 ease of reference if you need to, but I am referring to
4 FPL Exhibit R-133.

5 Do you have an opinion as to whether the
6 permit application provides the Department with
7 reasonable assurance that the proposed FPL project, if
8 implemented, would comply with the .15 pounds per
9 million BTU limit for NOx emission?

10 A Yes, I do.

11 Q Again, what is your opinion?

12 A My opinion is we provided that assurance
13 through design information, PE certification,
14 discussions with the department and intents to
15 guarantee that level from vendors.

16 Q Finally, that opinion of yours is predicated
17 on the 36-day rolling average?

18 A Yes.

19 THE COURT: Predicated on what?

20 MR. BEASON: The 36-day rolling average.

21 BY MR. BEASON:

22 Q One final question, Mr. Kosku. Again, to
23 the question of reasonable assurance, do you have an
24 opinion as to whether FPL has provided the Department
25 with reasonable assurance that the proposed facility,

PAGE 40

516

1 correct?

2 A I provided a professional engineer's
3 statement, yes, that's correct.

4 Q When did you do that?

5 A That was in December, around December 18th
6 of 1997.

7 Q You indicated that you made an assessment of
8 which pollutants would be subject to PSD review; is
9 that correct?

10 A Yes.

11 Q How did you go about making that assessment?
12 Just kind of briefly explain what you did.

13 A We looked at what's called actual emissions
14 of the facility as defined by FDEP regulations and
15 looked at the emissions of the facility after it would
16 begin operation.

17 Q So if I am understanding correctly, you
18 compared the past performance of the equipment at the
19 facility with the projected future?

20 A That's basically how it's done in simple
21 terms, yes.

22 Q Then what do you do? You see if there is a
23 difference?

24 A You see if there is a difference between
25 emissions historically versus the future. If there is

PAGE 41 SHEET 11

517

1 a. what's called a significant net increase, then there
2 is a certain review required.

3 Q Are there any regulatory requirements for
4 determining whether there is a significant net
5 increase?

6 A Yes, there are.

7 Q Do you know what those are?

8 A There is a specific definition within the
9 Department's rules of what's called actual emissions,
10 and that's a pretty specific definition.

11 There is also in the Department's rules a
12 discussion of how you go about looking at what's called
13 contemporaneous increases and decreases. If, in fact,
14 they occurred at the plant, as well as the significant
15 net emission rates. It's a criteria from which you
16 make that calculation.

17 Q So the regulations, I take it, sort of lay
18 out a little road map on how to do this?

19 A I wouldn't say you could characterize it as
20 a road map, but it's a lot more complicated than that.

21 Q A winding road map?

22 A That's probably a better characterization.

23 Q Okay. Is it a requirement that when you
24 determine the past actual emissions, that would be done
25 under conditions that are representative of the

VOLUME 5
PAGE 43

519

1 that are emission caps for the facility. The criteria
2 for determining whether or not prevention of
3 significant deterioration apply is based on tons per
4 year emissions. That will be a federally enforceable
5 emission limit in the PSD permit as well as the site
6 certification.

7 Q So the ton cap would be the enforceable
8 limit?

9 A Well, the ton cap is the controlling limit
10 for seeing whether or not you fit the criteria. There
11 is also the other emission limits which also would be
12 federally enforceable that I previously discussed.

13 Q Those would be -- could you just detail them
14 for me?

15 A For nitrogen oxides, .15 pounds per million
16 BTU on a 30-day rolling average. There is also the
17 emissions cap for NOx. For particulate, it's .22
18 pounds per million BTU.

19 Q Turning to the emission caps, I guess it
20 would be the B40 ton particulate stack emission and the
21 7,318 for nitrogen oxide. How would those be enforced?

22 A That would be enforced by providing
23 information to the Department on what the actual
24 emissions would be. And in fact, the previous
25 conditions of certification as a result of the 1995

PAGE 42

518

1 operation?

2 A That's part of the definition; that's
3 correct.

4 Q Is that what you did in this case?

5 A Yes.

6 Q When you determine the future performance of
7 the facility after the change, are you calculating what
8 is known as the potential to emit?

9 A You are calculating the potential to emit.
10 was.

11 Q Is it your understanding that it's
12 acceptable to place limits on the potential to emit to
13 have the facility avoid that PSD review?

14 A Well, it includes federally enforceable
15 limits on -- for example -- hours of operation could be
16 a capacity factor in this case, was.

17 Q Those limits have to be federally
18 enforceable?

19 A That's correct.

20 Q What are the federally enforceable limits
21 here for the pollutants that you described that are not
22 going to be subject to PSD review? And I guess
23 primarily I would be interested in particulate matter
24 and nitrogen oxide.

25 A There are emission limits in tons per year

PAGE 44

520

1 hearing includes such a statement.

2 Q Are there short-term limits on the amount
3 of, I guess, tons of pollutant that go out of the
4 stack? Are there any short-term limits or is it just
5 an annual number?

6 A No, there is an annual limit, there is
7 short-term limits. For example, on nitrogen oxides,
8 that's 30-day rolling average. The plant will have to
9 submit what's called a quarterly report to the
10 Department to demonstrate they comply with the nitrogen
11 oxide limit of .15 each quarter.

12 Q The .15 is the short-term limit?

13 A Yes.

14 Q But there are no short-term limits on the
15 total tons per year, are there?

16 A There is a short-term limit for tons a day,
17 and there is a limit on the tons per year.

18 Q Okay.

19 A If I can clarify, it's an annual emissions
20 cap. It's hard to get a short-term limit for an
21 emissions cap. They are two different --

22 Q That's kind of my point. What I was
23 wondering was: How is the Department going to come in,
24 let's say, after six months of operation and make a
25 determination whether or not you are on the way to

PAGE 45 SHEET 12

521

1 complying with the 7,318? Can you do that?

2 A Very easily. In quarterly reports, for NOx

3 tests there will be a continuous emission monitoring.

4 This particular monitor calculates emission rates on a

5 pound per million BTU. It can calculate emission rates

6 on a pounds per hour, it can calculate emission rates

7 on pounds per day or tons per day. It can calculate

8 both tons as well as for pounds per million on a 36-day

9 rolling average as well as any other averaging time you

10 want.

11 In effect, there is an instrument to provide

12 assurance to the Department that this 7,318 tons a year

13 would not be exceeded.

14 Q What you are describing, I think, are a

15 number of methods that they could make an assessment.

16 But those are not permit conditions: are they?

17 A The emission rates are permit conditions.

18 The use of the CEM in compliance will be a permit

19 condition.

20 Q The use of the CEM, but there is no

21 milestone that the Department can use to compare your

22 performance against. There is nothing in the permit

23 other than .15 and 7,318: is that right?

24 A Well, it would be no different than really.

25 In my judgment, any other sources that are submitted

VOLUME 5
PAGE 47

523

1 historical actual emission figures?

2 A The historical actual emissions, as I

3 testified, is based on the 1993-'94 emission rates

4 based on the actual operation of the plant during those

5 years.

6 Q Okay. The emission rate that you are

7 speaking of, is that a tested emission rate or is that

8 the permit limit emission rate?

9 A The calculation is based on the .3 pounds

10 per million BTU.

11 Q And what is the .3 pounds per million BTU?

12 A That's the emission rate.

13 Q Is that a permit limit or is that based on

14 testing?

15 A That's a permit limit.

16 Q And would you just explain to me the

17 calculation that you went through to -- what did you do

18 with the .3?

19 A You calculate the actual heat input for the

20 whole year from the plant and you use the .3 to make

21 the calculation. That ultimately winds up to be the

22 7,318 tons per year.

23 Q How does the fuel usage enter into that?

24 A It's the amount of BTUs that goes into the

25 furnace.

PAGE 46

522

1 quarterly report.

2 Q Excuse me. That's not the question.

3 The question is, is there anything in the

4 permit that, other than the .15 or the 7,318 --

5 A It doesn't provide what the Department would

6 do in reviewing information supplied by an applicant.

7 Q Right. But there is nothing in there, there

8 is no intermediate milestone, there is nothing they can

9 look at, no short-term hours of operation other than

10 the whole cap for the year and the emission limit to

11 determine compliance: is that right?

12 A Well, it doesn't specify how the Department

13 saw do its job with the information it gets.

14 Q Yeah. That's right. But there is nothing

15 that they can enforce other than the .15 and the 7,318:

16 is that correct?

17 A Well, that's not -- well, those are emission

18 limits, yes.

19 Q Those are --

20 A Yes, those are enforceable emission rates as

21 well as the tons per day limit as well as during the

22 ozone season.

23 Q Right. With respect to the nitrogen oxide

24 emissions that you described for us, could you tell us

25 how you arrived at the actual emission figures, the

PAGE 48

524

1 Q So is it accurate to say what you did was

2 take the .3, which is the permit limit, and then

3 essentially calculate that based on all the barrels of

4 fuel that were burned?

5 A That's correct.

6 Q Okay. Did the plants operate that way? In

7 other words, did they operate at .3 for each and every

8 barrel of fuel that they burned?

9 A Back in 1993 and 1994, there is really no

10 way of knowing. They didn't have continuous emission

11 monitors. It's my judgment that on an annual average

12 basis, the .3 would characterize and be representative

13 of their emissions.

14 Q Okay. Did the plants always operate that

15 way?

16 A We have no way of knowing. They likely

17 don't.

18 Q Okay. Is there stack test data available

19 for nitrogen oxide emissions for the years 1993 and

20 1994 for these plants?

21 A There is compliance data available, stack

22 test data.

23 Q Stack test data. Okay. Did you use that

24 information in arriving at the actual emission figures?

25 A I didn't use that information, no.

PAGE 49 SHEET 13

525

1 Q Why didn't you use that information?

2 A That information is a single stack test

3 which I do not consider representative of all the

4 operation for a year. In fact, the Department's staff,

5 as well as their regulations, also don't consider a

6 stack test to be representative.

7 Q Is the stack test the information that you

8 submit to the Department of Environmental Protection to

9 demonstrate compliance with the permit limits?

10 A It's a benchmark for a specific operating

11 condition that is a test that demonstrates compliance

12 for that particular standard.

13 Q Okay. Is it fair to say that the nitrogen

14 oxide emission from the facility would be the highest

15 when the loads were the highest?

16 A In general, that's true.

17 Q How is the stack test performed? Is it

18 performed at a high load?

19 A It's generally performed between 90 and 100

20 percent load.

21 Q Have there been any changes to the

22 facilities since the 1993-'94 period that might affect

23 the nitrogen oxide emissions?

24 A There have been changes at the plant that

25 when operated may influence the average nitrogen oxide

PAGE 50

526

1 emissions. I would say, yes.

2 Q I guess what I am thinking, there have been

3 some previous testimony about the installation of

4 something called a steam atomization system.

5 A That's correct.

6 Q Would that have any impact on nitrogen oxide

7 emissions?

8 A It would have a potential impact of allowing

9 the combustion process to be better controlled and

10 therefore meet an average NOx emission rate.

11 Q Is that another way of saying it would

12 result in lower nitrogen oxide emissions?

13 A Its primary purpose isn't that.

14 Q I understand that.

15 A But it can have an effect of reducing by

16 better combustion.

17 Q Okay. Do these units have continuous

18 emission monitoring equipment on them presently?

19 A Yes, they do.

20 Q Do you know when that equipment was

21 installed?

22 A That equipment was installed in 1995 as

23 required by the Clean Air Act and subsequent

24 regulations.

25 Q Okay. Have you looked at the nitrogen oxide

VOLUME 5
PAGE 51

527

1 emissions rate at these facilities since the continuous

2 emission monitoring systems have been installed?

3 A I have looked at the emission rates, yes.

4 Q What do the data show?

5 A Well, the data show emissions of various

6 types: going from the short-term to long-term, before

7 the installation of CEMs, that there was no way to know

8 what the plant operated because it fluctuates.

9 The CEM data shows that on the same basis

10 that you would do a stack test, in fact NOx emissions

11 are higher than .3. In fact, some of the emissions are

12 up to .45 pounds per million BTU.

13 The 30-day rolling average, which is a

14 compliance, varies -- the highest one is near .3,

15 probably more in the range of .27 on some of the

16 units.

17 And the overall average is probably more

18 like .25 on an annual average. That's my estimate of

19 looking at it. I haven't committed that to memory.

20 Q Okay. Would those emissions be more

21 representative of actual emissions, those emission

22 limits, than the ones that were selected based on

23 permit condition in 1993 and '94?

24 A Not in a regulatory sense as defined by DEP

25 regulations. And they are not -- they may not be any

PAGE 52

528

1 different than what would have occurred if we had CEMs

2 in '93, '94.

3 Q It sounds a little different to me, and

4 maybe I missed something, but I thought you said that

5 the 30-day rolling average would be .27 as opposed to

6 .3, and the annual average would be in the range of

7 .25. Those both sound lower to me. Did I miss

8 something?

9 A As annual average, they would be. However,

10 I also mentioned that there are emission rates up to

11 .45 pounds per million BTU on a daily basis.

12 Q Right. But wouldn't you be using the 30-day

13 rolling average?

14 A Well, you would be using the 30-day rolling

15 average in terms of compliance, yes.

16 Q Mr. Kosku, with respect to the particulate

17 matter emissions, the historical actuals that you

18 determined, did you use stack test information for

19 that?

20 A Yes.

21 Q How did you account for the soot blowing

22 operation in making that calculation?

23 A I accounted for the soot blowing using that

24 particular information as a factor in the calculation.

25 Q Do you recall exactly how you used it? What

PAGE 53 SHEET 14

529

1 did you assume for soot blowing?

2 A I assumed 21 hours for soot blowing, which

3 was equivalent to the actual operation of the plant,

4 and three hours of steady state as far as the stack

5 tests are concerned.

6 Q Over what period of time?

7 A Well, I used that figure to calculate an

8 annual emissions which I have characterized as being

9 low.

10 Q I think you indicated that you assumed 21

11 hours of soot blowing and three hours of steady state.

12 Was that over a 24-hour period?

13 A Yes, I sort of averaged that over 24 hours

14 and used that information to calculate an annual

15 emission.

16 Q Does the permit allow soot blowing to take

17 place for 21 hours in a 24-hour period?

18 A It doesn't prohibit it, no.

19 Q There is no limitation?

20 A There is no limitations on soot blowing.

21 Q Would assuming 21 hours of soot blowing and

22 three hours of steady state over a 24-hour period,

23 would that result in representative emissions in your

24 opinion?

25 A In my opinion, it represents a low estimate

PAGE 54

530

1 of representative emissions for particulate matter,

2 was.

3 Q Why would it be a low estimate. Would you

4 soot blow 24 hours instead of 21?

5 A Well, it was a calculation that was done

6 using stack test data. As I previously testified, that

7 particular single stack test data may not be

8 representative of the whole plant. In fact, the

9 Department's rules indicate that that kind of approach

10 may not be scientifically valid.

11 Q Looking for a moment on, I guess, your

12 Exhibit FP&L R-53, you indicate an emission limit there

13 of .814 going into the stack, I guess: is that right?

14 A It's an emission rate of .8144 on an annual

15 basis.

16 Q It's .8144 as opposed to .814?

17 A Yes.

18 Q Is that an enforceable limit?

19 A The .8144 as an annual average at 87 percent

20 capacity factor results in a federally enforceable

21 limit of 848 tons per year.

22 Q Well, is it your judgment that if the

23 Department of Environmental Protection wanted to force

24 you to meet .8144 under the current state of the draft

25 permits, that they could do it?

VOLUME 5
PAGE 55

531

1 A Currently, no.

2 Q The limit is not in the permit?

3 A No, it's .82 as a maximum limit.

4 Q I believe you indicated in response to some

5 questions from Mr. Cunningham that you were basing your

6 opinion on the ability to meet the NOx limit on various

7 information that you received from the vendors: is that

8 correct?

9 A That is correct.

10 Q Is part of that information things that you

11 reviewed from ICL?

12 A It is.

13 Q Is there a contract between ICL and FP&L, to

14 your knowledge?

15 A To my knowledge, there is not.

16 Q Is there any guarantee that's currently in

17 effect on the emission limit?

18 A As I had testified, there is a

19 reconfirmation of a technical guarantee from the

20 original proposal that ICL submitted and ABB has

21 reconfirmed that.

22 Q And they have done that in writing?

23 A Yes, they have.

24 Q In a binding contract?

25 A Well, it's a letter of commitment. I can't

PAGE 56

532

1 characterize what a contract is.

2 Q When did that take place?

3 A I believe it's this month, there is a letter

4 that was submitted.

5 Q January of 1998?

6 A I believe so.

7 Q But your certification was submitted to the

8 Department in December?

9 A That's correct.

10 Q I believe you indicated earlier, Mr. Kosky,

11 that there had not been much of a change in the

12 technology with respect to the NOx emissions since the

13 '85 hearing. Do you recall that?

14 A Yes, there hasn't been any change in the

15 concepts, low NOx burners and reburn.

16 Q Has any of the technology been designed, to

17 your knowledge?

18 A They have had what I would characterize as

19 additional engineering work done and developmental work

20 since the 1985 hearing. And I would characterize that

21 as being a considerable amount.

22 Q Right. But it hasn't actually been designed

23 yet: has it?

24 A Well, the final system probably not has been

25 finally designed, no.

PAGE 81 SHEET 21

557

1 A Not 828 megawatts. There is, I know of at
 2 least 828 megawatts. There is other several hundred
 3 megawatt plants that are using reburn technology.
 4 Q What are the size of the Manatee units?
 5 A They are 828 megawatts on oil. 728 on
 6 Oriskany.
 7 Q So the only units you are familiar with that
 8 are using the reburn technology are in the 828 megawatt
 9 range, correct?
 10 A As far as the largest size I am aware of,
 11 that's correct.
 12 MR. NEILSON: No further questions.
 13 MR. KUMARICH: I have some questions.
 14 CROSS-EXAMINATION
 15 BY MR. KUMARICH:
 16 Q I would like to return to this issue of
 17 historical emissions from the Manatee Plant.
 18 Is there some precedent or industry standard
 19 for establishing historical emission standards?
 20 A There is a regulatory precedence of what's
 21 considered in determining actual emissions from a
 22 plant, and that's used to compare with future
 23 emissions, yes.
 24 Q And where are those established?
 25 A That is in the Department of Environmental

PAGE 82

558

1 Regulation rules, 62-210 and 62-212.
 2 Q Does that conform to the way you have
 3 established historical standards for this plant?
 4 A Yes, it does.
 5 Q Are you familiar with the number of hours of
 6 operation, total number of hours of operation of the
 7 Manatee Plant in 1993 and '94?
 8 A I recall seeing a number. I am not that
 9 familiar with the exact hours, no.
 10 Q From information we received from the DEP,
 11 from Mr. Joe Cox on November 28, 1997, this is MCAP
 12 Document Number 38, the information we received stated
 13 that the -- if you add the total hours of operation of
 14 both units for 1993 and '94, that total would come to
 15 just slightly over 22,000 hours, adding both units for
 16 both years.
 17 Do you feel that would be -- you want the
 18 document here so you can take a look at this? I am
 19 sorry, I only have one copy here. I will need to get
 20 that back.
 21 A That's what is characterized as the hours of
 22 operation, yes.
 23 Q Then the comparable figures for NOx
 24 emissions for 1993 and '94, which were the numbers that
 25 you used for establishing historical levels: is that

VOLUME 5
PAGE 83

559

1 correct?
 2 A That's correct.
 3 Q Actually, if you add these two together, '93
 4 and '94, you'd get a total of 14,396 according to their
 5 numbers, and that would average to -- divided by two
 6 would average to 7,198 annual NOx emissions in tons,
 7 which is just slightly less than the historical levels
 8 indicated for use, your use, which was 7,318 tons: is
 9 that correct?
 10 A This particular calculation on this exhibit
 11 shows that, yes. I can't account where it comes from,
 12 though.
 13 Q If we take the total hours of operation for
 14 '95 and '96, add those together, that's 19,235 hours
 15 total for both units. And you take the comparable
 16 annual NOx emissions for those two years and add those
 17 together, that comes up to 18,514 tons annual NOx
 18 emissions.
 19 You take the total number of hours of
 20 operation '93-'94 and divide those into -- divide that
 21 into the tons of NOx emissions, you get a rate there of
 22 -- 22,000 divided into 14,396 -- you get a rate of .654
 23 tons of NOx per hour emissions. You divide the total
 24 hours of operation in '95 and '96 into the total annual
 25 emissions of 18,514, you get a rate of .547 tons per

PAGE 84

560

1 hour.
 2 The difference between the .654 and .547 is
 3 .107, which is an improvement of 17 percent.
 4 How do you account for that difference
 5 between the hours of operation and NOx emissions
 6 between the composite of those two years, that is '93
 7 and '94 versus '95-'96?
 8 A That type of calculation using annual hours
 9 and tons quite frankly is a bit meaningless because the
 10 plant operates at different loads at different times.
 11 For example, it could operate full load at 50 percent,
 12 it could operate at 30 percent load. It could operate
 13 a couple days at 100 percent load and you get all
 14 different types of annual amounts of operation.
 15 Q We are discussing here average hourly
 16 rates --
 17 A Correct.
 18 Q -- of NOx emissions.
 19 A Correct. Your calculation --
 20 Q We are talking about total, total annual
 21 emissions which is what you are referring to in your
 22 historical emissions.
 23 A Your calculation presumes that the plant
 24 operates each hour the same way. I can tell you for a
 25 fact this is not the case.

PAGE 85 SHEET 22

551

1 Q What difference would that make in terms of
2 the total annual emissions?

3 A Quite frankly, very little. It would depend
4 on how the plant would be operating during the hours
5 it's operating.

6 Q Are you stating that the total annual
7 emissions in tons of NOx emissions here is -- that that
8 figure is incorrect?

9 A Well, I can't authenticate whether or not
10 it's correct. I could state that the annual tons in
11 1995-'96, is lower than what it was in '93 and '94.
12 Whether there is a difference in rates, you just cannot
13 make that kind of calculation. It's wrong.

14 Q If we take it on a percentage basis, we are
15 still indicating a percentage reduction of
16 approximately 17 percent, no matter how you calculate
17 that.

18 You are getting over the number of hours.
19 The number of hours and the nitrous oxide or NOx
20 emissions indicate that there was a substantial
21 difference between the hours of operation and the NOx
22 emissions between the composites of those two years.

23 A Yes. It is lower. Part of the reason which
24 I have calculated, they used lower fuel and I am aware
25 that at least one unit during 1996 had a forced outage

PAGE 86

552

1 during the summer when it would be expected to be
2 operating. A forced outage is, I guess in simple
3 terms, the plant broke, and it wasn't operating for
4 about a month and a half during the time it normally
5 would operate.

6 So 1996 it's lower.

7 Q Was there any other technology that was
8 instituted, any changes in the plant in that time frame
9 of 1994 to 1995 that might account for that difference
10 in NOx emissions?

11 A Not from the standpoint of plant operation.
12 There was the installation of, as I testified, steam
13 atomization which was used to better control the
14 combustion process because 1994 to '95 a CEM would now
15 be used to demonstrate compliance.

16 It had the artifact of potentially reducing
17 the rates, but you can't really tell from this data as
18 I testified. The rate, for example, on the mass basis,
19 the rates at higher loads were much higher than .3.

20 Q Are you stating that the institution of the
21 use of steam atomizers would not account for that
22 reduction in NOx emissions?

23 A In looking at the information, I would say
24 no. A big part of that difference is just how much the
25 plant operated.

VOLUME 5
PAGE 87

553

1 Q How would you compute the period of time
2 for operation of the plant? You are saying that the
3 difference is due to the amount of time that the plant
4 operated?

5 A Well, the difference, the plant operated
6 less in terms of its fuel used during 1995 and '96 as
7 compared to '93 and '94. That results in lower NOx
8 emissions. What effect steam atomization had, you
9 can't tell from this information.

10 Q But there is no correlation here between the
11 number of hours of operation and the reduction in NOx
12 emissions?

13 A That's because the plant, although it might
14 operate several hours, it may operate at different
15 loads. So it uses different fuel now and it has
16 different NOx emissions.

17 Q Okay. Has the ESP unit that is proposed for
18 use at the Manatee Plant, has that unit been used in
19 any other facility that is burning Orimulsion?

20 A As I testified, the ESP design is based on
21 designs from Mitsubishi Heavy Industries which has
22 experience in collecting Orimulsion fly ash in Japan.
23 In fact, I believe they are firing it at one of their
24 plants.

25 Q With that specific unit?

PAGE 88

554

1 A It's not identical, but the design, the
2 designs that are going to be incorporated into the
3 Manatee project are similar. Size might be different,
4 that kind of thing.

5 Q Is it safe to say you have no practical or
6 experimental evidence to indicate that the unit as you
7 have it designed will achieve the reduction in
8 particulate emissions that you state that will achieve?

9 A Well, there is lots of practical evidence of
10 the type of particulate that would be emitted from
11 Orimulsion can be collected by an ESP of this type of
12 design.

13 Q What is the size distribution of the
14 particulate emissions from burning Orimulsion?

15 A Burning Orimulsion typically, the majority
16 of the particles would be less than 10 microns in
17 diameter. Approximately 90 percent, conservative
18 estimate that I have previously testified, would be a
19 particle size of 2.5 microns in diameter or less.

20 Q Is it not true that the emissions from the
21 plant in Delhouie, the tests that were done
22 originally, that 50 percent of the particulates were
23 8.3 microns or less?

24 A I believe that's about correct, yes. Maybe
25 in the range of 40 to 50 percent. I can't remember

PAGE 93 SHEET 24

559

1 Q If I could go back again on that issue,
2 based on your answer to my prior question, when the
3 particulate matter goes through both ESP and the
4 flue-gas -- or the FGD, you all don't have any
5 particulate matter essentially left to escape out of
6 the stack?

7 A Well, there will be 848 tons a year being
8 emitted. That's the cap.

9 Q I understand that. In excess of the PM 2.5?

10 A It will all be -- it will all be PM 2.5 in
11 excess. In practicality, there will be some. You will
12 probably collect some, but virtually --

13 Q A smaller percentage than currently goes out
14 of the stack?

15 A Oh, yes.

16 Q In regard to FP&L Exhibit R-133, the
17 historical oil figures, these are historically
18 permitted or historical actual?

19 A The pounds per million is the 38-day rolling
20 average permitted rate. The tons per day and tons per
21 year are the historical actual based on 1993-'94.

22 Q And did I understand that the historical
23 actual was around -- the 38-day rolling average was .27
24 based on your testimony?

25 A My testimony was in reviewing data in

VOLUME 5
PAGE 95

571

1 as such a function as how the plant burns its fuel. It
2 did have a lot less fuel, one of which was a case of a
3 forced outage during one of those years.

4 Q Okay. I understand that. I am not sure
5 that answered my question.

6 Was there a reduction in the number of hours
7 during the first two-year period, '93-'94 to '95-'96?

8 A I think there may have been a reduction of
9 hours from the exhibit -- I don't recall that -- the
10 NCAP exhibit. From my knowledge, there definitely was
11 reduction in the amount of fuel burned.

12 Q Do you know for sure if there was a
13 reduction in the NOx emission rate during that period?

14 A There was -- I really can't say. There were
15 instances where the data was clearly above .3. In
16 fact, I seen data at .45 for a daily. Historically the
17 .3 was a three-hour test. How it operated in the past,
18 it's difficult to know because there wasn't any CEMs
19 that we could compare now with '95-'96.

20 MR. BARNEBEY: I have no further questions.

21 Thank you.

22 THE COURT: No other cross? Any redirect?

23 MR. CUNNINGHAM: No, Your Honor. We have no
24 questions.

25 MR. REESE: Could I move what I marked as

PAGE 94

579

1 1995-'96, that's my recollection of where 38-day
2 rolling averages might be.

3 Q You testified in regard to a NOx reduction
4 test that was being proposed with the 1995 recommended
5 order. Is that condition being proposed to be
6 eliminated by FP&L?

7 A Not to my knowledge. I think it's still in
8 the conditions of certification.

9 Q So to your knowledge, FP&L is still
10 recommending the NOx reduction test review that
11 information as it comes out and make changes as
12 appropriate?

13 A Yes, if the conditions of certification are
14 approved, FP&L would have to implement that test.

15 Q Certainly if they are approved.

16 In regard to a question Mr. Kuasrich asked,
17 is it my understanding there was a reduction in NOx
18 emissions from 1993 and '94 to 1995 and '96?

19 A There are reduction in emissions from 1993
20 to '94 compared to '95-'96, I mean reduction in the
21 last two years, '95-'96, yes.

22 Q Did I understand you also to say that the
23 plant was not operating as many hours during that
24 period?

25 A As I testified, the hours really don't play

PAGE 96

572

1 Minnesota-88 R-18, the three sheets I showed the
2 witness? They had previously been identified as
3 Florida Power & Light R-56 and R-55. Items 1 and
4 2.

5 THE COURT: All right. Is there any
6 objection? They will be received.

7 (Minnesota-88 Exhibit R-18 received in
8 evidence.)

9 MR. BEASON: Your Honor, I am again quite
10 sure of the protocol. I intended to ask the
11 witness questions on redirect.

12 THE COURT: Go ahead.

13 RE-CROSS-EXAMINATION

14 BY MR. BEASON:

15 Q Mr. Kosku, I realize you have been up for a
16 while and you have been asked a lot of different
17 questions by a lot of different lawyers. I would like
18 to direct your attention back. I believe you testified
19 there were no final design drawings for the low NOx
20 burners and for the reburn portion of the modifications
21 to the boiler.

22 A I testified there was no, I guess, final
23 designs. I guess I would characterize that as being
24 final design drawings. You could sort of characterize
25 it that way.

PAGE 45 SHEET 12

45

1 whether or not those CO limits would be met; and if
2 anything we feel they are aggressively set too low
3 which confused us since that was the one pollutant they
4 did claim PSD for, PSD applicability for.

5 Q Mr. Elias, what analyses have you performed
6 concerning toxic air pollutants from the proposed
7 projects?

8 A We looked at the proposed toxic emissions
9 that were in the application. We reviewed and
10 attempted to find materials on toxic emissions from
11 Orinulsion burning at other plants worldwide. We then
12 also looked at EPA's database that they were collecting
13 under the Clean Air Act to estimate hazardous air
14 pollutant emissions associated with electrical
15 utilities.

16 Q Do you have an opinion as to whether the
17 expected air toxic pollutants have been adequately
18 addressed by the applicant?

19 A Yes, I do.

20 Q What is that opinion?

21 A We believe they have not been adequately
22 addressed.

23 Q What is the basis for that opinion?

24 A Based on the EPA studies, there is a strong
25 indication that the sources are likely to have

PAGE 46

46

1 hazardous air pollutant emissions, especially organic
2 emissions.

3 There were a number of metal emissions
4 identified, toxic metal emissions that were addressed
5 in the application, but we have been able to find no
6 data published by Bitor or searching overseas where
7 measurements were made of organic, trace organic
8 species.

9 Therefore, we feel due to the lack of data
10 and the probability of their occurrence, the applicant
11 should be required to perform a testing program for
12 organic hazardous air pollutants similar to the study
13 that was performed for EPA. This would involve testing
14 dioxins, purines and 16 polycyclic organic matter
15 emissions. We are proposing on an annual basis
16 alternating units for the first five years, and then
17 having the data collected from that program subjected
18 to the health risk assessment that's already contained
19 in the modified conditions of certification.

20 Q Mr. Elias, what analyses have you performed
21 concerning nitrogen oxide emissions from the proposed
22 project?

23 A For nitrogen oxide, we looked at the
24 historical actuals, we looked at the future projected
25 actuals.

VOLUME 16, 1-27-98

PAGE 47

47

1 Q Do you have an opinion as to the manner in
2 which historical nitrogen oxide emissions have been
3 calculated for the proposed project by the applicant?

4 MR. CUNNINGHAM: I register essentially the
5 same objection I have, to the extent that the
6 historical emissions of NOx were addressed fully
7 in the 1995 proceeding and established a figure of
8 7,318 tons per year.

9 I recognize time has moved on and there
10 could be an issue as to whether some later years'
11 information, which has been the subject of some
12 testimony here, is to be factored in somewhere.
13 But as to what the 1993, '94 NOx emissions are,
14 again, it seems to me if that's reopened in this
15 remand order, so is anything else that anyone
16 wishes to bring up.

17 MR. CURTIN: Your Honor, I believe we have
18 had testimony in this proceeding about the
19 comparison of the historical actual emissions to
20 the projected future emissions, and I believe we
21 also had testimony about the result of that and
22 the applicability of PSD review. And that is the
23 area that Mr. Elias is prepared to testify about.

24 THE COURT: I will overrule the objection.
25 BY MR. CURTIN:

PAGE 48

48

1 Q What is that opinion?

2 A Basically regarding the historical actuals,
3 the value has changed several times through the
4 application. The initial values as represented in the
5 draft permit and technical evaluation were based on the
6 four stack tests that were done for oxides and nitrogen
7 in 1993 and '94 at the units times the fuel utilization
8 values.

9 Originally, in DEP-B3, which is the response
10 prepared by the applicant to DEP, a value --

11 THE COURT: What were you referring to DEP,
12 37

13 THE WITNESS: DEP-B3, which is a January
14 15, '95, response in the original proceeding.

15 THE COURT: Okay.

16 A The heat content that was used for fuel oil
17 was a lower value than the one that was currently used
18 in the existing exhibit. It was 151,898 BTUs per pound
19 whereas now the applicant is using 152,381 BTU per
20 pound.

21 To give you a rough idea of the impact of
22 that, that's a difference between the 7,318 currently
23 calculated and the 7,294 that's contained in that
24 exhibit from the prior proceeding.

25 However, neither of those numbers were the

49

1 numbers utilized by the Department in the draft permit
2 or technical evaluation. As I started to say, there
3 were four stack tests performed in '93 and '94, one on
4 each unit each year.

5 These values ranged from .29 pounds per
6 million BTU in '93 for both units, .28 in '94 for
7 Boiler 1, and .26 pounds per million BTU for Boiler 2.

8 The Department averaged all four of those
9 tests together, averaged the fuel use based on the
10 higher heat content, and came up with 6,827 tons per
11 year as the historical NOx emissions.

12 In reality, if you keep the stack tests
13 identified with the years they were done and the fuel
14 use for those units and those years, the actual number
15 you would calculate would be 6,813 tons per year.

16 Additionally, the annual operating reports
17 which were addressed in that same DEP response
18 contained an average of 7,198 tons per year.

19 In reality, as I stated before, the actual
20 emissions, historical actual emissions, as required by
21 the regulation are supposed to be based on the two most
22 recent years following the particular date of the
23 application that are representative of normal source
24 operations. Normally that means the two years out of
25 the last five and in some cases the applicant's allowed

51

1 This then calculates out to 5,478 tons per
2 year. We feel that this meets the requirements of the
3 regulation in calculating historical actuals for NOx,
4 that this is a representation of how the unit is
5 currently operating.

6 THE COURT: What was the number again?

7 THE WITNESS: 5,478 tons.

8 THE COURT: What was the emission rate you
9 cited for Boiler Number 2, was it .229?

10 THE WITNESS: That's correct, pounds per
11 million BTU. And we used the higher heat content rate
12 that the applicant had switched to which was an average
13 for the two years of 48,785,409 BTU per year.

14 BY MR. CURTIN:

15 Q Just so I understand, with respect to the
16 5,478 number, did you arrive at that number by
17 utilizing the fuel used for '93 and '94 and the later
18 emission limit, '96-'97?

19 A Yes, that's correct. We utilized the
20 emission rate of the plant as it's currently operating
21 as representative of normal operations. And we
22 credited the operational capacity rate of the higher
23 capacity that was achieved during '93 and '94 to
24 develop the 5,478 tons.

25 Q Mr. Elias, using the numbers that you

50

1 to go back all the way to 10 years, that represent
2 current normal source operation.

3 As of the time of the application, normal
4 source operation was represented by the plan as
5 configured at that time. Since the PSD application is
6 still pending and under PSD guidance, it's required
7 that the permit remain open until the end of the
8 comment period. The current year's representative of
9 normal operation would be more representative of the
10 plant as it currently operates. This includes a steam
11 atomization system that was installed in late '94 and
12 '95.

13 There is continuous emission monitoring data
14 available for the last two quarters of '96 and the
15 first two quarters of '97 that was supplied by the
16 applicant.

17 In analyzing that data, for 1993, Boiler 1
18 emitted at a rate .219 pounds per million BTU. Boiler
19 2 at .229, this would again be based on the calculation
20 of '96, '97, so that stayed the same for '93 or '94
21 would be the same emission rates.

22 The fuel use, again we believe the applicant
23 correctly estimated that as representative years as
24 being '93 and '94 for a variety of reasons. So the
25 capacity factor we used was the same.

52

1 believe accurately reflects historical nitrogen oxide
2 emissions, would the project be subject to review, of
3 PSD review, rather, for nitrogen oxide?

4 A Yes, it would. We also believe that the
5 future estimated emissions are incorrectly calculated.

6 Q Using the number that you cited as a
7 Department of Environmental Protection number for
8 historical nitrogen oxide, would the project be subject
9 to PSD review for nitrogen oxide emissions?

10 A Yes, it would. In order to be subject to
11 PSD review, there would have to be a 48-ton per year
12 increase from the historical actuals to the future
13 actuals.

14 Q Have you reviewed information from the
15 applicant concerning the manner in which it proposes to
16 meet its suggested nitrogen oxide limitation?

17 A Yes, we have.

18 Q Do you have an opinion as to the capability
19 of the technology that has been proposed to meet the
20 emission limit of .15 pounds per million BTUs for
21 nitrogen oxide?

22 A Yes, I do.

23 Q What is that opinion?

24 A Similar to the case for CO, the emission
25 limit proposed for oxides of nitrogen we feel is a very

PAGE 53 SHEET 14

53

1 aggressive number for this type of configuration. Both
2 the low NOx burner as well as the reburn system are
3 attempting to achieve numbers that have not been
4 demonstrated before on any units. We still feel that
5 there is other available technology that would allow
6 the achievement of this number or, in fact, lower
7 numbers with a much simpler and cost effective
8 approach, primarily Selective Catalytic Reduction which
9 has been used with Orinulsion in Japan, which has in
10 the intervening two years since the original
11 demonstration been studied extensively in the United
12 States, including on high sulfur coals, and formed the
13 basis as the demonstrated technology for EPA's proposed
14 new source performance standards for utilities which
15 was published in July of 1997.

16 Q Do you have an opinion concerning the manner
17 in which future emissions for nitrogen oxide from the
18 facility have been calculated?

19 A Yes, I do.

20 Q What is that opinion?

21 A As I stated, we believe that the emissions
22 for the future actuals were not correctly calculated.

23 Q What was the basis for that opinion?

24 A That's based on the actual language in the
25 WEPCO ruling from the judge as well as EPA's subsequent

VOLUME 16, 1-27-98

PAGE 55

55

1 extensive requirements for the particulate emissions
2 and the minor sources.

3 In addition, we feel that there should be a
4 condition due to the uncertainty of achieving the NOx
5 standard to avoid future hearings, that if the
6 applicant is unable to achieve the proposed or
7 permitted emission limit of .15 pounds per million BTU
8 on a 30-year rolling average within the first year of
9 operation, that they be required to install an SCR
10 system in order to achieve the limit.

11 Finally -- well, two others. To address the
12 future actual emissions, the Department included a
13 condition in the technical evaluation but not in the
14 permit that's required under the WEPCO rule that the
15 applicant demonstrate compliance with the future
16 actuals for a period of a minimum of five years.

17 The rule goes on to say that that can be
18 extended to 10 years. Recent Department policy as
19 evidenced by the draft permit issued for the
20 Hillsborough County retrofit project, this is an
21 existing waste energy plant that's just adding
22 additional pollution control, they are removing an ESP
23 and putting in an acid gas scrubber and bag house.

24 The Department is requiring then to monitor
25 the future actuals for a period of not less than 10

PAGE 54

54

1 promulgation of the WEPCO rule. It clearly states that
2 future actuals have to be based on hourly emission
3 rates based on federally enforceable conditions times
4 the capacity factor.

5 The 7,318 for the future actuals is based on
6 .125 pounds per million BTU times a capacity factor.
7 The short-term limit with the 30-day rolling average
8 .15.

9 Under the WEPCO requirements, which is the
10 exemption that allows them to use future actuals, the
11 .15 should have been utilized times the capacity factor
12 to represent future actuals.

13 Q Based upon the analysis that you have
14 performed, are there additional conditions that you
15 believe should be considered for the project if it is
16 to be approved?

17 A Yes, we do.

18 Q Could you briefly describe those for us.

19 A Yes, there is a number of permit conditions,
20 some of them rather lengthy, that are typically
21 included by the Department in these type permits.
22 These relate to the fugitive sources.

23 An example would be the type conditions that
24 were included in the Florida Crush Stone permit, this
25 is a cement-producing plant which has much more

PAGE 56

56

1 years. We feel that the applicant should have a
2 specific permit condition that requires them to
3 demonstrate compliance with the future actuals for a
4 period of no less than 10 years, similar to the
5 condition (f)1 of the recent draft Hillsborough permit.

6 Finally, we believe, because of the
7 uncertainty associated with the numerous particulate
8 emission sources, both in terms of estimating emission
9 rates and impacts, typically what is done when you have
10 a model violation that is believed by the Department or
11 the applicant to be nonrepresentative -- in other
12 words, assuming the model is overly estimating what the
13 impact would be -- this is normally resolved by ambient
14 monitoring programs.

15 The state has required several sources
16 throughout the state to conduct such programs in order
17 to ensure there are no violations of standard.

18 We think there should be a condition in the
19 particulate for a minimum of a three-station network
20 for ISP, PM 10 and PM 2.5 along with meteorological
21 parameters that meet the guidelines of the PSD ambient
22 monitoring guidelines.

23 The current ambient monitoring network
24 that's in place is sited north and south of the plant
25 where the predominant wind direction is east/west.

VOLUME 16, 1-27-98

PAGE 81 SHEET 21

81

1 There is over 60 sources here.

2 Q That's not in the information you have with

3 you today?

4 A No, it's not. We provided copies of the

5 modeling runs to you. It's in the modeling input.

6 Q It would be whatever is stated in whatever

7 you provided; is that fair to say?

8 A I believe so.

9 Q I think, Mr. Elias, you also testified as to

10 the carbon monoxide emission limit and some concerns

11 you had with respect to this project's capability of

12 meeting that limit; is that correct?

13 A That's correct.

14 Q Is your conclusion regarding CO emissions in

15 that context based on your beliefs that the guaranteed

16 rate for excess CO emissions is 0.6 percent at the

17 reburn zone?

18 A I don't know whether that was a guaranteed

19 rate. As it was stated in the EER proposal, that was

20 the expected condition.

21 Q You were looking at that just spatially in

22 the boiler at the reburn zone?

23 A I believe that would carry up until you

24 injected the overfired area, yes.

25 Q With respect to your testimony regarding the

PAGE 82

82

1 historical NOx emissions from the plant, if I

2 understood your testimony, you applied, I believe it

3 was 1996 and 1997, continuous emission monitoring data

4 to the 1993, 1994 fuel usage; is that correct?

5 A That's correct. The last two quarters of

6 '96, the first two quarters of '97 was the data we had

7 available.

8 Q Did you take into account in any way the

9 load or capacity output at which the Manatee Plant was

10 operating?

11 A During the CEM data?

12 Q Yes.

13 A No, we did not. It was not available.

14 Q Did you ask for it?

15 A We did look through the files at the

16 southwest district office in an attempt to find it. It

17 wasn't present there. I don't know whether we -- I

18 don't believe we specifically asked FP&L for it.

19 Q Would you agree that it's generally true

20 that for units like the Manatee units, NOx emission

21 rates would be higher in higher loads?

22 A In general, I think that's probably an

23 accurate statement.

24 Q And finally, on that point, has the annual

25 NOx value changed in terms of any documents you have

PAGE 83

83

1 seen? I believe you testified it changed several times

2 and I just wanted to ask you if in your understanding,

3 that annual NOx value of 7,318 tons per year has

4 changed since December 1995?

5 A I don't have the exact dates of all the

6 documents. It certainly varied from the annual

7 operating report. The '94 permit application, the

8 draft permit and technical evaluation, all had

9 different numbers in than the 7,318. I couldn't

10 testify as to when the exact time period that the 7,318

11 became the accepted number or proposed number.

12 Q I will ask: Are you aware of any document

13 that's been submitted by Florida Power & Light or

14 issued by the Florida DEP that has a different number

15 since December 1995?

16 A December of '95?

17 Q Correct.

18 A I am not aware of any.

19 Q Thank you.

20 MR. CUNNINGHAM: Thank you, Mr. Elias. No

21 further questions.

22 THE COURT: Any redirect?

23 MR. CURTIN: Just briefly, Your Honor.

24 'REDIRECT EXAMINATION'

25 BY MR. CURTIN:

PAGE 84

84

1 Q Mr. Elias, does the fact that the proposed

2 NOx historical number of 7,318 may not have changed

3 since December 1995 have any bearing on your opinion as

4 to the accuracy of the calculation of historical NOx

5 emissions?

6 A None whatsoever. As I testified, I was

7 unable to find any documentation on why the number

8 shifted from the original 6,827 in the technical

9 evaluation to the 7,318 in terms of rationale by the

10 department or the applicant.

11 MR. CURTIN: Thank you. We have nothing

12 further, Your Honor.

13 MR. CUNNINGHAM: I guess I have one further

14 -- when my turn comes.

15 RECROSS-EXAMINATION

16 BY MR. CUNNINGHAM:

17 Q Did you, in fact, review the testimony that

18 was given by several witnesses including Mr. Kosky at

19 the December 1995 hearing in this proceeding?

20 A I did review portions of that testimony.

21 yes.

22 Q And found no explanation for the figure of

23 7,318 tons per year of NOx in his testimony?

24 A I found how it was calculated.

25 Q I am sorry, I thought you just testified

PAGE 65 SHEET 22

85

1 that you had not seen anything to explain that
2 calculation.

3 A No. I am sorry. You misunderstood. What I
4 testified was that there was no explanation of why that
5 method of calculation was now considered accurate
6 versus the original calculation which gave a 6,827 ton
7 per year number that was presented in the original
8 technical evaluation and draft permit.

9 Q But you acknowledge that, in fact, Mr. Kosku
10 does explain the basis for the 7,318 tons per year
11 before Judge Johnston in December '85?

12 A I don't recollect specifically from the
13 testimony. I would have to review it to be sure. But
14 certainly in the recent exhibits, it's been clearly
15 explained in Mr. Kosku's deposition as well as his
16 current testimony.

17 MR. CUNNINGHAM: Thank you.

18 MR. CURTIN: Nothing further. Your Honor.

19 THE COURT: Thank you. That's all. You may
20 be excused.

21 (Witness excused.)

22 THE COURT: For the record, FP&L Exhibit
23 R-136 has been moved and it is received. You may
24 call your next witness for the record.

25 (FP&L Exhibit R-136 received in evidence.)

PAGE 66

86

1 MR. HOLLIMON: At this time we call
2 Dr. Robert Sanson.
3 Thereupon,

4 ROBERT SANSON, PH.D.
5 was called as a witness, having been first duly sworn,
6 was examined and testified as follows:

7 DIRECT EXAMINATION

8 BY MR. HOLLIMON:

9 Q Mr. Sanson, will you please state your name
10 and business address.

11 A Robert L. Sanson, S-a-n-s-o-n. Business
12 address, 1901 North Moore Street, Arlington, Virginia.

13 Q By whom are you employed?

14 A The company is called Energy Ventures
15 Analysis, Inc.

16 Q What is your position?

17 A I am the president of the company.

18 (CSX Exhibit No. 8 marked for
19 identification.)

20 BY MR. HOLLIMON:

21 Q Dr. Sanson, will you please identify what's
22 been labeled as Exhibit CSX 8.

23 A Yes, that's my resume.

24 Q Is that a current resume?

25 A Reasonably current. I am not sure exactly

VOLUME 16, 1-27-98

PAGE 87

87

1 when it was prepared.

2 Q Dr. Sanson, will you outline your
3 educational background following high school.

4 A Yes. I graduated from the United States Air
5 Force Academy in 1964.

6 Q Following the Air Force Academy, what did
7 you do?

8 A I went to Georgetown University. The degree
9 from the Air Force Academy was a bachelor of science
10 degree. I went for a Master's degree in economics from
11 Georgetown University.

12 Q Was that a Fulbright scholarship?

13 A No, the Fulbright scholarship, I went to
14 Argentina on a Fulbright scholarship after that.

15 Q What did you do there?

16 A I went to Oxford and studied economics.

17 Q Was that on a road scholarship?

18 A Yes.

19 Q Dr. Sanson, what did you do when you left
20 Oxford?

21 A I was a White House Fellow in 1968, '69 and
22 worked for the Johnson Administration and the Nixon
23 Administration.

24 Q What did you do next?

25 A I was on the National Security Council Staff

PAGE 88

88

1 as a White House Fellow. And when Dr. Kissinger became
2 the assistant to the President for National Security
3 Affairs; he asked me to stay and I worked on the
4 National Security Staff through 1971, April, I think.

5 Q Where did you go after that?

6 A I went to the U.S. Environmental Protection
7 Agency.

8 Q What did you do there?

9 A My initial job was the deputy assistant
10 administrator for planning and evaluation. The
11 responsibilities of that job were to evaluate all
12 standards and actions of the agencies, primarily their
13 economic and environmental impact for the
14 administrator.

15 Q What did you do when you left the EPA?

16 A Well, later on, I changed jobs at the EPA
17 and I became the assistant administrator for air and
18 water programs. And then I left the EPA around April
19 1974 and started a company called Energy and
20 Environmental Analysis, Inc.

21 Q Dr. Sanson, will you please describe the
22 work you did while you were with Energy and
23 Environmental Analysis?

24 A Well, the principal focus of our work was
25 energy issues and environmental issues primarily

1 McCann works for Mr. Kosky and Mr. Kosky is fully
2 competent to testify about the results of the
3 analysis.

4 THE COURT: Anything else? I will take that
5 objection under advisement. I don't know that
6 that -- if there is -- if I am to make a finding
7 of fact based on the modeling, I am not sure that
8 those things will overcome the hearsay nature of
9 it. I will receive the exhibits, but as I say, it
10 may be that I would not be able to make a finding
11 of fact based upon the modeling.

12 (FP&L Exhibit R-125 received in evidence.)

13 (FP&L Exhibit R-178 received in evidence.)

14 MR. CUNNINGHAM: Thank you, Your Honor.

15 That being the case, I would advise that I will
16 consider here calling Mr. McCann to the stand.

17 But back to Mr. Kosky.

18 BY MR. CUNNINGHAM:

19 Q Mr. Elias testified that DEP originally
20 calculated historical NOx emissions for the Manatee
21 Plant to be 6,827 tons per year based on fuel usage
22 data and stack tests in 1993 and '94. In your opinion,
23 is it valid to use stack testing data for this purpose,
24 that is to calculate the historical NOx emissions from
25 the Manatee Plant for those years?

1 A In my opinion, it is not.

2 Q Why not?

3 A A single stack test is a snapshot in time of
4 the emissions of a source. In fact, FDEP rules
5 regarding actual emissions as they relate to the
6 federal air permitting program referred to as Title V
7 specifically excludes the use of a single stack test in
8 that use.

9 The other aspect of those tests are that
10 those tests of particularly NOx emissions are done by
11 an indirect method in terms of heat input. Heat input
12 actually is overstated by this particular technique.
13 When all those are taken into account, you actually
14 would use a number that I concluded was appropriate and
15 calculate the actual historical tons of 7,318 tons a
16 year.

17 Q Mr. Elias also stated that he calculated or
18 recalculated historical NOx emissions to be 5,478 tons
19 per year based on the 1993, '94, fuel usage and
20 extrapolating back from some 1996 and '97, continuous
21 emission monitoring data.

22 In your opinion, is the manner in which
23 Mr. Elias used the continuous emission monitoring data
24 to calculate '93, '94 NOx emissions correct?

25 A No, his method was not correct.

1 Q Why not?

2 A His method was not correct because he did
3 not factor in the actual load that the plant is
4 operated during the different years between 1993 and
5 '94, and 1995 and '96.

6 Q Let me show you what has been marked as FP&L
7 158.

8 (FP&L Exhibit No. R-158 marked for
9 identification.)

10 BY MR. CUNNINGHAM:

11 Q Can you identify this document?

12 A Yes, this is an exhibit that I prepared
13 showing historical NOx emissions using CEM data.

14 Q And referring to this exhibit, please
15 explain the basis for your opinion that Mr. Elias's
16 calculation of this figure is not correct.

17 A Mr. Elias's calculation incorrectly
18 considered what's called net load in his calculation,
19 that is the actual load while the plant is operating.
20 He did conclude that it was appropriate that NOx
21 emissions go up with load, but did not take that into
22 consideration in this calculation. If he did, he would
23 get a totally different conclusion than as shown on
24 this exhibit.

25 I have listed in the far column what's

1 called net load. That's the actual load that the plant
2 is when it's operating. It does include days of the
3 plant nonoperating.

4 I have listed in two columns the 1993, '94,
5 and 1995 net load factors. For '93, '94, it was 56
6 percent and for '95, '96, it was 41.1 percent. This is
7 a significant difference in how the plant operated
8 during those time frames.

9 The NOx, the actual NOx CEM data -- I
10 actually looked at the whole year's, two years' worth
11 of data in 1995 and '96 as well as I also looked at a
12 portion of the year 1997.

13 The NOx CEM over those two years was .23
14 pounds per million BTU. Now, when you consider the
15 differences in load, you can estimate in 1993, '94,
16 what the CEM could have been in that year using the
17 current CEM data. That is the '95, '96.

18 My conclusion as a result of my analysis was
19 that the emissions were .3 pounds per million BTU which
20 entirely supports my conclusion in the 1995 hearing as
21 well as this hearing.

22 Using the .3 pounds per million BTU and the
23 actual heat input, 1993, '94, you would calculate 7,318
24 tons a year.

25 Q In his testimony, Mr. Elias also noted that

1 the annual operating report for the Manatee Plant for
2 1993 and '94 expressed a different value for NOx
3 emissions than the 7,318 tons per year figure that you
4 have calculated.

5 Can you explain why there is a difference?

6 A The only difference between the annual
7 operating reports that Mr. Elias cited and our
8 calculation was that we went to the plant and actually
9 got the actual heat content of the fuels used during
10 1993, '94. That resulted in the calculation of the
11 7,318 tons a year.

12 Q How would you compare the accuracy of the
13 figure that you calculated versus what was contained in
14 the annual operating reports?

15 A The calculation that we made was much more
16 accurate.

17 MR. CUNNINGHAM: We would offer FP&L R-158.

18 THE COURT: It's received.

19 (FP&L Exhibit R-158 received in evidence.)

20 BY MR. CUNNINGHAM:

21 Q On a different subject, Mr. Elias testified
22 that NOx emission controls, other than the proposed low
23 NOx burners and reburn technology, specifically
24 mentioning Selective Catalytic Reduction, would be more
25 cost effective for this project. Do you agree with

1 that conclusion?

2 A No, I do not.

3 Q Why not?

4 A As I testified to in the 1995 hearing, for
5 Best Available Control Technology, I concluded that SCR
6 was not cost effective using low NOx burners at an
7 emission rate --

8 MR. CURTIN: Excuse me. We would just
9 object to this unless he is going to update it or
10 something. All he is doing is regurgitating the
11 testimony that he provided in 1995, which I think
12 is in the transcript.

13 MR. CUNNINGHAM: In light of Mr. Elias's
14 testimony, we did intend to update it.

15 MR. CURTIN: Okay. Pardon me.

16 A I recently updated the costs that I used in
17 the 1995 hearing and determined the cost effectiveness
18 of Selective Catalytic Reduction at an emission rate
19 assuming it could meet 0.1 pounds per million BTU.

20 My analysis showed that the cost
21 effectiveness of SCR would be \$35,000 per ton of NOx
22 removed. This is much higher than the 4,000 to \$7000 a
23 ton that FDEP has concluded on many projects as being
24 unreasonable as BACT.

25 The actual cost effectiveness of the low NOx

1 burners and reburn is \$280 per ton. Even if you were
2 to assume that BACT would apply to the project, the
3 actual BACT determination would be made at an emission
4 rate of .01255 pounds per million BTU.

5 MR. CURTIN: We object and move to strike.
6 Mr. Kosky is not -- our witness did not testify as
7 to a BACT analysis, and Mr. Kosky is now
8 apparently going to be providing us with some sort
9 of a BACT analysis.

10 That testimony does not rebut anything.

11 MR. CUNNINGHAM: I believe his testimony
12 rebuts Mr. Elias's statement about the other more
13 cost effective NOx control technologies, and BACT
14 is a commonly used regulatory context in which to
15 make that judgment.

16 MR. CURTIN: I have no problem with
17 Mr. Kosky updating the cost effectiveness, but
18 when he begins to testify about an emission
19 limitation and what would constitute BACT and what
20 would not, then I think he has gone beyond the
21 testimony that Mr. Elias provided. And I don't
22 know really what the reason is but obviously, they
23 are trying to get it in the record for some
24 reason.

25 THE COURT: I will sustain the objection.

1 MR. CUNNINGHAM: Can I inquire as to what
2 was stricken?

3 THE COURT: Nothing was stricken. The
4 objection was sustained.

5 MR. CURTIN: I did move to strike the
6 testimony about .1255 constituting BACT.

7 THE COURT: I will grant that part of it
8 because we are not -- I think it should be limited
9 to the question that's being rebutted, which is
10 what is the cost effectiveness of that SCR. And
11 it does not open up the question of what's BACT.

12 MR. CUNNINGHAM: Thank you.

13 BY MR. CUNNINGHAM:

14 Q Mr. Kosky, were you present for the
15 testimony of Mr. Pedersen on January 28, 1998, in this
16 proceeding?

17 A Yes, I was.

18 Q Mr. Pedersen expressed concern that one of
19 the conditions, condition Roman Numeral XIII B13, of
20 the proposed conditions of certification would enable
21 FP&L to change the 20 percent limit on opacity that is
22 contained in a different condition.

23 Do you agree that that's a basis for
24 concern?

25 A No. I don't believe it's a concern.

1 be coming from this project.

2 Q They are only mutually exclusive in your
3 estimation. They are in the permit. They are
4 separately listed in the permit; are they not?

5 A They are identified in the permit.

6 Q And they have been assigned emissions
7 limits, haven't they, opacity limits?

8 A They have some opacity limits as a result of
9 the performance standards.

10 Q Mr. Kosky, I am looking at, I guess, Page 23
11 of the exhibit, DEP R-1. I am going to read you a list
12 of sources here and see if these are ones that you are
13 saying should be eliminated.

14 Limerock, limestone, prepressure, 12 and 3,
15 those should be eliminated, or should they be retained?

16 A I don't have that exhibit here.

17 Q Let me give it to you.

18 THE COURT What page?

19 MR. CURTIN: 23.

20 BY MR. CURTIN:

21 Q Maybe the easiest way to do it is take the
22 exhibit that shows the sources that are gone, tell us
23 which of the sources are the gone sources.

24 A Page 23, it would be sources 10 through 18.
25 I am sorry, the conveyers -- yeah, 10 through 18.

1 Q 10 through 18. Those could be removed from
2 the permit then?

3 A Yes. Also source number 8 which is a
4 blending silo.

5 Q Thank you. Exhibit R-158, do you have that?

6 A Yes.

7 Q Looking at the column there, NOx CEM
8 adjusted under 1993, 1994, you arrived at a .3 pounds
9 per million BTU; correct?

10 A That's correct.

11 Q How exactly did you arrive at that number?

12 A I looked at the 1995, 1996, CEM data and the
13 corresponding load data, developed a relationship of
14 NOx emissions with load, then used that relationship to
15 estimate 1993, '94, NOx emissions based on the actual
16 load that the plant was operating in those years.

17 Q How did you develop that relationship? I
18 just don't understand what you did here. So we need to
19 have you explain that.

20 A It's real simple. I took the net load
21 factors for various data, looked at the CEM data and
22 developed a relationship, essentially an equation that
23 factors in the increase of NOx with load. And in fact,
24 that's the relationship that I determined from that
25 data. I used that relationship to estimate '93, '94

1 based on the actual loads that the plant was operating
2 during those years.

3 Q So it's kind of a linear relationship, is
4 that what you are saying?

5 A It is a linear relationship, yes. Actually
6 a quite good one.

7 Q NOx would go up as the load goes up,
8 generally speaking?

9 A Yes. In fact, it's an excellent
10 relationship. The differences I actually looked at
11 with this equation, you can call it equation for '95,
12 '96, I actually predicted for 1995-'96, what the CEM
13 data would predict. That's the NOx CEM adjusted of
14 .23. I actually predicted that.

15 The difference, the average differences in
16 any unit in the data that I used was less than 2
17 percent. I call that a very good distribution.

18 Q You brought all that data with you here
19 today so we could take a look at it?

20 A I have that data somewhere. I am not sure I
21 have it here today. But I have -- yes, I have it.

22 Q But you don't know if you have it here today
23 so we could have the benefit of taking a look at it?

24 A I may have it here, yes.

25 Q Tell me why you selected the '95, '96 time

1 frame? What was the reason for that?

2 A Well, that was essentially two full years of
3 CEM data that essentially have been validated. This is
4 a requirement the EPA and I used that data for being
5 full two years. Mr. Elias only used portions of '96
6 and '97.

7 In fact, I have looked at '97 and I get the
8 same relationship, same data he used. The data, all
9 data for 1997 is not yet available since it just was
10 taken.

11 Q Let me ask you this, Mr. Kosky. I think you
12 just testified that the relationship between NOx and
13 loads is linear and that you would expect higher limits
14 at higher -- or higher NOx at higher loads.

15 Explain to me why that is not reflected in
16 the 1993 and '94 stack tests that were performed, I
17 believe, at 84 percent, then 88 percent load?

18 A Well, as I characterized previously, that's
19 a snapshot in time. It's a view over a very short time
20 frame of load.

21 Also, that data is a -- it's taken
22 indirectly in terms of heat input and that reflects, I
23 believe, a slightly lower emission rate than when you
24 use actual heat input by the fuel. Those two things in
25 combination as well as DEP's position on using

1 individual stack test data.

2 Q So you are saying that the stack test data
3 should not be used to calculate or to give a historic
4 emission figure; is that your testimony?

5 A That's been my testimony and conclusion.

6 Q Why did you use stack test data for
7 particulate matter?

8 A It was an agreement. I concluded in June
9 1995 that that should not be used. In fact, the
10 original application, I took a similar approach as I
11 did with NOx.

12 In discussing that with the Department, we
13 used a calculation, because quite frankly, particulate
14 was not necessarily an issue in terms of historical
15 emissions.

16 My conclusion in 1995 and my conclusion
17 today is that the 1,768 that can be calculated is a low
18 number for historical PM emissions.

19 Q You used the stack test data for that; did
20 you not?

21 A Correct. It was an artifact of a
22 calculation.

23 Q But it's stack test data; isn't it?

24 A Yes.

25 Q Do you know what historical emission limit

1 is in the PSD preliminary determination for NOx?

2 A I believe I testified to that. I think it
3 was 6,827 tons a year, which I --

4 Q Do you know what that was based on?

5 A I believe that was based on using stack test
6 data.

7 Q Are you familiar with the report of the
8 Department of Environmental Protection in the 1995
9 proceeding, the one that was signed by Secretary
10 Wetherell?

11 A I am not that familiar. I am more familiar
12 with the draft permit.

13 Q You don't know what number would be in that
14 for historic NOx emissions?

15 A I haven't really looked at that.

16 Q I have got a copy here of what I believe is
17 DEP Exhibit 1 from the original hearing. Maybe you
18 could tell us what the historic NOx is out of that
19 document.

20 A The actual historical emissions as included
21 on Page 38, Table 1, is 6,827, which I have previously
22 expressed to be low.

23 Q Right. Yeah. We understand that.

24 Mr. Kosky, in order for your 7,318 number to
25 be the accurate number, it means that the facility

1 would have had to run at the permit limit for a period
2 of two years, '93, '94, for all barrels of oil that
3 were burned during that period; correct?

4 A Well, the average would be that. And in
5 fact, that's what your previous question on R-158
6 concluded.

7 Q That's what you concluded, but that wasn't
8 what my question concluded.

9 A Right.

10 Q So you don't think you should use the
11 continuous emission monitoring data or the stack test
12 data, you think you should just use the permit limit?

13 A Well, in the time frame of 1993, '94, there
14 was no CEM data.

15 Q Right.

16 A And as I indicated previously, I feel that
17 you should use the permit limit that reflects
18 historical emissions based on the factors that I
19 previously testified.

20 Q But in projecting the future emissions,
21 particularly NOx, you are not using the permit limit,
22 are you, you are using .1255. Why is that?

23 A Those are conditions for the project.

24 Q What conditions are those for the project;
25 they are not in the conditions of certification?

1 A Those are -- the conditions for the project
2 have included a ton a year limit, 30-day rolling
3 average limit, and a 24-hour maximum during ozone
4 season limit. That's what you project.

5 Q The permit limit is .15; correct?

6 A As it's currently in the remand.

7 Q And you don't have any data to show what
8 these particular units will do; do you?

9 A Well, you don't have data if it hasn't been
10 built.

11 Q Right. But yet, you are going to use a
12 lower limit than the permit limit to project the future
13 emissions; is that right?

14 A In my analysis, I am using the 7,318 which
15 is a permit limit.

16 Q You are assuming an emission limit of less
17 than .15; correct?

18 A Well, it's an average emission limit of
19 .1255, I don't see any reason why you couldn't meet
20 that on a 30-day rolling average.

21 Q Is .1255 less than .15?

22 A Yes.

23 Q But yet, for historic emissions, when there
24 are data available, you are using the .3 permit limit
25 to calculate those; is that right?

1 A I am using .3 in the calculation.

2 Q Is that the permit limit?

3 A That's the permit limit, yes.

4 MR. CURTIN: I have no further questions,
5 Your Honor.

6 THE COURT: Any other cross?

7 CROSS-EXAMINATION

8 BY MR. REESE:

9 Q Mr. Kosky, on your Exhibit R-156, those
10 emissions are for the plant site, correct, they don't
11 include any handling off the plant site?

12 A That is correct.


13 Q And your historic particulate emissions,
14 that was based, I think you previously stated it was
15 based on stack tests, but that was also with 21 days of
16 soot blowing or 21 hours of soot blowing per day?

17 A Yes.

18 Q And Mr. Curtin asked you about DEP Exhibit 1
19 from the 1995 hearing. The report that you testified
20 from concerning the historic NOx emissions, that was
21 the report signed by Secretary Wetherell, correct? I
22 think if you turn to the blue tab.

23 MR. CUNNINGHAM: I object to the form of
24 the question in that it suggests Mr. Kosky
25 testified from a report. Mr. Curtin had him read

STATE OF FLORIDA
DIVISION OF ADMINISTRATIVE HEARINGS



In Re: Florida Power & Light)
Company, Manatee Orimulsion)
Project, Application No. 94-35)
_____)

DOAH CASE NO: 94-5675-EPP

In Re: Florida Power & Light)
Company, Manatee Orimulsion)
Project, PSD Permit No.)
PSD-FL-29)
_____)

CASE NO. 95-4829
95-5036
95-5037
95-5598

WRITTEN PROFFER OF SURREBUTTAL TESTIMONY OF DONALD ELIAS

CSX Transportation, Inc. ("CSXT"), by and through undersigned counsel, hereby proffers the Surrebuttal Testimony of Donald Elias (Exhibit 1).

Respectfully submitted, this 16th day of February, 1998.

A handwritten signature in cursive script, appearing to read "Lawrence N. Curtin".

Lawrence N. Curtin
Florida Bar No. 218049
HOLLAND & KNIGHT LLP
P.O. Drawer 810
Tallahassee, FL 32302-0810
850/224-7000

William H. Hollimon
Florida Bar No. 0104868
AUSLEY & McMULLEN
P.O. Box 391
Tallahassee, FL 32302
850/224-9115

Attorneys for
CSX Transportation, Inc.

Proposed Surrebuttal
Testimony of Donald Elias

- A. Attachment 1 consists of pages 3-25, 3-26, 3-27, and 3-31 of the ISC3 Users Guide for Modeling. The ISC3 is the model used for impact assessment by both Florida Power & Light Company and CSX. This material states that the area source algorithms are to be used to model storage piles and mechanically generated emission sources such as mobile sources. The modeling performed on behalf of the applicant by Golder and Associates modeled these as volume sources. This underestimates the impacts and is totally inappropriate. Our modeling is identical with Golder's except for the area source correction. We show violations of standards that must be resolved. These violations preclude issuance of a permit.
- Q. Mr. Kosky testified that your method of calculating historical nitrogen oxide emissions for the facility is inappropriate. Do you agree with that conclusion?
- A. No I do not.
- Q. Please explain your answer.
- A. First of all, let me say that this is not merely an academic exercise that has no regulatory significance. The determination of whether PSD review is applicable for a particular pollutant, and whether the applicant must go through the rigorous analyses required by that review, depends upon the determination of the differences in emissions before and after physical changes or modifications have been made to

Proposed Surrebuttal
Testimony of Donald Elias

the facility. The starting point for this calculation, of course, is the historical actual nitrogen oxide emissions. As I testified earlier, the applicant utilized the permit limit as its estimate of historical actual emissions. This was done even though it is conceded that the facility did not operate at the permit limit. This is totally inappropriate. When actual testing data are available, the testing data must be used. Mr. Kosky stated that the stack test information that was used in our analysis and used by the Department in reaching its conclusions as to actual emissions in the 1995 proceeding is unreliable. This is apparently based on his perception that a single stack test is a snapshot in time. However, neither our calculations nor those made by the Department were based on a single stack test. These calculations were based upon the use of four stack tests during the 1993 and 1994 period. These are the tests that were submitted to the Department by Florida Power & Light Company for purposes of showing compliance with the permit limits. As I noted earlier, these show limits substantially lower than the permit limit for nitrogen oxide. The other information that should be considered in determining historical nitrogen oxide emissions would be the continuous emission monitoring data that has been available from the facility since 1996. It is appropriate to use these data for

Proposed Surrebuttal
Testimony of Donald Elias

several reasons. First, the data reflect the operation of the facilities after the steam atomization system was installed. This has the result of lowering the nitrogen oxide emissions substantially. Second, in determining the level of actual emissions that must be utilized, operational data from the most recent two years should be utilized. Florida Power & Light Company's decision to ignore the continuous emission monitoring data and the stack tests for nitrogen oxide emissions is unjustified and unexplained. In fact, it directly contradicts the applicant's decision to utilize stack testing data from 1993 and 1994 for establishing historical particulate matter emissions.

Q. Mr. Kosky testified that the Department's Title V rules specifically excludes the use of a single stack test for that program. Do you agree that this provides a justification for ignoring the stack test data in the calculation of historical emissions?

A. No I do not.

Q. Please explain your answer.

A. The Title V program is a program that is also mandated by the Federal Clean Air Act. The program requires that sources of air emissions generally obtain operation permits. The PSD program, on the other hand, is a construction permit program. One of the significant features of the Title V program is the

Proposed Surrebuttal
Testimony of Donald Elias

requirement that the administering agency charge sources fees based upon the amount of emissions from the facility to fund the program. The fees are generally based on allowable emissions unless the applicant can demonstrate that a lower actual emission figure should be used. To ensure that the actual emissions are representative, the Department will not allow the use of a single stack test to establish the emissions upon which the fee is based. This is certainly not inconsistent with the methodology for establishing actual historic emissions under the PSD program. Again, we are not suggesting that a single stack test be used. We reviewed four stack tests, and there are others available. In addition, there is a large body of continuous emission monitoring data that also could be used. We are simply stating that, in light of all this available data, it is unreasonable for the applicant to presume that the historical actual emissions equal the permit limit. To reach that conclusion it is necessary to ignore the available data. That result is just not acceptable under the PSD permit program. Moreover, it would be unusual for the Department to disallow the use of these data even for Title V purposes.

- Q. Mr. Kosky testified that it is customary to perform an impact analyses on what would be considered to be the worst case. Was this done in this application, in your opinion?

CONDITIONS OF CERTIFICATION

XIII. AIR

A. Operation and Construction

B. Fossil fuel-fired steam generating Units #1 and #2:

2. The maximum hourly heat input for each unit shall be 8650 MMBtu/hr while firing LSFO or HSFO; and 8100 MMBtu/hr while firing Orimulsion. The maximum rolling 12-month heat input for the facility while firing Orimulsion shall not exceed 116,64,360 MMBtu for all fuels.^a

3. While firing Orimulsion ~~or HSFO~~, the sulfur dioxide (SO₂) emissions from each unit shall not exceed 0.234 lb/MMBtu heat input, based upon a ~~30-day rolling~~ 3-hour^b average. While firing HSFO, the sulfur dioxide emissions from each unit shall not exceed 0.172 lb/MMBtu, based upon a 3-hour average.^{b,c} ~~The~~ annual facility emissions shall not exceed 13,643 tons per year, based upon actual annual MMBtu heat input. While firing LSFO the sulfur dioxide emissions from each unit shall not exceed ~~1.1~~ 0.055^{d,e} lb/MMBtu heat input, based upon a ~~1-hour~~ 3-hour^b average. Continuous emission monitors meeting the requirements of 40 CFR Part 75 shall be used to demonstrate compliance.

4.b. Compliance with these emission limits for Units 1 and 2 shall be demonstrated based upon quarterly compliance testing with Orimulsion or HSFO while burning each fuel that it fired using EPA Method 5B or 17 ~~for~~ conducted during any quarter in which the combined use of Orimulsion or HSFO is fired for more than 100 hours in either unit. Annual compliance testing with LSFO shall be required for any year in which LSFO is fired for more than 400 hours using the same methods. Compliance with the 858 tons per year limit shall be demonstrated by the following method: For each 3-run quarterly stack test, an average of the three test runs shall be calculated to the closest thousandth of lb/MMBtu for each emission unit. ~~The resulting average for each of the four quarterly tests in a calendar year shall then be averaged together to calculate an annual average to the closest average thousandth lb/MMBtu for each emission unit.~~ This annual average lb/MMBtu shall be multiplied by the actual fuel MMBtu input for ~~the~~ each calendar year quarter for each emission unit, based upon actual fuel receipts, inventories, and analyses, and summed to obtain the annual particulate emitted from each boiler.

If no quarterly test data is available, the previous quarter test results shall be used. The annual particulate emissions generated by the materials handling operations shall be calculated by stack test, if performed which shall be performed annually for all minor stack and vent sources,^f and by emission factors for fugitive sources, and the calculations sealed by a professional engineer. Necessary data and operating records shall be collected and maintained by FPL for all assumptions used in the calculation of total facility emissions as shown in condition 27 below.

7.e. After submittal of the engineering report required pursuant to specific condition 7.d. above, the Department shall make a determination based on the engineering report, regarding establishment of any revised NOx limit for both units when firing Orimulsion. If results of the test program demonstrate that a NOx emission rate lower than ~~0.230~~ 0.15 lb/MMBtu heat input is practically and consistently achievable using low-NOx burners and reburn technology, the NOx emission limit applicable when firing Orimulsion shall be adjusted to reflect the lower emission rate accordingly. If the source does not achieve 0.15 lb/MMBtu heat input on a 30-day rolling average within 12 months, selective catalytic reduction (SCR) must be installed and operating within 12 months. Under no circumstances shall the emission limit be increased beyond the currently permitted value.

7.g. After submittal of the engineering report required pursuant to specific condition 7.f., the Department shall make a determination based upon the engineering report regarding establishment of any revised NOx limit for both units when firing fuel oil. If the results of the test program demonstrate that a NOx emission rate lower than ~~0.270~~ 0.15 lb/MMBtu heat input is practicably and consistently achievable using low-NOx burners and reburn technology, the NOx emission limit applicable when firing oil shall be adjusted accordingly. If the source does not achieve 0.15 lb/MMBtu heat input on a 30-day rolling average within 12 months, selective catalytic reduction (SCR) must be installed and operating within 12 months. Under no circumstances shall the emission limit be increased beyond the currently permitted value.

8. While firing Orimulsion fuel, emissions of carbon monoxide (CO) from each unit shall not exceed 0.325 lbs/MMBtu while firing Orimulsion and 0.634 lb/MMBtu while firing HSFO or LSFO.⁹ ~~and the annual Rolling 12-month~~ facility emissions shall not exceed 18,948 tons per year based upon actual annual MMBtu

heat input. Compliance shall be demonstrated annually for each unit by conducting one 3-run test using EPA Method 10 while firing Orimulsion if Orimulsion is fired more than 400 hours. Testing shall be conducted for HSFO and/or LSFO for any year in which HSFO/LSFO firing exceeds 400 hours.

9. While firing Orimulsion, HSFO, or LSFO^g fuel, total ~~annual~~ rolling 12-month emissions of volatile organic compounds (VOC) from the facility shall not exceed the current actual emissions of 122 tons per year. Compliance shall be demonstrated annually for each unit by conducting one 3-run test using EPA Method 25 while firing Orimulsion if Orimulsion is fired more than 400 hours. Testing shall be conducted for HSFO and/or LSFO for any year in which HSFO/LSFO firing exceeds 400 hours.

10. While firing Orimulsion, HSFO, or LSFO^g fuel, ~~annual~~ rolling 12-month facility emissions of sulfuric acid mist shall not exceed 1,118 tons/year. Compliance shall be demonstrated annually for each unit by conducting one 3-run test using EPA Method 8 on each unit while firing Orimulsion if Orimulsion is fired more than 400 hours. Testing shall be conducted for HSFO and/or LSFO for any year in which HSFO/LSFO firing exceeds 400 hours. For each stack test, an average of the three test runs shall be calculated to the closest thousandth of lb/MMBtu. FPL shall design and operate each boiler to minimize SO₃ emissions.

11. While firing Orimulsion fuel, ~~annual facility~~ emissions of vanadium shall not exceed ~~170~~ 1.39 lb per hour per unit and 10.59 tons per year for the facility.^h Compliance shall be demonstrated using a department-approved method by annually conducting one 3-run test while firing Orimulsion.

12. While firing Orimulsion, ~~if any of the following air pollutants exceed the values listed below, FPL shall be required to demonstrate that the applicable Ambient Reference Concentrations would not be exceeded at the actual emission rate or to otherwise demonstrate that the emissions of such pollutant would not pose an unacceptable risk to human health. The annual emissions shall be calculated for the following and included in the Annual Operating Report for inventory purposes only. the following metals emitted from each facility shall not exceed the limits listed as follows:ⁱ~~

<u>Pollutant</u>	<u>Demonstration Trigger</u>	<u>Facility</u>
<u>ton/yr</u>	<u>Lb/hr for each unit</u>	

Antimony	0.0147	0.112
Arsenic	0.0106	0.0808
Barium	0.0101	0.0770
Beryllium	0.000061	0.0005
Cadmium	0.00515	0.0393
Chromium	0.0180	0.137
Copper	0.0118	0.0899
Fluoride	0.017	0.15
Lead	0.023	0.17
Manganese	0.0175	0.133
Mercury	0.001	0.008
Nickel	3.19	24.3
Phosphorous	0.0275	0.210
Selenium	0.126	0.960
Silver	0.00412	0.0314
Zinc	0.0324	0.247

Emissions testing for all listed metals shall be accomplished by ~~proposed~~ EPA Method 29 while firing Orimulsion during the initial test period and every five years thereafter. Emissions testing for fluoride shall be conducted using Method 13A or 13B while firing Orimulsion, during the initial test period and every five years thereafter.

While firing Orimulsion, emissions testing for the following pollutants shall also be performed during the initial test period and every five years thereafter. Emissions testing shall be accomplished by Method 23 (40 CFR 60 Appendix A) and Method 0010 (SW-846). For these pollutants, which were not considered in the permit application, FPL shall be required to demonstrate that the applicable Ambient Reference Concentrations would not be exceeded at the tested emission rate or otherwise to demonstrate that the emissions of each pollutant would not pose an unacceptable risk to human health and the environment.¹

<u>Acenaphthene</u>	<u>Acenaphthylene</u>	<u>Anthracene</u>
<u>Benzo(a)anthracene</u>	<u>Benzo(b)fluoroanthene</u>	<u>Benzo(k)fluoroanthene</u>
<u>Benzo(ghi)perylene</u>	<u>Benzo(a)pyrene</u>	<u>Dibenz(a,h)anthracene</u>
<u>Chrysene</u>	<u>Dioxins/Furans</u>	<u>Fluoroanthene</u>
<u>Fluorene</u>	<u>Indeno(1,2,3-cd)pyrene</u>	<u>Naphthalene</u>
<u>Phenanthrene</u>	<u>Pyrene</u>	

Results from the organic pollutant and metals testing will be included in the risk assessment required by Condition XXXI.4.

14. The flue gas desulfurization, electrostatic

precipitation, and NOx pollution reduction equipment including reburn technology equipment for each unit shall be in operation while each unit is firing Orimulsion, low sulfur fuel oil,^d or high sulfur fuel oil. ~~The electrostatic precipitator and the NOx pollution reduction equipment for each unit must be in operation while each unit is firing low sulfur fuel oil.~~

15. Excess Emissions

Materials Handling and Storage:

16. The maximum lime/limestone received at the facility shall be limited to 650,000 tons per year 12-month period.

17. The sources listed below are subject to the requirements of New Source Performance Standards for Non-Metallic Mineral Processing Plants 40 CFR 60 Subpart 000.

- ~~03 Limerock/Limestone Truck Unloading^k~~
- ~~04 Limerock Rail Unloading^k~~
- 05 Limestone Storage Pile
- 06 Limerock Storage Pile
- ~~07 Limerock/Limestone Receiving Hopper^k~~
- ~~08 Limestone Blending Silo^k~~
- 09 Covered Limerock/Limestone Conveyors
- ~~10 Limerock/Limestone Day Silo #1^k~~
- ~~11 Limerock/Limestone Day Silo #2^k~~
- ~~12 Limerock/Limestone Day Silo #3^k~~
- ~~13 Limerock Day Silo #1 Covered Recycle Conveyor^k~~
- ~~14 Limerock Day Silo #2 Covered Recycle Conveyor^k~~
- ~~15 Limerock Day Silo #3 Covered Recycle Conveyor^k~~
- ~~16 Limerock/Limestone Precrusher #1^k~~
- ~~17 Limerock/Limestone Precrusher #2^k~~
- ~~18 Limerock/Limestone Precrusher #3^k~~
- ~~19 Limestone Ball Mill #1 Tower Feed^k~~
- ~~20 Limestone Ball Mill #2 Tower Feed^k~~
- ~~21 Limestone Ball Mill #3 Tower Feed^k~~

~~a. Emission units 16, 17, 18, 19, 20, and 21, unless enclosed in a building, shall not discharge fugitive emission that exhibit an opacity greater than 15%.~~

~~b.a. Emission units 04, 05, 06, 07, 08, and 09, 10, 11, 12, 13, 14, and 15, unless enclosed in a building shall not discharge fugitive emissions that exhibit an opacity greater than 10%.~~

~~e-b.~~ If any emission unit listed in condition 17a, or 17b is enclosed in a building, it must comply with the emission limits of the applicable condition. Alternatively, the building can comply with the following:

18. Particulate matter emissions from the emission units listed below shall not exceed ~~0.02~~ 0.003^f gr/dscf and an opacity of 5%. Compliance with these standards shall be demonstrated by an initial performance test using EPA Method 5 or 17 and EPA Method 9 for opacity. ~~In accordance with F.A.C. 62-297.620, the particulate emission performance test may be waived if the units can demonstrate compliance with the visible emission standard of 5% opacity using EPA Method 9.^f~~

25. As required by 40 CFR 52.21(b)(21)(v), FPL shall maintain adequate records and submit information to the Department demonstrating that the modifications did not result in an increase in annual emissions. The information shall be submitted on an annual basis for a period of not less than ten years from the date the unit begins normal operation with Orimulsion fuel.¹

26. FPL shall provide to the Department all reasonable assurances as may be required prior to firing Orimulsion that public access will be restricted and denied in all areas excluded from the modeling analyses in the January 5, 1998 letter from Robert McCann to Wayne Ondler. Public access shall be restricted by fencelines of such extent to effectively deny public access, or any other methods which comply with USEPA guidance. The public shall mean all individuals other than FPL employees, their subcontractors, or plant visitors (i.e., leasing of FPL property for agricultural operations as currently described in the PPSA application will be prohibited in areas excluded from the modeling analyses).

27. In order to accurately estimate fugitive particulate emissions, FPL shall record and maintain the quantities of all materials (including gypsum and gypsum products, flyash and flyash products, limestone, limerock, and lime) moved, transported, stored, or disposed onsite capable of generating fugitive emissions. FPL shall periodically determine the silt and moisture contents of all material storage piles and predominately traveled onsite unpaved roads according to the procedures in AP-42 or similar EPA guidance documents (such measurements must be taken at least five days after any precipitation event or any surface watering).^m

Modifications

~~25-28.~~ FPL shall give written notification to the Department when there is any modification to this facility. This notice shall be submitted sufficiently in advance of any critical date involved to allow sufficient time for review, discussion, and revision of plans, if necessary. Such notice shall include, but not be limited to, information describing the precise nature of the change; modifications to any emission control system; production capacity of the facility before and after the change; and the anticipated completion date of the change.

XXIX. MANATEE COUNTY

C. TRUCK AND RAIL TRANSPORT

7. Rail transportation of orimulsion flyash from the Manatee Plant shall only be conducted in totally enclosed, pneumatic type, rail cars designed to completely contain the flyash.

ENDNOTES DESCRIBING REASONS FOR PROPOSED REVISIONS

^aAnnual limitation utilized by FPL for PSD applicability and contained in PSD Draft Permit.

^bAveraging time of emission standard should equal the shortest averaging time of the appropriate ambient air quality standard (3-hours for SO₂).

^cCondition XIII.B.14 requires the flue gas desulfurization equipment (specified in the PSD Draft Permit as achieving a minimum of 95% control) to be in operation while firing high sulfur fuel oil (HSFO), which gives emissions of:

$$\begin{array}{l} \text{3 lb sulfur} \times \text{1 lb HSFO} \times \text{2 lb SO}_2 \times \text{10}^6 \text{ Btu} \times (100\%-95\%) = \text{0.172} \\ \text{lb} \end{array}$$

100 lb HSFO	17,500 Btu	lb sulfur	MMBtu	MMBtu
-------------	------------	-----------	-------	-------

^dThe PSD Draft Permit (Specific Condition 14) requires operation of the flue gas desulfurization equipment while firing Orimulsion, HSFO, and LSFO. As currently written, the conditions of certification represent a relaxation from the PSD Draft Permit which was not appropriately publicly noticed.

^eFlue gas desulfurization equipment (specified in the PSD Draft Permit as achieving a minimum of 95% control) will limit low sulfur fuel oil (LSFO) emissions to:

$$\begin{array}{l} \text{1 lb sulfur} \times \text{1 lb HSFO} \times \text{2 lb SO}_2 \times \text{10}^6 \text{ Btu} \times (100\%-95\%) = \text{0.055} \\ \text{lb} \end{array}$$

100 lb HSFO	18,300 Btu	lb sulfur	MMBtu	MMBtu
-------------	------------	-----------	-------	-------

^fCompliance with the extremely aggressive (i.e., low) emission limit of 0.003 gr/dscf should be determined by annual stack tests, which will be federally enforceable.

^gAs a major criteria pollutant (or significant noncriteria pollutant) PSD source, emission limits should be specified for all fuels.

^hEmission rates as given in the PSD Draft Permit. The revised emissions in the conditions of certification would result in exceedances of the Florida Ambient Reference Concentrations for

vanadium, but no risk analysis was performed for the higher emission rate.

⁴The revised conditions of certification as currently written represent a relaxation from the PSD Draft Permit which were not appropriately publicly noticed.

¹No data has been gathered or presented by FPL for organic emissions (dioxins/furans and polycyclic organic matter), although there is a potential for emissions of these compounds based on EPA studies of electric utility sources using coal and oil. Since FPL is proposing to utilize a fuel that has never been commercially used in the United States and which has not been studied as part of the Section 112(n) of the Clean Air Act, such testing and health risk assessments should be performed as part of the initial compliance test and periodically thereafter.

*Sources deleted by FPL for rail enhancements based on Kosky testimony.

¹Since FPL has chosen to use future actual emissions under the electric utility steam generator unit rules to avoid PSD and BACT review for some pollutants, it is important that FPL demonstrates compliance as required by the regulations for this exemption. The Department is requiring 10 year recordkeeping and reporting for the retrofit projects at the Hillsborough County and City of Tampa McKay Bay municipal waste combustors.

¹Since FPL chose to avoid PSD and BACT review for particulate emissions by limiting emissions for all minor PM vents and fugitive emissions to less than 18 tons per year, FPL should be required to maintain adequate records in order to accurately estimate emissions from all such activities so that the permit limit is federally enforceable as a practical matter.



RTP ENVIRONMENTAL ASSOCIATES INC.®

AIR · WATER · SOLID WASTE CONSULTANTS

239 U.S. Highway 22 East
Green Brook, New Jersey 08812-1909
(rtpnj@rtp-environmental.com)

(732) 968-9600
Fax: (732) 968-9603

March 17, 1998

Mr. Brian Beals
U.S. EPA - Region IV
100 Alabama Street, N.W.
Atlanta, GA 30303

Dear Mr. Beals:

I've enclosed additional written information concerning our comments on the Orimulsion project proposed by Florida Power & Light (FP&L) for their Manatee power station. As I indicated to you during our phone conversation, we have considerable concerns related to this application and its processing. The most serious issue relates to the calculation of historical actual, and future predicted emissions for nitrogen oxides (NO_x). We believe there has been a clear miscalculation in the current permitting case, such that PSD review should be required. Additionally, numerous changes have occurred throughout the project that would necessitate reissuing a draft permit for public review.


I've enclosed some back-up calculations related to the NO_x issues to support our contention. Additionally, I understand Manasotta 88 submitted separately a copy of an issues book with references as part of the PSD permit. These contain our additional comments on the application process.

I appreciate your current staff difficulties in terms of availability, but feel that this project is extremely sensitive nationwide as well as within Region IV, and deserves a high priority.

Please feel free to give me a call at (732) 968-9600 if you wish to discuss the enclosed materials or require any further information.

Sincerely,

RTP ENVIRONMENTAL ASSOCIATES, INC.®


Donald F. Elias
Principal

DFE/trp

Enclosures

cc: G. Worley
C. Fancy
L. Curtin
Proj. File - HKOR

ISSUE # 5: Historical Actual Emissions for NO_x Overstated

Historical actual emissions for NO_x are incorrectly calculated and require a further reduction either in emission rate or unit availability to avoid PSD review.

BASIS: Historical actual NO_x emissions as presented in the application and recent applicant exhibits disagree with the annual operating reports filed by the applicant. Since both were filed as true, complete, and accurate, obviously one must be corrected. Assuming the current information filed with the application is correct, it states 7318 tons per year as the historical actuals. This seems to be based on the permit allowables rather than actuals. If you calculate the actuals used by the average of the CEM data, rather than the permit allowables, total average annual actual NO_x emissions based on the '93-'94 data would be 5478 tons/year. Since the facility now operates with steam atomization to reduce NO_x, the "representative" facility rate is the current rate represented by the CEM data times the historical capacity factor. In order to avoid a significant increase for NO_x, future actuals would need to be reduced either by reducing the emission rate or by reducing the operating hours.

BASIS: 1993 and 1994 Annual Operating Reports, Exhibit R-50 from Kosky deposition, CEM data for the Manatee Generating Station, and copy of calculations.

MEMORANDUM

TO: Donald F. Elias
 FROM: Brian L. Lubbert & A. Roger Greenway
 DATE: 23-Jan-98
 SUBJECT: Comparison of Actual Historical Emissions

Comparison of Actual Historical Emissions

Pollutant	Average Emissions Em. Stmt. 93-94	'94 Permit- App. Table 3-3 Emissions	FL-DEP Draft Permit Table 1	Kosky Exhibit 6	Additional Stack Test Data	CEM Data
NOx	7198	7581	6827	7318	6813	5478
TSP.	2516	3159	1707	1768-1792	1627	NA

See Attached Calculations, Exhibits, and Emission Statements

DEP - B3 1/15/95

NOx - 7294

caused by switch in
heat content
from

151,890 Btu/gal
to

152,381 Btu/gal

CALCULATIONS

NOx Emissions

Emission Statements

1993	44 lb /kgal	X	313,830.67 kgal	6904 Tons	Average= 7198 T
1994	45.71 lb /kgal	X	327,800.00 kgal	7492 Tons	

**44 lb/kgal is AP-42, 45.71 lbs/kgal is the product of 0.3 lbs/MMBtu by 152,381 Btu/gal

1994 Permit App.

1993	45.564 lb /kgal	X	313,830.68 kgal*	7150 Tons	Average= 7581 T
1994	45.564 lb /kgal	X	351,644.08 kgal*	8011 Tons	

1994 est on fuel usage

*Calculated from Table A-10 (bbbs)

**45.594 lbs/kgal is the approx. the product of 0.3 lbs/MMBtu by 151,980 Btu/gal

NOTE: calculation must use 45.564 lbs/kgal to equal what is in permit app.

FL-DEP Permit PA 94-35 PSD-FL-219

0.280 lbs/MMBtu	X	48,785,409 MMBtu	6827 Tons	Average= 6827 T
-----------------	---	------------------	-----------	-----------------

**Fuel usage/Heat Input based on Kosky Exhibit 10 (average 1993/94).

Emission Factor based on average emissions from stack test reports (see Table 1 footnote a) in Draft Permit PA-35 nPSD-FL-219

Kosky Exhibit 6

0.3 lbs/MMBtu	X	48,785,409 MMBtu	7318 Tons	Average= 7318 T
---------------	---	------------------	-----------	-----------------

**Fuel usage/Heat Input based on Kosky Exhibit 10 (average 1993/94)

CEM data

Boiler #1(93)	0.219 lbs/MMBtu	X	20,749,229 MMBtu	2272 Tons
Boiler #2(93)	0.229 lbs/MMBtu	X	27,072,589 MMBtu	3100 Tons
1993:			47,821,818 MMBtu	5372 Tons

Boiler #1(94)	0.219 lbs/MMBtu	X	22,451,949 MMBtu	2458 Tons
Boiler #2(94)	0.229 lbs/MMBtu	X	27,297,050 MMBtu	3126 Tons
1994:			49,748,999 MMBtu	5584 Tons

**Fuel usage/Heat Input based on Kosky Exhibit 10

Average= 5478 T

1993/1994 Emissions Compliance Test for Boilers #1 and #2

Boiler #1(93)	0.29 lbs/MMBtu	X	20,749,229 MMBtu	3009 Tons
Boiler #2(93)	0.29 lbs/MMBtu	X	27,072,589 MMBtu	3926 Tons
1993:			47,821,818 MMBtu	6934 Tons

Boiler #1(94)	0.28 lbs/MMBtu	X	22,451,949 MMBtu	3143 Tons
Boiler #2(94)	0.26 lbs/MMBtu	X	27,297,050 MMBtu	3549 Tons
1994:			49,748,999 MMBtu	6692 Tons

Average= 6813 T

Compliance test data is used to estimate the actual historical emissions during the year the stack test was taken.

Compliance test data for Boiler #1 is from 4/1/93 and 5/12/94.

Compliance test data for Boiler #2 is from 4/22/93 and 6/8/94.

**Fuel usage/Heat Input based on Kosky Exhibit 10

Annual emissions estimates are based on calculation format used in Kosky Exhibit 10

Emission Compliance Test (1993/94 assuming Worst-case results of 0.29 lbs/MMBtu)

0.29 lbs/MMBtu	X	48,785,409 MMBtu	7074 Tons	Average= 7074 T
----------------	---	------------------	-----------	-----------------

Emission Factor based on worst-case results of 1993 and 1994 stack tests.

** Fuel usage/Heat Input based on Kosky Exhibit 10 (average 1993/94)

CALCULATIONS

CEM Test Data: 3Q, 4Q 1996 and 1Q, 2Q, 1997 (Kosky Exhibit 10 12/11/97)

NOx

Boiler #1

1993	136,167	kGal/yr
x	152.381	MMBtu/kgal
	20,749,229	MMBtu
x	0.219	(EF)lbs/MMBtu
	<u>2272</u>	T (NOx)/year

1994	147,341	kGal/yr
x	152.381	MMBtu/kgal
	22,451,949	MMBtu
x	0.219	(EF)lbs/MMBtu
	<u>2458</u>	T (NOx)/year

Boiler #2

1993	177,664	kGal/yr
x	152.381	MMBtu/kgal
	27,072,589	MMBtu
x	0.229	(EF)lbs/MMBtu
	<u>3100</u>	T (NOx)/year

1994	179,137	kGal/yr
x	152.381	MMBtu/kgal
	27,297,050	MMBtu
x	0.229	(EF)lbs/MMBtu
	<u>3126</u>	T (NOx)/year

Total Emissions	Boiler #1	Boiler #2	Total
1993	2272	3100	5372 T (NOx)/year
1994	2458	3126	5584 T (NOx)/year
Average	2365	3113	5478 T (NOx)/year

(Kosky Exhibit 10 12/11/97)

PM

Boiler #1

1993	136,167	kGal/yr
x	152.381	MMBtu/kgal
	20,749,229	MMBtu
x	0.05875	(EF)lbs/MMBtu
	<u>610</u>	T (PM)/year

1994	147,341	kGal/yr
x	152.381	MMBtu/kgal
	22,451,949	MMBtu
x	0.07	(EF)lbs/MMBtu
	<u>786</u>	T (PM)/year

EF determined as 87.5% of operation: Sootblowing at 0.06 lbs/MMBtu

plus 12.5% of operation: Steady State at 0.05 lbs/MMBtu

EQ: $87.5\% \times 0.06 + 12.5\% \times 0.05 = 0.05875$

EF determined as 0.07 = sootblowing = steady state

Boiler #2

1993	177,664	kGal/yr
x	152.381	MMBtu/kgal
	27,072,589	MMBtu
x	0.08	(EF)lbs/MMBtu
	<u>1083</u>	T (PM)/year

1994	179,137	kGal/yr
x	152.381	MMBtu/kgal
	27,297,050	MMBtu
x	0.0775	(EF)lbs/MMBtu
	<u>1058</u>	T (PM)/year

EF determined as 0.08 = sootblowing = steady state

EF determined by 87.5% of operation: Sootblowing at 0.08 lbs/MMBtu

plus 12.5% of operation: Steady State at 0.06 lbs/MMBtu

EQ: $87.5\% \times 0.08 + 12.5\% \times 0.06 = 0.0775$

Total Emissions	Boiler #1	Boiler #2	Total
1993	610	1083	1693 T (PM)/year
1994	786	1058	1844 T (PM)/year
Average	698	1071	1769 T (PM)/year

NOTE: annual fuel usage is rounded to nearest kgal, MMBtu as shown above calculated (apparently) from actual gallons

Fuel usage numbers/Heat Input based on Exhibit 10)

CALCULATIONS**Annual Emissions Statement(s)**

Total Emissions	Boiler #1	Boiler #2	Total	
1993	828	1080	1908	T (PM)/year
1994	1404	1719	3123	T (PM)/year
Average	1116	1400	2516	T (PM)/year

Annual Emissions Statement(s)

Total Emissions	Boiler #1	Boiler #2	Total	
1993	2996	3909	6905	T (NOx)/year
1994	3367	4124	7491	T (NOx)/year
Average	3182	4017	7198	T (NOx)/year

See Attached Emission Statements

DEP-B3

Comment: The application states the current actual emissions to be the highest emissions while firing low sulfur fuel oil (LSFO), although actual emissions are defined in Rule 62-212.200(2) (a), FAC., to be "in general, actual emissions as of a particular date shall equal the average rate, in tons per year, at which the source actually emitted the pollutant during a two year period which precedes the particular date and which is representative of the normal operation of the source". Using the date of application, September 30, 1994, as the "particular date" please provide the actual emissions for the two-year period preceding it. Include your calculations, revise any tables as necessary, and revise or add any modeling as necessary. For example, a review of FPL's annual operating report data, which was submitted for 1992 and 1993, indicates that the increase in particulate matter and PM10 is PSD-significant.

Response: The emission data for the two units at the Manatee Plant presented in the Site Certification Application (SCA) represent actual emission data for the two units for 1993 and 1994. As discussed in the SCA, the 1994 data were based on actual fuel consumption through July 31, 1994, and prorated to the remainder of the year. These data were considered to represent the emissions from the normal operation of the two units for a 2-year period. Although another 2-year period might also be considered, the net changes in actual emissions from the units exceed the PSD significant emission rates for only nitrogen oxides (NO_x) and carbon monoxide (CO), regardless of which 2-year period is considered representative. The net changes in actual emissions are similar even if the last 3 years are considered in the evaluation. As a result, the PSD applicability analyses and review process do not change from those presented in the SCA. The suggestion that the increases in particulate matter and PM10 emissions are PSD-significant is incorrect.

Comparisons of actual annual emissions for the existing units at the Manatee Plant were performed by evaluating fuel usage data over the last 3 years, (1992 through 1994). As requested, an evaluation was performed for September 1992 through September 1994, the 2-year period preceding the application submittal date of September 30, 1994; an evaluation has also been performed for 1993 and 1994 using actual fuel use data for August through December 1994 that was not available at the time of SCA submittal. Summaries of the fuel usage and annual capacity factors for each unit are presented in Table DEP-B3-1 for the period of September 1992 through September 1994; and Table DEP-B3-2 for the years 1993 and 1994. These tables are comparable to Table A-10 presented in the Appendix 10.1.5, Volume II of the SCA.

Comparisons of the maximum estimated annual emissions for existing low sulfur fuel oil (LSFO) and the proposed firing of Orimulsion for the selected periods are presented in Table DEP-B3-3. Emissions are shown for sulfur dioxide, particulate matter, nitrogen oxides, carbon monoxide, volatile organic compounds, and lead. Emissions of other regulated pollutants presented in the SCA (i.e., sulfuric acid mist, fluorides, mercury, beryllium, and arsenic) were added together and summarized. As shown, although there are some differences in the net emission changes for all pollutants among the evaluations, NO_x and CO continue to be the only two pollutants for which there is a PSD-significant net emission increase. For the other regulated pollutants, there is a net decrease in emissions requiring no PSD review. As shown in the footnote, the average annual capacity factors for the plant for the evaluated time periods are within 3 percent, indicating the relatively minor differences in plant operation among the time periods. It should be noted that the emission data for 1992 may not be representative of actual plant operation because of planned outages for equipment upgrades that occur about once every 15 years (the units were not operating for about 25 percent of the year). Therefore, the use of emission data for this year is not necessarily representative of annual plant emissions.

The maximum emissions estimated for the AORs are different than those presented in the Air Permit Application. The information reported in the AORs are based on average emission factors obtained from the EPA document, "Compilation of Air Pollutant Emission Factors," which is referred to as AP-42. These factors do not account for "excess emissions" which are allowed under DEP regulations (Rule 62-210.700, Excess Emissions) and were incorporated in the air permit for each unit. For example, under steady-state operating conditions, each unit has a PM emission limit of 0.1 lb/MMBtu. However, during sootblowing and load changing, each unit can emit up to 0.3 lb/MMBtu for 3 hours in a 24-hour period. As an example, PM emissions for 1992 and 1993 reported in the AORs were estimated to be 1,896 TPY. For this same time period, by accounting for sootblowing, the PM emissions are estimated to be 2,953 TPY. Also, source specific allowable emissions can be assumed equivalent to actual emissions provided that the source specific allowable emissions are federally enforceable (see Rule 62-212.200(2)). These federally enforceable emission limiting standards are codified in Rule 62-296.405 for PM,

SO₂, and NO_x. As a result, the emission limits for these pollutants were used in estimating actual emissions when each unit is firing LSFO.

It should be noted that even using the AORs for 1992 and 1993, PSD applicability for PM/PM10 would not change. As noted above the AORs presented average annual PM/PM10 emissions of 1,896 TPY for 1992/1993. The representative actual PM/PM10 emissions when firing Orimulsion would be 1,749 TPY which is a 147 TPY decrease in PM/PM10 emissions even though sootblowing emissions were not expressly accounted for in the AORs; thus, PSD applicability would not be triggered.

No additional air modeling is required because the impacts due to firing Orimulsion or HSFO assumed the maximum emission rate for each pollutant and did not account for the difference in emissions between firing these fuels and LSFO. For example, the air quality modeling analyses for the Manatee Plant after conversion to Orimulsion that addressed compliance with the NO₂ maximum allowable PSD Class II and I increments did not include the existing Manatee Plant (see Section 7.3 and 7.4, Appendix 10.1.5, Volume II of the SCA). As a result, the increment consumption would be lower than the maximum value reported (increment consumption due to the Manatee Plant is the difference in impacts between the proposed future operations and actual existing operations).

Table DEP-B3-1. Existing Fuel Oil Usage at the FPL Manatee Plant (9/29/92 to 9/28/94)

Parameter	Values for FPL Units	
	Unit 1	Unit 2
Fuel Usage (bbls)		
9/29/92 to 9/28/94	6,639,726	7,951,034
Average	3,319,863	3,975,517
Maximum	11,877,957	11,877,957
Capacity Factor (a)		
9/29/92 to 9/28/94	27.95%	33.47%
Average	27.95%	33.47%
Sulfur Content:		
1992	0.989%	0.986%
1993	0.973%	0.973%
1994	0.973%	0.976%

(a) Based on maximum heat input of 8,650 MMBtu/hr per unit and fuel oil with heat content and density of 18,300 Btu/lb and 8.3 lb/gal, respectively.

13360/DEP/A11A13R3
01/15/98

Table DEP-B3-2. Existing Fuel Oil Usage at the FPL Manatee Plant (1993/1994) - Actual Fuel Use

Parameter	Values for FPL Units	
	Unit 1	Unit 2
Fuel Usage (bbls)		
1993	3,242,067	4,230,092
1994	3,508,117	4,265,164
Average	3,375,092	4,247,628
Maximum	11,877,957	11,877,957
Capacity Factor (a)		
1993	27.29%	35.61%
1994	29.53%	35.91%
Average	28.41%	35.76%
Sulfur Content:		
1993	0.973%	0.973%
1994	0.973%	0.976%

(a) Based on maximum heat input of 8,650 MMBtu/hr per unit and fuel oil with heat content and density of 18,300 Btu/lb and 8.3 lb/gal, respectively.

13366D/DEP/AQRCO

Table DEP-B3-3. Comparison of Maximum Estimated Annual Emissions for Existing Low Sulfur Fuel Oil (Actual) and Proposed Orimulsion Representative Actual) Firing at FPL Manatee Units 1 and 2

Pollutant	Emissions (TPY)- Existing Units	Emissions (TPY)- Orimulsion		PSD Significant Net Emission Rate (TPY)	Significant Net Emission Increase?
	Low Sulfur Fuel Oil	2 Units	Difference (Orimulsion-LSFO)		
<u>Actual Emissions Based on 1993/1994 - presented in SCA (1)</u>					
Sulfur Dioxide	27,617	13,635	-13,982	40	No
Particulate Matter	3,159	1,749	-1,410	25	No
Particulate Matter (PM10)	2,274	1,749	-525	15	No
Nitrogen Oxides	7,581	17,491	9,910	40	Yes
Carbon Monoxide	16,026	18,948	2,922	100	Yes
Volatile Organic Compounds	126.4	117.6	-8.8	40	No
Lead	0.708	0.163	-0.544	0.6	No
Other Regulated Pollutants (2)	1,162	420	-743	(2)	No
<u>Actual Emissions Based on 1993/1994 Actual Fuel Usage (3)</u>					
Sulfur Dioxide	26,573	13,635	-12,938	40	No
Particulate Matter	3,039	1,749	-1,290	25	No
Particulate Matter (PM10)	2,188	1,749	-439	15	No
Nitrogen Oxides	7,294	17,491	10,196	40	Yes
Carbon Monoxide	15,420	18,948	3,528	100	Yes
Volatile Organic Compounds	121.7	117.6	-4.1	40	No
Lead	0.681	0.163	-0.518	0.6	No
Other Regulated Pollutants (2)	1,119	420	-699	(2)	No
<u>Actual Emissions Based on 9/92 to 9/94 (4)</u>					
Sulfur Dioxide	25,432	13,635	-11,797	40	No
Particulate Matter	2,909	1,749	-1,160	25	No
Particulate Matter (PM10)	2,094	1,749	-345	15	No
Nitrogen Oxides	6,981	17,491	10,510	40	Yes
Carbon Monoxide	14,758	18,948	4,190	100	Yes
Volatile Organic Compounds	116.4	117.6	1.2	40	No
Lead	0.652	0.163	-0.488	0.6	No
Other Regulated Pollutants (2)	1,071	420	-651	(2)	No

(1) See Table 3-3 and Table A-11, Appendix 10.1.5, Volume II, Site Certification Application; fuel usage from 1993 and 1994 (fuel usage through 7/31/94 prorated to entire year).

(2) Other regulated pollutants include sulfuric acid mist (7 TPY), fluorides (3 TPY), mercury (0.1 TPY), beryllium (0.0004 TPY), and arsenic (0 TPY) [Numbers in parentheses in this footnote are the PSD significant emission rates for each specific pollutant].

(3) Based on actual fuel usage from 1993 and 1994.

(4) Based on maximum allowable emission rates/test data from SCA and fuel usage from September 29, 1992 through September 28, 1994.



Department of Environmental Protection

Lawton Chiles
Governor

Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Virginia B. Wetters
Secretary

PERMITTEE:

Florida Power & Light Company
700 Universe Boulevard
Juno Beach, Florida 33408

Permit Number: PA 94-35

PSD-FL-219

Expiration Date: December 31, 1998

County: Manatee

Location: Hwy 62, 5 miles NE of Parrish, FL

UTM: 17-367.3 km E 3054.1 km N

Project: Manatee Power Plant Modification
Orimulsion Conversion Project

This permit is issued under the provisions of Chapter 403, Florida Statutes, and Florida Administrative Code Chapters 62-200 through 297 & Chapter 62-4. The above named permittee is hereby authorized to perform the work or operate the facility shown on the application and approved drawing(s), plans, and other documents, attached hereto or on file with the department and made a part hereof and specifically described as follows:

For modification of existing emission units

- 01 Unit #1 - Fossil fuel-fired steam generating unit
- 02 Unit #2 - Fossil fuel-fired steam generating unit

including adding additional sootblowers and increasing heat surface area of the boilers to accommodate the firing of Orimulsion fuel, and High (maximum 3.0% by weight) Sulfur Fuel Oil (HSFO) when Orimulsion is unavailable, in addition to the Low (1.0% or less) Sulfur Fuel Oil (LSFO) currently fired in the units. Air pollution control equipment, including a Pure Air flue gas desulfurization (FGD) system with a minimum sulfur dioxide removal efficiency of 95%, Pure Air electrostatic precipitators (ESP) with a minimum particulate removal efficiency of 90%, and low-NOx burners, will be installed to reduce emissions of sulfur dioxide, particulate matter, and nitrogen oxides; and

For construction of new emission units for handling and storage of limerock/limestone, flyash, and gypsum as listed below:

- 03 Limerock/Limestone Truck Unloading - fugitive emissions
- 04 Limerock Rail Unloading - fugitive emissions
- 05 Limestone Storage Pile - fugitive emissions
- 06 Limerock Storage Pile - fugitive emissions
- 07 Limerock/Limestone Receiving Hoppers - fugitive emissions
- 08 Limestone Blending Silo with dust collector/bag filter vent

Table 1: Significant and Net Emission Rates (Tons per Year)

Pollutant	Low Sulfur Fuel Oil Actual Emissions _a	Projected Maximum Emissions _b	Proposed Net Emissions Increase	Significant Emission Rate	Applicable Pollutant (Yes/No)
PM **	1,707	1,707	0	25	No
PM ₁₀ **	1,707	1,707	0	15	No
SO ₂	24,492	13,643	-10,849	40	No
NO _x	6,827	15,742 *	8,915	40	Yes
CO	15,463	18,948	3,485	100	Yes
VOC	122	117 ***	-5	40	No
Lead	0.683	0.163 +	-0.520	0.6	No
Mercury	0.078	0.006 ***	-0.072	0.1	No
Beryllium	0.10240	0.00036 ***	-0.10205	0.0004	No
Fluorides	0.15	0.037 +	-0.117	3	No
Sulfuric Acid Mist	1,122	420 ***	-702	7	No

a-NO_x and particulate emission rates based on 1993 and 1994 fuel data, heat content of 152 mmBtu/kgal and average emissions from stack test reports. SO₂ emissions based on annual operating report (AOR). Emission rates for other pollutants based on emission factors.

b-based on 87 percent capacity factor and a maximum continuous heat input rating of 7,650 mmBtu/hr firing Orimulsion.

* Based on NO_x emission limit of 0.27 lb/mmBtu as provided by FPL. Annual NO_x emissions with a limit of 0.17 lb/mmBtu would be 9,912 TPY.

** Annual PM/PM₁₀ emissions capped at previous actual emission level by permit condition.

*** Based on emission rates from tests on Orimulsion submitted by FPL.

+ Based on EPA emission factor and 90% control.

BEST AVAILABLE COPY

FLORIDA POWER AND LIGHT COMPANY
PLANT SERVICES OPERATIONS SUPPORT
700 UNIVERSE BLVD.
JUNO BEACH, FLORIDA 33408-0240

NOx EMISSION TEST

PLANT: MANATEE
UNIT: 1
TEST: NITROGEN OXIDE EMISSIONS
METHOD: 40 CFR Pt. 60, App. A, 3A & 7E

	RUN 1	RUN 2	RUN 3
DATE OF RUN	04/01/93	04/01/93	04/01/93
GROSS LOAD (AVG MMBTU/HR)	7311	7311	7311
START TIME (24-HR CLOCK)	1129	1403	1538
END TIME (24-HR CLOCK)	1229	1503	1638
CO2 (CORRECTED % DRY)	13.2	13.5	13.4
O2 (CORRECTED % DRY)	4.1	3.9	4.0
Fo TEST	1.273	1.259	1.261
NET TIME OF RUN (MIN)	60	60	60
MEASURED CONCENTRATION (PPM NOx)	213.0	207.4	206.6
AVG ZERO BIAS CHECK (PPM NOx)	0.0	0.0	0.0
UPSCALE CALIBRATION GAS (PPM NOx)	205.0	205.0	205.0
AVG UPSCALE BIAS CHECK (PPM NOx)	202.3	200.3	199.4
CORRECTED CONCENTRATION (PPM NOx)	215.9	212.4	212.4
HEAT INPUT OIL (%)	100.0	100.0	100.0
HEAT INPUT GAS (%)	0.0	0.0	0.0
WEIGHTED AVERAGE F FACTOR (DSCF/MMBTU)	9190.0	9190.0	9190.0
NOx EMISSIONS (LB/MMBTU)	0.294	0.286	0.288
AVERAGE NOx EMISSIONS (LB/MMBTU)		0.29	
NOx EMISSIONS STANDARD (LB/MMBTU)		0.30	

FDEP SOUTHWEST DIST

Fax:813-744-6458

Jan 21 '98 10:26

P.02

FLORIDA POWER AND LIGHT COMPANY
PLANT SERVICES OPERATIONS SUPPORT
700 UNIVERSE BLVD.
JUNO BEACH, FLORIDA 33408-0240

NO_x EMISSION TEST

PLANT: MANATEE
UNIT: 2
TEST: NITROGEN OXIDE EMISSIONS
METHOD: 40 CFR Pt. 60, App. A, 3A & 7E

	RUN 1	RUN 2	RUN 3
DATE OF RUN	04/22/93	04/22/93	04/22/93
GROSS LOAD (AVG MMBTU/HR)	7231	7231	7231
START TIME (24-HR CLOCK)	1116	1255	1255
END TIME (24-HR CLOCK)	1216	1355	1355
CO ₂ (CORRECTED % DRY)	13.7	13.7	13.7
O ₂ (CORRECTED % DRY)	3.7	3.7	3.7
F _o TEST	1.255	1.255	1.255
NET TIME OF RUN (MIN)	60	60	60
MEASURED CONCENTRATION (PPM NO _x)	211.7	214.8	214.8
AVG ZERO BIAS CHECK (PPM NO _x)	0.0	0.0	0.0
UPSCALE CALIBRATION GAS (PPM NO _x)	128.9	128.9	128.9
AVG UPSCALE BIAS CHECK (PPM NO _x)	125.5	126.5	126.5
CORRECTED CONCENTRATION (PPM NO _x)	217.5	218.9	218.9
HEAT INPUT OIL (%)	100.0	100.0	100.0
HEAT INPUT GAS (%)	0.0	0.0	0.0
WEIGHTED AVERAGE F FACTOR (DSCF/MMBTU)	9190.0	9190.0	9190.0
NO _x EMISSIONS (LB/MMBTU)	0.289	0.291	0.291
AVERAGE NO _x EMISSIONS (LB/MMBTU)		0.29	
NO _x EMISSIONS STANDARD (LB/MMBTU)		0.30	

FLORIDA POWER AND LIGHT COMPANY
 PLANT SERVICES OPERATIONS SUPPORT
 700 UNIVERSE BLVD.
 JUNO BEACH, FLORIDA 33408-0240

NOx EMISSION TEST

PLANT: MANATEE
 UNIT: 2
 TEST: NITROGEN OXIDE EMISSIONS
 METHOD: 40 CFR Pt. 60, App. A, 3A & 7E

	RUN 1	RUN 2	RUN 3
DATE OF RUN	06/08/94	06/08/94	06/08/94
GROSS LOAD (AVG MMBTU/HR)	7602	7602	7602
START TIME (24-HR CLOCK)	1100	1232	1400
END TIME (24-HR CLOCK)	1200	1332	1500
CO2 (CORRECTED % DRY)	13.1	13.2	13.3
O2 (CORRECTED % DRY)	4.0	4.0	3.9
Fo TEST	1.293	1.280	1.275
NET TIME OF RUN (MIN)	60	60	60
MEASURED CONCENTRATION (PPM NOx)	193.5	197.1	193.5
AVG ZERO BIAS CHECK (PPM NOx)	0.0	0.5	1.0
UPSCALE CALIBRATION GAS (PPM NOx)	210.0	210.0	210.0
AVG UPSCALE BIAS CHECK (PPM NOx)	208.5	210.5	211.0
CORRECTED CONCENTRATION (PPM NOx)	194.8	196.6	192.5
HEAT INPUT OIL (%)	100.0	100.0	100.0
HEAT INPUT GAS (%)	0.0	0.0	0.0
WEIGHTED AVERAGE F FACTOR (DSCF/MMBTU)	9190.0	9190.0	9190.0
NOx EMISSIONS (LB/MMBTU)	0.264	0.266	0.262
AVERAGE NOx EMISSIONS (LB/MMBTU)		0.26	
NOx EMISSIONS STANDARD (LB/MMBTU)		0.30	

FLORIDA POWER AND LIGHT COMPANY
 OPERATIONS SERVICES EMISSION TEST GROUP
 700 UNIVERSE BLVD.
 JUNO BEACH, FLORIDA 33408-0240

NO EMISSION TEST

PLANT: MANATEE
 UNIT: 1
 TEST: NITROGEN OXIDE EMISSIONS
 METHOD: 40 CFR Pt. 60, App. A, 3A & 7E

	TOTAL RUN 1	TOTAL RUN 2	TOTAL RUN 3
DATE OF RUN	05/12/94	05/12/94	05/12/94
GROSS LOAD (AVG MMBTU/HR)	7514	7514	7514
START TIME (24-HR CLOCK)	949	1127	1314
END TIME (24-HR CLOCK)	1049	1227	1414
CO2 (CORRECTED % DRY)	13.6	13.6	13.5
O2 (CORRECTED % DRY)	3.7	3.8	3.6
Fo TEST	1.265	1.257	1.281
NET TIME OF RUN (MIN)	60	60	60
MEASURED CONCENTRATION (PPM NO)	210.96	212.90	204.89
AVG ZERO BIAS CHECK (PPM NO)	0.0	0.0	0.0
UPSCALE CALIBRATION GAS (PPM NO)	129.7	129.7	129.7
AVG UPSCALE BIAS CHECK (PPM NO)	127.4	127.3	127.0
CORRECTED CONCENTRATION (PPM NO)	214.8	217.0	209.2
HEAT INPUT OIL (%)	100.0	100.0	100.0
HEAT INPUT GAS (%)	0.0	0.0	0.0
WEIGHTED AVERAGE F FACTOR (DSCF/MMBTU)	9190.0	9190.0	9190.0
NO EMISSIONS (LB/MMBTU)	0.286	0.290	0.277
AVERAGE NO EMISSIONS (LB/MMBTU)		0.28	
NO EMISSIONS STANDARD (LB/MMBTU)		0.30	

CONFIDENTIAL
ATTORNEY WORK PRODUCT

ISSUE # 7: Future Projected Actuals Are Incorrectly Calculated

Projected actuals for PM/PM₁₀ and NO_x use hourly emission rates that are less than the permitted levels. Additionally, no limits exist for CO and VOC for HSFO and LSFO, and VOC has no hourly limit for Orimulsion. Also, SO₂ has a higher emission limit for HSFO and LSFO. These limits must be revised and permit limits established that demonstrate compliance with the future actual projections.

BASIS: WEPCO Rule 57 FR 32323, "The future actual projection is the product of: (1) the hourly emissions rate, which is based on the unit's physical and operational capabilities following the change and federally enforceable operational restrictions that would effect the hourly emissions rate following this change; and (2) projected capacity utilization, which is based on (a) the unit's historical annual utilization, and (b) all available information regarding the unit's likely post-change capacity utilization."

Also WEPCO ruling.

whether a utility unit is "less environmentally beneficial" after controls than it was before controls. Accordingly, the final rule allows consideration of all environmental impacts—beneficial and adverse—in making a determination.

B. Representative Actual Annual Emissions

1. Background

The EPA proposed to clarify its methodology for calculating emissions increases at electric utility steam generating sources that had begun normal operations. The EPA proposed to compare actual emissions before and after changes for all physical or operational changes at an existing electric utility steam generating unit other than the addition of a new unit or the replacement of an existing unit. The EPA proposed to consider a unit to be replaced if it would constitute a reconstructed unit within the meaning of 40 CFR 60.15. Since there is no relevant operating history for wholly new units and replaced units, it is not possible to reasonably project post-change utilization for these units; and hence, their future level of "representative annual actual emissions." For other changes, past operating history, and other relevant information, provides a basis for reasonable projections.

As proposed, the "representative actual annual emissions" methodology requires the utility to compare its baseline emissions with its future actual emissions to determine if the proposed change will increase actual emissions. The EPA's existing regulations define baseline emissions as "the average rate, in tpy, at which the unit actually emitted the pollutant during a 2-year period which precedes the particular date and which is representative of normal source operation" (see, e.g., 40 CFR 52.21). The Administrator "shall" allow use of a different time period "upon a determination that it is more representative of normal source operation." *Id.* Although not required by the regulations, EPA has historically used the 2 years immediately preceding the proposed change to establish the baseline [see 45 FR 52878, 52705, 52718 (1980)]. However, in some cases it has allowed the use of earlier periods. For example, in *WEPCO*, EPA found the fourth and fifth years prior to the modification more representative of *WEPCO's* normal operations since the source's capacity was reduced due to physical problems. The EPA proposed to retain this regulatory language, but to adopt a new presumption regarding its implementation.

Under the proposed action, the Administrator would presume that any 2 consecutive years within the 5 years prior to the proposed change is representative of normal source operations for a utility. This presumption is consistent with the 5-year period for "contemporaneous" emissions increases and decreases in 40 CFR 52.21(b)(3)(i)(b).¹⁷ Source owners or operators desiring to use other than a 2-year period or a baseline period prior to the last 5 years may seek the Administrator's specific determination that such period is more representative of normal operations.¹⁸

The future actual projection is the product of: (1) The hourly emissions rate, which is based on the unit's physical and operational capabilities following the change and federally-enforceable operational restrictions that would affect the hourly emissions rate following this change; and (2) projected capacity utilization, which is based on (a) the unit's historical annual utilization, and (b) all available information regarding the unit's likely post-change capacity utilization.¹⁹ The projection of post-change capacity utilization for applicability purposes should be based on a projection of utilization for a period after the physical or operational change. Specifically, EPA proposed to allow sources to base the projection of utilization on the 2 years after the change; or a different consecutive 2-year period within the 10 years after the change, where the Administrator determines that such period is more representative of normal source operations.

2. Comments Generally Favoring the EPA Proposal

a. Several commenters favored the expansion of the time period for establishing the pre-change emissions baseline. Suggestions included:

¹⁷ This presumption does not apply to past modifications at an emissions unit for the purpose of determining contemporaneous emission changes at a source and cannot be used to extend the 5 year period specified in that provision [see 40 CFR 52.21(b)(3)(i)(b)].

¹⁸ The level of baseline emissions selected must be consistent with current assumptions regarding the source's emissions that are used under the SIP for planning or permitting purposes. Thus, the source may not select a level of baseline emissions higher than that used by the permitting authority in issuing a PSD or other construction permit to a source in the area, if such higher level would result in a NAAQS or increment violation, or violate a visibility limitation.

¹⁹ In projecting future utilization and emissions factors, the permitting authority may consider the company's historical operational data, its own representations, filings with Federal, State or local regulatory authorities, and compliance plans developed under Title IV of the 1990 Amendments;

(1) Allow the use of any 2 consecutive years within the last 5 years of operation to allow for a more representative baseline for units that have been shut down;

(2) Allow utilities to request to use periods of representative high utilization outside the 5 year time period;

(3) Add the "any 2 out of the prior 5 year baseline period" discussed in the preamble to 40 CFR parts 51, 52, and 60;

(4) Allow utilities to use the maximum utilization in any 1 year within at least the last 10 years, since 10 years is a more relevant capacity investment planning horizon than 5 years;

(5) Clarify that the source will be able to select the relevant 2-year period with approval of the reviewing authority required only when the pre-change baseline is outside of the 5-year period preceding the change;

(6) Expand the baseline calculation period from 5 years to 10 years to be consistent with the after-change calculation period and to address a more representative time period;

(7) Allow the use of any 2 years (rather than consecutive years) due to long reserve shutdowns and because maintenance planning requires that utility boilers be operated in "abnormal" conditions for long durations; and

(8) Require sources to back up the choice of which 2 years to use with a short-term standard using an hourly rate, use the same 2-year period for determining the short-term and annual rates, and codify the 2 years used for the limit.

Several comments that recommended expanding the proposal to include industrial sources in the NSR exemption also noted that a "5-year window" is not satisfactory for industrial sources which do not always have representative periods of emissions immediately before a physical change. One industrial commenter suggested the use of any 2-year period be allowed.

Commenters in favor of the future actual emissions calculation method noted that it will alleviate uncertainty, for nonroutine repair, replacement, and maintenance projects while still protecting local air quality; the future-actual method reduces speculation and allows more reliance on factual data; and the actual-to-future-actual emissions comparison is more appropriate to look at the operating history and projected capacity of an existing unit to determine whether a change will increase emissions. One commenter stated that the actual-to-potential method discouraged environmentally beneficial modifications, but suggested that the

Wepeco Court Case #4,48

compare representative actual emissions for the baseline period to estimated future actual emissions based on all the available facts in the record. Specifically, in calculating post-renovation actual emissions, this approach takes into account 1) physical changes and operational restrictions that would affect the hourly emissions rate following the renovation, 2) WEPCO's pre-renovation capacity utilization, and 3) factors affecting WEPCO's likely post-renovation capacity utilization.

To quantify WEPCO's estimated future actual emissions after the proposed changes EPA relied heavily on projected and historical operational data (e.g., fuel consumption, MMBTU consumed) representative of the source. Specifically, the Agency considered available information regarding (1) projected post-change capacity utilization filed with public utility commissions; (2) Federal and State regulatory filings; (3) the source's own representations; and (4) the source's historical operating data. As described below, EPA determined an appropriate utilization factor for future operations and combined this with post-change emissions factors (to the extent they are or will be made federally enforceable) to estimate a future level of annual emissions for the purpose of determining whether the proposed physical and operational changes would be considered a major modification for PSD purposes. Where a significant emissions increase is projected to occur, WEPCO could voluntarily agree to federally-enforceable limits on any aspect of its future operation (including physical capacity and hours of operation) to ensure that no significant emissions increase will occur.


IV. THE AGENCY'S REVISED PSD APPLICABILITY DETERMINATION

A. Estimated Future Actual Emissions.

The Agency has revised its October 14, 1989 PSD applicability determination for WEPCO's proposed Port Washington renovation based on a "representative actual" to "estimated future actual emissions" comparison (as outlined above). As previously discussed, estimated future actual emissions projections take into account the likelihood that the plant will operate in the future as it has in the past.

The stated purpose of WEPCO's renovations is to refurbish the power plant units to an "as-new" condition in terms of their capacity, efficiency, and availability. Consequently, EPA has used actual, historical, operational data representative of the plant's past operations, approximating an "as-new" configuration, to calculate "estimated future actual emissions." The Agency has verified these data by comparison to WEPCO's own projections of post-renovation capacity utilization and industry averages.

As to the emissions factors used to calculate future emissions, EPA has used WEPCO's own emissions factors for future



hourly emissions rates. These emissions factors are based on WEPCO's own assumptions regarding future sulfur in fuel and control technology performance levels. However, since these assumptions go beyond current State implementation plan (SIP) requirements, they must be made federally enforceable for EPA to continue to consider them for PSD applicability purposes.

Operational data (i.e., heat input) from the years 1978-1979 show a capacity utilization factor of 42 percent. These data points represent the closest projection of WEPCO's operational characteristics, approximating an "as-new" state, as currently available to EPA. The data currently available to us regarding WEPCO's past operational levels are limited to a 10-year period. The Agency believes that these historical levels of operation are representative of the plant's past operations in an "as-new" condition. In addition, the 1978-79 data points appear consistent with WEPCO's own projection of future operations for the year 2010 (as submitted to the Wisconsin Department of Natural Resources on March 29, 1990) and common capacity levels for the utility industry, in general, for new units. However, by this letter, EPA is requesting that WEPCO submit operational data from previous years (i.e., pre-1978), if such data show heat input levels notably higher than the 1978-1979 levels.

As previously mentioned, to calculate future emissions levels for each pollutant, EPA assumed that the amount of future coal consumed in terms of heat input to the plant would be comparable to WEPCO's annual average 1978-1979 coal-consumption figure. On March 29, 1990, WEPCO submitted to the Wisconsin Department of Natural Resources information which contained estimates of future emissions for different levels of coal and heat input to the plant. The Agency used these estimates to establish future emissions based on 1978-1979 heat-input values. Again, it is important to note that EPA's calculation of "estimated future actual emissions" is based on WEPCO's projection of control technology performance levels and/or fuel sulfur content for post-renovation operations. Consequently, EPA's PSD applicability determination is valid only to the extent that the emissions factors (based on control technology performance levels and sulfur in fuel) used to calculate future emissions are made federally enforceable. Otherwise, the calculation of estimated future actual emissions for each pollutant will need to be revised by EPA based on existing federally-enforceable limits (i.e., applicable SIP, NSPS). The use of current, federally-enforceable emissions in the current SIP would result in higher projected future emissions than assumed in EPA's calculations and, consequently, could affect the indicated PSD applicability finding.



Department of Environmental Protection

Lawton Chiles
Governor

Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Virginia B. Wetherell
Secretary

FAX TRANSMITTAL SHEET

TO: Don Elias

DATE: 4-3-98

FAX
PHONE: 732/968-9603

TOTAL NUMBER OF PAGES, INCLUDING COVER PAGE: 7

FROM: Clair Fancy

DIVISION OF AIR RESOURCES MANAGEMENT

COMMENTS:

PHONE: 850/488-1344

FAX NUMBER: 850 /922-6979

If there are any problems with this fax transmittal, please call the above phone number.

Memorandum

January 22, 1998

To: Clair Fancy, P.E., FDEP

From: Ken Kosky, P.E., Golder Associates

RE: Historical NOx Emissions from Manatee Plant

Dear Clair:

Please find attached my analysis of the CEM, Net Load Factor (NLF) and Capacity Factor (CF) data from the Manatee Plant during 1995 and 1996. The NLF is the load that the unit is operating when it is running. As shown from these data 1993 and 1994 are quite different. An analysis of the CEM data clearly indicate a relationship of NLF and NOx emissions. This is as expected since higher loads produce higher NOx emissions. Using a direct linear relationship between NLF and NOx emissions (top table), NOx emissions for each unit during 1993 and 1994 were calculated. As shown the calculated NOx emission rate is 0.30 lb/mmBtu. The other method used was the actual regression equation that was developed from the CEM and NLF data. The resulting average NOx emission is also 0.3 lb/mmBtu. Given that the steam atomization provides better combustion control and therefore NOx, the relationships are likely to produce lower NOx emissions than what actually happened. I concluded back in 1994, and confirmed by an analysis of the CEM data, that using a single stack test for pollutants produced through combustion processes (i.e., NOx and PM) is not appropriate. Therefore the 7,318 tons/year is an appropriate emission.

I have also included a chart of the daily, 30-day rolling and annual NOx emissions from one of the Manatee units. Note that daily emissions frequently exceed the 0.3 and include considerable variability. Such variability alone make the use of a single test questionable. I totally agreed with your assessment in the development of the Title V process that fees which were to be based on actual emissions cannot be based on a single test.

Calculation of NOx Emission Rate Using CEM and Net Load Factor

Net Load Factor (NLF)	Unit 1	Unit 2	Average	
1993	55.03%	59.54%	57.49%	
1994	51.01%	58.51%	54.89%	56.19%
1995	42.30%	47.64%	45.16%	
1996	41.54%	45.09%	43.18%	44.17%
1995&96	41.92%	46.37%	44.17%	

NOx Emission Rates (NER) in lb/mmBtu

	Unit 1	Unit 2	Average	1993/94
1993(a)	0.282	0.317	0.302	
1994(a)	0.262	0.312	0.289	0.30
1995	0.207	0.242	0.227	
1996	0.223	0.252	0.237	0.23
1995&96	0.215	0.247		

Capacity Factor (CF)	Unit 1	Unit 2	Total	
1993	29.99%	39.11%	69.10%	0.3455
1994	31.97%	39.35%	71.32%	0.3566
1995	21.81%	28.35%	50.16%	0.2508
1996	22.74%	21.28%	44.02%	0.2201

Notes: (a) Unit NER calculated based on net load factor (NLF) for each unit relative to NOx emission rate from CEM:
 Unit 1993 NLF x 1/1995&96 NLF x 1995&96 NER
 Average NER calculated based on relative capacity factor
 [Unit 1(NER x CF) + Unit 2 (NER x CF)] / [Unit 1 CF + Unit 2

Calculation of 1993 & 1994 NOx CEM Using Regression Analysis

Regression
Equation


$$Y = mx + b$$

$$\text{NOx} = 0.53 (\text{NLF}) - 0.00282$$

	NLF	NOx (lb/mmBtu)
1993 Unit 1	55.03%	0.294
1994 Unit 1	51.01%	0.273
1993 Unit 2	59.54%	0.318
1994 Unit 2	58.51%	0.313
Average:		0.300

BEST AVAILABLE COPY

Manatee Plant Unit 1 NOx Data
July 1996 to July 1997



Memorandum

January 23, 1998

To: Clair Fancy, P.E., FDEP

From: Ken Kosky, P.E., Golder Associates

RE: Historical NOx Emissions from Manatee Plant

Dear Clair:

Attached is an updated prediction of NOx emission levels for 1993 and 1994 that includes the weighted average of NOx emissions based on the capacity factor (i.e., fuel usage). As shown, the predicted NOx level using the regression equation for 1993 and 1994 is 0.296 lb/mmBtu. This prediction is conservatively low, given the installation of steam atomization in 1995 to control the combustion process. This had the effect of being able to lower NOx levels in 1995 and 1996 relative to high pressure atomization used prior to 1995. Also included, is a comparison between the difference in predicted and actual concentrations. As shown the lb/mmBtu difference (last column) is quite small and the average difference is less than 5% (see 4.71%: 0.011 divided by 0.231). This is quite good given the limited data points used in the predictions.

I have also included a graphic of the historical NOx emission for the Manatee Plant over 19 years (1978 through 1996). The 19 year average is 6,970 tons/year. As shown in the figure, there have been years that the NOx was above and below the 1993 and 1994 levels.

Please call if you have any questions.

Ken

Calculation of NOx Emission Rate Using CEM and Net Load Factor

Net Load Factor (NLF)	Unit 1	Unit 2	Average	
1993	55.03%	59.54%	57.49%	
1994	51.01%	58.51%	54.89%	56.19%
1995	42.30%	47.64%	45.16%	
1996	41.54%	45.09%	43.18%	44.17%
1995&96	41.92%	46.37%	44.17%	

NOx Emission Rates (NER) in lb/mmBtu	Unit 1	Unit 2	Average	1993/94
1993(a)	0.282	0.317	0.302	
1994(a)	0.262	0.312	0.289	0.30
1995	0.207	0.242	0.227	
1996	0.223	0.252	0.237	0.23
1995&96	0.215	0.247		

Capacity Factor (CF)	Unit 1	Unit 2	Total	
1993	29.99%	39.11%	69.10%	0.3455
1994	31.97%	39.35%	71.32%	0.3566
1995	21.81%	28.35%	50.16%	0.2508
1996	22.74%	21.28%	44.02%	0.2201

Notes: (a) Unit NER calculated based on net load factor (NLF) for each unit relative to NOx emission rate from CEM:

Unit 1993 NLF x 1/1995&96 NLF x 1995&96 NER

Average NER calculated based on relative capacity factor:

$[\text{Unit 1 (NER} \times \text{CF)} + \text{Unit 2 (NER} \times \text{CF)}] / [\text{Unit 1 CF} + \text{Unit 2 CF}]$

Calculation of 1993 & 1994 NOx CEM Using Regression Analysis

Regression Equation	$Y = mx + b$		
	$\text{NOx} = 0.53 (\text{NLF}) - 0.00282$		
	NLF	Unweighted NOx (lb/mmBtu)	Capacity Factor
1993 Unit 1	55.03%	0.289	29.99%
1994 Unit 1	51.01%	0.267	31.97%
1993 Unit 2	59.54%	0.313	39.11%
1994 Unit 2	58.51%	0.307	39.35%


Average NOx: 0.294

Weighted NOx: 0.296

Note: weighted NOx based on capacity factor (i.e., total fuel usage)

Calculation of the Difference Between Regression and Actual Data

	NLF	Regression (a)	Actual (a)	Difference (a)
1995 Unit 1	42.30%	0.221	0.207	0.0142
1996 Unit 1	41.54%	0.217	0.223	-0.0058
1995 Unit 2	47.64%	0.250	0.242	0.0075
1996 Unit 2	45.09%	0.236	0.252	-0.0160
Average:		0.231	0.231	0.011
Std. Dev.		0.013	0.017	
Average Diff.		4.71%		





RTP ENVIRONMENTAL ASSOCIATES INC.®

AIR · WATER · SOLID WASTE CONSULTANTS

239 U.S. Highway 22 East
Green Brook, New Jersey 08812-1909
(rtpnj@rtp-environmental.com)

(732) 968-9600
Fax: (732) 968-9603

April 8, 1998

Mr. Clair Fancy
Florida Department of Environmental Protection
Bureau of Air Regulation
111 South Magnolia, Suite 4
Tallahassee, Florida 32301

Dear Mr. Fancy:

This letter is in response to the materials you faxed us on April 3, 1998, namely the January 22nd and January 23rd memos (copies attached) from Ken Kosky concerning the historical NO_x emissions from the Manatee County FP&L plant. As discussed previously with the agency and in our testimony, we still believe that the representative period that should be used to determine the historical actual emissions for the proposed Orimulsion® project would be the two-year period which precedes the particular date and which is representative of normal source operation. Due to the delay in the application process, this period should be 1996 and 1997. This requirement is defined in Rule 62-212.200(2)a F.A.C., as well as 40 CFR 52.21(b)21(ii). As noted in the regulation, "*The Administrator shall allow the use of a different time period upon a determination that it is more representative of normal source operation.*" No demonstration has been made which defines a different time period as more representative of normal source operations. In fact, in the original Site Certification/PSD application (SCA/PSD), the applicant chose to utilize fuel use data up through the end of 1994, using pro-rated fuel consumption data for the second half of 1994, as actual data was not yet available. This resulted in a more favorable determination (i.e., higher historical actual emissions) due to the increased fuel usage in the 1993-1994 period versus prior years. This approach confirms the use of the most recent two-year period.

As noted in the January 23, 1998 memo from Mr. Kosky, the NO_x emission rate for the 1995-1996 period, and as indicated in our testimony for the 1996-1997 period, was approximately 0.23 lbs/MMBTU, which when using the 1993-1994 average fuel usage/heat input would result in a calculation of 5621 tons of NO_x emitted per year. As noted in our testimony, the CEM data from 1996 and 1997 would yield a number less than 5500 tons per year. As stated above, due to the lack of any representations made that the pre-steam atomization operations represent current normal operations, we believe the Florida and federal rules require that the representative period be determined based on emissions associated with current normal operations which includes the steam atomization system.

RE: FP&L Manatee County Plant
 April 8, 1998
 Page 2

Further, in our review of the January 23, 1998 memo (which corrects the January 22, 1998 data), there are several important points to note, namely:

1. The data, as presented, indicates a PSD significant emissions increase for NO_x.
2. The analysis contains emissions for two years for Unit 2 in excess of the permit limits. This cannot be used in calculating historical actuals, as values up to but not over the permit limit are allowed to be used in this calculation.
3. The analysis is based on the assumption that there exists a linear relationship between the NO_x emission rate and the net load factor on a long-term basis. We concur that a relationship does exist between these two parameters, however there is no data to indicate that it is linear for large oil-fired units. Literature review indicates that the emission rate may be anywhere from 0.5 to 1% for a percentage of net load factor (see attached AP-40 and AP-42 sections). Additionally, the linear relationship that was established based on the 1995-1996 data was established with the steam atomization system in place. There is no data available to support that this relationship would be identical to that during the period when the Units were operating with the high-pressure atomization as opposed to steam atomization systems.
4. The calculations presented still contain mathematical errors. It is unclear how the average net load factors were calculated. They do not appear to match the data presented.
5. The statistics used (linear regression) are inappropriate for this data set and exhibit poor correlation.

Issue 1:

Regarding issue number 1, if you calculate the average NO_x emission rate for 1993 and 1994 using the data presented, results are as follows:

1993 Average	0.302	
1994 Average	<u>0.289</u>	Average = 0.296
	0.591	

$$0.296 \text{ lbs/MMBTU} \times 48,785,409 \text{ MMBTU} \times \frac{1 \text{ ton}}{2000 \text{ lbs}} = 7220 \text{ tons per year}$$

This would be a 98 ton per year increase, which is greater than the 40 ton per year PSD significance level.

RE: FP&L Manatee County Plant
April 8, 1998
Page 3

Issue 2:

Regarding the second issue, if the data for Unit 2 for 1993 and 1994 are reduced to the allowable levels of 0.30. The averages change as follows:

$$\begin{array}{rcl} 1993 \text{ Average} & 0.292 & \\ 1994 \text{ Average} & \underline{0.283} & \\ & 0.575 & \end{array} \qquad \text{Average} = 0.288$$

$$0.288 \text{ lbs/MMBTU} \times 48,785,409 \text{ MMBTU} \times \frac{1 \text{ ton}}{2000} = 7025 \text{ tons}$$

This yields a 293 ton per year increase, which again exceeds the 40 ton per year PSD significance level.

Issue 3:

In addition to the references cited above concerning the linear relationship of NO_x emission rates and net load factors, the attached stack test data (ten separate three hours tests) clearly indicates that this relationship cannot be linear throughout the normal range of operations. In fact, the relationship developed in the January 23, 1998 memo indicates that the NO_x emissions should be greater than the permit limit of 0.30 lbs/MMBTU whenever the units operate at loads higher than 56%. Additionally, the NO_x CEM data graph attached to the January 22, 1998 memo shows significant variability in NO_x emissions. It is unlikely that load followed these significant swings in NO_x emissions in a direct linear relationship.

In the rebuttal testimony provided by Mr. Kosky, he indicated that the stack test data was not representative of source operation. This statement is remarkable, in that annual compliance tests form the linchpin of the state program for determining that a source is in compliance at conditions representative of its maximum operations. Both the applicant and FDEP utilized individual stack test data for particulate matter (PM) in the recent application, and also used the 1993-1994 stack test data for NO_x and PM for calculating historical actuals in the original SCA/PSD application. To respond to the criticism that the stack tests represent a "snapshot" in time and may not be representative of normal operations of the source, we have obtained an additional eight stack tests that were available from the District Office files. Attached is a table of the results of these twelve three-hour tests, all of which indicate that the representative source operation, even prior to the steam atomization system, would yield a NO_x level below 0.30 lbs/MMBTU.

Issue 4:

All of the averages presented for the net load factor contain minor errors. The calculation for Unit 2 1993 and 1994 NO_x emission rates using the data in the table and the formula in

RE: FP&L Manatee County Plant
 April 8, 1998
 Page 4

footnote (a) are in error in favor of the applicant (0.310 vs. **0.317** and 0.305 vs. **0.312**, underlined values are the calculated numbers using the data in the table and the bold numbers are the values presented in the table). The capacity factor numbers presented in the January 23, 1998 memo vary from those provided by FP&L in the response to FDEP comments on the original SCA/PSD application (Table DEP-B3-2 attached).

Capacity Factors

	<u>Table DEP-B3-2</u>		<u>Kosky 1/23/98 Memo</u>	
	<u>Unit 1</u>	<u>Unit 2</u>	<u>Unit 1</u>	<u>Unit 2</u>
1993	27.29%	35.61%	29.99%	39.11%
1994	29.53%	35.91%	31.97%	39.35%

Issue 5:

I have attached a graph which shows the four data points used in the linear regression in the Kosky memo, and a line for the analyses presented in the January 23, 1998 memo, and a second line based off the four data points plus the twelve stack test points. The difference clearly demonstrates that a significantly lower value would be obtained for the NO_x emission rate/net load factor even assuming a linear relationship exists for these units. The correlation coefficient for the Kosky data is 0.544 and for the full data 0.698. Correlation coefficients typically exceed 0.9 for data that exhibit a consistent relationship. The standard error in the first coefficient for the Kosky data is 0.343. If the absolute value of the correlation coefficient is an order of magnitude larger than the standard error in the first coefficient, then you can be sure that the linear regression is significant (Principals and Procedures of Statistics, Steel & Torrie). The data passes a "t" test only at the 75% confidence level. Thus, the regression analysis proves that there is a poor fit for the data and little confidence in applying the predicted linear regression to predict 1993-1994 emissions based on net loads which were outside the range of data analyzed.

Including the 1989-1994 stack tests in the linear regression analysis gives the second line shown on the attached figure. The correlation coefficient for the stack test and CEM data is 0.70, primarily due to the larger number of data points, and the standard error in the first coefficient of 0.02 means that the correlation is significant at greater than the 99.9% confidence level. This line predicts average NO_x emissions of 0.244 lbs/MMBTU for 1993-1994, or 5952 tons per year, yielding a future increase of 1366 tons per year.

Therefore, it is obvious from the applicant's own data that the project is PSD significant for NO_x and should undergo full PSD review for this pollutant including BACT analyses. It is


RE: FP&L Manatee County Plant
April 8, 1998
Page 5

important, especially for a controversial project, that the process be followed correctly. This allows full public input and review of the application, as well as the agency's decision process. Possible changes that might occur through a full BACT review are differences in the emission rate as well as possible changes in the control technology. It is not possible at this time to accurately predict the conclusion of the process without performing the required analyses.

I hope the above proves useful in your review of the project. Should you have any questions concerning our analyses, please feel free to contact me at (732) 968-9600.

Sincerely,

RTP ENVIRONMENTAL ASSOCIATES, INC.®



Donald F. Elias
Principal

DFE/mpj

cc: L. Curtin, Esq.
B. Beals
G. Worley
W. Corbin
M. Hober
G. McCutchen
Proj. File: HKOR



Department of Environmental Protection

Lawton Chiles
Governor

Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Virginia B. Wetherell
Secretary

FAX TRANSMITTAL SHEET

TO: Don Elias

DATE: 4-3-98

FAX
PHONE: 732/968-9603

TOTAL NUMBER OF PAGES, INCLUDING COVER PAGE: 7

FROM: Clair Fancy

DIVISION OF AIR RESOURCES MANAGEMENT

COMMENTS:

PHONE: 850/488-1344

FAX NUMBER: 850 /922-6979

If there are any problems with this fax transmittal, please call the above phone number.

Memorandum

January 22, 1998

To: Clair Fancy, P.E., FDEP

From: Ken Kosky, P.E., Golder Associates

RE: Historical NOx Emissions from Manatee Plant

Dear Clair:

Please find attached my analysis of the CEM, Net Load Factor (NLF) and Capacity Factor (CF) data from the Manatee Plant during 1995 and 1996. The NLF is the load that the unit is operating when it is running. As shown from these data 1993 and 1994 are quite different. An analysis of the CEM data clearly indicate a relationship of NLF and NOx emissions. This is as expected since higher loads produce higher NOx emissions. Using a direct linear relationship between NLF and NOx emissions (top table), NOx emissions for each unit during 1993 and 1994 were calculated. As shown the calculated NOx emission rate is 0.30 lb/mmBtu. The other method used was the actual regression equation that was developed from the CEM and NLF data. The resulting average NOx emission is also 0.3 lb/mmBtu. Given that the steam atomization provides better combustion control and therefore NOx, the relationships are likely to produce lower NOx emissions than what actually happened. I concluded back in 1994, and confirmed by an analysis of the CEM data, that using a single stack test for pollutants produced through combustion processes (i.e., NOx and PM) is not appropriate. Therefore the 7,318 tons/year is an appropriate emission.

I have also included a chart of the daily, 30-day rolling and annual NOx emissions from one of the Manatee units. Note that daily emissions frequently exceed the 0.3 and include considerable variability. Such variability alone make the use of a single test questionable. I totally agreed with your assessment in the development of the Title V process that fees which were to be based on actual emissions cannot be based on a single test.

Calculation of NOx Emission Rate Using CEM and Net Load Factor

Net Load Factor (NLF)	Unit 1	Unit 2	Average	
1993	55.03%	59.54%	57.49%	
1994	51.01%	58.51%	54.89%	56.19%
1995	42.30%	47.64%	45.16%	
1996	41.54%	45.09%	43.18%	44.17%
1995&96	41.92%	46.37%	44.17%	

NOx Emission Rates (NER) in lb/mmBtu

	Unit 1	Unit 2	Average	1993/94
1993(a)	0.282	0.317	0.302	
1994(a)	0.262	0.312	0.289	0.30
1995	0.207	0.242	0.227	
1996	0.223	0.252	0.237	0.23
1995&96	0.215	0.247		

Capacity Factor (CF)	Unit 1	Unit 2	Total	
1993	29.99%	39.11%	69.10%	0.3455
1994	31.97%	39.35%	71.32%	0.3566
1995	21.81%	28.35%	50.18%	0.2508
1996	22.74%	21.28%	44.02%	0.2201

Notes: (a) Unit NER calculated based on net load factor (NLF) for each unit relative to NOx emission rate from CEM:
 Unit 1993 NLF x 1/1995&96 NLF x 1995&96 NER
 Average NER calculated based on relative capacity factor
 $[\text{Unit 1}(\text{NER} \times \text{CF}) + \text{Unit 2}(\text{NER} \times \text{CF})] / [\text{Unit 1 CF} + \text{Unit 2 CF}]$

Calculation of 1993 & 1994 NOx CEM Using Regression Analysis


Regression
Equation

$$Y = mx + b$$

$$\text{NOx} = 0.53 (\text{NLF}) - 0.00282$$

	NLF	NOx (lb/mmBtu)
1993 Unit 1	55.03%	0.294 .289
1994 Unit 1	51.01%	0.273 .267
1993 Unit 2	59.54%	0.318 .313
1994 Unit 2	58.51%	0.313 .307
Average:		0.300 .294

BEST AVAILABLE COPY
Manatee Plant Unit 1 NOx Data
July 1996 to July 1997



Memorandum

January 23, 1998

To: Clair Fancy, P.E., FDEP

From: Ken Kosky, P.E., Golder Associates

RE: Historical NOx Emissions from Manatee Plant

Dear Clair:

Attached is an updated prediction of NOx emission levels for 1993 and 1994 that includes the weighted average of NOx emissions based on the capacity factor (i.e., fuel usage). As shown, the predicted NOx level using the regression equation for 1993 and 1994 is 0.296 lb/mmBtu. This prediction is conservatively low, given the installation of steam atomization in 1995 to control the combustion process. This had the effect of being able to lower NOx levels in 1995 and 1996 relative to high pressure atomization used prior to 1995. Also included, is a comparison between the difference in predicted and actual concentrations. As shown the lb/mmBtu difference (last column) is quite small and the average difference is less than 5% (see 4.71%: 0.011 divided by 0.231). This is quite good given the limited data points used in the predictions.

I have also included a graphic of the historical NOx emission for the Manatee Plant over 19 years (1978 through 1996). The 19 year average is 6,970 tons/year. As shown in the figure, there have been years that the NOx was above and below the 1993 and 1994 levels.

Please call if you have any questions.

Ken

Calculation of NOx Emission Rate Using CEM and Net Load Factor

Net Load Factor (NLF)	Unit 1	Unit 2	Average	
1993	55.03%	59.54%	57.49%	
1994	51.01%	58.51%	54.89%	56.19%
1995	42.30%	47.64%	45.16%	
1996	41.54%	45.09%	43.18%	44.17%
1995&96	41.92%	46.37%	44.17%	

NOx Emission Rates (NER) in lb/mmBtu	Unit 1	Unit 2	Average	1993/94
1993(a)	0.282	0.317	0.302	
1994(a)	0.262	0.312	0.289	0.30
1995	0.207	0.242	0.227	
1996	0.223	0.252	0.237	0.23
1995&96	0.215	0.247		

Capacity Factor (CF)	Unit 1	Unit 2	Total	
1993	29.99%	39.11%	69.10%	0.3455
1994	31.97%	39.35%	71.32%	0.3566
1995	21.81%	28.35%	50.16%	0.2508
1996	22.74%	21.28%	44.02%	0.2201

Notes: (a) Unit NER calculated based on net load factor (NLF) for each unit relative to NOx emission rate from CEM:
 Unit 1993 NLF x 1/1995&96 NLF x 1995&96 NER
 Average NER calculated based on relative capacity factor:

$$[\text{Unit 1 (NER x CF)} + \text{Unit 2 (NER x CF)}] / [\text{Unit 1 CF} + \text{Unit 2 CF}]$$

Calculation of 1993 & 1994 NOx CEM Using Regression Analysis

Regression
Equation

$$Y = mx + b$$

$$\text{NOx} = 0.53 (\text{NLF}) - 0.00282$$

	NLF	Unweighted NOx (lb/mmBtu)	Capacity Factor
1993 Unit 1	55.03%	0.289	29.99%
1994 Unit 1	51.01%	0.267	31.97%
1993 Unit 2	59.54%	0.313	39.11%
1994 Unit 2	58.51%	0.307	39.35%

Average NOx: 0.294


Weighted NOx: 0.286

Note: weighted NOx based on capacity factor (i.e., total fuel usage)

Calculation of the Difference Between Regression and Actual Data

	NLF	Regression (a)	Actual (a)	Difference (a)
1995 Unit 1	42.30%	0.221	0.207	0.0142
1996 Unit 1	41.54%	0.217	0.223	-0.0058
1995 Unit 2	47.64%	0.250	0.242	0.0075
1996 Unit 2	45.09%	0.236	0.252	-0.0160
Average:		0.231	0.231	0.011
Std. Dev.		0.013	0.017	
Average Diff.		4.71%		

Historical NOx Emissions
FPL Manatee Plant (Units 1 and 2)



Air Pollution Engineering Manual



AIR & WASTE MANAGEMENT
ASSOCIATION

•
SINCE 1907

Edited by
Anthony J. Buonicore
Wayne T. Davis



VAN NOSTRAND REINHOLD
New York

recirculation, staged combustion, or some combination thereof, may result in NO_x reductions of 5–60%. In Japan, however, selective catalytic reduction technology is more common for oil-fired-boiler NO_x control.³⁰

Load reduction can likewise decrease NO_x production. Nitrogen oxide emissions may be reduced from 0.5% to 1% for each percentage reduction in load from full-load operation. It should be noted that most of these variables, with the exception of excess air, influence the NO_x emissions only of large oil-fired boilers. Limited excess air firing is possible in many small boilers, but the resulting NO_x reductions are not nearly as significant.

One U.S. utility noted, in a study, that the particulate emissions tended to increase with NO_x controls. Further studies have been planned and emphasis is being placed on improving atomizer design and on staging of air to reduce NO_x without increasing the particulate emissions.

Retrofit capital costs for installing LNB and OFA systems in oil-fired boilers are estimated to be \$20 to \$40 per kilowatt, based on 1989 estimates.³⁰

References

1. W. S. Smith, *Atmospheric Emissions from Fuel Oil Combustion: An Inventory Guide*, 999-AP-2, U.S. Environmental Protection Agency, Washington, DC, 1962.
2. *Air Pollution Engineering Manual*, J. A. Danielson, Ed.; 2nd ed., AP-40, U.S. Environmental Protection Agency, Research Triangle Park, NC, 1973 (out of print).
3. A. Levy, et al., "A field investigation of emissions from fuel oil combustion for space heating," *API Bulletin 3099*, Battelle Columbus Laboratories, Columbus, OH, 1971.
4. R. E. Barrett, et al., *Field Investigation of Emissions from Combustion for Space Heating*, EPA-R2-73-084a, U.S. Environmental Protection Agency, Research Triangle Park, NC, 1973.
5. G. A. Cato, et al., *Field Testing: Application of Combustion Modifications to Control Pollutant Emissions from Industrial Boilers—Phase I*, EPA-650/2-74-078a, U.S. Environmental Protection Agency, Washington, DC, 1974.
6. G. A. Cato, et al., *Field Testing: Application of Combustion Modifications to Control Pollutant Emissions from Industrial Boilers—Phase II*, EPA-600/2-76-086a, U.S. Environmental Protection Agency, Washington, DC, 1976.
7. *Particulate Emission Control Systems for Oil Fired Boilers*, EPA-450/3-74-063, U.S. Environmental Protection Agency, Research Triangle Park, NC, 1974.
8. W. Bartok, et al., *Systematic Field Study of NO_x Emission Control Methods for Utility Boilers*, APTD-1163, U.S. Environmental Protection Agency, Research Triangle Park, NC, 1971.
9. A. R. Crawford et al., *Field Testing: Application of Combustion Modifications to Control NO_x Emissions from Utility Boilers*, EPA-650/2-74-066, U.S. Environmental Protection Agency, Washington, DC, 1974.
10. J. F. Deffner et al., "Evaluation of Gulf Econojet equipment with respect to air conservation," Report No. 731RC044, Gulf Research and Development Co., Pittsburgh, PA, December 18, 1972.
11. C. E. Blakeslee and H. E. Burbach, "Controlling NO_x emission from steam generators," *J. APCA*, 23:37–42 (1973).
12. C. W. Siegmund, "Will desulfurized fuel oils help?" *ASHRAE J.*, 11:29 (1969).
13. F. A. Govan et al., "Relationships of particulate emissions versus partial to full load operations for utility-sized boilers," *Proceedings of Third Annual Industrial Air Pollution Control Conference*, Knoxville, TN, 1973.
14. R. E. Hall et al., *A Study of Air Pollutant Emissions from Residential Heating Systems*, EPA-650/2-74-003, U.S. Environmental Protection Agency, Washington, DC, 1974.
15. "Flue gas desulfurization: Installations and operations," PB 257721, National Technical Information Service, Springfield, VA, 1974.
16. *Proceedings: Flue Gas Desulfurization Symposium—1973*, EPA-650/2-73-038, U.S. Environmental Protection Agency, Washington, DC, 1973.
17. R. J. Milligan et al., *Review of NO_x Emission Factors for Stationary Fossil Fuel Combustion Sources*, EPA-450/4-79-021, U.S. Environmental Protection Agency, Research Triangle Park, NC, 1979.
18. N. F. Suprenant et al., *Emissions Assessment of Conventional Stationary Combustion Systems, Vol. I: Gas and Oil Fired Residential Heating Sources*, EPA-600/7-79-029b, U.S. Environmental Protection Agency, Washington, DC, 1979.
19. C. C. Shih et al., *Emissions Assessment of Conventional Stationary Combustion Systems, Vol. II: External Combustion Sources for Electricity Generation*, EPA Contract No. 68-02-2197, TRW, Inc., Redondo Beach, CA, 1980.
20. N. F. Suprenant et al., *Emissions Assessment of Conventional Stationary Combustion Systems, Vol. IV: Commercial Institutional Combustion Sources*, EPA Contract No. 68-02-2197, GCA Corp., Bedford, MA, 1980.
21. N. F. Suprenant et al., *Emissions Assessment of Conventional Stationary Combustion Systems, Vol. V: Industrial Combustion Sources*, EPA Contract No. 68-02-2197, GCA Corp., Bedford, MA, 1980.
22. *Fossil Fuel Fired Industrial Boilers—Background Information for Proposed Standards (Draft EIS)*, Office of Air Quality Planning and Standards, U.S. Environmental Protection Agency, Research Triangle Park, NC, 1980.
23. K. J. Lim et al., *Technology Assessment Report for Industrial Boiler Applications: NO_x Combustion Modification*, EPA-600/7-79-178f, U.S. Environmental Protection Agency, Washington, DC, 1979.
24. *Emission Test Report*, Docket No. OAQPS-78-1, Category II-I-257 through 265, Office of Air Quality Planning and Standards, U.S. Environmental Protection Agency, Research Triangle Park, NC, 1972 through 1974.
25. *Primary Sulfate Emission from Coal and Oil Combustion*, EPA Contract No. 68-02-3138, TRW, Inc., Redondo Beach, CA, 1980.
26. C. Leavitt et al., *Environmental Assessment of an Oil Fired Controlled Utility Boiler*, EPA-600/7-80-087, U.S. Environmental Protection Agency, Washington, DC, 1980.
27. W. A. Carter and R. J. Tidona, *Thirty-day Field Tests of Industrial Boilers: Site 2—Residual-Oil-Fired Boiler*, EPA-600/7-80-085b, U.S. Environmental Protection Agency, Washington, DC, 1980.
28. G. R. Offen et al., *Control of Particulate Matter from Oil Burners and Boilers*, EPA-450/3-76-005, U.S. Environmental Protection Agency, Research Triangle Park, NC, 1976.

AP-42
FIFTH EDITION
JANUARY 1995

COMPILATION OF AIR POLLUTANT EMISSION FACTORS

VOLUME I: STATIONARY POINT AND AREA SOURCES

Office Of Air Quality Planning And Standards
Office Of Air And Radiation
U. S. Environmental Protection Agency
Research Triangle Park, NC 27711

January 1995

combustion (SC), reduced air preheat (RAP), low NO_x burners (LNBs), or some combination thereof may result in NO_x reductions of 5 to 60 percent. Load reduction (LR) can likewise decrease NO_x production. Nitrogen oxides emissions may be reduced from 0.5 to 1 percent for each percentage reduction in load from full load operation. It should be noted that most of these variables, with the exception of excess air, influence the NO_x emissions only of large oil fired boilers. Low excess air-firing is possible in many small boilers, but the resulting NO_x reductions are less significant.

Recent N₂O emissions data indicate that direct N₂O emissions from oil combustion units are considerably below the measurements made prior to 1988. Nevertheless, the N₂O formation and reaction mechanisms are still not well understood or well characterized. Additional sampling and research is needed to fully characterize N₂O emissions and to understand the N₂O formation mechanism. Emissions can vary widely from unit to unit, or even from the same unit at different operating conditions. It has been shown in some cases that N₂O increases with decreasing boiler temperature. For this update, average emission factors based on reported test data have been developed for conventional oil combustion systems. These factors are presented in Table 1.3-9.

Table 1.3-9 (Metric And English Units). EMISSION FACTORS FOR NITROUS OXIDE (N₂O), POLYCYCLIC ORGANIC MATTER (POM), AND FORMALDEHYDE (HCOH) FROM FUEL OIL COMBUSTION

EMISSION FACTOR RATING: E

Firing Configuration (SCC) ^a	Emission Factor, kg/10 ³ L (lb/10 ¹² Btu)		
	N ₂ O ^b	POM ^c	HCOH ^c
Utility/industrial/commercial boilers			
No. 6 oil fired (1-01-004-01, 1-02-004-01, 1-03-004-01)	0.013 (0.11)	3.2-3.6 (7.4-8.4) ^d	69-174 (161-405)
Distillate oil fired (1-01-005-01, 1-02-005-01, 1-03-005-01)	0.013 (0.11)	9.7 (22) ^e	100-174 (233-405)
Residential furnaces (No SCC)	0.006 (0.05)	ND	ND

^a SCC = Source Classification Code. ND = no data.

^b References 28-29.

^c References 16-19.

^d Particulate and gaseous POM.

^e Particulate POM only.

The new source performance standards (NSPS) for PM, SO₂, and NO_x emissions from residual oil combustion in fossil fuel-fired boilers are shown in Table 1.3-10.

1.3.2.4 Carbon Monoxide Emissions¹⁶⁻¹⁹ -

The rate of CO emissions from combustion sources depends on the oxidation efficiency of the fuel. By controlling the combustion process carefully, CO emissions can be minimized. Thus if a unit is operated improperly or not well maintained, the resulting concentrations of CO (as well as organic compounds) may increase by several orders of magnitude. Smaller boilers, heaters, and furnaces tend to emit more of these pollutants than larger combustors. This is because smaller units

**SUMMARY OF NO_x STACK TEST DATA
(1989-1994)**

<u>Test Year</u>	<u>----- Unit 1 -----</u>			<u>----- Unit 2 -----</u>		
	<u>Test Date</u>	<u>lb/MMBtu</u>	<u>% Load</u>	<u>Test Date</u>	<u>lb/MMBtu</u>	<u>% Load</u>
1989	9/27/89	0.272	86%	1/11/89	0.274	86%
1990	6/27/90	0.259	89%	3/21/90	0.271	87%
1991	4/17/91	0.281	86%	7/17/91	0.271	89%
1992	7/15/92	0.295	86.5%	12/19/91	0.269	85.9%
1993	4/01/93	0.289	84.5%	4/22/93	0.289	83.6%
1994	5/12/94	0.284	86.9%	6/08/94	0.263	87.9%

13360/DEP/A11A13R3
01/15/98

Table DEP-B3-2. Existing Fuel Oil Usage at the FPL Manatee Plant (1993/1994) - Actual Fuel Use

Parameter	Values for FPL Units	
	Unit 1	Unit 2
Fuel Usage (bbls)		
1993	3,242,067	4,230,092
1994	3,508,117	4,265,164
Average	3,375,092	4,247,628
Maximum	11,877,957	11,877,957
Capacity Factor (a)		
1993	27.29%	35.61%
1994	29.53%	35.91%
Average	28.41%	35.76%
Sulfur Content:		
1993	0.973%	0.973%
1994	0.973%	0.976%

(a) Based on maximum heat input of 8,650 MMBtu/hr per unit and fuel oil with heat content and density of 18,300 Btu/lb and 8.3 lb/gal, respectively.

FPL MANATEE NO_x EMISSIONS

Linear Regression w/ least squares fit

